

AIR QUALITY PERMIT

Issued To: City of Billings Public Works Department – Permit #3827-01
Wastewater Treatment Plant Application Complete: 8/9/07
P.O, Box 30958 Preliminary Determination Issued: 8/22/07
Billings, MT 59111 Department's Decision Issued: 9/07/07
Permit Final: 09/25/07
AFS #111-0037

An air quality permit, with conditions, is hereby granted to the City of Billings Public Works Department – Wastewater Treatment Plant (Billings WWTP), pursuant to Sections 75-2-204 and 211 of the Montana Code Annotated (MCA), as amended, and Administrative Rules of Montana (ARM) 17.8.740, *et seq.*, as amended, for the following:

SECTION I: Permitted Facilities

A. Plant Location

Billings WWTP owns and operates a municipal wastewater treatment plant located at 725 Highway 87 East in Billings, Montana. The legal description of the site is in the southeast ¼ of Section 27, Township 1 North, Range 26 East, in Yellowstone County, Montana. The facility incorporates a digester gas-fired internal combustion engine to produce electricity, an emergency/back-up industrial flare, various boilers, and associated equipment. A complete list of permitted equipment is contained in the permit analysis to this permit.

B. Current Permit Action

On August 9, 2007, the Montana Department of Environmental Quality (Department) received a complete application from the Billings WWTP for the modification of Permit #3827-00. Specifically, the current permit action modifies the previously established Best Available Control Technology (BACT)-determined oxides of nitrogen (NO_x) and carbon monoxide (CO) emission limits applicable to the Waukesha digester gas-fired engine under Permit #3827-00, re-evaluates the operational circumstances of the emergency back-up digester gas industrial safety flare, and analyzes all facility emitting units affected by an increased facility-wide digester gas throughput value from the previously assumed 63 million standard cubic feet per year (MMScf/yr) to an actual capacity of 76 MMScf/yr. The affected emitting units include the Waukesha digester gas-fired engine, IBR natural gas/digester gas-fired boiler, and the emergency back-up digester gas industrial safety flare. A more complete analysis of the current permit action is contained in Section I.D of the Permit Analysis to this Permit.

SECTION II: Conditions and Limitations

A. Emission Limitations and Operational Conditions

1. The 658 brake horsepower (bhp) capacity Waukesha rich-burn internal combustion engine shall combust only digester gas collected from the wastewater treatment process (ARM 17.8.749 and ARM 17.8.752).

2. Emissions from the 658-bhp capacity Waukesha digester gas-fired rich-burn internal combustion engine shall be controlled by good combustion practices and proper operation and maintenance. Emissions from the unit shall not exceed the following (ARM 17.8.752):
 - a. NO_x: 12.2 pounds per hour (lb/hr)
 - b. CO: 6.0 lb/hr
 - c. Sulfur dioxide (SO₂): 6.8 lb/hr
3. The Cleaver Brooks and American Standard boilers shall combust pipeline quality natural gas only (ARM 17.8.752).
4. The IBR boiler may combust pipeline quality natural gas and/or digester gas only (ARM 17.8.752).
5. Emissions from the 16.74 million British thermal unit per hour (MMBtu/hr) heat input capacity Cleaver Brooks natural gas-fired boiler shall be controlled by good combustion practices and proper operation and maintenance. Emissions from the unit shall not exceed the following (ARM 17.8.752):
 - a. NO_x: 1.67 lb/hr
 - b. CO: 1.41 lb/hr
6. The emergency/back-up digester gas industrial safety flare shall be used, as necessary, to destroy any excess digester gas not used by either the Waukesha digester gas-fired engine and/or the IBR natural gas/digester gas fired boiler (ARM 17.8.749 and ARM 17.8.752).
7. The Cummins emergency diesel generator shall be limited to 500 hours of operation during any rolling 12-month time period (ARM 17.8.749).
8. Billings WWTP shall not cause or authorize emissions to be discharged into the outdoor atmosphere from any sources installed after November 23, 1968, that exhibit an opacity of 20% or greater averaged over 6 consecutive minutes (ARM 17.8.304 and ARM 17.8.752).
9. Billings WWTP shall not cause or authorize the use of any street, road, or parking lot without taking reasonable precautions to control emissions of airborne particulate matter (ARM 17.8.308).
10. Billings WWTP shall treat all unpaved portions of the haul roads, access roads, parking lots, or general plant area with water and/or chemical dust suppressant as necessary to maintain compliance with the reasonable precautions limitation (ARM 17.8.749).

B. Testing Requirements

1. Billings WWTP shall initially test the Waukesha digester gas-fired rich-burn engine for NO_x and CO emissions, concurrently, and demonstrate compliance with the NO_x and CO emission limits within 90 days of issuance of Permit #3827-01. After the initial source test, additional testing to monitor continued compliance with the NO_x and CO emission limits shall be conducted as required by the Department (ARM 17.8.105 and ARM 17.8.749).

2. All compliance source tests shall conform to the requirements of the Montana Source Test Protocol and Procedures Manual (ARM 17.8.106).
3. The Department may require further testing (ARM 17.8.105).

C. Operational Reporting Requirements

1. Billings WWTP shall supply the Department with annual production information for all emission points, as required by the Department in the annual emission inventory request. The request will include, but is not limited to, all sources of emissions identified in the emission inventory contained in the permit analysis.

Production information shall be gathered on a calendar-year basis and submitted to the Department by the date required in the emission inventory request. Information shall be in the units required by the Department. This information may be used to calculate operating fees, based on actual emissions from the facility, and/or to verify compliance with permit limitations (ARM 17.8.505).

2. Billings WWTP shall notify the Department of any construction or improvement project conducted pursuant to ARM 17.8.745, that would include a change in control equipment, stack height, stack diameter, stack flow, stack gas temperature, source location or fuel specifications, or would result in an increase in source capacity above its permitted operation or the addition of a new emission unit. The notice must be submitted to the Department, in writing, 10 days prior to start up or use of the proposed de minimis change, or as soon as reasonably practicable in the event of an unanticipated circumstance causing the de minimis change, and must include the information requested in ARM 17.8.745(1)(d) (ARM 17.8.745).
3. All records compiled in accordance with this permit must be maintained by Billings WWTP as a permanent business record for at least 5 years following the date of the measurement, must be available at the plant site for inspection by the Department, and must be submitted to the Department upon request (ARM 17.8.749).
4. Billings WWTP shall maintain an emergency/back-up digester gas industrial safety flare operations log to monitor compliance with the applicable operating conditions in Section II.A.6. The log shall contain, at a minimum, the initials of the documenting personnel and the fuel usage and run-times for the emergency/back-up digester gas industrial safety flare, the Waukesha digester gas-fired engine, and the IBR natural gas/digester gas-fired boiler. The information contained in the emergency/back-up digester gas industrial safety flare operations log shall be submitted to the Department upon request (ARM 17.8.749).
5. Billings WWTP shall document, by month, the hours of operation of the Cummins emergency diesel generator. By the 25th day of each month, Billings WWTP shall total the Cummins emergency diesel generator operating hours for the previous month. The monthly information will be used to verify compliance with the rolling 12-month operational limitation in Section II.A.7. The information for each of the previous months shall be submitted along with the annual emission inventory (ARM 17.8.749).

SECTION III: General Conditions

- A. Inspection – Billings WWTP shall allow the Department’s representatives access to the source at all reasonable times for the purpose of making inspections or surveys, collecting samples, obtaining data, auditing any monitoring equipment (CEMS, CERMS) or observing any monitoring or testing, and otherwise conducting all necessary functions related to this permit.

- B. Waiver – The permit and the terms, conditions, and matters stated herein shall be deemed accepted if Billings WWTP fails to appeal as indicated below.
- C. Compliance with Statutes and Regulations – Nothing in this permit shall be construed as relieving Billings WWTP of the responsibility for complying with any applicable federal or Montana statute, rule, or standard, except as specifically provided in ARM 17.8.740, *et seq.* (ARM 17.8.756).
- D. Enforcement – Violations of limitations, conditions and requirements contained herein may constitute grounds for permit revocation, penalties, or other enforcement action as specified in Section 75-2-401, *et seq.*, MCA.
- E. Appeals – Any person or persons jointly or severally adversely affected by the Department’s decision may request, within 15 days after the Department renders its decision, upon affidavit setting forth the grounds therefore, a hearing before the Board of Environmental Review (Board). A hearing shall be held under the provisions of the Montana Administrative Procedures Act. The filing of a request for a hearing does not stay the Department’s decision, unless the Board issues a stay upon receipt of a petition and a finding that a stay is appropriate under Section 75-2-211(11)(b), MCA. The issuance of a stay on a permit by the Board postpones the effective date of the Department’s decision until conclusion of the hearing and issuance of a final decision by the Board. If a stay is not issued by the Board, the Department’s decision on the application is final 16 days after the Department’s decision is made.
- F. Permit Inspection – As required by ARM 17.8.755, Inspection of Permit, a copy of the air quality permit shall be made available for inspection by the Department at the location of the source.
- G. Permit Fee – Pursuant to Section 75-2-220, MCA, as amended by the 1991 Legislature, failure to pay the annual operation fee by Billings WWTP may be grounds for revocation of this permit, as required by that section and rules adopted thereunder by the Board.

Permit Analysis
City of Billings Public Works Department – Wastewater Treatment Plant
Permit #3827-01

I. Introduction/Process Description

The City of Billings Public Works Department – Wastewater Treatment Plant (Billings WWTP) owns and operates a municipal wastewater treatment plant. The facility is located at 725 Highway 87 East in Billings, Montana. The legal description of the site is in the Southeast ¼ of Section 27, Township 1 North, Range 26 East, in Yellowstone County, Montana.

A. Permitted Equipment

The Billings WWTP owns and operates a Waukesha digester gas-fired rich-burn engine with a maximum rated design capacity of 658 brake horsepower (bhp); a Cleaver Brooks natural gas-fired boiler with a maximum heat input capacity of 16.74 million British thermal units per hour (MMBtu/hr); an American Standard natural gas-fired boiler with a heat input capacity of 2.20 MMBtu/hr; an IBR natural gas-fired boiler with a heat input capacity of 3.78 MMBtu/hr; an emergency back-up digester gas industrial safety flare; an emergency diesel generator with a maximum rated design capacity of 425 horsepower (Secondary Pump Station, Head Works, Blower Engine); and wastewater process tanks (Clarifiers, Aeration Basins).

B. Source Description

The Billings WWTP operates a Waukesha internal combustion engine that is fired with digester gas collected from the digesters at the waste-water treatment facility. Digesters are used during the treatment and processing of municipal wastewater. The digesters are covered tanks operated under anaerobic conditions (i.e., without oxygen). Although variable, the gas produced by the digesters is approximately 63% methane (CH₄) and 36% carbon dioxide (CO₂) with relatively low levels of hydrogen sulfide (H₂S) and nitrogen and trace level contaminants.

Billings WWTP collects the digester gas and uses it as fuel in the Waukesha engine to generate electricity. The Waukesha engine and associated co-generation equipment produces approximately 1.5 million kilowatt-hours of electricity annually (5-year average, 2000-2004). The electricity is used directly at the Billings WWTP facility and consequently reduces the demand for electricity from the power grid. Approximately 25% of the annual electricity demand for the Billings WWTP facility is supplied by the digester gas co-generation system.

C. Permit History

On August 22, 2006, the Billings WWTP was issued final **Permit #3827-00** for the operation of a 658-bhp Waukesha digester gas-fired rich-burn engine; a 16.74 MMBtu/hr capacity Cleaver Brooks natural gas-fired boiler; a 2.20 MMBtu/hr capacity American Standard natural gas-fired boiler; a 3.78 MMBtu/hr IBR natural gas or digester gas-fired boiler; an emergency back-up digester gas industrial safety flare; a 425-horsepower emergency diesel generator; and various wastewater process tanks.

D. Current Permit Action

On August 9, 2007, the Montana Department of Environmental Quality (Department) received a complete application from the Billings WWTP for the modification of Permit #3827-00. Specifically, the Billings WWTP proposed modification of the previous Best Available Control Technology (BACT)-determined oxides of nitrogen (NO_x) and carbon monoxide (CO) emission limits applicable to the Waukesha digester gas-fired engine. The initial Waukesha engine

BACT determinations for NO_x and CO emissions were established using published emission factors for the combustion of landfill gas because emissions data directly related to digester-gas combustion were not available at the time of initial permit development. Since issuance of Permit #3827-00, the Billings WWTP has conducted source testing for NO_x and CO demonstrating that the BACT limits established under Permit #3827-00 are not achievable on a consistent basis. A more complete analysis of the previous and current NO_x and CO BACT determinations for the affected unit and pollutants is contained in Section III of the Permit Analysis to this permit.

In addition, the initial application for Permit #3827-00 assumed a maximum facility digester gas throughput rate of 63 million standard cubic feet per year (MMScf/yr); however, since issuance of Permit #3827-00, the Billings WWTP has determined that this assumed digester gas throughput rate was underestimated and the actual capacity is 76 MMScf/yr. Therefore, the current permit action re-evaluates all emitting units affected by the increased digester gas throughput value including the Waukesha digester gas-fired rich-burn engine, the IBR natural gas/digester gas-fired boiler, and the emergency back-up digester gas industrial safety flare. The application for Permit #3827-00 assumed that the permitted emergency back-up digester gas industrial safety flare is only operational at times when the affected digester gas-fired units at the facility (Waukesha engine and IBR boiler) are not in operation. However, in practice, because the flare is an emission control strategy in and of itself, the emergency back-up digester gas industrial safety flare is operated on a relatively continuous basis, as necessary, to destroy any digester gas not used by either the Waukesha engine or IBR boiler. In light of this information, Section II.A.6 and Section II.C.4 of the permit have been modified to accurately reflect and regulate the emergency back-up digester gas industrial safety flare operations. **Permit #3827-01** replaces Permit #3827-00.

E. Additional Information

Additional information, such as applicable rules and regulations, BACT/Reasonably Available Control Technology (RACT) determinations, air quality impacts, and environmental assessments, is included in the analysis associated with each change to the permit.

II. Applicable Rules and Regulations

The following are partial explanations of some applicable rules and regulations that apply to the facility. The complete rules are stated in the Administrative Rules of Montana (ARM) and are available, upon request, from the Department. Upon request, the Department will provide references for location of complete copies of all applicable rules and regulations or copies where appropriate.

A. ARM 17.8, Subchapter 1 – General Provisions, including but not limited to:

1. ARM 17.8.101 Definitions. This rule includes a list of applicable definitions used in this chapter, unless indicated otherwise in a specific subchapter.
2. ARM 17.8.105 Testing Requirements. Any person or persons responsible for the emission of any air contaminant into the outdoor atmosphere shall, upon written request of the Department, provide the facilities and necessary equipment (including instruments and sensing devices) and shall conduct tests, emission or ambient, for such periods of time as may be necessary using methods approved by the Department.
3. ARM 17.8.106 Source Testing Protocol. The requirements of this rule apply to any emission source testing conducted by the Department, any source or other entity as required by any rule in this chapter, or any permit or order issued pursuant to this chapter, or the provisions of the Clean Air Act of Montana, 75-2-101, *et seq.*, Montana Code Annotated (MCA).

Billings WWTP shall comply with the requirements contained in the Montana Source Test Protocol and Procedures Manual, including, but not limited to, using the proper test methods and supplying the required reports. A copy of the Montana Source Test Protocol and Procedures Manual is available from the Department upon request.

4. ARM 17.8.110 Malfunctions. (2) The Department must be notified promptly by telephone whenever a malfunction occurs that can be expected to create emissions in excess of any applicable emission limitation or to continue for a period greater than 4 hours.
5. ARM 17.8.111 Circumvention. (1) No person shall cause or permit the installation or use of any device or any means that, without resulting in reduction of the total amount of air contaminant emitted, conceals or dilutes an emission of air contaminant that would otherwise violate an air pollution control regulation. (2) No equipment that may produce emissions shall be operated or maintained in such a manner as to create a public nuisance.

B. ARM 17.8, Subchapter 2 – Ambient Air Quality, including, but not limited to the following:

1. ARM 17.8.210 Ambient Air Quality Standards for Sulfur Dioxide
2. ARM 17.8.211 Ambient Air Quality Standards for Nitrogen Dioxide
3. ARM 17.8.212 Ambient Air Quality Standards for Carbon Monoxide
4. ARM 17.8.214 Ambient Air Quality Standards for Hydrogen Sulfide

Billings WWTP must maintain compliance with the applicable ambient air quality standards.

C. ARM 17.8, Subchapter 3 – Emission Standards, including, but not limited to:

1. ARM 17.8.304 Visible Air Contaminants. This rule requires that no person may cause or authorize emissions to be discharged into the outdoor atmosphere from any source installed after November 23, 1968, that exhibit an opacity of 20% or greater averaged over 6 consecutive minutes.
2. ARM 17.8.308 Particulate Matter, Airborne. (1) This rule requires an opacity limitation of less than 20% for all fugitive emission sources and that reasonable precautions be taken to control emissions of airborne particulate matter. (2) Under this rule, Billings WWTP shall not cause or authorize the use of any street, road, or parking lot without taking reasonable precautions to control emissions of airborne particulate matter.
3. ARM 17.8.309 Particulate Matter, Fuel Burning Equipment. This rule requires that no person shall cause, allow, or permit to be discharged into the atmosphere particulate matter caused by the combustion of fuel in excess of the amount determined by this rule.
4. ARM 17.8.310 Particulate Matter, Industrial Process. This rule requires that no person shall cause, allow, or permit to be discharged into the atmosphere particulate matter in excess of the amount set forth in this rule.
5. ARM 17.8.322 Sulfur Oxide Emissions--Sulfur in Fuel. This rule requires that no person shall burn liquid, solid, or gaseous fuel in excess of the amount set forth in this rule.
6. ARM 17.8.324 Hydrocarbon Emissions--Petroleum Products. (3) No person shall load or permit the loading of gasoline into any stationary tank with a capacity of 250 gallons or more from any tank truck or trailer, except through a permanent submerged fill pipe, unless such tank is equipped with a vapor loss control device as described in (1) of this rule.

ARM 17.8.340 Standard of Performance for New Stationary Sources and Emission Guidelines for Existing Sources. This rule incorporates, by reference, 40 CFR 60, Standards of Performance for New Stationary Sources (NSPS). This facility is not an NSPS affected source because it does not meet the definition of any NSPS subpart defined in 40 CFR Part 60.

D. ARM 17.8, Subchapter 5 – Air Quality Permit Application, Operation, and Open Burning Fees, including, but not limited to:

1. ARM 17.8.504 Air Quality Permit Application Fees. This rule requires that an applicant submit an air quality permit application fee concurrent with the submittal of an air quality permit application. A permit application is incomplete until the proper application fee is paid to the Department. Billings WWTP submitted the required permit application fee for the current permit action.
2. ARM 17.8.505 Air Quality Operation Fees. An annual air quality operation fee must, as a condition of continued operation, be submitted to the Department by each source of air contaminants holding an air quality permit (excluding an open burning permit) issued by the Department. The air quality operation fee is based on the actual or estimated actual amount of air pollutants emitted during the previous calendar year.

An air quality operation fee is separate and distinct from an air quality permit application fee. The annual assessment and collection of the air quality operation fee, described above, shall take place on a calendar-year basis. The Department may insert into any final permit issued after the effective date of these rules, such conditions as may be necessary to require the payment of an air quality operation fee on a calendar-year basis, including provisions that prorate the required fee amount.

E. ARM 17.8, Subchapter 7 – Permit, Construction, and Operation of Air Contaminant Sources, including, but not limited to:

1. ARM 17.8.740 Definitions. This rule is a list of applicable definitions used in this chapter, unless indicated otherwise in a specific subchapter.
2. ARM 17.8.743 Montana Air Quality Permits--When Required. This rule requires a person to obtain an air quality permit or permit alteration to construct, alter, or use any air contaminant sources that have the potential to emit (PTE) greater than 25 tons per year of any pollutant. Billings WWTP has a PTE greater than 25 tons per year of NO_x, CO, and SO₂; therefore, an air quality permit is required.
3. ARM 17.8.744 Montana Air Quality Permits--General Exclusions. This rule identifies the activities that are not subject to the Montana Air Quality Permit program.
4. ARM 17.8.745 Montana Air Quality Permits--Exclusion for De Minimis Changes. This rule identifies the de minimis changes at permitted facilities that do not require a permit under the Montana Air Quality Permit Program.
5. ARM 17.8.748 New or Modified Emitting Units--Permit Application Requirements. (1) This rule requires that a permit application be submitted prior to installation, alteration, or use of a source. Billings WWTP submitted the required permit application for the current permit action. (7) This rule requires that the applicant notify the public by means of legal publication in a newspaper of general circulation in the area affected by the application for a permit. Billings WWTP submitted an affidavit of publication of public notice for the July 19, 2007, issue of *The Billings Times*, a weekly newspaper of general circulation in the City of Billings in Yellowstone County, Montana, as proof of compliance with the public notice requirements.

6. ARM 17.8.749 Conditions for Issuance or Denial of Permit. This rule requires that the permits issued by the Department must authorize the construction and operation of the facility or emitting unit subject to the conditions in the permit and the requirements of this subchapter. This rule also requires that the permit must contain any conditions necessary to assure compliance with the Federal Clean Air Act (FCAA), the Clean Air Act of Montana, and rules adopted under those acts.
7. ARM 17.8.752 Emission Control Requirements. This rule requires a source to install the maximum air pollution control capability that is technically practicable and economically feasible, except that BACT shall be utilized. The required BACT analysis is included in Section III of this permit analysis.
8. ARM 17.8.755 Inspection of Permit. This rule requires that air quality permits shall be made available for inspection by the Department at the location of the source.
9. ARM 17.8.756 Compliance with Other Requirements. This rule states that nothing in the permit shall be construed as relieving Billings WWTP of the responsibility for complying with any applicable federal or Montana statute, rule, or standard, except as specifically provided in ARM 17.8.740, *et seq.*
10. ARM 17.8.759 Review of Permit Applications. This rule describes the Department's responsibilities for processing permit applications and making permit decisions on those permit applications that do not require the preparation of an environmental impact statement.
11. ARM 17.8.762 Duration of Permit. An air quality permit shall be valid until revoked or modified, as provided in this subchapter, except that a permit issued prior to construction of a new or altered source may contain a condition providing that the permit will expire unless construction is commenced within the time specified in the permit, which in no event may be less than 1 year after the permit is issued.
12. ARM 17.8.763 Revocation of Permit. An air quality permit may be revoked upon written request of the permittee, or for violations of any requirement of the Clean Air Act of Montana, rules adopted under the Clean Air Act of Montana, the FCAA, rules adopted under the FCAA, or any applicable requirement contained in the Montana State Implementation Plan (SIP).
13. ARM 17.8.764 Administrative Amendment to Permit. An air quality permit may be amended for changes in any applicable rules and standards adopted by the Board of Environmental Review (Board) or changed conditions of operation at a source or stack that do not result in an increase of emissions as a result of those changed conditions. The owner or operator of a facility may not increase the facility's emissions beyond permit limits unless the increase meets the criteria in ARM 17.8.745 for a de minimis change not requiring a permit, or unless the owner or operator applies for and receives another permit in accordance with ARM 17.8.748, ARM 17.8.749, ARM 17.8.752, ARM 17.8.755, and ARM 17.8.756, and with all applicable requirements in ARM Title 17, Chapter 8, Subchapters 8, 9, and 10.
14. ARM 17.8.765 Transfer of Permit. This rule states that an air quality permit may be transferred from one person to another if written notice of intent to transfer, including the names of the transferor and the transferee, is sent to the Department.

F. ARM 17.8, Subchapter 8 – Prevention of Significant Deterioration of Air Quality, including, but not limited to:

1. ARM 17.8.801 Definitions. This rule is a list of applicable definitions used in this subchapter.
2. ARM 17.8.818 Review of Major Stationary Sources and Major Modifications--Source Applicability and Exemptions. The requirements contained in ARM 17.8.819 through ARM 17.8.827 shall apply to any major stationary source and any major modification, with respect to each pollutant subject to regulation under the FCAA that it would emit, except as this subchapter would otherwise allow.

This facility is not a major stationary source because this facility is not a listed source and the facility's PTE is below 250 tons per year of any pollutant (excluding fugitive emissions).

G. ARM 17.8, Subchapter 12 – Operating Permit Program Applicability, including, but not limited to:

1. ARM 17.8.1201 Definitions. (23) Major Source under Section 7412 of the FCAA is defined as any source having:
 - a. PTE > 100 tons/year of any pollutant;
 - b. PTE > 10 tons/year of any one hazardous air pollutant (HAP), PTE > 25 tons/year of a combination of all HAPs, or lesser quantity as the Department may establish by rule; or
 - c. PTE > 70 tons/year of particulate matter with an aerodynamic diameter of 10 microns or less (PM₁₀) in a serious PM₁₀ nonattainment area.
2. ARM 17.8.1204 Air Quality Operating Permit Program. (1) Title V of the FCAA amendments of 1990 requires that all sources, as defined in ARM 17.8.1204(1), obtain a Title V Operating Permit. In reviewing and issuing Montana Air Quality Permit #3827-01 for the Billings WWTP, the following conclusions were made:
 - a. The facility's PTE is less than 100 tons/year for any pollutant.
 - b. The facility's PTE is less than 10 tons/year for any one HAP and less than 25 tons/year for all HAPs.
 - c. This source is not located in a serious PM₁₀ nonattainment area.
 - d. This facility is not subject to any current NSPS.
 - e. This facility is not subject to any current National Emission Standards for Hazardous Air Pollutants (NESHAP) standards.
 - f. This source is not a Title IV affected source, nor a solid waste combustion unit.
 - g. This source is not an EPA designated Title V source.

Based on these facts, the Department determined that Billings WWTP is a minor source of emissions as defined under Title V.

III. BACT Analysis and Determination

A BACT determination is required for each new or altered source. Billings WWTP shall install on the new or altered source the maximum air pollution control capability which is technically practicable and economically feasible, except that BACT shall be utilized. The following BACT analysis and determination evaluates NO_x and CO emissions from the existing 658-bhp capacity Waukesha digester gas-fired rich-burn engine and all regulated pollutants resulting from operation of the existing emergency/back-up digester gas-fired industrial safety flare and the IBR natural gas/digester gas fired boiler.

A. Introduction

The current permit action evaluates the appropriateness of the BACT determination for NO_x and CO emissions from the Waukesha digester gas-fired engine established under Permit #3827-00 and establishes current-day NO_x and CO BACT for the affected unit. In anticipation of upcoming testing requirements contained in Permit #3827-00, the Billings WWTP conducted preliminary source testing for NO_x, CO, and SO₂ emissions from the affected unit on April 18, 2007. The results of that preliminary source testing and the permitted allowable emission rate for the affected pollutants are contained in the following table.

Pollutant	Engine Performance Pounds Per Hour (lb/hr)	Emission Limit (Permit #3827-00) lb/hr
NO_x	6.1	1.1
CO	2.0	2.0
SO₂	4.8	6.8

As provided in the table above, the preliminary source testing showed that the engine would not be able to comply with the NO_x emission limit while the engine performed at the permitted limit for CO. During the public comment period for Permit #3827-00, in a letter dated July 31, 2006, Billings WWTP expressed concern regarding the engines ability to comply with the NO_x and CO emission rates deemed BACT under Permit #3827-00. The concern stemmed primarily from the fact that emissions information provided in the BACT analysis evaluated landfill gas emission characteristics, rather than digester gas characteristics, because emissions data directly related to digester-gas combustion were not available at the time of initial permit development. Both landfill gas (at approximately 55% methane (CH₄)) and digester gas (approximately 63% CH₄ at the Billings WWTP) will burn cooler than natural gas and therefore, in theory, generate less NO_x. However, with its higher CH₄ content, digester gas could be expected to produce more NO_x than the landfill gas analyzed under the BACT analysis conducted for Permit #3827-00. In addition, the Billings WWTP indicated concern in the ability of the engine to consistently meet the applicable NO_x and CO emission limits due to variability in digester gas methane content as well as changes in ambient temperature and pressure. In light of these concerns, and at the request of the Billings WWTP, the Department extended the required source testing schedule from a requirement to test within 180 days of permit issuance to a requirement to test within 365 days of permit issuance to afford Billings WWTP time to conduct pre-testing for the purpose of analyzing actual engine performance.

Based on the analysis provided in the application for Permit #3827-00, the Department believed that the BACT determined emission limits for NO_x and CO were achievable and thus the limits were permitted as BACT. However, due to the uncertainty surrounding the establishment of the affected BACT limits, the Department recognized the potential need for a permit modification if the BACT limits were deemed unachievable based on actual engine operating experience and performance. Prior to the source testing being conducted,

Waukesha-certified technicians evaluated and tuned the engine to ensure optimum performance during the source testing; therefore, the Department is confident that the engine performance, as it relates to NO_x and CO emissions, is not the result of inadequate maintenance or operating procedures. Further, after completion of the preliminary source testing, the Billings WWTP again consulted with Waukesha engineering staff to determine what factors might have contributed to the engines performance related to NO_x and CO emissions and to solicit information as to the emission rate(s) the affected engine could be expected to achieve on a consistent basis given the actual engine performance as demonstrated through preliminary source testing. Waukesha engine engineering staff indicated concern in the ability of the engine to consistently meet the applicable NO_x and CO emission limits due to variability in digester gas methane content, changes in ambient temperature and pressure, digester gas moisture content, ambient air humidity, engine air filter frictional losses, and engine ignition timing. Due to the uncertainty in digester gas characteristics and associated engine performance, Waukesha engineers indicated that the above-cited factors related to NO_x and CO emission variability could be expected to routinely change or drift over time and that the engine could be expected to emit NO_x at a rate up to twice the measured emission rate and CO emissions up to three times the measured emission rate.

Due to Billings WWTP's demonstrated inability to comply with the applicable NO_x BACT limit and their lack of confidence in the engines performance related to CO emissions, Billings WWTP submitted a current-day BACT analysis addressing the available methods of controlling NO_x and CO emissions from the Waukesha digester gas-fired rich-burn engine through the analysis of actual emissions data collected from engine specific operations. The Department reviewed these methods, as well as previous BACT determinations. The following control options have been reviewed by the Department in order to make the following BACT determination(s).

In addition, due to changes in assumed facility digester gas production and changed conditions of operation for the emergency back-up digester gas industrial flare, the current permit action re-evaluates BACT for the affected IBR natural gas/digester gas-fired boiler and the emergency back-up digester gas industrial flare.

1. Waukesha Digester Gas-Fired Rich-Burn Engine (658 bhp)

The Waukesha engine combusts digester gas collected from the facility digesters to produce approximately 25% of the necessary electricity for facility-wide operations, thereby reducing facility demand for electricity from the power grid. Digesters are used during the treatment of municipal wastewater. Typical digester gas produced at the facility consists of approximately 63% methane (CH₄) and 36% carbon dioxide (CO₂) with relatively low levels of hydrogen sulfide (H₂S), nitrogen, and trace levels of other contaminants.

Waukesha Digester Gas-Fired Rich-Burn Engine NO_x and CO Emissions

An internal combustion engine firing digester gas should inherently produce significantly lower NO_x emissions than the combustion of natural gas in the same unit. The lower CH₄ concentration in digester gas, as compared to natural gas (63% vs. 90%), should significantly reduce the combustion temperature thereby resulting in lower thermal NO_x emissions. However, as demonstrated through preliminary source testing conducted on the affected engine, this is not always the case.

Two available NO_x and CO control strategies are potentially applicable for the existing Waukesha engine:

- a. Conversion of existing rich-burn internal combustion engine to lean-burn engine; and
- b. Add non-selective catalytic reduction (NSCR) with air fuel ratio (AFR) controller to the existing rich-burn internal combustion engine.

The following text provides a summary of the identified available NO_x and CO control options for the digester gas-fired internal combustion engine:

a. Rich-Burn to Lean-Burn Engine Conversion

The actual reduction in NO_x and CO emissions achieved from a rich-burn to lean-burn engine conversion is unknown using available data, most of which is based on using natural gas fuel instead of digester gas. Furthermore, the lean-burn engine conversion would be approximately 75% of the cost of a new lean-burn engine. Therefore, considering the relatively low level of NO_x and CO emissions resulting from the operation of the affected digester gas-fired engine and the assumed minimal emission reduction and high cost of conversion, the Department determined that conversion to a lean-burn engine would be economically unreasonable and would not constitute BACT, in this case.

b. Addition of NSCR and AFR to Existing Rich-Burn Engine

NSCR and AFR are often used to reduce NO_x and CO emissions resulting from rich-burn engine operations fueled by natural gas and are capable of achieving a 90% reduction in emissions. However, catalytic reduction (selective or non-selective) for digester gas-fired engines is limited by contamination of the digester gas fuel with siloxanes and other trace contaminants. These contaminants are captured and trapped on the catalysts thereby fouling and substantially reducing catalyst life. Operational experience has indicated that catalyst fouling may occur in less than one hour of engine run time, although some catalysts remained partially effective for several weeks of engine run time. The typical catalyst life for an engine combusting natural gas is approximately 2 to 3 years. If the digester gas is not treated to remove these contaminants prior to combustion, the use of catalytic reduction would be technically infeasible. The cost of treating digester gas to remove contaminants to levels comparable to natural gas was estimated assuming the use of carbon absorption and a separate technology to remove H₂S. The NO_x and CO cost-effective analysis for NSCR and AFR for the proposed project is included below. A complete economic impact analysis is included in the application for Permit #3827-00 and Permit #3827-01.

NO_x Control Cost-Effective Analysis			
Control Technology/Strategy	Emission Rate (TPY)	Annual Cost (\$)	Cost-Effective Value (\$/ton removed)
No Additional Control	53.4	---	---
NSCR and AFR	5.34	193,000	4016
CO Control Cost-Effective Analysis			
No Additional Control	26.3	---	---
NSCR and AFR	2.63	193,000	8154

Based on the above-cited information the Department determined that the addition of NSCR and AFR to the existing and proposed Waukesha engine is technically and economically infeasible for the proposed project and does not constitute BACT, in this case.

Waukesha Digester Gas Rich-Burn Engine NO_x and CO BACT Determination

Based on the information summarized in the above-cited analysis, the Department determined that good combustion practices with no additional control and a NO_x and CO emission limit of 12.2 lb/hr and 6.0 lb/hr, respectively, constitutes BACT for NO_x and CO emissions from the Waukesha digester gas-fired rich-burn engine, in this case.

B. IBR Natural Gas/Digester Gas-Fired Boiler (3.78 MMBtu/hr)

Natural gas and digester gas-fired boilers are inherently low emitters of air pollution due to characteristics of the fuel fired to operate the boiler. Worst-case potential NO_x and CO emissions from the IBR boiler (using natural gas emission factors) are 4.64 tons per year (TPY) and 1.31 TPY, respectively, while potential emissions of all other regulated pollutants, except SO₂ (1.39 TPY), are less than 1 TPY. Because potential emissions of all regulated pollutants are low, incorporation of available pollutant-specific control technologies would result in high cost-effective values (\$/ton removed) thereby making pollutant-specific add-on controls for NO_x, CO, SO₂, PM/PM₁₀ and VOCs economically infeasible in this case. Therefore, the Department determined that combustion of pipeline-quality natural gas or digester-gas only and proper operation and maintenance of the IBR boiler with no additional control constitutes BACT for all regulated pollutants, in this case.

C. Emergency Back-Up Digester Gas Industrial Safety Flare

The emergency/back-up digester gas industrial safety flare is an emission control strategy in and of itself, as it is operated on a relatively continuous basis to destroy the collected digester gas in circumstances where the permitted Waukesha digester gas-fired engine and the IBR natural gas/digester gas fired units are non-operational or cannot accommodate all of the digester gas produced. Non-operational circumstances for the digester gas units include engine maintenance, engine repair, and/or necessary engine shutdown due to wastewater treatment plant operational circumstances such as changing the treatment plant digesters. Because potential emissions of all regulated pollutants are low, incorporation of available pollutant-specific control technologies would result in high cost-effective values (\$/ton removed) thereby making pollutant-specific add-on controls for NO_x, CO, SO₂, PM/PM₁₀ and VOCs economically infeasible in this case. Therefore, the Department determined that proper operation and maintenance of the emergency/back-up digester gas industrial safety flare with no additional control and operation of the affected unit, as necessary, to destroy any digester gas not used by the Waukesha engine and/or the IBR boiler constitutes BACT for all regulated pollutants, in this case.

The control options selected have controls and control costs comparable to other recently permitted similar sources and are capable of achieving the appropriate emission standards.

IV. Emission Inventory

Emitting Unit	tons of pollutant/year ^a					
	PM	PM ₁₀	NO _x	CO	SO ₂	VOC
Waukesha Digester Gas-Fired Engine	0.21	0.21	53.44	26.28	29.83	0.65
Cleaver Brooks Natural Gas-Fired Boiler	0.56	0.56	7.33	6.16	0.04	0.40
American Standard Natural Gas-Fired Boiler	0.07	0.07	0.96	0.81	0.01	0.05
IBR Natural Gas/Digester Gas-Fired Boiler ^b	0.13	0.13	1.66	1.39	24.40	0.09
Digester Gas Industrial Safety Flare ^c	0.03	0.03	0.06	1.18	2.40	0.22
Wastewater Process Tanks ^d	---	---	---	---	---	---
Total Emissions	1.00	1.00	63.45	35.82	56.68	1.41

^a A complete emission inventory was included in the applications for air quality Permits #3827-00 and #3827-01 and is on file with the Department

^b Assumes worst-case emissions combusting either 100% natural gas (PM, PM₁₀, NO_x, CO, VOC) or 100% digester gas (SO₂)

^c Assumes continuous operation combusting any excess digester gas not used by other permitted digester gas-fired units

^d Emissions assumed to be zero or negligible for all regulated pollutants from these process units

V. Existing Air Quality

The Billings WWTP facility is located at 725 Highway 87 East in Billings, Montana. The legal description of the site is in the Southeast ¼ of Section 27, Township 1 North, Range 26 East, in Yellowstone County, Montana. The Billings area is currently under a SIP-call action through the Federal Clean Air Act authority Section 110(k)(5). The SIP-call area is not considered a “non-attainment” area, but does have a regulatory control plan for SO₂. Existing and major new sources of SO₂ locating in the Billings area are regulated under the Billings SO₂ SIP. In addition, the facility is located in an area that has recently been re-designated from a CO non-attainment area to an attainment area for CO under a limited maintenance plan (LMP). The Billings WWTP facility has not been identified in any studies as impacting the previous CO nonattainment area status. Further, all sources of SO₂ and CO at the Billings WWTP facility are existing sources of emissions; therefore, the current permit action will not result in any additional adverse impact to existing air quality in the project area. In the view of the Department, the amount of controlled emissions, including SO₂ and CO, from this facility will not cause an exceedance of any ambient air quality standard or adversely impact the CO LMP.

VI. Ambient Air Impact Analysis

Based on the relatively low levels of pollutants emitted from the Billings WWTP, the Department determined that ambient air impacts from this permitting action will be minor. The Department believes the facility, operating under the limits and conditions included in this permit, will not cause or contribute to a violation of any applicable ambient air quality standard.

VII. Taking or Damaging Implication Analysis

As required by 2-10-105, MCA, the Department conducted a private property taking and damaging assessment and determined there are no taking or damaging implications.

VIII. Environmental Assessment

An environmental assessment, required by the Montana Environmental Policy Act, was completed for this project. A copy is attached.

DEPARTMENT OF ENVIRONMENTAL QUALITY
Permitting and Compliance Division
Air Resources Management Bureau
P.O. Box 200901, Helena, Montana 59620
(406) 444-3490

FINAL ENVIRONMENTAL ASSESSMENT (EA)

Issued To: City of Billings Public Works Department –
Wastewater Treatment Plant
P.O. Box 30958
Billings, MT 59111

Air Quality Permit Number: 3827-01

Preliminary Determination Issued: 8/22/01

Department Decision Issued: 09/07/07

Permit Final: 9/25/07

1. *Legal Description of Site:* The Billings WWTP is located at 725 Highway 87 East in Billings, Montana. The legal description of the site is in the Southeast ¼ of Section 27, Township 1 North, Range 26 East, in Yellowstone County, Montana.
2. *Description of Project:* The current permit action would modify the previous BACT-determined NO_x and CO emission limits applicable to the Waukesha digester gas-fired engine. The initial Waukesha engine BACT determinations for NO_x and CO emissions were established using published emission factors for the combustion of landfill gas because emissions data directly related to digester-gas combustion were not available at the time of initial permit development. Since issuance of Permit #3827-00, the Billings WWTP has conducted source testing for NO_x and CO demonstrating that the BACT limits established under Permit #3827-00 are not achievable on a consistent basis. A more complete analysis of the previous and current NO_x and CO BACT determinations for the affected unit and pollutants is contained in Section III of the Permit Analysis to this permit.

In addition, the initial application for Permit #3827-00 assumed a maximum facility digester gas throughput rate of 63 MMScf/yr; however, since issuance of Permit #3827-00, the Billings WWTP has determined that this assumed digester gas throughput rate was underestimated and the actual capacity is 76 MMScf/yr. Therefore, the current permit action would re-evaluate all emitting units affected by the increased digester gas throughput value including the Waukesha digester gas-fired rich-burn engine, the IBR natural gas/digester gas-fired boiler, and the emergency back-up digester gas industrial safety flare. The application for Permit #3827-00 assumed that the permitted emergency back-up digester gas industrial safety flare is only operational at times when the affected digester gas-fired units at the facility (Waukesha engine and IBR boiler) are not in operation. However, in practice, because the flare is an emission control strategy in and of itself, the emergency back-up digester gas industrial safety flare is operated on a relatively continuous basis, as necessary, to destroy any digester gas not used by either the Waukesha engine or IBR boiler. In light of this information, Section II.A.6 and Section II.C.4 of the permit would be modified to accurately reflect and regulate the emergency back-up digester gas industrial safety flare operations.

3. *Objectives of Project:* The objective of the proposed air quality permitting action is to re-evaluate previously BACT-determined conditions/limits applicable to the Waukesha digester gas-fired engine and the IBR natural gas/digester gas-fired boiler and to re-evaluate the operational conditions and previously BACT-determined conditions/limits applicable to the emergency back-up digester gas flare.
4. *Alternatives Considered:* In addition to the proposed action, the Department also considered the “no-action” alternative. The “no-action” alternative would deny issuance of the air quality permit to the proposed facility. However, the Department does not consider the “no-action” alternative to be appropriate because Billings WWTP demonstrated compliance with all applicable rules and regulations as required for permit issuance. Therefore, the “no-action” alternative was eliminated from further consideration.
5. *A Listing of Mitigation, Stipulations, and Other Controls:* A list of enforceable conditions, including a BACT analysis, would be included in Permit #3827-01.
6. *Regulatory Effects on Private Property:* The Department considered alternatives to the conditions imposed in this permit as part of the permit development. The Department determined that the permit conditions are reasonably necessary to ensure compliance with applicable requirements and demonstrate compliance with those requirements and do not unduly restrict private property rights.
7. The following table summarizes the potential physical and biological effects of the proposed project on the human environment. The “no-action” alternative was discussed previously.

		Major	Moderate	Minor	None	Unknown	Comments Included
A	Terrestrial and Aquatic Life and Habitats			X			Yes
B	Water Quality, Quantity, and Distribution			X			Yes
C	Geology and Soil Quality, Stability and Moisture			X			Yes
D	Vegetation Cover, Quantity, and Quality			X			Yes
E	Aesthetics			X			Yes
F	Air Quality			X			Yes
G	Unique Endangered, Fragile, or Limited Environmental Resources			X			Yes
H	Demands on Environmental Resource of Water, Air and Energy			X			Yes
I	Historical and Archaeological Sites				X		Yes
J	Cumulative and Secondary Impacts			X			Yes

SUMMARY OF COMMENTS ON POTENTIAL PHYSICAL AND BIOLOGICAL EFFECTS: The following comments have been prepared by the Department.

A. Terrestrial and Aquatic Life and Habitats:

Emissions from the project would affect terrestrial and aquatic life and habitats in the proposed project area. However, as discussed in Section VI of the permit analysis, any emissions and resulting impacts from the project would be minor due to the low level of those pollutants emitted.

Further, the waste-water treatment plant is an existing facility and no new construction or ground disturbance to the area would occur as a result of the current permit action. Overall, any impact to the terrestrial and aquatic life and habitats of the proposed project area would be minor.

B. Water Quality, Quantity and Distribution:

By design, the wastewater treatment plant would result in beneficial impact to water quality in the proposed project area. Further, emissions from the proposed project would result in minor negative impacts to water quality in the proposed project area. However, as discussed in Section VI of the permit analysis any emissions and resulting deposition impacts from the project would be minor due to the low level of those pollutants emitted.

Further, the waste-water treatment plant is an existing facility and no new water use would occur as a result of the current permit action. Overall, any impact to the water quality, quantity, and distribution in the proposed project area would be minor and generally beneficial.

C. Geology and Soil Quality, Stability, and Moisture:

The project would not impact the geology, soil quality, stability, and moisture of the proposed project area. The waste-water treatment plant is an existing facility and no new construction or ground disturbance to the area would occur as a result of the current permit action.

Further, as discussed in Section VI of the permit analysis, the wastewater treatment plant would result in minor air pollution emissions to the outside ambient environment. These pollutants would deposit on the soils in the surrounding area. Any impact from deposition of these pollutants would be minor and typical due to the existing industrial nature of the area and the low level of those pollutants emitted. Overall, any impact to the geology and soil quality, stability, and moisture of the proposed project area would be minor.

D. Vegetation Cover, Quantity, and Quality:

The project would not impact the vegetation cover, quantity, and quality in the proposed project area. The waste-water treatment plant is an existing facility and no new construction or ground disturbance to the area would occur as a result of the current permit action.

Further, as discussed in Section VI of the permit analysis, the wastewater treatment plant would result in minor air pollution emissions to the outside ambient environment. These pollutants would deposit on the vegetation in the surrounding area. Any impact from deposition of these pollutants would be minor and typical due to the existing industrial nature of the area and the low level of those pollutants emitted. Overall, any impact to the vegetation cover, quantity, and quality of the proposed project area would be minor.

E. Aesthetics:

The project would result in minor impacts to the aesthetic nature of the proposed project area because the wastewater treatment plant would operate within an existing building located in an area zoned as commercial and no new construction or further site disturbance would be required for the project. Because the wastewater treatment plant is an existing facility located in an area zoned for commercial uses, the project would not change the aesthetic nature of the area. Further, visible emissions from the source would be limited to 20% opacity and the permit would include emission control requirements. Also, the project would not result in excess noise from normal operations. Overall, any impact to the aesthetic character of the proposed project area would be minor.

F. Air Quality:

The proposed project would result in the emission of various air pollutants to the ambient air in the proposed project area. However, based on the relatively low levels of pollutants emitted from the Billings WWTP, the Department determined that ambient air impacts from this permitting action would be minor. The Department determined that the facility, operating under the limits and conditions included in this permit, will not cause or contribute to a violation of any applicable ambient air quality standard. Overall, any impact to the air quality of the proposed project area would be minor.

G. Unique Endangered, Fragile, or Limited Environmental Resources:

During the permit action for Permit #3827-00, the Department contacted the Montana Natural Heritage Program (MNHP) in an effort to identify any species of special concern that may be located within or near the Billings WWTP site (Southeast ¼ of Section 27, Township 1 North, Range 26 East, in Yellowstone County, Montana). Search results concluded that there are four such species of special concern on file for the area. Further, the MNHP report indicated *inferred extent* for two additional species of special concern. *Inferred extent* refers to an area that can be inferred to be probable occupied habitat based on the spatial location of the direct observation of a species and general information available for the foraging area or home range size of the species. Area in this case is defined by the Township and Range of the proposed site, with an additional 1-mile buffer. The four species of special concern located within the defined area include the *Apalone spinifera* (Spiny Softshell), *Heterodon nasicus* (Western Hognose Snake), *Falco perigrinus* (Perigrine Falcon), and *Lampropeltis triangulum* (Milk Snake) and the two species identified through *inferred extent* include *Centrocercus urophasianus* (Greater Sage Grouse) and *Euderma maculatum* (Spotted Bat).

While these species of special concern may be found in specific habitats within or near the defined area, the MNHP search did not indicate that these species of special concern would locate directly on or relatively near the existing industrial site. Given the existing industrial nature of the project area, it is unlikely that these species of special concern would locate on or near the project site and thus unlikely that these species of special concern would realize any impact from the wastewater treatment plant operations beyond minor air emission impacts discussed in greater detail below.

Emissions from the proposed project could impact the previously highlighted unique, endangered, fragile, or limited environmental resources located in the proposed project area. However, as detailed in Section VI of the permit analysis, any emissions and resulting impacts from the project would be minor due to the low concentration of those pollutants emitted and typical due to the existing industrial nature of the area. Overall, any impact to unique endangered, fragile, or limited environmental resources of the proposed project area would be minor.

H. Demands on Environmental Resource of Water, Air, and Energy:

The project would result in minor demands on environmental resources of water as discussed in Section 7.B of this EA. In addition, the proposed project would permit a digester gas engine which has historically been responsible for producing enough energy to provide approximately 25% of the facilities annual electricity needs. Therefore, the project would impact energy resources; however, any impacts would be minor and positive due to the relatively small size of the industrial operations and the ability to produce energy thereby avoiding reliance on additional energy resources in the area.

Further, as discussed in Section VI of the permit analysis, the wastewater treatment plant would result in minor air pollution emissions to the outside ambient environment. Any impact from the emission of these pollutants would be minor and typical due to the existing industrial nature of the area and the low level of those pollutants emitted. Overall, any impact to the demands on environmental resource of water, air, and energy in the proposed project area would be minor.

I. Historical and Archaeological Sites:

The proposed project would not result in any impact on historical and archaeological sites in the proposed project area. The wastewater treatment plant would operate within an existing building located in an area zoned as commercial and would not require any additional construction and ground disturbance.

According to previous correspondence from the Montana State Historic Preservation Office, there is low likelihood of any disturbance to any known archaeological or historic site, given previous industrial disturbance within the area. Therefore, the project would not impact any known historic or archaeological site that may be located within or near the proposed operating site.

J. Cumulative and Secondary Impacts:

The Billings WWTP is an existing facility. Emissions from the existing Billings WWTP would continue to impact the above-cited physical and biological resources of the environment after issuance of Permit #3827-01. However, the purpose of the current permit action would be to bring the existing Billings WWTP into compliance with the Montana Clean Air Act through issuance of the required Montana Air Quality Permit. Therefore, because the current permit action would not result in any changes to the existing facility, no direct or secondary and cumulative impacts to the above-cited physical and biological resources of the project area would occur as a result of the current permit action.

Overall, the cumulative and secondary impacts from this project on the physical and biological environment in the immediate area would be minor due to the relatively small size and potential environmental impact of the proposed operation. The Department believes that this facility could be expected to operate in compliance with all applicable rules and regulations as outlined in Permit #3827-01.

8. The following table summarizes the potential economic and social effects of the proposed project on the human environment. The “no-action” alternative was discussed previously.

		Major	Moderate	Minor	None	Unknown	Comments Included
A	Social Structures and Mores				X		Yes
B	Cultural Uniqueness and Diversity				X		Yes
C	Local and State Tax Base and Tax Revenue			X			Yes
D	Agricultural or Industrial Production				X		Yes
E	Human Health			X			Yes
F	Access to and Quality of Recreational and Wilderness Activities				X		Yes
G	Quantity and Distribution of Employment				X		Yes
H	Distribution of Population				X		Yes
I	Demands for Government Services			X			Yes
J	Industrial and Commercial Activity			X			Yes
K	Locally Adopted Environmental Plans and Goals				X		Yes
L	Cumulative and Secondary Impacts			X			Yes

SUMMARY OF COMMENTS ON POTENTIAL ECENOMIC AND SOCIAL EFFECTS: The Department has prepared the following comments.

- A. Social Structures and Mores:
- B. Cultural Uniqueness and Diversity:

The proposed project would not have any impact on the above economic and social resources as well as the cultural uniqueness and diversity of the proposed area of operation because the project is small by industrial standards and operations would take place within an existing building and no additional construction or employment would be required.

Further, the surrounding area is currently and would remain commercial/industrial in nature. The predominant use of the surrounding area would not change as a result of the proposed project.

- C. Local and State Tax Base and Tax Revenue:

The proposed project would have a minor impact on the local and state tax base and tax revenue because the project is small by industrial standards and would not result in any increased commercial activity beyond the proposed project. Further, the plant would operate within an existing industrial site with no new construction or ground disturbance occurring as a result of the current permit action.

- D. Agricultural or Industrial Production:

The proposed project would operate within an existing industrial area; therefore, the project would not affect or displace any land used for agricultural production. Further, because the current action would not require any additional industrial construction and the facility is an existing industrial operation, it is unlikely that the project would impact any industrial production.

E. Human Health:

Permit #3827-00 would include limits and conditions to ensure the facility would be operated in compliance with all applicable air quality rules and standards. These rules and standards are designed to be protective of human health. As described in Section III of the permit analysis, the air emissions from the proposed facility would be minimized by the use of BACT as required by Permit #3827-00. Overall, only minor impacts would be expected on human health from the proposed operations.

F. Access to and Quality of Recreational and Wilderness Activities:

Because the proposed project would operate within an existing industrial area, the project would not affect any access to or quality of any recreation or wilderness activities in the area.

G. Quantity and Distribution of Employment:

H. Distribution of Population:

The proposed project would not require any new employment in the area. The project would utilize existing employee(s) to operate the plant; therefore, the proposed project would not impact the quantity and distribution of population and employment in the area.

I. Demands for Government Services:

Government services would be required for acquiring the appropriate permits from government agencies. In addition, the permitted source of emissions would be subject to periodic inspections by government personnel. Demands for government services would be minor.

J. Industrial and Commercial Activity:

The proposed project would result in only a minor impact on local industrial and commercial activity because the proposed project would operate within an existing industrial area, would not require any additional industrial construction, and would not result in additional industrial production. Overall, any industrial or commercial activity occurring as a result of the project would be minor.

K. Locally Adopted Environmental Plans and Goals:

The Billings area is currently under a SIP-call action through the Federal Clean Air Act authority Section 110(k)(5). The SIP-call area is not considered a “non-attainment” area, but does have a regulatory control plan for SO₂. Existing and major new sources of SO₂ locating in the Billings area are regulated under the Billings SO₂ SIP. In addition, the facility is located in an area that has recently been re-designated from a CO non-attainment area to an attainment area for CO under a limited maintenance plan (LMP). The Billings WWTP facility has not been identified in any studies as impacting the previous CO nonattainment area status. Further, all sources of SO₂ and CO at the Billings WWTP facility are existing sources of emissions; therefore, the current permit action would not result in any additional adverse impact to existing air quality in the project area. In the view of the Department, the amount of controlled emissions, including SO₂ and CO, from this facility would not cause an exceedance of any ambient air quality standard or adversely impact the CO LMP.

The Department is not aware of any other locally adopted environmental plans or goals in the immediate area affected by the proposed project. The state standards would be protective of the proposed project area.

L. Cumulative and Secondary Impacts:

The Billings WWTP is an existing facility and would continue to impact the above-cited social and economic resources of the environment after issuance of Permit #3827-01. However, the purpose of the current permit action would be to bring the existing Billings WWTP into compliance with the Montana Clean Air Act through issuance of the required Montana Air Quality Permit. Therefore, because the current permit action would not result in any changes to the existing facility, no direct or secondary and cumulative impacts to the above-cited physical and biological resources of the project area would occur as a result of the current permit action.

Overall, the cumulative and secondary impacts from this project on the physical and biological environment in the immediate area would be minor due to the relatively small size and potential environmental impact of the proposed operation. The Department believes that this facility could be expected to operate in compliance with all applicable rules and regulations as outlined in Permit #3827-01.

Recommendation: No Environmental Impact Statement (EIS) is required.

If an EIS is not required, explain why the EA is an appropriate level of analysis: The current permit action is for the construction and operation of a wastewater treatment plant. Permit #3827-00 includes conditions and limitations to ensure the facility would operate in compliance with all applicable rules and regulations. In addition, as detailed in the above EA there are no significant impacts associated with the proposed project.

Other groups or agencies contacted or which may have overlapping jurisdiction: Montana Historical Society – State Historic Preservation Office, Natural Resource Information System – Montana Natural Heritage Program

Individuals or groups contributing to this EA: Department of Environmental Quality – Air Resources Management Bureau, Montana Historical Society – State Historic Preservation Office, Natural Resource Information System – Montana Natural Heritage Program.

EA prepared by: M. Eric Merchant

Date: August 15, 2007