



Montana Department of
ENVIRONMENTAL QUALITY

Brian Schweitzer, Governor

P. O. Box 200901

Helena, MT 59620-0901

(406) 444-2544

Website: www.deq.mt.gov

September 28, 2010

Patrick B. Kimmet
Refinery Manager
CHS Inc.
P.O. Box 909
Laurel, MT 59044

Dear Mr. Kimmet:

Montana Air Quality Permit #1821-22 is deemed final as of September 28, 2010, by the Department of Environmental Quality (Department). This permit incorporates various minor administrative changes. All conditions of the Department's Decision remain the same. Enclosed is a copy of your permit with the final date indicated.

For the Department,

Vickie Walsh
Air Permitting Program Supervisor
Air Resources Management Bureau
(406) 444-9741

Skye Hatten, P.E.
Environmental Engineer
Air Resources Management Bureau
(406) 444-5287

VW:SH
Enclosure

Montana Department of Environmental Quality
Permitting and Compliance Division

Montana Air Quality Permit #1821-22

CHS Inc.
Laurel Refinery
P.O. Box 909
Laurel, MT 59044-0909

September 28, 2010



Montana Air Quality Permit

Issued to: CHS Inc.
Laurel Refinery
P.O. Box 909
Laurel, MT 59044-0909

MAQP: #1821-22
Administrative Amendment (AA)
Request Received: July 27, 2010
Department Decision on AA: September 10, 2010
Permit Final: September 28, 2010
AFS #: 111-0012

A Montana Air Quality Permit (MAQP), with conditions, is hereby granted to CHS Inc. (CHS) pursuant to Sections 75-2-204, 211, and 215, Montana Code Annotated (MCA), as amended, and the Administrative Rules of Montana (ARM) 17.8.740, *et seq.*, as amended, for the following:

Section I: Permitted Facilities

A. Plant Location/Description

CHS operates the Laurel petroleum refinery, located in the South ½ of Section 16, Township 2 South, Range 24 East, in Yellowstone County, Montana. The facility includes, but is not limited to, the following permitted equipment, by section:

- Section II. Plant-Wide Requirements (including Plant-wide Applicability Limits (PALs)). The refinery flare is not included under the PAL.
- Section III. Fuel Gas & Fuel Oil Combustion Devices
- Section IV. Hydrodesulfurization (HDS) complex with associated Zone D sulfur recovery unit (SRU) and tail gas treatment unit (TGTU)
- Section V. Boiler #10
- Section VI. Truck Loading Rack and Vapor Combustion Unit (VCU)
- Section VII. No. 1 Crude Unit
- Section VIII. Ultra Low Sulfur Diesel (ULSD) Unit and Hydrogen Plant
- Section IX. TGTU for Zone A's SRU #1 and SRU #2 trains
- Section X. Fluidized Catalytic Cracking Unit (FCCU)
- Section XI. Naphtha Hydrotreater (NHT) Unit, Delayed Coker Unit, and Zone E SRU/TGTU and Tail Gas Incinerator (TGI)
- Section XII. Boiler #11
- Section XIII. Railcar Light Product Loading Rack and VCU
- Section XIV. Boiler #12
- Section XV. Benzene Reduction Unit

B. Current Permit Action

On July 27, 2010, the Department of Environmental Quality (Department) received a request to administratively amend MAQP #1821-21. The Department had inadvertently failed to modify all pertinent sections within MAQP #1821-20 to reflect the December 31, 2011 shutdown date for Boiler #4 and Boiler #5. CHS had requested the Department to administratively amend the permit to reflect this shutdown date in all applicable sections within the permit. CHS also requested the Department administratively amend the permit to include a reference to parts per million, volumetric dry (ppm_{vd}) units where Hydrogen Sulfide (H_2S) limits are expressed in grains per dry standard cubic feet (gr/dscf).

Section II: Plant-wide Refinery Limitations and Conditions (the refinery flare is not included).

A. National Emission Standards for Hazardous Air Pollutants

CHS shall comply with all applicable standards and limitations, and the reporting, recordkeeping, and notification requirements as required by 40 CFR 61, Subpart FF- National Emissions Standards for Benzene Waste Operations (ARM 17.8.341 and 40 CFR 61, Subpart FF).

B. Annual Plant-wide Emission Limitations (ARM 17.8.749):

1. Sulfur dioxide (SO_2) emissions shall not exceed 2,980.3 tons per year (TPY)
2. Nitrogen Oxide (NO_x) emissions shall not exceed 999.4 TPY
3. Carbon Monoxide (CO) emissions shall not exceed 678.2 TPY
4. Volatile organic compounds (VOC) emissions shall not exceed 1,967.5 TPY
5. Particulate matter with an aerodynamic diameter of 10 microns or less (PM_{10}) emissions shall not exceed 152.2 TPY
6. Particulate matter (PM) emissions shall not exceed 162.2 TPY

C. Compliance Determination (ARM 17.8.749):

CHS shall determine the CO, NO_x , and VOC emissions for combustion sources by utilizing the Plant Information (PI) system information and normalize that PI system information to the refinery yield report. CHS shall also provide the Department with the amount of fuel consumed annually in the refinery as documented in the refinery yield report. This methodology was used to determine the CO, NO_x , and VOC emissions in CHS's MAQP #1821-05 application and again in the August 12, 2004 letter from CHS to the Department.

CHS will track compliance with the emission caps based on source type, pollutant, calculation basis (emission factors, estimated yield and conversion), and key parameters (fuel oil use, fuel gas use, process gas use, and Continuous Emission Monitoring System (CEMS) data). The units included in each source type are listed in Section I.A of the permit analysis. The calculation basis for each unit is listed in Attachment A (Plant-Wide Refinery Limitations and Conditions Compliance Determination).

D. Reporting and Recordkeeping Requirements (ARM 17.8.749):

CHS shall provide quarterly emission reports to demonstrate compliance with Section II.B using data required in Section II.C. The quarterly report shall also include CEMS monitoring downtime that occurred during the reporting period.

E. Testing Requirements

1. Fuel flow rates, fuel heating value, production information and other data, as needed, shall be recorded during the performance of source tests in order to develop emission factors for use in the compliance determinations (ARM 17.8.749).
2. All compliance source tests shall be conducted in accordance with the Montana Source Test Protocol and Procedures Manual (ARM 17.8.106).
3. The Department may require further testing (ARM 17.8.105).

F. Operational and Emission Inventory Reporting Requirements (ARM 17.8.749):

1. CHS shall supply the Department with annual production information for all emission points, as required by the Department in the annual emission inventory request. The request will include, but is not limited to, all sources of emissions identified in the emission inventory contained in the permit analysis and sources identified in Section I of this permit.

Production information shall be gathered on a calendar-year basis and submitted to the Department by the date required in the emission inventory request. Information shall be in the units as required by the Department. This information may be used for calculating operating fees, based on actual emissions from the facility, and/or to verify compliance with permit limitations (ARM 17.8.505).

2. All records compiled in accordance with this permit must be maintained by CHS as a permanent business record for at least 5 years following the date of the measurement, must be available at the plant site for inspection by the Department, -EPA, and the Yellowstone County Air Pollution Control Agency, and must be submitted to the Department upon request (ARM 17.8.749).
3. CHS shall notify the Department of any construction or improvement project conducted, pursuant to ARM 17.8.745, that would include a change of control equipment, stack height, stack diameter, stack flow, stack gas temperature, source location, or fuel specifications, or would result in an increase in source capacity above its permitted operation or the addition of a new emission unit. The notice must be submitted to the Department, in writing, 10 days prior to start up or use of the proposed de minimis change, or as soon as reasonably practicable in the event of an unanticipated circumstance causing the de minimis change, and must include the information requested in ARM 17.8.745(1)(d) (ARM 17.8.745).

G. Notification Requirements

CHS shall provide the Department (both the Billings regional and the Helena offices) with written notification of the following dates within the following time periods (ARM 17.8.749 and 340):

1. All compliance source tests as required by the Montana Source Test Protocol and Procedures Manual (ARM 17.8.106).
2. The Department must be notified promptly by telephone whenever a malfunction occurs that can be expected to create emissions in excess of any applicable emission limitation, or to continue for a period greater than 4 hours (ARM 17.8.110).

Section III: Limitations and Conditions for Fuel Gas and Fuel Oil Combustion Devices

- A. CHS shall comply with all applicable standards and limitations, and the monitoring, recordkeeping and reporting requirements contained in 40 CFR Part 60, Standards of Performance for New Stationary Sources (NSPS). The following subparts, at a minimum, are applicable:
 1. Subpart A - General Provisions applies to all equipment or facilities subject to an NSPS subpart listed below.
 2. Subpart J - Standards of Performance for Petroleum Refineries applies to all fuel gas combustion devices as applicable, with the exception of the existing refinery flare. The flare will be subject to Subpart J once EPA has approved all proposed Alternative Monitoring Plans (CHS Consent Decree Paragraphs 55 and 57).
- B. CHS shall not cause or authorize emissions to be discharged into the outdoor atmosphere from any source installed after November 23, 1968, that exhibit an opacity of 20% or greater averaged over 6 consecutive minutes (ARM 17.8.304 (2)).
- C. Limitations on Fuel Gas and Fuel Oil Combustion Devices
 1. Prior to the startup of Boiler #12, SO₂ emissions from the combustion of alkylation unit polymer and fuel oil in all combustion devices is limited to 127.6 tons per rolling 365-day time period (ARM 17.8.749). Periods of natural gas curtailment are not exempt from this limit.

Following the startup of Boiler #12, SO₂ emissions from the combustion of alkylation unit polymer is limited to 50 tons per rolling 365-day time period (ARM 17.8.749). Periods of natural gas curtailment are not exempt from this limit.
 2. Following initial startup of Boiler #12, fuel oil combustion in refinery boilers is prohibited (ARM 17.8.749).
 3. Refinery fuel gas burned in fuel combustion devices shall not exceed 0.10 grains of H₂S per dry standard cubic foot (161 ppm_{vd} H₂S) per rolling 3-hour average. Refinery fuel gas burned in fuel combustion devices shall not exceed 0.05 grains of H₂S per dry standard cubic foot (81 ppm_{vd} H₂S) per 12-month average (ARM 17.8.749).
 4. The burning of old sour water stripper overhead (SWSOH) in any fuel gas combustion device is prohibited (CHS Consent Decree Paragraphs 43 and 50 and Appendix A).
 5. By December 31, 2011, CHS shall cease operation of Boilers #4 and #5 (CHS

Consent Decree).

D. Monitoring Requirements

1. CHS shall install and operate the following CEMS/Continuous emission rate monitors (CERMS): Continuous concentration (dry basis) monitoring of H₂S in refinery fuel gas burned in all refinery fuel gas combustion devices, with the exception of refinery fuel gas streams with approved Alternative Monitoring Plans (AMP) or AMPs under review.
2. CEMS and CERMS required by this permit shall comply with all applicable provisions of 40 CFR Parts 60.5 through 60.13, Subparts J, 60.100-108 and Appendix B, Performance Specification 7 and Appendix F (Quality Assurance/Quality Control) provisions.
3. H₂S refinery fuel gas CEMS and fuel gas flow rate meters shall comply with all applicable requirements of the Billings/Laurel SO₂ SIP Emission Control Plan, including Exhibit A and Attachments, adopted by the Board of Environmental Review, June 12, 1998, and stipulated to by Cenex Harvest States Cooperative and its successor CHS.
4. Fuel oil metering and analysis specifications (SOP SIP Method C-1) shall comply with all applicable requirements of the Billings/Laurel SO₂ SIP Emission Control Plan, including Exhibit A and Attachments, adopted by the Board of Environmental Review, June 12, 1998, and stipulated to by Cenex Harvest States Cooperative and its successor CHS.
5. CEMS are to be in operation at all times when the emission units are operating, except for quality assurance and control checks, breakdowns, and repairs. In the event the primary CEMS is unable to meet minimum availability requirements, the recipient shall provide a back-up or alternative monitoring system and plan such that continuous compliance can be demonstrated.

E. Compliance Determinations

1. Compliance determinations for SO₂ and H₂S limits for the fuel gas-fired units within the refinery shall be based upon CEMs data utilized for H₂S, as required in Section III.D.1 and fuel firing rates, if these units are fired on refinery fuel gas. Firing these units solely on natural gas shall demonstrate compliance with the applicable SO₂ limits.
2. Compliance determinations for the SO₂ limit from the combustion of alkylation unit polymer and fuel oil in all combustion devices shall be based upon methodology required in the Billings-Laurel SO₂ SIP and Appendix G of the CHS Consent Decree.
3. In addition to the testing required in each section, compliance determinations for the emission limits applicable to the fuel gas and fuel oil combustion devices shall be based upon actual fuel burning rates and the emission factors developed from the most recent compliance source test, and/or available CEM data. Fuel flow rates, fuel heating value, production information and other data, as needed, shall be recorded for each emitting unit during the performance of the source tests in order to develop emission factors for use in the compliance

determinations. New emission factors (subject to review and approval by the Department) shall become effective within 60 days after the completion of a source test. Firing these units solely on natural gas shall demonstrate compliance with the applicable VOC limits (ARM 17.8.749).

4. CHS shall provide the Department (both the Billings regional office and the Helena office) with written notification of the shutdown date(s) of Boilers #4 and #5 within 15 days after the actual shutdown date(s) (ARM 17.8.749).

F. Operational and Emission Inventory Reporting Requirements (ARM 17.8.749)

CHS shall submit quarterly emission reports to the Department. Emission reporting for SO₂ generated from the combustion of fuel oil and alkylation unit polymer shall consist of a daily 365-day rolling average (tons/year) for each calendar day. CHS shall submit the quarterly emission reports within 30 days of the end of each calendar quarter. Copies of the quarterly emission report shall be submitted to both the Billings regional office and the Helena office of the Department.

The quarterly report shall also include the following:

1. Source or unit operating time during the reporting period (Alkylation Unit and boilers burning fuel oil) and 24-hour (daily) average concentration of H₂S in the refinery fuel gas burned at the permitted facilities.
2. Monitoring downtime that occurred during the reporting period.
3. A summary of excess emissions or applicable concentrations for each pollutant and the averaging period identified in Section III.C.
4. Compliance determinations for hourly, 24-hour, and annual limits specifically allowed in Section III.C. (ARM 17.8.749).
5. Reasons for any emissions in excess of those specifically allowed in Section III.C. with mitigative measures utilized and corrective actions taken to prevent a recurrence of the situation.
6. For those refinery fuel gas streams covered by AMPs, the report should identify instances where AMP conditions were not met.

Section IV: Limitations and Conditions for the HDS Complex

- A. CHS shall comply with all applicable standards and limitations, and the monitoring, recordkeeping and reporting requirements contained in 40 CFR Part 60, NSPS. The following subparts, at a minimum, are applicable:
 1. Subpart A - General Provisions applies to all equipment or facilities subject to an NSPS subpart listed below.
 2. Subpart J - Standards of Performance for Petroleum Refineries applies to the SRU Incinerator Stack (E-407 & INC-401), the Fractionator Feed Heater Stack (H-202), the Reactor Charge Heater Stack (H-201), and the Hydrogen Reformer Heater (H-101).
 3. Subpart GGG - Standards of Performance for Equipment Leaks of VOC in

Petroleum Refineries applies to the HDS unit.

4. Subpart QQQ - Standards of Performance for VOC Emissions from Petroleum Refinery Wastewater Systems applies to the HDS unit.
- B. CHS shall comply with all applicable standards and limitations, and the reporting, recordkeeping, and notification requirements specified in 40 CFR Part 63, National Emission Standards for Hazardous Air Pollutants (NESHAPs) for Source Categories (ARM 17.8.342):
1. Subpart A – General Provisions applies to all equipment or facilities subject to a NESHAP for source categories subpart as listed below.
 2. Subpart ZZZZ – National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines. This applies to the replacement C-201B Compressor installed in 2006.
- C. CHS shall not cause or authorize emissions to be discharged into the outdoor atmosphere from any source installed after November 23, 1968, that exhibit an opacity of 20% or greater averaged over 6 consecutive minutes. This applies to the sources in the HDS complex (ARM 17.8.304 (2)).
- D. Limitations on Individual Sources

The HDS complex desulfurizes fluidized catalytic cracking unit feedstocks. The SRU and TGTU shall together utilize up to 70.7 long tons per day (LTD) of equivalent sulfur obtained from the equipment, to manufacture elemental sulfur.

1. Zone D SRU Incinerator Stack (E-407 & INC-401)
 - a. SO₂ emissions from the Zone D SRU incinerator stack shall not exceed (ARM 17.8.749):
 - i. 31.1 tons/rolling 12-calendar month total,
 - ii. 125 ppm_{vd}, rolling 12-month average corrected to 0% oxygen, on a dry basis,
 - iii. 341.04 lb/day,
 - iv. 14.21 lb/hr, and
 - v. 250 parts per million, volumetric dry (ppm_{vd}), rolling 12-hour average corrected to 0% oxygen, on a dry basis.
 - b. CHS shall operate and maintain the TGTU on the Zone D SRU to limit SO₂ emissions from the Zone D SRU incinerator stack (E-407 & INC-401) to no more than 125 ppm_{vd} on a rolling 12-month average corrected to 0% oxygen on a dry basis (ARM 17.8.752).
 - c. NO_x emissions from the Zone D SRU incinerator stack shall not exceed (ARM 17.8.749):
 - i. 3.5 tons/rolling 12-calendar month total,
 - ii. 19.2 lb/day, and
 - iii. 0.8 lb/hr.
 - d. CHS shall not fire fuel oil in this unit (ARM 17.8.749).

2. Compressor Gas Engine Stack (C-201B)
- a. NO_x emissions from C-201B shall not exceed (ARM 17.8.749):
 - i. 30.43 tons/rolling 12-calendar month total
 - ii. 7.14 lb/hr
 - b. CO emissions from C-201B shall not exceed (ARM 17.8.749):
 - i. 68.59 tons/rolling 12-calendar month total
 - ii. 6.40 lb/hr when firing natural gas
 - iii. 16.10 lb/hr when firing propane
 - c. VOC emissions from C-201B shall not exceed 10.1 tons/rolling 12-calendar month total (ARM 17.8.749).
 - d. CHS shall only combust natural gas or propane in C-201B (ARM 17.8.749).
 - e. CHS will maintain and operate a CO catalyst on the C-201B compressor exhaust (ARM 17.8.749).

3. Reformer Heater Stack (H-101)

- a. SO₂ emissions from H-101 shall not exceed (ARM 17.8.749):
 - i. 1.68 tons/rolling 12-calendar month total
 - ii. 2.15 lb/hr
- b. NO_x emissions from H-101 shall not exceed (ARM 17.8.749):
 - i. 27.16 tons/rolling 12-calendar month total
 - ii. 6.78 lb/hr
- c. CO emissions from H-101 shall not exceed (ARM 17.8.749):
 - i. 13.93 tons/rolling 12-calendar month total
 - ii. 4.51 lb/hr
- d. VOC emissions from H-101 shall not exceed 0.35 tons/rolling 12-calendar month total (ARM 17.8.749).
- e. CHS shall not combust fuel oil in this unit (ARM 17.8.749, ARM 17.8.340, and 40 CFR 60, Subpart J).

4. Reactor Charge Heater Stack (H-201)

- a. SO₂ emissions from H-201 shall not exceed (ARM 17.8.749):
 - i. 4.35 tons/rolling 12-calendar month total
 - ii. 1.99 lb/hr
- b. NO_x emissions from H-201 shall not exceed (ARM 17.8.749):

- i. 11.56 tons/rolling 12-calendar month total
- ii. 2.90 lb/hr
- c. CO emissions from H-201 shall not exceed (ARM 17.8.749):
 - i. 8.92 tons/rolling 12-calendar month total
 - ii. 2.23 lb/hr
- d. VOC Emissions from H-201 shall not exceed 0.91 tons/rolling 12-calendar month total (ARM 17.8.749).
- e. CHS shall not fire fuel oil in this unit (ARM 17.8.749).

5. Fractionator Feed Heater Stack (H-202)

- a. SO₂ emissions from H-202 shall not exceed (ARM 17.8.749):
 - i. 3.14 tons/rolling 12 calendar-month total
 - ii. 1.43 lb/hr
- b. NO_x emissions from H-202 shall not exceed (ARM 17.8.749):
 - i. 8.34 tons/rolling 12 calendar-month total
 - ii. 2.09 lb/hr
- c. CO emissions from H-202 shall not exceed (ARM 17.8.749):
 - i. 6.43 tons/rolling 12-calendar month total
 - ii. 1.61 lb/hr
- d. VOC emissions from H-202 shall not exceed 0.65 tons/rolling 12-calendar month total (ARM 17.8.749).
- e. CHS shall not fire fuel oil in this unit (ARM 17.8.749).

E. Monitoring Requirements

- 1. CHS shall install and operate the following CEMS/CERMS for the SRU Incinerator Stack (E-407/INC-401):
 - a. SO₂ (SO₂ SIP, 40 CFR 60 Subpart J)
 - b. O₂ (40 CFR 60, Subpart J)
 - c. Volumetric Flow Rate (SO₂ SIP)
- 2. CEMS and CERMS required by this permit shall comply with all applicable provisions of 40 CFR Parts 60.5 through 60.13, Subparts J, 60.100-108 and Appendix B, Performance Specifications 2, 3, 6, and Appendix F; and 40 CFR 52, Appendix E, for certifying Volumetric Flow Rate Monitors (ARM 17.8.749).
- 3. CEMS are to be in operation at all times when the emission units are operating, except for quality assurance and control checks, breakdowns, and repairs. Startup

shall be considered to be when acid gas and SWS streams are first introduced into the sulfur recovery facility. In the event the primary CEMS is unable to meet minimum availability requirements, the recipient shall provide a back-up or alternative monitoring system and plan such that continuous compliance can be demonstrated (ARM 17.8.749).

F. Testing Requirements

1. The SRU Incinerator Stack (E-407 & INC-401) shall be tested annually, or according to another testing/monitoring schedule as may be approved by the Department, for SO₂ and NO_x, and the results submitted to the Department in order to demonstrate compliance with the SO₂ and NO_x emission limits contained in Section IV.D.1.a, b and c (ARM 17.8.105 and ARM 17.8.749).
2. The Superior Clean Burn II 12 SGIB (C201-B) compressor engine shall be tested annually, or according to another testing/monitoring schedule as may be approved by the Department, for NO_x and CO, concurrently, and the results submitted to the Department in order to demonstrate compliance with the NO_x and CO emission limits contained in Section IV.D.2.a and b (ARM 17.8.105 and ARM 17.8.749).
3. The Reformer Heater Stack (H-101) shall be tested annually, or according to another testing/monitoring schedule as may be approved by the Department, for NO_x and CO, concurrently, and the results submitted to the Department in order to demonstrate compliance with the emission limits contained in Section IV.D.3.b and c (ARM 17.8.105 and ARM 17.8.749).
4. The Reactor Charge Heater Stack (H-201) shall be tested every two years, or according to another testing/monitoring schedule as may be approved by the Department, for NO_x and CO, concurrently, and the results submitted to the Department in order to demonstrate compliance with the NO_x and CO emission limits contained in Section IV.D.4.b and c (ARM 17.8.105 and ARM 17.8.749).
5. The Fractionator Feed Heater Stack (H-202) shall be tested every two years, or according to another testing/monitoring schedule as may be approved by the Department, for NO_x and CO, concurrently, and the results submitted to the Department in order to demonstrate compliance with the NO_x and CO emission limits contained in Section IV.D.5.b and c (ARM 17.8.105 and ARM 17.8.749).

G. Compliance Determinations

1. In addition to the testing required in Section IV.F, compliance determinations for hourly, 24-hour, and annual SO₂ limits for the SRU Incinerator stack shall be based upon CEMS data utilized for SO₂ as required in Section IV.E.1.
2. Compliance with the opacity limitation listed in Section IV.C shall be determined using EPA Reference Method 9 testing by a qualified observer.

H. Operational and Emission Inventory Reporting Requirements (ARM 17.8.749)

CHS shall submit quarterly emission reports to the Department based on data from the installed CEMS/CERMS. Emission reporting for SO₂ from the emission rate monitor shall consist of a daily 24-hour average (ppm SO₂, corrected to 0% oxygen (O₂)) and a 24-hour total (lb/day) for each calendar day. CHS shall submit the monthly emission

reports within 30 days of the end of each calendar quarter. Copies of the quarterly emission report shall be submitted to both the Billings regional office and the Helena office of the Department. The quarterly report shall also include the following:

1. Source or unit operating time during the reporting period and quarterly fuel gas consumption rates.
2. Monitoring downtime that occurred during the reporting period.
3. A summary of excess emissions or applicable concentrations for each pollutant and the averaging period identified in Sections IV.D.1 through 5.
4. Compliance determinations for hourly, 24-hour, and annual limits specifically allowed in Sections IV.D.1 through 5 (ARM 17.8.749).
5. Reasons for any emissions in excess of those specifically allowed in Sections IV.D.1 through 5 with mitigative measures utilized and corrective actions taken to prevent a recurrence of the situation.

Section V: Limitations and Conditions for Boiler #10

- A. CHS shall comply with all applicable standards and limitations, and the monitoring, recordkeeping and reporting requirements contained in 40 CFR Part 60 for Boiler #10. The following subparts, at a minimum, are applicable (ARM 17.8.340):
 1. Subpart A - General Provisions applies to all equipment or facilities subject to an NSPS subpart listed below.
 2. Subpart Db - Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units.
 3. Subpart J - Standards of Performance for Petroleum Refineries. The requirements of this Subpart apply to Boiler #10.
 4. Subpart GGG - Standards of Performance for Equipment leaks of VOC in Petroleum Refineries applies to the refinery fuel gas supply lines to Boiler #10.
- B. Emission Limitations for Boiler #10 (limitations in Section V.B are applicable prior to startup of Boiler #10 following installation of ULNBs).
 1. Fuel oil burning is not allowed in this unit (ARM 17.8.340, ARM 17.8.749, and ARM 17.8.752).
 2. SO₂ emissions shall not exceed 3.83 lb/hr (ARM 17.8.752).
 3. NO_x emissions shall not exceed 0.058 pounds per million British thermal units (lb/MMBtu) fired and 5.79 lb/hr (ARM 17.8.752).
 4. CO emissions shall not exceed 0.10 lb/MMBtu fired and 9.99 lb/hr (ARM 17.8.752).
 5. VOC emissions shall not exceed 0.015 lb/MMBtu fired and 1.50 lb/hr (ARM 17.8.752).
 6. Opacity shall not exceed 20%, averaged over any 6 consecutive minutes (ARM

17.8.304).

7. Boiler #10 shall be fitted with low NO_x burners with flue gas recirculation (FGR) and have a minimum stack height of 75 feet above ground level (ARM 17.8.340 and ARM 17.8.749).

Ba. Emission Limitations for Boiler #10 (limitations in Section V.Ba are applicable upon startup of Boiler #10 following installation of the ULNBs)

1. Fuel oil burning is not allowed in this unit (ARM 17.8.340, ARM 17.8.749, and ARM 17.8.752).
2. SO₂ emissions shall not exceed:
 - a. 60 ppmv H₂S in refinery fuel gas, 365-day rolling average (ARM 17.8.752)
 - b. 4.14 tons/rolling 12-calendar month total (ARM 17.8.749)
 - c. 2.53 lb/hr (ARM 17.8.752)
3. NO_x emissions shall not exceed:
 - a. 0.03 pounds per million British thermal units – Higher Heating Value (lb/MMBtu-HHV), 365-day rolling average (ARM 17.8.752)
 - b. 13.13 tons/rolling 12-calendar month total (ARM 17.8.749)
 - c. 3.0 lb/hr (ARM 17.8.749)
4. During periods of startup or shutdown, CO emissions shall not exceed 10.0 lb/hr, 24-hour rolling average (ARM 17.8.752). Otherwise, CO emissions shall not exceed:
 - a. 0.05 lb/MMBtu-HHV, 365-day rolling average (ARM 17.8.752)
 - b. 21.88 tons/rolling 12-calendar month total (ARM 17.8.749)
 - c. 5.0 lb/hr (ARM 17.8.749)
5. VOC emissions shall not exceed 2.24 tons/rolling 12-calendar month total (ARM 17.8.752).
6. Opacity shall not exceed 20%, averaged over any 6 consecutive minutes (ARM 17.8.304).
7. Boiler #10 shall be fitted with ULNBs, flue gas recirculation (FGR) and steam injection to the flame zone (ARM 17.8.752), and have a minimum stack height of 75 feet above ground level (ARM 17.8.749).

C. Monitoring Requirements

1. CHS shall install, operate, and maintain a CEMS/CERMS on Boiler #10, to monitor and record the NO_x and O₂ for demonstration of compliance with the limits in Sections V.B and V.Ba, for each day when the boiler is combusting fuel gas (40 CFR 60, Subpart Db).
2. Boiler #10's continuous NO_x and O₂ concentration monitors shall comply with all applicable provisions of 40 CFR Parts 60.5 through 60.13, Subparts Db, Appendix B (Performance Specifications 2 and 3), and Appendix F (Quality Assurance/Quality Control) provisions (ARM 17.8.340, ARM 17.8.105 and ARM 17.8.749).
3. Prior to the startup of Boiler #10 following the installation of the ULNBs, CHS shall install, operate, and maintain a CEMS/CERMS on Boiler #10, to monitor and record the CO for demonstration of compliance with the limits in V.Ba, for each day when the boiler is combusting fuel gas. The CO CEMS shall comply with all applicable provisions of 40 CFR 60, Appendix B (Performance Specification 4) and Appendix F (Quality Assurance/Quality Control) provisions (ARM 17.8.749).
4. CEMS are to be in operation at all times when the emission units are operating, except for quality assurance and control checks, breakdowns, and repairs. In the event the primary CEMS is unable to meet minimum availability requirements, the recipient shall provide a back-up or alternative monitoring system and plan such that continuous compliance can be demonstrated.
5. Prior to the startup of Boiler #10 following the installation of the ULNBs, CHS shall install and operate a volumetric stack flow rate monitor on Boiler #10. The volumetric flow rate monitor shall comply with the Billings/Laurel SIP Pollution Control Plan Exhibit A, Attachment 1 Methods A-1 and B-1 (ARM 17.8.749).

D. Testing Requirements

Boiler #10 shall be tested for NO_x, CO, and VOC concurrently at a minimum of every 5 years or according to another testing/monitoring schedule as may be approved by the Department. Testing shall be conducted for both natural gas and refinery fuel gas (ARM 17.8.105 and ARM 17.8.106).

E. Compliance Determinations

1. Compliance with the opacity limitations shall be determined according to 40 CFR, Part 60, Appendix A, Method 9 Visual Determination of Opacity of Emissions from Stationary Sources (ARM 17.8.749).
2. With exception to the initial performance test period, compliance with the lb/MMBtu limit(s) will be demonstrated using statistically significant F-factor values. The factor will be updated on a regular basis using data from all valid fuel gas samples representative of the fuel gas burned in Boiler #10. The method of compliance demonstration involving F-factor statistical significance is subject to change upon agreement with the Department and CHS (40 CFR 60, Appendix A, Reference Method 19).
3. Compliance with the NO_x lb/hr limit shall be determined using the NO_x CEM and the volumetric stack flow rate monitor (ARM 17.8.749).

4. Compliance with the CO lb/hr limit in Section V.Ba shall be determined using the CO CEM and the volumetric stack flow rate monitor (ARM 17.8.749).

F. Operational and Emission Inventory Reporting Requirements (ARM 17.8.749)

1. CHS shall submit quarterly emission reports to the Department within 30 days of the end of each calendar quarter. Copies of the quarterly emission reports, excess emissions, emission testing reports and other reports required by Sections V.D and V.F.1 shall be submitted to both the Billings regional office and the Helena office. Reporting requirements shall be consistent with 40 CFR Part 60, or as specified by the Department (ARM 17.8.340). The quarterly report shall include the following:
 - a. SO₂ emission data from the refinery fuel gas system continuous H₂S concentration monitor required by Section III. The SO₂ emission rates shall be reported for the following averaging periods:
 - i. Average lb/hr per calendar day
 - ii. Total lb per calendar day
 - iii. Total tons per month
 - b. NO_x emission data from the CEMS, fuel gas flow rate meter, and emission factors developed from the most recent compliance source test. The NO_x emission rates shall be reported for the following averaging periods:
 - i. Average lb/MMBtu per calendar day
 - ii. Total tons per month
 - iii. lb/MMBtu per rolling 30-day average
 - iv. lb/MMBtu per rolling 365-day average (this requirement applicable upon startup of Boiler #10 following installation of the ULNBs)
 - v. Daily average and maximum lb/hr (this requirement applicable upon startup of Boiler #10 following installation of the ULNBs)
 - c. Source or unit operating time during the reporting period and daily, monthly, and quarterly refinery fuel gas and natural gas consumption rates.
 - d. Monitoring downtime that occurred during the reporting period.
 - e. An excess emission summary, which shall include excess emissions (lb/hr) for each pollutant identified in Section V.B.
 - f. Reasons for any emissions in excess of those specifically allowed in Section V.B with mitigative measures utilized and corrective actions taken to prevent a recurrence of the situation.
2. CHS shall comply with the reporting and recordkeeping requirements in 40 CFR 60.7 and 40 CFR 60.49b.

G. Notification

CHS shall provide the Department (both the Billings regional office and the Helena

office) with written notification of the actual installation of the ULNBs on Boiler #10 within 15 days after the actual installation date (ARM 17.8.340 and ARM 17.8.749).

Section VI: Limitations and Conditions for the Truck Loading Rack Vapor Combustion Unit (VCU)

- A. CHS shall comply with all applicable standards and limitations, and the reporting, recordkeeping, and notification requirements of ARM 17.8.342, as specified in 40 CFR Part 63, NESHAP for Source Categories.
1. Subpart A - General Provisions applies to all equipment or facilities subject to a NESHAP for source categories subpart as listed below.
 2. Subpart CC - NESHAP from Petroleum Refineries shall apply to, but not be limited to, the truck ("product") loading rack and VCU.
 3. The product loading rack and vapor combustion unit shall be operated and maintained as follows:
 - a. CHS's product loading rack shall be equipped with a vapor collection system designed to collect the organic compound vapors displaced from cargo tanks during gasoline product loading (ARM 17.8.342).
 - b. CHS's collected vapors shall be routed to the VCU at all times. In the event the VCU is inoperable, CHS may continue to load distillates with a Reid vapor pressure of less than 27.6 kilopascals, provided the Department is notified in accordance with the requirements of ARM 17.8.110 (ARM 17.8.749).
 - c. The vapor collection and liquid loading equipment shall be designed and operated to prevent gauge pressure in the gasoline cargo tank from exceeding 4,500 Pascals (Pa) (450 millimeters (mm) of water) during product loading. This level shall not be exceeded when measured by the procedures specified in the test methods and procedures in 40 CFR 60.503(d) (ARM 17.8.342).
 - d. No pressure-vacuum vent in the permitted terminal's vapor collection system shall begin to open at a system pressure less than 4,500 Pa (450 mm of water) (ARM 17.8.342).
 - e. The vapor collection system shall be designed to prevent any VOC vapors collected at one loading rack from passing to another loading rack (ARM 17.8.342).
 - f. Loadings of liquid products into gasoline cargo tanks shall be limited to vapor-tight gasoline cargo tanks, using the following procedures (ARM 17.8.342):
 - i. CHS shall obtain annual vapor tightness documentation described in the test methods and procedures in 40 CFR 63.425(e) for each gasoline cargo tank that is to be loaded at the product loading rack.
 - ii. CHS shall require the cargo tank identification number to be recorded as each gasoline cargo tank is loaded at the terminal.

- iii. CHS shall cross-check each tank identification number obtained during product loading with the file of tank vapor tightness documentation within 2 weeks after the corresponding cargo tank is loaded.
- iv. CHS shall notify the owner or operator of each non-vapor-tight cargo tank loaded at the product loading rack within 3 weeks after the loading has occurred.
- v. CHS shall take the necessary steps to ensure that any non-vapor-tight cargo tank will not be reloaded at the product loading rack until vapor tightness documentation for that cargo tank is obtained, which documents that:
 - aa. The gasoline cargo tank meets the applicable test requirements in 40 CFR 63.425(e) to this permit.
 - bb. For each gasoline cargo tank failing the test requirements in 40 CFR 63.425(f) or (g), the gasoline cargo tank must either:
 - 1. Before the repair work is performed on the cargo tank, meet the test requirements in 40 CFR 63.425 (g) or (h), or
 - 2. After repair work is performed on the cargo tank before or during the tests in 40 CFR 63.425 (g) or (h), subsequently pass the annual certification test described in 40 CFR 63.425(e).
- g. CHS shall ensure that loadings of gasoline cargo tanks at the product loading rack are made only into cargo tanks equipped with vapor collection equipment that is compatible with the terminal's vapor collection system (ARM 17.8.342).
- h. CHS shall ensure that the terminal's and the cargo tank's vapor recovery systems are connected during each loading of a gasoline cargo tank at the product loading rack (ARM 17.8.342).
- i. The VCU stack shall be 35 feet above grade (ARM 17.8.749).

B. Emission Limitations for the Truck Loading Rack VCU

- 1. The total VOC emissions to the atmosphere from the VCU due to loading liquid product into cargo tanks shall not exceed 10.0 milligrams per liter (mg/L) of gasoline loaded (ARM 17.8.342 and ARM 17.8.752).
- 2. The total CO emissions to the atmosphere from the VCU due to loading liquid product into cargo tanks shall not exceed 10.0 mg/L of gasoline loaded (ARM 17.8.752).
- 3. The total NO_x emissions to the atmosphere from the VCU due to loading liquid product into cargo tanks shall not exceed 4.0 mg/L of gasoline loaded (ARM 17.8.752).

4. CHS shall not cause or authorize to be discharged into the atmosphere from the enclosed VCU any visible emissions that exhibit an opacity of 20% or greater over any 6 consecutive minutes (ARM 17.8.304(2)).

C. Monitoring Requirements

1. CHS shall perform the testing and monitoring procedures specified in 40 CFR §§63.425 and 63.427 of Subpart R, except §63.425(d) or §63.427(c) (ARM 17.8.342).
2. CHS shall install and continuously operate a thermocouple and an associated recorder, or an ultraviolet flame detector and relay system, which will render the loading rack inoperable if a flame is not present at the VCU, or any other equivalent device, to detect the presence of a flame (ARM 17.8.342 and ARM 17.8.752).
3. CHS shall monitor and maintain all pumps, shutoff valves, relief valves and other piping and valves associated with the gasoline loading rack as described in 40 CFR 60.482-1 through 60.482-10.

D. Testing Requirements

1. CHS shall comply with all test methods and procedures as specified by Subpart R §63.425 (a) through (c), and §63.425 (e) through (h). This shall apply to, but not be limited to, the product loading rack, the vapor processing system, and all gasoline equipment located at the product loading rack.
2. The product loading rack VCU shall be tested for VOCs, and compliance demonstrated with the emission limitation contained in Section VI.B.1 on an every 5-year basis or according to another testing/monitoring schedule as may be approved by the Department. CHS shall perform the test methods and procedures as specified in 40 CFR 63.425, Subpart R (ARM 17.8.105 and 17.8.342).
3. The product loading rack VCU shall be tested for CO and NO_x, concurrently, and compliance demonstrated with the CO and NO_x emission limitations contained in Section VI.B.2 and 3, as required by the Department (ARM 17.8.105).

E. Operational and Emission Inventory Reporting Requirements

CHS shall supply the Department with the following reports, as required by 40 CFR Part 63 (ARM 17.8.342).

1. Subpart CC - CHS shall keep all records and furnish all reports to the Department as required by 40 CFR Part 63.428 (b) and (c), (g)(1), and (h)(1) through (h)(3) of Subpart R.
2. Subpart CC - CHS shall keep all records and furnish all reports to the Department as required by 40 CFR Part 63.654.

Section VII: Limitations and Conditions for the No. 1 Crude Unit

- A. CHS shall comply with all applicable standards and limitations, and the monitoring,

recordkeeping and reporting requirements contained in 40 CFR Part 60 for the No. 1 Crude Unit. The following subparts, at a minimum, are applicable (ARM 17.8.340):

1. Subpart A - General Provisions applies to all equipment or facilities subject to an NSPS subpart listed below.
2. Subpart GGG - Standards of Performance for Equipment Leaks of VOC in the Petroleum Refineries applies to the various new pumps, valves, flanges, and other equipment in Hazardous Air Pollutant (HAP) service within the No. 1 Crude Unit (40 CFR 63, Subpart CC: Maximum Achievable Control Technology (MACT) Standards for Petroleum Refineries).

B. Emission Control Requirements for No. 1 Crude Unit (ARM 17.8.752):

1. The No. 1 Crude Unit shall be maintained and operated as per the Leak Detection and Repair (LDAR) Program. The LDAR program would apply to new equipment in both HAP and non-HAP VOC service in the No. 1 Crude Unit. The LDAR program would not apply to existing equipment in non-HAP service undergoing retrofit measures.
2. CHS shall monitor and maintain all pumps, shutoff valves, relief valves and other piping and valves associated (as defined above) with the No. 1 Crude Unit as described in 40 CFR 60.482-1 through 60.482-10. Records of monitoring and maintenance shall be maintained on site for a minimum of 2 years.

Section VIII: Limitations and Conditions for the ULSD Unit (900 Unit) and Hydrogen Plant (1000 Unit)

A. CHS shall comply with all applicable standards and limitations, and the monitoring, recordkeeping, and reporting requirements contained in 40 CFR Part 60, NSPS. The following subparts, at a minimum, are applicable (ARM 17.8.340):

1. Subpart A - General Provisions applies to all equipment or facilities subject to an NSPS subpart listed below.
2. Subpart J - Standards of Performance for Petroleum Refineries applies to the two new ULSD Unit heaters (H-901 and H-902) and the Hydrogen Plant heater (H-1001).
3. Subpart GGG - Standards of Performance for Equipment leaks of VOC in Petroleum Refineries applies to the ULSD Unit and the Hydrogen Plant fugitive piping equipment in VOC service.
4. Subpart QQQ - Standards of Performance for VOC Emissions from Petroleum Refinery Wastewater Systems applies to the ULSD Unit and Hydrogen Plant process drains.

B. CHS shall comply with all applicable standards and limitations, and the reporting, recordkeeping, and notification requirements specified in 40 CFR Part 63, NESHAP for Source Categories (ARM 17.8.342).

1. Subpart A – General Provisions applies to all equipment or facilities subject to a NESHAP for source categories subpart as listed below.

2. Subpart CC – NESHAP from Petroleum Refineries shall apply to, but not be limited to, Tank 96 when it is utilized in gasoline service.
- C. CHS shall not cause or authorize emissions to be discharged into the outdoor atmosphere from any source installed after November 23, 1968, that exhibit an opacity of 20% or greater averaged over 6 consecutive minutes. This applies to the sources in the ULSD Unit and Hydrogen Plant (ARM 17.8.304 (2)).
- D. Limitations on Individual Sources (ARM 17.8.752)
1. Reactor Charge Heater H-901
 - a. SO₂ emissions from H-901 shall not exceed (ARM 17.8.752):
 - i. 1.96 tons/rolling 12-calendar month total
 - ii. 0.90 lb/hr
 - b. NO_x emissions from H-901 shall not exceed (ARM 17.8.752):
 - i. 2.19 tons/rolling 12-calendar month total
 - ii. 0.50 lb/hr
 - c. CO emissions from H-901 shall not exceed (ARM 17.8.752):
 - i. 9.00 tons/rolling 12-calendar month total
 - ii. 2.05 lb/hr
 - d. VOC Emissions from H-901 shall not exceed 0.59 tons/rolling 12-calendar month total (ARM 17.8.752).
 - e. CHS shall not fire fuel oil in this unit (ARM 17.8.752 and ARM 17.8.749).
 2. Fractionator Reboiler H-902
 - a. SO₂ emissions from H-902 shall not exceed (ARM 17.8.752):
 - i. 3.95 tons/rolling 12-calendar month total
 - ii. 1.80 lb/hr
 - b. NO_x emissions from H-902 shall not exceed (ARM 17.8.752):
 - i. 4.40 tons/rolling 12-calendar month total
 - ii. 1.00 lb/hr
 - c. CO emissions from H-902 shall not exceed (ARM 17.8.752):
 - i. 8.50 tons/rolling 12-calendar month total
 - ii. 1.94 lb/hr
 - d. VOC Emissions from H-902 shall not exceed 1.19 tons/rolling 12-calendar month total (ARM 17.8.752).
 - e. CHS shall not fire fuel oil in this unit (ARM 17.8.752 and ARM

17.8.749).

3. Reformer Heater H-1001

- a. SO₂ emissions from H-1001 shall not exceed (ARM 17.8.752):
 - i. 12.69 tons/rolling 12-calendar month total
 - ii. 5.80 lb/hr
- b. NO_x emissions from H-1001 shall not exceed (ARM 17.8.752):
 - i. 28.31 tons/rolling 12-calendar month total
 - ii. 6.46 lb/hr
- c. CO emissions from H-1001 shall not exceed (ARM 17.8.752):
 - i. 400 ppmvd at 3% oxygen on a 30-day rolling average
 - ii. 14.15 tons/rolling 12-calendar month total
 - iii. 3.23 lb/hr
- d. VOC Emissions from H-1001 shall not exceed 3.82 tons/rolling 12-calendar month total (ARM 17.8.752).
- e. CHS shall not fire fuel oil in this unit (ARM 17.8.752 and ARM 17.8.749).

E. Monitoring Requirements (ARM 17.8.340).

- 1. CHS shall install and operate the following (CEMS/CERMS) for H-1001:
 - a. O₂ (40 CFR 60, Subpart J)
 - b. SO₂ (40 CFR 60, Subpart J)
- 2. CEMS and CERMS required by this permit shall comply with all applicable provisions of 40 CFR Part 60.5 through 60.13, Subpart Db 60.40b through 60.49b, Subparts J, 60.100-108, and Appendix B, Performance Specifications 2, 3, 4 or 4A, and Appendix F. The volumetric flow rate monitor shall, if required, comply with the Billings/Laurel SIP Pollution Control Plan Exhibit A, Attachment 1 Methods A-1 and B-1.
- 3. CEMS are to be in operation at all times when the emission units are operating, except for quality assurance and control checks, breakdowns, and repairs. In the event the primary CEMS is unable to meet minimum availability requirements, the recipient shall provide a back-up or alternative monitoring system and plan such that continuous compliance can be demonstrated.

F. Testing Requirements

- 1. The Reactor Charge Heater (H-901) shall be tested every two years, or according to another testing/monitoring schedule as may be approved by the Department,

for NO_x and CO, concurrently, and the results submitted to the Department in order to demonstrate compliance with the NO_x and CO emission limits contained in Section VIII.D.1.b and c (ARM 17.8.105 and ARM 17.8.749).

2. The Fractionator Reboiler (H-902) shall be tested every two years, or according to another testing/monitoring schedule as may be approved by the Department, for NO_x and CO, concurrently, and the results submitted to the Department in order to demonstrate compliance with the NO_x and CO emission limits contained in Section VIII. D.2.b and c (ARM 17.8.105 and ARM 17.8.749).
3. The Reformer Heater (H-1001) shall be tested annually, or according to another testing/monitoring schedule as may be approved by the Department, for NO_x and CO, concurrently, and the results submitted to the Department in order to demonstrate compliance with the NO_x and CO emission limits contained in Section VIII.D.3.b and c (ARM 17.8.105 and ARM 17.8.749).

G. Compliance Determinations (ARM 17.8.749).

1. In addition to stack testing required in Section VIII.F, compliance determinations for the SO₂ limit in Section VIII.D.3 for H-1001 shall also be based upon monitoring data as required in Section VIII.E.
2. Compliance with the opacity limitation listed in Section VIII.C shall be determined using EPA Reference Method 9 testing by a qualified observer.

H. Operational and Emission Inventory Reporting Requirements (ARM 17.8.749)

CHS shall prepare and submit a quarterly emission report within 30 days of the end of each calendar quarter. Copies of the quarterly emission report shall be submitted to both the Billings regional office and the Helena office of the Department. The quarterly report shall also include the following:

1. Source or unit operating time during the reporting period and quarterly fuel gas consumption rates and SO₂ in the H-1001 stack.
2. Monitoring downtime that occurred during the reporting period.
3. A summary of excess emissions or applicable concentrations for each pollutant and the averaging period identified in VIII.D.1 through 3.
4. Compliance determinations for hourly, 24-hour, and annual limits specifically allowed in VIII.D.1 through 3.
5. Reasons for any emissions in excess of those specifically allowed in VIII. D.1 through 3 with mitigative measures utilized and corrective actions taken to prevent a recurrence of the situation.

Section IX: Limitations and Conditions for the TGTU for Zone A's SRU #1 and SRU #2 trains and Zone A's Sulfur Recovery Plants

- A. CHS shall comply with all applicable standards and limitations, and the monitoring,

recordkeeping, and reporting requirements contained in 40 CFR Part 60, NSPS. The following subparts, at a minimum, are applicable (ARM 17.8.340):

1. Subpart A - General Provisions applies to all equipment or facilities subject to an NSPS subpart listed below.
 2. Subpart J - Standards of Performance for Petroleum Refineries applies to Zone A's SRU #1 and #2 tail gas incinerator (SRU-AUX-4) stack.
 3. Subpart QQQ - Standards of Performance for VOC Emissions from Petroleum Refinery Wastewater Systems applies to the TGTU process drains as applicable.
- B. CHS shall comply with all applicable standards and limitations, and the reporting, recordkeeping, and notification requirements specified in 40 CFR Part 63, NESHAP for Source Categories (ARM 17.8.342).
1. Subpart A – General Provisions applies to all equipment or facilities subject to a NESHAP for source categories subpart as listed below.
 2. Subpart UUU – MACT Standard for Catalytic Cracking Units, Catalytic Reforming Units, and Sulfur Recovery Units. CHS shall comply with Subpart UUU by complying with 40 CFR Part 60, NSPS Subpart J.
- C. CHS shall not cause or authorize emissions to be discharged into the outdoor atmosphere from any source installed after November 23, 1968, that exhibit an opacity of 20% or greater averaged over 6 consecutive minutes. This applies to the sources in the TGTU (ARM 17.8.304 (2)).
- D. The Department determined, based on modeling provided by CHS, that the SRU-AUX-4 stack shall be maintained at a height no less than 132 feet.
- E. Limitations on Individual Sources
1. SO₂ emissions from the SRU-AUX-4 stack shall not exceed:
 - a. 250 ppm, rolling 12-hour average corrected to 0% oxygen, on a dry basis (Consent Decree paragraph 63 and ARM 17.8.749)
 - b. 200 ppm, rolling 12-month average corrected to 0% oxygen, on a dry basis
 - c. 40.66 tons/rolling 12-month total
 - d. 11.60 lb/hr
 - e. 278.40 lb/day
 2. CHS shall operate and maintain the TGTU on the Zone A SRU to limit SO₂ emissions from the Zone A SRU-AUX-4 stack to no more than 200 ppm on a rolling 12-month average corrected to 0% oxygen on a dry basis.
 3. NO_x emissions from the SRU-AUX-4 stack shall not exceed:
 - a. 4.8 tons/rolling 12-calendar month total
 - b. 1.09 lb/hr

4. CHS shall not fire fuel oil in this unit (ARM 17.8.749).

F. Monitoring Requirements

1. CHS shall install and operate the following CEMS/CERMS on the Zone A SRU-AUX-4 Stack (CHS Inc, Consent Decree):
 - a. SO₂ (40 CFR 60, Subpart J and Billings SO₂ SIP)
 - b. O₂ (40 CFR 60, Subpart J)
 - c. Volumetric Flow Rate (Billings SO₂ SIP)
2. CEMS and CERMS required by this permit shall comply with all applicable provisions of 40 CFR Parts 60.5 through 60.13, Subparts J, 60.100-108 and Appendix B, Performance Specifications 2, 3, 6, and Appendix F. The volumetric flow rate monitor shall comply with the Billings/Laurel SIP Pollution Control Plan Exhibit A, Attachment 1 Methods A-1 and B-1.
3. CEMS are to be in operation at all times when the emission units are operating, except for quality assurance and control checks, breakdowns, and repairs. In the event the primary CEMS is unable to meet minimum availability requirements, the recipient shall provide a back-up or alternative monitoring system and plan such that continuous compliance can be demonstrated.

G. Testing Requirements

The SRU-AUX-4 Stack shall be tested annually, or according to another testing/monitoring schedule as may be approved by the Department for SO₂, and shall be tested on an every 5-year basis, or according to another testing/monitoring schedule as may be approved by the Department, for NO_x. The results shall be submitted to the Department in order to demonstrate compliance with the SO₂ and NO_x emission limits contained in Sections IX.E.1, 2, and 3 (ARM 17.8.105 and ARM 17.8.749).

H. Compliance Determinations (ARM 17.8.749)

1. In addition to the testing required in Section IX.G, compliance determinations for ppm concentration, hourly, 3-hour, 24-hour, rolling 12-month, and annual SO₂ limits for the SRU-AUX-4 Stack shall be based upon CEMS data utilized for SO₂ as required in Section IX.F.1.
2. Compliance with the opacity limitation listed in Section IX.C shall be determined using EPA reference method 9 testing by a qualified observer.

I. Operational and Emission Inventory Reporting Requirements (ARM 17.8.749)

Emission reporting for SO₂ from the emission rate monitors shall consist of a daily 24-hour average concentration (ppm SO₂, corrected to 0% O₂) and a 24-hour total (lb/day) for each calendar day. CHS shall submit a quarterly emission report within 30 days of the end of each calendar quarter. Copies of the quarterly emission report shall be submitted to both the Billings regional office and the Helena office of the Department. The quarterly report shall also include the following:

1. Source or unit operating time during the reporting period and quarterly fuel gas consumption rates.
2. Monitoring downtime that occurred during the reporting period.

3. A summary of excess emissions or applicable concentrations for each pollutant and the averaging period identified in Section IX.E.
4. Compliance determinations for hourly, 24-hour, and annual limits specifically allowed in Section IX.E.
5. Reasons for any emissions in excess of those specifically allowed in Section IX.E with mitigative measures utilized and corrective actions taken to prevent a recurrence of the situation.

Section X: Limitations and Conditions for the FCCU and related units

- A. CHS shall comply with all applicable standards and limitations, and the monitoring, recordkeeping and reporting requirements contained in 40 CFR Part 60, NSPS. The following subparts, at a minimum, are applicable:
 1. Subpart A - General Provisions applies to all equipment or facilities subject to an NSPS subpart listed below.
 2. Subpart J - Standards of Performance for Petroleum Refineries applies to the FCCU Regenerator for SO₂, CO, PM and opacity.
- B. CHS shall comply with all applicable standards and limitations, and the reporting, recordkeeping, and notification requirements specified in 40 CFR Part 63, NESHAPs for Source Categories (ARM 17.8.342):
 1. Subpart A – General Provisions applies to all equipment or facilities subject to a NESHAP for source categories subpart as listed below.
 2. Subpart CC – Refinery MACT I shall apply to, but not be limited to, certain parts of the FCCU piping.
 3. Subpart UUU – Refinery MACT II shall apply to, but not be limited to, the FCCU.
- C. CHS shall not cause or authorize emissions to be discharged into the outdoor atmosphere from any source installed on or before November 23, 1968, that exhibit an opacity of 40% or greater averaged over 6 consecutive minutes (ARM 17.8.304).
- D. Limitations on Individual Emitting Units
 1. FCCU Regenerator Stack
 - a. CO emissions from the FCCU Regenerator Stack shall not exceed 500 ppm at 0% O₂ per 1-hour time period (CHS Consent Decree Paragraph 41, ARM 17.8.340, 40 CFR Part 60, Subpart J; and ARM 17.8.752).
 - b. CO emissions from the FCCU Regenerator Stack shall not exceed 100 ppm_{vd} at 0% O₂, on a 365-day rolling average basis (CHS Consent Decree Paragraph 41).
 - c. CHS shall not exceed 50 ppm SO₂ by volume (corrected to 0% O₂) on a 7-day rolling average and shall also comply with an SO₂ concentration

limit of 25 ppm_{vd} at 0% O₂ on a 365-day rolling average basis (CHS Consent Decree Paragraphs 32-33).

- d. PM emissions from the FCCU shall be controlled with an ESP. PM emissions from the FCCU shall not exceed 1.0 lb PM/1,000 lb of coke burned (ARM 17.8.752).
- e. NO_x emissions from the FCCU shall not exceed 65.1 ppm_{vd} at 0% oxygen on a 365-day rolling average basis. This long-term limit shall apply at all times (including during startup, shutdown and malfunction) that the FCCU is operating (CHS Consent Decree Paragraph 29 and ARM 17.8.752).
- f. NO_x emissions from the FCCU shall not exceed 102 ppm_{vd} at 0% oxygen on a 7-day rolling average basis. This short-term limit shall exclude periods of startup, shutdown, malfunction or hydrotreater outages, but shall apply at all other times that the FCCU is operating. For days and hours in which the FCCU is not operating, no NO_x value shall be used in the average, and those periods shall be skipped in determining compliance with the 7-day and 365-day averages (CHS Consent Decree Paragraph 29 and ARM 17.8.752).

2. FCC Charge Heater (FCC-Heater-1)

- a. The FCC Charge Heater (FCC-Heater-1) shall not exceed 49.7 MMBtu/hr on a rolling 12-calendar month basis (ARM 17.8.749).
- b. NO_x emissions from the FCC Charge Heater (FCC-Heater-1) shall not exceed (ARM 17.8.749):
 - i. 22.87 tons/rolling 12-calendar month total
 - ii. 6.27 lb/hr
- c. CO emissions from the FCC Charge Heater (FCC-Heater-1) shall not exceed (ARM 17.8.749):
 - i. 19.21tons/rolling 12-calendar month total
 - ii. 5.26 lb/hr

E. Monitoring Requirements

- 1. CHS shall install and operate the following CEMS/CERMS on the FCCU Regenerator Stack (CHS Consent Decree):
 - a. CO
 - b. NO_x
 - c. SO₂
 - d. O₂
 - e. Opacity (40 CFR 63, Subpart UUU)
- 2. CEMS and CERMS required by this permit shall comply with all applicable provisions of 40 CFR Parts 60.5 through 60.13, Subparts J, 60.100-108 and Appendix B, Performance Specifications 1, 2, 3, 6, and Appendix F. The volumetric flow rate monitor shall comply with the Billings/Laurel SIP Pollution Control Plan Exhibit A, Attachment 1 Methods A-1 and B-1.

3. The FCCU CEMS, stack gas volumetric flow rate CEMS, and the fuel gas flow meters shall comply with all applicable requirements of the Billings/Laurel SO₂ SIP Emission Control Plan, including Exhibit A and Attachments, adopted by the Board of Environmental Review, June 12, 1998, and stipulated to by Cenex Harvest States Cooperative and its successor CHS.
4. CEMS are to be in operation at all times when the emission units are operating, except for quality assurance and control checks, breakdowns, and repairs. In the event the primary CEMS is unable to meet minimum availability requirements, the recipient shall provide a back-up or alternative monitoring system and plan such that continuous compliance can be demonstrated.

F. Testing Requirements

1. CHS shall follow the stack protocol specified in 40 CFR 60.106(b)(2) to measure PM emissions from the FCCU Regenerator stack. CHS shall conduct the PM tests on an annual basis or on another testing schedule as may be approved by the Department (CHS Consent Decree Paragraph 38 and ARM 17.8.105).
2. The FCC Charge Heater (FCC-Heater-1) shall be tested annually, or according to another testing/ monitoring schedule as may be approved by the Department, for NO_x and CO, concurrently, and the results submitted to the Department in order to demonstrate compliance with the NO_x and CO emission limits contained in Section X.D.2.b and c (ARM 17.8.105 and ARM 17.8.749).

G. Compliance Determinations

1. Compliance determinations for the FCCU Regenerator Stack emission limits in Section X.D for NO_x, CO, and SO₂ shall be based upon monitor data, as required in Section X.E.1.
2. Compliance with the opacity limitation listed in Section X.C shall be determined using EPA reference method 9 observations by a qualified observer or a certified continuous opacity monitor system (COMS).

H. Operational and Emission Inventory Reporting Requirements (ARM 17.8.749)

CHS shall submit quarterly emission reports to the Department based on data from the installed CEMS/CERMS. Emission reporting for CO from the emission monitor shall consist of a daily maximum 1-hour average (ppm) for each calendar day. CHS shall submit the quarterly emission reports within 30 days of the end of each calendar quarter. Copies of the quarterly emission report shall be submitted to both the Billings regional office and the Helena office of the Department. The quarterly report shall also include the following:

1. Source or unit operating time during the reporting period and the 7-day and 365-day rolling average SO₂ concentrations (ppmv).
2. The daily and monthly NO_x averages in ppm, corrected to 0% O₂.
3. Monitoring downtime that occurred during the reporting period.
4. A summary of excess emissions or applicable concentrations for each pollutant and the averaging period identified in Section X.D.

5. Compliance determinations for hourly, 24-hour, and annual limits specifically allowed in Section X.D (ARM 17.8.749).
6. Reasons for any emissions in excess of those specifically allowed in Section X.D with mitigative measures utilized and corrective actions taken to prevent a recurrence of the situation.

Section XI: Limitations and Conditions for the Naptha Hydrotreating Unit, Delayed Coker Unit and Zone E SRU/TGTU/TGI

- A. CHS shall comply with all applicable standards and limitations, and the monitoring, recordkeeping, and reporting requirements contained in 40 CFR Part 60, NSPS. The following subparts, at a minimum, are applicable (ARM 17.8.340):
 1. Subpart A - General Provisions applies to all equipment or facilities subject to an NSPS subpart listed below.
 2. Subpart J - Standards of Performance for Petroleum Refineries applies to the NHT Charge Heater (H-8301), the Coker Charge Heater (H-7501), and the Zone E SRU/TGTU/TGI.
 3. Subpart GGG - Standards of Performance for Equipment leaks of VOC in Petroleum Refineries applies to the Naptha Hydrotreating Unit and the Delayed Coker Unit fugitive piping equipment in VOC service.
 4. Subpart QQQ - Standards of Performance for VOC Emissions from Petroleum Refinery Wastewater Systems applies to the Delayed Coker Unit process drains.
- B. CHS shall comply with all applicable standards and limitations, and the reporting, recordkeeping, and notification requirements specified in 40 CFR Part 63, NESHAPs for Source Categories (ARM 17.8.342):
 1. Subpart A – General Provisions applies to all equipment or facilities subject to a NESHAP for source categories subpart as listed below.
 2. Subpart CC – Refinery MACT I shall apply to, but not be limited to, affected sources or the collection of emission points as defined in this subpart.
 3. Subpart UUU – Refinery MACT II shall apply to, but not be limited to, the Zone E SRU/TGTU/TGI.
- C. CHS shall not cause or authorize emissions to be discharged into the outdoor atmosphere from any source installed after November 23, 1968, that exhibit an opacity of 20% or greater averaged over 6 consecutive minutes. This applies to the sources in the Delayed Coker Unit (ARM 17.8.304 (2)).
- D. Limitations on Individual Sources
 1. NHT Charge Heater (H-8301)
 - a. SO₂ emissions from the NHT Charge Heater (H-8301) shall not exceed (ARM 17.8.752):

- i. 1.54 tons/rolling 12-calendar month total
 - ii. 0.70 lb/hr
 - b. NO_x emissions from the NHT Charge Heater (H-8301) shall not exceed (ARM 17.8.752):
 - i. 6.55 tons/rolling 12-calendar month total
 - ii. 1.50 lb/hr
 - c. CO emissions from the NHT Charge Heater (H-8301) shall not exceed 400 ppm_{vd} at 3% oxygen on a 30-day rolling average (ARM 17.8.752).
 - d. VOC Emissions from the NHT Charge Heater (H-8301) shall not exceed 0.86 tons/rolling 12-calendar month total (ARM 17.8.752).
 - e. CHS shall not fire fuel oil in this unit (ARM 17.8.340; 40 CFR 60, Subpart J; and ARM 17.8.752).
- 2. Coker Charge Heater (H-7501)
 - a. SO₂ emissions from the Coker Charge Heater (H-7501) shall not exceed (ARM 17.8.752):
 - i. 6.61 tons/rolling 12-calendar month total
 - ii. 3.02 lb/hr
 - b. NO_x emissions from the Coker Charge Heater (H-7501) shall not exceed (ARM 17.8.752):
 - i. 28.2 tons/rolling 12-calendar month total
 - ii. 6.44 lb/hr
 - c. CO emissions from the Coker Charge Heater (H-7501) shall not exceed (ARM 17.8.752):
 - i. 400 ppm_{vd} at 3% oxygen on a 30-day rolling average
 - ii. 35.2 tons/rolling 12-calendar month total
 - iii. 8.05 lb/hr
 - d. VOC Emissions from the Coker Charge Heater (H-7501) shall not exceed 1.41 tons/rolling 12-calendar month total (ARM 17.8.752).
 - e. CHS shall not fire fuel oil in this unit (ARM 17.8.340; 40 CFR 60, Subpart J; and ARM 17.8.752).
- 3. The Coker unit flare shall operate with a continuous pilot flame and a continuous pilot flame-operating device and meet applicable control device requirements of 40 CFR Part 63.11 (40 CFR 63.11, ARM 17.8.752).
- 4. VOC emissions from the Sour Water Storage Tank (TK-129) shall be controlled by the installation and use of an internal floating roof and a submerged fill pipe (ARM 17.8.752).
- 5. VOC emissions from the Coker Sludge Storage Tank (TK-7504) shall be controlled by the installation and use of a fixed roof, a submerged fill pipe, and a conservation vent (ARM 17.8.752).

6. Coke processing operations
 - a. CHS shall store onsite coke in the walled enclosure for coke storage only. Onsite coke storage shall be limited to a volume that is contained within the walled enclosure. Storage of coke outside of the walled enclosure is prohibited (ARM 17.8.752).
 - b. The coke pile shall not exceed the height of the enclosure walls adjacent to the pile at any time (ARM 17.8.752).
 - c. CHS shall not cause or authorize emissions to be discharged into the atmosphere from coke handling without taking reasonable precautions to control emissions of airborne particulate matter. CHS shall wet the coke as needed to comply with the reasonable precautions standard (ARM 17.8.308 and ARM 17.8.752).
 - d. CHS shall install and maintain enclosures surrounding the coke conveyors, coke transfer drop points (not including the location at which coke is transferred from the front-end loader to the initial coke sizing screen), and crusher (ARM 17.8.752).
 - e. CHS shall install and maintain a telescoping loading spout for loading coke into railcars (ARM 17.8.752).
 - f. Alternate Coke Handling Method: In the event the conveyors are inoperable (as described in Section XI.D.6.d and e) due to either planned or unplanned maintenance activities, CHS may transport uncrushed coke only from the coke storage area to the railcar using a front-end loader. The requirements specified in Section XI.D.6.a – c still apply. The alternate coke handling method is limited to 24 batches per year (ARM 17.8.752).

7. Zone E SRU/TGTU/TGI
 - a. SO₂ emissions from the Zone E SRU/TGTU/TGI shall not exceed (ARM 17.8.752):
 - i. 49.4 tons/rolling 12-calendar month total (based on 200 ppm, rolling 12-month average corrected to 0% oxygen, on a dry basis)
 - ii. 14.1 lb/hr (based on 250 ppm, rolling 12-hour rolling average corrected to 0% oxygen, on a dry basis)
 - b. CHS shall operate and maintain the TGTU on the Coker Unit to limit SO₂ emissions from the Coker Unit stack to no more than 200 ppm on a rolling 12-month average corrected to 0% oxygen on a dry basis.
 - c. NO_x emissions from the Zone E SRU/TGTU/TGI shall not exceed (ARM 17.8.749):
 - i. 4.62 tons/rolling 12-calendar month total
 - ii. 1.05 lb/hr

- d. CHS shall not cause or authorize to be discharged into the atmosphere from the TGI:
 - i. Any visible emissions that exhibit an opacity of 10% or greater (ARM 17.8.752)
 - ii. Any particulate emissions in excess of 0.10 gr/dscf corrected to 12% CO₂ (ARM 17.8.752)
- 8. CHS is required to operate and maintain a mist eliminator on the Coker Cooling Tower that limits PM₁₀ emissions to no more than 0.002% of circulating water flow (ARM 17.8.752).
- 9. Coke Drum Steam Vent
 - a. While operating the delayed coking unit, CHS shall depressurize to 5 lb per square inch gauge (psig) during reactor vessel depressurizing and vent the exhaust gases to the fuel gas recovery system for combustion in a fuel gas combustion device. The vessel shall not be opened to atmosphere until the pressure is 5.0 psig or lower. (ARM 17.8.749).
 - b. VOC emissions from the Coke Drum Steam Vent shall not exceed 18.10 tons/yr as determined on a monthly rolling 12-month average (ARM 17.8.749).
 - c. PM₁₀ emissions from the Coke Drum Steam Vent shall not exceed 4.52 tons/yr as determined on a monthly rolling 12-month average (ARM 17.8.749).

E. Monitoring requirements

- 1. CHS shall install and operate the following (CEMS/CERMS):
 - Zone E SRU/TGTU/TGI (Billings/Laurel SO₂ SIP)
 - i. SO₂ (40 CFR 60, Subpart J)
 - ii. O₂ (40 CFR 60, Subpart J)
 - iii. Volumetric Flow Rate (Billings/Laurel SO₂ SIP)
- 2. CEMS and CERMS required by this permit shall comply with all applicable provisions of 40 CFR Part 60.5 through 60.13, Subpart Db 60.40b through 60.49b, Subparts J, 60.100-108, and Appendix B, Performance Specifications 2, 3, 4 or 4A, 6, and Appendix F. The volumetric flow rate monitor shall comply with the Billings/Laurel SIP Pollution Control Plan Exhibit A, Attachment 1 Methods A-1 and B-1
- 3. The Delayed Coker Unit SO₂ CEMS, stack gas volumetric flow rate CEMS, and fuel gas flow rate meters shall comply with all applicable requirements of the Billings/Laurel SO₂ SIP Emission Control Plan, including Exhibit A and Attachments, adopted by the Board of Environmental Review, June 12, 1998, and stipulated to by Cenex Harvest States Cooperative and its successor CHS.
- 4. CEMS are to be in operation at all times when the emission units are operating,

except for quality assurance and control checks, breakdowns, and repairs. In the event the primary CEMS is unable to meet minimum availability requirements, the recipient shall provide a back-up or alternative monitoring system and plan such that continuous compliance can be demonstrated.

5. CHS shall continuously monitor the pressure in the coke drums such that the pressure at which each drum is depressurized can be determined (ARM 17.8.749).

F. Testing Requirements

1. The NHT Charge Heater (H-8301) shall be tested every two years, or according to another testing/monitoring schedule as may be approved by the Department, for NO_x and CO, concurrently, and the results submitted to the Department in order to demonstrate compliance with the NO_x and CO emission limits contained in Section XI.D.1.b and c (ARM 17.8.105 and ARM 17.8.749).
2. The Coker Charge Heater (H-7501) shall be tested annually, or according to another testing/monitoring schedule as may be approved by the Department, for NO_x and CO, concurrently, and the results submitted to the Department in order to demonstrate compliance with the NO_x and CO emission limits contained in Section XI.D.2.b and c (ARM 17.8.105 and ARM 17.8.749).
3. The Zone E SRU/TGTU/TGI stack shall be tested annually, or according to another testing/monitoring schedule as may be approved by the Department for SO₂, and shall be tested on an every 5-year basis, or according to another testing/monitoring schedule as may be approved by the Department, for NO_x. The results shall be submitted to the Department in order to demonstrate compliance with the SO₂ and NO_x emission limits contained in Section XI.D.7.a, b, and c, respectively (ARM 17.8.105 and ARM 17.8.749).

G. Compliance Determinations (ARM 17.8.749).

1. In addition to the testing required in Section XI.F, compliance determinations for ppm concentration, hourly, and rolling 12-month SO₂ limits for the Zone E SRU/TGTU/TGI shall be based upon CEMS data utilized for SO₂ as required in Section XI.E.1 (ARM 17.8.749).
2. Compliance with the opacity limitation listed in Section XI.C shall be determined using EPA reference method 9 observations by a qualified observer or a certified COMS.
3. Using the following equations, CHS shall determine the VOC and PM₁₀ emissions from the Coke Drum Steam Vent each time a steam vent is opened to the atmosphere (cycle). CHS shall sum emissions from all cycles on a rolling 12-month basis to determine compliance with the emissions limits (ARM 17.8.749).

$$PM_{10}, lb / cycle = \left(\frac{15}{2} / \frac{65}{4} \right) (-1.5041P^2 + 17.603P + 3.7022)$$

$$VOC, lb / cycle = \left(\frac{15}{2} / \frac{65}{4} \right) (2.6378P^3 - 33.487P^2 + 144.5P - 37.706)$$

P = pressure (psig) at which each coke drum is depressurized.

H. Operational and Emission Inventory Reporting Requirements (ARM 17.8.749)

1. CHS shall prepare and submit a quarterly emission and coke handling report within 30 days of the end of each calendar quarter. Emission reporting for SO₂ from the emission rate monitors shall consist of a daily 24-hour average concentration (ppm SO₂, corrected to 0% O₂) and a 24-hour total (lb/day) for each calendar day. Copies of the quarterly emission report shall be submitted to both the Billings regional office and the Helena office of the Department. The quarterly report shall also include the following:
 - a. Source or unit operating time during the reporting period and quarterly fuel gas consumption rates.
 - b. Monitoring downtime that occurred during the reporting period.
 - c. A summary of excess emissions or applicable concentrations for each pollutant and the averaging period identified in XI.D.1 through 2, 7 and 8.
 - d. Compliance determinations for hourly, 24-hour, and annual limits specifically allowed in Section XI.G.
 - e. Reasons for any emissions in excess of those specifically allowed in Section XI.D.1 through 2, 7 and 8 with mitigative measures utilized and corrective actions taken to prevent a recurrence of the situation.
 - f. A summary of the number of batches of coke that were processed using the alternative coke handling method (ARM 17.8.749).
2. For non-minor (defined in the June 12, 1998 Stipulation) flaring events, CHS shall comply with the reporting requirements identified in Section (3)(A)(5) of Exhibit A-1 of the Stipulation signed by the Board of Environmental Review on June 12, 1998 (ARM 17.8.749).
3. CHS shall include in the quarterly emissions report the VOC and PM₁₀ emissions as tons/rolling 12-month total and any instances that the drum is not depressurized at below 5 psig (ARM 17.8.749).

Section XII: Limitations and Conditions for Boiler #11

- A. CHS shall comply with all applicable standards and limitations, and the monitoring, recordkeeping, and reporting requirements contained in 40 CFR Part 60, NSPS. The following subparts, at a minimum, are applicable (ARM 17.8.340):
 1. Subpart A - General Provisions applies to all equipment or facilities subject to an NSPS subpart listed below.
 2. Subpart J - Standards of Performance for Petroleum Refineries applies to Boiler #11.
 3. Subpart Db – Standards of Performance for Steam Generating Units applies to Boiler #11.
- B. CHS shall not cause or authorize emissions to be discharged into the outdoor atmosphere from any source installed after November 23, 1968, that exhibit an opacity of 20% or greater averaged over 6 consecutive minutes. This applies to the sources in Boiler #11 (ARM 17.8.304 (2)).

C. Limitations on Boiler #11

1. SO₂ emissions from Boiler #11 shall not exceed (ARM 17.8.752):
 - a. 8.59 tons/rolling 12-calendar month total
 - b. 3.92 lb/hr
2. NO_x emissions from Boiler #11 shall not exceed (ARM 17.8.752):
 - a. 18.3 tons/rolling 12-calendar month total
 - b. 4.18 lb/hr
3. During periods of startup or shutdown, CO emissions from Boiler #11 shall not exceed 23 lb/hr on a 24-hour rolling average (ARM 17.8.752). Otherwise, CO emissions shall not exceed (ARM 17.8.752):
 - a. 400 ppm_{vd} at 3% oxygen on a 30-day rolling average
 - b. 36.63 tons/rolling 12-calendar month total
 - c. 15.26 lb/hr
4. VOC Emissions from the Boiler #11 shall not exceed 4.83 tons/rolling 12-calendar month total (ARM 17.8.752).
5. CHS shall not fire fuel oil in this unit (ARM 17.8.340; 40 CFR 60, Subpart J; and ARM 17.8.752).

D. Monitoring requirements

1. CHS shall install and operate the following (CEMS/CERMS) for Boiler #11:
 - a. NO_x (40 CFR 60, Subpart Db)
 - b. O₂ (40 CFR 60, Subpart Db)
2. CEMS and CERMS required by this permit shall comply with all applicable provisions of 40 CFR Part 60.5 through 60.13, Subpart Db 60.40b through 60.49b, Subparts J, 60.100-108, and Appendix A, Appendix B, Performance Specifications 2, 3, 4 or 4A, 6, and Appendix F.
3. CEMS are to be in operation at all times when the emission units are operating, except for quality assurance and control checks, breakdowns, and repairs. In the event the primary CEMS is unable to meet minimum availability requirements, the recipient shall provide a back-up or alternative monitoring system and plan such that continuous compliance can be demonstrated.
4. With exception to the initial performance test period, compliance with the lb/MMBtu limit(s) will be demonstrated using statistically significant F-factor values. The factor will be updated on a regular basis using data from all valid fuel gas samples representative of the fuel gas burned in Boiler #11. The method of compliance demonstration involving F-factor statistical significance is subject to change upon agreement with the Department and CHS (40 CFR 60, Appendix A, Reference Method 19).
5. CHS shall install and operate a volumetric stack flow rate monitor on Boiler #11. The volumetric flow rate monitor shall comply with the Billings/Laurel SIP Pollution Control Plan Exhibit A, Attachment 1 Methods A-1 and B-1. The

volumetric stack flow rate monitor is required within 180 days of the issuance of MAQP #1821-21 (ARM 17.8.749).

E. Testing Requirements

Boiler #11 shall be tested annually, or according to another testing/monitoring schedule as may be approved by the Department, for NO_x and CO, concurrently, and the results submitted to the Department in order to demonstrate compliance with the NO_x and CO emission limits contained in Sections XII.C.2 and 3 (ARM 17.8.105 and ARM 17.8.749).

F. Compliance Determinations (ARM 17.8.749).

1. In addition to stack testing required in Section XII.E, compliance determinations for the NO_x limit in Section XII.C for Boiler #11 shall also be based upon monitoring data as required in Section XII.D.
2. Compliance with the opacity limitation listed in Section XII.B shall be determined using EPA Reference Method 9 observations by a qualified observer or a certified COMS.

G. Operational and Emission Inventory Reporting Requirements (ARM 17.8.749)

CHS shall prepare and submit a quarterly emission report within 30 days of the end of each calendar quarter. Copies of the quarterly emission report shall be submitted to both the Billings regional office and the Helena office of the Department. The quarterly report shall also include the following:

1. SO₂ emission data from the refinery fuel gas system continuous H₂S concentration monitor required by Section III. The SO₂ emission rates shall be reported for the following averaging periods:
 - a. Average lb/hr per calendar day
 - b. Total lb per calendar day
 - c. Total tons per month
2. NO_x emission data from the CEMS, fuel gas flow rate meter, and emission factors developed from the most recent compliance source test. The NO_x emission rates shall be reported for the following averaging periods:
 - a. Average lb/MMBTU per calendar day
 - b. Total tons per month
 - c. lb/MMBTU per rolling 30-day average
3. Source or unit operating time during the reporting period and quarterly fuel gas consumption rates.
4. Monitoring downtime that occurred during the reporting period.
5. A summary of excess emissions or applicable concentrations for each pollutant and the averaging period identified in Section XII.C.1 through 4.
6. Reasons for any emissions in excess of those specifically allowed in Section XII.C with mitigative measures utilized and corrective actions taken to prevent a recurrence of the situation.

Section XIII: Limitations and Conditions for the Railcar Light Product Loading Rack and Vapor Combustion Unit (VCU)

- A. CHS shall commence construction of the Railcar Light Product Loading Rack no later than June 27, 2011 (three years following issuance of MAQP #1821-17) (ARM 17.8.749 and ARM 17.8.762).
- B. CHS shall comply with all applicable standards and limitations, and the reporting, recordkeeping, and notification requirements of ARM 17.8.342, as specified in 40 CFR Part 63, NESHAP for Source Categories.
 - 1. Subpart A - General Provisions applies to all equipment or facilities subject to a NESHAP for source categories subpart as listed below.
 - 2. Subpart R – Gasoline Distribution MACT
 - 3. Subpart CC – Refinery MACT I shall apply to, but not be limited to, the product loading rack and VCU. The Gasoline Loading Rack provisions in Subpart CC require compliance with certain Subpart R provisions.
- C. The Railcar Light Product Loading Rack and VCU shall be operated and maintained as follows:
 - 1. CHS' railcar light product loading rack shall be equipped with a vapor collection system designed to collect the organic compound vapors displaced from railcars during gasoline product loading (ARM 17.8.342 and ARM 17.8.752).
 - 2. CHS' collected vapors shall be routed to the VCU at all times. In the event the VCU is inoperable, CHS may continue to load distillates with a Reid vapor pressure of less than 27.6 kilopascals, provided the Department is notified in accordance with the requirements of ARM 17.8.110 (ARM 17.8.749).
 - 3. Loadings of liquid products into gasoline cargo tanks shall be limited to vapor-tight gasoline cargo tanks, using procedures as listed in 40 CFR 63, Subpart R (ARM 17.8.342 and ARM 17.8.752).
- D. Emission Limitations for the Railcar Light Product Loading Rack VCU
 - 1. The total VOC emissions to the atmosphere from the VCU due to loading liquid product into cargo tanks shall not exceed 10.0 milligrams per liter (mg/L) of gasoline loaded (ARM 17.8.342 and ARM 17.8.752).
 - 2. The total CO emissions to the atmosphere from the VCU due to loading liquid product into cargo tanks shall not exceed 10.0 mg/L of gasoline loaded (ARM 17.8.752).
 - 3. The total NO_x emissions to the atmosphere from the VCU due to loading liquid product into cargo tanks shall not exceed 4.0 mg/L of gasoline loaded (ARM 17.8.752).
 - 4. CHS shall not cause or authorize to be discharged into the atmosphere from the VCU:

- a. Any visible emissions that exhibit an opacity of 10% or greater (ARM 17.8.752); and
- b. Any particulate emissions in excess of 0.10 gr/dscf corrected to 12% CO₂ (ARM 17.8.752).

E. Monitoring and Testing Requirements

- 1. CHS shall perform the testing and monitoring procedures, as applicable, specified in 40 CFR 63, Subpart R (ARM 17.8.342 and 40 CFR 63, Subpart R).
- 2. CHS shall install and continuously operate a thermocouple and an associated recorder for temperature monitoring in the firebox or ductwork immediately downstream in a position before any substantial heat occurs and develop an operating parameter value in accordance with the provisions of 40 CFR 63.425 and 63.427 for the VCU. CHS shall install and continuously operate an ultraviolet flame detector and relay system which will render the loading rack inoperable if a flame is not present at the VCU firebox or any other equivalent device, to detect the presence of a flame (ARM 17.8.342 and ARM 17.8.752).
- 3. The VCU shall be initially tested for VOCs, and compliance demonstrated with the emission limitation contained in Section XIII.C.1 within 180 days of initial startup and testing continued every 5 years, or according to another testing/monitoring schedule as may be approved by the Department, until such time that the Railcar Light Product Loading Rack is complete. Following construction completion of the Railcar Light Product Loading Rack, the VCU shall be tested on an every 2-year basis. CHS shall perform the test methods and procedures as specified in 40 CFR 63.425, Subpart R (ARM 17.8.105 and 17.8.342).
- 4. The VCU shall be initially tested for CO and NO_x, concurrently, and compliance demonstrated with the CO and NO_x emission limitations contained in Section XIII.C.2 and 3 within 180 days of initial start up (ARM 17.8.105).

Section XIV: Limitations and Conditions for Boiler #12

- A. CHS shall comply with all applicable standards and limitations, and the monitoring, recordkeeping, and reporting requirements contained in 40 CFR Part 60, NSPS. The following subparts, at a minimum, are applicable (ARM 17.8.340):
 - 1. Subpart A - General Provisions applies to all equipment or facilities subject to an NSPS subpart listed below.
 - 2. Subpart Db – Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units applies to Boiler #12.
 - 3. Subpart Ja - Standards of Performance for Petroleum Refineries for Which Construction, Reconstruction, or Modification Commenced After May 14, 2007 applies to Boiler #12.
 - 4. Subpart GGG – Standards of Performance for Equipment Leaks of VOC in Petroleum Refineries applies to the refinery fuel gas supply lines to Boiler #12.
- B. CHS shall not cause or authorize emissions to be discharged into the outdoor atmosphere from any source installed after November 23, 1968, that exhibit an opacity of 20% or

greater averaged over 6 consecutive minutes. This applies to the sources in Boiler #12 (ARM 17.8.304 (2)).

C. Limitations on Boiler #12

1. SO₂ emissions from Boiler #12 shall not exceed (ARM 17.8.752):
 - a. 0.05 grains/dscf H₂S (81 ppmvd H₂S) refinery fuel gas, rolling 12-month average
 - b. 7.88 tons/rolling 12-calendar month total
 - c. 3.60 lb/hr
2. NO_x emissions from Boiler #12 shall not exceed (ARM 17.8.752):
 - a. 0.02 lbs/MMBtu-HHV, on a rolling 365-calendar day average
 - b. 18.31 tons/rolling 12-calendar month total
 - c. 4.18 lb/hr
3. During periods of startup or shutdown, CO emissions from Boiler #12 shall not exceed 23 lb/hr on a 24-hour rolling average (ARM 17.8.752). Otherwise, CO emissions shall not exceed (ARM 17.8.752):
 - a. 400 ppm_{vd} at 3% oxygen on a 30-day rolling average
 - b. 36.63 tons/rolling 12-calendar month total
 - c. 15.26 lb/hr
4. VOC Emissions from the Boiler #12 shall not exceed 4.81 tons/rolling 12-calendar month total (ARM 17.8.752).
5. Boiler #12 shall be fitted with ultra low NO_x burners with FGR (ARM 17.8.752).
6. CHS shall not fire fuel oil in this unit (ARM 17.8.749 and ARM 17.8.752).

D. Monitoring requirements

1. CHS shall install and operate the following (CEMS/CERMS) for Boiler #12:
 - a. NO_x (40 CFR 60, Subpart Db)
 - b. O₂ (40 CFR 60, Subpart Db)
2. CEMS and CERMS required by this permit shall comply with all applicable provisions of 40 CFR Part 60.5 through 60.13, Subpart Db 60.40b through 60.49b, Subparts J, 60.100-108, and Appendix A, Appendix B, Performance Specifications 2, 3, 4 or 4A, 6, and Appendix F (ARM 17.8.749 and ARM 17.8.342).
3. CEMS are to be in operation at all times when the emission units are operating, except for quality assurance and control checks, breakdowns, and repairs. In the event the primary CEMS is unable to meet minimum availability requirements, the recipient shall provide a back-up or alternative monitoring system and plan such that continuous compliance can be demonstrated (ARM 17.8.749).

4. With exception to the initial performance test period, compliance with the lb/MMBtu limit(s) will be demonstrated using statistically significant F-factor values. The factor will be updated on a regular basis using data from all valid fuel gas samples representative of the fuel gas burned in Boiler #12. The method of compliance demonstration involving F-factor statistical significance is subject to change upon agreement with the Department and CHS (40 CFR 60, Appendix A, Reference Method 19).
5. CHS shall install and operate a volumetric stack flow rate monitor on Boiler #12. The volumetric flow rate monitor shall comply with the Billings/Laurel SIP Pollution Control Plan Exhibit A, Attachment 1 Methods A-1 and B-1 (ARM 17.8.749).

E. Testing Requirements

Boiler #12 shall be tested annually, or according to another testing/monitoring schedule as may be approved by the Department, for NO_x and CO, concurrently, and the results submitted to the Department in order to demonstrate compliance with the NO_x and CO emission limits contained in Sections XIV.C.2 and 3 (ARM 17.8.105 and ARM 17.8.749).

F. Compliance Determinations (ARM 17.8.749).

1. In addition to stack testing required in Section XIV.E, compliance determinations for the NO_x limits in Section XIV.C for Boiler #12 shall also be based upon monitoring data as required in Section XIV.D.
2. Compliance with the opacity limitation listed in Section XIV.B shall be determined using EPA Reference Method 9 observations by a qualified observer or a certified COMS.
3. Compliance with the limit in Section XIV.C.2.c. shall be determined using the NO_x CEM required in Section XIV.D.1 and the volumetric stack flow rate monitor required in Section XIV.D.5.

G. Operational and Emission Inventory Reporting Requirements (ARM 17.8.749)

CHS shall prepare and submit a quarterly emission report within 30 days of the end of each calendar quarter. Copies of the quarterly emission report shall be submitted to both the Billings regional office and the Helena office of the Department. The quarterly report shall also include the following:

1. SO₂ emission data from the refinery fuel gas system continuous H₂S concentration monitor required by Section III. The SO₂ emission rates shall be reported for the following averaging periods:
 - a. Average lb/hr per calendar day
 - b. Total lb per calendar day
 - c. Total tons per month
2. NO_x emission data from the CEMS, fuel gas flow rate meter, and emission factors developed from the most recent compliance source test. The NO_x emission rates shall be reported for the following averaging periods:

- a. Average lb/MMBTU per calendar day
 - b. Total tons per month
 - c. lb/MMBTU per rolling 30-day average
 - d. lb/MMBTU per rolling 365-day average
 - e. Daily average and maximum lb/hr
3. Source or unit operating time during the reporting period and quarterly fuel gas consumption rates.
 4. Monitoring downtime that occurred during the reporting period.
 5. A summary of excess emissions or applicable concentrations for each pollutant and the averaging period identified in Section XIV.C.1 through 4.
 6. Reasons for any emissions in excess of those specifically allowed in Section XIV.C with mitigative measures utilized and corrective actions taken to prevent a recurrence of the situation.

Section XV: Benzene Reduction Unit

- A. CHS shall comply with all applicable standards and limitations, and the monitoring, recordkeeping and reporting requirements contained in 40 CFR Part 60, NSPS. The following subparts, at a minimum, are applicable:
 1. Subpart A - General Provisions applies to all equipment or facilities subject to an NSPS subpart listed below.
 2. Subpart Ja - Standards of Performance for Petroleum Refineries for Which Construction, Reconstruction, or Modification Commenced After May 14, 2007 applies to the Platformer Splitter Reboiler.
 3. Subpart GGGa – Standards of Performance for Equipment Leaks of VOC in Petroleum Refineries for Which Construction, Reconstruction, or Modification Commenced After November 7, 2006, applies to all of the fugitive VOC emitting components added in the affected facility.
 4. Subpart QQQ - Standards of Performance for VOC Emissions from Petroleum Refining Wastewater Systems shall apply to, but not be limited to, any new, modified, or reconstructed affected facility associated with the benzene reduction project.
- B. CHS shall comply with all applicable standards and limitations, and the reporting, recordkeeping, and notification requirements specified in 40 CFR Part 63, NESHAPs for Source Categories (ARM 17.8.342):
 1. Subpart A – General Provisions applies to all equipment or facilities subject to a NESHAP for source categories subpart as listed below.
 2. Subpart CC - National Emission Standards for Hazardous Air Pollutants from Petroleum Refineries (Refinery MACT I) applies to certain parts of the Benzene Reduction Unit.
- C. CHS shall not cause or authorize emissions to be discharged into the outdoor atmosphere

from any source installed after November 23, 1968, that exhibit an opacity of 20% or greater averaged over 6 consecutive minutes. This applies to the sources in the Benzene Reduction Unit (ARM 17.8.304 (2)).

D. Limitations on Platformer Splitter Reboiler

1. SO₂ emissions from the Platformer Splitter Reboiler shall not exceed:
 - a. 60 ppm, H₂S in refinery fuel gas, 365-day rolling average for the Platformer Splitter Reboiler (ARM 17.8.752, ARM 17.8.340, and 40 CFR 60, Subpart Ja)
 - b. 1.18 tons/ rolling 12-calendar month total (ARM 17.8.749)
 - c. 0.72 lb/hr (ARM 17.8.749)
2. NO_x emissions from the Platformer Splitter Reboiler shall not exceed:
 - a. 6.99 tons/ rolling 12-calendar month total (ARM 17.8.749)
 - b. 1.60 lb/hr (ARM 17.8.752)
3. CO emissions from the Platformer Splitter Reboiler shall not exceed:
 - a. 13.62 tons/ rolling 12-calendar month total (ARM 17.8.749)
 - b. 3.11 lb/hr (ARM 17.8.752)
4. PM/PM₁₀ emissions from the Platformer Splitter Reboiler shall not exceed:
 - a. 1.31 tons/ rolling 12-calendar month total (ARM 17.8.749)
 - b. 0.30 lb/hr (ARM 17.8.752)
5. VOC emissions from the Platformer Splitter Reboiler shall not exceed 0.64 tons/rolling 12-calendar month total (ARM 17.8.752).
6. The Platformer Splitter Reboiler shall be fitted with ULNBs (ARM 17.8.752).
7. The heat input rate for the Platformer Splitter Reboiler shall not exceed 39.9 MMBtu-HHV/hr (ARM 17.8.749).

E. Limitations on Wastewater System Components

1. All new drains associated with the benzene reduction project will be routed to the sewer system that is NSPS Subpart QQQ compliant and all such drains will be treated as subject to NSPS Subpart QQQ requirements (ARM 17.8.752).
2. All new junction boxes/vessels constructed as part of the benzene reduction project will be either water sealed, equipped with vent pipes meeting NSPS Subpart QQQ standards (applicable to new junction boxes), or equipped with closed vent systems and control devices that are designed and operated to meet the control requirements of NSPS Subpart QQQ (ARM 17.8.752).

F. Testing Requirements

The Platformer Splitter Reboiler (P-HTR-3) shall be initially tested for NO_x and CO, concurrently, and the results submitted to the Department in order to demonstrate compliance with the NO_x and CO emission limits contained in Sections XV.D.2 and 3 (ARM 17.8.105 and ARM 17.8.749).

G. Operational and Emission Inventory Reporting Requirements (ARM 17.8.749)

CHS shall prepare and submit a quarterly emission report within 30 days of the end of each calendar quarter. Copies of the quarterly emission report shall be submitted to both the Billings regional office and the Helena office of the Department. The quarterly report shall also include the following:

1. SO₂ emission data from the refinery fuel gas system continuous H₂S concentration monitor required by Section III. The SO₂ emission rates shall be reported for the following averaging periods:
 - a. Average lb/hr per calendar day
 - b. Total lb per calendar day
 - c. Total tons per month
2. NO_x emission data from the fuel gas flow rate meter and emission factors developed from the most recent compliance source test. The NO_x emission rates shall be reported for the following averaging periods:
 - a. Average lb/hr per calendar day
 - b. Total tons per month
3. Source or unit operating time during the reporting period and quarterly fuel gas consumption rates.
4. A summary of excess emissions or applicable concentrations for each pollutant and the averaging period identified in Section XV.D.1 through 5.
5. Reasons for any emissions in excess of those specifically allowed in Section XV.D with mitigative measures utilized and corrective actions taken to prevent a recurrence of the situation.

H. Notification Requirements

CHS shall provide the Department (both the Billings regional office and the Helena office) with written notification of the actual start-up date of the Platformer Splitter Reboiler within 15 days after the actual start-up date (ARM 17.8.340 and ARM 17.8.749).

Section XVI: General Conditions

- A. Inspection - CHS shall allow the Department's representatives access to the source at all reasonable times for the purpose of making inspections or surveys, collecting samples, obtaining data, auditing any monitoring equipment (CEMS, CERMS) or observing any monitoring or testing, and otherwise conducting all necessary functions related to this

permit.

- B. Waiver - The permit and all the terms, conditions, and matters stated herein shall be deemed accepted if CHS fails to appeal as indicated below.
- C. Compliance with Statutes and Regulations - Nothing in this permit shall be construed as relieving CHS of the responsibility for complying with any applicable federal or Montana statute, rule, or standard, except as specifically provided in ARM 17.8.740, *et seq.* (ARM 17.8.756).
- D. Enforcement - Violations of limitations, conditions and requirements contained herein may constitute grounds for permit revocation, penalties, or other enforcement as specified in Section 75-2-401 *et seq.*, MCA.
- E. Appeals – Any person or persons jointly or severally adversely affected by the Department’s decision may request, within 15 days after the Department renders its decision, upon affidavit setting forth the grounds therefore, a hearing before the Board of Environmental Review (Board). A hearing shall be held under the provisions of the Montana Administrative Procedures Act. The filing of a request for a hearing does not stay the Department’s decision, unless the Board issues a stay upon receipt of a petition and a finding that a stay is appropriate under Section 75-2-211(11)(b), MCA. The issuance of a stay on a permit by the Board postpones the effective date of the Department’s decision until conclusion of the hearing and issuance of a final decision by the Board. If a stay is not issued by the Board, the Department’s decision on the application is final 16 days after the Department’s decision is made.
- F. Permit Inspection - As required by ARM 17.8.755, Inspection of Permit, a copy of the air quality permit shall be made available for inspection by Department personnel at the location of the permitted source.
- G. Duration of Permit - Construction or installation must begin or contractual obligations entered into that would constitute substantial loss within 3 years of permit issuance and proceed with due diligence until the project is complete or the permit shall expire (ARM 17.8.762).
- H. Permit Fees - Pursuant to Section 75-2-220, MCA, as amended by the 1991 Legislature, failure to pay the annual operation fee by CHS may be grounds for revocation of this permit, as required by that section and rules adopted thereunder by the Board.

ATTACHMENT A

Plant-Wide Refinery Limitations and Conditions Compliance Determination

1. Gas fired external combustion
 - a. SO₂
 - i. Calculation Basis: AP-42 Section 1-4 (7/98 revision) and complete conversion of fuel gas H₂S to SO₂
 - ii. Key Parameters: Monthly fuel use (scf) per combustion unit and refinery fuel gas H₂S content from CEMS.
 - b. NO_x, CO, PM₁₀/PM, VOC
 - i. Calculation Basis: AP-42 Section 1-4 (7/98 revision)
 - ii. Key Parameters: Monthly fuel use (scf) per combustion unit and monthly average fuel gas heat content.
2. Fuel oil fired external combustion
 - a. SO₂
 - i. Calculation Basis: Methodology required in the Billings-Laurel SO₂ SIP and Appendix G of the CHS Consent Decree.
 - ii. Key Parameters: Sulfur content and specific gravity of alkylation unit polymer pursuant to Appendix G of the CHS Consent Decree.
3. Gas fired internal combustion
 - a. SO₂
 - i. Calculation Basis: AP-42 Section 1-4 (7/98 revision) and complete conversion of fuel gas H₂S to SO₂
 - ii. Key Parameters: Monthly fuel use (scf) per combustion unit and fuel gas H₂S and Sulfur content
 - b. NO_x, CO
 - i. Calculation Basis: AP-42 Section 3-2 (10/96 revision)
 - ii. Key Parameters: Monthly fuel use (scf) per combustion unit and monthly average fuel gas heat content
 - c. PM₁₀/PM: Not applicable – not a significant source
 - d. VOC

Calculation Basis: AP-42 Section 3-2 (10/96 revision)
Key Parameters: Monthly fuel use (scf) per combustion unit and monthly average fuel gas heat content
4. Zone D, ULSD Unit (900 Unit), Hydrogen Plant (1000 Unit), Delayed Coker

Unit combustion sources, Boiler #11, and NHT Charge Heater (H-8301)

- a. SO₂: Calculation Basis: CEMS data and methodology required in the Billings/Laurel SO₂ SIP
 - b. NO_x
 - i. Calculation Basis: NO_x and O₂ CEMS, Emission factors based on annual stack tests
 - ii. Key Parameters: NO_x stack tests, monthly fuel use (scf) per combustion unit
 - c. CO
 - i. Calculation Basis: CO and O₂ CEMS, Emission factors based on annual stack tests
 - ii. Key Parameters: CO stack tests, monthly fuel use (scf) per combustion unit
 - d. PM₁₀/PM
 - i. Calculation Basis: AP-42 Section 1-4 (7/98 revision)
 - ii. Key Parameters: Monthly fuel use (scf) per combustion unit and monthly average fuel gas heat content
 - e. VOC
 - i. Calculation Basis: Emission factors based on annual stack tests for sources burning refinery fuel gas. For sources firing only natural gas, the most current VOC stack test will be used to develop emission factors.
 - ii. Key Parameters: VOC stack test
5. Fugitive equipment leaks
- a. SO₂, NO_x, CO, PM₁₀/PM: Not applicable
 - b. VOC
 - i. Calculation Basis: EPA factors and NSPS and MACT control efficiencies (EPA-453/R-95-017)
 - ii. Key Parameters: Component counts by type and service
6. Boilers #10 and #12
- a. SO₂
 - i. Calculation Basis: Complete conversion of fuel gas H₂S to SO₂
 - ii. Key Parameters: Monthly fuel use (scf) per combustion unit and refinery fuel gas H₂S content from CEMS
 - b. NO_x

- i. Calculation Basis: NO_x and O₂ CEMS, Volumetric stack flow rate monitor, Emission factors based on stack tests
 - ii. Key Parameters: NO_x and O₂ CEMS, Reference Method 19, NO_x stack tests, monthly fuel use (scf), volumetric stack flow rate
 - c. CO
 - i. Calculation Basis: CO and O₂ CEMS, Emission factors based on stack tests
 - ii. Key Parameters: CO stack tests, monthly fuel use (scf)
 - d. PM₁₀/PM
 - i. Calculation Basis: AP-42 Section 1-4 (7/98 revision)
 - ii. Key Parameters: Monthly fuel use (scf) and monthly average fuel gas heat content
 - e. VOC
 - i. Calculation Basis: Emission factors based on stack tests
 - ii. Key Parameters: VOC stack tests, monthly fuel use (scf)
- 7. FCCU
 - a. SO₂

Calculation Basis: CEMS data and methodology required in CHS Consent Decree, NSPS Subpart J, and the Billings/Laurel SO₂ SIP
 - b. NO_x

Calculation Basis: CEMS data and methodology required in CHS Consent Decree, NSPS Subpart J, and FCCU Regenerator flue gas flow rate.
 - c. CO

Calculation Basis: CEMS data and methodology required in CHS Consent Decree and NSPS Subpart J, and FCCU Regenerator flue gas flow rate.
 - d. PM₁₀/PM
 - i. Calculation Basis: Annual stack test results
 - ii. Key Parameters: Monthly FCC charge rate (bbl)
 - e. VOC
 - i. Calculation Basis: AP-42 Section 5.1 (1/95 revision) and assumed 98% control efficiency
 - ii. Key Parameters: Monthly FCC charge rate (bbl)
- 8. Zone A SRU Incinerator

- a. SO₂: Calculation Basis: CEMS data and methodology required in Billings/Laurel SO₂ SIP
 - b. NO_x
 - i. Calculation Basis: Emission factors based on every 5-year stack tests
 - ii. Key Parameters: Every 5-year NO_x stack test, monthly fuel use (scf)
 - c. CO, PM₁₀/PM, VOC
 - i. Calculation Basis: AP-42 Section 1-4 (7/98 revision)
 - ii. Key Parameters: Monthly fuel use (scf) and average fuel gas heat content
9. Zone D SRU Incinerator
- a. SO₂: Calculation Basis: CEMS data and methodology required in Billings/Laurel SO₂ SIP
 - b. NO_x
 - i. Calculation Basis: Emission factors based on annual stack tests
 - ii. Key Parameters: Annual NO_x stack test, monthly fuel use (scf)
 - c. CO, PM₁₀/PM, VOC: Not applicable – not a significant source
10. Zone E SRU Incinerator
- a. SO₂: Calculation Basis: CEMS data and methodology required in Billings/Laurel SO₂ SIP
 - b. NO_x
 - i. Calculation Basis: Emission factors based on every 5ve-year stack tests
 - ii. Key Parameters: Every 5-year NO_x stack test, monthly fuel use (scf)
 - c. CO, PM₁₀/PM, VOC: Not applicable – not a significant source
11. Wastewater
- a. SO₂, NO_x, CO, PM₁₀/PM: Not applicable – not a source
 - b. VOC
 - i. Calculation Basis: AP-42, Table 5.1-2 (1/95 rev.)
 - ii. Key Parameters: Monthly wastewater flow (gal) from Lab Information Management System (LIMS)
12. Cooling towers

- a. SO₂, NO_x, CO: Not applicable – not a source
- b. PM₁₀/PM: Cooling tower design (Delayed coker unit cooling tower applicable)
- c. VOC
 - i. Calculation Basis: AP-42, Section 5.1 (1/95 rev.)
 - ii. Key Parameters: Monthly cooling tower circulation (gal)

13. Loading facilities

- a. SO₂: Not applicable – not a source
- b. NO_x
 - i. Calculation Basis: VCU stack tests for lb NO_x/gal loaded
 - ii. Key Parameters: Monthly volume of materials loaded from yield accounting
- c. CO
 - i. Calculation Basis: VCU stack tests for lb CO/gal loaded
 - ii. Key Parameters: Monthly volume of materials loaded from yield accounting
- d. PM₁₀/PM: Not applicable – not a significant source
- e. VOC
 - i. Calculation Basis: AP-42, Section 5.2-4 (1/95 rev.) and VCU stack tests for lb VOC/gal loaded
 - ii. Key Parameters: Monthly volume of material throughput from yield accounting, material property data (VP, MW, etc.)

14. Storage tanks

- a. SO₂, NO_x, CO, PM₁₀/PM: Not applicable – not a source
- b. VOC
 - i. Calculation Basis: EPA TANKS4.0
 - ii. Key Parameters: Monthly volume of material throughput from yield accounting, material property data (VP, MW, etc.)

Montana Air Quality Permit (MAQP) Analysis
CHS Inc. – Laurel Refinery
MAQP #1821-22

I. Introduction/Process Description

A. Site Location/Description

The CHS Inc. (CHS) Laurel Refinery is a petroleum refinery located in the South ½ of Section 16, Range 24 East, Township 2 South, in Yellowstone County. A complete list of permitted equipment is available in the permit, with the exception of the source categories for the Plant-wide Applicability Limit (PAL), which are listed below.

1. Gas-fired external combustion source type, includes:
 - #1 crude heater, crude preheater, #1 crude vacuum heater
 - #2 crude heater, #2 crude vacuum heater
 - Alkylation Unit hot oil belt heater
 - Platformer Heater (P-HTR-1), platformer debutanizer heater
 - Fluid Catalytic Cracking (FCC) Charge Heater (FCC-Heater-1)
 - Naphtha Hydrotreater (NHT) Charge Heater (H-8301), NHT Reboiler Heater #1 (H-8302), NHT Reboiler Heater #2 (H-8303), and NHT Splitter Reboiler (H-8304)
 - Zone D Hydrogen Plant Reformer Heater (H-101), Reactor Charge Heater (H-201), Fractionator Feed Heater (H-202)
 - Ultra Low Sulfur Diesel (ULSD) Unit Reactor charge heater (H-901), ULSD Unit Fractionation heater (H-902)
 - Hydrogen Plant Reformer heater (H-1001)
 - Coker Charge Heater (H-7501)
 - Asphalt Loading Heater #1
 - #1 fuel oil heater, #60 tank heater
 - Boiler #5, Boiler #9, Boiler #10, Boiler #11, and Boiler #12
 - Platformer Splitter Reboiler (P-HTR-3);
2. Fuel oil-fired external combustion sources, includes: #4 boiler, and #5 boiler (until startup of Boiler #12);
3. Gas-fired internal combustion source, includes: Platformer recycle turbine, Zone D compressor gas engine (C-201B);

4. FCC unit (FCCU) Regenerator;
5. Zone A Sulfur Recovery Unit (SRU) Tail Gas Incinerator (TGI, SRU-AUX-4);
6. Zone D SRU Incinerator;
7. Delayed Coker Unit: Zone E SRU/Tail Gas Treatment Unit (TGTU)/TGI;
8. Fugitive equipment leaks include all equipment, as defined in 40 Code of Federal Regulations (CFR) 60, Subpart VV, in hydrocarbon service;
9. Wastewater source type includes: old American Petroleum Institute (API) separator, Zone D API separator, ULSD Unit Wastewater, TGTU Wastewater; Benzene Reduction Unit Oily Water Sewer
10. Cooling tower sources: #1 cooling tower (CT), #2 CT, #3 CT, #5 CT, and #6 CT;
11. Loading facilities: light product truck rack and vapor combustion unit (VCU), heavy oil truck rack, heavy oil rail rack; and railcar light loading rack and VCU; and
12. Storage tanks: tank numbers 2, 7, 12, 41, 47, 56, 60, 61, 62, 63, 65, 66, 67, 68, 70, 71, 73, 74, 75, 76, 77, 78, 79, 80, 81, 82, 83, 85, 86, 87, 88, 91, 92, 93, 94, 95, 96, 97, 98, 99, 100, 101, 102, 103, 104, 105, 106, 107, 108, 109, 110, 111, 112, 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 126, 127, 128, 129, B-1, B-2, B-7, firetk 2, firetk 3, firetk 4, TGTU-VSSL-6, and coker sludge storage tank (TK-7504).

B. Permit History

On May 11, 1992, Cenex Harvest States Cooperatives (Cenex) was issued **MAQP #1821-01** for the construction and operation of a hydro-treating process to desulfurize FCC Unit feedstocks. The existing refinery property lies immediately south of the City of Laurel and about 13 miles southwest of Billings, Montana. The new equipment for the desulfurization complex is located near the western boundary of the existing refining facilities.

The hydrodesulfurization (HDS) process is utilized to pretreat Fluid Catalytic Cracking Unit (FCCU) feeds by removing metal, nitrogen, and sulfur compounds from these feeds. The proposed HDS unit also improved the quality of refinery finished products including gasoline, kerosene, and diesel fuel. The HDS project significantly improved the finished product quality by reducing the overall sulfur contents of liquid products from the Cenex Refinery. The HDS unit provided low sulfur gas-oil feedstocks for the FCCU, which resulted in major reductions of sulfur oxide emissions to the atmosphere. However, only a minor quantity of the proposed sulfur dioxide (SO₂) emission reductions was made federally enforceable.

The application was not subject to the New Source Review (NSR) program for either nonattainment or Prevention of Significant Deterioration (PSD) since Cenex chose to "net out of major modification review" for the affected pollutants due to contemporaneous emission reductions at an existing emission unit.

The application was deemed complete on March 24, 1992. Additional information was received on April 16, 1992, in which Cenex proposed new short-term emission rates based upon modeled air quality impacts.

The basis for the permit application was due to a net contemporaneous emissions increase that was less than the significant level of 40 tons per year (TPY) for SO₂ and nitrogen oxides (NO_x). The application referred to significant SO₂ emission reductions, which were expected by addition of the HDS project. These anticipated major SO₂ reductions were not committed to by Cenex under federally enforceable permit conditions and limitations. The contemporaneous emissions decrease for SO₂ and NO_x, which were made federally enforceable under this permitting action, amount to approximately 15.5 and 23.7 tons per year, respectively.

Construction of the HDS/sulfur recovery complex was completed in December 1993 and the 180-day-shakedown period ended in June 1994.

MAQP #1821-02 was issued on February 1, 1997, to authorize the installation of an additional boiler (Boiler #10) to provide steam for the facility. Cenex submitted the original permit application for a 182.50-million British thermal units per hr (MMBtu/hr) boiler on February 9, 1996. This size boiler is a New Source Performance Standard (NSPS) affected facility and the requirements of NSPS Subpart Db would have applied to the boiler. On November 15, 1996, Cenex submitted a revised permit application proposing a smaller boiler (99.90 MMBtu/hr). The manufacturer of the proposed boiler has not been identified; however, the boiler is to be rated at approximately 80,000 lbs steam/hour with a heat input of 99.9 MMBtu/hour. The boiler shall have a minimum stack height of 75 feet above ground level. The boiler will be fired on natural gas until November 1, 1997, at which time Cenex will be allowed to fire refinery fuel gas in the boiler. The requirements of NSPS Subpart Dc apply to the boiler. The requirements of NSPS Subpart J and GGG will also apply as of November 1, 1997. Increases in emissions from the new boiler are detailed in the permit analysis for MAQP #1821-02. Modeling performed has shown that the emission increase will not result in a significant impact to the ambient air quality.

Cenex has also requested a permit alteration to remove the SO₂ emission limits for the C-201B compressor engine because the permit already limits C-201B to be fired on either natural gas or unodorized propane. Cenex also requested that if the SO₂ emission limits could not be removed, the limits should be corrected to allow for the combustion of natural gas and propane. The Department of Environmental Quality (Department) has altered the permit to allow for burning odorized propane in the C-201B compressor.

Cenex also requested a permit modification to change the method of determining compliance with the HDS Complex emitting units. MAQP #1821-01 requires that compliance with the hourly (lb/hr) emission limits be determined through annual source testing and that the daily (lb/day), annual (ton/yr), and Administrative Rules of Montana (ARM) 17.8 Subchapter 8 requirements (i.e., PSD significant levels and review) be determined by using actual fuel burning rates and the manufacturer's guaranteed emission factors listed in Attachment B. Cenex has requested to use actual fuel burning rates and fixed emission factors determined from previous source test data in order to determine compliance with the daily (lb/day) and annual (ton/yr) emission limits. The Department agrees that actual stack testing data is preferred to manufacturer's data for the development of emission factors. However, the Department is requiring that the emission factor be developed from the most recent source test and not on an average of previous source tests. The permit has been changed to remove Attachment B and rely on emission factors derived from the most recent source test, along with actual fuel flow rates for compliance determinations. However, in order to determine compliance with ARM 17.8 Subchapter 8, Cenex shall continue to monitor the fuel gas flow rates in both scf/hr and scf/year.

On June 4, 1997, Cenex was issued **MAQP #1821-03** to modify emissions and operational limitations on components in the Hydrodesulfurization Complex at the Laurel refinery. The unit was originally permitted in 1992, but has not been able to operate adequately under the emissions and operational limitations originally proposed by Cenex and permitted by the Department. This permitting action corrected these limitations and conditions. The new limitations established by this permitting action were based on operational experience and source testing at the facility and the application of Best Available Control Technology (BACT).

The following emission limitations were modified by this permit.

Source	Pollutant	Previous Limit	New Limit
SRU Incinerator stack (E-407 & INC-401)	SO ₂	291.36 lb/day	341.04 lb/day
	NO _x	2.1 ton/yr 11.52 lb/day 0.48 lb/hr	3.5 ton/yr 19.2 lb/day 0.8 lb/hr
Compressor (C201-B)	NO _x	18.42 ton/yr	30.42 ton/yr
		6.26 lb/hr	7.14 lb/hr
	CO	16.45 ton/yr	68.6 ton/yr
		5.15 lb/hr - when on natural gas	6.4 lb/hr - when on natural gas
VOC	6.26 ton/yr	10.1 ton/yr	
Fractionator Feed Heater (H-202)	SO ₂	0.53 ton/yr	4.93 ton/yr
		0.135 lb/hr	1.24 lb/hr
	NO _x	6.26 ton/yr	8.34 ton/yr
		1.43 lb/hr	2.09 lb/hr
	CO	3.29 ton/yr	6.42 ton/yr
		1.00 lb/hr	1.61 lb/hr
VOC	0.26 ton/yr	0.51 ton/yr	
Reactor Charge Heater (H-201)	SO ₂	0.214 lb/hr	1.716 lb/hr
		0.79 ton/yr	6.83 ton/yr
	NO _x	9.24 ton/yr	11.56 ton/yr
		2.11 lb/hr	2.90 lb/hr
	CO	4.86 ton/yr	8.89 ton/yr
		1.40 lb/hr	2.23 lb/hr
VOC	0.39 ton/yr	0.71 ton/yr	
Reformer Heater (H-101)	SO ₂	0.128 lb/hr	2.15 lb/hr
		0.48 ton/yr	3.35 ton/yr
	NO _x	6.16 lb/hr	6.78 lb/hr
	VOC	0.24 ton/yr	0.35 ton/yr
Old Sour Water Stripper	SO ₂	304.2 ton/yr	290.9 ton/yr
	NO _x	125.7 ton/yr	107.9 ton/yr

Emission limitations in this permit are based on the revised heat input capacities for units within the HDS. The following changes were made to the operational requirements of the facility.

Unit	Originally Permitted Capacity	New Capacity
SRU Incinerator stack (E-407 & INC-401)	4.8 MMBtu/hr	8.05 MMBtu/hr
Compressor (C201-B)	1600 hp (short term) 1067 hp (annual average)	1800 hp (short term and annual average)
Fractionator Feed Heater (H-202)	27.2 MMBtu/hr (short term) 20.4 MMBtu/hr (annual avg.)	29.9 MMBtu/hr (short term) 27.2 MMBtu/hr (annual avg.)
Reactor Charge Heater (H-201)	37.7 MMBtu/hr (short term) 30.2 MMBtu/hr (annual avg.)	41.5 MMBtu/hr (short term) 37.7 MMBtu/hr (annual avg.)
Reformer Heater (H-101)	123.2 MMBtu/hr (short term and annual avg.)	135.5 MMBtu/hr (short term) 123.2 MMBtu/hr (annual avg.)

It has been determined that the emission and operational rates proposed during the original permitting of the HDS unit were incorrect and should have been at the levels Cenex is now proposing. Because of this, the current action and the original permitting of the HDS must be considered one project in order to determine the permitting requirements. When combined with the original permitting of the HDS, the emission increases of NO_x and SO₂ would exceed significant levels and subject this action to the requirements of the NSR/PSD program. During the original permitting of the HDS complex, Cenex chose to “net out” of NSR and PSD review by accepting limitations on the emissions of NO_x and SO₂ from the old SWS. Because of the emission increases proposed in this permitting action, additional emission reductions must occur. Cenex has proposed additional reductions in emissions from the old SWS to offset the increases allowed by this permitting action. These limitations will reduce the “net emission increase” to less than significant levels and negate the need for review under the NSR/PSD program.

The new emission limits for SO₂ and NO_x from the old SWS are 290.9 and 107.9 tons per year, respectively.

This permitting action also removes the emission limits and testing requirements for particulate matter with an aerodynamic diameter of 10 microns or less (PM₁₀) on the HDS heaters (H-101, H-201, and H-202). These heaters combust refinery gas, natural gas and PSA gas. The Department has determined that potential PM₁₀ emissions from these fuels are minor and that emission limits and the subsequent compliance demonstrations for this pollutant are unnecessary.

Also removed from this permit are the compliance demonstration requirements for SO₂ and Volatile Organic Compounds (VOC) when the combustion units are firing natural gas. The Department has determined that firing the units solely on natural gas will, in itself, demonstrate compliance with the applicable limits.

This action will result in an increase in allowable emissions of VOC and Carbon Monoxide (CO) by 4.7 tons per year and 60 tons per year, respectively. Because of the offsets provided by reducing emissions from the old SWS, this permitting action will not increase allowable emissions of SO₂ or NO_x from the facility.

The following changes have been made to the Department's preliminary determination (PD) in response to comments from Cenex.

The emission limits for the old SWS have been revised to ensure that the required offsets are provided without putting Cenex in a non-compliance situation at issuance of the permit. The compliance determinations and the reporting requirements were also changed to reflect this requirement.

The CO emission limits for H-201 have been revised; the old limits were inadvertently left in the PD. The table included in the analysis has also been revised to reflect this change.

Section III.E.2 was changed to clarify that the firing of natural gas would show compliance with the VOC emission limits for Boiler #10.

Section F. of the General Conditions was removed because the Department has placed the applicable requirements from the permit application into the permit.

Numbering has been changed in Section III.

MAQP #1821-04 was issued to Cenex on March 6, 1998, in order to comply with the gasoline loading rack provisions of 40 CFR 63, Subpart CC - National Emission Standards for Petroleum Refineries, by August 18, 1998. Cenex proposed to install a gasoline vapor collection system and enclosed flare for the reduction of Hazardous Air Pollutants (HAPs) resulting from the loading of gasoline. A vapor combustion unit (VCU) was added to the product loading rack. The gasoline vapors would be collected from the trucks during loading, then routed to an enclosed flare where combustion would occur. The result of this project would be an overall reduction in the amount of VOCs (503.7 TPY) and HAPs emitted, but CO and NO_x emissions would increase slightly (4.54 TPY and 1.82 TPY).

The product loading rack is used to transfer refinery products (gasoline, burner and/or diesel fuels) from tank storage to trucks, which transport gasoline and other products, to retail outlets. The loading rack consists of three arms, each with a capacity of 500 gpm. However, only two loading arms are presently used for loading gasoline at any one time. A maximum gasoline-loading rate of 2000 gpm, a maximum short-term rate, was modeled to account for future expansion.

Because Cenex's product loading rack VCU is defined as an incinerator under 75-2-215, Montana Code Annotated (MCA), a determination that the emissions from the VCU would constitute a negligible risk to public health was required prior to the issuance of a permit to the facility. Cenex and the Department identified the following HAPs from the flare, which were used in the health risk assessment. These constituents are typical components of Cenex's gasoline:

1. Benzene
2. Toluene
3. Ethyl Benzene
4. Xylenes

5. Hexane
6. 2,2,4 Trimethylpentane
7. Cumene
8. Napthalene
9. Biphenyl

The reference concentration for Benzene was obtained from Environmental Protection Agency's (EPA) IRIS database. The ISCT3 modeling performed by Cenex, for the HAPs identified above, demonstrated compliance with the negligible risk requirement.

MAQP #1821-05 was issued to Cenex on September 3, 2000, to revamp its No. 1 Crude Unit in order to increase crude capacity, improve product quality, and enhance energy recovery. The project involved the replacement and upgrade of various heat exchangers, pumps, valves, towers, and other equipment. Only VOC emissions were affected by the new equipment. The capacity of the No. 1 Crude Unit was expected to increase by 10,000 or more barrels per stream day.

No increase in allowable emissions was sought under this permit application. The project would actually decrease VOC emissions from the No. 1 Crude Unit. However, increasing the capacity of the No. 1 Crude Unit was expected to increase the current utilization of other units throughout the refinery and thus possibly increase actual site-wide emissions, as compared to previous historical levels. Therefore, the permit included enforceable limits, requested by Cenex, on future site-wide emissions. The limits allow emission increases to remain below the applicable significant modification thresholds that trigger the NSR program for PSD and Nonattainment Area (NAA) permitting.

The site-wide limits were calculated based on the addition of the PSD/NAA significance level for each particular pollutant to the actual refinery emissions from April 1998, through March 2000, for SO₂, NO_x, CO, PM₁₀, and particulate matter (PM) minus 0.1 TPY to remain below the significance level. A similar methodology was used for the VOC emissions cap, except that baseline data from the time period 1993 and 1999 were used to track creditable increases and decreases in emissions. The site-wide limits are listed in the following table.

Pollutant	Period Considered for Prior Actual Emissions	Average Emissions over 2-yr Period (TPY)	PSD/NAA Significance Level (TPY)	Proposed Emissions Cap (TPY)
SO ₂	April 1998-March 2000	2940.4	40	2980.3
NO _x	April 1998-March 2000	959.5	40	999.4
CO	April 1998-March 2000	430.8	100	530.7
VOC	1993-1999	1927.6	40	1967.5
PM ₁₀	April 1998-March 2000	137.3	15	152.2
PM	April 1998-March 2000	137.3	25	162.2

For example, the SO₂ annual emissions cap was calculated as follows:

Average refinery-wide SO₂ emissions in the period of April 1998 through 2000 added to the PSD/NAA significance level for SO₂ minus 0.1 TPY =
 2940.4 TPY + 40 TPY – 0.1 TPY = 2980.3 TPY = Annual emissions cap.

MAQP#1821-05 replaced MAQP #1821-04.

MAQP #1821-06 was issued on April 26, 2001, for the installation and operation of eight temporary, portable Genertek reciprocating engine electricity generators and two accompanying distillate fuel storage tanks. Each generator is capable of generating approximately 2.5 megawatts of power. These generators are necessary because of the high cost of electricity. The operation of the generators will not occur beyond two years and is not expected to last for an extended period of time, but rather only for the length of time necessary for Cenex to acquire a more economical supply of power.

Because these generators would only be used when commercial power is too expensive to obtain, the amount of emissions expected during the actual operation of these generators is minor. In addition, the installation of these generators qualifies as a “temporary source” under the PSD permitting program because the permit will limit the operation of these generators to a time period of less than 2 years. Therefore, Cenex would not need to comply with ARM 17.8.804, 17.8.820, 17.8.822, and 17.8.824. Even though the portable generators are considered temporary, the Department required compliance with BACT and public notice requirements; therefore, compliance with ARM 17.8.819 and 17.8.826 would be ensured. In addition, Cenex would be responsible for complying with all applicable air quality standards. In order to keep this permitting action below the threshold of nonattainment area permitting requirements, Cenex requested a limitation to keep the project’s potential emissions of SO₂ below 40 tons. MAQP #1821-06 replaced MAQP #1821-05.

MAQP #1821-07 was issued on August 28, 2001, to change the wording regarding the stack height on the temporary generators, to allow for the installation of mufflers on those stacks, thus increasing the total stack height. In addition, the Department modified the permit to eliminate references to the repealed odor rule, to correct conditions improperly referencing the incinerator rule, and to update a testing frequency on the product loading rack VCU based on the Title V permit term. MAQP #1821-07 replaced MAQP #1821-06.

On June 3, 2002, the Department received a request from Cenex to modify MAQP #1821-07 to remove all references to 8 temporary, portable electricity generators. The generators were permitted under MAQP #1821-06, with further clarification added in MAQP #1821-07 regarding generator stack height. The generators have not been operated since August 10, 2001, and Cenex has no intention of operating them in the future. The references to the generators were removed, and the generators are no longer included in Cenex’s permitted equipment. **MAQP #1821-08** replaced MAQP #1821-07.

On March 13, 2003, the Department received a complete permit application from Cenex to modify MAQP #1821-08 to add a new Ultra Low Sulfur Diesel (ULSD) Unit, Hydrogen Plant, and associated equipment to meet the EPA’s 15 parts per million (ppm) sulfur standard for highway diesel fuel for 2006. The permit action removed the Middle Distillate Unifiner (MDU) charge heater, MDU stripper heater, MDU fugitives, and the #3 and #4 Unifier Compressors. The ULSD Unit included two heaters, four compressors, C-901 A/B and C-902 A/B, process drains, and fugitive piping components. The Hydrogen Plant included a single fired reformer heater, process drains, and fugitive piping components.

The treated stream from the ULSD Unit was separated into its constituent fuel blending products or into material needing further refining. The resulting stream was then stored in existing tanks and one new tank (128). Three existing tanks (73, 86, and 117) were converted to natural gas blanketed tanks to reduce emissions of VOCs from the ULSD Unit feed stock product streams. Cenex was to install a new TGTU for both the SRU #1

and #2 trains that will be operational prior to startup of the ULSD Unit but technically are not part of this permitting action. **MAQP #1821-09** replaced MAQP #1821-08. On July 30, 2003, the Department received a complete application from CHS to modify MAQP #1821-09. The application was complete with the addition of modeling information provided to the Department on August 22, 2003. CHS requested to add a new TGTU and associated equipment for Zone A's SRU #1 and SRU #2 trains to control and reduce SO₂ emissions from this source. CHS submitted modeling to the Department for a determination of a minimum stack height for the existing SRU #1 and SRU #2 tail gas incinerator stack. CHS also submitted a letter to the Department to change the name on the permit from Cenex to CHS. The permit action added the new TGTU, set a minimum stack height for the tail gas incinerator stack, and changed the name on the permit from Cenex to CHS. **MAQP #1821-10** replaced MAQP #1821-09.

On June 1, 2004, the Department received two applications from CHS to modify MAQP #1821-10. The applications were complete with the addition of requested information provided to the Department on June 16, 2004. In one application CHS requested to change the nomenclature for Reformer Heater H-801 to Reformer Heater H-1001. H-801 was previously permitted during the ULSD project (MAQP #1821-09), at 150-MMBtu/hr. CHS requested to change the size of Reformer Heater H-801 (H-1001) from 150-MMBtu/hr to 161.56-MMBtu/hr. In the other application CHS requested to increase the PAL for CO from 530.7 tons per year to 678.2 tons per year based on new information obtained by CHS. The new information was obtained after the installation of a CO continuous emission monitor (CEMS) on the FCCU Stack. Emissions of CO from the FCCU Stack were assumed to be zero until the installation of the CEMS. CHS also requested that specific emission limits, standards, and schedules required by the CHS Consent Decree be incorporated into the permit. **MAQP #1821-11** replaced MAQP #1821-10.

On December 15, 2004, the Department received a letter from CHS to amend MAQP #1821-11. The changes were administrative, primarily related to changing routine reporting requirements from a monthly basis to quarterly. The changes to the permit were made under the provisions of ARM 17.8.764, Administrative Amendment to Permit. **MAQP #1821-12** replaced MAQP #1821-11.

On March 28, 2006, the Department issued **MAQP #1821-13** to CHS to build a new 15,000-barrel per day (BPD) delayed coker unit and associated equipment. The new delayed coker unit allows CHS to increase gasoline and diesel production by 10-15% by processing heavy streams that formerly resulted in asphalt (asphalt production is expected to decrease by approximately 75%, but the capability to produce asphalt at current levels was maintained and no emission credits were taken with respect to any possible reduction in asphalt production) without increasing overall crude capacity at the refinery. The delayed coker unit produces 800 short tons per day of a solid petroleum coke product. To accommodate the downstream changes created by the new delayed coker unit, several other units will be modified including the Zone D FCC Feed Hydrotreater, FCCU, ULSD Unit, and Hydrofluoric Acid (HF) Alky Unit. Other units will be added: Delayed Coker SRU/TGTU/TGI, NHT Unit, NHT Charge Heater, Boiler No. 11, Light Products Railcar Loading Facility, and two new tanks will be added to the Tank Farm. Other units will be shut down: the Propane Deasphalting Unit, Unifiner Compressors No. 1 and 2, No. 2 Naphtha Unifier Charge Heater and Reboiler, BP2 Pitch Heater, and Boilers No. 3 and 4. The VCU associated with the new Light Products Railcar Loading Facility and the Coker Unit TGI were subject to and the requirements of 75-2-215, MCA and ARM 17.8.770, Additional Requirements for Incinerators. The Delayed Coker project and associated equipment modifications did not cause a net emission increase greater than significant

levels and, therefore, does not require a New Source Review (NSR) analysis. The net emission changes were as follows:

Constituent	Total Project PTE (TPY)	Contemporaneous Emission Changes (TPY)	Net Emissions Change (TPY)	PSD Significance Level (TPY)
NO _x	39.2	-7.5	31.8	40
VOC	-1.5	-53.3	-54.8	40
CO	106.7	-23.2	83.5	100
SO ₂	39.7	0.0	39.7	40
PM	7.6	6.6	14.2	25
PM ₁₀	6.7	6.6	13.3	15

The following is a summary of the CO emissions included in the CO netting analysis: Coker project (+106.7 TPY), emergency generator (+0.44 TPY, start-up in 2002), Zone A TGTU project (+8.3 TPY, initial startup at end of 2004), and Ultra Low Sulfur Diesel project (-31.9 TPY, started up in 2005). MAQP #1821-13 replaced MAQP #1821-12.

On May 4, 2006, the Department received a complete application from CHS to incorporate the final design of three emission sources associated with the new 15,000 BPD delayed coker unit project permitted under MAQP #1821-13. The final design capacities have increased for the new NHT Charge Heater, the new Coker Charge Heater and the new Boiler No. 11. The application also includes a request to reduce the refinery-wide fuel oil burning SO₂ emission limitation. This reduction allows CHS to stay below the significance threshold for the applicability of the New Source Review-PSD program. The maximum firing rates are proposed to increase with the current permitting action. The following summarizes the originally permitted firing rates (MAQP #1821-13) and the new proposed firing rates for the heaters and the boiler:

NHT Charge Heater: 13.2 to 20.1 million British thermal units – Lower Heating Value per hour (MMBtu-LHV/hr) (22.1 million British thermal units – Higher Heating Value per hour (MMBtu-HHV/hr))

Coker Charge Heater: 129.3 to 146.2 MMBtu-LHV/hr (160.9 MMBtu-HHV/hr)

Boiler #11: 175.9 to 190.1 MMBtu-LHV/hr (209.1 MMBtu-HHV/hr)

CHS also requested several clarifications to the permit. Under MAQP #1821-13 several 12-month rolling limits were established for modified older equipment and limits for new equipment. CHS requested clarifications be included to determine when compliance would need to be demonstrated for these new limits. MAQP #1821-13 went final on March 28, 2006, and CHS is required to demonstrate compliance with the new limitations from this date forward. For the 12-month rolling limits proposed under MAQP #1821-13 and any changes to limitations under the current permit action, CHS would be required to demonstrate compliance on a monthly rolling basis calculated from March 28, 2006. For modified units the limitations will have zero emissions until modifications are made. New units will have zero emissions until start-up of these units. Start-up is defined as the time that the unit is combusting fuel, not after the start-up demonstration period. Some units have clearly designated compliance timeframes based on the consent decree. These limitations and associated time periods are listed within the permit.

The Department agreed that the heading to Section X.A.3 can include the “*Naptha Hydrotreating Unit*”; Section D.1.c is based on a 30-day rolling average; Section X.D.7.a.ii should state that the SO₂ limit is based on a 12-hour average; and that Section

XI.E.3 should be revised to remove the requirement for a stack gas volumetric flow rate monitor. The Department made some clarifications to the language in Section X.D.6.b. The Department's intent in permitting the coke pile with enclosures was to ensure that at no time would the coke pile be higher than the top of the enclosure walls at any point on the pile, not only the portion of the pile that is adjacent to the wall.

The Department did not believe it was necessary to designate the Sour Water Storage Tank as a 40 CFR 60, Subpart Kb applicable tank, when currently these regulations do not apply. If CHS makes changes in the future and 40 CFR 60, Subpart Kb becomes applicable to the tank, then CHS can notify the Department and the Department can include the change in the next permit action.

The Department received comments from CHS on the preliminary determination of MAQP #1821-14 on June 21, 2006. The comments were editorial in nature and the changes were made prior to issuance of the Department Determination on MAQP #1821-14. CHS requested corrections to the PM, PM₁₀, NO_x netting values in contained in the permit analysis, and the Department agreed that the edits were needed. CHS also requested further clarification to the requirements of Section X.D.6.b of the permit.

CHS stated that the coke pile will be dropped from two coke drums to a location directly adjacent to the highest walls of the enclosure area. The height of the dropped coke piles will not exceed the height of the wall. If CHS is required to relocate and temporarily store the coke at another location within the enclosure area, CHS will not pile the coke higher than the walls adjacent to the temporary storage location. **MAQP #1821-14** replaced MAQP #1821-13.

On September 11, 2006, the Department received an application from CHS to incorporate the final design of emission sources associated with the new 15,000-BPD delayed coker unit project permitted under MAQP #1821-13 and revised under MAQP #1821-14. The changes included:

- Retaining Boiler #4 operations and permanently shutting down the CO Boiler;
- Modifying the FCCU Regenerator CO limit due to the air grid replacement;
- Rescinding the permitted bottleneck project for Zone D SRU/TGTU/TGI and revising the long term SO₂ potential to emit;
- Modifying the Zone E (Delayed Coker) SRU/TGTU/TGI - Incinerator design and NO_x limits;
- Rescinding the firing rate restriction and associated long-term emission limits, and revising VOC emission calculations for H-201 and H-202; and
- Removing the 99.9 MMBtu/hr restriction and reclassifying Boiler #10 as subject to NSPS Subpart Db.

On October 11, 2006, the Department received a request to temporarily stop review of the permit application until several additional proposals were submitted, which included:

- On October 24, 2006, the Department received a de minimis notification for stack design changes for the Delayed Coker Unit (Zone E) SRU Incinerator.

- On October 31, 2006, the Department received clarification on the ULSD project.
- On November 1, 2006, the Department received a request to limit the maximum heat rate capacity of the #2 N.U. Heater to below 40 MMBTU/hour in conformance with the CHS Consent Decree. CHS also requested that the Department re-initiate review of MAQP #1821-15.

All of the above changes allowed CHS to stay below the significance thresholds for the applicability of the New Source Review-PSD program. CHS also requested several clarifications to be included in the permit, and the Department suggested streamlining the permit's organization. **MAQP #1821-15** replaced MAQP #1821-14.

On October 10, 2007, the Department received an application from CHS to modify MAQP #1821-15 to incorporate the final design of the NHT Charge Heater. This heater was permitted as part of the refinery's delayed coker project permitted under MAQP #1821-13 and revised under MAQP #1821-14 and MAQP #1821-15. The modification to MAQP #1821-15 was requested to address an operating scenario that was overlooked during the delayed coker unit design process. This operating scenario is for the case in which the NHT unit is in operation, but the delayed coker unit is not. In this operating scenario, the characteristics of the naptha being processed in the unit are such that additional heat input to the heater is required to achieve the design NHT Unit throughput. For this reason, CHS requested approval for an increase in the design firing rate of the NHT Charge Heater (H-8301). The following summarizes the permitted firing rates under MAQP #1821-15 and the new proposed firing rates for the NHT Charge Heater:

Maximum Firing Rate (LHV): 20.1 MMBtu-LHV/hr to 34.0 MMBtu-LHV/hr
 Maximum Firing Rate (HHV): 22.1 MMBtu-HHV/hr to 37.4 MMBtu-HHV/hr
 This change does not impact any of the other design conditions in the original delayed coker permit, including unit throughputs and operating rates. The application also includes a request to reduce the refinery-wide fuel oil burning SO₂ emission limitation. This reduction allows CHS to stay below the significance thresholds for the applicability of the New Source Review-PSD program. CHS also requested some administrative changes to the permit. **MAQP #1821-16** replaced MAQP #1821-15.

On February 25, 2008, the Department received a complete application from CHS to modify MAQP #1821-16 for the completion of two separate projects. For the first project, CHS proposed to construct a new 209.1 MMBtu-HHV/hr steam generating boiler (Boiler #12). This project includes the permanent shutdown of two existing boilers, Boilers #4 and #5, which have a combined capacity of 190 MMBtu-LHV/hr. The two existing boilers are being shutdown in part to meet the consent decree NO_x reduction requirements, as well as to generate NO_x offsets for this permitting action.¹ Due to the operational complexity of replacing two existing boilers with one new boiler in the refinery steam system, CHS requested to maintain the ability to operate the #5 Boiler for 1 year after initial start-up of Boiler #12. Combustion of fuel oil in the refinery boilers would also be eliminated primarily to generate NO_x offsets for this permitting action.

For the second project, CHS proposed an expansion of its railcar light product loading facilities. Although there would be no increase in refinery production from this expansion, the project would increase flexibility in the transportation of refinery products. After project completion, there would be a total of nine spots available at this loading rack for product loading into railcars. The railcar light product loading facility

1. This is later clarified in the permit history for MAQP #1821-21. No creditable NO_x emissions reductions from the shutdown of Boiler #4 and #5 were used in the permit for construction of new Boiler #12 (MAQP #1821-17).

was originally permitted as part of the delayed coker project permitted under MAQP #1821-13 and revised under MAQP #1821-14, #1821-15, and #1821-16. This change does not require a modification to the originally permitted VCU since the maximum loading rate of 2,000 gallons per minute (gpm) will remain unchanged.

The application also included a request to reduce the limitation for SO₂ emissions from the combustion of alkylation unit polymer and fuel oil in all combustion devices from 127.6 TPY to 50 TPY (for alkylation unit polymer only since fuel oil combustion in refinery boilers will be eliminated). Although the potential to emit for the combustion of alkylation unit polymer in the Alkylation Unit Hot Oil Heater is estimated to be around 8.3 TPY for SO₂ (based on a specific gravity of 0.7 and a sulfur content of 1 wt%; the exact potential to emit has not been determined due to the variability of specific gravity and sulfur content), the allowable emissions are set at 50 TPY in this permitting action. According to ARM 17.8.801(24)(f), the decrease in actual emissions from the elimination of fuel oil combustion in refinery boilers is creditable for PSD purposes provided the old level of actual emission or the old level of allowable emissions, *whichever is lower*, exceeds the new level of actual emissions and the decrease in emissions is federally enforceable at and after the time that actual construction begins. Since the old level of actual emissions is lower than the old level of allowable emissions for combustion of fuel oil in refinery boilers, CHS requested a creditable reduction based on actual emissions from the boilers. This reduction resulted in a total of 50 TPY SO₂ allowed for the combustion of alkylation unit polymer in the Alkylation Unit Hot Oil Heater, the only unit that is part of the original SO₂ limitation for fuel oil combustion devices that will continue to operate. While it appears that the emissions from the combustion of alkylation unit polymer would be allowed to increase through this permitting action, it is important to note that physical modifications and/or changes in the method of operation would first have to occur for the Alkylation Unit Hot Oil Heater to emit more than its estimated potential of 8.3 TPY (note: the exact potential to emit has not been determined at this time). As acknowledged by CHS, a modification and/or change in method of operation to this unit would require a permit modification. Therefore, the Department does not anticipate any increase in actual emissions from this unit, even though the allowable has been set at 50 TPY. In addition, should CHS eliminate or reduce the combustion of alkylation unit polymer in future permit actions in order to have a creditable decrease for PSD purposes, only the change in actual emissions would be available since the actual emissions will be lower than the allowable, unless a modification to the unit is made.

In addition, CHS requested that the permit CO emission limits for Boiler #11 be changed to 36.63 TPY and 15.26 lb/hr, based on a revised emission factor from performance test data completed in 2007 for Boiler #11 used to calculate the PTE. All of these changes allow CHS to stay below the significance thresholds for the applicability of the New Source Review-PSD program.

CHS also requested some additional administrative changes to the permit, including clarification of the applicability of 40 CFR 63, Subpart DDDDD: NESHAP for Industrial, Commercial, and Institutional Boilers and Process Heaters to various sources given the fact that the federal rule was vacated on July 30, 2007. Although the federal rule has been vacated, the vacated federal rule remains incorporated by reference in ARM 17.8.103 and ARM 17.8.302 (with the applicable publication date specified in ARM 17.8.102) at the time of **MAQP #1821-17** issuance and as such, it remains an applicable requirement under state rules; each applicable permit condition has been marked 'State-Only Requirement'.

On April 1, 2008, CHS requested that the Department delay issuance of the preliminary

determination for this permit application until additional information could be submitted regarding alternative coke handling practices. This additional information was submitted to the Department on April 3, 2008, with follow-up information received by the Department on April 14, 2008. CHS requested that an alternative coke handling process be included in MAQP #1821-17. The coke handling process, originally permitted as part of the delayed coker project, included the use of conveyors to transport coke to a crusher and to a railcar loading system. Because the system is enclosed, it is not possible to transport coke to the crusher and loading system without the use of the conveyors. CHS has since identified the need for an alternate coke handling method to be used when the conveyors are out of operation for either planned or unplanned maintenance. MAQP #1821-17 replaced MAQP #1821-16.

On November 7, 2008, the Department received a MAQP application from CHS for a benzene reduction project. In this application, CHS requested to modify MAQP #1821-17, to allow construction of a new Benzene Reduction Unit within the Laurel refinery to meet the requirements of the Mobile Source Air Toxics Rule (40 CFR 80, Subpart L). This rule requires that the refinery's average gasoline benzene concentration in any annual averaging period not exceed 0.62 volume percent, beginning January 1, 2011. This new unit will be inserted in the middle of the existing Platformer Unit. The new process will receive feed from the high pressure separator of the existing Platformer unit and produce a heavy platformate stream that will go directly to product storage and a light platformate stream that will be treated further. The light platformate stream, concentrated with benzene, will undergo a benzene hydrogenation reaction to convert the benzene to cyclohexane. This stream will then be fed to the existing Platformer Unit's debutanizer.

Because the Benzene Reduction Unit includes a hydrogenation reaction, hydrogen is required for the process. For this reason, modification to the existing 1,000 Unit Hydrogen Plant is planned. This modification will essentially increase hydrogen production in the amount needed in the new process and includes the addition of a steam superheater and an Enhanced Heat Transfer Reformer (EHTR). In the existing process, hydrogen is produced by mixing natural gas and the hydrogen-rich Platformer Unit off gas stream with saturated steam. However, in the modified process, only natural gas will be used. Additionally, the steam used will be super-heated to supply additional heat to the primary reformer by means of a higher inlet process gas temperature. This modified process will allow for an increase in the process feed gas flow at the same reformer heat duty. As a result, more hydrogen will be produced in the reformer without increasing the firing rate, and thus, emission rate, of the H-1001 Reformer Heater. For this reason, the H-1001 Reformer Heater is not a project affected emission unit.

In this application, CHS also requested to make enforceable the retrofit of the Platformer Heater with low NO_x burners. This modification is being done to achieve Consent Decree required NO_x reductions. This modification is not required by the Benzene Reduction project; however, the retrofit of the Platformer Heater will occur during the construction phase of the Benzene Reduction project.²

The Department reviewed this application and deemed it incomplete on December 1, 2008. The Department requested additional information to support the BACT analysis for the Platformer Splitter Reboiler. The Department received the requested follow-up

2. The requirement to retrofit the Platformer Heater with low NO_x burners was removed in MAQP #1821-21. CHS elected to achieve the Consent Decree required NO_x reductions by using projects other than the Platformer Heater retrofit.

information from CHS on December 15, 2008; the application was deemed complete as of this date.

In addition to making the requested changes, the Department has clarified the permit language for the bulk loading rack VCU regarding the products that may be loaded in the event the VCU is inoperable and deleted all references to 40 CFR 63, Subpart DDDDD: NESHAP for Industrial, Commercial, and Institutional Boilers and Process Heaters, as it was removed from the ARM in October 2008. **MAQP #1821-18** replaced MAQP #1821-17.

On February 27, 2009, the Department received a complete MAQP application from CHS requesting clarification of an existing NO_x emissions limit for Boiler #12. In this application, CHS requested that the averaging period for the NO_x pound per million British thermal unit (lb/MMBtu) limit be specified as a 365-day rolling average. CHS submitted information to support this averaging period as the original basis for the BACT analysis conducted in MAQP #1821-17 for Boiler #12. **MAQP #1821-19** replaced MAQP #1821-18.

On August 13, 2009, the Department received a complete application from CHS requesting a modification to MAQP #1821-19. CHS proposed to retrofit the existing Boiler #10 with a lower NO_x control technology burner and to update the permit limits for this unit accordingly. This project was completed on a voluntary basis by CHS in order to improve environmental performance and boiler reliability. On September 17, 2009, the Department received a revision to this application addressing the SO₂ BACT analysis for both Boiler #10 and the recently permitted Platformer Splitter Reboiler. This application revision was submitted in consultation with the Department and revised the SO₂ BACT analysis to reflect the recently finalized NSPS Subpart Ja requirements. **MAQP #1821-20** replaced MAQP #1821-19.

On March 31, 2010, the Department received an application from CHS requesting a modification to MAQP #1821-20. Additional information was received on April 22, 2010 resulting in a complete application. The application and additional information included requests for several modifications within the permit.

During the issuance of MAQP #1821-17, it became apparent that the Department and CHS had differing interpretations of paragraphs 177 and 180 of the CHS Consent Decree (CD) with EPA and the State of Montana (Consent Decree CV-03-153-BLG-RFC). Based on these differing interpretations, CHS deemed it necessary to retroactively analyze previous permit actions, particularly associated with the Delayed Coker Project, where changes may be necessary as a result of interpreting the CD in an alternative manner. On October 26, 2009, CHS provided an analysis concluding that the Delayed Coker Project was properly permitted as a non-major modification under New Source Review (including both PSD and Non-attainment Area New Source Review (NNSR)). For four pollutants (CO, VOC, TSP, and PM₁₀), project related emissions increases determined under Step 1 of the required applicability analysis were below the applicable significance thresholds. For two pollutants (NO_x and SO₂), the net emissions change, including project related emissions increases and contemporaneous emissions changes, were below the applicability significance thresholds. Following review, the Department concurred with CHS' analysis. However, as a result of this re-examination, including updates and changes to the original Delayed Coker Project emissions calculations, the following updates to MAQP #1821-20 were necessary to accurately reflect the refinery's overall process and individual emitting units.

1. Coke Drum Steam Vent

The original Delayed Coker Permit application did not include an estimate of the emissions associated with depressurizing the coke drum as part of the decoking operation. Based on emissions quantified at another facility, CHS was able to estimate emissions from their Coke Drum Steam Vent. MAQP #1821-21 has been updated to include this emitting unit in addition to the limitations and conditions assigned to it.

2. FCCU Regenerator

As part of the CD requirements, CHS completed catalyst additive trials at the FCCU in order to reduce NO_x emissions. Upon completion of the trials, CHS proposed short term (7-day rolling average) and long term (365-day rolling average) concentration-based NO_x limits to EPA. CHS proposed a long term concentration limit of 65.1 parts per million, volumetric dry (ppm_{vd}) on a 365-day rolling average basis and a short term concentration limit of 102 ppm_{vd} on a 7-day rolling average basis. EPA has agreed to these proposed limitations and these limits have been included within MAQP #1821-21.

3. Boiler 12 and Railcar Light Product Loading Projects

Originally permitted within MAQP #1821-17, the Boiler 12 and Railcar Light Product Loading Projects were included in the same permit application for administrative convenience only and should not be included as part of the Delayed Coker Project's emissions increase calculations. The Department agrees that the two projects were not substantially related and had no apparent interconnection to each other or to the Delayed Coker Project. The emissions calculations have been updated to reflect this conclusion.

4. Shutdown Timing for #4 and #5 Boilers

Included in the permitting action resulting in MAQP #1821-17 were shutdown dates for Boiler #4 and Boiler #5, which was tied to the initial startup of Boiler #12. Because emissions reductions from the boiler shutdowns were not required to avoid triggering the PSD requirements, the shutdown dates are no longer related to the startup of Boiler #12. The timing is driven by the CD, requiring all NO_x reduction projects (including shutdown of Boiler #4 and Boiler #5) to be completed by December 31, 2011. The shutdown timing has been updated.

5. Benzene Reduction Unit Project Updates

As a portion of the plan to achieve required NO_x emissions reductions as outlined in the CD, CHS had elected to retrofit the Platformer Heater (P-HTR-1) with low NO_x burners. The proposed retrofit was included in the application for the Benzene Reduction Project (MAQP #1821-18). CHS has determined that the retrofit will no longer be necessary to achieve the CD required NO_x reductions. All emission limitation and monitoring, reporting and notification requirements were removed.

6. Boiler #11 and Boiler #12 BACT Analysis Update

The original BACT analyses included in the permit applications associated with Boiler #11 and Boiler #12 did not specifically address CO emissions during startup and shutdown operations. During these operations, the boiler may experience an increase in CO emissions as a result of the ultra low nitrogen oxide (NO_x) burner (ULNB) design. Based on an analysis of data collected during startup and shutdown operations for Boiler #11 and Boiler #12, a short term CO limit of 23 lb/hr on a 24-hour average basis, was included for periods of boiler startup and shutdown. Additionally, CHS proposed installation and operation of a volumetric stack flow rate monitor on Boiler #11 in order to be consistent with Boilers #10 and #12.

In addition to the aforementioned updates, CHS also requested a modification to the stack testing requirements to require stack testing every two years as opposed to annual stack testing for the following sources: Reactor Charge Heater (H-201), Fractionator Feed Heater (H-202), Reactor Charge Heater (H-901), Fractionator Reboiler (H-902), and NHT Charge Heater (H-8301). The Department approved this new testing schedule and MAQP #1821-21 has been updated accordingly. Additionally, various miscellaneous administrative changes were requested and included in this permitting action. **MAQP #1821-21** replaced MAQP #1821-20.

C. Current Permit Action

On July 27, 2010, the Department received a request to administratively amend MAQP #1821-21. The Department had inadvertently failed to modify all pertinent sections within MAQP #1821-20 to reflect the December 31, 2011 shutdown date for Boiler #4 and Boiler #5. CHS had requested the Department to administratively amend the permit to reflect this shutdown date in all applicable sections within the permit. CHS also requested the Department administratively amend the permit to include a reference to ppm_{vd} units where H₂S limits are expressed in grains per dry standard cubic feet (gr/dscf). The Department made the aforementioned administrative changes. **MAQP #1821-22** replaces MAQP #1821-21.

D. Process Description – Permitted Equipment

HDS Complex - CHS constructed a new desulfurization complex within the existing refinery to desulfurize the gas-oil streams from the crude, vacuum, and the propane deasphalting units in 1992. The HDS unit removes sulfur from the gas-oil feedstock before further processing by the existing FCC unit. The new HDS unit greatly reduces the sulfur content of the FCCU feeds and, thereby, reduces the regenerator sulfur oxide emissions. Sulfur oxide emissions from the FCCU occur when coke-sulfur is burned off the catalyst at the unit's regenerator. Also, the FCCU clarified oil will contain a much lower sulfur content due to the HDS unit. FCCU clarified oil, when burned throughout the refinery in various furnaces and boilers, will result in lower sulfur oxide emissions. By removing sulfur compounds from the gas-oil and other FCCU feedstocks, the HDS process effectively reduces the sulfur content of refinery finished products, such as gasoline, kerosene, and diesel fuel. Lower sulfur content in gasoline and diesel fuels results in lower sulfur oxide emissions to the atmosphere from combustion by motor vehicle engines.

Additionally, the desulfurization complex includes other process units, such as the SWS, amine, SRU, and the TGTU. The new Hydrogen Plant and new HDS unit make up the new desulfurization complex for the refinery.

CHS filed a petition for declaratory judgment, which was granted by district court, which affords confidentiality protection on all HDS process and material rates, unit and equipment capacities, and other information relating to production. These are declared to be trade secrets and are not part of the public record. Hence, the reason for not providing the barrels-per-stream-day (BPSD) capacity of the new HDS unit and other new units, save the SRU, considered in this permit application analysis.

Hydrogen Plant - This unit produces pure hydrogen from propane/natural gas and recycled hydrocarbon from the hydrosulfurizer, which, in turn, is used in the HDS unit. The feed is first purified of sulfur and halide compounds by conversion over a cobalt/molybdenum catalyst and subsequent absorption removal. The purified hydrocarbon is mixed with steam and the whole stream is reformed over a nickel catalyst to produce hydrogen (H_2), CO, carbon dioxide (CO_2), and methane (CH_4). The CO is converted to CO_2 over an iron oxide catalyst and the total gas stream cooled and finally purified by a solid absorbent in a fixed bed or Pressure Swing Adsorption unit (PSA), (hydrogen purification unit).

The reformer heater (H-101) is utilized by the Hydrogen Plant. The design heat input rate is 123.2 MMBtu/hr; however, CHS has determined that heat inputs of up to 135.5 MMBtu/hr are necessary for short periods of time. This heater burns a combination of natural/refinery gas and recovered PSA gas. PSA gas (374Mscf/hr) supplies 85% (104.7 MMBtu/hr) of the necessary fuel requirement. The remaining 15% (18.5 MMBtu/hr) fuel requirement is supplied by natural/refinery gas (19.3Mscf/hr).

HDS Unit – A feed blend of preheated gas oils/light cycle oils from various crude units are filtered and dewatered. The feed is further heated by the reactor charge heater (H-201) and combined with a stream of hydrogen-rich treat gas and charged to the first of three possible reactors. Only two reactors (first and second) are installed and a third reactor may be added in the future. The reactors contain one or more proprietary hydro-treating catalysts, which convert combined sulfur and nitrogen in the feed into hydrogen sulfide (H_2S) and ammonia (NH_3). Effluent off the reactor flows to a hot high-pressure separator where the vapor and liquid phases separate. The vapor/liquid stream then enters the cold high-pressure separator where the phases separate. Liquid water separates from the liquid hydrocarbon phase and collects in the boot of the vessel where vapor separates from the liquids. The vapor stream from the cold high-pressure separator flows to the high-pressure absorber, where it is contacted with amine solution to remove H_2S . The vapor stream is then subjected to a water wash to remove entrained amine. Amine, rich in H_2S , is pressured from the bottom of the absorber to the amine regeneration unit. The scrubbed and washed gas leaves the top of the high-pressure absorber and passes to the recycle cylinders of the make-up/recycle gas compressors. A portion of the discharge gas from these compressor cylinders is used as quench to control the inlet temperatures of the second reactor (and possibly a third reactor in the future).

H_2 from the Hydrogen Plant flows into the make-up/recycle gas unit section. The H_2 is compressed in the two-stage make-up cylinders of the make-up/recycle gas compressors and then mixed with the recycle gas stream. The combined gas (treat gas) recovers heat from the hot high-pressure separator and is then injected into the preheated oil feed at the inlet of the heat recovery exchangers.

In the fractionation section of the HDS unit, hot liquid from the hot high-pressure separator is mixed with cold liquid from the cold high-pressure separator and the combined stream is flashed into the H_2S stripper tower. The heat in the tower feed and

steam stripping separates an off-gas product from the feed with essentially complete removal of H₂S from the bottom product. This off-gas product leaves the H₂S stripper overhead drum and flows to the amine unit for recovery of sulfur. The bottom product from the H₂S stripper is heated in the fractionator feed heater (H-202) and is charged to the flash zone of the fractionator. In the fractionator tower and associated diesel stripper tower, H₂S stripper bottoms are separated into a naphtha overhead product, a diesel stripper stream product, and a bottom product of FCC feed. Separation is achieved by heat in the feed, steam stripping of the bottom product, and reboiling of the diesel product.

The naphtha product is pumped from the fractionator overhead drum to intermediate storage. The diesel and bottoms desulfurized gas-oil (FCC feed) products are also pumped to intermediate storage. A new wash water and sour water system will accompany the reaction/separation section of the HDS unit. Water is pumped from the wash water surge tank and injected into the inlet of the high-pressure separator vapor condenser to remove salts and into the high-pressure absorber circulating water system to remove amine. Water injected to the hot high-pressure separator vapor condenser produces sour water, which accumulates in the water boot of the cold/high-pressure separator. This sour water is pressured to the sour water flash drum. Additional sour water is produced from stripping steam and heater injection steam and accumulates in the water boots of the H₂S stripper overhead drum and the fractionator overhead drum. Other accumulations from sour water sources, such as knock-out drums, are also sent up to the sour water flash drum. The sour water is pressured from the sour water flash drum and sent to the sour water storage tank.

A reactor charge heater (H-201) and fractionator feed heater (H-202) is utilized by the HDS unit. H-201 design heat input rate is 37.7 MMBtu/hr. Once the HDS reactors are at operating temperature, the process is exothermic. As a result, H-201 firing rates are reduced. For purposes of this application, the worst case assumption is made that H-201 always operates at 80% for design (30.2 MMBtu/hr and 31.2 Mscf/hr). H-202 heat input design rate is 27.2 MMBtu/hr. Similar to H-201, once the HDS reactors are at operating temperature, the process is exothermic and produces sufficient heat to sustain the reaction temperature. Excess heat is recovered and transferred to the fractionator feed which reduces the need for the fractionator feed heater. For purposes of this application, the worst case assumption is made that H-202 operates at 75% of full design capacity (20.4 MMBtu/hr and 21.3 Mscf/hr).

The natural gas-fired compressor engine (C-201B) is utilized by the make-up/recycle gas section of the HDS unit. Two combined compressors operate in parallel at 50% of design duty or at 2/3 of machine design capacity. Each compressor is designed for 75% of the design process duty. The gas-fired engine is a 2000-HP (horsepower) rated unit. For purposes of the application, pollutant emission rates are based on normal operating load of 1060 HP (7918 scf/hr). The compressor engine will not fire refinery fuel gas; instead, natural gas will be burned with propane as a contingency fuel. Due to piston failure of C-201B in 2006, an identical replacement engine was installed, which will be subject to NSPS and MACT standards.

Amine Unit - A solution of amine (nitrogen-containing organic compounds) in water removes H₂S from two refinery gas streams. The new amine unit will not process sour refinery fuel gas since this operation is to be handled by the existing refinery amine unit, except for amine unit start-up operations.

Amine temperature is controlled to assure that no hydrocarbon condensation occurs in the absorber tower. A large flash tank with a charcoal filter is used to remove any dissolved

hydrocarbons. The flash vapor flows to the TGTU for sulfur recovery. Also from the flash tank, the rich amine flows through the rich/lean exchanger where it is heated and sent to the still regenerator. The regenerator is heat controlled. The clean amine level is controlled and the amine cooler stream is sent to a surge tank with a gas blanket. Lean low-pressure and high-pressure streams are pumped from the surge tank to their respective contactors. H₂S in the overhead gas from the amine still accumulator are directed to the new SRU.

Sour Water Stripper - A new SWS was constructed, which replaced the operation of the older existing SWS. The new SWS unit serves the existing and proposed facilities of this HDS project. The old SWS cannot be removed, however, and functions only as the back-up unit. Sour water from a variety of sources in the refinery is accumulated in the sour water storage tank where hydrocarbons are separated. The hydrocarbon is sent to the existing slop oil system for recovery. The gas vapors from the sour water tank are compressed and sent to the tail gas unit for sulfur recovery. Sour water from the storage tank is pumped into the SWS tower. Steam heat is applied to the stripper to remove H₂S and NH₃ from the water. The stripper overhead gas containing H₂S and NH₃ is sent to the new SRU for sulfur recovery and incineration of NH₃.

Sulfur Recovery Plant - The SRU is designed as a dual operation facility. The SRU has two different modes of operation.

Mode I - Standard Straight Through Operation is where the unit operates as a standard three-bed Claus unit. The Claus operation consists of a sulfur reaction furnace designed to sufficiently burn (oxidize) incoming acid gas (H₂S) to SO₂, to form water vapor and elemental sulfur. SO₂ further reacts with H₂S to form more sulfur and water vapor. This is accomplished over three sulfur reactor catalyst beds and four condensers. Following the final reactor and condensing phase, the tail gas from the SRU is directed to the TGTU where additional sulfur treating occurs to further enhance recovery.

The new SRU has a design input rate of 79.18 short tons of sulfur per day (70.69 long ton/day) from three refinery feed streams. The overall efficiency of Mode I operation is 97.0%. This figure does not include additional sulfur recovery at the TGTU. Mode II - Sub-Dew Point Operation utilizes the same Claus reaction and front-end operation, except the second and third catalyst beds are alternated as sub-dew point reactors. The gas flow is switched between the two beds. When a bed is in the last position, the inlet temperature is lowered, which allows further completion of the H₂S-SO₂ reaction and, thereby, recovering more sulfur. The sulfur produced condenses, due to the lower temperature, and is absorbed by the catalyst. After 24 hours of absorbing sulfur, the switching valve directs the gas flow from the third reactor to the second reactor and from reactor #2 to reactor #3. The cold bed is then heated by being diverted to the hot position and all the absorbed sulfur is vaporized off, condensed and collected. The former hot bed is then cooled and utilized as the sub-dew point reactor for a period of 24 hours. The system cycles on a daily basis. The overall efficiency of Mode II operation is 98.24%. This figure does not include additional sulfur recovery at the TGTU. The advantage to two different modes of operation is for those times when the TGTU is not operating. The final heater (E-407) is used during the standard Claus unit operation; but, during the sub-dew point mode, it is blocked to prevent sulfur accumulation.

Tail Gas Treating Unit - The TGTU converts all sulfur compounds to H₂S so they can be removed and recycled back to the SRU for reprocessing. This process is accomplished by catalytically hydrogenating the Claus unit effluent in a reactor bed. From the reactor, the vapor is cooled in a quench tower before entering the unit's amine contactor. The hot vapors enter the bottom of the quench tower and contact water coming down the tower.

The water is sent through a cooler exchanger and recycled in the tower. Excess water is drawn off and sent to the new sour water storage system. The cooled-off gas enters the bottom of the unit's amine contactor where H₂S is removed prior to final incineration. The TGTU's amine contactor and regeneration system are separate from the other two amine units previously mentioned. This design prevents cross-contamination of amine solutions. The off-gas from the TGTU amine contactor containing residual H₂S is sent to the sulfur plant incinerator. The concentrated H₂S stream is directed to the SRU sulfur reaction furnace, which converts the H₂S to SO₂, which recycles through the Claus process. The efficiency of the TGTU for sulfur removal is 99.46%. The TGTU adds additional sulfur recovery efficiency to the sulfur plant. The overall efficiency for sulfur removal for the SRU, plus TGTU, is 99.96%.

The sulfur plant incinerator (INC-401) is designed to burn any H₂S and other substances that make it past the SRU and TGTU. Also, exhaust gas from reheater E-407 (operated during Mode I) at the SRU is vented to the sulfur plant incinerator. The design heat input rate for reheater E-407 is 1.0 MMBtu/hr and is fired by natural/refinery gas. The design heat input rate for INC-401 is 3.8 MMBtu/hr. Therefore, these two fuel-burning devices, together, will fire a potential 5.0 Mscf/hr of fuel gas (4.8 total MMBtu/hr).

The overhead gas (H₂S, NH₃) from the SWS unit is treated by the SRU. SWS gas from the existing unit is currently incinerated at the FCC-CO boiler and results in significant emissions of SO₂ and NO_x. This refinery activity and resultant emissions will cease, contemporaneously, with the new HDS operation. Also, the sulfur feed to the existing refinery Claus SRU will be greatly diminished. This should result in significant SO₂ emission reductions, which have not been quantified.

Ultra Low Sulfur Diesel Unit and Hydrogen Plant – The ULSD Unit was designed to meet the new sulfur standards for highway diesel fuel as mandated through the national sulfur control program in 40 CFR Parts 69, 80, and 86. CHS shut down the existing MDU and replaced it with the ULSD Unit, to produce ultra low sulfur diesel and other fuels. At installation, the ULSD Unit was designed to handle the existing MDU process feeds of 21,000 bpd including; raw diesel from #1 and #2 Crude Units, hydrotreated diesel from the Gas Oil Hydrotreater, light cycle oil from the FCCU, and burner fuel from the #1 and #2 Crude Units. The feed streams are processed into several product streams; finished diesel, finished #1 burner fuel, and raw naphtha. After the delayed Coker project in 2007, the available feed processed by the ULSD unit is expected to increase to 24,000 bpd.

These products are stored in existing tanks dedicated to similar products from the MDU. Seven storage tanks were modified as a result of the original ULSD Unit project.

CHS's existing Hydrogen Plant and the proposed Hydrogen Plant would supply hydrogen for hydrotreatment. These units catalytically reform a heated propane/natural gas and steam mixture into hydrogen and carbon dioxide then purify the hydrogen steam for use in the ULSD Unit. Existing plant sources also supply steam and amine for the ULSD Unit.

Sour water produced in the ULSD Unit will be managed by existing equipment, including a sour water storage tank and a sour water stripper that vents to SRU #400. Fuel gas produced in the unit will be treated and distributed within the plant fuel gas system. Oily process wastewater and storm water from process areas managed in existing systems will be treated in the existing plant wastewater treatment plant.

Zone A's TGTU for SRU #1 and #2 Trains - The SRUs convert H₂S from various units within the refinery into molten elemental sulfur. The SRU process consists of two parallel trains (SRU #1 and SRU #2 trains) that each include thermal and catalytic sections that convert the H₂S and SO₂ into sulfur. In each train, the process gas exits the catalytic reactors and enters a condenser where sulfur is recovered and is gravity fed into the sulfur pits. Process gas from the condensers is then sent to the TGTU for additional sulfur removal. The TGTU is an amine-type H₂S recovery and recycle TGTU. The TGTU utilizes an in-line tail gas heater (TGTU-AUX-1), which also generates hydrogen from reducing gases that reduce the SO₂ in the tail gas to H₂S. After passing through the quench tower, the stream enters an amine absorber where H₂S is selectively absorbed. The off-gas passes to the SRU-AUX-4, where it is incinerated to convert remaining H₂S to SO₂ before venting to atmosphere. The rich amine leaving the absorber is regenerated in the tail gas regenerator, and the H₂S recovered is routed back to the front of the SRU unit. The lean amine is routed to a new MDEA surge tank (TGTU-VSSL-6). The efficiency of the TGTU for sulfur removal is 98.93%. The TGTU adds additional sulfur recovery efficiency to the sulfur plant. The overall efficiency for sulfur removal for the SRU, plus TGTU, plus the SRU-AUX-4, is nearly 100%.

The SRU-AUX-4 is designed to burn any H₂S and other substances that make it past the SRU and TGTU. Also, exhaust gas from the SRU-AUX-1 is vented to SRU-AUX-4. The design heat input rate for TGTU-AUX-1 is 4.17 MMBtu/hr and the unit is fired by natural/refinery fuel gas. The design heat input rate for SRU-AUX-4 is 10.85 MMBtu/hr and the unit is fired on refinery fuel gas. Therefore, these two fuel-burning devices, together, will potentially use 18.55 Mscf/hr of natural and refinery fuel gas (15.02 total MMBtu/hr).

Delayed Coker Unit – The delayed coker unit is designed to process 15,000 bpd of a residual asphalt stream (crude vacuum distillation bottoms). Through the delayed coking process, the unit will produce 800 short tons per day of a solid petroleum coke product and various quantities of other liquid and gaseous petroleum fractions that will be further processed in other refinery units. When integrated into other refinery operations, it is expected that the coker will result in an approximate 75% decrease in asphalt production and a 10-15% increase in gasoline and diesel production. Although the delayed coker project and other projects described in Permit Application #1821-13 will result in a shift in the type of products that will be made at the refinery, there will not be a change to the refinery's 58,000 bpd capacity, and actual crude processing rates are not expected to increase.

Some of the major equipment items in the delayed coker unit include: a new 160.9 MMBtu-high heating value (HHV)/hr Coker Charge Heater (H-7501), a new Coke Storage Area and Solids Handling Equipment to store and transfer the 800 short tons per day of coke product to rail cars for shipment; a new Coker Flare used exclusively to control emissions during start-up, shutdown, and malfunctions (no continuous vents will be flared); and a new coker amine unit and a Zone E (previously called Coker) SRU/TGTU/TGI, which is designed to process 70.6 long tons per day of sulfur. There will be emissions from a Coker Unit Oily Water Sewer and Cooling Tower.

E. Additional Information

Additional information, such as applicable rules and regulations, BACT/Reasonably Available Control Technology (RACT) determinations, air quality impacts, and environmental assessments, is included in the analysis associated with each change to the permit.

II. Applicable Rules and Regulations

The following are partial explanations of some applicable rules and regulations that apply to the facility. The complete rules are stated in the ARM and are available upon request from the Department. Upon request, the Department will provide references for locations of complete copies of all applicable rules and regulations, or copies, where appropriate.

A. ARM 17.8, Subchapter 1 – General Provisions, including, but not limited to:

1. ARM 17.8.101 Definitions. This rule is a list of applicable definitions used in this chapter, unless indicated otherwise in a specific subchapter.
2. ARM 17.8.105 Testing Requirements. Any person or persons responsible for the emission of any air contaminant into the outdoor atmosphere shall, upon written request of the Department, provide the facilities and necessary equipment, including instruments and sensing devices, and shall conduct tests, emission or ambient, for such periods of time as may be necessary, using methods approved by the Department.
3. ARM 17.8.106 Source Testing Protocol. The requirements of this rule apply to any emission source testing conducted by the Department, any source, or other entity as required by any rule in this chapter, or any permit or order issued pursuant to this chapter, or the provisions of the Montana Clean Air Act, 75-2-101, *et seq.*, MCA.

CHS shall comply with all requirements contained in the Montana Source Test Protocol and Procedures Manual including, but not limited to, using the proper test methods and supplying the required reports. A copy of the Montana Source Test Protocol and Procedures Manual is available from the Department upon request.

4. ARM 17.8.110 Malfunctions. The Department must be notified promptly by telephone whenever a malfunction occurs that can be expected to create emissions in excess of any applicable emission limitation, or to continue for a period greater than 4 hours.
5. ARM 17.8.111 Circumvention. (1) No person shall cause or permit the installation or use of any device or any means that, without resulting in reduction of the total amount of air contaminant emitted, conceals or dilutes an emission of air contaminant that would otherwise violate an air pollution control regulation. (2) No equipment that may produce emissions shall be operated or maintained in such a manner as to create a public nuisance.

B. ARM 17.8, Subchapter 2 – Ambient Air Quality, including, but not limited to the following:

1. ARM 17.8.204 Ambient Air Monitoring
2. ARM 17.8.210 Ambient Air Quality Standards for Sulfur Dioxide

3. ARM 17.8.211 Ambient Air Quality Standards for Nitrogen Dioxide
4. ARM 17.8.212 Ambient Air Quality Standards for Carbon Monoxide
5. ARM 17.8.213 Ambient Air Quality Standard for Ozone
6. ARM 17.8.214 Ambient Air Quality Standard for Hydrogen Sulfide
7. ARM 17.8.220 Ambient Air Quality Standard for Settled Particulate Matter
8. ARM 17.8.221 Ambient Air Quality Standard for Visibility
9. ARM 17.8.222 Ambient Air Quality Standard for Lead
10. ARM 17.8.223 Ambient Air Quality Standard for PM₁₀

CHS must comply with the applicable ambient air quality standards.

C. ARM 17.8, Subchapter 3 – Emission Standards, including, but not limited to:

1. ARM 17.8.304 Visible Air Contaminants. This rule requires that no person may cause or authorize emissions to be discharged into the outdoor atmosphere from any source installed after November 23, 1968, that exhibit an opacity of 20% or greater averaged over 6 consecutive minutes.
2. ARM 17.8.308 Particulate Matter, Airborne. (1) This rule requires an opacity limitation of less than 20% for all fugitive emission sources and that reasonable precautions be taken to control emissions of airborne particulate matter. (2) Under this rule, CHS shall not cause or authorize the use of any street, road, or parking lot without taking reasonable precautions to control emissions of airborne particulate matter.
3. ARM 17.8.309 Particulate Matter, Fuel Burning Equipment. This rule requires that no person shall cause, allow, or permit to be discharged into the atmosphere particulate matter caused by the combustion of fuel in excess of the amount determined by this rule.
4. ARM 17.8.310 Particulate Matter, Industrial Process. This rule requires that no person shall cause, allow, or permit to be discharged into the atmosphere particulate matter in excess of the amount set forth in this rule.
5. ARM 17.8.322 Sulfur Oxide Emissions--Sulfur in Fuel. Commencing July 1, 1971, no person shall burn any gaseous fuel containing sulfur compounds in excess of 50 grains per 100 cubic feet of gaseous fuel, calculated as hydrogen sulfide at standard conditions.
6. ARM 17.8.324 Hydrocarbon Emissions – Petroleum Products. (3) No person shall load or permit the loading of gasoline into any stationary tank with a capacity of 250 gallons or more from any tank truck or trailer, except through a permanent submerged fill pipe, unless such tank is equipped with a vapor loss control device as described in (1) of this rule.
7. ARM 17.8.340 Standard of Performance for New Stationary Sources. The owner or operator of any stationary source or modification, as defined and applied in 40 CFR Part 60, shall comply with the standards and provisions of 40 CFR Part 60, Standards of Performance for New Stationary Sources (NSPS). The applicable NSPS Subparts include, but are not limited to:
 - a. Subpart A - General Provisions apply to all equipment or facilities subject to an NSPS Subpart as listed below.

- b. Subpart Db - Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units applies to Boilers #10, #11, and #12.
 - c. Subpart J - Standards of Performance for Petroleum Refineries shall apply to the SRU Incinerator Stack (E-407 & INC-401), Fractionator Feed Heater Stack (H-202), Reactor Charge Heater Stack (H-201), the FCCU Regenerator, and all fuel gas combustion devices, as applicable, with the exception of the Naphtha Unifier Splitter Heater, the Hydrogen Reformer Heater (H-101), the Alkylation Hot Oil Belt Heater, the Loading Rack Vapor Combustion Unit, and the Refinery Flare (CHS Consent Decree paragraphs 55, 57, and Appendix F).
 - d. Subpart Ja, Standards of Performance for Petroleum Refineries for Which Construction, Reconstruction, or Modification Commenced After May 14, 2007 shall apply to Boiler #12, the Platformer Splitter Reboiler (P-HTR-30, and the Refinery Flare (once new connections are made). Note: Portions of Subpart Ja are currently stayed until February 24, 2009. EPA has proposed revisions to Subpart Ja with respect to certain provisions for flares. Once the stay is lifted or final revised Subpart Ja provisions are promulgated, those final provisions affecting flares will apply to the Refinery Flare.
 - e. Subpart GGG - Standards of Performance for Equipment Leaks of VOC in Petroleum Refineries shall apply to the HDS Complex, including, but not be limited to, the SRU Incinerator Stack (E-407 & INC-401), Superior Clean Burn II 12 SGIB (C201-B), Fractionator Feed Heater Stack (H-202), Reactor Charge Heater Stack (H-201), the Reformer Heater Stack (H-101), refinery fuel gas supply lines to the Boilers #10, and #12, the fugitive ULSD Unit and Hydrogen Plant fugitive piping equipment, the Zone A TGTU fugitive piping equipment in VOC service, the Delayed Coker Unit fugitive piping equipment in VOC service and the Naptha Hydrotreating Unit and any other applicable equipment constructed or modified after January 4, 1983.
 - f. Subpart GGGa – Standards of Performance for Equipment Leaks of VOC in Petroleum Refineries for Which Construction, Reconstruction, or Modification Commenced After November 7, 2006, shall apply to all of the fugitive VOC emitting components added in the Benzene Reduction Unit project and any other applicable equipment constructed, reconstructed, or modified after November 7, 2006.
 - g. Subpart QQQ - Standards of Performance for VOC Emissions from Petroleum Refining Wastewater Systems shall apply, but not be limited to, the HDS Complex, SRU Incinerator Stack (E-407 & INC-401), Superior Clean Burn II 12 SGIB (C201-B), Fractionator Feed Heater Stack (H-202), Reactor Charge Heater Stack (H-201), the Reformer Heater Stack (H-101), the ULSD Unit and Hydrogen Plant wastewater streams, the Zone A TGTU process drains, the Delayed Coker, the Zone E SRU/TGTU/TGI, the Benzene Reduction Unit, and any other applicable equipment. NSPS Subpart QQQ does not apply to boiler #10, since the boiler drains will not contain any oily wastewater.
8. ARM 17.8.341 Emission Standards for Hazardous Air Pollutants. This source shall comply with the standards and provisions of 40 CFR Part 61, as appropriate.

- a. Subpart A – General Provisions apply to all equipment or facilities subject to a Subpart as listed below.
 - b. Subpart FF – National Emissions Standards for Benzene Waste Operations.
9. ARM 17.8.342 Emission Standards for Hazardous Air Pollutants for Source Categories. The source, as defined and applied in 40 CFR Part 63, shall comply with the requirements of 40 CFR Part 63, as listed below:
- a. Subpart A - General Provisions applies to all NESHAP source categories subject to a Subpart as listed below.
 - b. Subpart CC - National Emission Standards for Hazardous Air Pollutants from Petroleum Refineries shall apply to, but not be limited to, the Product Loading Rack, tank 96 when it is utilized for gasoline service, and certain parts of the Benzene Reduction Unit.
 - c. Subpart UUU – MACT Standard for Catalytic Cracking Units, Catalytic Reforming Units, and Sulfur Recovery Units.
 - d. Subpart ZZZZ – National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines
- D. ARM 17.8, Subchapter 4 – Stack Height and Dispersion Techniques, including, but not limited to:
- 1. ARM 17.8.401 Definitions. This rule includes a list of definitions used in this chapter, unless indicated otherwise in a specific subchapter.
 - 2. ARM 17.8.402 Requirements. CHS must demonstrate compliance with the ambient air quality standards with a stack height that does not exceed Good Engineering Practices (GEP).
- E. ARM 17.8, Subchapter 5 – Air Quality Permit Application, Operation, and Open Burning Fees, including, but not limited to:
- 1. ARM 17.8.504 Air Quality Permit Application Fees. This rule requires that an applicant submit an air quality permit application fee concurrent with the submittal of an air quality permit application. A permit application is incomplete until the proper application fee is paid to the Department. A permit fee is not required for the current permit action because the permit action is considered an administrative permit change.
 - 2. ARM 17.8.505 Air Quality Operation Fees. An annual air quality operation fee must, as a condition of continued operation, be submitted to the Department by each source of air contaminants holding an air quality permit (excluding an open burning permit) issued by the Department. The air quality operation fee is based on the actual or estimated actual amount of air pollutants emitted during the previous calendar year.

An air quality operation fee is separate and distinct from an air quality permit application fee. The annual assessment and collection of the air quality operation fee, described above, shall take place on a calendar-year basis. The Department may insert into any final permit issued after the effective date of these rules, such conditions as may be necessary to require the payment of an air quality operation

fee on a calendar-year basis, including provisions that prorate the required fee amount.

- F. ARM 17.8, Subchapter 7 – Permit, Construction, and Operation of Air Contaminant Sources, including, but not limited to:
1. ARM 17.8.740 Definitions. This rule is a list of applicable definitions used in this chapter, unless indicated otherwise in a specific subchapter.
 2. ARM 17.8.743 Montana Air Quality Permits--When Required. This rule requires a person to obtain an air quality permit or permit modification to construct, modify, or use any air contaminant sources that have the Potential to Emit (PTE) greater than 25 tons per year of any pollutant. CHS has a PTE greater than 25 tons per year of SO₂, NO_x, CO, VOC, and PM emissions; therefore, an air quality permit is required.
 3. ARM 17.8.744 Montana Air Quality Permits--General Exclusions. This rule identifies the activities that are not subject to the Montana Air Quality Permit program.
 4. ARM 17.8.745 Montana Air Quality Permits--Exclusion for De Minimis Changes. This rule identifies the de minimis changes at permitted facilities that do not require a permit under Montana Air Quality Permit Program.
 5. ARM 17.8.748 New or Modified Emitting Units--Permit Application Requirements. (1) This rule requires that a permit application be submitted prior to installation, modification, or use of a source. A permit application was not required for the current permit action because the permit change is considered an administrative permit change. (7) This rule requires that the applicant notify the public by means of legal publication in a newspaper of general circulation in the area affected by the application for a permit. An affidavit of publication of public notice was not required for the current permit action because the permit change is considered an administrative permit change.
 6. ARM 17.8.749 Conditions for Issuance or Denial of Permit. This rule requires that the permits issued by the Department must authorize the construction and operation of the facility or emitting unit subject to the conditions in the permit and the requirements of this subchapter. This rule also requires that the permit must contain any conditions necessary to assure compliance with the Federal Clean Air Act (FCAA), the Clean Air Act of Montana, and rules adopted under those acts.
 7. ARM 17.8.752 Emission Control Requirements. This rule requires a source to install the maximum air pollution control capability that is technically practicable and economically feasible, except that BACT shall be utilized. The required BACT analysis is included in Section III of this permit analysis.
 8. ARM 17.8.755 Inspection of Permit. This rule requires that air quality permits shall be made available for inspection by the Department at the location of the source.
 9. ARM 17.8.756 Compliance with Other Requirements. This rule states that nothing in the permit shall be construed as relieving CHS of the responsibility for complying with any applicable federal or Montana statute, rule, or standard,

except as specifically provided in ARM 17.8.740, *et seq.*

10. ARM 17.8.759 Review of Permit Applications. This rule describes the Department's responsibilities for processing permit applications and making permit decisions on those permit applications that do not require the preparation of an environmental impact statement.
 11. ARM 17.8.762 Duration of Permit. An air quality permit shall be valid until revoked or modified, as provided in this subchapter, except that a permit issued prior to construction of a new or modified source may contain a condition providing that the permit will expire unless construction is commenced within the time specified in the permit, which in no event may be less than 1 year after the permit is issued.
 12. ARM 17.8.763 Revocation of Permit. An air quality permit may be revoked upon written request of the permittee, or for violations of any requirement of the Clean Air Act of Montana, rules adopted under the Clean Air Act of Montana, the FCAA, rules adopted under the FCAA, or any applicable requirement contained in the Montana State Implementation Plan (SIP).
 13. ARM 17.8.764 Administrative Amendment to Permit. An air quality permit may be amended for changes in any applicable rules and standards adopted by the Board of Environmental Review (Board) or changed conditions of operation at a source or stack that do not result in an increase of emissions as a result of those changed conditions. The owner or operator of a facility may not increase the facility's emissions beyond permit limits unless the increase meets the criteria in ARM 17.8.745 for a de minimis change not requiring a permit, or unless the owner or operator applies for and receives another permit in accordance with ARM 17.8.748, ARM 17.8.749, ARM 17.8.752, ARM 17.8.755, and ARM 17.8.756, and with all applicable requirements in ARM Title 17, Chapter 8, Subchapters 8, 9, and 10.
 14. ARM 17.8.765 Transfer of Permit. This rule states that an air quality permit may be transferred from one person to another if written notice of intent to transfer, including the names of the transferor and the transferee, is sent to the Department.
 15. ARM 17.8.770 Additional Requirements for Incinerators. This rule specifies the additional information that must be submitted to the Department for incineration facilities subject to 75-2-215, MCA.
- G. ARM 17.8, Subchapter 8 – Prevention of Significant Deterioration of Air Quality, including, but not limited to:
1. ARM 17.8.801 Definitions. This rule is a list of applicable definitions used in this subchapter.
 2. ARM 17.8.818 Review of Major Stationary Sources and Major Modifications -- Source Applicability and Exemptions. The requirements contained in ARM 17.8.819 through ARM 17.8.827 shall apply to any major stationary source and any major modification with respect to each pollutant subject to regulation under the FCAA that it would emit, except as this subchapter would otherwise allow.

CHS's existing petroleum refinery in Laurel is defined as a "major stationary source" because it is a listed source with a PTE more than 100 tons per year of several pollutants (PM, SO₂, NO_x, CO, and VOCs). This permit action constitutes of administrative changes only and, therefore, does not require a New Source Review (NSR) analysis.

- H. ARM 17.8, Subchapter 9 – Permit Requirements for Major Stationary Sources of Modifications Located within Nonattainment Areas including, but not limited to:

ARM 17.8.904 When Air Quality Preconstruction Permit Required. This rule requires that major stationary sources or major modifications located within a nonattainment area must obtain a preconstruction permit in accordance with the requirements of this Subchapter, as well as the requirements of Subchapter 7.

The current permit action is not considered a major modification because no increase in emissions will occur as a result. Therefore, the requirements of this subpart are not applicable.

- I. ARM 17.8, Subchapter 12 – Operating Permit Program Applicability, including, but not limited to:

1. ARM 17.8.1201 Definitions. (23) Major Source under Section 7412 of the FCAA is defined as any stationary source having:
 - a. PTE > 100 tons/year of any pollutant;
 - b. PTE > 10 tons/year of any one HAP, PTE > 25 tons/year of a combination of all HAPs, or a lesser quantity as the Department may establish by rule; or
 - c. PTE > 70 tons/year of PM₁₀ in a serious PM₁₀ nonattainment area.
2. ARM 17.8.1204 Air Quality Operating Permit Program Applicability. (1) Title V of the FCAA Amendments of 1990 requires that all sources, as defined in ARM 17.8.1204 (1), obtain a Title V Operating Permit. In reviewing and issuing MAQP #1821-22 for CHS, the following conclusions were made:
 - a. The facility's PTE is greater than 100 tons/year for several pollutants.
 - b. The facility's PTE is greater than 10 tons/year for any one HAP and greater than 25 tons/year of all HAPs.
 - c. This source is not located in a serious PM₁₀ nonattainment area.
 - d. This facility is subject to NSPS requirements (40 CFR 60, Subparts A, Db, J, Ja, GGG, GGGa, and QQQ).
 - e. This facility is subject to current NESHAP standards (40 CFR 61, Subpart FF and 40 CFR 63, Subparts R, CC, UUU, and ZZZZ).
 - f. This source is not a Title IV affected source, nor a solid waste

combustion unit.

- g. This source is not an EPA designated Title V source.

Based on these facts, the Department determined that CHS is a major source of emissions as defined under Title V and currently operates under Operating Permit #OP1821-05, which was issued final and effective on May 21, 2010. The changes associated with this permit action will be incorporated into the next Operating Permit modification.

- J. MCA 75-2-103, Definitions, provides, in part, as follows:

1. "Incinerator" means any single or multiple-chambered combustion device that burns combustible material, alone or with a supplemental fuel or catalytic combustion assistance, primarily for the purpose of removal, destruction, disposal, or volume reduction of all or any portion of the input material.
2. "Solid waste" means all putrescible and nonputrescible solid, semisolid, liquid, or gaseous wastes, including, but not limited to...air pollution control facilities...

- K. MCA 75-2-215, Solid or Hazardous Waste Incineration -- Additional Permit Requirements, including, but not limited to, the following requirements:

The Department may not issue a permit to a facility until the Department has reached a determination that the projected emissions and ambient concentrations will constitute a negligible risk to the public health, safety, and welfare and to the environment. For MAQP #1821-04, CHS submitted a health risk assessment identifying the risk from the burning of HAPs in the flare as part of their permit application. The risk assessment contained the HAPs from the 1990 Federal Clean Air Act Amendments with an established risk value. The ambient concentrations were determined using ISCT3 and the risk assessment model used EPA's unit risk estimates and reference concentrations. The Department included limits in the permit that ensure the amount of material used in the models was not exceeded. The risk assessment results were summarized in the following table.

Flare Risk Assessment - CHS Refinery, MAQP #1821-04

Chemical Compound	Hourly Conc µg/m ³	Cancer ELCR Chronic	Non-Cancer Hazard Quotient Chronic Acute	
Benzene*	4.67E-02	8.3E-06	3.9E-07	ND
Toluene	3.82E-02	ND	ND	ND
Ethyl Benzene	2.85E-03	ND	ND	ND
Xylenes	1.25E-02	ND	ND	ND
Hexane	8.55E-02	ND	ND	ND
Cumene	1.14E-04	ND	ND	ND
Napthalene	1.60E-05	ND	ND	ND
Biphenyl	7.98E-08	ND	ND	ND
Total Risks =	0.186	8.3E-06	3.9E-07	ND

*The reference concentration for Benzene is 71 µg/m³ (EPA IRIS database).

The modeling demonstrated that the ambient concentrations of HAPs, with the exception of Benzene, are less than the concentrations contained in Table I and Table II of ARM 17.8.770; therefore, these HAPs were excluded from further review.

A risk assessment for Benzene was calculated because the predicted ambient concentration was greater than the concentration contained in Table I of ARM 17.8.770. This assessment demonstrated that the excess lifetime cancer risk was 3.9×10^{-7} . Therefore, the Department determined that the health risk assessment model demonstrated negligible risk to public health in this case.

For MAQP #1821-13, CHS submitted a health risk assessment identifying the risk from the burning of HAPs in the rail loading rack VCU as part of their permit application. The risk assessment contained the HAPs from the 1990 Federal Clean Air Act Amendments with an established risk value. The ambient concentrations were determined using ISC3 and the risk assessment model used EPA's unit risk estimates and reference concentrations. The Department included limits in the permit that ensure the amount of material used in the models was not exceeded. The risk assessment results were summarized in the following table.

Rail Loading Rack VCU Risk Assessment - CHS Refinery, Permit #1821-13

Chemical Compound	Modeled Conc. $\mu\text{g}/\text{m}^3$	Table 1* Conc.1 $\mu\text{g}/\text{m}^3$	Table 2* Conc. $\mu\text{g}/\text{m}^3$
Benzene	1.81E-02	1.20E-02	7.10E-01
Ethyl Benzene	8.29E-04	--	1.00E+01
Napthalene	4.08E-05	--	1.40E-01
Toluene	1.22E-02	--	4.00E+00
Xylenes	4.35E-03	--	3.00E+00
Hexane	2.68E-02	--	2.00E+00

Total concentrations = 0.0623

*Refers to ARM 17.8.770

The modeling demonstrated that the ambient concentrations of HAPs, with the exception of Benzene, are less than the concentrations contained in Table 1 and Table 2 of ARM 17.8.770; therefore, these HAPs were excluded from further review.

A risk assessment for Benzene was calculated because the predicted ambient concentration was greater than the concentration contained in Table I of ARM 17.8.770. The modeled benzene concentration was compared to EPA Region III's, "Risk-Based Concentration (RBC) Table," dated October, 2005. RBC screening levels represent concentrations which are determined to present a lifetime cancer risk of no greater than 1×10^{-6} . The RBC concentration for benzene is listed as 2.3×10^{-1} , which is higher than the modeled concentration for benzene. Therefore, the Department determined that the health risk assessment model demonstrated negligible risk to public health in this case.

Although CHS proposes to expand the railcar light product loading rack under MAQP #1821-17, no modifications to the VCU are proposed. In addition, the basis for the Human Health Risk assessment submitted as part of MAQP #1821-13 has not changed. As such, an additional assessment is not necessary for the proposed expansion of the railcar light product loading rack.

Also for MAQP #1821-13, CHS submitted a health risk assessment identifying the risk from the burning of HAPs in the coker unit TGI as part of their permit application. The risk assessment contained the HAPs from the 1990 Federal Clean Air Act Amendments with an established risk value. The ambient concentrations were determined using SCREEN3 and the risk assessment model used EPA's unit risk estimates and reference concentrations. The Department included limits in the permit that ensure the amount of material used in the models was not exceeded. The risk assessment results were summarized in the following table.

Coker Unit TGI Risk Assessment - CHS Refinery, MAQP #1821-13

Chemical Compound	Modeled Conc. $\mu\text{g}/\text{m}^3$	Table 1* Conc.1 $\mu\text{g}/\text{m}^3$	Table 2* Conc. $\mu\text{g}/\text{m}^3$
Carbon Disulfide	3.18E-02	--	7.00E-00
Total concentrations =	3.18E-02		

*Refers to ARM 17.8.770

The modeling demonstrated that the ambient concentrations of the carbon disulfide (the only HAP expected to be emitted), are less than the concentrations contained in Table 1 and Table 2 of ARM 17.8.770; therefore, the carbon disulfide were excluded from further review. Updated information provided to the Department on October 24, 2006, revised the modeled concentration of carbon disulfide to 3.05E-02, which did not effect this determination. Therefore, the Department determined that the health risk assessment model demonstrated negligible risk to public health in this case.

III. BACT Determination

A BACT determination is required for each new or modified source. CHS shall install on the new or modified source the maximum air pollution control capability, which is technically practicable and economically feasible, except that BACT shall be utilized.

A BACT analysis was not required for the current permit action because the current permit action is considered an administrative permit action.

IV. Emission Inventory

The current permit action is administrative in nature and the changes made do not result in a change in the emissions from this facility. Therefore, an emissions inventory was not prepared. Emissions inventories from previous permit actions are on file with the Department.

V. Existing Air Quality

There are two areas in Billings (approximately 12 miles northeast of the CHS Refinery) which were federally designated nonattainment for CO (National Ambient Air Quality Standards (NAAQS)) and for the old secondary total suspended particulates (PM) standard. EPA redesignated the Billings CO nonattainment area to attainment on April 22, 2002. The old PM standard has since been revoked and replaced with new PM₁₀ (respirable) standards. The Billings area is listed as not classified/attainment for the new PM₁₀ standard.

The area (2.0 km) around the CHS Refinery in Laurel is federally designated as nonattainment for the SO₂ NAAQS (40 CFR 81.327). Ambient air quality monitoring data for SO₂ from 1981 through 1992 recorded SO₂ levels in the Laurel and Billings areas in excess of the Montana Ambient Air Quality Standards (MAAQS) for the 24-hour and annual averages. In 1993, EPA determined that

the SO₂ SIP for the Billings/Laurel area was inadequate and needed to be revised. The Department, in cooperation with the Billings/Laurel area SO₂ emitting industries, adopted a new control plan to reduce SO₂ emissions by establishing emission limits and requiring continuous emission monitors on most stacks. In addition, on April 21, 2008, the EPA issued a federal implementation plan (FIP) for those SIP provisions it deemed inadequate. The FIP includes additional flare requirements for specified sources. Area SO₂ emissions have since declined between 1992 and 2008. The decline can be attributed to industrial controls added as part of the SIP/FIP requirements, plants operating at less than full capacity, and industrial process changes to meet sulfur in fuel regulations. Ambient air quality monitoring for SO₂, PM₁₀, and CO in the Billings/Laurel area continues.

VI. Air Quality Impacts

The Department did not conduct ambient air modeling for this permit action. The current permit action is administrative and the Department believes it will not cause or contribute to a violation of any ambient air quality standard because no increases in emissions are proposed.

VII. Ambient Air Impact Analysis

The Department determined that the impact from this permitting action will be minor because it is an administrative action. The Department believes it will not cause or contribute to a violation of any ambient air quality standard.

VIII. Taking or Damaging Implication Analysis

As required by 2-10-105, MCA, the Department conducted the following private property taking and damaging assessment.

YES	NO	
X		1. Does the action pertain to land or water management or environmental regulation affecting private real property or water rights?
	X	2. Does the action result in either a permanent or indefinite physical occupation of private property?
	X	3. Does the action deny a fundamental attribute of ownership? (ex.: right to exclude others, disposal of property)
	X	4. Does the action deprive the owner of all economically viable uses of the property?
	X	5. Does the action require a property owner to dedicate a portion of property or to grant an easement? [If no, go to (6)].
		5a. Is there a reasonable, specific connection between the government requirement and legitimate state interests?
		5b. Is the government requirement roughly proportional to the impact of the proposed use of the property?
	X	6. Does the action have a severe impact on the value of the property? (consider economic impact, investment-backed expectations, character of government action)
	X	7. Does the action damage the property by causing some physical disturbance with respect to the property in excess of that sustained by the public generally?
	X	7a. Is the impact of government action direct, peculiar, and significant?
	X	7b. Has government action resulted in the property becoming practically inaccessible, waterlogged or flooded?
	X	7c. Has government action lowered property values by more than 30% and necessitated the physical taking of adjacent property or property across a public way from the property in question?
	X	Takings or damaging implications? (Taking or damaging implications exist if YES is checked in response to question 1 and also to any one or more of the following questions: 2, 3, 4, 6, 7a, 7b,

		7c; or if NO is checked in response to questions 5a or 5b; the shaded areas)
--	--	--

Based on this analysis, the Department determined there are no taking or damaging implications associated with this permit action.

VIII. Environmental Assessment

This permitting action will not result in an increase of emissions from the facility and is considered an administrative action; therefore, an Environmental Assessment is not required.

Permit Analysis Prepared by: Skye Hatten
Date: August 26, 2010