

STATEMENT OF ENERGY PERFORMANCE

DLI-Butte Job Service
2201 White Blvd.
Butte

Date: 9/7/2018
Year Built: 2000

	Baseline:	2012	12/31/2013	Current:
Energy Date:	12/31/2007	12/31/2012	12/31/2013	12/31/2017
Energy Star Score:	28	42	39	38
Gross Floor Area:	6,907	6,907	6,907	6,907 Sq. Ft.
Heating Degree Days	6,778	7,046	7,351	7,862
Cooling Degree Days	730	517	579	731

Reported Annual Energy Use:

Site Energy Use:	527.06	431.51	451.35	499.77 MBTU
Site EUI:	76,308	62,474	65,347	72,358 BTU/ft ²
Electricity:	76,437	63,073	65,184	58,876 kWh
Max Electric Demand:	44	42	30	31 kW
Natural Gas:	2,663	2,163	2,289	2,989 Therms

Reported Annual Energy Cost:

Electricity Cost:	\$8,049	\$7,133	\$7,335	\$7,404
Electric Demand Cost:	\$3,158	\$2,586	\$2,501	\$2,710
Natural Gas Cost:	\$3,087	\$2,108	\$2,216	\$2,457
Energy Cost/ft ²	\$1.612	\$1.338	\$1.383	\$1.428

Weather Normalized Energy Use:

Site Energy Use:	554.83	446.57	453.72	495.12 MBTU
Site EUI:	80,329	64,655	65,690	71,684 BTU/ft ²
Electricity:	76,437	63,073	64,959	58,876 kWh
Natural Gas:	2,940	2,314	2,321	2,942 Therms

National Median Energy Use:

Site Energy Use:	397.11	390.82	394.56	433.94 MBTU
Site EUI:	57,494	56,583	57,125	62,826 BTU/ft ²

Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Direct Emissions:	14.1	11.5	12.2	15.9
Indirect Emissions:	23	19	19	18
Total Emissions:	37	30	32	33

National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Total Emissions:	27.8	27.4	27.6	29
------------------	------	------	------	----

% Difference from National Median:

Site EUI:	32.72	10.41	14.39	15.17
Total Emissions:	32.73	10.22	14.13	15.17

Adjusted Energy Based on Current Year:

Site Energy Use:	527.09	436.92	455.15	499.77 MBTU
Site EUI:	76,312	63,257	65,897	72,358 BTU/ft ²

% Difference Adjusted Site Energy Use

2012 to Baseline	-17.11
2013 to Baseline	-13.65
Current to Baseline	-5.18
Current to 2013	9.80