

STATEMENT OF ENERGY PERFORMANCE

DLI-Missoula Job Service
539 S 3rd St W
Missoula

Date: 9/7/2018
Year Built: 1972

	Baseline:	2012	12/31/2013	Current:
	12/31/2007	12/31/2012	12/31/2013	12/31/2017
Energy Date:	12/31/2007	12/31/2012	12/31/2013	12/31/2017
Energy Star Score:	56	58	52	65
Gross Floor Area:	10,369	10,369	10,369	10,369 Sq. Ft.
Heating Degree Days	6,934	6,992	7,448	7,738
Cooling Degree Days	646	396	565	528
Reported Annual Energy Use:				
Site Energy Use:	541.67	556.29	629.68	541.26 MBTU
Site EUI:	52,239	53,650	60,727	52,200 BTU/ft ²
Electricity:	97,569	88,342	90,791	74,959 kWh
Max Electric Demand:	40	39	40	30 kW
Natural Gas:	2,088	2,549	3,199	2,855 Therms
Reported Annual Energy Cost:				
Electricity Cost:	\$9,722	\$9,373	\$10,243	\$9,156
Electric Demand Cost:	\$3,497	\$3,057	\$3,431	\$3,205
Natural Gas Cost:	\$2,523	\$2,396	\$2,903	\$2,364
Energy Cost/ft ²	\$1.181	\$1.135	\$1.268	\$1.111
Weather Normalized Energy Use:				
Site Energy Use:	549.23	566.14	609.79	518.86 MBTU
Site EUI:	52,968	54,599	58,809	50,039 BTU/ft ²
Electricity:	97,016	88,271	90,593	74,081 kWh
Natural Gas:	2,182	2,650	3,007	2,661 Therms
National Median Energy Use:				
Site Energy Use:	590.92	618.57	654.42	664.81 MBTU
Site EUI:	56,989	59,656	63,113	64,115 BTU/ft ²
Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):				
Direct Emissions:	11.1	13.5	17	15.2
Indirect Emissions:	29	26	27	22
Total Emissions:	40	40	44	37
National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):				
Total Emissions:	43.7	44.3	45.7	46
% Difference from National Median:				
Site EUI:	-8.34	-10.07	-3.78	-18.58
Total Emissions:	-8.24	-10.16	-3.72	-18.70
Adjusted Energy Based on Current Year:				
Site Energy Use:	538.11	561.58	628.29	541.26 MBTU
Site EUI:	51,896	54,160	60,593	52,200 BTU/ft ²
% Difference Adjusted Site Energy Use				
2012 to Baseline	4.36			
2013 to Baseline	16.76			
Current to Baseline	0.59			
Current to 2013	-13.85			