

STATEMENT OF ENERGY PERFORMANCE

DMA-Anaconda Armory
101 N Polk
Anaconda

Date: 9/7/2018
Year Built: 1970

	Baseline:	2012	12/31/2013	Current:	
	12/31/2007	12/31/2012	12/31/2013	12/31/2017	
Energy Date:	12/31/2007	12/31/2012	12/31/2013	12/31/2017	
Energy Star Score:	N/A	N/A	N/A	N/A	
Gross Floor Area:	9,661	9,661	9,661	9,661	Sq. Ft.
Heating Degree Days	6,778	7,046	7,351	7,862	
Cooling Degree Days	730	517	579	731	

Reported Annual Energy Use:

Site Energy Use:	687.08	669.17	683.38	832.77	MBTU
Site EUI:	71,119	69,265	70,736	86,199	BTU/ft ²
Electricity:	23,964	23,402	26,710	33,167	kWh
Max Electric Demand:	14	14	15	11	kW
Natural Gas:	6,053	5,893	5,922	7,196	Therms

Reported Annual Energy Cost:

Electricity Cost:	\$2,800	\$3,014	\$3,358	\$3,754
Electric Demand Cost:	\$1,196	\$1,259	\$1,277	\$1,082
Natural Gas Cost:	\$6,799	\$5,211	\$5,277	\$5,661
Energy Cost/ft ²	\$0.994	\$0.851	\$0.894	\$0.975

Weather Normalized Energy Use:

Site Energy Use:	730.58	707.53	703.96	814.08	MBTU
Site EUI:	75,622	73,236	72,866	84,264	BTU/ft ²
Electricity:	23,964	24,041	27,065	33,167	kWh
Natural Gas:	6,488	6,255	6,116	7,009	Therms

National Median Energy Use:

Site Energy Use:	685.44	685.14	672.03	669.72	MBTU
Site EUI:	70,950	70,918	69,561	69,322	BTU/ft ²

Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Direct Emissions:	32.2	31.3	31.5	38.2
Indirect Emissions:	7	7	8	10
Total Emissions:	39	38	39	48

National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Total Emissions:	39.2	39.2	38.7	38.7
------------------	------	------	------	------

% Difference from National Median:

Site EUI:	0.24	-2.33	1.69	24.35
Total Emissions:	0.26	-2.30	1.81	24.29

Adjusted Energy Based on Current Year:

Site Energy Use:	N/A	N/A	N/A	N/A	MBTU
Site EUI:	N/A	N/A	N/A	N/A	BTU/ft ²

% Difference Adjusted Site Energy Use

2012 to Baseline	N/A
2013 to Baseline	N/A
Current to Baseline	N/A
Current to 2013	N/A