

# STATEMENT OF ENERGY PERFORMANCE

DMA-Belgrade OMS  
361 Tower Road  
Belgrade

Date: 9/7/2018  
Year Built: 1991

	<b>Baseline:</b>	<b>2012</b>	<b>12/31/2013</b>	<b>Current:</b>
Energy Date:	12/31/2007	12/31/2012	12/31/2013	12/31/2017
Energy Star Score:	N/A	N/A	N/A	N/A
Gross Floor Area:	10,218	10,218	10,218	10,218 Sq. Ft.
Heating Degree Days	7,094	7,500	8,220	8,315
Cooling Degree Days	591	314	297	340

### Reported Annual Energy Use:

Site Energy Use:	516.64	575.89	637.09	582.20 MBTU
Site EUI:	50,562	56,361	62,349	56,978 BTU/ft <sup>2</sup>
Electricity:	49,415	60,088	62,415	49,557 kWh
Max Electric Demand:	24	26	26	24 kW
Natural Gas:	3,480	3,709	4,241	4,131 Therms

### Reported Annual Energy Cost:

Electricity Cost:	\$5,256	\$6,617	\$7,108	\$6,271
Electric Demand Cost:	\$2,062	\$2,282	\$2,398	\$2,302
Natural Gas Cost:	\$3,907	\$3,318	\$3,694	\$3,478
Energy Cost/ft <sup>2</sup>	\$0.897	\$0.972	\$1.057	\$0.954

### Weather Normalized Energy Use:

Site Energy Use:	541.32	580.45	584.53	528.26 MBTU
Site EUI:	52,977	56,807	57,206	51,699 BTU/ft <sup>2</sup>
Electricity:	49,764	60,088	61,674	48,717 kWh
Natural Gas:	3,715	3,754	3,741	3,620 Therms

### National Median Energy Use:

Site Energy Use:	610.71	591.76	605.53	635.34 MBTU
Site EUI:	59,768	57,914	59,261	62,178 BTU/ft <sup>2</sup>

### Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Direct Emissions:	18.5	19.7	22.5	21.9
Indirect Emissions:	15	18	19	15
Total Emissions:	33	38	41	37

### National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Total Emissions:	39.2	38.6	39	40
------------------	------	------	----	----

### % Difference from National Median:

Site EUI:	-15.40	-2.68	5.21	-8.36
Total Emissions:	-15.31	-2.59	5.38	-8.25

### Adjusted Energy Based on Current Year:

Site Energy Use:	N/A	N/A	N/A	N/A	MBTU
Site EUI:	N/A	N/A	N/A	N/A	BTU/ft <sup>2</sup>

### % Difference Adjusted Site Energy Use

2012 to Baseline	N/A
2013 to Baseline	N/A
Current to Baseline	N/A
Current to 2013	N/A