

## STATEMENT OF ENERGY PERFORMANCE

Fort Harrison Building 1002 Cold Storage  
0

Date: 9/7/2018  
Year Built: 1960

Fort Harrison

	<b>Baseline:</b>	<b>2012</b>	<b>12/31/2013</b>	<b>Current:</b>	
	12/31/2007	12/31/2012	12/31/2013	12/31/2017	
Energy Date:	12/31/2007	12/31/2012	12/31/2013	12/31/2017	
Energy Star Score:	N/A	N/A	N/A	N/A	
Gross Floor Area:	22,264	22,264	22,264	22,264	Sq. Ft.
Heating Degree Days	6,778	7,046	7,351	7,862	
Cooling Degree Days	730	517	579	731	

### Reported Annual Energy Use:

Site Energy Use:	110.81	47.44	42.44	50.51	MBTU
Site EUI:	4,977	2,131	1,906	2,269	BTU/ft <sup>2</sup>
Electricity:	32,477	13,903	12,439	14,802	kWh
Max Electric Demand:	14	14	14	12	kW
Natural Gas:	0	0	0	0	Therms

### Reported Annual Energy Cost:

Electricity Cost:	\$3,509	\$2,486	\$2,355	\$2,630
Electric Demand Cost:	\$1,370	\$1,395	\$1,331	\$1,373
Natural Gas Cost:	\$0	\$0	\$0	\$0
Energy Cost/ft <sup>2</sup>	\$0.158	\$0.112	\$0.106	\$0.118

### Weather Normalized Energy Use:

Site Energy Use:	109.88	47.44	42.44	50.51	MBTU
Site EUI:	4,935	2,131	1,906	2,269	BTU/ft <sup>2</sup>
Electricity:	32,203	13,903	12,439	14,802	kWh
Natural Gas:	0	0	0	0	Therms

### National Median Energy Use:

Site Energy Use:	420.45	420.45	420.45	420.45	MBTU
Site EUI:	18,885	18,885	18,885	18,885	BTU/ft <sup>2</sup>

### Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Direct Emissions:	0	0	0	0
Indirect Emissions:	10	4	4	4
Total Emissions:	10	4	4	4

### National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Total Emissions:	36.6	36.6	36.6	36.6
------------------	------	------	------	------

### % Difference from National Median:

Site EUI:	-73.64	-88.72	-89.91	-87.99
Total Emissions:	-73.50	-88.80	-89.89	-87.98

### Adjusted Energy Based on Current Year:

Site Energy Use:	N/A	N/A	N/A	N/A	MBTU
Site EUI:	N/A	N/A	N/A	N/A	BTU/ft <sup>2</sup>

### % Difference Adjusted Site Energy Use

2012 to Baseline	N/A
2013 to Baseline	N/A
Current to Baseline	N/A
Current to 2013	N/A