

STATEMENT OF ENERGY PERFORMANCE

DMA-Glasgow MIRF
81 Airport Road
Glasgow

Date: 9/7/2018
Year Built: 1992

	Baseline:	2012	12/31/2013	Current:	
	12/31/2007	12/31/2012	12/31/2013	12/31/2017	
Energy Date:	12/31/2007	12/31/2012	12/31/2013	12/31/2017	
Energy Star Score:	N/A	N/A	N/A	N/A	
Gross Floor Area:	6,865	6,865	6,865	6,865	Sq. Ft.
Heating Degree Days	7,954	7,796	8,826	8,122	
Cooling Degree Days	756	654	517	717	
Reported Annual Energy Use:					
Site Energy Use:	28.50	85.01	31.73	19.36	MBTU
Site EUI:	4,151	12,383	4,622	2,820	BTU/ft ²
Electricity:	8,352	24,915	9,300	5,674	kWh
Max Electric Demand:	13	22	10	8	kW
Natural Gas:	0	0	0	0	Therms
Reported Annual Energy Cost:					
Electricity Cost:	\$1,814	\$2,860	\$1,683	\$1,423	
Electric Demand Cost:	\$1,190	\$1,009	\$885	\$900	
Natural Gas Cost:	\$0	\$0	\$0	\$0	
Energy Cost/ft ²	\$0.264	\$0.417	\$0.245	\$0.207	
Weather Normalized Energy Use:					
Site Energy Use:	28.50	85.01	31.73	19.36	MBTU
Site EUI:	4,151	12,383	4,622	2,820	BTU/ft ²
Electricity:	8,352	24,915	9,300	5,674	kWh
Natural Gas:	0	0	0	0	Therms
National Median Energy Use:					
Site Energy Use:	218.88	218.88	218.88	218.88	MBTU
Site EUI:	31,883	31,883	31,883	31,883	BTU/ft ²
Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):					
Direct Emissions:	0	0	0	0	
Indirect Emissions:	3	7	3	2	
Total Emissions:	3	7	3	2	
National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):					
Total Emissions:	19.1	19.1	19.1	19.1	
% Difference from National Median:					
Site EUI:	-86.98	-61.16	-85.50	-91.16	
Total Emissions:	-86.91	-61.26	-85.34	-91.10	
Adjusted Energy Based on Current Year:					
Site Energy Use:	N/A	N/A	N/A	N/A	MBTU
Site EUI:	N/A	N/A	N/A	N/A	BTU/ft ²
% Difference Adjusted Site Energy Use					
2012 to Baseline	N/A				
2013 to Baseline	N/A				
Current to Baseline	N/A				
Current to 2013	N/A				