

STATEMENT OF ENERGY PERFORMANCE

DMA-Helena AHB Cold Storage
3333 Skyway Drive
Helena

Date: 9/7/2018
Year Built: 1960

	Baseline:	2012	12/31/2013	Current:
Energy Date:	12/31/2007	12/31/2012	12/31/2013	2/29/2016
Energy Star Score:	N/A	N/A	N/A	N/A
Gross Floor Area:	9,983	9,983	9,983	9,983 Sq. Ft.
Heating Degree Days	6,778	7,046	7,351	6,649
Cooling Degree Days	730	517	579	551

Reported Annual Energy Use:

Site Energy Use:	15.95	26.12	19.97	8.77 MBTU
Site EUI:	1,597	2,616	2,000	878 BTU/ft ²
Electricity:	4,674	7,654	5,853	2,569 kWh
Max Electric Demand:	0	0	0	0 kW
Natural Gas:	0	0	0	0 Therms

Reported Annual Energy Cost:

Electricity Cost:	\$540	\$891	\$733	\$367
Electric Demand Cost:	\$0	\$0	\$0	\$0
Natural Gas Cost:	\$0	\$0	\$0	\$0
Energy Cost/ft ²	\$0.054	\$0.089	\$0.073	\$0.037

Weather Normalized Energy Use:

Site Energy Use:	15.95	26.12	19.97	8.77 MBTU
Site EUI:	1,597	2,616	2,000	878 BTU/ft ²
Electricity:	4,674	7,654	5,853	2,569 kWh
Natural Gas:	0	0	0	0 Therms

National Median Energy Use:

Site Energy Use:	188.53	188.53	188.53	188.53 MBTU
Site EUI:	18,885	18,885	18,885	18,885 BTU/ft ²

Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Direct Emissions:	0	0	0	0
Indirect Emissions:	1	2	2	1
Total Emissions:	1	2	2	1

National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Total Emissions:	16.4	16.4	16.4	16.4
------------------	------	------	------	------

% Difference from National Median:

Site EUI:	-91.54	-86.15	-89.41	-95.35
Total Emissions:	-91.46	-85.98	-89.63	-95.12

Adjusted Energy Based on Current Year:

Site Energy Use:	N/A	N/A	N/A	N/A	MBTU
Site EUI:	N/A	N/A	N/A	N/A	BTU/ft ²

% Difference Adjusted Site Energy Use

2012 to Baseline	N/A
2013 to Baseline	N/A
Current to Baseline	N/A
Current to 2013	N/A