

# STATEMENT OF ENERGY PERFORMANCE

DNRC-Missoula EDC Warehouse  
3125 Spurgin Road  
Missoula

Date: 9/7/2018  
Year Built: 1970

	<b>Baseline:</b>	<b>2012</b>	<b>12/31/2013</b>	<b>Current:</b>
Energy Date:	12/31/2007	12/31/2012	12/31/2013	12/31/2017
Energy Star Score:	N/A	N/A	N/A	N/A
Gross Floor Area:	12,550	12,550	12,550	12,550 Sq. Ft.
Heating Degree Days	6,934	6,992	7,448	7,738
Cooling Degree Days	646	396	565	528

### Reported Annual Energy Use:

Site Energy Use:	690.64	489.81	502.71	473.31 MBTU
Site EUI:	55,031	39,028	40,056	37,714 BTU/ft <sup>2</sup>
Electricity:	29,672	23,019	19,889	24,288 kWh
Max Electric Demand:	0	13	13	16 kW
Natural Gas:	5,894	4,113	4,348	3,904 Therms

### Reported Annual Energy Cost:

Electricity Cost:	\$2,940	\$2,846	\$2,772	\$3,421
Electric Demand Cost:	\$0	\$1,125	\$1,192	\$1,349
Natural Gas Cost:	\$6,168	\$3,479	\$3,596	\$2,938
Energy Cost/ft <sup>2</sup>	\$0.726	\$0.504	\$0.507	\$0.507

### Weather Normalized Energy Use:

Site Energy Use:	720.97	510.55	478.87	437.28 MBTU
Site EUI:	57,448	40,681	38,157	34,843 BTU/ft <sup>2</sup>
Electricity:	29,632	23,501	19,889	23,612 kWh
Natural Gas:	6,199	4,304	4,110	3,567 Therms

### National Median Energy Use:

Site Energy Use:	507.92	913.84	945.36	489.24 MBTU
Site EUI:	40,472	72,816	75,328	38,984 BTU/ft <sup>2</sup>

### Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Direct Emissions:	31.3	21.8	23.1	20.7
Indirect Emissions:	9	7	6	7
Total Emissions:	40	29	29	28

### National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Total Emissions:	29.5	53.5	54.6	28.9
------------------	------	------	------	------

### % Difference from National Median:

Site EUI:	35.97	-46.40	-46.82	-3.26
Total Emissions:	35.93	-46.36	-46.89	-3.11

### Adjusted Energy Based on Current Year:

Site Energy Use:	N/A	N/A	N/A	N/A	MBTU
Site EUI:	N/A	N/A	N/A	N/A	BTU/ft <sup>2</sup>

### % Difference Adjusted Site Energy Use

2012 to Baseline	N/A
2013 to Baseline	N/A
Current to Baseline	N/A
Current to 2013	N/A