

# STATEMENT OF ENERGY PERFORMANCE

Eastmont/Watch East  
700 E Little St.  
Glendive

Date: 9/7/2018  
Year Built: 1970

	Baseline:	2012	12/31/2013	Current:
Energy Date:	12/31/2007	11/30/2012	12/31/2013	11/30/2012
Energy Star Score:	N/A	N/A	N/A	N/A
Gross Floor Area:	48,832	48,832	48,832	48,832 Sq. Ft.
Heating Degree Days	7,024	6,591	7,637	6,410
Cooling Degree Days	1,063	1,124	845	1,124

## Reported Annual Energy Use:

Site Energy Use:	4358.70	4765.53	N/A	4765.53 MBTU
Site EUI:	89,259	97,590	N/A	97,590 BTU/ft <sup>2</sup>
Electricity:	486,978	518,600	0	518,600 kWh
Max Electric Demand:	107	124	0	124 kW
Natural Gas:	26,971	29,961	0	29,961 Therms

## Reported Annual Energy Cost:

Electricity Cost:	\$26,490	\$35,151	\$0	\$35,151
Electric Demand Cost:	\$8,017	\$11,892	\$0	\$11,892
Natural Gas Cost:	\$20,026	\$17,953	\$0	\$17,953
Energy Cost/ft <sup>2</sup>	\$0.953	\$1.087	N/A	\$1.087

## Weather Normalized Energy Use:

Site Energy Use:	4559.20	5254.46	N/A	5254.46 MBTU
Site EUI:	93,365	107,603	N/A	107,603 BTU/ft <sup>2</sup>
Electricity:	486,978	518,600	0	518,600 kWh
Natural Gas:	28,976	34,850	0	34,850 Therms

## National Median Energy Use:

Site Energy Use:	3057.13	2825.44	2825.44	3088.30 MBTU
Site EUI:	62,605	57,860	57,860	63,243 BTU/ft <sup>2</sup>

## Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Direct Emissions:	143.3	159.1	0	159.1
Indirect Emissions:	145	154	0	154
Total Emissions:	288	313	N/A	313

## National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Total Emissions:	202	194.2	194.2	203
------------------	-----	-------	-------	-----

## % Difference from National Median:

Site EUI:	42.57	68.67	N/A	54.31
Total Emissions:	42.57	61.33	N/A	54.33

## Adjusted Energy Based on Current Year:

Site Energy Use:	N/A	N/A	N/A	N/A	MBTU
Site EUI:	N/A	N/A	N/A	N/A	BTU/ft <sup>2</sup>

## % Difference Adjusted Site Energy Use

2012 to Baseline	N/A
2013 to Baseline	N/A
Current to Baseline	N/A
Current to 2013	N/A