

STATEMENT OF ENERGY PERFORMANCE

FWP-Anaconda Hatchery
600 West Pennsylvania St
Anaconda

Date: 9/7/2018
Year Built: 1988

	Baseline:	2012	12/31/2013	Current:
Energy Date:	12/31/2007	12/31/2012	12/31/2013	12/31/2017
Energy Star Score:	N/A	N/A	N/A	N/A
Gross Floor Area:	21,477	21,477	21,477	21,477 Sq. Ft.
Heating Degree Days	6,778	7,046	7,351	7,862
Cooling Degree Days	730	517	579	731

Reported Annual Energy Use:

Site Energy Use:	825.52	709.68	741.98	915.26 MBTU
Site EUI:	38,437	33,044	34,548	42,616 BTU/ft ²
Electricity:	70,964	57,489	66,326	63,358 kWh
Max Electric Demand:	0	0	0	0 kW
Natural Gas:	5,834	5,135	5,157	6,991 Therms

Reported Annual Energy Cost:

Electricity Cost:	\$7,081	\$6,165	\$7,362	\$7,263
Electric Demand Cost:	\$0	\$0	\$0	\$0
Natural Gas Cost:	\$6,856	\$4,938	\$5,022	\$5,763
Energy Cost/ft ²	\$0.649	\$0.517	\$0.577	\$0.607

Weather Normalized Energy Use:

Site Energy Use:	877.44	745.92	761.75	890.07 MBTU
Site EUI:	40,855	34,731	35,468	41,443 BTU/ft ²
Electricity:	72,699	58,364	66,663	62,697 kWh
Natural Gas:	6,294	5,468	5,343	6,762 Therms

National Median Energy Use:

Site Energy Use:	1226.46	1250.13	1210.62	1310.24 MBTU
Site EUI:	57,106	58,208	56,368	61,006 BTU/ft ²

Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Direct Emissions:	31	27.3	27.4	37.1
Indirect Emissions:	21	17	20	19
Total Emissions:	52	44	47	56

National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Total Emissions:	77.4	78.2	76.9	80.1
------------------	------	------	------	------

% Difference from National Median:

Site EUI:	-32.69	-43.23	-38.71	-30.15
Total Emissions:	-32.69	-43.22	-38.75	-30.09

Adjusted Energy Based on Current Year:

Site Energy Use:	N/A	N/A	N/A	N/A	MBTU
Site EUI:	N/A	N/A	N/A	N/A	BTU/ft ²

% Difference Adjusted Site Energy Use

2012 to Baseline	N/A
2013 to Baseline	N/A
Current to Baseline	N/A
Current to 2013	N/A