

# STATEMENT OF ENERGY PERFORMANCE

MDT-Billings HQ  
424 Morey Lane  
Billings

Date: 9/7/2018  
Year Built: 1963

	<b>Baseline:</b>	<b>2012</b>	<b>12/31/2013</b>	<b>Current:</b>	
Energy Date:	12/31/2007	11/30/2012	12/31/2013	11/30/2012	
Energy Star Score:	N/A	N/A	N/A	N/A	
Gross Floor Area:	56,864	56,864	56,864	56,864	Sq. Ft.
Heating Degree Days	6,634	6,093	6,939	5,988	
Cooling Degree Days	841	945	777	945	

## Reported Annual Energy Use:

Site Energy Use:	3119.49	1730.10	N/A	1730.10	MBTU
Site EUI:	54,859	30,425	N/A	30,425	BTU/ft <sup>2</sup>
Electricity:	311,366	245,613	257,608	246,004	kWh
Max Electric Demand:	0	0	0	0	kW
Natural Gas:	20,571	8,907	0	8,907	Therms

## Reported Annual Energy Cost:

Electricity Cost:	\$28,686	\$24,930	\$27,021	\$24,825
Electric Demand Cost:	\$0	\$0	\$0	\$0
Natural Gas Cost:	\$15,423	\$5,913	\$0	\$5,913
Energy Cost/ft <sup>2</sup>	\$0.776	\$0.541	N/A	\$0.541

## Weather Normalized Energy Use:

Site Energy Use:	3138.96	1881.45	N/A	1881.45	MBTU
Site EUI:	55,201	33,087	N/A	33,087	BTU/ft <sup>2</sup>
Electricity:	308,158	245,613	257,608	248,052	kWh
Natural Gas:	20,875	10,351	0	10,351	Therms

## National Median Energy Use:

Site Energy Use:	3084.12	2279.49	2279.49	2673.18	MBTU
Site EUI:	54,237	40,087	40,087	47,010	BTU/ft <sup>2</sup>

## Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Direct Emissions:	109.3	47.3	0	47.3
Indirect Emissions:	93	73	77	73
Total Emissions:	202	120	N/A	120

## National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Total Emissions:	199.5	163.6	163.6	186.1
------------------	-------	-------	-------	-------

## % Difference from National Median:

Site EUI:	1.15	-24.10	N/A	-35.28
Total Emissions:	1.15	-26.41	N/A	-35.30

## Adjusted Energy Based on Current Year:

Site Energy Use:	N/A	N/A	N/A	N/A	MBTU
Site EUI:	N/A	N/A	N/A	N/A	BTU/ft <sup>2</sup>

## % Difference Adjusted Site Energy Use

2012 to Baseline	N/A
2013 to Baseline	N/A
Current to Baseline	N/A
Current to 2013	N/A