

# STATEMENT OF ENERGY PERFORMANCE

MDT-Hamilton Equipment Storage  
909 Hub Lane  
Hamilton

Date: 9/7/2018  
Year Built: 1960

	<b>Baseline:</b>	<b>2012</b>	<b>12/31/2013</b>	<b>Current:</b>	
	12/31/2007	12/31/2012	12/31/2013	12/31/2017	
Energy Date:	12/31/2007	12/31/2012	12/31/2013	12/31/2017	
Energy Star Score:	N/A	N/A	N/A	N/A	
Gross Floor Area:	6,436	6,436	6,436	6,436	Sq. Ft.
Heating Degree Days	6,934	6,992	7,448	7,738	
Cooling Degree Days	646	396	565	528	
<b>Reported Annual Energy Use:</b>					
Site Energy Use:	42.11	53.16	48.74	50.94	MBTU
Site EUI:	6,543	8,259	7,573	7,915	BTU/ft <sup>2</sup>
Electricity:	12,343	15,579	14,285	14,930	kWh
Max Electric Demand:	14	14	16	15	kW
Natural Gas:	0	0	0	0	Therms
<b>Reported Annual Energy Cost:</b>					
Electricity Cost:	\$1,854	\$2,408	\$2,335	\$2,611	
Electric Demand Cost:	\$990	\$1,200	\$1,175	\$1,351	
Natural Gas Cost:	\$0	\$0	\$0	\$0	
Energy Cost/ft <sup>2</sup>	\$0.288	\$0.374	\$0.363	\$0.406	
<b>Weather Normalized Energy Use:</b>					
Site Energy Use:	44.09	56.07	46.72	47.65	MBTU
Site EUI:	6,850	8,712	7,259	7,404	BTU/ft <sup>2</sup>
Electricity:	12,921	16,433	13,693	13,966	kWh
Natural Gas:	0	0	0	0	Therms
<b>National Median Energy Use:</b>					
Site Energy Use:	222.71	222.71	222.71	222.71	MBTU
Site EUI:	34,603	34,603	34,603	34,603	BTU/ft <sup>2</sup>
<b>Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):</b>					
Direct Emissions:	0	0	0	0	
Indirect Emissions:	4	5	4	4	
Total Emissions:	4	5	4	4	
<b>National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):</b>					
Total Emissions:	19.4	19.4	19.4	19.4	
<b>% Difference from National Median:</b>					
Site EUI:	-81.09	-76.13	-78.11	-77.13	
Total Emissions:	-80.93	-76.29	-78.35	-77.32	
<b>Adjusted Energy Based on Current Year:</b>					
Site Energy Use:	N/A	N/A	N/A	N/A	MBTU
Site EUI:	N/A	N/A	N/A	N/A	BTU/ft <sup>2</sup>
<b>% Difference Adjusted Site Energy Use</b>					
2012 to Baseline	N/A				
2013 to Baseline	N/A				
Current to Baseline	N/A				
Current to 2013	N/A				