

STATEMENT OF ENERGY PERFORMANCE

MDT-Lima
200 Reeder Road
Lima

Date: 9/7/2018
Year Built: 2007

	Baseline:	2012	12/31/2013	Current:	
	12/31/2007	12/31/2012	12/31/2013	12/31/2017	
Energy Date:	12/31/2007	12/31/2012	12/31/2013	12/31/2017	
Energy Star Score:	N/A	N/A	N/A	N/A	
Gross Floor Area:	7,822	7,822	7,822	7,822	Sq. Ft.
Heating Degree Days	7,701	7,079	8,358	7,784	
Cooling Degree Days	454	447	437	318	
Reported Annual Energy Use:					
Site Energy Use:	42.97	69.68	73.08	68.50	MBTU
Site EUI:	5,493	8,908	9,343	8,757	BTU/ft ²
Electricity:	12,593	20,422	21,418	20,075	kWh
Max Electric Demand:	0	0	0	0	kW
Natural Gas:	0	0	0	0	Therms
Reported Annual Energy Cost:					
Electricity Cost:	\$808	\$1,109	\$1,414	\$1,450	
Electric Demand Cost:	\$0	\$0	\$0	\$0	
Natural Gas Cost:	\$0	\$0	\$0	\$0	
Energy Cost/ft ²	\$0.103	\$0.142	\$0.181	\$0.185	
Weather Normalized Energy Use:					
Site Energy Use:	43.73	75.05	72.66	69.08	MBTU
Site EUI:	5,591	9,594	9,289	8,831	BTU/ft ²
Electricity:	12,816	21,995	21,296	20,245	kWh
Natural Gas:	0	0	0	0	Therms
National Median Energy Use:					
Site Energy Use:	270.67	270.67	270.67	270.67	MBTU
Site EUI:	34,603	34,603	34,603	34,603	BTU/ft ²
Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):					
Direct Emissions:	0	0	0	0	
Indirect Emissions:	4	6	6	6	
Total Emissions:	4	6	6	6	
National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):					
Total Emissions:	23.6	23.6	23.6	23.6	
% Difference from National Median:					
Site EUI:	-84.12	-74.26	-73.00	-74.69	
Total Emissions:	-84.32	-74.15	-72.88	-74.58	
Adjusted Energy Based on Current Year:					
Site Energy Use:	N/A	N/A	N/A	N/A	MBTU
Site EUI:	N/A	N/A	N/A	N/A	BTU/ft ²
% Difference Adjusted Site Energy Use					
2012 to Baseline	N/A				
2013 to Baseline	N/A				
Current to Baseline	N/A				
Current to 2013	N/A				