

# STATEMENT OF ENERGY PERFORMANCE

MDT-Scobey Section Garage  
 Highway 5  
 Scobey

Date: 9/7/2018  
 Year Built: 1978

	Baseline:	2012	12/31/2013	Current:
Energy Date:	12/31/2007	10/31/2012	12/31/2013	10/31/2012
Energy Star Score:	N/A	N/A	N/A	N/A
Gross Floor Area:	15,600	15,600	15,600	15,600 Sq. Ft.
Heating Degree Days	8,307	7,943	9,105	7,643
Cooling Degree Days	701	593	412	593

## Reported Annual Energy Use:

Site Energy Use:	94.80	162.33	N/A	162.33 MBTU
Site EUI:	6,077	10,406	N/A	10,406 BTU/ft <sup>2</sup>
Electricity:	27,785	47,577	0	47,577 kWh
Max Electric Demand:	36	47	0	47 kW
Natural Gas:	0	0	0	0 Therms

## Reported Annual Energy Cost:

Electricity Cost:	\$2,678	\$4,374	\$0	\$4,374
Electric Demand Cost:	\$1,209	\$1,617	\$0	\$1,617
Natural Gas Cost:	\$0	\$0	\$0	\$0
Energy Cost/ft <sup>2</sup>	\$0.172	\$0.280	N/A	\$0.280

## Weather Normalized Energy Use:

Site Energy Use:	98.57	172.49	N/A	172.49 MBTU
Site EUI:	6,319	11,057	N/A	11,057 BTU/ft <sup>2</sup>
Electricity:	28,890	50,553	0	50,553 kWh
Natural Gas:	0	0	0	0 Therms

## National Median Energy Use:

Site Energy Use:	539.81	746.72	746.72	539.81 MBTU
Site EUI:	34,603	47,867	47,867	34,603 BTU/ft <sup>2</sup>

## Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Direct Emissions:	0	0	0	0
Indirect Emissions:	8	14	0	14
Total Emissions:	8	14	N/A	14

## National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Total Emissions:	47	55	55	47
------------------	----	----	----	----

## % Difference from National Median:

Site EUI:	-82.44	-78.26	N/A	-69.93
Total Emissions:	-82.34	-74.36	N/A	-70.00

## Adjusted Energy Based on Current Year:

Site Energy Use:	N/A	N/A	N/A	N/A	MBTU
Site EUI:	N/A	N/A	N/A	N/A	BTU/ft <sup>2</sup>

## % Difference Adjusted Site Energy Use

2012 to Baseline	N/A
2013 to Baseline	N/A
Current to Baseline	N/A
Current to 2013	N/A