

STATEMENT OF ENERGY PERFORMANCE

MDT-St Mary
HWY 89 N. MP 34.8
Browning

Date: 9/7/2018
Year Built: 2004

	Baseline:	2012	12/31/2013	Current:
Energy Date:	12/31/2007	12/31/2012	12/31/2013	12/31/2015
Energy Star Score:	N/A	N/A	N/A	N/A
Gross Floor Area:	5,000	5,000	5,000	5,000 Sq. Ft.
Heating Degree Days	7,475	7,505	7,807	7,248
Cooling Degree Days	371	203	287	304

Reported Annual Energy Use:

Site Energy Use:	49.07	63.01	68.61	59.30 MBTU
Site EUI:	9,814	12,601	13,722	11,859 BTU/ft ²
Electricity:	14,381	18,466	20,108	17,379 kWh
Max Electric Demand:	0	0	0	0 kW
Natural Gas:	0	0	0	0 Therms

Reported Annual Energy Cost:

Electricity Cost:	\$1,296	\$1,659	\$1,774	\$1,616
Electric Demand Cost:	\$0	\$0	\$0	\$0
Natural Gas Cost:	\$0	\$0	\$0	\$0
Energy Cost/ft ²	\$0.259	\$0.332	\$0.355	\$0.323

Weather Normalized Energy Use:

Site Energy Use:	50.81	65.36	69.21	62.47 MBTU
Site EUI:	10,162	13,073	13,841	12,494 BTU/ft ²
Electricity:	14,892	19,157	20,283	18,309 kWh
Natural Gas:	0	0	0	0 Therms

National Median Energy Use:

Site Energy Use:	173.02	173.02	173.02	173.02 MBTU
Site EUI:	34,603	34,603	34,603	34,603 BTU/ft ²

Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Direct Emissions:	0	0	0	0
Indirect Emissions:	4	6	6	5
Total Emissions:	4	6	6	5

National Median Annual Greenhouse Gas Emissions (Metric Tons CO2 equivalent):

Total Emissions:	15.1	15.1	15.1	15.1
------------------	------	------	------	------

% Difference from National Median:

Site EUI:	-71.64	-63.58	-60.35	-65.73
Total Emissions:	-71.52	-63.58	-60.26	-65.56

Adjusted Energy Based on Current Year:

Site Energy Use:	N/A	N/A	N/A	N/A	MBTU
Site EUI:	N/A	N/A	N/A	N/A	BTU/ft ²

% Difference Adjusted Site Energy Use

2012 to Baseline	N/A
2013 to Baseline	N/A
Current to Baseline	N/A
Current to 2013	N/A