

Facility Summary in Big Horn County in the City of Crow Agency

Location: CROW NATION EXPRESS
US Hwy 212 & I-90
Crow Agency, MT 59022 Big Horn

System Facility ID:02-10867

Facility Code: 17827
Last Inspected On: 12/19/2023
Operating Permit Renewal Date: 01/06/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Becky Wilson;Crow Tribe of Indians

(406) 638-2059;(406) 679-2400

becky.wilson@crow-nsn.gov

Operator Contact:

Owner/Operator: Becky Wilson

(406) 679-2400

becky.wilson@crow-nsn.gov

Owner/Operator: Crow Tribe of Indians

(406) 679-2400

becky.wilson@crow-nsn.gov

Tank Code	05	Tank Age	25	Tank Installed Date	02/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4174	Spill Test Date	12/18/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/21/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	08/02/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/18/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	25	Tank Installed Date	02/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4175	Spill Test Date	12/18/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/21/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	08/02/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/18/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	07	Tank Age	25	Tank Installed Date	02/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4176	Spill Test Date	12/18/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/21/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	08/02/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/18/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	25	Tank Installed Date	02/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4177	Spill Test Date	12/18/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/21/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	08/02/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/18/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	25	Tank Installed Date	02/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4178	Spill Test Date	12/18/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/21/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	08/02/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/18/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Big Horn County in the City of Crow Agency

Location: TEEPEE SERVICE INC
6959 E Makawasha Ave
Crow Agency, MT 59022-0280 Big Horn

System Facility ID:02-07334

Facility Code: 17799
Last Inspected On: 04/09/2025
Operating Permit Renewal Date: 07/22/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Teepee Service Inc

(406) 638-2269

Operator Contact: James Watt

2teepee@nemont.net

Owner/Operator: Teepee Service Inc

(406) 638-2269

James Watt, UST Class A Operator
James Watt, UST Class A Operator
James Watt, UST Class B Operator
James Watt, UST Class B Operator

2teepee@nemont.net
2teepee@nemont.net
2teepee@nemont.net
2teepee@nemont.net

Tank Code	07	Tank Age	30	Tank Installed Date	07/03/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	2097	Spill Test Date	05/09/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/09/2022	Tank/Piping CP Test Date	04/16/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/09/2022	Line Tightness Test Date	03/06/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/09/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	30	Tank Installed Date	07/03/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	2098	Spill Test Date	05/09/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/09/2022	Tank/Piping CP Test Date	04/16/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/09/2022	Line Tightness Test Date	02/18/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	05/09/2022			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
--	--	---------------------------	------------	--	--	-----------------	--	--	--	--	--

Facility Summary in Big Horn County in the City of Fort Smith

Location: BIGHORN CANYON MAINTENANCE FACILITY (NPS)
5th Ave B
Fort Smith, MT 59035 Big Horn

System Facility ID:02-09815

Facility Code: 17820
Last Inspected On: 03/10/2021
Operating Permit Renewal Date: 03/21/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: National Park Service Yellowtail (406) 666-3311

Operator Contact: Jesse Macklin;Kelly Peacock;Lyndon Driftwood;William Snell (406) 666-3310;(406) 666-3312 kelly_peacock@nps.gov;lyndon_driftwood@nps.gov

Owner/Operator: National Park Service Yellowtail (406) 666-3311

Jesse Macklin, UST Class A Operator
Jesse Macklin, UST Class B Global Operator
Jesse Macklin, UST Class B Operator
Kelly Peacock, UST Class A Operator
Kelly Peacock, UST Class B Operator
Lyndon Driftwood, UST Class A Operator
Lyndon Driftwood, UST Class B Global Operator
Norman Griffin, UST Class B Operator
Roger Watson, UST Class B Global Operator
William Snell, UST Class A Operator
William Snell, UST Class B Global Operator
William Snell, UST Class B Operator

kelly_peacock@nps.gov
kelly_peacock@nps.gov
lyndon_driftwood@nps.gov
lyndon_driftwood@nps.gov

Tank Code	05	Tank Age	37	Tank Installed Date	01/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	1745	Spill Test Date	06/15/2023	Piping Installed Date	10/16/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/10/2021	Sump Tightness Test Date	10/16/2017	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/26/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	03/10/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	06/15/2023			ATG Type	Veeder Root/TLS-300				

Tank Code	06	Tank Age	37	Tank Installed Date	01/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	1746	Spill Test Date	06/15/2023	Piping Installed Date	10/16/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/10/2021	Sump Tightness Test Date	10/16/2017	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/26/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	03/10/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	06/15/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Big Horn County in the City of Fort Smith

Location: OK A BEH MARINA
5 Ave B
Fort Smith, MT 59035 Big Horn

System Facility ID:56-13877

Facility Code: 30554
Last Inspected On: 05/08/2021
Operating Permit Renewal Date: 05/26/2022

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: National Park Service Yellowtail (406) 666-3311

Operator Contact: Christian Fighter;Jaris Pretty Paint;Kelly Peacock;Marvin Stewart;Shawn Backbone;Tristan Stewart (406) 683-5313
fighterchristian117@gmail.com;jpretypaint01@gmail.com;kelly_peacock@nps.gov;shawnbackbone78@gmail.com;tristantoddstewart@gmail.com

Owner/Operator: National Park Service Yellowtail (406) 666-3311

Christian Fighter, UST Class A Operator
Christian Fighter, UST Class B Operator
Jaris Pretty Paint, UST Class A Operator
Kelly Peacock, UST Class A Operator
Kelly Peacock, UST Class B Operator
Marvin Stewart, UST Class A Operator
Marvin Stewart, UST Class B Operator
Shawn Backbone, UST Class A Operator
Tristan Stewart, UST Class A Operator
Tristan Stewart, UST Class B Operator

fighterchristian117@gmail.com
fighterchristian117@gmail.com
jpretypaint01@gmail.com
kelly_peacock@nps.gov
kelly_peacock@nps.gov

shawnbackbone78@gmail.com
tristantoddstewart@gmail.com
tristantoddstewart@gmail.com

Tank Code	07	Tank Age	35	Tank Installed Date	05/14/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1747	Spill Test Date	06/14/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/02/2021	Sump Tightness Test Date	06/22/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/19/2020	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	06/02/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

Facility Summary in Big Horn County in the City of Fort Smith

Location: YELLOWTAIL MARKET
Park Dale Ct
Fort Smith, MT 59035 Big Horn

System Facility ID:02-05862

Facility Code: 17785
Last Inspected On: 10/03/2024
Operating Permit Renewal Date: 10/20/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Crow Tribe of Indians (406) 638-2059

Operator Contact: Becky Wilson;John Wilson (406) 638-2400;(406) 679-2400 becky.wilson@crow-nsn.gov

Owner/Operator: Crow Tribe of Indians (406) 638-2059

Becky Wilson, UST Class A Operator
Becky Wilson, UST Class A Operator
Becky Wilson, UST Class B Operator
Becky Wilson, UST Class B Operator
John Wilson, UST Class A Operator
John Wilson, UST Class B Global Operator

becky.wilson@crow-nsn.gov
becky.wilson@crow-nsn.gov
becky.wilson@crow-nsn.gov
becky.wilson@crow-nsn.gov

Tank Code	03	Tank Age	27	Tank Installed Date	03/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1210	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	01/10/2025	Tank/Piping CP Test Date	10/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/03/2024	Line Tightness Test Date	03/04/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/10/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	27	Tank Installed Date	03/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1211	Spill Test Date	10/03/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	01/10/2025	Tank/Piping CP Test Date	10/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/03/2024	Line Tightness Test Date	03/04/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	01/10/2025			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
--	--	---------------------------	------------	--	--	-----------------	--	--	--	--	--

Facility Summary in Big Horn County in the City of Garryowen

Location: GARRYOWEN CONOCO
200 Town Hall
Garryowen, MT 59031 Big Horn

System Facility ID:02-03284

Facility Code: 17761
Last Inspected On: 10/15/2021
Operating Permit Renewal Date: 10/25/2021

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Neda LLC (406) 638-2020

Operator Contact: Chris Kortlander (406) 679-4444 chris@historicalrarities.com

Owner/Operator: Neda LLC (406) 638-2020

Chris Kortlander, UST Class A Operator chris@historicalrarities.com
Chris Kortlander, UST Class A Operator chris@historicalrarities.com
Petra Pretty On Top, UST Class B Global Operator
Petra Pretty On Top, UST Class B Global Operator

Tank Code	01	Tank Age	29	Tank Installed Date	06/21/1996	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3392	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/29/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	10/15/2018	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	02	Tank Age	29	Tank Installed Date	06/21/1996	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3393	Spill Test Date		Piping Installed Date	06/11/2013	Tank Construction	Double-Walled	Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/29/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	12000	ATG Test Date		Line Tightness Test Date	10/15/2018	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Big Horn County in the City of Hardin

Location: BIG HORN COUNTY COMMUNITY SERVICE FACILITY
809 N Custer Ave
Hardin, MT 59034-1311 Big Horn

System Facility ID:02-10287

Facility Code: 17825
Last Inspected On: 01/08/2021
Operating Permit Renewal Date: 01/17/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Big Horn County Health Dept (406) 665-8720

Operator Contact: Craig Taft (406) 665-8724 ctaft@co.bighorn.mt.us

Craig Taft, UST Class A Operator
Craig Taft, UST Class A Operator
Craig Taft, UST Class B Global Operator
Craig Taft, UST Class B Global Operator

ctaft@co.bighorn.mt.us
ctaft@co.bighorn.mt.us
ctaft@co.bighorn.mt.us
ctaft@co.bighorn.mt.us

Tank Code	02	Tank Age	27	Tank Installed Date	11/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	443	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/21/2011	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Big Horn County in the City of Hardin

Location: DOLLIES CONVENIENCE STORE
804 3rd St W
Hardin, MT 59034-1606 Big Horn

System Facility ID:02-00061

Facility Code: 17730
Last Inspected On: 12/16/2022
Operating Permit Renewal Date: 12/16/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jagadish LLC;Susan Greer (406) 665-1424;(605) 517-1140 cpatel8897@gmail.com

Operator Contact: Chetan Patel;Megan Ashinhurst (605) 517-1140 cpatel8897@gmail.com

Owner/Operator: Jagadish LLC (605) 517-1140 cpatel8897@gmail.com

Owner/Operator: Susan Greer (605) 517-1140 cpatel8897@gmail.com

- Chetan Patel, UST Class A Operator cpatel8897@gmail.com
- Chetan Patel, UST Class A Operator cpatel8897@gmail.com
- Chetan Patel, UST Class B Operator cpatel8897@gmail.com
- Chetan Patel, UST Class B Operator cpatel8897@gmail.com
- Constance Weigand, UST Class B Operator
- Constance Weigand, UST Class B Operator
- Corri Duncan, UST Class B Operator corriduncan@aol.com
- Corri Duncan, UST Class B Operator corriduncan@aol.com
- Megan Ashinhurst, UST Class A Operator
- Megan Ashinhurst, UST Class A Operator
- Megan Ashinhurst, UST Class B Global Operator
- Megan Ashinhurst, UST Class B Global Operator

Tank Code	01	Tank Age	41	Tank Installed Date	12/20/1984	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4463	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/16/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	01/21/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Tank Code	03	Tank Age	23	Tank Installed Date	12/16/2002	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4773	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/16/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.1; Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	01/21/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Big Horn County in the City of Hardin

Location: FORMER BAIRS TRUCK STOP HARDIN
315 13th St W
Hardin, MT 59034-1006 Big Horn

System Facility ID:02-05752

Facility Code: 17781
Last Inspected On: 03/09/2022
Operating Permit Renewal Date: 06/01/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hardin 2 RE2 LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers;Town Pump

Trentb@townpump.com;environmental@townpump.com

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Operator
Trent Biggers, UST Class B Operator

environmental@townpump.com
environmental@townpump.com
environmental@townpump.com
environmental@townpump.com

Tank Code	01	Tank Age	56	Tank Installed Date	04/25/1969	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3894	Spill Test Date	08/31/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	08/13/2018	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/09/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	40000	ATG Test Date		Line Tightness Test Date	02/07/2013	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/31/2020			ATG Type					
Tank Code	03	Tank Age	46	Tank Installed Date	04/26/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3895	Spill Test Date	06/20/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	08/13/2018	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/09/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	40000	ATG Test Date		Line Tightness Test Date	01/04/2013	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	06/20/2022			ATG Type					

Tank Code	04	Tank Age	56	Tank Installed Date	04/25/1969	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3896	Spill Test Date	08/31/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	08/13/2018	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/09/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	24000	ATG Test Date		Line Tightness Test Date	01/04/2013	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	06/20/2022			ATG Type					

Facility Summary in Big Horn County in the City of Hardin

Location: GOOD 2 GO STORES LLC
1600 N Crawford Ave
Hardin, MT 59034 Big Horn

System Facility ID:02-00538

Facility Code: 17731
Last Inspected On: 08/08/2022
Operating Permit Renewal Date: 12/11/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: #8 Hardin Montana Property LLC	(208) 523-6582	compliance@southforkmanagement.com
Operator Contact: Amy Packard;Good 2 Go Stores LLC;Garry Wells;Good 2 Go Stores LLC;Jeanette Nette;Good 2 Go Stores LLC;Lisa Yates;Good 2 Go Stores LLC	(208) 417-1590	gdubb350@gmail.com;licensing@good2gostores.com;jnetty1970@gmail.com;licensing@good2gostores.com;lisa.yates@good2go.com;licensing@good2gostores.com;store218@good2gostores.com;licensing@good2gostores.com

Owner/Operator: #8 Hardin Montana Property LLC	(208) 523-6582	compliance@southforkmanagement.com
Amy Packard, UST Class A Operator Amy Packard, UST Class B Operator Garry Wells, UST Class A Operator Garry Wells, UST Class B Operator Jeanette Nette, UST Class A Operator Jeanette Nette, UST Class B Operator Lisa Yates, UST Class A Operator Lisa Yates, UST Class B Operator		licensing@good2gostores.com licensing@good2gostores.com licensing@good2gostores.com licensing@good2gostores.com licensing@good2gostores.com licensing@good2gostores.com licensing@good2gostores.com

Tank Code	03	Tank Age	51	Tank Installed Date	04/12/1974	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3789	Spill Test Date	08/08/2022	Piping Installed Date	04/16/2010	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/09/2022	Tank/Piping CP Test Date	08/28/2007	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/08/2022	Line Tightness Test Date	07/26/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/24/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	51	Tank Installed Date	04/12/1974	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3790	Spill Test Date	08/08/2022	Piping Installed Date	04/16/2010	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	05/09/2022	Tank/Piping CP Test Date	08/08/2007	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/08/2022	Line Tightness Test Date	04/24/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/08/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	51	Tank Installed Date	04/12/1974	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3791	Spill Test Date	08/08/2022	Piping Installed Date	04/16/2010	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/09/2022	Tank/Piping CP Test Date	08/28/2007	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/08/2022	Line Tightness Test Date	03/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/08/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	51	Tank Installed Date	04/12/1974	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3792	Spill Test Date	08/08/2022	Piping Installed Date	04/16/2010	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/09/2022	Tank/Piping CP Test Date	09/07/2007	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/08/2022	Line Tightness Test Date	07/26/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/08/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Big Horn County in the City of Hardin

Location: HARDIN C STORE
1223 N Crawford Ave
Hardin, MT 59034-1009 Big Horn

System Facility ID:02-13635

Facility Code: 17852
Last Inspected On: 08/08/2022
Operating Permit Renewal Date: 12/10/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Town and Country Supply Association (406) 628-6314

Operator Contact: Wes Burley (406) 256-1020

Owner/Operator: Town and Country Supply Association (406) 628-6314

Jennifer Reinhardt, UST Class B Global Operator
Melanie Hale, UST Class B Operator
Wes Burley, UST Class A Operator

jreinhardt@tandcsupply.com
mhale@tandcsupply.com

Tank Code	01	Tank Age	30	Tank Installed Date	07/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	927	Spill Test Date	08/08/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	08/08/2022	Tank/Piping CP Test Date	08/08/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	16000	ATG Test Date	08/08/2022	Line Tightness Test Date	08/04/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/08/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	30	Tank Installed Date	07/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	928	Spill Test Date	08/08/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/08/2022	Tank/Piping CP Test Date	08/08/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	16000	ATG Test Date	08/08/2022	Line Tightness Test Date	08/07/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/08/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	03	Tank Age	30	Tank Installed Date	07/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm

Tag Number	929	Spill Test Date	08/08/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/08/2022	Tank/Piping CP Test Date	08/08/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	16000	ATG Test Date	08/08/2022	Line Tightness Test Date	07/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/08/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	30	Tank Installed Date	07/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	930	Spill Test Date	08/08/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date	08/08/2022	Tank/Piping CP Test Date	08/08/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/08/2022	Line Tightness Test Date	07/30/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/08/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	30	Tank Installed Date	07/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	931	Spill Test Date	08/08/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/08/2022	Tank/Piping CP Test Date	08/08/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/08/2022	Line Tightness Test Date	07/20/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/08/2022			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Big Horn County in the City of Hardin

Location: L and B LAST STOP
531 E Railway St
Hardin, MT 59034-1903 Big Horn

System Facility ID:02-05856

Facility Code: 17783
Last Inspected On: 04/17/2024
Operating Permit Renewal Date: 10/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Gary and Lynette VanDersloot (406) 665-3414

Operator Contact: Lynette VanDersloot (406) 665-3414 laststop531@gmail.com

Owner/Operator: Gary and Lynette VanDersloot (406) 665-3414

Lynette VanDersloot, UST Class A Operator
Lynette VanDersloot, UST Class B Operator

laststop531@gmail.com
laststop531@gmail.com

Tank Code	03	Tank Age	26	Tank Installed Date	01/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass	Overfill Types	Flapper Valve
Tag Number	3915	Spill Test Date	04/17/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/29/2013	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/03/2024			ATG Type					
Tank Code	04	Tank Age	26	Tank Installed Date	01/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass	Overfill Types	Flapper Valve
Tag Number	3916	Spill Test Date	04/17/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/29/2013	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/17/2024			ATG Type					

Facility Summary in Big Horn County in the City of Hardin

Location: LOVES TRAVEL STOP HARDIN #679
1270 N State Hwy 47
Hardin, MT 59034 Big Horn

System Facility ID:60-15284

Facility Code: 30991
Last Inspected On: 06/30/2023
Operating Permit Renewal Date: 12/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Loves Travel Stops and Country Stores Inc

environmental@loves.com

Operator Contact: Eric Bennett;Loves Travel Stops and Country Stores Inc;Ted Parrish (405) 779-3768;(615) 580-9096

environmental@loves.com;environmental@loves.com;tparrish@m
vifieldservices.com

Owner/Operator: Loves Travel Stops and Country Stores Inc

environmental@loves.com

Eric Bennett, UST Class A Operator
Eric Bennett, UST Class B Operator
Ted Parrish, UST Class A Operator
Ted Parrish, UST Class A Operator
Ted Parrish, UST Class B Global Operator
Ted Parrish, UST Class B Global Operator

environmental@loves.com
environmental@loves.com
tparrish@m
vifieldservices.com
tparrish@m
vifieldservices.com
tparrish@m
vifieldservices.com
tparrish@m
vifieldservices.com

Tank Code	01	Tank Age	8	Tank Installed Date	05/27/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	5658	Spill Test Date	08/08/2023	Piping Installed Date	10/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/08/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	07/01/2023	Line Tightness Test Date	06/29/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-5000 EVO				
Tank Code	02	Tank Age	8	Tank Installed Date	05/27/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	5659	Spill Test Date		Piping Installed Date	10/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-5000 EVO				
Tank Code	03	Tank Age	8	Tank Installed Date	05/27/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	5660	Spill Test Date		Piping Installed Date	10/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-5000 EVO				
Tank Code	04	Tank Age	8	Tank Installed Date	05/27/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	5661	Spill Test Date		Piping Installed Date	10/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-5000 EVO				
Tank Code	05	Tank Age	8	Tank Installed Date	05/27/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	5662	Spill Test Date		Piping Installed Date	10/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-5000 EVO				

Tank Code	06	Tank Age	8	Tank Installed Date	05/27/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	5663	Spill Test Date		Piping Installed Date	10/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Biodiesel, <=B20	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-5000 EVO				
Tank Code	07	Tank Age	8	Tank Installed Date	05/27/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	5664	Spill Test Date		Piping Installed Date	10/01/2016	Tank Construction		Piping Construction		AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date	06/05/2017	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2;ELLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring;Not Listed	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Big Horn County in the City of Hardin

Location: MATOVICH OIL CO INC
900 4th St W
Hardin, MT 59034 Big Horn

System Facility ID:02-13423

Facility Code: 17850
Last Inspected On: 11/22/2023
Operating Permit Renewal Date: 03/05/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Matovich Oil Co Inc (406) 665-1400 cwittmato@yahoo.com

Operator Contact: Jon Matovich (406) 665-1400 cwittmato@yahoo.com

Owner/Operator: Matovich Oil Co Inc (406) 665-1400 cwittmato@yahoo.com

Jon Matovich, UST Class A Operator	cwittmato@yahoo.com
Jon Matovich, UST Class A Operator	cwittmato@yahoo.com
Jon Matovich, UST Class B Operator	cwittmato@yahoo.com
Jon Matovich, UST Class B Operator	cwittmato@yahoo.com

Tank Code	01	Tank Age	31	Tank Installed Date	05/24/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1580	Spill Test Date	11/22/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	11/22/2023	Tank/Piping CP Test Date	11/22/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	2000	ATG Test Date	11/22/2023	Line Tightness Test Date	09/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	31	Tank Installed Date	05/24/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1581	Spill Test Date	11/22/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	11/22/2023	Tank/Piping CP Test Date	11/22/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	2000	ATG Test Date	11/22/2023	Line Tightness Test Date	09/16/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	03	Tank Age	31	Tank Installed Date	05/24/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1582	Spill Test Date	11/22/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	11/22/2023	Tank/Piping CP Test Date	11/22/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	11/22/2023	Line Tightness Test Date	09/02/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	31	Tank Installed Date	05/24/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1583	Spill Test Date	11/22/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	11/22/2023	Tank/Piping CP Test Date	03/28/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	11/22/2023	Line Tightness Test Date	09/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/22/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Big Horn County in the City of Hardin

Location: TOWN AND COUNTRY SUPPLY #48
225 W Railroad St
Hardin, MT 59034 Big Horn

System Facility ID:02-01403

Facility Code: 17744
Last Inspected On: 08/29/2022
Operating Permit Renewal Date: 12/10/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Town and Country Supply Association (406) 628-6314

Operator Contact: Wes Burley;Town and Country Supply Association (406) 256-1020;(406) 628-6314

Owner/Operator: Town and Country Supply Association (406) 628-6314

Connie Roundtree, UST Class B Global Operator
Jennifer Reinhardt, UST Class B Global Operator
Wes Burley, UST Class A Operator

croundtree@tandcsupply.com
jreinhardt@tandcsupply.com

Tank Code	S6	Tank Age	35	Tank Installed Date	06/01/1990	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	923	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	08/08/2022	Sump Tightness Test Date	08/08/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	08/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S7	Tank Age	35	Tank Installed Date	06/01/1990	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	924	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	08/08/2022	Sump Tightness Test Date	08/08/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	08/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S8	Tank Age	35	Tank Installed Date	06/01/1990	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	925	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes

Tank Status	Currently in Use	MLLD Test Date	08/08/2022	Sump Tightness Test Date	08/08/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	08/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S9	Tank Age	35	Tank Installed Date	06/01/1990	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	926	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date	08/20/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	08/20/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Big Horn County in the City of Hardin

Location: TOWN PUMP INC HARDIN
1010 N Crawford Ave
Hardin, MT 59034-1217 Big Horn

System Facility ID:02-08703

Facility Code: 17811
Last Inspected On: 03/07/2024
Operating Permit Renewal Date: 09/08/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hardin 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Hardin 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
 Trent Biggers, UST Class A Operator Trentb@townpump.com
 Trent Biggers, UST Class B Global Operator Trentb@townpump.com
 Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Code	01	Tank Age	41	Tank Installed Date	10/01/1984	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2377	Spill Test Date	06/07/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	08/29/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	41	Tank Installed Date	10/01/1984	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2378	Spill Test Date	06/07/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	08/29/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	41	Tank Installed Date	10/01/1984	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2379	Spill Test Date	06/07/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	08/29/2024	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	44	Tank Installed Date	04/14/1981	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2380	Spill Test Date	08/18/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	08/29/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	48	Tank Installed Date	01/01/1977	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2381	Spill Test Date	12/20/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/05/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	08/29/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/20/2022	Line Tightness Test Date	08/05/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	25	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve

Tag Number	4362	Spill Test Date	08/18/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	12/05/2018	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	25	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4363	Spill Test Date	06/07/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	12/14/2009	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	08	Tank Age	25	Tank Installed Date	05/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4364	Spill Test Date	06/07/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	12/14/2009	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/18/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Big Horn County in the City of Hardin

Location: WAGNER TRAVEL SHOPPE EXPRESS STOP
1424 N Crawford Ave
Hardin, MT 59034-1008 Big Horn

System Facility ID:02-04841

Facility Code: 17774
Last Inspected On: 07/12/2023
Operating Permit Renewal Date: 07/12/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Stockton Oil Co Billings

office@stocktonoil.com

Operator Contact:

Owner/Operator: Stockton Oil Co Billings

office@stocktonoil.com

Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Sue Nutgens, UST Class B Operator
Sue Nutgens, UST Class B Operator

cstockton@stocktonoil.com
jstockton@stocktonoil.com
jstockton@stocktonoil.com
jmccconnell@stocktonoil.com
jmccconnell@stocktonoil.com

Tank Code	07	Tank Age	35	Tank Installed Date	01/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve; Flapper Valve
Tag Number	2231	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1; Automatic Tank Gauging 0.2; Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/26/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	08	Tank Age	35	Tank Installed Date	01/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve; Flapper Valve
Tag Number	2232	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/26/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	09	Tank Age	35	Tank Installed Date	01/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2233	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	05/26/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S4	Tank Age	46	Tank Installed Date	04/03/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	2234	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	14000	ATG Test Date		Line Tightness Test Date	05/26/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S5	Tank Age	46	Tank Installed Date	04/03/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	2235	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	14000	ATG Test Date		Line Tightness Test Date	05/26/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date			ATG Type						
Tank Code	S6	Tank Age	46	Tank Installed Date	04/03/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	2236	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	14000	ATG Test Date		Line Tightness Test Date	05/26/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Big Horn County in the City of Lodge Grass

Location: FARMERS UNION OIL CO LODGE GRASS
 US Hwy 87
 Lodge Grass, MT 59050-0560 Big Horn

System Facility ID:02-09976

Facility Code: 17822
Last Inspected On: 03/02/2024
Operating Permit Renewal Date: 07/20/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Farmers Union Oil Co Lodge Grass

Operator Contact: Debra Edwards;Farmers Union Oil Co Lodge Grass

2FUOC@NEMONT.NET

Owner/Operator: Farmers Union Oil Co Lodge Grass

Alvin Edwards, UST Class B Operator
 Alvin Edwards, UST Class B Operator
 Darin BigMedicine, UST Class B Operator
 Darin BigMedicine, UST Class B Operator
 Debra Edwards, UST Class A Operator
 Debra Edwards, UST Class A Operator
 Debra Edwards, UST Class B Operator
 Debra Edwards, UST Class B Operator
 Lorene Flatmouth, UST Class B Operator
 Lorene Flatmouth, UST Class B Operator
 Merla Mullenberg, UST Class B Operator
 Merla Mullenberg, UST Class B Operator

alvinbedwards78@yahoo.com
 alvinbedwards78@yahoo.com
 dbigmedicine@facebook.com
 dbigmedicine@facebook.com
 2FUOC@NEMONT.NET
 2FUOC@NEMONT.NET
 2FUOC@NEMONT.NET
 2FUOC@NEMONT.NET

mmullenberg@hotmail.com
 mmullenberg@hotmail.com

Tank Code	09	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3603	Spill Test Date	02/29/2024	Piping Installed Date	05/09/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/09/2024	Tank/Piping CP Test Date	02/29/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/09/2024	Line Tightness Test Date	03/03/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/29/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	3604	Spill Test Date	02/29/2024	Piping Installed Date	05/09/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/09/2024	Tank/Piping CP Test Date	02/29/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/09/2024	Line Tightness Test Date	03/03/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/29/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	11	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3605	Spill Test Date	02/29/2024	Piping Installed Date	05/09/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/09/2024	Tank/Piping CP Test Date	02/29/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/09/2024	Line Tightness Test Date	03/03/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/29/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Big Horn County in the City of Lodge Grass

Location: LODGE GRASS SCHOOL DIST 27
124 N George St
Lodge Grass, MT 59050 Big Horn

System Facility ID:02-10772

Facility Code: 17826
Last Inspected On: 03/15/2024
Operating Permit Renewal Date: 03/15/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 27 Lodge Grass (406) 639-2304

Operator Contact:

Owner/Operator: School Dist 27 Lodge Grass (406) 639-2304

Donald Gardner, UST Class B Global Operator
Leroy Wallace, UST Class B Operator
Steve Amyotte, UST Class B Operator

donald.gardner@lodgegrass.k12.mt.us

steve.amyotte@lodgegrass.k12.mt.us

Tank Code	02	Tank Age	40	Tank Installed Date	04/04/1985	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4361	Spill Test Date		Piping Installed Date	10/20/2006	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/17/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Big Horn County in the City of Lodge Grass

Location: OUR LADY OF LORETTO CHURCH
Harding Ave & Helen St
Lodge Grass, MT 59050 Big Horn

System Facility ID:02-09970

Facility Code: 17821
Last Inspected On: 11/03/2023
Operating Permit Renewal Date: 02/11/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Our Lady of Loretto Church (312) 995-0702

Operator Contact: Michael Dorn;Tien Dinh brmikedorn@gmail.com;tientxd@gmail.com

Owner/Operator: Our Lady of Loretto Church (312) 995-0702

Michael Dorn, UST Class A Operator
Michael Dorn, UST Class B Operator
Tien Dinh, UST Class A Operator
Tien Dinh, UST Class B Operator

brmikedorn@gmail.com
brmikedorn@gmail.com
tientxd@gmail.com
tientxd@gmail.com

Tank Code	S2	Tank Age	35	Tank Installed Date	07/23/1990	Tank Material	Cathodically Protected Steel	Piping Material	Copper	Overfill Types	High Level Alarm
Tag Number	1778	Spill Test Date	11/03/2023	Piping Installed Date		Tank Construction		Piping Construction	PVC	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	11/03/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	3000	ATG Test Date	11/03/2023	Line Tightness Test Date	11/03/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/03/2023			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Big Horn County in the City of Pryor

Location: PLENTY COUPS HIGH SCHOOL
1 High School Ln
Pryor, MT 59066-0229 Big Horn

System Facility ID:02-01131

Facility Code: 17735
Last Inspected On: 07/03/2024
Operating Permit Renewal Date: 08/26/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Plenty Coups High School (406) 259-7329

Operator Contact: Craig Cliff;Plenty Coups High School (406) 422-7289;(406) 259-7329 craigcliff@pryorstaff.org

Owner/Operator: Plenty Coups High School (406) 259-7329

Craig Cliff, UST Class A Operator
Craig Cliff, UST Class B Operator

craigcliff@pryorstaff.org
craigcliff@pryorstaff.org

Tank Code	05	Tank Age	27	Tank Installed Date	06/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1824	Spill Test Date	07/03/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/02/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	01/24/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/03/2024			ATG Type	Veeder Root/TLS-300				
Tank Code	06	Tank Age	27	Tank Installed Date	06/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1825	Spill Test Date	07/03/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/02/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	01/24/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/03/2024			ATG Type	Veeder Root/TLS-300				

Facility Summary in Big Horn County in the City of Pryor

Location: PRYOR SELF SERVICE
704 Mak Pua Ave
Pryor, MT 59066 Big Horn

System Facility ID:02-10164

Facility Code: 17823
Last Inspected On: 02/10/2023
Operating Permit Renewal Date: 05/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: William Hoffman

Operator Contact: William Hoffman

Owner/Operator: William Hoffman

William Hoffman, UST Class A Operator

William Hoffman, UST Class B Global Operator

Tank Code	03	Tank Age	27	Tank Installed Date	10/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1389	Spill Test Date	02/10/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	02/04/2011	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/10/2023			ATG Type					

Facility Summary in Big Horn County in the City of Pryor

Location: SAINT CHARLES MISSION
29 Pryor Gap Rd
Pryor, MT 59066 Big Horn

System Facility ID:56-04505

Facility Code: 29917
Last Inspected On: 05/09/2024
Operating Permit Renewal Date: 10/09/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: St Labre Indian School (406) 784-4994 STLMAINTINV@STLABRE.ORG

Operator Contact: Dana Davis;Leney Mcnac ddavis@stlabre.org;lmcnac@stlabre.org

Owner/Operator: St Labre Indian School (406) 784-4994 STLMAINTINV@STLABRE.ORG

Dana Davis, UST Class A Operator ddavis@stlabre.org
 Dana Davis, UST Class B Global Operator ddavis@stlabre.org
 Leney Mcnac, UST Class A Operator lmcnac@stlabre.org
 Leney Mcnac, UST Class B Global Operator lmcnac@stlabre.org

Tank Code	02	Tank Age	35	Tank Installed Date	08/20/1990	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1958	Spill Test Date	05/09/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/09/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	05/09/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/09/2024			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Big Horn County in the City of Saint Xavier

Location: PRETTY EAGLE SCHOOL
1 mi W of St Xavier
Saint Xavier, MT 59075-0257 Big Horn

System Facility ID:02-04504

Facility Code: 17768
Last Inspected On: 05/09/2024
Operating Permit Renewal Date: 10/09/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: St Labre Indian School

(406) 784-4994

STLMAINTINV@STLABRE.ORG

Operator Contact: Dana Davis;Leney Mcnac

ddavis@stlabre.org;lmcnac@stlabre.org

Owner/Operator: St Labre Indian School

(406) 784-4994

STLMAINTINV@STLABRE.ORG

Dana Davis, UST Class A Operator
Dana Davis, UST Class B Global Operator
Leney Mcnac, UST Class A Operator
Leney Mcnac, UST Class B Global Operator

ddavis@stlabre.org
ddavis@stlabre.org
lmcnac@stlabre.org
lmcnac@stlabre.org

Tank Code	03	Tank Age	35	Tank Installed Date	04/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1956	Spill Test Date	07/17/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/09/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	05/09/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/09/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	S4	Tank Age	35	Tank Installed Date	04/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3672	Spill Test Date	06/17/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	05/09/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/17/2021	Line Tightness Test Date	11/05/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

	Overfill Test Date	06/17/2021						
--	---------------------------	------------	--	--	--	--	--	--

			ATG Type	Gilbarco-Veeder Root/TLS-350				
--	--	--	-----------------	---------------------------------	--	--	--	--

Facility Summary in Big Horn County in the City of Wyola

Location: WYOLA ELEMENTARY SCHOOL
 1 Mondell Ave
 Wyola, MT 59089 Big Horn

System Facility ID:02-13762

Facility Code: 17853
Last Inspected On: 07/12/2022
Operating Permit Renewal Date: 07/12/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 29 Wyola

(406) 343-2722

Operator Contact: Bradford Crooked Arm

bradfordcrookedarm@gmail.com

Owner/Operator: School Dist 29 Wyola

(406) 343-2722

Bradford Crooked Arm, UST Class A Operator

bradfordcrookedarm@gmail.com

Bradford Crooked Arm, UST Class B Global Operator

bradfordcrookedarm@gmail.com

Tank Code	02	Tank Age	26	Tank Installed Date	07/01/1999	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4370	Spill Test Date	07/12/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/24/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	07/12/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/12/2022			ATG Type	Veeder Root/TLS-300				