

**Facility Summary in Deer Lodge County in the City of Anaconda**

**Location:** FAIRMONT RV PARK AND CAMPGROUND LLC  
1700 Fairmont Rd  
Anaconda, MT 59711-9419 Deer Lodge

System Facility ID:56-13976

**Facility Code:** 30638  
**Last Inspected On:** 09/07/2022  
**Operating Permit Renewal Date:** 11/01/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** SILVER BOW RESORTS INC DBA FAIRMONT RV RESORT (406) 979-3505

**DANBRADSHAW27@ICLOUD.COM**

**Operator Contact:** Dan Bashaw;Joe Bashaw

**(406) 593-0929;(406) 797-3505**

**danbashaw27@icloud.com;fairmontrvpark@aol.com**

**Owner/Operator:** SILVER BOW RESORTS INC DBA FAIRMONT RV RESORT (406) 979-3505

**DANBRADSHAW27@ICLOUD.COM**

Dan Bashaw, UST Class A Operator

fairmontrvpark@aol.com

Dan Bashaw, UST Class B Global Operator

fairmontrvpark@aol.com

Joe Bashaw, UST Class A Operator

danbashaw27@icloud.com

Joe Bashaw, UST Class B Global Operator

danbashaw27@icloud.com

<b>Tank Code</b>	02	<b>Tank Age</b>	25	<b>Tank Installed Date</b>	04/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4187	<b>Spill Test Date</b>	11/11/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	3000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/11/2021			<b>ATG Type</b>					
<b>Tank Code</b>	03	<b>Tank Age</b>	25	<b>Tank Installed Date</b>	04/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4188	<b>Spill Test Date</b>	11/11/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	3000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/11/2021			<b>ATG Type</b>					

**Facility Summary in Deer Lodge County in the City of Anaconda**

**Location:** MAIN GRANULATED SLAG PILE - ANACONDA SMELTER  
 NPL SITE  
 6 mi west of I-90 on Hwy 1  
 Anaconda, MT 59711-9190 Deer Lodge

System Facility ID:12-10912

**Facility Code:** 19943  
**Last Inspected On:** 09/06/2022  
**Operating Permit Renewal Date:** 09/06/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** ARCO Environmental Remediation LLC (406) 782-9964

**Operator Contact:**

<b>Tank Code</b>	S1	<b>Tank Age</b>	40	<b>Tank Installed Date</b>	04/16/1985	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	
<b>Tag Number</b>	1836	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/19/2019	<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	25600	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	07/19/2019	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Deer Lodge County in the City of Anaconda**

**Location:** THRIFTWAY SUPER STOP 3  
1420 E Park Ave  
Anaconda, MT 59711-2766 Deer Lodge

System Facility ID:12-07938

**Facility Code:** 19928  
**Last Inspected On:** 01/31/2025  
**Operating Permit Renewal Date:** 06/12/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

**Operator Contact:** Linda Otonicar;Louis Sutey (406) 491-5808;(406) 494-2305 ldsutey66@thriftwayss.com;otonicarlinda@aol.com

**Owner/Operator:** Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Linda Otonicar, UST Class A Operator	otonicarlinda@aol.com
Louis Sutey, UST Class A Operator	ldsutey66@thriftwayss.com
Louis Sutey, UST Class B Global Operator	ldsutey66@thriftwayss.com
Patty Kline, UST Class B Operator	ldsutey66@thriftwayss.com
Theresa Weinman, UST Class B Operator	thriftway3@thriftwayss.com
Theresa Weinman, UST Class B Operator	thriftway3@thriftwayss.com

<b>Tank Code</b>	06	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	09/01/1990	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2048	<b>Spill Test Date</b>	01/30/2025	<b>Piping Installed Date</b>	10/04/2012	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/24/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/08/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	04/08/2024	<b>Line Tightness Test Date</b>	02/10/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/30/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	07	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	09/01/1990	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2049	<b>Spill Test Date</b>	01/30/2025	<b>Piping Installed Date</b>	10/04/2012	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/24/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/08/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No

<b>Capacity</b>	12000	<b>ATG Test Date</b>	04/08/2024	<b>Line Tightness Test Date</b>	02/10/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/30/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	08	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	09/01/1990	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2050	<b>Spill Test Date</b>	01/30/2025	<b>Piping Installed Date</b>	10/04/2012	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/24/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	04/08/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	04/08/2024	<b>Line Tightness Test Date</b>	02/10/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/30/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	09	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	09/01/1990	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2051	<b>Spill Test Date</b>	01/30/2025	<b>Piping Installed Date</b>	10/04/2012	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/24/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	04/08/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	04/08/2024	<b>Line Tightness Test Date</b>	02/10/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/30/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	10	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	09/01/1990	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2052	<b>Spill Test Date</b>	01/30/2025	<b>Piping Installed Date</b>	10/04/2012	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/24/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	04/08/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	04/08/2024	<b>Line Tightness Test Date</b>	02/10/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/30/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				

## Facility Summary in Deer Lodge County in the City of Anaconda

**Location:** THRIFTWAY SUPER STOP 7  
2035 W Park Ave  
Anaconda, MT 59711-1774 Deer Lodge

System Facility ID:12-00101

**Facility Code:** 19861  
**Last Inspected On:** 10/29/2024  
**Operating Permit Renewal Date:** 02/27/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

**Operator Contact:** Brian Clemons;Jack Hook;Linda Otonicar;Louis Sutey;Theodore Weinman (406) 491-5808;(406) 494-2305;(406) 560-3928;(406) 563-2410 ldsutey66@thriftwayss.com;otonicarlinda@aol.com;tweinman62@gmail.com;wolfenmist@aol.com

**Owner/Operator:** Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Allyn Moses, UST Class B Operator thriftway7@thriftwayss.com  
 Brian Clemons, UST Class A Operator wolfenmist@aol.com  
 Jack Hook, UST Class A Operator  
 Linda Otonicar, UST Class A Operator otonicarlinda@aol.com  
 Louis Sutey, UST Class A Operator ldsutey66@thriftwayss.com  
 Theodore Weinman, UST Class A Operator tweinman62@gmail.com  
 Toni Clemons, UST Class B Operator anacondacwolf59711@yahoo.com

<b>Tank Code</b>	02	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	07/01/1993	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2045	<b>Spill Test Date</b>	10/29/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	04/09/2024	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/14/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	04/09/2024	<b>Line Tightness Test Date</b>	04/09/2024	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/29/2024			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	04	<b>Tank Age</b>	54	<b>Tank Installed Date</b>	12/31/1971	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2046	<b>Spill Test Date</b>	10/29/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	04/09/2024	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/14/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No

<b>Capacity</b>	12000	<b>ATG Test Date</b>	04/09/2024	<b>Line Tightness Test Date</b>	04/09/2024	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/29/2024			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	05	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	07/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2047	<b>Spill Test Date</b>	10/29/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	04/09/2024	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/14/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	04/09/2024	<b>Line Tightness Test Date</b>	04/09/2024	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/29/2024			<b>ATG Type</b>	Gilbarco/EMC Basic				

## Facility Summary in Deer Lodge County in the City of Anaconda

**Location:** TOWN PUMP INC ANACONDA 1  
6940 MT Hwy 1 Ste A  
Anaconda, MT 59711 Deer Lodge

System Facility ID:12-09326

**Facility Code:** 19935  
**Last Inspected On:** 03/26/2025  
**Operating Permit Renewal Date:** 08/29/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Anaconda 1 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

**Operator Contact:** Trent Biggers

**Trentb@townpump.com**

**Owner/Operator:** Anaconda 1 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator  
Trent Biggers, UST Class B Global Operator

Trentb@townpump.com  
Trentb@townpump.com  
Trentb@townpump.com  
Trentb@townpump.com

<b>Tank Code</b>	05	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	05/01/1991	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2411	<b>Spill Test Date</b>	07/28/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	07/20/2022	<b>Tank/Piping CP Test Date</b>	05/05/2021	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	07/18/2023	<b>Line Tightness Test Date</b>	09/01/2005	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/28/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	06	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	05/01/1991	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2412	<b>Spill Test Date</b>	07/28/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/20/2022	<b>Tank/Piping CP Test Date</b>	05/05/2021	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No

<b>Capacity</b>	12000	<b>ATG Test Date</b>	07/18/2023	<b>Line Tightness Test Date</b>	09/01/2005	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/28/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	07	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	12/01/1994	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2413	<b>Spill Test Date</b>	10/01/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/20/2022	<b>Tank/Piping CP Test Date</b>	06/24/2014	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	07/18/2023	<b>Line Tightness Test Date</b>	09/01/2005	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/28/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	08	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	11/01/1994	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2414	<b>Spill Test Date</b>	07/28/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/20/2022	<b>Tank/Piping CP Test Date</b>	06/24/2014	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	07/18/2023	<b>Line Tightness Test Date</b>	09/01/2005	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/28/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	09	<b>Tank Age</b>	24	<b>Tank Installed Date</b>	07/01/2001	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4574	<b>Spill Test Date</b>	10/16/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	07/20/2022	<b>Tank/Piping CP Test Date</b>	05/05/2012	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	07/18/2023	<b>Line Tightness Test Date</b>	09/01/2005	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No



		<b>Overfill Test Date</b>	07/28/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	10	<b>Tank Age</b>	24	<b>Tank Installed Date</b>	07/01/2001	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4575	<b>Spill Test Date</b>	10/16/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	07/20/2022	<b>Tank/Piping CP Test Date</b>	05/05/2012	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	07/18/2023	<b>Line Tightness Test Date</b>	09/01/2005	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/28/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				

## Facility Summary in Deer Lodge County in the City of Anaconda

**Location:** TOWN PUMP INC ANACONDA 2  
819 W Park Ave  
Anaconda, MT 59711 Deer Lodge

System Facility ID:12-08668

**Facility Code:** 19933  
**Last Inspected On:** 03/26/2025  
**Operating Permit Renewal Date:** 02/06/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Anaconda 2 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

**Operator Contact:** Trent Biggers

**Trentb@townpump.com**

**Owner/Operator:** Anaconda 2 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

<b>Tank Code</b>	03	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	04/01/1991	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	2407	<b>Spill Test Date</b>	09/17/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	06/19/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	06/19/2023	<b>Line Tightness Test Date</b>	10/31/2006	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/17/2024			<b>ATG Type</b>	/TLS-450PLUS;Gilbarco-veeder Root/TLS-450PLUS				
<b>Tank Code</b>	04	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	04/01/1991	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	2408	<b>Spill Test Date</b>	09/17/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	06/19/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	06/19/2023	<b>Line Tightness Test Date</b>	10/31/2006	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	09/17/2024			<b>ATG Type</b>	/TLS-450PLUS;Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	05	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	04/01/1991	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	2409	<b>Spill Test Date</b>	09/17/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	06/19/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	06/19/2023	<b>Line Tightness Test Date</b>	10/31/2006	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/17/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	06	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	04/01/1991	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	2410	<b>Spill Test Date</b>	09/17/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	06/19/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	06/19/2023	<b>Line Tightness Test Date</b>	10/31/2006	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/17/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				

**Facility Summary in Deer Lodge County in the City of Warm Springs**

**Location:** XANTHOPOULOS BLDG  
2 C St  
Warm Springs, MT 59756 Deer Lodge

System Facility ID:12-07585

**Facility Code:** 19926  
**Last Inspected On:** 08/10/2023  
**Operating Permit Renewal Date:** 11/26/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Montana Dept of Corrections (406) 444-6551 JCHRISTOFFERSON@MT.GOV

**Operator Contact:** Suzann Podruzny;Montana Dept of Corrections (406) 444-6551 sue.chvilicek@mt.gov;JCHRISTOFFERSON@MT.GOV

**Owner/Operator:** Montana Dept of Corrections (406) 444-6551 JCHRISTOFFERSON@MT.GOV

Mark James, UST Class B Operator

JCHRISTOFFERSON@MT.GOV

Suzann Podruzny, UST Class A Operator

JCHRISTOFFERSON@MT.GOV

<b>Tank Code</b>	04	<b>Tank Age</b>	38	<b>Tank Installed Date</b>	01/01/1987	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	829	<b>Spill Test Date</b>	08/10/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/10/2023	<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.1	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	05/22/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/10/2023			<b>ATG Type</b>	Veeder Root/TLS-300				