

Facility Summary in Lewis and Clark County in the City of Augusta

Location: AUGUSTA GAS STATION LLC
130 Main St
Augusta, MT 59410 Lewis and Clark

System Facility ID:25-02114

Facility Code: 23462
Last Inspected On: 06/01/2023
Operating Permit Renewal Date: 08/22/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Augusta Service Station LLP (406) 562-3477 augustastation2017@gmail.com

Operator Contact: Susan Carlstrom (406) 562-3377 augustastation2017@gmail.com

Owner/Operator: Augusta Service Station LLP (406) 562-3477 augustastation2017@gmail.com

Susan Carlstrom, UST Class A Operator	augustastation2017@gmail.com
Susan Carlstrom, UST Class A Operator	augustastation2017@gmail.com
Susan Carlstrom, UST Class B Operator	augustastation2017@gmail.com
Susan Carlstrom, UST Class B Operator	augustastation2017@gmail.com

Tank Code	06	Tank Age	36	Tank Installed Date	06/06/1989	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3950	Spill Test Date	06/01/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/08/2008	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	1500	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/01/2022			ATG Type					
Tank Code	05	Tank Age	36	Tank Installed Date	06/06/1989	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3951	Spill Test Date	06/01/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/08/2008	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	750	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/01/2022			ATG Type					

Tank Code	04	Tank Age	36	Tank Installed Date	06/06/1989	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3952	Spill Test Date	06/01/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/08/2008	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	750	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/01/2022			ATG Type					

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB F 1
US Hwy 287
Augusta, MT 59410 Lewis and Clark

System Facility ID:50-09030

Facility Code: 28877
Last Inspected On: 05/16/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	01	Tank Age	63	Tank Installed Date	06/02/1962	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	303	Spill Test Date	05/16/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/16/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/08/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	11/06/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/06/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB F 5
 MT Hwy 21
 Augusta, MT 59410 Lewis and Clark

System Facility ID:25-09034

Facility Code: 23808
Last Inspected On: 04/01/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	05/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	247	Spill Test Date	04/01/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/01/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/01/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB F 6
 US Hwy 287
 Augusta, MT 59410 Lewis and Clark

System Facility ID:25-09035

Facility Code: 23809
Last Inspected On: 04/01/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	05/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	248	Spill Test Date	04/01/2024	Piping Installed Date	08/19/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/01/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/01/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB F 7
Road 434
Augusta, MT 59410 Lewis and Clark

System Facility ID:25-09036

Facility Code: 23810
Last Inspected On: 04/01/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	06/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	249	Spill Test Date	04/01/2024	Piping Installed Date	09/25/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/01/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/01/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB G 10
 US Hwy 287
 Augusta, MT 59410 Lewis and Clark

System Facility ID:25-09050

Facility Code: 23816
Last Inspected On: 04/17/2024
Operating Permit Renewal Date: 09/23/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	06/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	255	Spill Test Date	04/17/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/17/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/17/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/17/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Augusta

Location: MALMSTROM AFB G 9
US Hwy 287
Augusta, MT 59410 Lewis and Clark

System Facility ID:25-09049

Facility Code: 23815
Last Inspected On: 04/17/2024
Operating Permit Renewal Date: 09/23/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	34	Tank Installed Date	10/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	254	Spill Test Date	04/17/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/17/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/17/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/17/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of East Helena

Location: CANYON FERRY MINI BASKET
3012 Canyon Ferry Rd
East Helena, MT 59635-3025 Lewis and Clark

System Facility ID:25-03122

Facility Code: 23511
Last Inspected On: 09/20/2023
Operating Permit Renewal Date: 05/25/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Big Sky Food and Fuel Inc Helena;Robert Merzlak (406) 443-3608 Minibasket@live.com;Rob&Traci@msn.com

Operator Contact: Rob Merzlak;Big Sky Food and Fuel Inc Helena;Robert Merzlak (406) 443-3608 Minibasket@live.com;Minibasket@live.com;Rob&Traci@msn.com

Owner/Operator: Big Sky Food and Fuel Inc Helena (406) 443-3608 Rob&Traci@msn.com

Owner/Operator: Robert J Merzlak (406) 443-3608 Rob&Traci@msn.com

Rob Merzlak, UST Class A Operator Rob&Traci@msn.com
Rob Merzlak, UST Class B Operator Rob&Traci@msn.com
Robert J Merzlak, UST Class A Operator Minibasket@live.com
Robert J Merzlak, UST Class B Global Operator Minibasket@live.com
Robert J Merzlak, UST Class B Operator Minibasket@live.com

Tank Code	01	Tank Age	31	Tank Installed Date	06/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2319	Spill Test Date	01/24/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/25/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	01/24/2022	Line Tightness Test Date	03/30/2006	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	02/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	04	Tank Age	18	Tank Installed Date	10/16/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5151	Spill Test Date	05/25/2023	Piping Installed Date	05/23/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/24/2021	Sump Tightness Test Date	05/25/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	5000	ATG Test Date	05/25/2023	Line Tightness Test Date	01/24/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/25/2023			ATG Type	Franklin Fueling Systems/EVO 6000				
Tank Code	05	Tank Age	18	Tank Installed Date	10/16/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5152	Spill Test Date	05/25/2023	Piping Installed Date	05/23/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/25/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	05/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/25/2023			ATG Type					
Tank Code	06	Tank Age	2	Tank Installed Date	05/23/2023	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6153	Spill Test Date	05/25/2023	Piping Installed Date	05/23/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/25/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	05/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/25/2023			ATG Type					
Tank Code	07	Tank Age	2	Tank Installed Date	05/23/2023	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6154	Spill Test Date	05/25/2023	Piping Installed Date	05/23/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/25/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/25/2023			ATG Type					

Facility Summary in Lewis and Clark County in the City of East Helena

Location: TOWN PUMP EAST HELENA 1
3680 East Hwy 12
East Helena, MT 59635 Lewis and Clark

System Facility ID:00-32557

Facility Code: 32557
Last Inspected On: 03/24/2025
Operating Permit Renewal Date: 11/19/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: EAST HELENA 1 RE2 LLC (406) 497-6700

Operator Contact: Trent Biggers;Town Pump

Trentb@townpump.com;environmental@townpump.com

Owner/Operator: EAST HELENA 1 RE2 LLC (406) 497-6700

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Operator

environmental@townpump.com
environmental@townpump.com

Tank Code	01	Tank Age	2	Tank Installed Date	11/02/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6201	Spill Test Date	07/17/2024	Piping Installed Date	09/12/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/17/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	10/24/2024	Line Tightness Test Date	11/12/2024	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/17/2024			ATG Type					
Tank Code	02	Tank Age	2	Tank Installed Date	11/02/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6202	Spill Test Date	07/17/2024	Piping Installed Date	09/12/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/17/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	10/24/2024	Line Tightness Test Date	11/12/2024	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/17/2024			ATG Type					
Tank Code	03	Tank Age	2	Tank Installed Date	11/02/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	6203	Spill Test Date	07/17/2024	Piping Installed Date	09/12/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/17/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	10/24/2024	Line Tightness Test Date	11/12/2024	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/17/2024			ATG Type					
Tank Code	04	Tank Age	2	Tank Installed Date	11/02/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6204	Spill Test Date	07/17/2024	Piping Installed Date	09/12/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/17/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	10/24/2024	Line Tightness Test Date	11/12/2024	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/17/2024			ATG Type					
Tank Code	05	Tank Age	2	Tank Installed Date	11/02/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6205	Spill Test Date	07/17/2024	Piping Installed Date	09/12/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	10/24/2024	Line Tightness Test Date	11/12/2024	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/17/2024			ATG Type					
Tank Code	06	Tank Age	2	Tank Installed Date	11/02/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6206	Spill Test Date	07/17/2024	Piping Installed Date	09/12/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/17/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	10000	ATG Test Date	10/24/2024	Line Tightness Test Date	11/12/2024	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/17/2024			ATG Type					
Tank Code	07	Tank Age	2	Tank Installed Date	11/02/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6207	Spill Test Date	07/17/2024	Piping Installed Date	09/12/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/17/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	10/24/2024	Line Tightness Test Date	11/12/2024	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/17/2024			ATG Type					
Tank Code	08	Tank Age	2	Tank Installed Date	11/02/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6208	Spill Test Date		Piping Installed Date	09/12/2024	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	09	Tank Age	2	Tank Installed Date	11/02/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6276	Spill Test Date	07/17/2024	Piping Installed Date	09/12/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/17/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline, E85	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	10/24/2024	Line Tightness Test Date	11/12/2024	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/17/2024			ATG Type					

Facility Summary in Lewis and Clark County in the City of East Helena

Location: TOWN PUMP EAST HELENA 2
116 S Lane Ave
East Helena, MT 59635 Lewis and Clark

System Facility ID:56-13915

Facility Code: 30585
Last Inspected On: 03/20/2025
Operating Permit Renewal Date: 07/29/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: East Helena 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: East Helena 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	01	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4028	Spill Test Date	06/04/2021	Piping Installed Date	06/12/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/18/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/20/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	06/04/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4029	Spill Test Date	06/04/2021	Piping Installed Date	06/12/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/18/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/20/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No

		Overfill Test Date	06/04/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4030	Spill Test Date	10/09/2024	Piping Installed Date	06/12/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/18/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	06/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/20/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	01/18/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4031	Spill Test Date	06/04/2021	Piping Installed Date	06/12/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/18/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/20/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	06/04/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4032	Spill Test Date	06/04/2021	Piping Installed Date	06/12/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/18/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/20/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No

		Overfill Test Date	06/04/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	26	Tank Installed Date	03/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4033	Spill Test Date	06/04/2021	Piping Installed Date	06/12/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/18/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/20/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	06/04/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	22	Tank Installed Date	08/18/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4861	Spill Test Date	06/04/2021	Piping Installed Date	06/12/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/18/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/20/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	06/04/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Lewis and Clark County in the City of East Helena

Location: TOWN PUMP INC EAST HELENA
418 W Main St
East Helena, MT 59635 Lewis and Clark

System Facility ID:25-08697

Facility Code: 23791
Last Inspected On: 07/22/2022
Operating Permit Renewal Date: 07/25/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: East Helena 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator
Trent Biggers, UST Class B Global Operator

Trentb@townpump.com
Trentb@townpump.com
Trentb@townpump.com
Trentb@townpump.com

Tank Code	01	Tank Age	57	Tank Installed Date	04/14/1968	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4672	Spill Test Date	08/11/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/25/2022	Tank/Piping CP Test Date	06/04/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	24000	ATG Test Date	05/25/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/11/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	57	Tank Installed Date	04/14/1968	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4673	Spill Test Date	08/11/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/25/2022	Tank/Piping CP Test Date	06/04/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	24000	ATG Test Date	05/25/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	08/11/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	57	Tank Installed Date	04/14/1968	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4674	Spill Test Date	08/11/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	08/28/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/25/2022	Tank/Piping CP Test Date	06/04/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	16000	ATG Test Date	05/25/2022	Line Tightness Test Date	08/28/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/21/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	57	Tank Installed Date	04/14/1968	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4675	Spill Test Date	08/11/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	05/25/2022	Tank/Piping CP Test Date	06/04/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/25/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/11/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	57	Tank Installed Date	04/14/1968	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4676	Spill Test Date	08/11/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	05/25/2022	Tank/Piping CP Test Date	06/04/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/25/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/11/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	48	Tank Installed Date	04/14/1977	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve

Tag Number	4677	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	05/25/2022	Tank/Piping CP Test Date	06/04/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/25/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/11/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	48	Tank Installed Date	04/14/1977	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4678	Spill Test Date	08/11/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/25/2022	Tank/Piping CP Test Date	06/04/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/25/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/11/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Fort Harrison

Location: VETERANS HEALTH ADMINISTRATION
3687 Veterans Dr Bldg 141
Fort Harrison, MT 59636 Lewis and Clark

System Facility ID:25-05908

Facility Code: 23656
Last Inspected On: 11/14/2023
Operating Permit Renewal Date: 02/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: US Dept of Veterans Affairs

Operator Contact: Gregory Riccaldo; Josiah Walker; Veterans Administration

(406) 594-8112; (406) 442-6410

gregory.riccaldo@va.gov; Josiah.Walker@va.gov

Owner/Operator: US Dept of Veterans Affairs

Gregory Riccaldo, UST Class A Operator
Josiah Walker, UST Class A Operator
Josiah Walker, UST Class B Operator

gregory.riccaldo@va.gov
Josiah.Walker@va.gov
Josiah.Walker@va.gov

Tank Code	08	Tank Age	32	Tank Installed Date	12/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2214	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	32	Tank Installed Date	12/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2216	Spill Test Date	08/21/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/08/2024	Line Tightness Test Date	08/14/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	04/08/2024			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	13	Tank Age	15	Tank Installed Date	10/01/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5278	Spill Test Date	08/21/2020	Piping Installed Date	04/26/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/21/2020	Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	08/14/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	3-Year Line Tightness Test	Energy Act	Yes
		Overfill Test Date	08/13/2020			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	14	Tank Age	13	Tank Installed Date	05/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5366	Spill Test Date	08/21/2020	Piping Installed Date	05/01/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/21/2020	Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/13/2020	Line Tightness Test Date	08/14/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	3-Year Line Tightness Test	Energy Act	Yes
		Overfill Test Date	08/13/2020			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				

Facility Summary in Lewis and Clark County in the City of Helena

Location: ARMY AVIATION SUPPORT FACILITY
3333 Skyway Dr
Helena, MT 59602 Lewis and Clark

System Facility ID:56-13821

Facility Code: 30507
Last Inspected On: 07/09/2024
Operating Permit Renewal Date: 07/17/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: US Dept of Military Affairs Helena (406) 324-3000 adel.m.johnson.mil@mail.mil

Operator Contact: Elizka McFetridge;Guthrie Oiestad;Matthew Kent;US Dept of Military Affairs Helena;Thad Waples (361) 249-5454;(406) 324-3000 matthew.kent10.nfg@army.mil;adel.m.johnson.mil@mail.mil;oiestadg@gmail.com;thad.waples@us.army.mil

Owner/Operator: US Dept of Military Affairs Helena (406) 324-3000 adel.m.johnson.mil@mail.mil

Aaron Linz, UST Class B Global Operator
Elizka McFetridge, UST Class A Operator
Elizka McFetridge, UST Class B Operator
Guthrie Oiestad, UST Class A Operator
Matthew Kent, UST Class A Operator
Matthew Kent, UST Class B Operator
Michael Bramhall, UST Class B Operator
Rylee Gannon, UST Class B Operator
Thad Waples, UST Class A Operator
Victoria Stipcich, UST Class B Operator

oiestadg@gmail.com
adel.m.johnson.mil@mail.mil
adel.m.johnson.mil@mail.mil
michaeljbramhall323@gmail.com
ryleeratd@hotmail.com
thad.waples@us.army.mil
vstipcich1@gmail.com

Tank Code	01	Tank Age	28	Tank Installed Date	03/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	827	Spill Test Date	07/09/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	25000	ATG Test Date	07/09/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/09/2024			ATG Type	Gilbarco-Veeder Root/Other				
Tank Code	02	Tank Age	28	Tank Installed Date	03/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	Flapper Valve;High Level Alarm

Tag Number	828	Spill Test Date	07/09/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	25000	ATG Test Date	07/09/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/09/2024			ATG Type	Gilbarco-Veeder Root/Other				

Facility Summary in Lewis and Clark County in the City of Helena

Location: BOBS VALLEY SERVICE INC UST
7507 N Montana Ave
Helena, MT 59602-9389 Lewis and Clark

System Facility ID:25-07404

Facility Code: 23734
Last Inspected On: 11/07/2023
Operating Permit Renewal Date: 03/26/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bobs Valley Market

(406) 458-5140

steve@montanavalleyhams.com

Operator Contact: Dylan Pizzini

Owner/Operator: Bobs Valley Market

(406) 458-5140

steve@montanavalleyhams.com

Craig Sprankle, UST Class B Operator
Craig Sprankle, UST Class B Operator
Dylan Pizzini, UST Class A Operator
Dylan Pizzini, UST Class A Operator
Dylan Pizzini, UST Class B Global Operator
Dylan Pizzini, UST Class B Global Operator
Stephen Bartmess, UST Class B Global Operator
Stephen Bartmess, UST Class B Global Operator
Steve Nummerdor, UST Class B Global Operator
Steve Nummerdor, UST Class B Global Operator

cls66@live.com
cls66@live.com

steve@montanavalleyhams.com
steve@montanavalleyhams.com
steve@montanavalleyhams.com
steve@montanavalleyhams.com

Tank Code	05	Tank Age	37	Tank Installed Date	03/27/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	474	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	37	Tank Installed Date	03/27/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	475	Spill Test Date	10/06/2021	Piping Installed Date	05/14/2011	Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	09/06/2023	Tank/Piping CP Test Date	11/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	09/06/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/07/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	33	Tank Installed Date	06/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	476	Spill Test Date	10/06/2021	Piping Installed Date	05/14/2011	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	09/06/2023	Tank/Piping CP Test Date	11/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	09/06/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/07/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	27	Tank Installed Date	11/15/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	477	Spill Test Date	04/08/2022	Piping Installed Date	05/14/2011	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	09/06/2023	Tank/Piping CP Test Date	11/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	09/06/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/29/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: CEDAR STREET CONOCO
1701 Cedar St
Helena, MT 59601-1109 Lewis and Clark

System Facility ID:25-03466

Facility Code: 23531
Last Inspected On: 04/01/2024
Operating Permit Renewal Date: 06/11/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cedar Street Conoco;Michael Salois (406) 495-0953 Gabes.7.Store@gmail.com

Operator Contact: Michael Salois mike.salois416@gmail.com

Owner/Operator: Cedar Street Conoco (406) 495-0953 Gabes.7.Store@gmail.com

Owner/Operator: Michael J Salois (406) 495-0953 Gabes.7.Store@gmail.com

Daren Griffeth, UST Class B Operator luckyme6719@gmail.com
Daren Griffeth, UST Class B Operator luckyme6719@gmail.com
Michael Salois, UST Class A Operator mike.salois416@gmail.com
Michael Salois, UST Class A Operator mike.salois416@gmail.com

Tank Code	05	Tank Age	27	Tank Installed Date	09/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2228	Spill Test Date	04/01/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	04/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/01/2024			ATG Type	Veeder Root/TLS-350				
Tank Code	06	Tank Age	27	Tank Installed Date	09/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2229	Spill Test Date	04/01/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	04/01/2024			ATG Type	Veeder Root/TLS-350				
Tank Code	07	Tank Age	27	Tank Installed Date	09/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2230	Spill Test Date	04/01/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/01/2024			ATG Type	Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Helena

Location: CIRCLE K STORE 2746270
401 Euclid Ave
Helena, MT 59601 Lewis and Clark

System Facility ID:25-08067

Facility Code: 23766
Last Inspected On: 06/06/2023
Operating Permit Renewal Date: 09/09/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Operator Contact: Veronica Rivera ESS-WestCoast@circlek.com

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Julie Cordie, UST Class B Operator
Veronica Rivera, UST Class A Operator

brad.lee@holidaycompanies.com
jeff.reed@holidaycompanies.com
NT-ESS@Circlek.com
ESS-WestCoast@circlek.com

Tank Code	01	Tank Age	38	Tank Installed Date	05/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	3017	Spill Test Date	06/03/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/03/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/01/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date		Line Tightness Test Date	05/23/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	38	Tank Installed Date	05/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	3018	Spill Test Date	06/03/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/03/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/01/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	10000	ATG Test Date		Line Tightness Test Date	06/02/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	38	Tank Installed Date	11/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	3019	Spill Test Date	06/03/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/03/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/01/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/23/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	38	Tank Installed Date	11/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	3020	Spill Test Date	06/03/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/03/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/01/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/23/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: CIRCLE K STORE 2746723
606 N Fee St
Helena, MT 59601-3148 Lewis and Clark

System Facility ID:56-13956

Facility Code: 30624
Last Inspected On: 11/06/2018
Operating Permit Renewal Date: 03/30/2022

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil Co Inc	(602) 728-8000	vrivera1@circlek.com
Operator Contact: Chuck Nyberg;Kegan Krueger;Patrick Patnaude;Robert Deninno;Stephen Reckinger;Valeria Jeffries;Veronica Rivera	(406) 321-0938;(952) 830-8028;(952) 830-8721;(952) 830-8722	ESS-WestCoast@circlek.com;kegan.krueger@holidaycompanies.com;patrick.patnaude@holidaycompanies.com;steve.reckinger@holidaycompanies.com;valeria.jeffries@holidaycompanies.com

- | | |
|--|---------------------------------------|
| Brad Lee, UST Class B Global Operator | brad.lee@holidaycompanies.com |
| Chuck Nyberg, UST Class A Operator | |
| Craig Hagmeier, UST Class B Operator | s02008.fir@albertsons.com |
| Cynthia Hellwitz, UST Class B Operator | chellwitz@yahoo.com |
| Julie Cordie, UST Class B Global Operator | tigger2_4u@yahoo.com |
| Kegan Krueger, UST Class A Operator | kegan.krueger@holidaycompanies.com |
| Patrick Patnaude, UST Class A Operator | patrick.patnaude@holidaycompanies.com |
| Robert Deninno, UST Class A Operator | |
| Ryan Coey, UST Class B Operator | s02004.adir@albertsons.com |
| Stephen Reckinger, UST Class A Operator | steve.reckinger@holidaycompanies.com |
| Stephen Reckinger, UST Class B Global Operator | steve.reckinger@holidaycompanies.com |
| Todd White, UST Class B Global Operator | todd.white@holidaycompanies.com |
| Valeria Jeffries, UST Class A Operator | valeria.jeffries@holidaycompanies.com |
| Veronica Rivera, UST Class A Operator | ESS-WestCoast@circlek.com |
| Veronica Rivera, UST Class B Global Operator | ESS-WestCoast@circlek.com |

Tank Code	01	Tank Age	26	Tank Installed Date	10/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	4128	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date	09/05/2018	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date			ATG Type	Veeder Root/TLS-450					
Tank Code	02	Tank Age	26	Tank Installed Date	10/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	4129	Spill Test Date	04/25/2019	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	04/23/2018	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-450				

Facility Summary in Lewis and Clark County in the City of Helena

Location: COMBINED CRIMINAL JUSTICE FACILITY
221 Breckenridge St
Helena, MT 59601-4230 Lewis and Clark

System Facility ID:25-00945

Facility Code: 23395
Last Inspected On: 09/06/2024
Operating Permit Renewal Date: 08/15/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lewis and Clark County Jail (406) 447-8299

Operator Contact: Robert McCarley (406) 447-8299

Owner/Operator: Lewis and Clark County Jail (406) 447-8299

Robert McCarley, UST Class A Operator
Robert McCarley, UST Class B Global Operator

Tank Code	01	Tank Age	40	Tank Installed Date	04/21/1985	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4060	Spill Test Date	09/06/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/06/2024	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/06/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	3000	ATG Test Date	09/06/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/06/2024			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Lewis and Clark County in the City of Helena

Location: COSTCO GASOLINE 633
2195 E Custer Ave
Helena, MT 59602 Lewis and Clark

System Facility ID:60-15051

Facility Code: 30825
Last Inspected On: 12/12/2022
Operating Permit Renewal Date: 02/24/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Costco Wholesale (425) 251-6222 gaslicenses@costco.com

Operator Contact: Andrew Erdahl;Daniel Manibusan;Patty Vaughan;Costco Wholesale Corporation Seattle (406) 495-7042;(406) 652-8765;(425) 313-8100 w633gas@costco.com;w633gas@costco.com;gaslicenses@costco.com

Owner/Operator: Costco Wholesale (425) 251-6222 gaslicenses@costco.com

- Andrew Erdahl, UST Class A Operator w633gas@costco.com
- Andrew Erdahl, UST Class B Global Operator w633gas@costco.com
- Andrew Erdahl, UST Class B Operator w633gas@costco.com
- Daniel Manibusan, UST Class A Operator w633gas@costco.com
- Daniel Manibusan, UST Class B Operator w633gas@costco.com
- Patty Vaughan, UST Class A Operator gaslicenses@costco.com
- Patty Vaughan, UST Class B Operator gaslicenses@costco.com

Tank Code	01	Tank Age	19	Tank Installed Date	10/05/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5095	Spill Test Date	04/22/2024	Piping Installed Date	08/23/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/22/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/06/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	30000	ATG Test Date	10/06/2022	Line Tightness Test Date	10/06/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	19	Tank Installed Date	10/05/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5096	Spill Test Date	04/22/2024	Piping Installed Date	08/23/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/22/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	10/06/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	30000	ATG Test Date	10/06/2022	Line Tightness Test Date	10/06/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	19	Tank Installed Date	10/05/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5097	Spill Test Date	04/22/2024	Piping Installed Date	08/23/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/22/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/06/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	30000	ATG Test Date	10/06/2022	Line Tightness Test Date	10/06/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	14	Tank Installed Date	04/12/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5281	Spill Test Date	04/22/2024	Piping Installed Date	10/25/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/06/2022	Sump Tightness Test Date	04/22/2024	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1500	ATG Test Date	10/06/2022	Line Tightness Test Date	11/13/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	Yes
		Overfill Test Date	04/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Helena

Location: DAVES EXPRESS LUBE
4990 N Montana Ave
Helena, MT 59602-7268 Lewis and Clark

System Facility ID:56-13828

Facility Code: 30514
Last Inspected On: 03/31/2022
Operating Permit Renewal Date: 07/27/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Dave's Express Lube Inc (406) 449-9667

Operator Contact: Dave Clemens (406) 449-9667 dcirocz@aol.com

Owner/Operator: Dave's Express Lube Inc (406) 449-9667

Dave Clemens, UST Class A Operator
Dave Clemens, UST Class B Operator

dcirocz@aol.com
dcirocz@aol.com

Tank Code	01	Tank Age	27	Tank Installed Date	01/30/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	372	Spill Test Date	03/31/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/13/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/13/2024			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	02	Tank Age	27	Tank Installed Date	01/30/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	373	Spill Test Date	03/31/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/13/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/13/2024			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	03	Tank Age	27	Tank Installed Date	01/30/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve

Tag Number	374	Spill Test Date	03/31/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/13/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/13/2024			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	04	Tank Age	27	Tank Installed Date	01/30/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	375	Spill Test Date	03/31/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/13/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/13/2024			ATG Type	Franklin Fueling Systems/EVO 600				

Facility Summary in Lewis and Clark County in the City of Helena

Location: EXEC AIR MONTANA INC 1
2430 Airport Rd
Helena, MT 59601-1234 Lewis and Clark

System Facility ID:25-00642

Facility Code: 23382
Last Inspected On: 12/06/2023
Operating Permit Renewal Date: 04/14/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Exec Air Montana Inc

(406) 442-2190

adam_weitz@execairmontana.com

Operator Contact:

Owner/Operator: Exec Air Montana Inc

(406) 442-2190

adam_weitz@execairmontana.com

Tank Code	05	Tank Age	34	Tank Installed Date	06/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	3344	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Galvanic
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date	12/06/2023	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	04/11/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/11/2024			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	06	Tank Age	34	Tank Installed Date	06/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	3345	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	12/06/2023	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	04/11/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/11/2024			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	07	Tank Age	8	Tank Installed Date	09/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	High Level Alarm

Tag Number	5765	Spill Test Date		Piping Installed Date	09/10/2017	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	12/06/2023	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	30000	ATG Test Date	04/11/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	04/11/2024			ATG Type	Franklin Fueling Systems/EVO 600; Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: EXEC AIR MONTANA INC 2
2430 Airport Rd
Helena, MT 59601-1234 Lewis and Clark

System Facility ID:25-02123

Facility Code: 23464
Last Inspected On: 04/11/2016
Operating Permit Renewal Date: 07/09/2018

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Exec Air Montana Inc (406) 442-2190 adam_weitz@execairmontana.com

Operator Contact: John Maxness (406) 449-9337 john@execairmontana.com

John Maxness, UST Class A Operator

john@execairmontana.com

John Maxness, UST Class B Global Operator

john@execairmontana.com

Tank Code	01	Tank Age	59	Tank Installed Date	04/01/1966	Tank Material	Bare Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	3646	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	09/11/2013	Primary Tank Leak Detection	Vapor Monitoring	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	59	Tank Installed Date	04/01/1966	Tank Material	Bare Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	3647	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	09/11/2013	Primary Tank Leak Detection	Vapor Monitoring	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	03	Tank Age	59	Tank Installed Date	04/01/1966	Tank Material	Bare Steel	Piping Material	No Piping	Overfill Types	High Level Alarm

Tag Number	3648	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/11/2013	Primary Tank Leak Detection	Vapor Monitoring	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	04	Tank Age	59	Tank Installed Date	04/01/1966	Tank Material	Bare Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	3649	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/11/2013	Primary Tank Leak Detection	Vapor Monitoring	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Lewis and Clark County in the City of Helena

Location: EXEC AIR SELF SERVICE
3122 Airport Rd
Helena, MT 59601 Lewis and Clark

System Facility ID:25-12834

Facility Code: 23905
Last Inspected On: 07/14/2023
Operating Permit Renewal Date: 08/19/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: LEADING EDGE MONTANA DBA EXEC AIR MONTANA (406) 442-2190 adam_weitz@execairmontana.com

Operator Contact: Adam Weitz;Exec Air Montana Inc (406) 442-2190;(406) 442-2190 adam_weitz@execairmontana.com;adam_weitz@execairmontana.com

Owner/Operator: LEADING EDGE MONTANA DBA EXEC AIR MONTANA (406) 442-2190 adam_weitz@execairmontana.com

Adam Weitz, UST Class A Operator

adam_weitz@execairmontana.com

Adam Weitz, UST Class B Operator

adam_weitz@execairmontana.com

Tank Code	01	Tank Age	33	Tank Installed Date	09/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4444	Spill Test Date	05/18/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/18/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/10/2023	Line Tightness Test Date	05/18/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/18/2020			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Helena

Location: FEDERAL RESERVE BANK HELENA
100 Neill Ave
Helena, MT 59601-3329 Lewis and Clark

System Facility ID:25-11291

Facility Code: 23861
Last Inspected On: 11/20/2024
Operating Permit Renewal Date: 01/09/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Federal Reserve Bank (406) 447-3919 chris.bruski@mpls.frb.org

Operator Contact: Timothy Leonard (406) 447-3946 tim.leonard@mpls.frb.org

Owner/Operator: Federal Reserve Bank (406) 447-3919 chris.bruski@mpls.frb.org
Timothy Leonard, UST Class A Operator tim.leonard@mpls.frb.org
Timothy Leonard, UST Class B Operator tim.leonard@mpls.frb.org

Tank Code	S1	Tank Age	36	Tank Installed Date	10/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2322	Spill Test Date		Piping Installed Date	12/02/2002	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	10/17/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/17/2023	Line Tightness Test Date	05/01/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/17/2023			ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	01	Tank Age	1	Tank Installed Date	06/18/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Steel with plastic coating	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6240	Spill Test Date	06/28/2024	Piping Installed Date	06/18/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/28/2024	Catastrophic L.D Type 3.0		Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/28/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Approved Remote Monitoring	Energy Act	Yes
		Overfill Test Date	06/28/2024			ATG Type					

Facility Summary in Lewis and Clark County in the City of Helena

Location: FRIENDLYS SINCLAIR
1831 11th Ave
Helena, MT 59601-4769 Lewis and Clark

System Facility ID:25-01314

Facility Code: 23408
Last Inspected On: 04/17/2023
Operating Permit Renewal Date: 07/26/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Friendlys Inc (406) 442-4865 friendlys03@gmail.com

Operator Contact: Barbara Leland;Edward Dimock (406) 442-4865 barb640@hotmail.com;Lamond1329@aol.com

Owner/Operator: Friendlys Inc (406) 442-4865 friendlys03@gmail.com

- | | |
|--------------------------------------|-----------------------|
| Barbara Leland, UST Class A Operator | barb640@hotmail.com |
| Barbara Leland, UST Class A Operator | barb640@hotmail.com |
| Edward Dimock, UST Class A Operator | Lamond1329@aol.com |
| Edward Dimock, UST Class A Operator | Lamond1329@aol.com |
| Edward Dimock, UST Class B Operator | Lamond1329@aol.com |
| Edward Dimock, UST Class B Operator | Lamond1329@aol.com |
| Scott Leland, UST Class B Operator | friendlys03@gmail.com |

Tank Code	05	Tank Age	23	Tank Installed Date	01/02/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4611	Spill Test Date	06/22/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/17/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/17/2023	Line Tightness Test Date	04/17/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/07/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	06	Tank Age	23	Tank Installed Date	01/02/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4612	Spill Test Date	09/22/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/17/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No

Capacity	12000	ATG Test Date	04/17/2023	Line Tightness Test Date	04/17/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/07/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	07	Tank Age	23	Tank Installed Date	01/02/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve; Flapper Valve
Tag Number	4613	Spill Test Date	09/22/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/17/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	04/17/2023	Line Tightness Test Date	04/17/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/07/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Lewis and Clark County in the City of Helena

Location: GATES OF THE MOUNTAINS INC
3106 Gates of The Mountains Rd
Helena, MT 59604-4478 Lewis and Clark

System Facility ID:25-06619

Facility Code: 23697
Last Inspected On: 11/12/2024
Operating Permit Renewal Date: 04/30/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Gates of The Mountains Inc (406) 458-5241

Operator Contact: Brian Zimmerman;Melissa Zimmerman info@gatesofthemountains.com;tugcapt78@gmail.com

Owner/Operator: Gates of The Mountains Inc (406) 458-5241

Brian Zimmerman, UST Class A Operator
Brian Zimmerman, UST Class B Global Operator
Melissa Zimmerman, UST Class A Operator
Melissa Zimmerman, UST Class B Operator

tugcapt78@gmail.com
tugcapt78@gmail.com
info@gatesofthemountains.com
info@gatesofthemountains.com

Tank Code	03	Tank Age	39	Tank Installed Date	04/29/1986	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1202	Spill Test Date	04/30/2024	Piping Installed Date	03/12/2007	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/30/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/12/2024	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	04/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/30/2024			ATG Type					
Tank Code	04	Tank Age	39	Tank Installed Date	04/29/1986	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1203	Spill Test Date	04/30/2024	Piping Installed Date	03/12/2007	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/30/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/12/2024	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date	04/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/30/2024			ATG Type					

Facility Summary in Lewis and Clark County in the City of Helena

Location: GREEN MEADOW MARKET
3300 Green Meadow Dr
Helena, MT 59602-7707 Lewis and Clark

System Facility ID:25-05688

Facility Code: 23648
Last Inspected On: 04/27/2022
Operating Permit Renewal Date: 08/13/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: JTA Inc (406) 442-7095 jayrule62@gmail.com

Operator Contact: John Rule;Todd Adams (406) 442-7095 jayrule62@gmail.com

Owner/Operator: JTA Inc (406) 442-7095 jayrule62@gmail.com

John Rule, UST Class A Operator jayrule62@gmail.com
John Rule, UST Class B Global Operator jayrule62@gmail.com
Todd Adams, UST Class A Operator jayrule62@gmail.com
Todd Adams, UST Class A Operator

Tank Code	01	Tank Age	46	Tank Installed Date	10/01/1979	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3243	Spill Test Date	11/06/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/06/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/27/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	11/06/2024	Line Tightness Test Date	11/06/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/06/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	46	Tank Installed Date	10/01/1979	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3244	Spill Test Date	11/06/2024	Piping Installed Date	08/08/2007	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/06/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/27/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/06/2024	Line Tightness Test Date	11/06/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/06/2024			ATG Type	Gilbarco/EMC Basic				

Tank Code	03	Tank Age	18	Tank Installed Date	08/08/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5135	Spill Test Date	11/06/2024	Piping Installed Date	08/08/2007	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/06/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/27/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	11/06/2024	Line Tightness Test Date	11/06/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/06/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	18	Tank Installed Date	08/08/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5136	Spill Test Date	11/06/2024	Piping Installed Date	08/08/2007	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/06/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	04/27/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	7000	ATG Test Date	11/06/2024	Line Tightness Test Date	11/06/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/06/2024			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Lewis and Clark County in the City of Helena

Location: HELENA MAIN CENTRAL OFFICE
441 N Park Ave
Helena, MT 59601-5020 Lewis and Clark

System Facility ID:25-08775

Facility Code: 23796
Last Inspected On: 04/24/2023
Operating Permit Renewal Date: 10/18/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Qwest Corporation/Century Link

kevin.robison@centurylink.com

Operator Contact: Stephanie Miller

(501) 680-8141

Stephanie.miller@lumen.com

Owner/Operator: Qwest Corporation/Century Link

kevin.robison@centurylink.com

Stephanie Miller, UST Class A Operator

Stephanie.miller@lumen.com

Stephanie Miller, UST Class B Global Operator

Stephanie.miller@lumen.com

Tank Code	02	Tank Age	33	Tank Installed Date	01/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1728	Spill Test Date	04/24/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	2500	ATG Test Date	04/24/2023	Line Tightness Test Date	02/27/2023	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/24/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Lewis and Clark County in the City of Helena

Location: HELENA SERVICE CENTER
1315 N Last Chance Gulch
Helena, MT 59601-2909 Lewis and Clark

System Facility ID:25-01183

Facility Code: 23405
Last Inspected On: 03/02/2023
Operating Permit Renewal Date: 08/12/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Northwestern Energy Butte (406) 655-2521 beth.stimatz@northwestern.com

Operator Contact: Brian Ranf;John Habeger;Kellen Gilreath;Phil Hatfield (406) 239-0025;(406) 443-8951 brian.ranf@northwestern.com;Grimacepch@aol.com;john.habeger@northwestern.com;kellenjgilreath@yahoo.com

Owner/Operator: Northwestern Energy Butte (406) 655-2521 beth.stimatz@northwestern.com

- | | |
|--|-------------------------------|
| Brian Ranf, UST Class A Operator | brian.ranf@northwestern.com |
| John Habeger, UST Class A Operator | john.habeger@northwestern.com |
| John Habeger, UST Class A Operator | john.habeger@northwestern.com |
| John Habeger, UST Class A Operator | john.habeger@northwestern.com |
| Kellen Gilreath, UST Class A Operator | kellenjgilreath@yahoo.com |
| Kellen Gilreath, UST Class A Operator | kellenjgilreath@yahoo.com |
| Kellen Gilreath, UST Class A Operator | kellenjgilreath@yahoo.com |
| Kellen Gilreath, UST Class B Global Operator | kellenjgilreath@yahoo.com |
| Kellen Gilreath, UST Class B Global Operator | kellenjgilreath@yahoo.com |
| Kellen Gilreath, UST Class B Global Operator | kellenjgilreath@yahoo.com |
| Phil Hatfield, UST Class A Operator | Grimacepch@aol.com |
| Phil Hatfield, UST Class A Operator | Grimacepch@aol.com |
| Phil Hatfield, UST Class A Operator | Grimacepch@aol.com |
| Phil Hatfield, UST Class B Global Operator | Grimacepch@aol.com |
| Phil Hatfield, UST Class B Global Operator | Grimacepch@aol.com |
| Phil Hatfield, UST Class B Global Operator | Grimacepch@aol.com |

Tank Code	04	Tank Age	27	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1678	Spill Test Date	09/17/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/08/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	09/17/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	27	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1679	Spill Test Date	09/17/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/08/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/17/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: JOLLY OS GAS N GO
1200 Cedar St
Helena, MT 59601 Lewis and Clark

System Facility ID:25-04966

Facility Code: 23600
Last Inspected On: 03/18/2025
Operating Permit Renewal Date: 03/18/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Stockton Oil Co Billings

office@stocktonoil.com

Operator Contact:

Owner/Operator: Stockton Oil Co Billings

office@stocktonoil.com

Joseph Stockton, UST Class B Global Operator

jstockton@stocktonoil.com

Joseph Stockton, UST Class B Global Operator

jstockton@stocktonoil.com

Tank Code	01	Tank Age	40	Tank Installed Date	03/26/1985	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4784	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	40	Tank Installed Date	03/26/1985	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4785	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Tank Code	04	Tank Age	34	Tank Installed Date	09/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Positive Shutoff
Tag Number	4786	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Lewis and Clark County in the City of Helena

Location: KIMS MARINA AND RESORT
8015 Canyon Ferry Rd
Helena, MT 59602-8509 Lewis and Clark

System Facility ID:25-01091

Facility Code: 23401
Last Inspected On: 02/03/2023
Operating Permit Renewal Date: 05/10/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 8015 LLC (303) 356-4071 lukejewett65@gmail.com

Operator Contact: Joseph Musalek jmusalek1@gmail.com

Owner/Operator: 8015 LLC (303) 356-4071 lukejewett65@gmail.com

Joseph Musalek, UST Class A Operator jmusalek1@gmail.com
Joseph Musalek, UST Class B Operator jmusalek1@gmail.com

Tank Code	05	Tank Age	32	Tank Installed Date	05/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3516	Spill Test Date	06/15/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/22/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	3782	ATG Test Date	11/22/2022	Line Tightness Test Date	11/22/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	02/03/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Helena

Location: LAKESIDE MARKET AND GAS
5330 York Rd
Helena, MT 59602 Lewis and Clark

System Facility ID:25-13657

Facility Code: 23950
Last Inspected On: 10/19/2023
Operating Permit Renewal Date: 03/30/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sandra Gast;Sunflower LLC (406) 422-8407 sunflowerllc@outlook.com

Operator Contact: Sandra Gast;Shari Winters (406) 227-8157 winchums1@gmail.com

Owner/Operator: Sandra Gast

Owner/Operator: Sunflower LLC

Jessica Minetti, UST Class B Operator
Sandra Gast, UST Class A Operator
Sandra Gast, UST Class B Operator
Shari Winters, UST Class A Operator
Trisha Huston, UST Class B Operator

jminetti9@gmail.com

winchums1@gmail.com

tubr2010@gmail.com

Tank Code	02	Tank Age	30	Tank Installed Date	07/24/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4552	Spill Test Date	10/19/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/19/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	10/19/2023	Line Tightness Test Date	10/19/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/19/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	01	Tank Age	30	Tank Installed Date	07/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4553	Spill Test Date	10/19/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/19/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/19/2023	Line Tightness Test Date	10/19/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

	Overfill Test Date	10/19/2023						
--	---------------------------	------------	--	--	--	--	--	--

			ATG Type	Veeder Root/TLS-300				
--	--	--	-----------------	---------------------	--	--	--	--

				Veeder Root/TLS-300				
--	--	--	--	---------------------	--	--	--	--

Facility Summary in Lewis and Clark County in the City of Helena

Location: LITHIA CHRYSLER JEEP DODGE RAM OF HELENA
3401 US Hwy 12 E
Helena, MT 59601-9708 Lewis and Clark

System Facility ID:25-13687

Facility Code: 23952
Last Inspected On: 08/26/2020
Operating Permit Renewal Date: 08/28/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lithia Chrysler Jeep Dodge Ram of Helena

(406) 442-9994

astewart@lithia.com

Operator Contact:

Owner/Operator: Lithia Chrysler Jeep Dodge Ram of Helena

(406) 442-9994

astewart@lithia.com

Howard Reed, UST Class B Operator

hreed@lithia.com

Justin Smith, UST Class B Operator

jsmith@lithia.com

Tank Code	01	Tank Age	29	Tank Installed Date	03/15/1996	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	
Tag Number	1244	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date	08/26/2020	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	Manual Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	04/03/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	3-Year Line Tightness Test	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Lewis and Clark County in the City of Helena

Location: MAVERIK # 731
3196 Colonial Drive
Helena, MT 59601 Lewis and Clark

System Facility ID:00-32528

Facility Code: 32528
Last Inspected On: 06/18/2024
Operating Permit Renewal Date: 06/18/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Maverick, Inc. (801) 335-3898

Operator Contact: Alana May;Maverik Inc (801) 244-9025;(801) 910-7061 alana.may@maverik.com;dennis.riding@maverik.com

Owner/Operator: Maverick, Inc. (801) 335-3898

Alana May, UST Class A Operator
Alana May, UST Class B Operator
Erin Angove, UST Class B Operator

dennis.riding@maverik.com
dennis.riding@maverik.com
hbigbearmt@aol.com

Tank Code	01	Tank Age	2	Tank Installed Date	08/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	6181	Spill Test Date	02/21/2024	Piping Installed Date	10/23/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/05/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	40000	ATG Test Date	02/21/2024	Line Tightness Test Date	09/23/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	02/21/2024			ATG Type					
Tank Code	02	Tank Age	2	Tank Installed Date	08/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	6182	Spill Test Date	02/21/2024	Piping Installed Date	10/03/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/05/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	40000	ATG Test Date	02/21/2024	Line Tightness Test Date	09/23/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	02/21/2024			ATG Type					
Tank Code	03	Tank Age	2	Tank Installed Date	08/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm

Tag Number	6183	Spill Test Date	02/21/2024	Piping Installed Date	10/03/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/05/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	16000	ATG Test Date	02/21/2024	Line Tightness Test Date	02/21/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	02/21/2024			ATG Type					
Tank Code	04	Tank Age	2	Tank Installed Date	08/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	6184	Spill Test Date	02/21/2024	Piping Installed Date	10/03/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/05/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	16000	ATG Test Date	02/21/2024	Line Tightness Test Date	02/21/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	02/21/2024			ATG Type					
Tank Code	05	Tank Age	2	Tank Installed Date	08/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	6185	Spill Test Date	02/21/2024	Piping Installed Date	10/03/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/21/2024	Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	02/21/2024	Line Tightness Test Date	02/21/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	02/21/2024			ATG Type					

Facility Summary in Lewis and Clark County in the City of Helena

Location: MDOT HELENA HEADQUARTERS
2701 Prospect Ave
Helena, MT 59601-9746 Lewis and Clark

System Facility ID:25-06849

Facility Code: 23715
Last Inspected On: 08/15/2023
Operating Permit Renewal Date: 11/19/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: MDOT Helena	(406) 444-6163	mmurolo@mt.gov
Operator Contact: Joe Radonich;Montana Dept of Transportation;Mike Murolo;Montana Dept of Transportation;Tracy Deeds;MDOT Helena;Walt Kerttula;Montana Dept of Transportation	(406) 444-6151;(406) 444-7632;(406) 444-6163;(406) 444-7632;(406) 444-9204;(406) 444-7632;(406) 461-0769;(406) 444-6163	jradonich@mt.gov;jradonich@mt.gov;mmurolo@mt.gov;jradonich@mt.gov;tdeeds@mt.gov;mmurolo@mt.gov;wkerttula@mt.gov;jradonich@mt.gov

Owner/Operator: MDOT Helena	(406) 444-6163	mmurolo@mt.gov
Douglas Robbins, UST Class B Global Operator		jradonich@mt.gov
Joe Radonich, UST Class A Operator		jradonich@mt.gov
Joe Radonich, UST Class B Global Operator		jradonich@mt.gov
Karl Thalmann, UST Class B Operator		jradonich@mt.gov
Mike Murolo, UST Class A Operator		jradonich@mt.gov
Tracy Deeds, UST Class A Operator		mmurolo@mt.gov
Walt Kerttula, UST Class A Operator		jradonich@mt.gov

Tank Code	04	Tank Age	29	Tank Installed Date	03/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2911	Spill Test Date	06/27/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/27/2023	Line Tightness Test Date	01/27/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	29	Tank Installed Date	03/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2912	Spill Test Date	06/27/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	12000	ATG Test Date	06/27/2023	Line Tightness Test Date	01/17/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/27/2023			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: MDT EQUIPMENT DEVELOPMENT BUILDING
490 18th St
Helena, MT 59601 Lewis and Clark

System Facility ID:60-15139

Facility Code: 30883
Last Inspected On: 04/17/2023
Operating Permit Renewal Date: 05/15/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana Dept of Administration

(406) 444-3060

Operator Contact: Ed Sivils

esivils@mt.gov

Owner/Operator: Montana Dept of Administration

(406) 444-3060

Daniel Messerli, UST Class B Operator
David Spradlin, UST Class B Operator
Ed Sivils, UST Class A Operator
Ed Sivils, UST Class B Operator
James Simmons, UST Class B Operator

dan_messerli@hotmail.com
DSpradlin2@mt.gov
esivils@mt.gov
esivils@mt.gov
jasimms35@yahoo.com

Tank Code	S1	Tank Age	16	Tank Installed Date	10/01/2009	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5214	Spill Test Date		Piping Installed Date	07/08/2009	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/17/2023	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	04/17/2023			ATG Type					
Tank Code	S2	Tank Age	13	Tank Installed Date	10/01/2012	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5386	Spill Test Date		Piping Installed Date	07/31/2012	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/17/2023	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	04/17/2023			ATG Type					

Facility Summary in Lewis and Clark County in the City of Helena

Location: MERGENTHALER TRANSFER AND STORAGE CARTER DR
1430 Carter Dr
Helena, MT 59601-6429 Lewis and Clark

System Facility ID:56-13831

Facility Code: 30515
Last Inspected On: 12/21/2023
Operating Permit Renewal Date: 03/19/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mergenthalers Transfer and Storage (406) 442-9470 merg_ap@mergenthaler.net

Operator Contact: Dave Gardner;Justin Archer;Mergenthalers Transfer and Storage (406) 442-9470 dgardner@mergenthaler.net;jarcher@ccfs.com;merg_ap@mergenthaler.net

Owner/Operator: Mergenthalers Transfer and Storage (406) 442-9470 merg_ap@mergenthaler.net
Dave Gardner, UST Class A Operator dgardner@mergenthaler.net
Dave Gardner, UST Class B Operator dgardner@mergenthaler.net
Justin Archer, UST Class A Operator merg_ap@mergenthaler.net

Tank Code	01	Tank Age	28	Tank Installed Date	11/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	1609	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Galvanic
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date	12/21/2023	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date	12/21/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Lewis and Clark County in the City of Helena

Location: MOUNTAIN VIEW COOP HELENA
720 Custer Ave
Helena, MT 59602 Lewis and Clark

System Facility ID:60-15323

Facility Code: 31020
Last Inspected On: 06/16/2023
Operating Permit Renewal Date: 06/21/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mountain View Coop Black Eagle

(406) 453-5900

ddouglas@mountainviewcoop.com

Operator Contact: David Douglas

ddouglas@mountainviewcoop.com

Owner/Operator: Mountain View Coop Black Eagle

(406) 453-5900

ddouglas@mountainviewcoop.com

Cody Tripp, UST Class B Global Operator

ctripp@mountainviewcoop.com

David Douglas, UST Class A Operator

ddouglas@mountainviewcoop.com

Tank Code	01	Tank Age	7	Tank Installed Date	11/19/2018	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	5841	Spill Test Date	06/16/2023	Piping Installed Date	11/19/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/05/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/16/2023	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	06/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	06/16/2023			ATG Type	Incon/TS-550 EVO				
Tank Code	02	Tank Age	7	Tank Installed Date	11/19/2018	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	5842	Spill Test Date	06/16/2023	Piping Installed Date	11/19/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/05/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/16/2023	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	9000	ATG Test Date	06/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	06/16/2023			ATG Type	Incon/TS-550 EVO				
Tank Code	03	Tank Age	7	Tank Installed Date	11/19/2018	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff

Tag Number	5843	Spill Test Date	06/16/2023	Piping Installed Date	11/19/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/05/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/16/2023	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	9000	ATG Test Date	06/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	06/16/2023			ATG Type	Incon/TS-550 EVO				
Tank Code	04	Tank Age	7	Tank Installed Date	11/19/2018	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	5844	Spill Test Date	06/16/2023	Piping Installed Date	11/19/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/05/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/16/2023	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/16/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	06/16/2023			ATG Type	Incon/TS-550 EVO				

Facility Summary in Lewis and Clark County in the City of Helena

Location: PAR MONTANA HELENA PRODUCTS TERMINAL
3120 E US Hwy 12
Helena, MT 59601-9701 Lewis and Clark

System Facility ID:25-08728

Facility Code: 23795
Last Inspected On: 07/01/2024
Operating Permit Renewal Date: 10/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: PAR MONTANA (281) 899-4847 bmcfarland@parpacific.com

Operator Contact: Bry Joaillier Allen;Christopher Martin;James Vokral;Janie Lee;Jason Martin;Michael Bailey;Michael James;Robert Ochsenbein (406) 586-6927;(406) 657-5404;(435) 764-7049;(832) 624-7774;(832) 624-7876 colt_ochsenbein@hotmail.com;jason.m.martin@exxonmobil.com

Owner/Operator: PAR MONTANA (281) 899-4847 bmcfarland@parpacific.com

- Bry Joaillier Allen, UST Class A Operator
- Bry Joaillier Allen, UST Class A Operator
- Bry Joaillier Allen, UST Class A Operator
- Bry Joaillier Allen, UST Class B Global Operator
- Bry Joaillier Allen, UST Class B Global Operator
- Bry Joaillier Allen, UST Class B Global Operator
- Christopher Martin, UST Class A Operator
- Christopher Martin, UST Class A Operator
- Christopher Martin, UST Class A Operator
- Christopher Martin, UST Class B Operator
- Christopher Martin, UST Class B Operator
- Christopher Martin, UST Class B Operator
- James Vokral, UST Class A Operator
- James Vokral, UST Class A Operator
- James Vokral, UST Class A Operator
- James Vokral, UST Class B Global Operator
- James Vokral, UST Class B Global Operator
- James Vokral, UST Class B Global Operator
- Janie Lee, UST Class A Operator
- Janie Lee, UST Class A Operator
- Janie Lee, UST Class A Operator
- Janie Lee, UST Class B Global Operator
- Janie Lee, UST Class B Global Operator
- Janie Lee, UST Class B Global Operator
- Jim Gullon, UST Class B Global Operator
- Jim Gullon, UST Class B Global Operator

Jim Gullon, UST Class B Global Operator
 M Martin, UST Class A Operator
 M Martin, UST Class A Operator
 M Martin, UST Class A Operator
 M Martin, UST Class B Global Operator
 M Martin, UST Class B Global Operator
 M Martin, UST Class B Global Operator
 Marc Larson, UST Class B Global Operator
 Marc Larson, UST Class B Global Operator
 Marc Larson, UST Class B Global Operator
 Michael Bailey, UST Class A Operator
 Michael Bailey, UST Class A Operator
 Michael Bailey, UST Class A Operator
 Michael Bailey, UST Class B Global Operator
 Michael Bailey, UST Class B Global Operator
 Michael Bailey, UST Class B Global Operator
 Michael Bailey, UST Class B Global Operator
 Michael James, UST Class A Operator
 Michael James, UST Class A Operator
 Michael James, UST Class A Operator
 Michael James, UST Class B Global Operator
 Michael James, UST Class B Global Operator
 Michael James, UST Class B Global Operator
 Robert Ochsenbein, UST Class A Operator
 Robert Ochsenbein, UST Class A Operator
 Robert Ochsenbein, UST Class A Operator
 Robert Ochsenbein, UST Class B Global Operator
 Robert Ochsenbein, UST Class B Global Operator
 Robert Ochsenbein, UST Class B Global Operator

jason.m.martin@exxonmobil.com
 jason.m.martin@exxonmobil.com
 jason.m.martin@exxonmobil.com
 jason.m.martin@exxonmobil.com
 jason.m.martin@exxonmobil.com
 jason.m.martin@exxonmobil.com

colt_ochsenbein@hotmail.com
 colt_ochsenbein@hotmail.com
 colt_ochsenbein@hotmail.com
 colt_ochsenbein@hotmail.com
 colt_ochsenbein@hotmail.com
 colt_ochsenbein@hotmail.com

Tank Code	14	Tank Age	38	Tank Installed Date	01/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	2767	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/18/2024	Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Impressed Current
Product	Mixture	PLLD Test Date		Tank/Piping CP Test Date	06/24/2021	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	12/07/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/01/2024			ATG Type	Other/Other				

Tank Code	S01	Tank Age	75	Tank Installed Date	01/01/1950	Tank Material	Bare Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2768	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/13/2023	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	603330	ATG Test Date		Line Tightness Test Date	12/06/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S03	Tank Age	75	Tank Installed Date	01/01/1950	Tank Material	Bare Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2770	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/13/2023	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	604000	ATG Test Date		Line Tightness Test Date	12/15/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S05	Tank Age	75	Tank Installed Date	01/01/1950	Tank Material	Bare Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2772	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/13/2023	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	1200000	ATG Test Date		Line Tightness Test Date	12/04/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S07	Tank Age	75	Tank Installed Date	01/01/1950	Tank Material	Bare Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2774	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/13/2023	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	638000	ATG Test Date		Line Tightness Test Date	12/11/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Tank Code	S11	Tank Age	75	Tank Installed Date	01/01/1950	Tank Material	Bare Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2778	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/13/2023	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	633000	ATG Test Date		Line Tightness Test Date	12/13/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S15	Tank Age	38	Tank Installed Date	01/01/1987	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	
Tag Number	2780	Spill Test Date		Piping Installed Date	01/11/2017	Tank Construction		Piping Construction	Secondary Containment Chase	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/18/2024	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S18	Tank Age	38	Tank Installed Date	01/01/1987	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	2783	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/28/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S21	Tank Age	38	Tank Installed Date	01/01/1987	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	2786	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/18/2024	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	

Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Lewis and Clark County in the City of Helena

Location: PHILLIPS 66 HELENA TERMINAL
3180 E US Hwy 12
Helena, MT 59601-9701 Lewis and Clark

System Facility ID:25-01846

Facility Code: 23445
Last Inspected On: 10/26/2023
Operating Permit Renewal Date: 06/28/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Phillips 66 Helena Terminal (406) 255-5714

Operator Contact: Brian Buckley;Ryan Norwood (406) 441-4752 Ryan.P.Norwood@p66.com

Owner/Operator: Phillips 66 Helena Terminal (406) 255-5714

- | | |
|---|-------------------------------------|
| Brian Buckley, UST Class A Operator | |
| Brian Buckley, UST Class A Operator | |
| Brian Buckley, UST Class A Operator | |
| Brian Buckley, UST Class B Operator | |
| Brian Buckley, UST Class B Operator | |
| Brian Buckley, UST Class B Operator | |
| Clifford Pearce, UST Class B Operator | cliff.e.pearce@conocophillips.com |
| Clifford Pearce, UST Class B Operator | cliff.e.pearce@conocophillips.com |
| Clifford Pearce, UST Class B Operator | cliff.e.pearce@conocophillips.com |
| Dane Whittaker, UST Class B Global Operator | dane.t.whittaker@conocophillips.com |
| Dane Whittaker, UST Class B Global Operator | dane.t.whittaker@conocophillips.com |
| Dane Whittaker, UST Class B Global Operator | dane.t.whittaker@conocophillips.com |
| Jeb Pedrazzi, UST Class B Global Operator | jeb.c.pedrazzi@p66.com |
| Jeb Pedrazzi, UST Class B Global Operator | jeb.c.pedrazzi@p66.com |
| Jeb Pedrazzi, UST Class B Global Operator | jeb.c.pedrazzi@p66.com |
| Ryan Norwood, UST Class A Operator | Ryan.P.Norwood@p66.com |
| Ryan Norwood, UST Class A Operator | Ryan.P.Norwood@p66.com |
| Ryan Norwood, UST Class A Operator | Ryan.P.Norwood@p66.com |
| Ryan Norwood, UST Class B Operator | Ryan.P.Norwood@p66.com |
| Ryan Norwood, UST Class B Operator | Ryan.P.Norwood@p66.com |
| Ryan Norwood, UST Class B Operator | Ryan.P.Norwood@p66.com |

Tank Code	S30OUT	Tank Age	72	Tank Installed Date	01/01/1953	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	4259	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Regulated by DOT	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	

Product	Kerosene	PLLD Test Date		Tank/Piping CP Test Date	06/13/2006	Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Approved Remote Monitoring;MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	840000	ATG Test Date		Line Tightness Test Date	08/23/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	39	Tank Age	32	Tank Installed Date	01/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	4919	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	
Product	Mixture	PLLD Test Date		Tank/Piping CP Test Date	05/14/2020	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	10/18/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/26/2023			ATG Type	Other/Other				
Tank Code	S30IN	Tank Age	72	Tank Installed Date	01/01/1953	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	725	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Regulated by DOT	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Kerosene	PLLD Test Date		Tank/Piping CP Test Date	06/13/2006	Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Approved Remote Monitoring;MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	840000	ATG Test Date		Line Tightness Test Date	08/23/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S31IN	Tank Age	72	Tank Installed Date	01/01/1953	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	727	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Regulated by DOT	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/13/2006	Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Approved Remote Monitoring;MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1260000	ATG Test Date		Line Tightness Test Date	08/23/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Tank Code	S31OUT	Tank Age	72	Tank Installed Date	01/01/1953	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	728	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Regulated by DOT	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/13/2006	Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Approved Remote Monitoring;MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1260000	ATG Test Date		Line Tightness Test Date	08/23/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S32IN	Tank Age	72	Tank Installed Date	01/01/1953	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	729	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Regulated by DOT	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/13/2006	Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Approved Remote Monitoring;MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	840000	ATG Test Date		Line Tightness Test Date	08/23/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S32OUT	Tank Age	72	Tank Installed Date	01/01/1953	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	730	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Regulated by DOT	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/13/2006	Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Approved Remote Monitoring;MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	840000	ATG Test Date		Line Tightness Test Date	08/23/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S33IN	Tank Age	72	Tank Installed Date	01/01/1953	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	731	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Regulated by DOT	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/13/2006	Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Approved Remote Monitoring;MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1260000	ATG Test Date		Line Tightness Test Date	08/23/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S33OUT	Tank Age	72	Tank Installed Date	01/01/1953	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	732	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Regulated by DOT	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/13/2006	Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Approved Remote Monitoring;MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1260000	ATG Test Date		Line Tightness Test Date	08/23/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S35OUT	Tank Age	66	Tank Installed Date	01/01/1959	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	733	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Regulated by DOT	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/13/2006	Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Approved Remote Monitoring;MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1260000	ATG Test Date		Line Tightness Test Date	08/23/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S35IN	Tank Age	66	Tank Installed Date	01/01/1959	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	734	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Regulated by DOT	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/13/2006	Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Approved Remote Monitoring;MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1260000	ATG Test Date		Line Tightness Test Date	08/23/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Tank Code	S36IN	Tank Age	66	Tank Installed Date	01/01/1959	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	735	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Regulated by DOT	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/13/2006	Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Approved Remote Monitoring;MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1260000	ATG Test Date		Line Tightness Test Date	08/23/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S36OUT	Tank Age	66	Tank Installed Date	01/01/1959	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	736	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Regulated by DOT	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/13/2006	Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Approved Remote Monitoring;MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1260000	ATG Test Date		Line Tightness Test Date	08/23/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S37PIPE	Tank Age	72	Tank Installed Date	01/01/1953	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	737	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Regulated by DOT	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/13/2006	Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Approved Remote Monitoring;MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1260000	ATG Test Date		Line Tightness Test Date	08/23/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Lewis and Clark County in the City of Helena

Location: QUEEN CITY EXXON LLC
1721 Cedar St
Helena, MT 59601-1109 Lewis and Clark

System Facility ID:25-07848

Facility Code: 23755
Last Inspected On: 04/26/2024
Operating Permit Renewal Date: 08/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Queen City Exxon LLC;Timothy Hornbacher

dnvogle@mt.net

Operator Contact: Darcie Ogle;Queen City Exxon LLC;Vaughn Ogle

(406) 439-4469

dnvogle@mt.net;queencityexxon@gmail.com;dnvogle@mt.net

Owner/Operator: Queen City Exxon LLC

dnvogle@mt.net

Owner/Operator: Timothy C Hornbacher

dnvogle@mt.net

Darcie Ogle, UST Class A Operator
Darcie Ogle, UST Class B Operator
Vaughn Ogle, UST Class A Operator
Vaughn Ogle, UST Class B Operator

dnvogle@mt.net
dnvogle@mt.net
dnvogle@mt.net
dnvogle@mt.net

Tank Code	04	Tank Age	38	Tank Installed Date	12/29/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1396	Spill Test Date	08/02/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	04/26/2024	Tank/Piping CP Test Date	04/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/26/2024	Line Tightness Test Date	09/01/2004	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/26/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	38	Tank Installed Date	12/29/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1397	Spill Test Date	08/02/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	04/26/2024	Tank/Piping CP Test Date	04/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/26/2024	Line Tightness Test Date	09/01/2004	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/26/2024			ATG Type	Gilbarco/EMC Basic				

Tank Code	06	Tank Age	38	Tank Installed Date	12/29/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1398	Spill Test Date	08/02/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	04/26/2024	Tank/Piping CP Test Date	04/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/26/2024	Line Tightness Test Date	09/01/2004	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/26/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	08	Tank Age	35	Tank Installed Date	11/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	
Tag Number	1399	Spill Test Date		Piping Installed Date	04/24/2009	Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Galvanic
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date	04/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	04/26/2024	Line Tightness Test Date	09/01/2004	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Lewis and Clark County in the City of Helena

Location: SAFEWAY GASOLINE HELENA
611 N Montana Ave
Helena, MT 59601-3827 Lewis and Clark

System Facility ID:56-14000

Facility Code: 30661
Last Inspected On: 02/05/2024
Operating Permit Renewal Date: 01/29/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Albertsons - Safeway (208) 412-2233 page.rost@albertsons.com

Operator Contact: Danny Sager;Rachel Jones (208) 395-3269 rachel.jones@albertsons.com;s1486c60@safeway.com

Owner/Operator: Albertsons - Safeway (208) 412-2233 page.rost@albertsons.com
 Danny Sager, UST Class A Operator s1486c60@safeway.com
 Danny Sager, UST Class B Global Operator s1486c60@safeway.com
 Page Rost, UST Class B Global Operator page.rost@albertsons.com
 Rachel Jones , UST Class A Operator rachel.jones@albertsons.com
 Rachel Jones , UST Class B Global Operator rachel.jones@albertsons.com

Tank Code	01	Tank Age	24	Tank Installed Date	06/01/2001	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4330	Spill Test Date	06/10/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	06/27/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	40000	ATG Test Date	01/18/2023	Line Tightness Test Date	11/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	24	Tank Installed Date	06/01/2001	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4331	Spill Test Date	06/10/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	06/17/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes

Capacity	20000	ATG Test Date	01/18/2023	Line Tightness Test Date	11/22/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	24	Tank Installed Date	06/01/2001	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4332	Spill Test Date	06/10/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	06/27/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	01/18/2023	Line Tightness Test Date	11/18/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	2	Tank Installed Date	09/21/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6210	Spill Test Date	10/31/2023	Piping Installed Date	09/21/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/31/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	10/31/2023	Line Tightness Test Date	10/31/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/31/2023			ATG Type					
Tank Code	05	Tank Age	2	Tank Installed Date	09/21/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6211	Spill Test Date	10/31/2023	Piping Installed Date	09/21/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/31/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	10/31/2023	Line Tightness Test Date	10/31/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/31/2023			ATG Type					

Tank Code	06	Tank Age	2	Tank Installed Date	09/21/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6212	Spill Test Date	10/31/2023	Piping Installed Date	09/21/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/31/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/31/2023	Line Tightness Test Date	10/31/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/31/2023			ATG Type					
Tank Code	07	Tank Age	2	Tank Installed Date	09/21/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6213	Spill Test Date	10/31/2023	Piping Installed Date	09/21/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/31/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	10/31/2023	Line Tightness Test Date	10/31/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/31/2023			ATG Type					

Facility Summary in Lewis and Clark County in the City of Helena

Location: SAMS HIGH COUNTRY TRAVEL PLAZA
3122 E US Hwy 12
Helena, MT 59601 Lewis and Clark

System Facility ID:25-08659

Facility Code: 23790
Last Inspected On: 02/16/2023
Operating Permit Renewal Date: 03/15/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Helena Food and Gas LLC (530) 713-2805 helenafgllc@gmail.com

Operator Contact: Sukhvinder Singh helenafgllc@gmail.com

Owner/Operator: Helena Food and Gas LLC (530) 713-2805 helenafgllc@gmail.com

Sukhvinder Singh, UST Class A Operator helenafgllc@gmail.com
Sukhvinder Singh, UST Class B Operator helenafgllc@gmail.com

Tank Code	07	Tank Age	35	Tank Installed Date	06/19/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4526	Spill Test Date	02/16/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/16/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	02/16/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/16/2023	Line Tightness Test Date	02/16/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/13/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	35	Tank Installed Date	06/19/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4527	Spill Test Date	02/16/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/07/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	02/16/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/16/2023	Line Tightness Test Date	02/16/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/13/2023			ATG Type	Gilbarco/EMC Basic				

Tank Code	12	Tank Age	29	Tank Installed Date	10/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4528	Spill Test Date	02/16/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/16/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/16/2016	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	02/16/2023	Line Tightness Test Date	02/16/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/13/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	13	Tank Age	29	Tank Installed Date	10/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4529	Spill Test Date	02/16/2023	Piping Installed Date	05/19/2023	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/19/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/16/2016	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	02/16/2023	Line Tightness Test Date	05/19/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/13/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	14	Tank Age	29	Tank Installed Date	10/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4530	Spill Test Date	02/16/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/16/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/16/2016	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	02/16/2023	Line Tightness Test Date	02/16/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/13/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	15	Tank Age	29	Tank Installed Date	10/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4531	Spill Test Date	02/16/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date	02/16/2023	Sump Tightness Test Date	08/23/2021	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/16/2016	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	15000	ATG Test Date	02/16/2023	Line Tightness Test Date	02/16/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/13/2023			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Lewis and Clark County in the City of Helena

Location: SHODAIR CHILDRENS HOSPITAL
2755 Colonial Drive
Helena, MT 59601 Lewis and Clark

System Facility ID:00-32497

Facility Code: 32497
Last Inspected On: 04/27/2023
Operating Permit Renewal Date: 06/27/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: MONTANA CHILDRENS HOME & HOSPITAL

Operator Contact:

Owner/Operator: MONTANA CHILDRENS HOME & HOSPITAL

Tank Code	01	Tank Age	3	Tank Installed Date	06/22/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6091	Spill Test Date	09/12/2022	Piping Installed Date	06/22/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/12/2022	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date	08/25/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	09/12/2022			ATG Type					

Facility Summary in Lewis and Clark County in the City of Helena

Location: SLEEPING GIANT CONVENIENCE STORE
3425 E US Hwy 12
Helena, MT 59601-9708 Lewis and Clark

System Facility ID:25-13763

Facility Code: 23958
Last Inspected On: 08/12/2019
Operating Permit Renewal Date: 10/22/2019

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sleeping Giant Holding LLC

chad@offthewallmt.com

Operator Contact: Mike Clasby;Todd Bachmeier

(406) 422-9034

clasbym@bresnan.net;toddy600@yahoo.com

Mike Clasby, UST Class A Operator
Mike Clasby, UST Class B Operator
Todd Bachmeier, UST Class A Operator
Todd Bachmeier, UST Class B Global Operator

clasbym@bresnan.net
clasbym@bresnan.net
toddy600@yahoo.com
toddy600@yahoo.com

Tank Code	01	Tank Age	29	Tank Installed Date	10/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	365	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	16000	ATG Test Date		Line Tightness Test Date	07/30/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	29	Tank Installed Date	10/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	366	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	07/30/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Tank Code	04	Tank Age	29	Tank Installed Date	10/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	368	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	07/30/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	03	Tank Age	29	Tank Installed Date	10/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4333	Spill Test Date		Piping Installed Date	07/13/2010	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	16000	ATG Test Date		Line Tightness Test Date	07/30/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Lewis and Clark County in the City of Helena

Location: SOUTHS COUNTRY STORE
3105 York Rd
Helena, MT 59602-8816 Lewis and Clark

System Facility ID:25-07353

Facility Code: 23731
Last Inspected On: 04/25/2022
Operating Permit Renewal Date: 09/23/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: C And C Stores (406) 461-5504 cecilalexander1@gmail.com

Operator Contact: Lonnie Bennett (406) 443-4833 lonnieshawna@gmail.com

Owner/Operator: C And C Stores (406) 461-5504 cecilalexander1@gmail.com
Lonnie Bennett, UST Class A Operator lonnieshawna@gmail.com
Lonnie Bennett, UST Class B Operator lonnieshawna@gmail.com

Tank Code	05	Tank Age	32	Tank Installed Date	05/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3562	Spill Test Date	04/25/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/25/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/06/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/25/2022	Line Tightness Test Date	04/25/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/25/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	32	Tank Installed Date	05/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3563	Spill Test Date	04/25/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/25/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/06/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/25/2022	Line Tightness Test Date	04/25/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/25/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: SPRINT HELENA POP
1100 Phoenix Ave
Helena, MT 59601 Lewis and Clark

System Facility ID:56-14011

Facility Code: 30671
Last Inspected On: 04/19/2023
Operating Permit Renewal Date: 08/08/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sprint Communications Co LLP (913) 762-5957

Operator Contact: Brian Schmitt; Brian Wiedower (913) 315-8631 brian.c.wiedower@sprint.com; brian.schmitt@bolininc.com

Owner/Operator: Sprint Communications Co LLP (913) 762-5957

Brandon Hyde, UST Class B Operator
Brian Schmitt, UST Class A Operator
Brian Schmitt, UST Class B Operator
Brian Wiedower, UST Class A Operator
Matt Santee, UST Class B Global Operator
Scott Hallesy, UST Class B Operator

brandon.i.hyde@sprint.com
brian.schmitt@bolininc.com
brian.schmitt@bolininc.com
brian.c.wiedower@sprint.com
matt.santee@bolininc.com
scott.g.hallesy@sprint.com

Tank Code	01	Tank Age	24	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve; High Level Alarm
Tag Number	4322	Spill Test Date	03/19/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/01/2023	Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	2500	ATG Test Date	04/19/2024	Line Tightness Test Date	04/19/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/24/2024			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Lewis and Clark County in the City of Helena

Location: THRIFTWAY SUPER STOP 9
1405 Euclid Ave
Helena, MT 59601-2052 Lewis and Clark

System Facility ID:25-07931

Facility Code: 23761
Last Inspected On: 06/01/2022
Operating Permit Renewal Date: 06/12/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Operator Contact: Jack Hook;Linda Otonicar;Louis Sutey (406) 491-5808;(406) 494-2305 ldsutey66@thriftwayss.com;otonicarlinda@aol.com

Owner/Operator: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

- Brody Sheehan, UST Class B Global Operator beverssheehan@gmail.com
- Bryan Kelsey, UST Class B Operator bkelsey66@thriftwayss.com
- Douglas Bond, UST Class B Operator db1131958@gmail.com
- Jack Hook, UST Class A Operator
- Jack Hook, UST Class B Global Operator
- Jack Hook, UST Class B Operator
- Kirsten Jakubec, UST Class B Global Operator wegs1203@yahoo.com
- Kirsten Jakubec, UST Class B Operator wegs1203@yahoo.com
- Linda Otonicar, UST Class A Operator otonicarlinda@aol.com
- Louis Sutey, UST Class A Operator ldsutey66@thriftwayss.com
- Louis Sutey, UST Class B Global Operator ldsutey66@thriftwayss.com
- Peggy Johnson, UST Class B Operator thriftway9@thriftwayss.com
- Ruth Coladonato, UST Class B Operator ruth.pettite@ymail.com

Tank Code	06	Tank Age	29	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2056	Spill Test Date	04/11/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/02/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	02/02/2022	Line Tightness Test Date	12/27/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/11/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	07	Tank Age	29	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2057	Spill Test Date	04/11/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/02/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	02/02/2022	Line Tightness Test Date	12/10/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/11/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	29	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2058	Spill Test Date	04/11/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/02/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	02/02/2022	Line Tightness Test Date	12/02/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/11/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP HELENA 8
2910 N Montana Ave
Helena, MT 59601-0549 Lewis and Clark

System Facility ID:56-13846

Facility Code: 30528
Last Inspected On: 08/29/2024
Operating Permit Renewal Date: 11/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Helena 8 RE2 LLC (406) 497-6700 arnoldo@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Helena 8 RE2 LLC (406) 497-6700 arnoldo@townpump.com
 Trent Biggers, UST Class A Operator Trentb@townpump.com
 Trent Biggers, UST Class A Operator Trentb@townpump.com
 Trent Biggers, UST Class B Global Operator Trentb@townpump.com
 Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Code	01	Tank Age	27	Tank Installed Date	06/16/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2680	Spill Test Date	03/11/2024	Piping Installed Date	03/11/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/11/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/25/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/11/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	03/11/2024			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	27	Tank Installed Date	06/16/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2681	Spill Test Date	03/11/2024	Piping Installed Date	03/11/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/11/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/25/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	8000	ATG Test Date	03/11/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	03/11/2024			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	27	Tank Installed Date	06/16/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2682	Spill Test Date	03/11/2024	Piping Installed Date	03/11/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/11/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/25/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/11/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	03/11/2024			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	27	Tank Installed Date	06/16/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2683	Spill Test Date	03/11/2024	Piping Installed Date	03/11/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/11/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/25/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/11/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	03/11/2024			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	27	Tank Installed Date	07/24/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2684	Spill Test Date	03/11/2024	Piping Installed Date	03/11/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/11/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/25/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/11/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes

		Overfill Test Date	03/11/2024			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	24	Tank Installed Date	09/07/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4671	Spill Test Date	03/11/2024	Piping Installed Date	03/11/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/11/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/25/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/11/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	03/11/2024			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	1	Tank Installed Date	03/07/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6152	Spill Test Date	03/11/2024	Piping Installed Date	03/11/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/11/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	03/11/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	03/11/2024			ATG Type					

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP INC HELENA #3
3161 N Sanders
Helena, MT 59602 Lewis and Clark

System Facility ID:60-15210

Facility Code: 30930
Last Inspected On: 04/26/2023
Operating Permit Renewal Date: 11/15/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Helena 3 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Helena 3 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Code	01	Tank Age	13	Tank Installed Date	05/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5367	Spill Test Date	08/30/2022	Piping Installed Date	02/04/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/30/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/06/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/06/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	13	Tank Installed Date	05/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5369	Spill Test Date	11/23/2022	Piping Installed Date	02/04/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/30/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/06/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	04/06/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes

		Overfill Test Date	08/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	13	Tank Installed Date	05/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5370	Spill Test Date	11/23/2022	Piping Installed Date	02/04/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/30/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/06/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	04/06/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	13	Tank Installed Date	05/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5371	Spill Test Date	08/30/2022	Piping Installed Date	02/04/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/30/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/06/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/06/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	13	Tank Installed Date	05/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5372	Spill Test Date	08/30/2022	Piping Installed Date	02/04/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/30/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/06/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	04/06/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP INC HELENA 1
1240 Prospect Ave
Helena, MT 59601 Lewis and Clark

System Facility ID:25-08706

Facility Code: 23792
Last Inspected On: 03/14/2023
Operating Permit Renewal Date: 10/29/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Helena 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Helena 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Code	01	Tank Age	42	Tank Installed Date	04/15/1983	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2506	Spill Test Date	04/06/2022	Piping Installed Date	05/24/2024	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/24/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/13/2023	Tank/Piping CP Test Date	09/06/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/13/2023	Line Tightness Test Date	05/24/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	42	Tank Installed Date	04/15/1983	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2507	Spill Test Date	04/06/2022	Piping Installed Date	05/24/2024	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/24/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/13/2023	Tank/Piping CP Test Date	09/06/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	12000	ATG Test Date	07/13/2023	Line Tightness Test Date	05/24/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	42	Tank Installed Date	04/15/1983	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2508	Spill Test Date	04/06/2022	Piping Installed Date	05/24/2024	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/24/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/13/2023	Tank/Piping CP Test Date	09/06/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/13/2023	Line Tightness Test Date	05/24/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	27	Tank Installed Date	11/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2509	Spill Test Date	04/06/2022	Piping Installed Date	05/24/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/24/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/13/2023	Tank/Piping CP Test Date	09/25/2014	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/13/2023	Line Tightness Test Date	05/24/2024	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/31/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	08	Tank Age	27	Tank Installed Date	11/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2510	Spill Test Date	04/06/2022	Piping Installed Date	05/24/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/24/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/13/2023	Tank/Piping CP Test Date	09/25/2014	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/13/2023	Line Tightness Test Date	05/24/2024	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	10/31/2022			ATG Type	Gilbarco-Veeder Root/TLS- 450PLUS				
--	--	---------------------------	------------	--	--	-----------------	---	--	--	--	--

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP INC HELENA 2
1140 Euclid Ave
Helena, MT 59601 Lewis and Clark

System Facility ID:25-08707

Facility Code: 23793
Last Inspected On: 03/01/2023
Operating Permit Renewal Date: 11/14/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Helena 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Helena 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Code	03	Tank Age	41	Tank Installed Date	04/14/1984	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4832	Spill Test Date	09/07/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/25/2021	Tank/Piping CP Test Date	09/07/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	03/01/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/31/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	34	Tank Installed Date	07/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4833	Spill Test Date	09/07/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/25/2021	Tank/Piping CP Test Date	11/29/2005	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/01/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	05	Tank Age	34	Tank Installed Date	07/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4834	Spill Test Date	09/07/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/25/2021	Tank/Piping CP Test Date	11/29/2005	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/01/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	34	Tank Installed Date	07/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4835	Spill Test Date	09/07/2022	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/25/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/01/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP INC HELENA 5
1822 E Custer Ave
Helena, MT 59602-1206 Lewis and Clark

System Facility ID:60-15029

Facility Code: 30813
Last Inspected On: 04/26/2023
Operating Permit Renewal Date: 11/17/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Helena 5 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Helena 5 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Code	01	Tank Age	19	Tank Installed Date	12/06/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5064	Spill Test Date	08/20/2022	Piping Installed Date	12/06/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	07/24/2023	Line Tightness Test Date	12/07/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	19	Tank Installed Date	12/06/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5065	Spill Test Date	08/20/2022	Piping Installed Date	12/06/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	07/24/2023	Line Tightness Test Date	12/07/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	08/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	19	Tank Installed Date	12/06/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5066	Spill Test Date	11/02/2022	Piping Installed Date	12/06/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/24/2023	Line Tightness Test Date	12/11/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	19	Tank Installed Date	12/06/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5067	Spill Test Date	08/20/2022	Piping Installed Date	12/06/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/24/2023	Line Tightness Test Date	12/11/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	19	Tank Installed Date	12/06/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5068	Spill Test Date	08/20/2022	Piping Installed Date	12/06/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/24/2023	Line Tightness Test Date	12/15/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Code	06	Tank Age	19	Tank Installed Date	12/06/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5074	Spill Test Date	08/30/2022	Piping Installed Date	12/06/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/24/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/24/2023	Line Tightness Test Date	12/15/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Lewis and Clark County in the City of Helena

Location: TOWN PUMP INC HELENA 6
2401 N Montana Ave
Helena, MT 59601-0876 Lewis and Clark

System Facility ID:56-13818

Facility Code: 30505
Last Inspected On: 05/11/2023
Operating Permit Renewal Date: 11/18/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Helena 6 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Helena 6 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	02	Tank Age	28	Tank Installed Date	10/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3443	Spill Test Date	09/06/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/26/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	06/26/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	01	Tank Age	28	Tank Installed Date	09/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4610	Spill Test Date	09/06/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/26/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	06/26/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	09/06/2022			ATG Type	Gilbarco-Veeder Root/TLS- 450PLUS				
--	--	---------------------------	------------	--	--	-----------------	---	--	--	--	--

Facility Summary in Lewis and Clark County in the City of Helena

Location: UNITED PARCEL SERVICES HELENA
3029 Airport Rd
Helena, MT 59601 Lewis and Clark

System Facility ID:25-04538

Facility Code: 23584
Last Inspected On: 10/25/2024
Operating Permit Renewal Date: 06/01/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: United Parcel Service Inc Seattle

cdd6jxd@ups.com

Operator Contact: Jonathan Dunbar;United Parcel Service Inc Seattle;Russell Stott

(503) 978-7678

jstott@ups.com;jxdunbar@ups.com;cdd6jxd@ups.com

Owner/Operator: United Parcel Service Inc Seattle

cdd6jxd@ups.com

- Jonathan Dunbar, UST Class A Operator
- Jonathan Dunbar, UST Class B Operator
- Russell Stott, UST Class A Operator
- Russell Stott, UST Class A Operator
- Russell Stott, UST Class B Operator
- Russell Stott, UST Class B Operator

- cdd6jxd@ups.com
- cdd6jxd@ups.com
- jstott@ups.com
- jstott@ups.com
- jstott@ups.com
- jstott@ups.com

Tank Code	05	Tank Age	32	Tank Installed Date	12/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4446	Spill Test Date	04/09/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/09/2025	Sump Tightness Test Date	04/29/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/09/2025	Line Tightness Test Date	04/09/2025	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/09/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: WATKINS and SHEPARD TRUCKING HELENA
1500 Blaine St
Helena, MT 59601 Lewis and Clark

System Facility ID:25-12917

Facility Code: 23915
Last Inspected On: 05/24/2017
Operating Permit Renewal Date: 07/18/2020

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Albatross Inc (406) 434-5259 grizfan16@gmail.com

Operator Contact: Brandon Dulaney;Caryssa Berg;Derek Townsend (406) 442-9536;(920) 592-3928 bergc1@schneider.com;brandond@wksh.com;townsendd@schneider.com

Brandon Dulaney, UST Class A Operator
Brandon Dulaney, UST Class B Operator
Caryssa Berg, UST Class A Operator
Derek Townsend, UST Class A Operator
Derek Townsend, UST Class B Global Operator

brandond@wksh.com
brandond@wksh.com
bergc1@schneider.com
townsendd@schneider.com
townsendd@schneider.com

Tank Code	01	Tank Age	32	Tank Installed Date	02/03/1993	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	
Tag Number	4458	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	05/25/2017	Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Galvanic
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date	06/09/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2;Manual Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	02	Tank Age	32	Tank Installed Date	02/03/1993	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	
Tag Number	4459	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	05/25/2017	Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Galvanic

Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date	06/09/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2;Manual Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	03	Tank Age	30	Tank Installed Date	11/01/1995	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4460	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	05/25/2017	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/09/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	24000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Lewis and Clark County in the City of Helena

Location: ZIP TRIP 42
3100 N Montana Ave
Helena, MT 59602-7812 Lewis and Clark

System Facility ID:25-12353

Facility Code: 23889
Last Inspected On: 12/06/2023
Operating Permit Renewal Date: 03/02/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Operator Contact: Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

Jim Alford, UST Class A Operator
Jim Alford, UST Class B Operator
Luci Tuttle, UST Class B Operator
Sean Hurley, UST Class A Operator
Travis Weber, UST Class B Operator

jim.alford@chsinc.com
jim.alford@chsinc.com
Lucinda.Tuttle@chsinc.com
sean.hurley@chsinc.com
travis.weber3@chsinc.com

Tank Code	01	Tank Age	34	Tank Installed Date	06/07/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	559	Spill Test Date	02/15/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	07/26/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	07/26/2023	Line Tightness Test Date	07/26/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	34	Tank Installed Date	06/07/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	560	Spill Test Date	02/15/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	07/26/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/26/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	07/26/2023	Line Tightness Test Date	07/26/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	02/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	34	Tank Installed Date	06/07/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	561	Spill Test Date	02/15/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	07/26/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/26/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	07/26/2023	Line Tightness Test Date	07/26/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Helena

Location: ZIP TRIP 43
1318 Euclid Ave
Helena, MT 59601-2169 Lewis and Clark

System Facility ID:25-05774

Facility Code: 23652
Last Inspected On: 12/06/2023
Operating Permit Renewal Date: 03/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Operator Contact: Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jim Alford, UST Class A Operator
Jim Alford, UST Class A Operator
Jim Alford, UST Class B Operator
Jim Alford, UST Class B Operator
Luci Tuttle, UST Class B Operator
Sean Hurley, UST Class A Operator
Sean Hurley, UST Class A Operator
Travis Weber, UST Class B Operator

jim.alford@chsinc.com
jim.alford@chsinc.com
jim.alford@chsinc.com
jim.alford@chsinc.com
Lucinda.Tuttle@chsinc.com
sean.hurley@chsinc.com
sean.hurley@chsinc.com
travis.weber3@chsinc.com

Tank Code	03	Tank Age	41	Tank Installed Date	04/26/1984	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4518	Spill Test Date	02/15/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/27/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/24/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/27/2023	Line Tightness Test Date	07/27/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	01	Tank Age	42	Tank Installed Date	04/26/1983	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4519	Spill Test Date	02/15/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/27/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/24/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No

Capacity	10000	ATG Test Date	07/27/2023	Line Tightness Test Date	07/27/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	28	Tank Installed Date	04/23/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4520	Spill Test Date	08/28/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/27/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/24/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/27/2023	Line Tightness Test Date	07/27/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/28/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Lincoln

Location: MOUNTAIN VIEW COOP LINCOLN
525 Main St
Lincoln, MT 59639 Lewis and Clark

System Facility ID:25-03995

Facility Code: 23557
Last Inspected On: 08/24/2023
Operating Permit Renewal Date: 10/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

Operator Contact: David Douglas ddouglas@mountainviewcoop.com

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

David Douglas, UST Class A Operator ddouglas@mountainviewcoop.com
David Douglas, UST Class B Global Operator ddouglas@mountainviewcoop.com
Ranae Brown, UST Class B Global Operator rbrown@mountainviewcoop.com
Ranae Brown, UST Class B Operator rbrown@mountainviewcoop.com

Tank Code	04	Tank Age	29	Tank Installed Date	07/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2252	Spill Test Date	05/16/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/06/2021	Sump Tightness Test Date	09/08/2020	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/02/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	05/06/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	29	Tank Installed Date	07/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2253	Spill Test Date	05/16/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/06/2021	Sump Tightness Test Date	09/08/2020	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/02/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	05/06/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	29	Tank Installed Date	07/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2254	Spill Test Date	05/16/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/06/2021	Sump Tightness Test Date	09/08/2020	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/02/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	05/06/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	29	Tank Installed Date	07/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2255	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/06/2021	Sump Tightness Test Date	09/08/2020	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/02/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	05/06/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/16/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Wolf Creek

Location: CANYON STORE EXXON
175 Recreation Rd
Wolf Creek, MT 59648 Lewis and Clark

System Facility ID:25-04132

Facility Code: 23568
Last Inspected On: 11/09/2023
Operating Permit Renewal Date: 03/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Otheim Family LLC;Paul and Cheryl D Beister (406) 235-4111

Operator Contact: Shawn Otheim (775) 527-4507 otheims@yahoo.com

Owner/Operator: Otheim Family LLC (406) 235-4111

Owner/Operator: Paul D and Cheryl D Beister (406) 235-4111

Shawn Otheim, UST Class A Operator
Shawn Otheim, UST Class A Operator
Shawn Otheim, UST Class B Operator
Shawn Otheim, UST Class B Operator

otheims@yahoo.com
otheims@yahoo.com
otheims@yahoo.com
otheims@yahoo.com

Tank Code	03	Tank Age	27	Tank Installed Date	11/30/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3483	Spill Test Date	11/09/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	3000	ATG Test Date	11/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/09/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	27	Tank Installed Date	11/30/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3484	Spill Test Date	11/09/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	7000	ATG Test Date	11/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/09/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	27	Tank Installed Date	11/30/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3946	Spill Test Date	11/09/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	11/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/09/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Lewis and Clark County in the City of Wolf Creek

Location: THE BOAT LOFT
1460 Beartooth Rd
Wolf Creek, MT 59648-8743 Lewis and Clark

System Facility ID:25-05921

Facility Code: 23657
Last Inspected On: 06/06/2024
Operating Permit Renewal Date: 06/06/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Driftwood Enterprises LLC (406) 235-4435 boatloft@bresnan.net

Operator Contact: Darrell Greenwood (406) 727-0629 darrell.greenwood@launchwatersports.com

Owner/Operator: Driftwood Enterprises LLC (406) 235-4435 boatloft@bresnan.net
 Darrell Greenwood, UST Class A Operator darrell.greenwood@launchwatersports.com
 Darrell Greenwood, UST Class B Operator darrell.greenwood@launchwatersports.com
 Marshall Trainor, UST Class B Global Operator boatloft@bresnan.net

Tank Code	02	Tank Age	32	Tank Installed Date	04/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	473	Spill Test Date	11/06/2024	Piping Installed Date	11/13/2002	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/06/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/06/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/06/2024			ATG Type	Gilbarco-Veeder Root/EMC Basic				