

**Facility Summary in Liberty County in the City of Chester**

**Location:** AG AIR INC  
 Liberty County Airport  
 Chester, MT 59522-0670 Liberty

System Facility ID:26-02182

**Facility Code:** 23979  
**Last Inspected On:** 05/17/2022  
**Operating Permit Renewal Date:** 09/24/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Ag Air Inc (406) 355-4257

**Operator Contact:**

**Owner/Operator:** Ag Air Inc (406) 355-4257

James Briden, UST Class B Operator  
 James Briden, UST Class B Operator  
 James Briden, UST Class B Operator

jdbriden@itstriangle.com  
 jdbriden@itstriangle.com  
 jdbriden@itstriangle.com

<b>Tank Code</b>	05	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	05/01/1994	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	358	<b>Spill Test Date</b>	07/30/2021	<b>Piping Installed Date</b>	07/30/2021	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/30/2021	<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring;Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Aviation Gas	<b>PLLD Test Date</b>	05/17/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	05/17/2022	<b>Line Tightness Test Date</b>	10/03/2019	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/30/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Liberty County in the City of Chester**

**Location:** CHESTER SUPERMARKET  
1278 US Hwy 2  
Chester, MT 59522 Liberty

System Facility ID:26-13532

**Facility Code:** 24091  
**Last Inspected On:** 03/08/2024  
**Operating Permit Renewal Date:** 03/13/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** MPR Inc

chestersupermarket@gmail.com

**Operator Contact:** Harinder Singh;Manjit Maan

(209) 647-8034;(406) 868-2062

inder4030@yahoo.com;mcpshelby@gmail.com

**Owner/Operator:** MPR Inc

chestersupermarket@gmail.com

Charnjit Maan, UST Class B Operator  
Harinder Singh, UST Class A Operator  
Manjit Maan, UST Class A Operator  
Pardeep Kumar, UST Class B Operator

inder4030@yahoo.com  
mcpshelby@gmail.com  
pardeep.k51@yahoo.com

<b>Tank Code</b>	01	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	09/01/1995	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	3223	<b>Spill Test Date</b>	03/08/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/08/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	03/08/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/08/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	02	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	09/01/1995	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	3224	<b>Spill Test Date</b>	03/08/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	03/08/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No

<b>Capacity</b>	5000	<b>ATG Test Date</b>	03/08/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/08/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	03	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	09/01/1995	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	3225	<b>Spill Test Date</b>	03/08/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	03/08/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	7000	<b>ATG Test Date</b>	03/08/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/08/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				

**Facility Summary in Liberty County in the City of Chester**

**Location:** FRASER OIL INC CHESTER  
119 Washington Ave  
Chester, MT 59522 Liberty

System Facility ID:26-13006

**Facility Code:** 24087  
**Last Inspected On:** 11/16/2023  
**Operating Permit Renewal Date:** 03/17/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Fraser Oil Inc

**Operator Contact:** Cory Fraser

**Operator Contact:** frasfuel@yahoo.com

**Owner/Operator:** Fraser Oil Inc

Cory Fraser, UST Class A Operator  
Cory Fraser, UST Class A Operator  
Cory Fraser, UST Class B Operator  
Cory Fraser, UST Class B Operator  
Craig Fraser, UST Class B Operator  
Craig Fraser, UST Class B Operator  
Jesse Kuegler, UST Class B Operator  
Jesse Kuegler, UST Class B Operator

frasfuel@yahoo.com  
frasfuel@yahoo.com  
frasfuel@yahoo.com  
frasfuel@yahoo.com  
fraser\_46@hotmail.com  
fraser\_46@hotmail.com  
kealohakuegler@gmail.com  
kealohakuegler@gmail.com

<b>Tank Code</b>	04	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	10/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1123	<b>Spill Test Date</b>	11/16/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	11/16/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/14/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	11/16/2023	<b>Line Tightness Test Date</b>	11/16/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/16/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	05	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	10/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1124	<b>Spill Test Date</b>	11/16/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	11/16/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/14/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No

<b>Capacity</b>	1000	<b>ATG Test Date</b>	11/16/2023	<b>Line Tightness Test Date</b>	11/16/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/16/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	06	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	10/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1125	<b>Spill Test Date</b>	11/16/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	11/16/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/14/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>	11/16/2023	<b>Line Tightness Test Date</b>	11/16/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/16/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Liberty County in the City of Chester**

**Location:** ROOSEVELT SERVICE INC  
219 Washington Ave  
Chester, MT 59522 Liberty

System Facility ID:26-06061

**Facility Code:** 24034  
**Last Inspected On:** 06/17/2022  
**Operating Permit Renewal Date:** 09/29/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Roosevelt Service Inc

**Operator Contact:** Dan Davis;Teresa Barrett;Roosevelt Service Inc

**admin@rooseveltservice.com;dan@rooseveltservice.com**

**Owner/Operator:** Roosevelt Service Inc

Dan Davis, UST Class A Operator  
Dan Davis, UST Class B Global Operator  
Teresa Barrett, UST Class A Operator

dan@rooseveltservice.com  
dan@rooseveltservice.com  
admin@rooseveltservice.com

<b>Tank Code</b>	06	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	06/01/1991	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1752	<b>Spill Test Date</b>	06/17/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	07/20/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/17/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	12/14/2023	<b>Line Tightness Test Date</b>	07/20/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/17/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-300				
<b>Tank Code</b>	07	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	06/01/1991	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1753	<b>Spill Test Date</b>	06/17/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	07/20/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/17/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	12/14/2023	<b>Line Tightness Test Date</b>	07/20/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/17/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-300				

**Facility Summary in Liberty County in the City of Chester**

**Location:** TIBER MARINA  
669 Tiber Marina Rd  
Chester, MT 59522 Liberty

System Facility ID:26-03877

**Facility Code:** 24011  
**Last Inspected On:** 06/02/2022  
**Operating Permit Renewal Date:** 09/29/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Bureau of Reclamation Billings (406) 247-7310

**Operator Contact:** Eric Kleinsasser;Kenneth Scheffler

**EKleinsasser@usbr.gov;kscheffler@usbr.gov**

**Owner/Operator:** Bureau of Reclamation Billings (406) 247-7310

Eric Kleinsasser, UST Class A Operator  
Eric Kleinsasser, UST Class B Global Operator  
Eric Kleinsasser, UST Class B Operator  
Kenneth Scheffler, UST Class A Operator  
Kenneth Scheffler, UST Class B Operator

EKleinsasser@usbr.gov  
EKleinsasser@usbr.gov  
EKleinsasser@usbr.gov  
kscheffler@usbr.gov  
kscheffler@usbr.gov

<b>Tank Code</b>	04	<b>Tank Age</b>	39	<b>Tank Installed Date</b>	05/01/1986	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3997	<b>Spill Test Date</b>	06/02/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/02/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>	06/02/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/02/2022			<b>ATG Type</b>	EMCO Electronics/EECO 1500				