

## Facility Summary in Musselshell County in the City of Melstone

**Location:** JAKES GARAGE  
221 US Hwy 12  
Melstone, MT 59054 Musselshell

System Facility ID:33-01481

**Facility Code:** 25794  
**Last Inspected On:** 06/03/2024  
**Operating Permit Renewal Date:** 10/01/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Jake Zaharko;Jakes Garage Inc (406) 358-2389

**Operator Contact:** Larry Zaharko;Tim DeJaegher (406) 358-2389 Fivezs@midrivers.com;tdejaegher@live.com

**Owner/Operator:** Jake Zaharko

**Owner/Operator:** Jakes Garage Inc

Larry Zaharko, UST Class A Operator  
Larry Zaharko, UST Class A Operator  
Larry Zaharko, UST Class B Operator  
Larry Zaharko, UST Class B Operator  
Tim DeJaegher, UST Class A Operator  
Tim DeJaegher, UST Class A Operator  
Tim DeJaegher, UST Class B Operator  
Tim DeJaegher, UST Class B Operator

Fivezs@midrivers.com  
Fivezs@midrivers.com  
Fivezs@midrivers.com  
Fivezs@midrivers.com  
tdejaegher@live.com  
tdejaegher@live.com  
tdejaegher@live.com  
tdejaegher@live.com

<b>Tank Code</b>	08	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	12/01/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3770	<b>Spill Test Date</b>	06/03/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	01/04/2013	<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	3750	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/03/2024			<b>ATG Type</b>					
<b>Tank Code</b>	09	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	12/01/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3771	<b>Spill Test Date</b>	06/03/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	01/04/2013	<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No

<b>Capacity</b>	2250	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/03/2024			<b>ATG Type</b>					

## Facility Summary in Musselshell County in the City of Roundup

**Location:** CONOCO CONVENIENCE CENTER  
806 Main St  
Roundup, MT 59072-2224 Musselshell

System Facility ID:33-05030

**Facility Code:** 25845  
**Last Inspected On:** 10/04/2022  
**Operating Permit Renewal Date:** 12/14/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** McCleary Distributing Inc (406) 323-1108

**Operator Contact:** Terry Watkins (406) 323-1108 [dwatkins3389@hotmail.com](mailto:dwatkins3389@hotmail.com)

**Owner/Operator:** McCleary Distributing Inc (406) 323-1108

Terry Watkins, UST Class A Operator  
Terry Watkins, UST Class A Operator  
Terry Watkins, UST Class B Operator  
Terry Watkins, UST Class B Operator

[dwatkins3389@hotmail.com](mailto:dwatkins3389@hotmail.com)  
[dwatkins3389@hotmail.com](mailto:dwatkins3389@hotmail.com)  
[dwatkins3389@hotmail.com](mailto:dwatkins3389@hotmail.com)  
[dwatkins3389@hotmail.com](mailto:dwatkins3389@hotmail.com)

<b>Tank Code</b>	06	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	08/30/1989	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1591	<b>Spill Test Date</b>	08/23/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Not Listed	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	08/23/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	08/23/2022	<b>Line Tightness Test Date</b>	09/09/2016	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/23/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	07	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	08/30/1989	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1592	<b>Spill Test Date</b>	08/23/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	08/23/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	08/23/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	08/23/2022	<b>Line Tightness Test Date</b>	08/23/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/23/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

<b>Tank Code</b>	08	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	09/01/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1593	<b>Spill Test Date</b>	08/23/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	08/23/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	08/23/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	08/23/2022	<b>Line Tightness Test Date</b>	08/23/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/23/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	09	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	10/01/1996	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1594	<b>Spill Test Date</b>	08/23/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	08/23/2022	<b>Sump Tightness Test Date</b>	07/10/2018	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	08/23/2022	<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	08/23/2022	<b>Line Tightness Test Date</b>	08/23/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/23/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/ILS-350				
<b>Tank Code</b>	10	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	10/01/1996	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1595	<b>Spill Test Date</b>	08/23/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	08/23/2022	<b>Sump Tightness Test Date</b>	07/10/2018	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	08/23/2022	<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	08/23/2022	<b>Line Tightness Test Date</b>	08/23/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/23/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/ILS-350				
<b>Tank Code</b>	11	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	10/01/1996	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1596	<b>Spill Test Date</b>	08/23/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	08/23/2022	<b>Sump Tightness Test Date</b>	07/10/2018	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic

<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	08/23/2022	<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	08/23/2022	<b>Line Tightness Test Date</b>	08/23/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/23/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/ILS-350				
<b>Tank Code</b>	12	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	10/01/1996	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1597	<b>Spill Test Date</b>	08/23/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	08/23/2022	<b>Sump Tightness Test Date</b>	07/10/2018	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	08/23/2022	<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	08/23/2022	<b>Line Tightness Test Date</b>	08/23/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/23/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/ILS-350				

## Facility Summary in Musselshell County in the City of Roundup

**Location:** EXPRESS STOP  
701 1st Ave W  
Roundup, MT 59072 Musselshell

System Facility ID:33-06612

**Facility Code:** 25862  
**Last Inspected On:** 07/14/2022  
**Operating Permit Renewal Date:** 09/10/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** Thind Inc (510) 894-5533 lakhbirkamboj@yahoo.com

---

**Operator Contact:** Lakhbir Singh (510) 894-5533 lakhbirkamboj@yahoo.com

---

**Owner/Operator:** Thind Inc (510) 894-5533 lakhbirkamboj@yahoo.com

Lakhbir Singh, UST Class A Operator  
Lakhbir Singh, UST Class B Operator

lakhbirkamboj@yahoo.com  
lakhbirkamboj@yahoo.com  
lakhbirkamboj@yahoo.com

<b>Tank Code</b>	04	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1985	<b>Spill Test Date</b>	07/14/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	07/14/2022	<b>Tank/Piping CP Test Date</b>	12/12/2011	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	07/14/2022	<b>Line Tightness Test Date</b>	02/10/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/14/2022			<b>ATG Type</b>	Gilbarco/TLS-350				
<b>Tank Code</b>	05	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1986	<b>Spill Test Date</b>	07/14/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	07/14/2022	<b>Tank/Piping CP Test Date</b>	12/12/2011	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	07/14/2022	<b>Line Tightness Test Date</b>	07/14/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/14/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	06	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm

<b>Tag Number</b>	1987	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	12/12/2011	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	01	<b>Tank Age</b>	40	<b>Tank Installed Date</b>	03/26/1985	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	3757	<b>Spill Test Date</b>	07/14/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/14/2022	<b>Tank/Piping CP Test Date</b>	08/24/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	07/14/2022	<b>Line Tightness Test Date</b>	02/08/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/14/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	40	<b>Tank Installed Date</b>	03/26/1985	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	3758	<b>Spill Test Date</b>	07/14/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/14/2022	<b>Tank/Piping CP Test Date</b>	08/24/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	07/14/2022	<b>Line Tightness Test Date</b>	02/06/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/14/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	03	<b>Tank Age</b>	40	<b>Tank Installed Date</b>	03/26/1985	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	3759	<b>Spill Test Date</b>	08/16/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current

<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/14/2022	<b>Tank/Piping CP Test Date</b>	08/24/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	07/14/2022	<b>Line Tightness Test Date</b>	07/14/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/24/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				



## Facility Summary in Musselshell County in the City of Roundup

**Location:** FORMER WELLS FARGO BANK ROUNDUP  
12 Main St  
Roundup, MT 59072-2828 Musselshell

System Facility ID:33-02079

**Facility Code:** 25806  
**Last Inspected On:** 03/23/2022  
**Operating Permit Renewal Date:** 07/02/2025

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Roundup SD 55 and 55H

**Operator Contact:** A. Paul Thompson;Scott Wells

**(406) 860-7125;(406) 940-5377**

**paulthompson@k12.mt.us;sckwells@gmail.com**

A. Paul Thompson, UST Class A Operator  
A. Paul Thompson, UST Class B Global Operator  
Scott Wells, UST Class A Operator  
Scott Wells, UST Class B Global Operator

paulthompson@k12.mt.us  
paulthompson@k12.mt.us  
sckwells@gmail.com  
sckwells@gmail.com

<b>Tank Code</b>	S2	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	10/06/1993	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Copper	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3495	<b>Spill Test Date</b>	03/23/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/28/2016	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Heating Oil	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/23/2022	<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/23/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-300				