

Facility Summary in Sheridan County in the City of Medicine Lake

Location: LAKE PIT STOP  
729 Main St  
Medicine Lake, MT 59247 Sheridan

System Facility ID:46-01127

Facility Code: 27958  
Last Inspected On: 10/28/2021  
Operating Permit Renewal Date: 03/30/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lake Pit Stop LLC

Operator Contact: Chanel Johnson;James BoBo;Robert Herman 4064805957;7015722478

Owner/Operator: Lake Pit Stop LLC

Chanel Johnson, UST Class A Operator  
Chanel Johnson, UST Class B Operator  
James BoBo, UST Class A Operator  
James BoBo, UST Class B Operator  
Robert Herman, UST Class A Operator

Tank Code	S6	Tank Age	27	Tank Installed Date	10/01/1997	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	2323	Spill Test Date		Piping Installed Date	06/03/2013	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	12/15/2021	Sump Tightness Test Date	10/28/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	04/24/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	S7	Tank Age	27	Tank Installed Date	10/01/1997	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	2324	Spill Test Date		Piping Installed Date	06/03/2013	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	12/15/2021	Sump Tightness Test Date	10/28/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	

Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	04/24/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	S8	Tank Age	27	Tank Installed Date	10/01/1997	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	2325	Spill Test Date		Piping Installed Date	06/03/2013	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	12/15/2021	Sump Tightness Test Date	10/28/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	04/24/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	S9	Tank Age	27	Tank Installed Date	10/01/1997	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	2326	Spill Test Date		Piping Installed Date	06/03/2013	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	12/15/2021	Sump Tightness Test Date	10/28/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	04/24/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Sheridan County in the City of Medicine Lake

Location: MEDICINE LAKE SCHOOL DIST 7  
1 Young St  
Medicine Lake, MT 59247 Sheridan

System Facility ID:46-01122

Facility Code: 27957  
Last Inspected On: 04/20/2022  
Operating Permit Renewal Date: 06/03/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 7 Medicine Lake4067892211

Operator Contact: Aaron Webster4067892211

Owner/Operator: School Dist 7 Medicine Lake

Aaron Webster, UST Class A Operator  
Aaron Webster, UST Class B Global Operator  
Sandor Forizs, UST Class B Operator

Tank Code	S3	Tank Age	33	Tank Installed Date	08/01/1991	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1603	Spill Test Date	06/14/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/26/2019	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	01/16/2014	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	10066	ATG Test Date	04/20/2022	Line Tightness Test Date	04/20/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/14/2022			ATG Type	OPW / EMCO/EECO 1500				

Facility Summary in Sheridan County in the City of Plentywood

Location: AUTO TECH SERVICES  
327 W 1st Ave  
Plentywood, MT 59254-1802 Sheridan

System Facility ID:46-01524

Facility Code: 27977  
Last Inspected On: 04/21/2022  
Operating Permit Renewal Date: 04/21/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Farmers Union Oil Co Plentywood	4067651171
Operator Contact: James Kibbe;L Kibbe	4067651180

Owner/Operator: Farmers Union Oil Co Plentywood

- James Kibbe, UST Class A Operator
- James Kibbe, UST Class B Global Operator
- L James Kibbe, UST Class A Operator
- L James Kibbe, UST Class B Global Operator

Tank Code	08	Tank Age	35	Tank Installed Date	12/10/1989	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1114	Spill Test Date	11/24/2023	Piping Installed Date	11/02/2023	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/24/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	10/09/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	11/07/2023	Line Tightness Test Date	11/07/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/07/2023			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	09	Tank Age	35	Tank Installed Date	12/10/1989	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1115	Spill Test Date	11/24/2023	Piping Installed Date	11/02/2023	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/24/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/09/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	11/07/2023	Line Tightness Test Date	11/07/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	11/07/2023			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	10	Tank Age	35	Tank Installed Date	12/10/1989	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1116	Spill Test Date	11/24/2023	Piping Installed Date	11/02/2023	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/24/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/09/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/07/2023	Line Tightness Test Date	11/07/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/07/2023			ATG Type	Veeder Root/TLS-450PLUS				

Facility Summary in Sheridan County in the City of Plentywood

Location: FARMERS UNION OIL CO PLENTYWOOD

301 W 1st Ave

Plentywood, MT 59254-1802 Sheridan

System Facility ID:46-06801

Facility Code: 28147

Last Inspected On: 08/04/2021

Operating Permit Renewal Date: 08/23/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Farmers Union Oil Co Plentywood 4067651171

Operator Contact: L Kibbe

Owner/Operator: Farmers Union Oil Co Plentywood

L James Kibbe, UST Class A Operator  
L James Kibbe, UST Class B Global Operator

Tank Code	09	Tank Age	28	Tank Installed Date	06/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1038	Spill Test Date	09/27/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/13/2015	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/18/2021	Tank/Piping CP Test Date	06/17/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	07/28/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/30/2022			ATG Type	Veeder Root/TLS-450				
Tank Code	10	Tank Age	28	Tank Installed Date	06/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1039	Spill Test Date	09/27/2022	Piping Installed Date	05/20/2009	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/13/2015	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	06/18/2021	Tank/Piping CP Test Date	06/17/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	07/28/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/30/2022			ATG Type	Veeder Root/TLS-450				
Tank Code	11	Tank Age	28	Tank Installed Date	06/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	1040	Spill Test Date	09/30/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/13/2015	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/18/2021	Tank/Piping CP Test Date	06/17/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	07/28/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/30/2022			ATG Type	Veeder Root/TLS-450				
Tank Code	12	Tank Age	28	Tank Installed Date	06/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1041	Spill Test Date	09/27/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/13/2015	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	06/18/2021	Tank/Piping CP Test Date	06/17/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	03/24/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/30/2022			ATG Type	Veeder Root/TLS-450				
Tank Code	13	Tank Age	28	Tank Installed Date	06/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1042	Spill Test Date	09/27/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/13/2015	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	06/18/2021	Tank/Piping CP Test Date	06/17/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	07/28/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/30/2022			ATG Type	Veeder Root/TLS-450				
Tank Code	14	Tank Age	28	Tank Installed Date	06/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1043	Spill Test Date	09/27/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/13/2015	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	06/18/2021	Tank/Piping CP Test Date	06/17/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	8000	ATG Test Date		Line Tightness Test Date	03/24/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/30/2022			ATG Type	Veeder Root/TLS-450				
Tank Code	15	Tank Age	28	Tank Installed Date	06/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1044	Spill Test Date	09/27/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/13/2015	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	06/18/2021	Tank/Piping CP Test Date	06/17/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	03/24/2016	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/30/2022			ATG Type	Veeder Root/TLS-450				



Facility Summary in Sheridan County in the City of Plentywood

Location: KUM AND GO STORE 808  
211 W 1st Ave  
Plentywood, MT 59254-1830 Sheridan

System Facility ID:46-05200

Facility Code: 28101  
Last Inspected On: 04/12/2023  
Operating Permit Renewal Date: 09/10/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Krause Gentle Corp5154576382

Operator Contact: Aeon Long;Amanda Schumacher;Anthony Alred;Christopher Bergman;Kevin Kautzman;Mike Simpson;Wayne Lundquist4805886181;7013401435;7013918114;7016091594;7016094711;7632293142;9522003139

Owner/Operator: Krause Gentle Corp

- Aeon Long, UST Class A Operator
- Aeon Long, UST Class B Global Operator
- Amanda Schumacher, UST Class A Operator
- Amanda Schumacher, UST Class B Global Operator
- Anthony Alred, UST Class A Operator
- Anthony Alred, UST Class B Global Operator
- Christopher Bergman, UST Class A Operator
- Kevin Kautzman, UST Class A Operator
- Kevin Kautzman, UST Class B Global Operator
- Mike Simpson, UST Class A Operator
- Wayne Lundquist, UST Class A Operator
- Wayne Lundquist, UST Class B Global Operator

Tank Code	03	Tank Age	42	Tank Installed Date	12/01/1982	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1498	Spill Test Date	06/09/2020	Piping Installed Date	06/26/2009	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	03/07/2023	Tank/Piping CP Test Date	04/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/07/2023	Line Tightness Test Date	08/28/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	36	Tank Installed Date	01/01/1988	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	1500	Spill Test Date	06/09/2020	Piping Installed Date	06/26/2009	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/07/2023	Tank/Piping CP Test Date	04/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/07/2023	Line Tightness Test Date	08/28/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	36	Tank Installed Date	01/01/1988	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4358	Spill Test Date	06/09/2020	Piping Installed Date	06/26/2009	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/07/2023	Tank/Piping CP Test Date	04/12/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/07/2023	Line Tightness Test Date	08/28/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/27/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Sheridan County in the City of Plentywood

Location: MILLER OIL CO INC E RAILROAD AVE  
416 W Railroad Ave  
Plentywood, MT 59254 Sheridan

System Facility ID:46-08609

Facility Code: 28240  
Last Inspected On: 10/28/2021  
Operating Permit Renewal Date: 03/04/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Miller Oil Co Inc Culbertson

Operator Contact: Kevin Miller;Matthew Miller4067657730

Owner/Operator: Miller Oil Co Inc Culbertson

Kevin Miller, UST Class A Operator

Kevin Miller, UST Class B Operator

Matthew Miller, UST Class A Operator

Matthew Miller, UST Class B Global Operator

Tank Code	S1	Tank Age	57	Tank Installed Date	04/08/1967	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	1617	Spill Test Date		Piping Installed Date	03/23/2009	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/18/2015	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12048	ATG Test Date		Line Tightness Test Date	08/05/2009	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S2	Tank Age	63	Tank Installed Date	04/07/1961	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	1618	Spill Test Date		Piping Installed Date	03/23/2009	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/18/2015	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/08/2006	Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5327	ATG Test Date		Line Tightness Test Date	08/05/2009	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Tank Code	S3	Tank Age	57	Tank Installed Date	04/08/1967	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	1619	Spill Test Date		Piping Installed Date	03/23/2009	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/18/2015	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/08/2006	Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	14848	ATG Test Date		Line Tightness Test Date	08/05/2009	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S4	Tank Age	56	Tank Installed Date	04/07/1968	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	1620	Spill Test Date		Piping Installed Date	03/23/2009	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/18/2015	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/08/2006	Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	14773	ATG Test Date		Line Tightness Test Date	08/05/2009	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Sheridan County in the City of Plentywood

Location: MONTANA PIONEER MANOR INC  
605 Sheridan St  
Plentywood, MT 59254-1715 Sheridan

System Facility ID:46-10679

Facility Code: 28282  
Last Inspected On: 03/07/2022  
Operating Permit Renewal Date: 06/04/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana Pioneer Manor Inc4067651362

Operator Contact:

Owner/Operator: Montana Pioneer Manor Inc

Tank Code	S2	Tank Age	28	Tank Installed Date	05/01/1996	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1673	Spill Test Date	04/20/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/23/2019	Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	04/07/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/20/2022			ATG Type					

Facility Summary in Sheridan County in the City of Plentywood

Location: SHERIDAN COUNTY  
100 W Laurel Ave  
Plentywood, MT 59254-1647 Sheridan

System Facility ID:46-06278

Facility Code: 28126  
Last Inspected On: 04/12/2023  
Operating Permit Renewal Date: 04/21/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sheridan County Sanitarian

Operator Contact: Arthur Kurk;Austin Tommerup;D. A. Michels;Gary Bartnes;Jerry Hendrickson;Monica Vines;Ricky Lagerquist 4064892017;4067651221;4067652310;4067653405;4067657046;4067657702

Owner/Operator: Sheridan County Sanitarian

- Arthur Kurk, UST Class A Operator
- Austin Tommerup, UST Class A Operator
- D. A. Michels, UST Class A Operator
- Gary Bartnes, UST Class A Operator
- Gary Bartnes, UST Class B Global Operator
- Jerry Hendrickson, UST Class A Operator
- Jody Lowe, UST Class B Operator
- Monica Vines, UST Class A Operator
- Ricky Lagerquist, UST Class A Operator
- Ryan Mitchell, UST Class B Operator

Tank Code	S2	Tank Age	29	Tank Installed Date	09/01/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1911	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date	03/10/2020	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	01/05/2011	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	03/10/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	3-Year Line Tightness Test	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Sheridan County in the City of Plentywood

Location: SHERIDAN COUNTY SHOP  
MT Hwy 16 E  
Plentywood, MT 59254 Sheridan

System Facility ID:46-06279

Facility Code: 28127  
Last Inspected On: 01/23/2023  
Operating Permit Renewal Date: 02/19/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sheridan County Sanitarian

Operator Contact: Arthur Kurk;Austin Tommerup4067651221

Owner/Operator: Sheridan County Sanitarian

Arthur Kurk, UST Class A Operator  
Austin Tommerup, UST Class A Operator  
Russell Christensen, UST Class B Operator

Tank Code	05	Tank Age	34	Tank Installed Date	01/01/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1912	Spill Test Date	03/10/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/05/2011	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/23/2023			ATG Type					
Tank Code	06	Tank Age	34	Tank Installed Date	01/01/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1913	Spill Test Date	03/10/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/05/2011	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	10150	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/23/2023			ATG Type					
Tank Code	07	Tank Age	34	Tank Installed Date	01/01/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1914	Spill Test Date	03/10/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/05/2011	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	10150	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/23/2023			ATG Type					
Tank Code	08	Tank Age	34	Tank Installed Date	01/01/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	1915	Spill Test Date	03/10/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date	01/05/2011	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	1002	ATG Test Date		Line Tightness Test Date	01/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					



Facility Summary in Sheridan County in the City of Plentywood

Location: SHERIDAN MEMORIAL HOSPITAL  
440 W Laurel Ave  
Plentywood, MT 59254-1526 Sheridan

System Facility ID:46-00795

Facility Code: 27939  
Last Inspected On: 03/08/2022  
Operating Permit Renewal Date: 06/03/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sheridan Memorial Hospital

Operator Contact: Mark Brensdal;Murvin Anderson4067652646;4067653700

Owner/Operator: Sheridan Memorial Hospital

Athena Gardenier, UST Class B Global Operator  
Athena Gardenier, UST Class B Operator  
Mark Brensdal, UST Class A Operator  
Martin Carlson, UST Class B Global Operator  
Murvin Anderson, UST Class A Operator

Tank Code	S3	Tank Age	26	Tank Installed Date	10/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1918	Spill Test Date	03/07/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/07/2022	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	03/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/21/2022			ATG Type					

Facility Summary in Sheridan County in the City of Plentywood

Location:

WELCOME STOP PLENTYWOOD, LLC  
203 Raymond Rd  
Plentywood, MT 59254-1545 Sheridan

Facility Code:

28312

Last Inspected On:

08/26/2021

Operating Permit Renewal Date:

11/13/2024

System Facility ID:

46-12667

Note:

Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	John Gilligan	4807171776
Operator Contact:	John Gilligan;Lance Chandler	4067652983;4807171776

Owner/Operator: John Gilligan											
John Gilligan, UST Class A Operator											
John Gilligan, UST Class B Global Operator											
John Gilligan, UST Class B Operator											
Lance Chandler, UST Class A Operator											
Lance Chandler, UST Class B Operator											
Tank Code	01	Tank Age	33	Tank Installed Date	07/01/1991	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2954	Spill Test Date	07/15/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/28/2021			ATG Type					
Tank Code	02	Tank Age	33	Tank Installed Date	07/01/1991	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2955	Spill Test Date	07/15/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/28/2021			ATG Type					

Facility Summary in Sheridan County in the City of Reserve

Location: J AND R SERVICE  
101 Main St  
Reserve, MT 59258 Sheridan

System Facility ID:46-02103

Facility Code: 28008  
Last Inspected On: 06/28/2022  
Operating Permit Renewal Date: 08/10/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: J and R Services

Operator Contact: Jeff Brensdal 4062865276

Owner/Operator: J and R Services

Jeff Brensdal, UST Class A Operator  
Jeff Brensdal, UST Class B Global Operator  
Jeff Brensdal, UST Class B Operator  
Ryan Brensdal, UST Class B Operator

Tank Code	05	Tank Age	24	Tank Installed Date	07/27/2000	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4213	Spill Test Date	06/28/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/28/2022			ATG Type					
Tank Code	03	Tank Age	33	Tank Installed Date	05/21/1991	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4733	Spill Test Date	06/28/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/28/2022			ATG Type					