

Facility Summary in Valley County in the City of Fort Peck

Location: ROCK CREEK MARINA
652 S Rock Creek Rd
Fort Peck, MT 59223-7001 Valley

System Facility ID:29-11049

Facility Code: 24936
Last Inspected On: 07/20/2022
Operating Permit Renewal Date: 10/08/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rock Creek Marina LLC (406) 245-2560 rockcreekmarina2023@gmail.com

Operator Contact: David Frank rockcreekmarina2023@gmail.com

Owner/Operator: Rock Creek Marina LLC (406) 245-2560 rockcreekmarina2023@gmail.com

David Frank, UST Class A Operator

rockcreekmarina2023@gmail.com

David Frank, UST Class B Operator

rockcreekmarina2023@gmail.com

Tank Code	02	Tank Age	34	Tank Installed Date	05/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1846	Spill Test Date	09/09/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/09/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/09/2021			ATG Type	Gilbarco/TLS-300				

Facility Summary in Valley County in the City of Fort Peck

Location: US ARMY CORPS OF ENGINEERS FORT PECK
 Judith Rd
 Fort Peck, MT 59223 Valley

System Facility ID:53-04612

Facility Code: 29268
Last Inspected On: 04/03/2024
Operating Permit Renewal Date: 08/28/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: US Army Corps of Engineers Fort Peck (406) 526-3411

Operator Contact: Mary Nyquist;Seth Reedy;Thomas Grant (406) 526-3411;(406) 526-3431 mary.b.nyquist@usace.army.mil;seth.a.reedy@usace.army.mil;thomas.d.grant@usace.army.mil

Owner/Operator: US Army Corps of Engineers Fort Peck (406) 526-3411

Mary Nyquist, UST Class A Operator
 Mary Nyquist, UST Class B Operator
 Seth Reedy, UST Class A Operator
 Seth Reedy, UST Class B Global Operator
 Seth Reedy, UST Class B Operator
 Thomas Grant, UST Class A Operator
 Thomas Grant, UST Class B Operator

mary.b.nyquist@usace.army.mil
 mary.b.nyquist@usace.army.mil
 seth.a.reedy@usace.army.mil
 seth.a.reedy@usace.army.mil
 seth.a.reedy@usace.army.mil
 thomas.d.grant@usace.army.mil
 thomas.d.grant@usace.army.mil

Tank Code	08	Tank Age	35	Tank Installed Date	06/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2154	Spill Test Date	04/03/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/03/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	9000	ATG Test Date	04/03/2024	Line Tightness Test Date	04/03/2024	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	35	Tank Installed Date	06/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2155	Spill Test Date	04/03/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date	04/03/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2500	ATG Test Date	04/03/2024	Line Tightness Test Date	04/03/2024	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	35	Tank Installed Date	06/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2156	Spill Test Date	04/03/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/03/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/03/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2500	ATG Test Date	04/03/2024	Line Tightness Test Date	04/03/2024	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Valley County in the City of Frazer

Location: TRIBAL EXPRESS II
207 Main Ave
Frazer, MT 59225 Valley

System Facility ID:56-13890

Facility Code: 30564
Last Inspected On: 03/11/2025
Operating Permit Renewal Date: 03/17/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Fort Peck Assiniboine and Sioux Tribes (406) 768-5155

Operator Contact: Lynette Adams (406) 650-7774 tribalexpress@yahoo.com

Owner/Operator: Fort Peck Assiniboine and Sioux Tribes (406) 768-5155

Lynette Adams, UST Class A Operator tribalexpress@yahoo.com

Tank Code	01	Tank Age	28	Tank Installed Date	12/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6214	Spill Test Date	03/12/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/12/2025			ATG Type					
Tank Code	02	Tank Age	28	Tank Installed Date	12/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6215	Spill Test Date	03/12/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/12/2025			ATG Type					

Facility Summary in Valley County in the City of Glasgow

Location: AGLAND COOP GLASGOW
54197 US Hwy 2
Glasgow, MT 59230-1803 Valley

System Facility ID:53-03160

Facility Code: 29245
Last Inspected On: 02/26/2024
Operating Permit Renewal Date: 07/11/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Agland Coop Wolf Point (406) 653-1221 dave.williams@agland-coop.com

Operator Contact: Kory Hentges (406) 228-4641 kory.hentges@agland-coop.com

Owner/Operator: Agland Coop Wolf Point (406) 653-1221 dave.williams@agland-coop.com

- | | |
|--|-------------------------------|
| Allen Richard, UST Class B Global Operator | allen.richard@agland-coop.com |
| Allen Richard, UST Class B Global Operator | allen.richard@agland-coop.com |
| Allen Richard, UST Class B Operator | allen.richard@agland-coop.com |
| Allen Richard, UST Class B Operator | allen.richard@agland-coop.com |
| Kory Hentges, UST Class A Operator | kory.hentges@agland-coop.com |
| Kory Hentges, UST Class A Operator | kory.hentges@agland-coop.com |
| Kory Hentges, UST Class B Operator | kory.hentges@agland-coop.com |
| Kory Hentges, UST Class B Operator | kory.hentges@agland-coop.com |
| Michael Pallvoda, UST Class B Operator | fuoilwp@nemont.net |
| Michael Pallvoda, UST Class B Operator | fuoilwp@nemont.net |
| Steven Long, UST Class B Operator | |
| Steven Long, UST Class B Operator | |

Tank Code	05	Tank Age	34	Tank Installed Date	05/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1574	Spill Test Date	02/26/2024	Piping Installed Date	08/31/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/26/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/17/2023	Tank/Piping CP Test Date	02/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	06	Tank Age	34	Tank Installed Date	05/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1575	Spill Test Date	02/26/2024	Piping Installed Date	08/31/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/26/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/17/2023	Tank/Piping CP Test Date	02/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	34	Tank Installed Date	05/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1576	Spill Test Date	02/26/2024	Piping Installed Date	08/31/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/26/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/17/2023	Tank/Piping CP Test Date	02/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	34	Tank Installed Date	05/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1577	Spill Test Date	02/26/2024	Piping Installed Date	08/31/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/26/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/17/2023	Tank/Piping CP Test Date	02/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	34	Tank Installed Date	05/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm

Tag Number	1578	Spill Test Date	02/26/2024	Piping Installed Date	08/31/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/26/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/17/2023	Tank/Piping CP Test Date	02/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	05/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	13	Tank Installed Date	10/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5391	Spill Test Date	02/26/2024	Piping Installed Date	08/31/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/26/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/17/2023	Tank/Piping CP Test Date	02/26/2024	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/17/2023	Line Tightness Test Date	10/26/2012	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	02/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Valley County in the City of Glasgow

Location: CIRCLE K STORE 2746281
108 1st Ave N
Glasgow, MT 59230 Valley

System Facility ID:53-09712

Facility Code: 29324
Last Inspected On: 07/25/2023
Operating Permit Renewal Date: 10/01/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Operator Contact: Chuck Nyberg;Dean Townsend (952) 830-8722 dean.townsend@holidaycompanies.com

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator	brad.lee@holidaycompanies.com
Brad Lee, UST Class B Global Operator	brad.lee@holidaycompanies.com
Chuck Nyberg, UST Class A Operator	
Dean Townsend, UST Class A Operator	dean.townsend@holidaycompanies.com
Dean Townsend, UST Class A Operator	dean.townsend@holidaycompanies.com
Dylan Imbrescia, UST Class B Operator	djimbrescia2715@gmail.com
Dylan Imbrescia, UST Class B Operator	djimbrescia2715@gmail.com
Greg Brewer, UST Class B Global Operator	greg.brewer@holidaycompanies.com
Greg Brewer, UST Class B Global Operator	greg.brewer@holidaycompanies.com
Jon Garcia, UST Class B Operator	jon.p.garcia89@gmail.com
Jon Garcia, UST Class B Operator	jon.p.garcia89@gmail.com
Travis Struckman, UST Class B Global Operator	travis.struckman@holidaycompanies.com
Travis Struckman, UST Class B Global Operator	travis.struckman@holidaycompanies.com

Tank Code	04	Tank Age	36	Tank Installed Date	08/01/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4431	Spill Test Date	04/19/2022	Piping Installed Date	08/12/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/10/2020	Tank/Piping CP Test Date	03/10/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	01	Tank Age	39	Tank Installed Date	03/01/1986	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve; Flapper Valve
Tag Number	4432	Spill Test Date	04/10/2023	Piping Installed Date	08/12/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	04/10/2023	Tank/Piping CP Test Date	04/10/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/10/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	37	Tank Installed Date	04/15/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4433	Spill Test Date		Piping Installed Date	08/12/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	03/10/2020	Tank/Piping CP Test Date	03/10/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Valley County in the City of Glasgow

Location: EZZIES MIDTOWN
204 1st Ave N
Glasgow, MT 59230-1820 Valley

System Facility ID:53-05709

Facility Code: 29276
Last Inspected On: 10/25/2022
Operating Permit Renewal Date: 04/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale Inc

bill@ezzies.com

Operator Contact: Brandon Hoerster;Conor Moran;Ezzies Wholesale Inc

(406) 228-2713

brandon@ezzies.com;conor@ezzies.com;bill@ezzies.com

Owner/Operator: Ezzies Wholesale Inc

bill@ezzies.com

Brandon Hoerster, UST Class A Operator
Brandon Hoerster, UST Class A Operator
Brandon Hoerster, UST Class B Operator
Brandon Hoerster, UST Class B Operator
Conor Moran, UST Class A Operator

brandon@ezzies.com
brandon@ezzies.com
brandon@ezzies.com
brandon@ezzies.com
bill@ezzies.com

Tank Code	05	Tank Age	25	Tank Installed Date	06/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4201	Spill Test Date	10/25/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/13/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/13/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	25	Tank Installed Date	06/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4202	Spill Test Date	10/25/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/02/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/13/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

	Overfill Test Date 07/13/2022						
--	--------------------------------------	--	--	--	--	--	--

		ATG Type					
--	--	-----------------	--	--	--	--	--

			Gilbarco-Veeder Root/TLS-350				
--	--	--	---------------------------------	--	--	--	--

Facility Summary in Valley County in the City of Glasgow

Location: EZZIES WHOLESALE GLASGOW
1330 US Hwy 2 W
Glasgow, MT 59230 Valley

System Facility ID:53-10475

Facility Code: 29361
Last Inspected On: 12/14/2023
Operating Permit Renewal Date: 03/24/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale Inc

bill@ezzies.com

Operator Contact: Brandon Hoerster;Conor Moran;Ezzies Wholesale Inc

(406) 228-2713

brandon@ezzies.com;conor@ezzies.com;bill@ezzies.com

Owner/Operator: Ezzies Wholesale Inc

bill@ezzies.com

Brandon Hoerster, UST Class A Operator

brandon@ezzies.com

Brandon Hoerster, UST Class A Operator

brandon@ezzies.com

Brandon Hoerster, UST Class B Global Operator

brandon@ezzies.com

Brandon Hoerster, UST Class B Global Operator

brandon@ezzies.com

Brandon Hoerster, UST Class B Operator

brandon@ezzies.com

Brandon Hoerster, UST Class B Operator

brandon@ezzies.com

Conor Moran, UST Class A Operator

bill@ezzies.com

Jarid Jensen, UST Class B Operator

jpjensen@hotmail.com

Jarid Jensen, UST Class B Operator

jpjensen@hotmail.com

Tank Code	07	Tank Age	23	Tank Installed Date	11/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4758	Spill Test Date	11/20/2023	Piping Installed Date	08/15/2012	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/20/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	11/20/2023	Line Tightness Test Date	11/20/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/20/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	23	Tank Installed Date	11/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4759	Spill Test Date	11/20/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/20/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel	PLLD Test Date	11/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/20/2023	Line Tightness Test Date	11/20/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/20/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	23	Tank Installed Date	11/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4760	Spill Test Date	11/20/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/20/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/20/2023	Line Tightness Test Date	11/20/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/20/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	23	Tank Installed Date	11/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4761	Spill Test Date	11/20/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/20/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	11/20/2023	Line Tightness Test Date	11/20/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/20/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	11	Tank Age	23	Tank Installed Date	11/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	4762	Spill Test Date	11/20/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/20/2023	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	11/20/2023	Line Tightness Test Date	11/20/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	11/20/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	12	Tank Age	23	Tank Installed Date	11/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4763	Spill Test Date	11/20/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/20/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/20/2023	Line Tightness Test Date	11/20/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/20/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	13	Tank Age	23	Tank Installed Date	11/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4764	Spill Test Date	11/20/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	12/05/2023	Sump Tightness Test Date	11/20/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/05/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	11/20/2023	Line Tightness Test Date	12/05/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/20/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	14	Tank Age	23	Tank Installed Date	11/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4765	Spill Test Date	11/20/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/20/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/20/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	30000	ATG Test Date	11/20/2023	Line Tightness Test Date	11/20/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/20/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Valley County in the City of Glasgow

Location: FRANCES MAHON DEACONESS HOSPITAL
621 3rd St S
Glasgow, MT 59230-2604 Valley

System Facility ID:53-05192

Facility Code: 29273
Last Inspected On: 05/17/2023
Operating Permit Renewal Date: 11/06/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Frances Mahon Deaconess Hospital (406) 228-4351

Operator Contact: David Nixdorf

Owner/Operator: Frances Mahon Deaconess Hospital (406) 228-4351

David Nixdorf, UST Class A Operator
Jeff Damboise, UST Class B Operator
Paul Sallee, UST Class B Operator

jeff.damboise@fmdh.org
dolby2070@gmail.com

Tank Code	03	Tank Age	30	Tank Installed Date	10/01/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1118	Spill Test Date	05/17/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/22/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/10/2024	Line Tightness Test Date	07/22/2020	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/10/2024			ATG Type	Veeder Root/TLS-300				
Tank Code	04	Tank Age	30	Tank Installed Date	10/01/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1119	Spill Test Date	05/17/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/22/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	2000	ATG Test Date	07/10/2024	Line Tightness Test Date	05/17/2023	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

	Overfill Test Date 07/10/2024		ATG Type	Veeder Root/TLS-300			
--	--------------------------------------	--	-----------------	---------------------	--	--	--

Facility Summary in Valley County in the City of Glasgow

Location: GLASGOW INTERNATIONAL AIRPORT
89 Airport Rd
Glasgow, MT 59230-2843 Valley

System Facility ID:53-03271

Facility Code: 29250
Last Inspected On: 04/04/2024
Operating Permit Renewal Date: 04/04/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Dave Reinhardt;Valley County Airport Commission	(406) 228-8221	airport@valleycountymt.gov
Operator Contact: Lucas Locke;Manfreda Donovan;Robert Lipscomb	(406) 230-2257;(406) 263-7010;(406) 293-2067	airport@valleycountymt.gov;irpilot@nemont.net;sevencarpileup1970@gmail.com

Owner/Operator: Dave Reinhardt

Owner/Operator: Valley County Airport Commission

- Lucas Locke, UST Class A Operator
- Lucas Locke, UST Class A Operator
- Lucas Locke, UST Class B Operator
- Lucas Locke, UST Class B Operator
- Manfreda Donovan, UST Class A Operator
- Manfreda Donovan, UST Class A Operator
- Manfreda Donovan, UST Class B Operator
- Manfreda Donovan, UST Class B Operator
- Robert Lipscomb, UST Class A Operator
- Robert Lipscomb, UST Class A Operator
- Robert Lipscomb, UST Class B Operator
- Robert Lipscomb, UST Class B Operator

- airport@valleycountymt.gov
- airport@valleycountymt.gov
- airport@valleycountymt.gov
- airport@valleycountymt.gov
- sevencarpileup1970@gmail.com
- sevencarpileup1970@gmail.com
- sevencarpileup1970@gmail.com
- sevencarpileup1970@gmail.com
- irpilot@nemont.net
- irpilot@nemont.net
- irpilot@nemont.net
- irpilot@nemont.net

Tank Code	01	Tank Age	45	Tank Installed Date	01/01/1980	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	2726	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date	04/04/2024	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	08/09/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	44	Tank Installed Date	04/07/1981	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm

Tag Number	2727	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	04/04/2024	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	08/09/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Valley County in the City of Glasgow

Location: LAKERIDGE LODGING AND BAIT SHOP
5990 MT Hwy 24 S
Glasgow, MT 59230-8822 Valley

System Facility ID:53-08383

Facility Code: 29312
Last Inspected On: 11/26/2024
Operating Permit Renewal Date: 05/04/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Carrie Mindt;Team Lakeridge LLC (406) 526-3597 lakeridgefortpeck@gmail.com;lakeridgefortpek@gmail.com

Operator Contact: Carrie Mindt;Gene Moore (406) 526-3597 lakeridgefortpeck@gmail.com

Owner/Operator: Carrie Mindt (406) 526-3597 lakeridgefortpeck@gmail.com

Owner/Operator: Team Lakeridge LLC (406) 526-3597 lakeridgefortpeck@gmail.com

- Carrie Mindt, UST Class A Operator lakeridgefortpeck@gmail.com
- Carrie Mindt, UST Class A Operator lakeridgefortpeck@gmail.com
- Carrie Mindt, UST Class B Global Operator lakeridgefortpeck@gmail.com
- Carrie Mindt, UST Class B Global Operator lakeridgefortpeck@gmail.com
- Carrie Mindt, UST Class B Operator lakeridgefortpeck@gmail.com
- Carrie Mindt, UST Class B Operator lakeridgefortpeck@gmail.com
- Gene Moore, UST Class A Operator lakeridgefortpeck@gmail.com
- Gene Moore, UST Class A Operator lakeridgefortpeck@gmail.com
- Gene Moore, UST Class B Operator lakeridgefortpeck@gmail.com
- Gene Moore, UST Class B Operator lakeridgefortpeck@gmail.com

Tank Code	05	Tank Age	28	Tank Installed Date	05/15/1997	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1509	Spill Test Date	11/25/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/21/2013	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/25/2024			ATG Type					
Tank Code	06	Tank Age	28	Tank Installed Date	05/15/1997	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1510	Spill Test Date	11/25/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Single Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/21/2013	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/25/2024			ATG Type					

Facility Summary in Valley County in the City of Glasgow

Location: TRAILSIDE GENERAL STORE GLASGOW
54271 Hwy 2 E
Glasgow, MT 59230 Valley

System Facility ID:53-07787

Facility Code: 29299
Last Inspected On: 07/25/2023
Operating Permit Renewal Date: 07/25/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Wayne Waarvik (406) 228-9528 wtwaarvik@nemont.net

Operator Contact: Wayne Waarvik (406) 228-9528 wtwaarvik@nemont.net

Wayne Waarvik, UST Class A Operator

wtwaarvik@nemont.net

Wayne Waarvik, UST Class B Global Operator

wtwaarvik@nemont.net

Tank Code	03	Tank Age	34	Tank Installed Date	09/09/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	3873	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/25/2023	Primary Tank Leak Detection	Inventory Reconciliation; Tank Tightness Testing	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	04	Tank Age	34	Tank Installed Date	09/09/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	3874	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/25/2023	Primary Tank Leak Detection	Inventory Reconciliation; Tank Tightness Testing	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Valley County in the City of Hinsdale

Location: RAIDERS QUICK STOP
842 1st Ave N
Hinsdale, MT 59241 Valley

System Facility ID:60-15298

Facility Code: 31002
Last Inspected On: 04/10/2023
Operating Permit Renewal Date: 10/11/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale Inc

bill@ezzies.com

Operator Contact: Brandon Hoerster;Conor Moran;Ezzies Wholesale Inc

(406) 228-2713

brandon@ezzies.com;conor@ezzies.com;bill@ezzies.com

Owner/Operator: Ezzies Wholesale Inc

bill@ezzies.com

Brandon Hoerster, UST Class A Operator

brandon@ezzies.com

Conor Moran, UST Class A Operator

bill@ezzies.com

Nena Malmend, UST Class B Operator

bill@ezzies.com

Tank Code	01	Tank Age	8	Tank Installed Date	04/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5716	Spill Test Date	07/22/2020	Piping Installed Date	04/12/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/22/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	07/05/2017	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/22/2020			ATG Type	Incon/TS-550 EVO				
Tank Code	02	Tank Age	8	Tank Installed Date	04/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5717	Spill Test Date	07/22/2020	Piping Installed Date	04/12/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/22/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	5000	ATG Test Date		Line Tightness Test Date	07/05/2017	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/22/2020			ATG Type	Incon/TS-550 EVO				

Tank Code	03	Tank Age	8	Tank Installed Date	04/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5718	Spill Test Date	07/22/2020	Piping Installed Date	04/12/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/22/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	2000	ATG Test Date		Line Tightness Test Date	07/05/2017	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/22/2020			ATG Type	Incon/TS-550 EVO				
Tank Code	04	Tank Age	8	Tank Installed Date	04/10/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5727	Spill Test Date	07/22/2020	Piping Installed Date	04/12/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/22/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2500	ATG Test Date		Line Tightness Test Date	07/05/2017	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/22/2020			ATG Type	Incon/TS-550 EVO				

Facility Summary in Valley County in the City of Nashua

Location: AGLAND COOP NASHUA
810 Front St
Nashua, MT 59248 Valley

System Facility ID:53-10461

Facility Code: 29360
Last Inspected On: 06/15/2021
Operating Permit Renewal Date: 08/07/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Agland Coop Wolf Point

(406) 653-1221

dave.williams@agland-coop.com

Operator Contact: James Merideth

Allen Richard, UST Class B Global Operator
Allen Richard, UST Class B Global Operator
Allen Richard, UST Class B Operator
Allen Richard, UST Class B Operator
James Merideth, UST Class A Operator
James Merideth, UST Class A Operator
James Merideth, UST Class B Global Operator
James Merideth, UST Class B Global Operator
Michael Pallvoda, UST Class B Operator
Michael Pallvoda, UST Class B Operator
Steven Long, UST Class B Operator
Steven Long, UST Class B Operator

allen.richard@agland-coop.com
allen.richard@agland-coop.com
allen.richard@agland-coop.com
allen.richard@agland-coop.com

fuoilwp@nemont.net
fuoilwp@nemont.net

Tank Code	05	Tank Age	35	Tank Installed Date	03/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	937	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/15/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	35	Tank Installed Date	03/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	938	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/15/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	07	Tank Age	35	Tank Installed Date	03/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	939	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/15/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	08	Tank Age	35	Tank Installed Date	03/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	940	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/15/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Valley County in the City of Opheim

Location: PRO COOP OPHEIM
45 S Main
Opheim, MT 59250 Valley

System Facility ID:53-07814

Facility Code: 29300
Last Inspected On: 11/09/2023
Operating Permit Renewal Date: 02/12/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Pro Coop Opheim (406) 762-3231

Operator Contact: Jason Nasby;Myron Redfield;Timothy Stenglein (406) 762-3231 jnasby@procoopag.com;mtstenglein@yahoo.com

Owner/Operator: Pro Coop Opheim (406) 762-3231

Jason Nasby, UST Class A Operator

jnasby@procoopag.com

Jason Nasby, UST Class B Operator

jnasby@procoopag.com

Myron Redfield, UST Class A Operator

Myron Redfield, UST Class B Operator

Timothy Stenglein, UST Class A Operator

mtstenglein@yahoo.com

Timothy Stenglein, UST Class B Operator

mtstenglein@yahoo.com

Tank Code	04	Tank Age	32	Tank Installed Date	08/01/1993	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1820	Spill Test Date	11/09/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/19/2020	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2300	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/09/2023			ATG Type					
Tank Code	05	Tank Age	32	Tank Installed Date	08/01/1993	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1821	Spill Test Date	11/09/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasohol/Ethanol	PLLD Test Date		Tank/Piping CP Test Date	11/19/2020	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	3700	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/09/2023			ATG Type					

Tank Code	06	Tank Age	32	Tank Installed Date	08/01/1993	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1822	Spill Test Date	11/09/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/19/2020	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2300	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/09/2023			ATG Type					
Tank Code	07	Tank Age	32	Tank Installed Date	08/01/1993	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1823	Spill Test Date	11/09/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/19/2020	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	3700	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/09/2023			ATG Type					

Facility Summary in Valley County in the City of Saint Marie

Location: MT AVIATION RESEARCH BLDG CO BLDG 649A
Address Unavailable (DEQ_GEO_LOC_INFO : 44095)
Saint Marie, MT 59231 Valley

System Facility ID:53-12774

Facility Code: 29550
Last Inspected On: 07/19/2024
Operating Permit Renewal Date: 10/19/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana Aviation Research Co (406) 524-3777

Operator Contact: Brad Juntunen;Brian Mix;Darcel Wesen;Kenny Bryan;Kevin Wersal;Lynn Blatter;Michael Myrick;Preston Murch (406) 228-9584;(406) 263-1362;(406) 263-4591;(406) 263-6931;(406) 524-3777 darcel.d.wesen@boeing.com;marco787@nemont.net;marcomaintenance916@gmail.com;mm2000chevy@yahoo.com;shirleyblatter@yahoo.com;wersal5@hotmail.com

Owner/Operator: Montana Aviation Research Co (406) 524-3777

- | | |
|---|-------------------------------|
| Brad Juntunen, UST Class A Operator | marco787@nemont.net |
| Brad Juntunen, UST Class B Operator | marco787@nemont.net |
| Brian Mix, UST Class A Operator | marco787@nemont.net |
| Brian Mix, UST Class B Operator | marco787@nemont.net |
| Darcel Wesen, UST Class A Operator | darcel.d.wesen@boeing.com |
| Darcel Wesen, UST Class B Operator | darcel.d.wesen@boeing.com |
| Kenny Bryan, UST Class A Operator | marcomaintenance916@gmail.com |
| Kenny Bryan, UST Class B Global Operator | marcomaintenance916@gmail.com |
| Kenny Bryan, UST Class B Operator | marcomaintenance916@gmail.com |
| Kevin Wersal, UST Class A Operator | wersal5@hotmail.com |
| Kevin Wersal, UST Class B Operator | wersal5@hotmail.com |
| Lynn Blatter, UST Class A Operator | shirleyblatter@yahoo.com |
| Lynn Blatter, UST Class B Global Operator | shirleyblatter@yahoo.com |
| Michael Myrick, UST Class A Operator | mm2000chevy@yahoo.com |
| Michael Myrick, UST Class B Operator | mm2000chevy@yahoo.com |
| Preston Murch, UST Class A Operator | marco787@nemont.net |
| Preston Murch, UST Class B Operator | marco787@nemont.net |

Tank Code	S4	Tank Age	31	Tank Installed Date	01/01/1994	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	2975	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	50000	ATG Test Date	07/19/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	S5	Tank Age	31	Tank Installed Date	01/01/1994	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	2976	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	50000	ATG Test Date	07/19/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				