

**MONTANA DEPARTMENT OF
ENVIRONMENTAL QUALITY**

AUTHORIZATION TO DISCHARGE UNDER THE
MONTANA GROUND WATER POLLUTION CONTROL SYSTEM

In compliance with Montana Water Quality Act, Title 75, Chapter 5, Montana Code Annotated (MCA) and the Administrative Rules of Montana (ARM) 17.30 Subchapter 5, Subchapter 7, and Subchapter 10 *et seq.*,

TRD Inc.

is authorized to discharge from **Bozeman Hot Springs Campground Wastewater Treatment System**; N ½, SE ¼, Section 14 T2S, R4E, Gallatin County; to receiving waters, **Class I ground water**,

in accordance with discharge point(s), effluent limitations, monitoring requirements and other conditions set forth herein. Authorization for discharge is limited to those outfalls specifically listed in the permit. The numeric effluent limits, water quality standards, and special conditions specified herein support the protection of the affected receiving water.

This permit shall become effective: **TBD**.

This permit and the authorization to discharge shall expire at midnight, **TBD (five years after issue date)**.

FOR THE MONTANA DEPARTMENT OF
ENVIRONMENTAL QUALITY

DRAFT

Jon Kenning, Chief
Water Protection Bureau

Issue Date: **TBD**_____

TABLE OF CONTENTS

I.	EFFLUENT LIMITS, MONITORING REQUIREMENTS & OTHER CONDITIONS	4
A.	DESCRIPTION OF DISCHARGE POINTS AND MIXING ZONES	4
B.	EFFLUENT LIMITATIONS	4
C.	EFFLUENT MONITORING AND REPORTING REQUIREMENTS	5
D.	SPECIAL CONDITIONS – GROUND WATER MONITORING AND REPORTING REQUIREMENTS	7
E.	SPECIAL CONDITIONS – OTHER	9
F.	COMPLIANCE SCHEDULE	10
II.	MONITORING, RECORDING AND REPORTING REQUIREMENTS	10
A.	REPRESENTATIVE SAMPLING	10
B.	MONITORING PROCEDURES	11
C.	PENALTIES FOR TAMPERING	11
D.	REPORTING	11
E.	COMPLIANCE SCHEDULES	11
F.	ADDITIONAL MONITORING BY THE PERMITTEE	12
G.	RECORDS CONTENTS	12
H.	RETENTION OF RECORDS	12
I.	TWENTY-FOUR HOUR NOTICE OF NONCOMPLIANCE REPORTING	12
J.	OTHER NONCOMPLIANCE REPORTING	13
K.	INSPECTION AND ENTRY	13
III.	COMPLIANCE RESPONSIBILITIES	14
A.	DUTY TO COMPLY	14
B.	PENALTIES FOR VIOLATIONS OF PERMIT CONDITIONS	14
C.	NEED TO HALT OR REDUCE ACTIVITY NOT A DEFENSE	14
D.	DUTY TO MITIGATE	14
E.	PROPER OPERATION AND MAINTENANCE	15
F.	REMOVED SUBSTANCES	15
G.	BYPASS OF TREATMENT FACILITIES	15
IV.	GENERAL REQUIREMENTS	16
A.	PLANNED CHANGES	16
B.	ANTICIPATED NONCOMPLIANCE	16
C.	PERMIT ACTIONS	16
D.	DUTY TO REAPPLY	17
E.	DUTY TO PROVIDE INFORMATION	17
F.	OTHER INFORMATION	17
G.	SIGNATORY REQUIREMENTS	17
H.	PENALTIES FOR FALSIFICATION OF REPORTS	18

- I. AVAILABILITY OF REPORTS..... 18
- J. OIL AND HAZARDOUS SUBSTANCE LIABILITY 19
- K. PROPERTY OR WATER RIGHTS..... 19
- L. SEVERABILITY..... 19
- M. TRANSFERS 19
- N. FEES 19
- O. REOPENER PROVISIONS 20
- V. DEFINITIONS 20**

DRAFT

I. EFFLUENT LIMITS, MONITORING REQUIREMENTS & OTHER CONDITIONS

A. Description of Discharge Points and Mixing Zones

The authorization to discharge provided under this permit is limited to the outfall specially designated below as the discharge location. Discharges at any location not authorized under a MGWPCS permit is a violation of the Montana Water Quality Act and may subject the person(s) responsible for such discharge to penalties under the Act. Knowingly discharging from an unauthorized location or failing to report an unauthorized discharge within a reasonable time from first learning of an unauthorized discharge could subject such person to criminal penalties as provided under Section 75-5-632 of the Montana Water Quality Act.

<u>Outfall</u>	<u>Description</u>
001	Location: Subsurface discharge structure: 45.6615° Latitude and -111.19026° Longitude; N ½, SE ¼, Section 14 T2S, R4E, Gallatin County, Montana

Mixing Zone: A standard (500 foot) mixing zone bearing N13°W is authorized.

Treatment Works: Conventional septic to pressure-dose drainfield.

B. Effluent Limitations

Upon the effective date of the permit and lasting until the term of the permit; the quality of effluent discharged must, as a minimum, meet the limitations set forth in Table 1.

Proposed Final Effluent Limits – Outfall 001			
Parameter	Units	Daily maximum(1)	Annual maximum
Flow	gpd	12,250	
Total nitrogen	lbs/day	5.5	
Phosphorus, total (as P)	lbs/year		949
Footnotes:			
Beneficial Uses: ARM 17.30.1006			
(1) See definition in Part V of permit.			

C. Effluent Monitoring and Reporting Requirements

- Samples representative of effluent quality must be collected from:
 - EFF-001: drainfield dose tank
- Effluent samples must be representative of the nature of the monitored discharge.
- Effluent sampling requirements are listed in Table 2. The required sample type, sampling frequency, reporting requirements, and reporting frequency is listed in Table 2.
- Parameter analytical methods must be in accordance with the C-*-*ode of Federal Regulations, Title 40, Part 136, unless specified or otherwise approved by the Department.
- Submittal of electronic discharge monitoring reports (DMRs) are required regardless of the operational status of the facility. If no discharge occurs during an individual monitoring period, it shall be stated within the DMR (Outfall 001) that no discharge or overflow occurred.
- Effluent flow rate measurements must be collected from:
 - FM-001: flow meter at distribution valve vault prior to release to drainfield.
- Effluent flow rate measurements must be representative of the volume of the monitored discharge.
- Effluent flow monitoring and reporting requirements are listed in Table 2.

Table 2.

Effluent Monitoring and Reporting Requirements – Outfall 001						
Analyte/Measurement	Monitor Location	Units	Sample Type⁽¹⁾	Minimum Sample Frequency	Reporting Requirements⁽¹⁾⁽²⁾	Report Freq
Count of Daily Samples Collected During Reporting Period	EFF-001				Count	Monthly
Flow Rate, Effluent ⁽³⁾	FM-001	gpd	Continuous	Continuous	Daily Maximum Monthly Average	Monthly
Nitrogen, Nitrite+Nitrate (as N)	EFF-001	mg/L	Composite	Monthly	Daily Maximum Monthly Average	Monthly
Nitrogen, Total Kjeldahl (TKN)(as N)	EFF-001	mg/L	Composite	Monthly	Daily Maximum Monthly Average	Monthly
Nitrogen, Total (as N) ⁽⁴⁾	EFF-001	mg/L	Calculate	Monthly	Daily Maximum Monthly Average	Monthly
		lbs/day ⁽⁵⁾	Calculate	Monthly	Daily Maximum ⁽⁶⁾ Monthly Average ⁽⁷⁾	Monthly
Phosphorus, Total (as P)	EFF-001	mg/L	Composite	Monthly	Monthly Average	Monthly
		lbs/day ⁽⁵⁾	Calculate	Monthly	Monthly Average ⁽⁷⁾	Monthly
		lbs/year ⁽⁸⁾	Calculate	1/Year	Annual Maximum ⁽⁹⁾	Annually ⁽⁹⁾

Footnotes:

EFF-001: Sampling is from the dose tank just prior to discharge to drainfield.

FM-001: Located in the distribution valve vault prior to release into the drainfield.

If no discharge occurs during the reporting period, “no discharge” shall be recorded on the effluent Discharge Monitoring Report (DMR) report forms.

Grab sample will represent concentration for a 24 hour period.

Parameter analytical methods shall be in accordance with the Code of Federal Regulations, 40 CFR Part 136, unless specified above.

(1) See definitions in Part V of the permit.

(2) Daily Maximum: Report highest measured daily value for the reporting period on Discharge Monitoring Report

(3) Requires recording device or totalizing meter, must be capable of recording daily effluent volume.

(4) Total Nitrogen is the sum of Nitrate + Nitrite and Total Kjeldahl Nitrogen.

(5) Load calculation: lbs/day = (mg/L) x flow (gpd) x [8.34 x 10⁻⁶].

(6) Daily Maximum Load calculation: lbs/day = the maximum of all calculated individual daily average loads (lbs/day) recorded during the reporting period.

(7) Monthly Average Load calculation: lbs/day = the average of all calculated individual daily average loads (lbs/day) recorded during the reporting period.

(8) Annual Load calculation: lbs/year = (mg/L) x flow (gpd) x [8.34 x 10⁻⁶] x 365 (days/year).

(9) Annual maximum load shall be reported (DMR) on an annual basis (due January 28 each year of the permit cycle).

D. Special Conditions – Ground Water Monitoring and Reporting Requirements

1. Ground water monitoring and reporting is required for monitoring wells: MW-1a, MW-1b, MW-2. These wells must be individually sampled at the frequency and with the type of measurement respectively listed in Table 4. Samples must include, but not be limited to, the respective parameters listed in Table 4 for each listed monitoring well. The reporting requirements and reporting frequencies are listed in Table 4.
2. Parameter analytical methods must be in accordance with the Code of Federal Regulations, Title 40, Part 136, unless specified or otherwise approved by the Department.
3. The permittee shall document the methodology and equipment used to sample monitoring wells during all sampling events. Self-monitoring records shall be maintained in accordance with Part II.H. of this permit.
4. Submittal of electronic discharge monitoring reports (DMRs) are required, regardless of the operational status of the facility or of each individual monitoring well. At no time shall the permittee mark or state “No Discharge” within any monitoring well DMR.
5. If any of the monitoring wells are abandoned, destroyed, decommissioned or non-viable; or are no longer able to be sampled due to fluctuations in the ground water table; the permittee shall install (or rehab) a new well to replace the abandoned, destroyed, decommissioned, or non-viable well(s).

Table 3.

Downgradient Ground Water Monitoring and Reporting Requirements (MW-1a, MW-1b)						
Analyte/Measurement	Monitor Location⁽¹⁾	Units	Sample Type⁽²⁾	Minimum Sampling Frequency	Reporting⁽²⁾⁽³⁾⁽⁴⁾ Requirements	Reporting Frequency
Chloride (as Cl)	MW-1a MW-1b	mg/L	Grab	Monthly	Monthly Average	Monthly
<i>Escherichia coli</i> Bacteria	MW-1a MW-1b	CFU/100ml	Grab	Monthly	Daily Maximum Monthly Average ⁽⁵⁾	Monthly
Nitrogen, nitrate + nitrite (as N)	MW-1a MW-1b	mg/L	Grab	Monthly	Daily Maximum Monthly Average	Monthly
Nitrogen, total kjeldahl (TKN)(as N)	MW-1a MW-1b	mg/L	Grab	Monthly	Daily Maximum Monthly Average	Monthly
Specific conductivity @ 25°C	MW-1a MW-1b	µS/cm	Grab	Monthly	Monthly Average	Monthly
Static water level (SWL) ⁽⁶⁾	MW-1a MW-1b	ft-bmp	Instantaneous	Monthly	Monthly Average	Monthly
Upgradient Ground Water Monitoring and Reporting Requirements (DEQ approved upgradient monitoring well)						
Analyte/Measurement	Monitor Location*	Units	Sample Type⁽²⁾	Minimum Sampling Frequency	Reporting⁽²⁾⁽³⁾⁽⁴⁾ Requirements	Reporting Frequency
Chloride (as Cl)	*	mg/L	Grab	Quarterly	Quarterly Average	Quarterly
Total organic carbon	*	mg/L	Grab	Quarterly	Quarterly Average	Quarterly
Total dissolved solids	*	mg/L	Grab	Quarterly	Quarterly Average	Quarterly
pH	*	s.u.	Grab	Quarterly	Monthly Average	Quarterly
<i>Escherichia coli</i> Bacteria	*	CFU/100ml	Grab	Quarterly	Daily Maximum Quarterly Average ⁽⁵⁾	Quarterly
Nitrogen, nitrate + nitrite (as N)	*	mg/L	Grab	Quarterly	Daily Maximum Quarterly Average	Quarterly
Nitrogen, total kjeldahl (TKN)(as N)	*	mg/L	Grab	Quarterly	Daily Maximum Quarterly Average	Quarterly
Specific conductivity @ 25°C	*	µS/cm	Grab	Quarterly	Quarterly Average	Quarterly
Static water level (SWL) ⁽⁶⁾	*	ft-bmp	Instantaneous	Quarterly	Quarterly Average	Quarterly
Footnotes:						
CFU = Colony Forming Units						
ft-bmp = feet below measuring point						
* Sampling location is the DEQ approved monitoring well as described in the special conditions of this fact sheet and the permit.						
s.u. = standard units						
At no time shall the permittee mark or state "no discharge" on any monitoring well DMR form.						
Each monitor well to be individually sampled and analyzed for each respective parameter listed above.						
If any monitoring well(s) are abandoned, destroyed or decommissioned, or are no longer able to be sampled due to fluctuations in the ground water table; the permittee shall install a new well to replace the abandoned, destroyed, decommissioned, or non-viable well(s).						
Parameter analytical methods shall be in accordance with the Code of Federal Regulations, 40 CFR Part 136, unless specified above.						
Submittal of discharge monitoring report forms (DMRs) will be required, regardless of the operational status of the facility or of each individual monitoring well.						
(1) Refer to Section 2 of the Fact Sheet for the existing location of the monitoring wells.						
(2) See definitions in Part V of the permit.						
(3) Submittal of DMRs will be required, regardless of the installation status of each individual monitoring well.						
(4) Daily Maximum: Report highest measured daily value for the reporting period on Discharge Monitoring Report (DMR).						
(5) The geometric mean must be reported if more than one sample is taken during a reporting period.						
(6) Measuring point (point of reference) for SWL measurements shall be from top of casing and measured to within 1/100th of one foot.						

E. Special Conditions – Other

1. Upon issuance of this permit, the applicant shall begin sampling and reporting for all parameters required in this permit and listed in **Section 6.1** of this fact sheet. Parameters and monitoring schedules have changed since the last permit cycle. Sample collection, preservation and analysis shall be in compliance with ARM 19.30.1007. Ground water/Effluent monitoring and reporting commencement dates for each monitoring well is listed in **Table 3** and **Table 4** (Compliance Table).

2. Within 180 days of the issuance of this permit, the applicant will provide to DEQ for approval, the location and details of the well to be used as the DEQ approved upgradient monitoring well.

3. Within 12 months of the issuance of this permit, the applicant will provide to DEQ for approval, a site plan for the Bozeman Hot Springs campground accurately showing the location of all current structures on the site. The site plan must identify all installed and proposed infrastructure included in MGWPCS permit. The site plan will identify and locate all installed wastewater and water infrastructure on the site associated with all existing structures not connected to MTX000126. The site plan should identify and locate all existing and planned water and wastewater infrastructure on the site that serve any existing facilities within the site not included in the scope of MGWPCS permit MTX000126. Site plan should include the fate of all wastewater leaving the site. The respective completion and reporting dates are listed in **Table 4** (Compliance Table).

F. Compliance Schedule

Table 4.

Compliance Schedule for Bozeman Hot Springs MGWPCS #MTX000126			
Action	Frequency	Scheduled Completion Date of Action⁽¹⁾	Scheduled Report Due Date.⁽²⁾
Develop and submit to DEQ a site plan accurately representing all current water and wastewater infrastructure on the site. Site plan will include the Bozeman Hot Springs Campground water and wastewater systems as well as any other systems on the site. The plan will include all current existing structures accurately located, and will include a description of wastewater management for all facilities and structures on the site.	Single event ⁽³⁾	Within 12 months of the effective date on the permit.	Due on or before the 28th day of the month following the completion date.
Begin new monitoring program including the sampling of all required parameters and at the locations as required in the permit renewal.	Continuing event ⁽⁵⁾	Beginning at the effective date of the permit.	Due on or before the 28th day of the month following the completion date.
Provide for DEQ approval, the location and description of an upgradeint monitoring well. Provide three consecutive quarters of upgradinet monitoring data once the location is approved.	Single event ⁽⁴⁾⁽⁵⁾⁽⁶⁾	Within 180 days of the effective date of the permit.	Due on or before the 28th day of the month following the completion date.
Footnotes:			
(1) The actions must be completed on or before the scheduled completion dates.			
(2) Reports must be received by DEQ on or before the scheduled report due dates. The reports must include all information as required for each applicable action as listed in Section 5.3.			
(3) The completed plan (action), in place of a written report, must be received by the DEQ on or before the scheduled "report" due date.			
(4) The written report documenting monitoring well installation must include: drilling methods used; borehole lithologic logs; diagram of well construction details; measuring point details; surveyed base location of all monitoring wells; surveyed measuring point elevation of all monitoring wells; depth to the top contact of the first saturated ground water bearing zone; well development records; depth to static water level (post development). This information must be included for each respective monitoring well.			
(5) Sampling parameters required for each respective monitoring well as listed within Table 10 and Table 5 of Fact Sheet.			
(6) Three separate consecutive quarterly sampling events required from this monitoring well once approved by DEQ and installed.			

II. MONITORING, RECORDING AND REPORTING REQUIREMENTS

A. Representative Sampling

Samples taken in compliance with the monitoring requirements established under Part I of the permit must be collected from the effluent stream prior to discharge into the receiving waters. Samples and measurements must be representative of the volume and nature of the monitored discharge.

B. Monitoring Procedures

Monitoring must be conducted according to test procedures approved under Part 136, Title 40 of the Code of Federal Regulations, unless other test procedures have been specified in this permit. All flow-measuring and flow-recording devices used in obtaining the data submitted in self-monitoring reports must indicate values within 10 percent of the actual flow being measured.

C. Penalties for Tampering

The Montana Water Quality Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate, any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$25,000, or by imprisonment for not more than six months, or by both.

D. Reporting

Monitoring results must be reported within a Discharge Monitoring Report (DMR). Monitoring results must be submitted electronically (NetDMR web-based application) no later than the 28th day of the month following the end of the monitoring period. If no discharge occurs during the entire reporting period, "No Discharge" must be reported within the respective DMR. Monitoring reports must be electronically signed and certified in accordance with Part IV.G. "Signatory Requirements" of this permit.

All other reports (e.g. special conditions, compliance actions) must be submitted no later than the 28th day of the month following the completion due date, unless otherwise specified. All reports required herein, must be signed and certified in accordance with Part IV.G. "Signatory Requirements" of this permit and submitted to DEQ at the following address:

Montana Department of Environmental Quality
Water Protection Bureau
PO Box 200901
Helena, Montana 59620-0901

E. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on interim and final requirements contained in any Compliance Schedule of this permit shall be submitted to the Department in either electronic or paper format and be postmarked no later than 14 days following each schedule date unless otherwise specified in this permit.

F. Additional Monitoring by the Permittee

If the permittee monitors any additional parameters or any parameter more frequently than required by this permit using approved analytical methods as specified in this permit, the results of this monitoring shall be included in the analysis and reporting of the data submitted in the Discharge Monitoring Report. Such increased frequency shall also be indicated.

G. Records Contents

Records of monitoring information must include:

1. The date, exact place, and time of sampling or measurements;
2. The initials or name(s) of the individual(s) who performed the sampling or measurements;
3. The date(s) analyses were performed;
4. The time analyses were initiated;
5. The initials or name(s) of individual(s) who performed the analyses;
6. References and written procedures, when available, for the analytical techniques or methods used; and
7. The results of such analyses, including the bench sheets, instrument readouts, computer disks or tapes, etc., used to determine these results.

H. Retention of Records

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least three years from the date of the sample, measurement, report, or application. This period may be extended by the request of the Department at any time. Data collected on site, copies of Discharge Monitoring Reports, and a copy of this MGWPCS permit must be maintained on site during the duration of activity at the permitted location.

I. Twenty-Four Hour Notice of Noncompliance Reporting

1. The permittee shall report any serious incidents of noncompliance affecting the environment as soon as possible, but no later than twenty-four (24) hours from the time the permittee first became aware of the circumstances. The report shall be made to the Water Protection Bureau at

(406) 444-5546 or the Office of Disaster and Emergency Services at (406) 324-4777. The following examples are considered serious incidents:

- a. Any noncompliance which may seriously endanger health or the environment; or
 - b. Any unanticipated bypass which exceeds any effluent limitation in the permit (See Part III.G. of this permit, "Bypass of Treatment Facilities").
2. A written submission shall also be provided within five days of the time that the permittee becomes aware of the circumstances. The written submission shall contain:
 - a. A description of the noncompliance and its cause;
 - b. The period of noncompliance, including exact dates and times;
 - c. The estimated time noncompliance is expected to continue if it has not been corrected; and
 - d. Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
 3. The Department may waive the written report on a case-by-case basis if the oral report has been received within 24 hours by the Water Protection Bureau, by phone, at (406) 444-5546.
 4. Reports must be submitted to the addresses in Part II.D. of this permit, "Reporting of Monitoring Results."

J. Other Noncompliance Reporting

Instances of noncompliance not required to be reported within 24 hours must be reported at the time that monitoring reports for Part II.D. of this permit are submitted. The reports must contain the information listed in Part II.I.2. of this permit.

K. Inspection and Entry

The permittee shall allow the head of the Department, the Director, or an authorized representative thereof, upon the presentation of credentials and other documents as may be required by law, to:

1. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;

2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
3. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
4. Sample or monitor at reasonable times, for the purpose of assuring permit compliance, any substances or parameters at any location.

III. COMPLIANCE RESPONSIBILITIES

A. **Duty to Comply**

The permittee shall comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Montana Water Quality Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. The permittee shall give the Department advance notice of any planned changes at the permitted facility or of an activity which may result in permit noncompliance.

B. **Penalties for Violations of Permit Conditions**

The Montana Water Quality Act provides that any person who violates a permit condition of the Act is subject to civil or criminal penalties not to exceed \$25,000 per day or one year in prison, or both, for the first conviction, and \$50,000 per day of violation or by imprisonment for not more than two years, or both, for subsequent convictions. MCA 75-5-611(9)(a) also provides for administrative penalties not to exceed \$10,000 for each day of violation and up to a maximum not to exceed \$100,000 for any related series of violations. Except as provided in Part III.G. of this permit, "Bypass of Treatment Facilities," nothing in this permit shall be construed to relieve the permittee of the civil or criminal penalties for noncompliance.

C. **Need to Halt or Reduce Activity not a Defense**

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

D. **Duty to Mitigate**

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

E. Proper Operation and Maintenance

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit. However, the permittee shall operate, as a minimum, one complete set of each main line unit treatment process whether or not this process is needed to achieve permit effluent compliance.

F. Removed Substances

Collected screenings, grit, solids, sludge, or other pollutants removed in the course of treatment must be disposed of in such a manner so as to prevent any pollutant from entering any waters of the state or creating a health hazard.

G. Bypass of Treatment Facilities

1. **Bypass not exceeding limitations.** The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Parts III.G.2. and III.G.3. of this permit.

2. Notice:

- a. Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible, at least 10 days before the date of the bypass.
- b. Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required under Part II.I. of this permit, "Twenty-Four Hour Reporting."

3. Prohibition of bypass:

- a. Bypass is prohibited, and the Department may take enforcement action against a permittee for a bypass, unless:
 - 1) The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;

- 2) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - 3) The permittee submitted notices as required under Part III.G.2. of this permit.
- b. The Department may approve an anticipated bypass, after considering its adverse effects, if the Department determines that it will meet the three conditions listed above in Part III.G.3.a. of this permit.

IV. GENERAL REQUIREMENTS

A. Planned Changes

The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:

1. The alteration or addition could significantly change the nature or increase the quantity of pollutant discharged. This notification applies to pollutants which are not subject to effluent limitations in the permit; or
2. There are any planned substantial changes to the existing sewage sludge management practices of storage and disposal. The permittee shall give the Department notice of any planned changes at least 180 days prior to their implementation.

B. Anticipated Noncompliance

The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

C. Permit Actions

This permit may be revoked, modified and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

D. Duty to Reapply

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee shall apply for and obtain a new permit. The application must be submitted at least 180 days before the expiration date of this permit.

E. Duty to Provide Information

The permittee shall furnish to the Department, within a reasonable time, any information which the Department may request to determine whether cause exists for revoking, modifying and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Department, upon request, copies of records required to be kept by this permit.

F. Other Information

When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or any report to the Department, it shall promptly submit such facts or information with a narrative explanation of the circumstances of the omission or incorrect submittal and why they weren't supplied earlier.

G. Signatory Requirements

All applications, reports or information submitted to the Department must be signed and certified.

1. All permit applications shall be signed as follows:
 - a. For a corporation: by a responsible corporate officer:
 - b. For a partnership or sole proprietorship: by a general partner or the proprietor, respectively; or
 - c. For a municipality, State, Federal, or other public agency: by either a principal executive officer or ranking elected official.
2. All reports required by the permit and other information requested by the Department shall be signed by a person described above or by a duly authorized representative of that person. A person is considered a duly authorized representative only if:
 - a. The authorization is made in writing by a person described above and submitted to the Department; and
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility, such as

the position of plant manager, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters (a duly authorized representative may thus be either a named individual or an individual occupying a named position).

3. Changes to authorization. If an authorization under Part IV.G.2. of this permit is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Part IV.G.2. of this permit must be submitted to the Department prior to or together with any reports, information, or applications to be signed by an authorized representative.
4. Certification. Any person signing a document under this section shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

H. Penalties for Falsification of Reports

The Montana Water Quality Act provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction be punished by a fine of not more than \$25,000 per violation, or by imprisonment for not more than six months per violation, or by both.

I. Availability of Reports

All reports prepared in accordance with the terms of this permit must be available for public inspection at the offices of the Department and the EPA. Permit applications, permits and effluent data must not be considered confidential and must also be available for public inspection.

J. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject under Section 311 of the Clean Water Act.

K. Property or Water Rights

The issuance of this permit does not convey any property or water rights of any sort, or any exclusive privileges, nor does it authorize any injury to private property, any invasion of personal rights, or any infringement of federal, state or local laws or regulations.

L. Severability

The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, must not be affected thereby.

M. Transfers

This permit may be automatically transferred to a new permittee if:

1. The current permittee notifies the Department at least 30 days in advance of the proposed transfer date;
2. The notice includes a written agreement between the existing and new permittees containing a specific date for transfer of permit responsibility, coverage, and liability between them;
3. The Department does not notify the existing permittee and the proposed new permittee of the intent to revoke or modify and reissue the permit. If this notice is not received, the transfer is effective on the date specified in the agreement mentioned in Part IV.M.2. of this permit; and
4. Required annual and application fees have been paid.

N. Fees

The permittee is required to submit payment of an annual fee as set forth in ARM 17.30.201. If the permittee fails to pay the annual fee within 90 days after the due date for the payment, the Department may:

1. Impose additional fee assessment(s) computed at the rates established under ARM 17.30.201; and

2. Suspend the processing of the application for a permit or authorization or, if the nonpayment involves an annual permit fee, suspend the permit, certificate or authorization for which the fee is required. The Department may lift suspension at any time up to one year after the suspension occurs if the holder has paid all outstanding fees, including all penalties, assessments and interest imposed under this sub-section. Suspensions are limited to one year, after which the permit will be terminated.

O. Reopener Provisions

This permit may be reopened and modified (following proper administrative procedures) to include the appropriate effluent limitations (and compliance schedule, if necessary), or other appropriate requirements if one or more of the following events occurs:

1. **Water Quality Standards:** The water quality standards of the receiving water(s) to which the permittee discharges are modified in such a manner as to require different effluent limits than contained in this permit; or
2. **Water Quality Standards are Exceeded:** If it is found that water quality standards or trigger values, excluding mixing zones designated by ARM 17.30.501-518, for parameters included in the permit or others, the department may modify the effluent limits or water management plan.

V. DEFINITIONS

1. **“30-day (and Monthly) Average”** other than for *E. coli* bacteria, means the arithmetic average of all individual daily discharge measurements during a consecutive 30-day period or calendar month, whichever is applicable (see Daily Discharge). The arithmetic average must not include any individual daily measurements collected on days in which discharge did not occur (e.g. flow measurements). Geometric means must be calculated for the *E. coli* bacteria parameter.
2. **“90-day (and Quarterly) Average”** other than for *E. coli* bacteria, means the arithmetic average of all individual daily discharge measurements during a consecutive 90-day period or calendar quarter, whichever is applicable (see Daily Discharge). The arithmetic average must not include any individual daily measurements collected on days in which discharge did not occur (e.g. flow measurements). Geometric means must be calculated for the *E. coli* bacteria parameter.

3. **"180-day (and Six-Month or Semi-Annual) Average"** other than for *E. coli* bacteria, means the arithmetic average of all individual daily discharge measurements collected during a consecutive 180-day period or calendar half-year, whichever is applicable (see Daily Discharge). The arithmetic average must not include any individual daily measurements collected on days in which discharge did not occur (e.g. flow measurements). Geometric means must be calculated for the *E. coli* bacteria parameter.
4. **"Act"** means the Montana Water Quality Act, Title 75, chapter 5, MCA.
5. **"Annual Average Load"** means the arithmetic mean of all calculated individual daily average loads (lbs/day) recorded during the calendar year, multiplied by 365 (days/year) for a monitored parameter.
6. **"Annual Maximum Limit"** means the maximum allowable discharge of a parameter during a calendar year (or defined 365-day period).
7. **"Best management practices" ("BMPs")** means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of state waters. BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.
8. **"BOD₅"** means the five-day measure of the biochemical oxygen demand parameter.
9. **"Bypass"** means the intentional diversion of waste streams from any portion of a treatment facility.
10. **"Composite Sample"** means a sample that consists of two or more discrete aliquots. Composite samples must be flow proportioned. The composite sample must, as a minimum, contain at least four (4) samples collected over the compositing period. Unless otherwise specified, the time between the collection of the first sample and the last sample must not be less than six (6) hours nor more than 24 hours. Acceptable methods for preparation of composite samples are as follows:
 - a. Constant time interval between samples, sample volume proportional to flow rate at time of sampling;

- b. Constant time interval between samples, sample volume proportional to total flow (volume) since last sample. For the first sample, the flow rate at the time the sample was collected may be used;
 - c. Constant sample volume, time interval between samples proportional to flow (i.e. sample taken every "X" gallons of flow); and,
 - d. Continuous collection of sample, with sample collection rate proportional to flow rate.
11. **"CFR"** means Code of Federal Regulations.
 12. **"CFU"** means Colony Forming Units.
 13. **"Continuous"** means a measurement occurring without interruption throughout the operating hours of the facility, except for infrequent shutdowns for maintenance process changes, or other similar activities.
 14. **"Daily Discharge"** means the discharge of a parameter (or pollutant) measured during a calendar day (or any 24-hour period that reasonably represents the calendar day for purposes of sampling). For parameters with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the parameter discharged over the day. For parameters with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic average of all measurements (or samples) collected over the day.
 15. **"Daily Maximum"** means the highest individual measured daily value occurring in a defined reporting period (see Daily Discharge).
 16. **"Daily Maximum Limit"** means the maximum allowable discharge of a parameter for any calendar day (see Daily Discharge).
 17. **"DEQ"** means the Montana Department of Environmental Quality.
 18. **"Department"** means the Montana Department of Environmental Quality.
 19. **"Discharge"** means the injection, deposit, dumping, spilling, leaking, placing, or failing to remove any pollutant so that it or any constituent thereof may enter into state waters, including ground water.
 20. **"Grab Sample"** means a sample which is taken from a waste stream on a one-time basis without consideration of flow rate of the effluent or without consideration for time.

21. **“Instantaneous”** means a single reading, observation, or measurement.
22. **“Load Limits”** are mass-based discharge limits expressed in units such as lbs/day.
23. **“Mixing Zone”** means a limited area of a surface water body or ground water bearing zone where initial dilution of a discharge takes place and where certain water quality standards may be exceeded.
24. **“Nondegradation”** means the prevention of a significant change in water quality that lowers the quality of high quality water for one or more parameters. Also, the prohibition of any increase in discharge that exceeds the design capacity or limitations established under or determined from a permit or approval issued by the Department prior to April 29, 1993.
25. **“RRV”** means Required Reporting Values (DEQ Circular 7).
26. **“Severe Property Damage”** means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
27. **“TSS”** means the total suspended solids parameter.
28. **“Total Inorganic Nitrogen (TIN)”** means the arithmetic sum of Nitrate + Nitrite and Ammonia.
29. **“Total Nitrogen (TN)”** means the arithmetic sum of Nitrate + Nitrite and Total Kjeldahl Nitrogen.