



**PUBLIC NOTICE NO. MT-19-19**  
**September 9, 2019**

PURPOSE OF PUBLIC NOTICE

The purpose of this notice is to state the Department's intention to issue a wastewater discharge permit to the facility listed in this notice. This permit is issued by the Department under the authority of 75-5-402, Montana Code Annotated (MCA) and the Administrative Rules of Montana 17.30.1001 et seq., Montana Ground Water Pollution Control System (MGWPCS). The Water Protection Bureau has prepared a draft permit for the facility listed below. Copies of the draft permit, fact sheet, and environmental assessment are available upon request from the Water Protection Bureau or on the Department's website [www.deq.mt.gov](http://www.deq.mt.gov)

APPLICANT INFORMATION

APPLICANT NAME: Fox Crossing III Homeowners Association, Inc.

FACILITY NAME: Fox Crossing Residential Subdivision Phase III

FACILITY LOCATION: Latitude: 46.63134°, Longitude: -111.89975°  
NE ¼ of Section 18, Township 10 N, Range 2 W,  
Lewis and Clark County

RECEIVING WATER: Outfall 001 - Class I ground water

PERMIT NUMBER: MTX000174

A determination has been made by DEQ to reissue a Montana Ground Water Pollution Control System (MGWPCS) permit, MTX000174, to Fox Crossing III Homeowners Association, Inc. for Fox Crossing Residential Subdivision Phase III. This permitting action authorizes discharge of treated wastewater to ground water. The scope of this permitting action is for the continued operation and maintenance of the wastewater treatment and disposal system.

Each home has an individual septic tank for primary treatment. Effluent flows by gravity to a lift station that pumps to a recirculation tank. The recirculation tank supplies water to the recirculating sand filter (RSF) where it undergoes secondary treatment. The RSF routes 80% of the treated effluent back into the recirculation tank and 20% to the dose tank that pressure-doses to a subsurface drain field.

PUBLIC COMMENT

Public comments are invited **ANYTIME PRIOR TO CLOSE OF BUSINESS October 10, 2019.** Comments may be directed to the DEQ Water Quality Division, Water Protection Bureau, PO Box 200901, Helena, MT 59620. All comments received or postmarked **PRIOR TO CLOSE OF BUSINESS October 10, 2019** will be considered in the formulation of final determinations to be imposed on the permit. If you wish to comment electronically, you may e-mail the Department at [DEQWPBPublicComments@mt.gov](mailto:DEQWPBPublicComments@mt.gov).

During the public comment period provided by the notice, the Department will accept requests for a public hearing. A request for a public hearing must be in writing and must state the nature of the issue proposed to be raised in the hearing (ARM 17.30.1024).

The Department will respond to all substantive comments and issue a final decision within sixty days of this notice or as soon as possible thereafter. Additional information may be obtained upon request by calling (406) 444-5546 or by writing to the aforementioned address. The complete administrative record, including permit application and other pertinent information, is maintained at the Water Protection Bureau office in Helena and is available for review during business hours.

**PUBLIC NOTICE NO. MT-19-19**  
**September 9, 2019**