Facility Summary in BEAVERHEAD County in the City of DELL

Location: DELL CENTER LLC
24 MAIN ST PO BOX 240036
DELL, MT 59724 BEAVERHEAD
Contact: (406) 276-3332

Sys Fac ID: 01-01523
Last Inspected On: 10/8/2014
Operating Permit Renewal Date: 2/7/2018

Owners/Operators: Dell Center LLC, Owner (406)-276-3332 ELLEN BURDICK
PO BOX 240064
DELL MT 59724-0064

Jeanne Schnitzler, UST Class A Operator
Joel Schnitizer, UST Class B Operator
Jeanne Schnitzler, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	11	10/6/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5045		9/24/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
5	11	10/6/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5046		9/24/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			TLS-350/Gilbarco EMC , Veeder Root		
6	11	10/6/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5047		9/24/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
7	11	10/6/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5048		9/24/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DELL

Location: DELL AIRPORT CANYON RANCH
DELL AIRPORT
DELL, MT 59724 BEAVERHEAD

Sys Fac ID: 01-09843
Last Inspected On: 10/30/2015
Operating Permit Renewal Date:

Contact:

Owners/Operators: Montana Department of Transportation, Owner (406)-444-6163 2701 PROSPECT
PO BOX 201001
HELENA MT 59620

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	27	6/13/1989	Cathodically Protected Steel	No Piping	High Level Alarm
516			Double-Walled	None	Yes
Temporarily Out of Use			Not Required	Pressurized	Galvanic
Jet Fuel		10/28/2015	Manual Interstitial Monitor	Deferred	
10,000					

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: THE MINI INC
410 N MONTANA ST
DILLON, MT 59725 BEAVERHEAD

Contact: Jeff DuBose, (406) 683-6168

Sys Fac ID: 01-01215
Last Inspected On: 10/9/2015
Operating Permit Renewal Date: 10/13/2018

Owners/Operators: The Mini Inc, Owner (406)-683-6168 410 N MONTANA ST
DILLON MT 59725-3313

Mandy Cerino, UST Class A Operator
Jeffrey DuBose, UST Class A Operator
Lori DuBose, UST Class A Operator
Cathie Wasser, UST Class A Operator
Don Williams, UST Class A Operator
JimiKaye Balsley, UST Class B Operator
Jill Bertrand, UST Class B Operator
Brian Boyd, UST Class B Operator
Mandy Cerino, UST Class B Operator
Rachel Cherry, UST Class B Operator
Katie Corrigan, UST Class B Operator
Jeffrey DuBose, UST Class B Operator
Lori DuBose, UST Class B Operator
Lynette Goodale, UST Class B Operator
Vonnica Knapp, UST Class B Operator
Shadeen Novich, UST Class B Operator
Margaret Smith, UST Class B Operator
Cathie Wasser, UST Class B Operator
Lydia Wellborn, UST Class B Operator
Dennis A Franks, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	5/6/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3088		10/9/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: THE MINI INC
410 N MONTANA ST
DILLON, MT 59725 BEAVERHEAD

Contact: Jeff DuBose, (406) 683-6168

Sys Fac ID: 01-01215
Last Inspected On: 10/9/2015
Operating Permit Renewal Date: 10/13/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	18	5/6/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3089		10/9/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			Gilbarco EMC Basic , Gilbarco		
6	18	5/6/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3090		10/9/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: DIETRICHS COLLEGE EXXON UST
636 S ATLANTIC ST
DILLON, MT 59725 BEAVERHEAD

Contact: Timothy Dietrich, (406) 683-0070

Sys Fac ID: 01-05401
Last Inspected On: 11/14/2015
Operating Permit Renewal Date:

Owners/Operators: Timothy Dietrich, Owner (406)-683-0070 636 S ATLANTIC ST
DILLON MT 59725-2725

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	7/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3227			None	None	Yes
Temporarily Out of Use		7/1/2004	Not Required	Safe Suction	Galvanic
Gasoline		11/14/2015	Tank Tightness Testing, Inventory Reconciliation	Deferred	
6,000					
2	22	7/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3226			None	None	Yes
Temporarily Out of Use		7/1/2004	Not Required	Safe Suction	Galvanic
Gasoline		11/14/2015	Tank Tightness Testing, Inventory Reconciliation	Deferred	
10,000					

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: COUNTY COURTHOUSE
2 S PACIFIC ST
DILLON, MT 59725 BEAVERHEAD

Contact: Chris Kraft, (406) 683-2642

Sys Fac ID: 01-05668
Last Inspected On: 7/2/2014
Operating Permit Renewal Date: 11/6/2017

Owners/Operators: Beaverhead County Clerk, Owner (406)-683-5245 2 S PACIFIC ST DILLON MT 59725-4000

Christopher Booth, UST Class A Operator
Jay Hansen, UST Class A Operator
Chris Kraft, UST Class A Operator
Jim Sivils, UST Class A Operator
Chris Kraft, UST Class B Operator
Christopher Booth, UST Class B Global Operator
Jay Hansen, UST Class B Global Operator
Jim Sivils, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	2/1/1993	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
421			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		7/2/2014	Automatic Tank Gauging 0.2	Deferred	
2,000		3/1/2008	TLS-250 , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: TOWN PUMP INC DILLON 1
101 E HELENA ST
DILLON, MT 59725 BEAVERHEAD
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 01-08695
Last Inspected On: 2/4/2015
Operating Permit Renewal Date: 2/6/2018

Owners/Operators: Town Pump Inc Butte, Owner (406)-782-9121 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	55	4/14/1961	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4794			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/12/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	30	1/1/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4795			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/12/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	30	1/1/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4796			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/12/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: TOWN PUMP INC DILLON 2
635 N MONTANA ST
DILLON, MT 59725 BEAVERHEAD
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 01-08696
Last Inspected On: 6/30/2015
Operating Permit Renewal Date: 10/14/2018

Owners/Operators: Major Brands Distributing Imports Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	9/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2375		3/30/2015	None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
2	26	9/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2376		3/30/2015	None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
4	26	9/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2372		3/30/2015	None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: TOWN PUMP INC DILLON 2
635 N MONTANA ST
DILLON, MT 59725 BEAVERHEAD
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 01-08696
Last Inspected On: 6/30/2015
Operating Permit Renewal Date: 10/14/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	26	9/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2373		3/30/2015	None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
6	26	9/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2374		3/30/2015	None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
7	17	5/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4541			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	15	8/20/2001	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4356		3/30/2015	Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: TOWN PUMP INC DILLON 2
635 N MONTANA ST
DILLON, MT 59725 BEAVERHEAD

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 01-08696
Last Inspected On: 6/30/2015
Operating Permit Renewal Date: 10/14/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	15	8/20/2001	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4357		3/30/2015	Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
5,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: ROCKY MOUNTAIN SUPPLY INC DILLON
700 N MONTANA ST
DILLON, MT 59725 BEAVERHEAD

Contact: Jason Rorabaugh, (406) 683-2308

Sys Fac ID: 01-10034
Last Inspected On: 11/2/2015
Operating Permit Renewal Date: 2/19/2019

Owners/Operators: Rocky Mountain Supply Inc, Owner (406)-388-4008 JASON RORABAUGH PETROLEUM MGR
PO BOX 129
BELGRADE MT 59714-3035

Jason Rorabaugh, UST Class A Operator
Tari Eaves, UST Class B Operator
Michael Holton, UST Class B Operator
Kevin Lathrop, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	35	1/12/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3900			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/22/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		1/27/2009	TLS-350/Gilbarco EMC , Veeder Root		
2	35	1/12/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3901			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/22/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		1/27/2009	TLS-350/Gilbarco EMC , Veeder Root		
3	35	1/12/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3902			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/22/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		1/27/2009	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: ROCKY MOUNTAIN SUPPLY INC DILLON
700 N MONTANA ST
DILLON, MT 59725 BEAVERHEAD

Contact: Jason Rorabaugh, (406) 683-2308

Sys Fac ID: 01-10034
Last Inspected On: 11/2/2015
Operating Permit Renewal Date: 2/19/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	35	1/12/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3903			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/22/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		1/27/2009	TLS-350/Gilbarco EMC , Veeder Root		
5	35	1/12/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3904			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/22/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		1/27/2009	TLS-350/Gilbarco EMC , Veeder Root		
9	17	12/1/1998	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3905			Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/25/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		6/22/2015	TLS-350/Gilbarco EMC , Veeder Root		
10	17	12/1/1998	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3906			Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/25/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,100		6/22/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: ROCKY MOUNTAIN SUPPLY INC DILLON
700 N MONTANA ST
DILLON, MT 59725 BEAVERHEAD

Contact: Jason Rorabaugh, (406) 683-2308

Sys Fac ID: 01-10034
Last Inspected On: 11/2/2015
Operating Permit Renewal Date: 2/19/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	17	12/1/1998	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3907			Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/25/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
7,900		6/22/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: GATEWAY CANYON TRAVEL PLAZA
4055 REBICH LN
DILLON, MT 59725 BEAVERHEAD

Contact: Dustin Clint, (443) 745-8081

Sys Fac ID: 01-13101
Last Inspected On: 3/2/2015
Operating Permit Renewal Date: 3/3/2018

Owners/Operators: Beseckers Excavation & Trucking, Owner (937)-459-9159 4055 REBICH LN DILLON MT 59725

Dan Besecker, UST Class A Operator
Patricia Besecker, UST Class A Operator
Casey Palmer, UST Class A Operator
Emma Peterson, UST Class A Operator
Patricia Besecker, UST Class B Operator
Casey Palmer, UST Class B Operator
Dan Besecker, UST Class B Global Operator
Emma Peterson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	7/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4634			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		9/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	23	7/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4635			None	None	Yes
Currently in Use		7/1/2003	Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		9/29/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: GATEWAY CANYON TRAVEL PLAZA
4055 REBICH LN
DILLON, MT 59725 BEAVERHEAD
Contact: Dustin Clint, (443) 745-8081

Sys Fac ID: 01-13101
Last Inspected On: 3/2/2015
Operating Permit Renewal Date: 3/3/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	23	7/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4636			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		9/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		9/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
4	23	7/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4637			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		9/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		9/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
5	23	7/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4638			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		9/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		9/29/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: DILLON AIRPORT
2400 AIRPORT RD
DILLON, MT 59725 BEAVERHEAD

Contact: Denise DeVino, (406) 683-5242

Sys Fac ID: 56-13894
Last Inspected On: 1/9/2015
Operating Permit Renewal Date: 3/4/2018

Owners/Operators: Beaverhead County Clerk, Owner (406)-683-5245 2 S PACIFIC ST DILLON MT 59725-4000

Christopher Booth, UST Class A Operator
Jay Hansen, UST Class A Operator
Chris Kraft, UST Class A Operator
Jim Sivils, UST Class A Operator
Chris Kraft, UST Class B Operator
Christopher Booth, UST Class B Global Operator
Jay Hansen, UST Class B Global Operator
Jim Sivils, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	34	4/1/1982	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3995			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Jet Fuel		1/9/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		4/9/2014	Gilbarco EMC Basic , Gilbarco		
2	34	4/1/1982	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3996			Lined Interior/Impressed Current	None	Yes
Currently in Use		3/1/2009	Mechanical Line Leak Detector	Pressurized	Impressed Current
Aviation Gas		1/9/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		4/9/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in BEAVERHEAD County in the City of DILLON

Location: SAFEWAY 1581 DILLON
570 N MONTANA ST
DILLON, MT 59725 BEAVERHEAD

Contact: Shanna Sunderlin, (406) 596-0388

Sys Fac ID: 56-13989
Last Inspected On: 8/16/2016
Operating Permit Renewal Date: 11/5/2019

Owners/Operators: Safeway Stores Inc, Owner (425)-455-6545 1121 124TH AVE NE BELLEVUE WA 98005-2101

Rachel Jones, UST Class A Operator
Aaron Nelson, UST Class A Operator
Lynn Pehrson, UST Class A Operator
Rachel Jones, UST Class B Global Operator
Page Rost, UST Class B Global Operator
Shanna Sunderlin, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	16	10/9/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4222			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	16	10/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4223			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	16	10/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4224			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BEAVERHEAD County in the City of JACKSON

Location: CIRCLE S RANCH
30300 HIGHWAY 278
JACKSON, MT 59736 BEAVERHEAD
Contact: Cindy Yorton, (406) 834-3450

Sys Fac ID: 01-07024
Last Inspected On: 3/13/2014
Operating Permit Renewal Date: 6/3/2017

Owners/Operators: Circle S of Montana, Owner (406)-834-3450 30300 HIGHWAY 278 JACKSON MT 59736-9700

Robert Bertch, UST Class A Operator
Cindy Yorton, UST Class A Operator
Robert Bertch, UST Class B Operator
Cindy Yorton, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	19	7/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4228			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1	Deferred	
1,000					
6	19	7/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4229			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1	Deferred	
1,000					

Facility Summary in BEAVERHEAD County in the City of LIMA

Location: RALPHS EXXON
114 SOUTH HARRISON
LIMA, MT 59739 BEAVERHEAD

Contact: Kevin Stosich, (406) 276-3431

Sys Fac ID: 01-00671
Last Inspected On: 8/8/2016
Operating Permit Renewal Date: 9/21/2019

Owners/Operators: Kevin Stosich, Owner (406)-276-3376 T & R ENTERPRISES INC
PO BOX 206
LIMA MT 59739-0206

Kevin Stosich, UST Class A Operator
Kevin Stosich, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	18	9/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2078		7/28/2016	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			Gilbarco EMC Basic , Gilbarco		
8	18	9/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2079		7/28/2016	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in BEAVERHEAD County in the City of LIMA

Location: LIMA SCHOOL DIST 12 INC
1 N HARRISON ST
LIMA, MT 59739 BEAVERHEAD

Contact: Tim Slater Jr, (406) 276-3571

Sys Fac ID: 01-07158
Last Inspected On: 8/27/2014
Operating Permit Renewal Date: 1/17/2018

Owners/Operators: School Dist 12 Lima, Owner (406)-276-3571 PO BOX 186
LIMA MT 59739-0186

Walt Patterson, UST Class A Operator
Walt Patterson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	24	6/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1535			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Diesel		8/27/2014	Manual Interstitial Monitor	Continuous Interstitial Monitor	
10,000		7/9/2012	Other , Other		

Facility Summary in BEAVERHEAD County in the City of WISDOM

Location: BIG HOLE PETROLEUM INC
318 MT HIGHWAY 43 PO BOX 175
WISDOM, MT 59761 BEAVERHEAD

Contact: Ed Stede, (406) 689-3225

Sys Fac ID: 01-02173
Last Inspected On: 5/1/2014
Operating Permit Renewal Date: 7/30/2017

Owners/Operators: Edward Stede, Owner (406)-689-3225 PO BOX 175 WISDOM MT 59761-0175

Edward Stede, UST Class A Operator
Edward Stede, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	3/10/1985	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3323			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		5/1/2014	Stat. Inventory Reconcilitation	Deferred	
2,000		5/3/2005			
2	31	3/10/1985	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3324			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		5/1/2014	Stat. Inventory Reconcilitation	Deferred	
1,000		5/3/2005			

Facility Summary in BEAVERHEAD County in the City of WISE RIVER

Location: WISE RIVER MERCANTILE
65221 HIGHWAY 43
WISE RIVER, MT 59762 BEAVERHEAD

Contact: Connie Holland, (406) 832-3271

Sys Fac ID: 01-02080
Last Inspected On: 4/29/2016
Operating Permit Renewal Date: 10/13/2019

Owners/Operators:

JimCon Inc, Owner	(406)-832-3271	PO BOX 173 WISE RIVER MT 59762
Wise River Mercantile, Operator	(406)-832-3271	65221 HWY 43 WISE RIVER MT 59762

Connie Holland, UST Class A Operator
Dawna Wilkinson, UST Class A Operator
Connie Holland, UST Class B Operator
Laura Delaney, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	18	6/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1224			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
2,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in BIG HORN County in the City of CROW AGENCY

Location: TEEPEE SERVICE INC
EXIT 509 INTERSTATE 90 PO BOX 280
CROW AGENCY, MT 59022 BIG HORN

Contact: Jim Watt, (406) 638-7277

Sys Fac ID: 02-07334
Last Inspected On: 1/27/2016
Operating Permit Renewal Date: 7/7/2019

Owners/Operators: Teepee Service Inc, Owner (406)-638-2269 PO BOX 245
CROW AGENCY MT 59022-0245

James Watt, UST Class A Operator
James Watt, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	21	7/3/1995	Steel Clad	Flexible Plastic	High Level Alarm
2097			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/16/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	21	7/3/1995	Steel Clad	Flexible Plastic	High Level Alarm
2098			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/16/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BIG HORN County in the City of CROW AGENCY

Location: LITTLE BIG HORN CAMP
INTERSTATE 90 & US HIGHWAY 212
CROW AGENCY, MT 59022 BIG HORN

Contact: Paul Pryor, (406) 861-4859

Sys Fac ID: 02-08937
Last Inspected On: 9/11/2013
Operating Permit Renewal Date:

Owners/Operators: Pryor LLC, Owner (406)-638-2870 PO BOX 1152
CROW AGENCY MT 59022

R F Mische, UST Class A Operator
R F Mische, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	17	1/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3919			Double-Walled	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		9/13/2010	Continuous Interstitial Monitor	Not Listed	
8,000					
4	17	1/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3920			Double-Walled	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		9/13/2010	Continuous Interstitial Monitor	Not Listed	
12,000					

Facility Summary in BIG HORN County in the City of CROW AGENCY

Location: Crow Nation Express
US HIGHWAY 212 & INTERSTATE 90
CROW AGENCY, MT 59022 BIG HORN
Contact: Robin Vallie, (406) 245-6376

Sys Fac ID: 02-10867
Last Inspected On: 12/16/2014
Operating Permit Renewal Date: 1/6/2018

Owners/Operators: Crow Tribe of Indians, Owner (406)-638-2400 PO BOX 179
CROW AGENCY MT 59022

Mykel Stockton, UST Class A Operator
Robin Vallie, UST Class A Operator
John Wilson, UST Class A Operator
Robin Vallie, UST Class B Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Mykel Stockton, UST Class B Global Operator
John Wilson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	16	2/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4174			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/21/2011	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		8/2/2015	TLS-350/Gilbarco EMC , Veeder Root		
6	16	2/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4175			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/21/2011	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		8/2/2015	TLS-350/Gilbarco EMC , Veeder Root		
7	16	2/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4176			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/21/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		8/2/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BIG HORN County in the City of CROW AGENCY

Location: Crow Nation Express
US HIGHWAY 212 & INTERSTATE 90
CROW AGENCY, MT 59022 BIG HORN
Contact: Robin Vallie, (406) 245-6376

Sys Fac ID: 02-10867
Last Inspected On: 12/16/2014
Operating Permit Renewal Date: 1/6/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	16	2/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4177			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/21/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		8/2/2015	TLS-350/Gilbarco EMC , Veeder Root		
9	16	2/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4178			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/21/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		8/2/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BIG HORN County in the City of FORT SMITH

Location: YELLOWTAIL MARKET
PARKDALE COURT
FORT SMITH, MT 59035 BIG HORN

Contact: Kerry Stewart, (406) 666-2333

Sys Fac ID: 02-05862
Last Inspected On: 5/19/2015
Operating Permit Renewal Date: 10/20/2018

Owners/Operators:

Crow Tribe of Indians, Owner	(406)-638-2059	PO BOX 159 CROW AGENCY MT 59022
Apsaalooke Nights Casino, Operator	(406)-638-4440	PO BOX 609 CROW AGENCY MT 59022

Brenda Fenner, UST Class A Operator
Kerry Stewart, UST Class A Operator
Pamela BirdHat, UST Class B Operator
Brenda Fenner, UST Class B Operator
Pamela BirdHat, UST Class B Global Operator
Kerry Stewart, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	18	3/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1210			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		1/18/2015	TLS-350/Gilbarco EMC , Veeder Root		
4	18	3/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1211			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		1/20/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BIG HORN County in the City of FORT SMITH

Location: BIGHORN CANYON MAINTENANCE FACILITY
5TH AVE B
FORT SMITH, MT 59035 BIG HORN
Contact: Joe Bartlette, (406) 666-2412

Sys Fac ID: 02-09815
Last Inspected On: 11/30/2015
Operating Permit Renewal Date: 4/26/2019

Owners/Operators: National Park Service Yellowtail, Owner (406)-666-3311 PO BOX 7458 YELLOWTAIL MT 59035-7458

Lyndon Driftwood, UST Class A Operator
Jesse Macklin, UST Class A Operator
Jesse Macklin, UST Class B Operator
Lyndon Driftwood, UST Class B Global Operator
Jesse Macklin, UST Class B Global Operator
Roger Watson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	28	1/1/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm, Ball Float Valve
1746		12/18/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		11/5/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
2,000		11/5/2015	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
3	28	1/1/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm, Ball Float Valve
1745		12/18/2012	Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/5/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
2,000		11/5/2015	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BIG HORN County in the City of FORT SMITH

Location: OK A BEH MARINA
5TH AVE B
FORT SMITH, MT 59035 BIG HORN

Contact: Ernest Redden, (406) 666-3311

Sys Fac ID: 56-13877
Last Inspected On: 5/11/2015
Operating Permit Renewal Date: 5/11/2018

Owners/Operators: National Park Service Yellowtail, Owner (406)-666-3311 PO BOX 7458
YELLOWTAIL MT 59035-7458

Lyndon Driftwood, UST Class A Operator
Jesse Macklin, UST Class A Operator
Sami Walking Bear, UST Class A Operator
Roger Watson, UST Class A Operator
Ferole Lopez-Spotted Bear, UST Class B Operator
Jesse Macklin, UST Class B Operator
Brenda Pretty Paint, UST Class B Operator
MaeZee Pretty Paint, UST Class B Operator
Sami Walking Bear, UST Class B Operator
Lyndon Driftwood, UST Class B Global Operator
Jesse Macklin, UST Class B Global Operator
Victoria J Pretty Paint, UST Class B Global Operator
Roger Watson, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	5/14/1990	Cathodically Protected Steel	Flexible Plastic	Positive Shutoff
1747		6/18/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/3/2012	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
2,000		5/29/2016	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BIG HORN County in the City of GARRYOWEN

Location: GARRYOWEN CONOCO
GARRYOWEN FRONTAGE RD
GARRYOWEN, MT 59031 BIG HORN

Contact: Chris Kortlander, (406) 638-2020

Sys Fac ID: 02-03284
Last Inspected On: 7/14/2014
Operating Permit Renewal Date: 8/13/2017

Owners/Operators:

Neda LLC, Owner	(406)-638-2020	ATTN CHRIS KORTLANDER PO BOX 200 GARRYOWEN MT 59031-0200
Chris Kortlander, Operator	(406)-638-2020	PO BOX 200 GARRYOWEN MT 59031-0200

Chris Kortlander, UST Class A Operator
Petra Pretty On Top, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	6/21/1996	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3392			Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/29/2008	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
8,000		6/18/2013	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
2	20	6/21/1996	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3393			Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/29/2008	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
12,000		6/18/2013	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BIG HORN County in the City of HARDIN

Location: DOLLIES CONVENIENCE STORE
804 W 3RD ST
HARDIN, MT 59034 BIG HORN

Contact: Chetan Pater, (605) 517-1140

Sys Fac ID: 02-00061
Last Inspected On: 1/21/2015
Operating Permit Renewal Date:

Owners/Operators:

Jagadish LLC, Owner	(605)-517-1140	804 W 3RD ST HARDIN MT 59034
Pooja LLC DBA Dollies, Operator	(605)-517-1140	804 W 3RD ST HARDIN MT 59034

Megan Ashinhurst, UST Class A Operator
Victor F Uffelman, UST Class A Operator
Angelica Wiley, UST Class A Operator
Corri Duncan, UST Class B Operator
Constance Weigand, UST Class B Operator
Megan Ashinhurst, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	12/20/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4463			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/21/2015	TLS-300 , Veeder Root		
3	13	12/16/2002	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4773			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		1/21/2015	TLS-300 , Veeder Root		

Facility Summary in BIG HORN County in the City of HARDIN

Location: GOOD 2 GO STORE LLC
1600 N CRAWFORD AVE
HARDIN, MT 59034 BIG HORN

Contact: Brad Hinze, (406) 665-2920

Sys Fac ID: 02-00538
Last Inspected On: 8/18/2016
Operating Permit Renewal Date: 12/11/2019

Owners/Operators:

#8 Hardin Montana Property LLC, Owner	(208)-523-6582	PO BOX 50620 IDAHO FALLS ID 83405
Good 2 Go Stores LLC, Operator	(307)-899-1051	1600 NORTH CRAWFORD HARDIN MT 59034

Paul Ferro, UST Class A Operator
Brad Hinze, UST Class A Operator
Kenneth Knight, UST Class A Operator
Paul Ferro, UST Class B Operator
Brad Hinze, UST Class B Global Operator

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
1	42	4/12/1974	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3790			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/8/2007	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		7/31/2010	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	42	4/12/1974	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3789			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/28/2007	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		7/31/2010	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	42	4/12/1974	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3791			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		8/28/2007	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		7/31/2010	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BIG HORN County in the City of HARDIN

Location: GOOD 2 GO STORE LLC
1600 N CRAWFORD AVE
HARDIN, MT 59034 BIG HORN

Contact: Brad Hinze, (406) 665-2920

Sys Fac ID: 02-00538
Last Inspected On: 8/18/2016
Operating Permit Renewal Date: 12/11/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	42	4/12/1974	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3792			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/7/2007	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		7/31/2010	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BIG HORN County in the City of HARDIN

Location: TOWN AND COUNTRY SUPPLY #48
225 W RAILROAD ST PO BOX 385
HARDIN, MT 59034 BIG HORN

Contact: Ronald Nedens, (406) 665-1103

Sys Fac ID: 02-01403
Last Inspected On: 8/18/2016
Operating Permit Renewal Date: 12/10/2019

Owners/Operators: Town & Country Supply Association, Owner/Operator (406)-628-6314 PO BOX 367 LAUREL MT 59044-0367

Steven Shelton, UST Class A Operator
Leonard Zier, UST Class A Operator
Connie Roundtree, UST Class B Global Operator
Steven Shelton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	6/1/1990	Bare Steel	Fiberglass Reinforced Plastic	
923	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
6,000		8/18/2016			
3	26	6/1/1990	Bare Steel	Fiberglass Reinforced Plastic	
924	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
6,000		8/18/2016			
4	26	6/1/1990	Bare Steel	Fiberglass Reinforced Plastic	
925	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
6,000		8/18/2016			
5	26	6/1/1990	Bare Steel	Fiberglass Reinforced Plastic	
926	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
6,000		8/18/2016			

Facility Summary in BIG HORN County in the City of HARDIN

Location: WAGNER TRAVEL SHOPPE EXPRESS STOP
1424 N CRAWFORD AVE
HARDIN, MT 59034 BIG HORN

Contact: Larry Wagner, (406) 665-1061

Sys Fac ID: 02-04841
Last Inspected On: 11/19/2014
Operating Permit Renewal Date: 1/6/2018

Owners/Operators: Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756
BILLINGS MT 59103-1756

Mykel Stockton, UST Class A Operator
Sue Nutgens, UST Class B Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Mykel Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	26	1/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
2231			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
10,000		5/26/2011			
5	26	1/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
2232			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
10,000		5/26/2011			
6	26	1/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
2233			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
6,000		5/26/2011			

Facility Summary in BIG HORN County in the City of HARDIN

Location: WAGNER TRAVEL SHOPPE EXPRESS STOP
1424 N CRAWFORD AVE
HARDIN, MT 59034 BIG HORN

Contact: Larry Wagner, (406) 665-1061

Sys Fac ID: 02-04841
Last Inspected On: 11/19/2014
Operating Permit Renewal Date: 1/6/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	37	4/3/1979	Bare Steel	Fiberglass Reinforced Plastic	
2234	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
14,000		5/26/2011			
8	37	4/3/1979	Bare Steel	Fiberglass Reinforced Plastic	
2235	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
14,000		5/26/2011			
9	37	4/3/1979	Bare Steel	Fiberglass Reinforced Plastic	
2236	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
14,000		5/26/2011			

Facility Summary in BIG HORN County in the City of HARDIN

Location: FOX SERVICE CENTER UST
25 3RD ST E
HARDIN, MT 59034 BIG HORN

Contact: Dennis Fox, (406) 665-3648

Sys Fac ID: 02-05561
Last Inspected On: 2/23/1999
Operating Permit Renewal Date:

Owners/Operators: Hanser Holding LLC, Owner (406)-248-7795 430 S BILLINGS BLVD
BILLINGS MT 59101-4703

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	51	1/1/1965	Bare Steel	Other	
0			None	None	No
Currently in Use			Not Required	Not Listed	Galvanic
Hydraulic Fluid			Inventory Reconciliation, Not Listed	Not Listed	
40					
11	51	1/1/1965	Bare Steel	Other	
0			None	None	No
Currently in Use			Not Required	Not Listed	Galvanic
Hydraulic Fluid			Inventory Reconciliation, Not Listed	Not Listed	
40					

Facility Summary in BIG HORN County in the City of HARDIN

Location: BAIRS TRUCK STOP HARDIN
315 13TH ST W
HARDIN, MT 59034 BIG HORN

Contact: Riding Dennis, (801) 936-5557

Sys Fac ID: 02-05752
Last Inspected On: 3/24/2016
Operating Permit Renewal Date: 6/1/2019

Owners/Operators: Alsaker Corp, Owner (509)-534-1502 DBA BROADWAY TRUCK STOPS
PO BOX 14646
SPOKANE VALLEY WA 99214-0646

Rocco Cooper, UST Class A Operator
Paul Dallas, UST Class A Operator
Sara Dibble, UST Class A Operator
Arthur Jemerigbe, UST Class A Operator
Paul Dallas, UST Class B Operator
Sara Dibble, UST Class B Operator
Arthur Jemerigbe, UST Class B Operator
Lynn Peterson, UST Class B Operator
Rocco Cooper, UST Class B Global Operator
Sara Dibble, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	47	4/25/1969	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3894			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		5/18/2016	Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
10,000		2/7/2013			
3	37	4/26/1979	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3895			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/18/2016	Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
10,000		1/4/2013			

Facility Summary in BIG HORN County in the City of HARDIN

Location: BAIRS TRUCK STOP HARDIN
315 13TH ST W
HARDIN, MT 59034 BIG HORN

Contact: Riding Dennis, (801) 936-5557

Sys Fac ID: 02-05752
Last Inspected On: 3/24/2016
Operating Permit Renewal Date: 6/1/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	47	4/25/1969	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3896			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/18/2016	Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
6,000		1/4/2013			

Facility Summary in BIG HORN County in the City of HARDIN

Location: L & B LAST STOP
531 E RAILWAY ST
HARDIN, MT 59034 BIG HORN

Sys Fac ID: 02-05856
Last Inspected On: 4/6/2016
Operating Permit Renewal Date: 7/16/2019

Contact: Lynette & Gary Vandersloot, (406) 665-3414

Owners/Operators:

Gary VanDersloot, Owner	(406)-665-3414	PO BOX 156 HARDIN MT 59034-0156
Lynette VanDersloot, Owner	(406)-665-3414	PO BOX 156 HARDIN MT 59034-0156

Lynette VanDersloot, UST Class A Operator
Lynette VanDersloot, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	17	1/1/1999	Steel Clad	Fiberglass	Flapper Valve (Auto Shutoff)
3915			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		5/29/2013	Manual Interstitial Monitor	Deferred	
4,000					
4	17	1/1/1999	Steel Clad	Fiberglass	Flapper Valve (Auto Shutoff)
3916			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		5/29/2013	Manual Interstitial Monitor	Deferred	
2,000					

Facility Summary in BIG HORN County in the City of HARDIN

Location: TOWN PUMP INC HARDIN
1010 N CRAWFORD AVE
HARDIN, MT 59034 BIG HORN

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 02-08703
Last Inspected On: 2/29/2016
Operating Permit Renewal Date: 4/27/2019

Owners/Operators: Town Pump of Hardin Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	10/1/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2377			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/20/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	32	10/1/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2378			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/20/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	32	10/1/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2379			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		11/20/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BIG HORN County in the City of HARDIN

Location: TOWN PUMP INC HARDIN
1010 N CRAWFORD AVE
HARDIN, MT 59034 BIG HORN

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 02-08703
Last Inspected On: 2/29/2016
Operating Permit Renewal Date: 4/27/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	35	4/14/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2380			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		11/20/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
5	39	1/1/1977	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2381			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/20/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
6	16	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4362			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/14/2009	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	16	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4363			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/14/2009	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BIG HORN County in the City of HARDIN

Location: TOWN PUMP INC HARDIN
1010 N CRAWFORD AVE
HARDIN, MT 59034 BIG HORN

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 02-08703
Last Inspected On: 2/29/2016
Operating Permit Renewal Date: 4/27/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	16	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4364			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/14/2009	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BIG HORN County in the City of HARDIN

Location: BIG HORN COUNTY COMMUNITY SERVICE FACILITY
809 N CUSTER AVE
HARDIN, MT 59034 BIG HORN

Contact: Craig Taft, (406) 665-1005

Sys Fac ID: 02-10287
Last Inspected On: 11/4/2014
Operating Permit Renewal Date: 1/17/2018

Owners/Operators: Big Horn County Health Dept, Owner (406)-665-8720 809 N CUSTER AVE HARDIN MT 59034-1311

Craig Taft, UST Class A Operator
Craig Taft, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	18	11/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
443			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		12/21/2011	Continuous Interstitial Monitor	Continuous Interstitial Monitor, Deferred	
2,000					

Facility Summary in BIG HORN County in the City of HARDIN

Location: MATOVICH OIL CO INC
900 4TH ST W
HARDIN, MT 59034 BIG HORN

Contact: Jon Matovich, (406) 665-1400

Sys Fac ID: 02-13423
Last Inspected On: 11/4/2014
Operating Permit Renewal Date: 3/5/2018

Owners/Operators: Matovich Oil Co Inc, Owner (406)-665-1400 PO BOX 431
HARDIN MT 59034-0431

John Darr Matovich, UST Class A Operator
John Darr Matovich, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	5/24/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1582			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		9/10/2014			
2	22	5/24/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1583			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		9/10/2014			
3	22	5/24/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1580			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
2,000		9/10/2014			
4	22	5/24/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1581			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
2,000		9/10/2014			

Facility Summary in BIG HORN County in the City of HARDIN

Location: HARDIN C STORE
1223 N CRAWFORD AVE
HARDIN, MT 59034 BIG HORN

Contact: Ronald Nedens, (406) 665-1155

Sys Fac ID: 02-13635
Last Inspected On: 9/6/2016
Operating Permit Renewal Date: 12/10/2019

Owners/Operators: Town & Country Supply Association, Owner/Operator (406)-628-6314 PO BOX 367
LAUREL MT 59044-0367

Steven Shelton, UST Class A Operator
Peggy DelCamp, UST Class B Operator
Ronnie Lane, UST Class B Operator
Steven Shelton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	7/1/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
927			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/6/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
16,000		9/2/2010	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	21	7/1/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
928			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/6/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
16,000		9/2/2010	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	21	7/1/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
929			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/6/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
16,000		9/2/2010	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in BIG HORN County in the City of HARDIN

Location: HARDIN C STORE
1223 N CRAWFORD AVE
HARDIN, MT 59034 BIG HORN

Contact: Ronald Nedens, (406) 665-1155

Sys Fac ID: 02-13635
Last Inspected On: 9/6/2016
Operating Permit Renewal Date: 12/10/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	21	7/1/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
930			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/6/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		9/2/2010	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
5	21	7/1/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
931			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/6/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		9/2/2010	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in BIG HORN County in the City of LODGE GRASS

Location: OUR LADY OF LORETTO CHURCH
HARDING AVE & HELEN ST
LODGE GRASS, MT 59050 BIG HORN

Contact: Jim Antoine, (406) 639-2254

Sys Fac ID: 02-09970
Last Inspected On: 12/16/2014
Operating Permit Renewal Date: 2/11/2018

Owners/Operators: Our Lady of Loretto Church, Owner (406)-639-2254 PO BOX 509
LODGE GRASS MT 59050-0509

Jim Antoine, UST Class A Operator
Jim Antoine, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	7/23/1990	Cathodically Protected Steel	Copper	High Level Alarm
1778			None	PVC	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Heating Oil		12/16/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
3,000		12/16/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in BIG HORN County in the City of LODGE GRASS

Location: FARMERS UNION OIL CO LODGE GRASS
HWY 87 PO BOX 560
LODGE GRASS, MT 59050 BIG HORN

Contact: Christel Smith, (406) 639-2413

Sys Fac ID: 02-09976
Last Inspected On: 4/23/2015
Operating Permit Renewal Date: 7/20/2018

Owners/Operators: Farmers Union Oil Co Lodge Grass, Owner (406)-639-2505 HC 45 BOX 922
LODGE GRASS MT 59050-9707

Debra Edwards, UST Class A Operator
DARIN BIGMEDICINE, UST Class B Operator
ALVIN EDWARDS, UST Class B Operator
Debra Edwards, UST Class B Operator
LORENE FLATMOUTH, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	17	12/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3603			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		4/23/2015	TLS-350/Gilbarco EMC , Veeder Root		
10	17	12/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3604			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		4/24/2015	TLS-350/Gilbarco EMC , Veeder Root		
11	17	12/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3605			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		4/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		4/23/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BIG HORN County in the City of LODGE GRASS

Location: LODGE GRASS SCHOOL DIST 27
124 N GEORGE ST
LODGE GRASS, MT 59050 BIG HORN
Contact: Jim Dabney, (406) 639-2304

Sys Fac ID: 02-10772
Last Inspected On: 10/24/2014
Operating Permit Renewal Date: 11/19/2017

Owners/Operators: School Dist 27 Lodge Grass, Owner (406)-639-2304 PO BOX 810
LODGE GRASS MT 59050

Leroy Wallace, UST Class A Operator
Leroy Wallace, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	31	4/4/1985	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4361			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel		10/17/2011	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, Deferred	
8,000			TLS-300 , Veeder Root		

Facility Summary in BIG HORN County in the City of PRYOR

Location: PLENTY COUPS HIGH SCHOOL
1 PRYOR SCHOOL LOOP PO BOX 229
PRYOR, MT 59066 BIG HORN

Contact: Whiteman Ross, (406) 259-7329

Sys Fac ID: 02-01131
Last Inspected On: 5/15/2015
Operating Permit Renewal Date: 8/26/2018

Owners/Operators: Plenty Coups High School, Owner (406)-259-7329 PO BOX 229
PRYOR MT 59066-0229

Ross Whiteman, UST Class A Operator
Ross Whiteman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	18	6/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1824			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		5/15/2015	Automatic Tank Gauging 0.2	Deferred	
1,000			TLS-300 , Veeder Root		
6	18	6/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1825			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		5/15/2015	Automatic Tank Gauging 0.2	Deferred	
2,000			TLS-300 , Veeder Root		

Facility Summary in BIG HORN County in the City of PRYOR

Location: PRYOR SELF SERVICE
704 MAK PUA AVE
PRYOR, MT 59066 BIG HORN

Contact: William Hoffman, (406) 252-9240

Sys Fac ID: 02-10164
Last Inspected On: 3/3/2014
Operating Permit Renewal Date: 5/16/2017

Owners/Operators: William A Hoffman, Owner (406)-252-9240 PO BOX 130 PRYOR MT 59066-0130
William A Hoffman, UST Class A Operator
William A Hoffman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	18	10/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1389			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		2/4/2011	Manual Interstitial Monitor	Not Listed	
2,000					

Facility Summary in BIG HORN County in the City of PRYOR

Location: SAINT CHARLES MISSION
ADDRESS UNKNOWN
PRYOR, MT 59066 BIG HORN

Contact: Bruce Spotted Bear, (406) 784-2746

Sys Fac ID: 56-04505
Last Inspected On: 12/18/2014
Operating Permit Renewal Date: 2/11/2018

Owners/Operators: St Labre Indian School, Owner (406)-666-2215 1000 TONGUE RIVER RD ASHLAND MT 59003

Dana Davis, UST Class A Operator
Leney Mcnac, UST Class A Operator
Ronald Messman, UST Class A Operator
Dana Davis, UST Class B Global Operator
Leney Mcnac, UST Class B Global Operator
Ronald Messman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	8/20/1990	Cathodically Protected Steel	Steel	High Level Alarm
1958			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/23/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BIG HORN County in the City of SAINT XAVIER

Location: PRETTY EAGLE SCHOOL
PO BOX 257
SAINT XAVIER, MT 59075 BIG HORN
Contact: David Duke, (406) 784-4597

Sys Fac ID: 02-04504
Last Inspected On: 11/5/2013
Operating Permit Renewal Date: 12/31/2016

Owners/Operators: St Labre Indian School, Owner (406)-666-2215 1000 TONGUE RIVER RD ASHLAND MT 59003

Dana Davis, UST Class A Operator
Leney Mcnac, UST Class A Operator
Ronald Messman, UST Class A Operator
Dana Davis, UST Class B Global Operator
Leney Mcnac, UST Class B Global Operator
Ronald Messman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	26	4/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1956			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		9/3/2013	Automatic Tank Gauging 0.2	Not Listed	
1,000					
4	26	4/1/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3672			None	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Heating Oil		9/3/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
10,000		11/5/2013			

Facility Summary in BIG HORN County in the City of WYOLA

Location: WYOLA ELEMENTARY SCHOOL
1 MONDELL AVE
WYOLA, MT 59089 BIG HORN

Contact: Linda Peas Bren, (406) 343-2722

Sys Fac ID: 02-13762
Last Inspected On: 6/14/2016
Operating Permit Renewal Date: 7/12/2019

Owners/Operators: School Dist 29 Wyola, Owner (406)-343-2722 PO BOX 66
WYOLA MT 59089-0066

Bradford E Crooked Arm Sr, UST Class A Operator
Brad Crookz, UST Class A Operator
Bradford E Crooked Arm Sr, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	17	7/1/1999	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
4370			Excavation Liner	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		6/14/2016	Automatic Tank Gauging 0.2	Deferred	
1,000			TLS-300 , Veeder Root		

Facility Summary in BLAINE County in the City of CHINOOK

Location: EZZIES WHOLESALE INC CHINOOK
40450 US HIGHWAY 2 E
CHINOOK, MT 59523 BLAINE
Contact: Dave Skiff, (406) 654-2331

Sys Fac ID: 03-07801
Last Inspected On: 6/29/2015
Operating Permit Renewal Date: 10/30/2018

Owners/Operators: EZZIES WHOLESALE INC, Owner (406)-654-2331 PO BOX 1770
MALTA MT 59538-9640

David Skiff, UST Class A Operator
TRISHA HUESTIS, UST Class B Operator
Sherry Ortner, UST Class B Operator
Shannon Partridge, UST Class B Operator
David Skiff, UST Class B Operator
Durwin Williams, UST Class B Operator
David Skiff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	04	5/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5332			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
7	04	5/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5333			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
8	04	5/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5334			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in BLAINE County in the City of CHINOOK

Location: EZZIES WHOLESALE INC CHINOOK
40450 US HIGHWAY 2 E
CHINOOK, MT 59523 BLAINE

Contact: Dave Skiff, (406) 654-2331

Sys Fac ID: 03-07801
Last Inspected On: 6/29/2015
Operating Permit Renewal Date: 10/30/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	04	5/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5335			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
10	04	5/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5336			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
11	04	5/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5337			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in BLAINE County in the City of CHINOOK

Location: TOWN PUMP INC CHINOOK FOOD STORE
108 NEW YORK ST
CHINOOK, MT 59523 BLAINE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 03-08688
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 4/1/2019

Owners/Operators: Town Pump of Chinook Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	1/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2384			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/28/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		11/3/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	23	1/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2385			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/28/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		11/3/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	23	1/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4462			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/28/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		11/3/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BLAINE County in the City of CHINOOK

Location: TOWN PUMP INC CHINOOK FOOD STORE
108 NEW YORK ST
CHINOOK, MT 59523 BLAINE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 03-08688
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 4/1/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	23	1/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2382			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/28/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		11/3/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
10	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4354			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		11/5/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
11	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4355			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		11/5/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BLAINE County in the City of CHINOOK

Location: CHS BIG SKY CHINOOK
135 1ST ST
CHINOOK, MT 59523 BLAINE

Contact: Steve Kleinjan, (406) 357-2280

Sys Fac ID: 03-10274
Last Inspected On: 3/21/2016
Operating Permit Renewal Date: 5/7/2019

Owners/Operators:

CHS Inc - Inver Grove Heights, Owner	(800)-232-3639	5500 CENEX DR INVER GROVE HEIGHTS MN 55077-1721
Milk River Cooperative, Operator	(406)-357-2280	PO BOX 339 CHINOOK MT 59523-0339

Steve Kleinjan, UST Class A Operator
Don Cornell, UST Class B Operator
Brenda Drugge, UST Class B Operator
Steve Kleinjan, UST Class B Operator
Logan Abrahamson, UST Class B Global Operator
Willard Abrahamson, UST Class B Global Operator
Steve Kleinjan, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	4/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
962		6/7/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	21	4/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
963		6/7/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
3	21	4/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
964		6/7/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
20,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BLAINE County in the City of CHINOOK

Location: CHS BIG SKY CHINOOK
135 1ST ST
CHINOOK, MT 59523 BLAINE

Contact: Steve Kleinjan, (406) 357-2280

Sys Fac ID: 03-10274
Last Inspected On: 3/21/2016
Operating Permit Renewal Date: 5/7/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	21	4/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
965		6/7/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	21	4/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
966		6/7/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
6	21	4/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
967		6/7/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
17	21	4/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
968		6/7/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in BLAINE County in the City of HARLEM

Location: E Z MART
US HIGHWAY 2
HARLEM, MT 59526 BLAINE

Contact: Doug McCracken, (406) 353-2411

Sys Fac ID: 03-05982
Last Inspected On: 3/23/2016
Operating Permit Renewal Date: 7/9/2019

Owners/Operators: E Z Mart, Owner (406)-353-2335 PO BOX 249
HARLEM MT 59526-0249

Douglas McCracken, UST Class A Operator
Deb Newman, UST Class A Operator
Douglas McCracken, UST Class B Operator
Deb Newman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	23	8/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3265			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/23/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		7/10/2009	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
5	23	8/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3266			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/23/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		7/10/2009	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
6	23	8/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3267			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/23/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		7/10/2009	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in BLAINE County in the City of HARLEM

Location: E Z MART
US HIGHWAY 2
HARLEM, MT 59526 BLAINE
Contact: Doug McCracken, (406) 353-2411

Sys Fac ID: 03-05982
Last Inspected On: 3/23/2016
Operating Permit Renewal Date: 7/9/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	23	8/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3268			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/23/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		7/10/2009	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
8	23	8/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3269			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/23/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		7/10/2009	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in BLAINE County in the City of HARLEM

Location: FORT BELKNAP KWIKSTOP
148 ASSINBOINE AVE
HARLEM, MT 59526 BLAINE

Contact: Dave Skiff, (406) 654-2331

Sys Fac ID: 03-09729
Last Inspected On: 11/25/2014
Operating Permit Renewal Date: 3/10/2018

Owners/Operators:

Fort Belknap Indian Community, Owner	(406)-353-2205	656 AGENCY MAIN STREET HARLEM MT 59526-9705
Kwikland LLP, Operator	(406)-353-4964	PO BOX 729 HARLEM MT 59526

David Skiff, UST Class A Operator
Valerie Blackcrow, UST Class B Operator
Raymond D Gone, UST Class B Operator
David Skiff, UST Class B Operator
David Skiff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	28	8/2/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3820			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000		11/9/2011			
2	28	8/2/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3821			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000		11/9/2011			
3	28	8/2/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3822			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
6,000		11/9/2011			

Facility Summary in BLAINE County in the City of HARLEM

Location: FORT BELKNAP KWIKSTOP
148 ASSINBOINE AVE
HARLEM, MT 59526 BLAINE

Contact: Dave Skiff, (406) 654-2331

Sys Fac ID: 03-09729
Last Inspected On: 11/25/2014
Operating Permit Renewal Date: 3/10/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	28	8/2/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3823			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000		11/9/2011			

Facility Summary in BLAINE County in the City of TURNER

Location: CHS BIG SKY TURNER
US HIGHWAY 241
TURNER, MT 59542 BLAINE
Contact: Don Cornell, (406) 357-2280

Sys Fac ID: 56-13805
Last Inspected On: 4/4/2014
Operating Permit Renewal Date: 6/21/2017

Owners/Operators: CHS INC, Owner (800)-232-3638 5500 CENEX DR
INVER GROVE HEIGHTS MN 55077-1733

Johannas Brown, UST Class A Operator
Steve Kleinjan, UST Class A Operator
Johannas Brown, UST Class B Operator
Don Cornell, UST Class B Operator
Steve Kleinjan, UST Class B Operator
Logan Abrahamson, UST Class B Global Operator
Willard Abrahamson, UST Class B Global Operator
Steve Kleinjan, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	8/14/1997	Unknown	Flexible Plastic	
969	Yes	5/9/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Not Listed	Continuous Interstitial Monitor	
10,000					
2	19	8/14/1997	Unknown	Flexible Plastic	
970	Yes	5/9/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Not Listed	Continuous Interstitial Monitor	
10,000					
3	19	8/14/1997	Unknown	Flexible Plastic	
971	Yes	5/9/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Not Listed	Continuous Interstitial Monitor	
10,000					

Facility Summary in BLAINE County in the City of TURNER

Location: CHS BIG SKY TURNER
US HIGHWAY 241
TURNER, MT 59542 BLAINE
Contact: Don Cornell, (406) 357-2280

Sys Fac ID: 56-13805
Last Inspected On: 4/4/2014
Operating Permit Renewal Date: 6/21/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	19	8/14/1997	Unknown	Flexible Plastic	
972	Yes	5/9/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Not Listed	Continuous Interstitial Monitor	
6,000					
5	19	8/14/1997	Unknown	Flexible Plastic	
3606	Yes	5/9/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Not Listed	Continuous Interstitial Monitor	
6,000					
6	19	8/14/1997	Unknown	Flexible Plastic	
3607	Yes	5/9/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Not Listed	Continuous Interstitial Monitor	
6,000					

Facility Summary in BROADWATER County in the City of THREE FORKS

Location: TOWN PUMP INC THREE FORKS
10800 US HIGHWAY 287
THREE FORKS, MT 59752 BROADWATER

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 16-08721
Last Inspected On: 7/18/2015
Operating Permit Renewal Date: 10/27/2018

Owners/Operators: Major Brands Distributing Imports Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	42	4/14/1974	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4543			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		7/8/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	42	4/14/1974	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4681			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		7/8/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	42	4/14/1974	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4544			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/8/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BROADWATER County in the City of THREE FORKS

Location: TOWN PUMP INC THREE FORKS
10800 US HIGHWAY 287
THREE FORKS, MT 59752 BROADWATER

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 16-08721
Last Inspected On: 7/18/2015
Operating Permit Renewal Date: 10/27/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	36	4/14/1980	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4545			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/8/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	36	4/14/1980	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4546			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/8/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	36	4/14/1980	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2450			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		7/8/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
10	27	1/1/1989	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4886			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/8/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
11	27	1/1/1989	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2452			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/8/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BROADWATER County in the City of THREE FORKS

Location: TOWN PUMP INC THREE FORKS
10800 US HIGHWAY 287
THREE FORKS, MT 59752 BROADWATER

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 16-08721
Last Inspected On: 7/18/2015
Operating Permit Renewal Date: 10/27/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
12	27	1/1/1989	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4882			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/8/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
13	11	2/2/2005	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4931			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/8/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BROADWATER County in the City of THREE FORKS

Location: WHEAT MONTANA FARMS INC
10778 US HIGHWAY 287
THREE FORKS, MT 59752 BROADWATER

Contact: Dean Folkvord, (406) 285-3614

Sys Fac ID: 56-14009
Last Inspected On: 4/21/2016
Operating Permit Renewal Date: 7/7/2019

Owners/Operators: Wheat Montana Bakery Inc, Owner (406)-285-3614 10778 US HIGHWAY 287
THREE FORKS MT 59752-9518

Russell Barnett, UST Class A Operator
Peter Carlson, UST Class A Operator
Russell Barnett, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4384		4/21/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		
2	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4385		4/21/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		
3	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4386		4/21/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in BROADWATER County in the City of TOWNSEND

Location: TOWN PUMP INC TOWNSEND
206 N FRONT ST
TOWNSEND, MT 59644 BROADWATER

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 04-03456
Last Inspected On: 7/18/2015
Operating Permit Renewal Date: 10/27/2018

Owners/Operators: Town Pump of Townsend Inc, Owner (406)-497-6700 600 SOUTH MAIN ST BUTTE MT 59701-2534

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	21	3/15/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
2386			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		7/16/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	21	3/15/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
2387			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
10,000		7/16/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	21	3/15/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
2388			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
12,000		7/16/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BROADWATER County in the City of TOWNSEND

Location: TOWN PUMP INC TOWNSEND
206 N FRONT ST
TOWNSEND, MT 59644 BROADWATER

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 04-03456
Last Inspected On: 7/18/2015
Operating Permit Renewal Date: 10/27/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	21	3/15/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
2389			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
12,000		7/16/2015	TLS-350/Gilbarco EMC , Veeder Root		
11	03	7/1/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5428		8/15/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	Yes
12	03	7/1/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5429		8/15/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	Yes

Facility Summary in BROADWATER County in the City of TOWNSEND

Location: ROCKY MOUNTAIN SUPPLY INC TOWNSEND
310 S FRONT ST
TOWNSEND, MT 59644 BROADWATER

Contact: Jason Rorabaug, (406) 388-4008

Sys Fac ID: 04-07862
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 4/15/2019

Owners/Operators: Rocky Mountain Supply Inc, Owner (406)-388-4008 JASON RORABAUGH PETROLEUM MGR
PO BOX 129
BELGRADE MT 59714-3035

Jason Rorabaugh, UST Class A Operator
Carla Ahern, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	4/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4298			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		1/18/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		1/19/2010	TLS-450 , Veeder Root	Continuous Interstitial Monitor	
8	21	4/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4299			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		1/19/2010	TLS-450 , Veeder Root	Continuous Interstitial Monitor	
9	21	4/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4300			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		1/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		1/19/2010	TLS-450 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BROADWATER County in the City of TOWNSEND

Location: ROCKY MOUNTAIN SUPPLY INC TOWNSEND
310 S FRONT ST
TOWNSEND, MT 59644 BROADWATER

Contact: Jason Rorabaug, (406) 388-4008

Sys Fac ID: 04-07862
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 4/15/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	21	4/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4301			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		1/19/2010	TLS-450 , Veeder Root	Continuous Interstitial Monitor	
11	04	8/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5382		11/7/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
12	04	8/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5383		11/7/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in BROADWATER County in the City of WINSTON

Location: WINSTON STORE
6473 US HIGHWAY 287
WINSTON, MT 59647 BROADWATER

Contact: Allen L. Brewer, (406) 227-5597

Sys Fac ID: 04-00280
Last Inspected On: 9/29/2014
Operating Permit Renewal Date:

Owners/Operators: Allen Brewer, Owner (406)-227-5597 1134 8TH AVE HELENA MT 59601
Allen L Brewer, UST Class A Operator
Allen L Brewer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	23	9/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3152			None	None	Yes
Temporarily Out of Use		9/1/2003	Not Required	Safe Suction	Galvanic
Gasoline		9/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
1,000					
4	23	9/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3153			None	None	Yes
Temporarily Out of Use		9/1/2003	Not Required	Safe Suction	Galvanic
Diesel		9/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
1,000					

Facility Summary in CARBON County in the City of BELFRY

Location: BLACKS SERVICE STATION
332 BROADWAY AVE
BELFRY, MT 59008 CARBON

Contact: Earl Black, (406) 664-3289

Sys Fac ID: 05-02954
Last Inspected On: 4/8/2016
Operating Permit Renewal Date: 6/8/2019

Owners/Operators: Earl Black, Owner (406)-664-3289 PO BOX 50
BELFRY MT 59008-0058

Louise Black, UST Class A Operator
Louise Black, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	23	5/1/1993	Bare Steel	Fiberglass Reinforced Plastic	
449	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
1,000		5/8/2016			
10	23	5/1/1993	Bare Steel	Fiberglass Reinforced Plastic	
450	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
1,000		5/8/2016			

Facility Summary in CARBON County in the City of BRIDGER

Location: MAVERIK INC #7
US HIGHWAY 310 N
BRIDGER, MT 59014 CARBON

Sys Fac ID: 05-00218
Last Inspected On: 7/20/2015
Operating Permit Renewal Date: 9/15/2018

Contact: Dennis Riding, (801) 936-5557

Owners/Operators:

Maverik Inc, Owner	(801)-936-5557	880 W CENTER ST NORTH SALT LAKE UT 84054-2913
Maverik Inc #7, Operator	(406)-662-3356	HWY 310 NORTH BRIDGER MT 59014

Dennis Riding, UST Class A Operator
Breann Christiansen, UST Class B Operator
Dennis Riding, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	25	7/21/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
530			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	25	7/21/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
531			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CARBON County in the City of BRIDGER

Location: TOWN & COUNTRY SUPPLY BRIDGER
209 MAIN ST
BRIDGER, MT 59014 CARBON
Contact: (406) 662-3623

Sys Fac ID: 05-04498
Last Inspected On: 5/15/2015
Operating Permit Renewal Date: 10/27/2018

Owners/Operators: Town & Country Supply Association, Owner (406)-628-6314 PO BOX 367
LAUREL MT 59044-0367

Wesley Burley, UST Class A Operator
Steven Shelton, UST Class A Operator
Mike Ventling, UST Class A Operator
Leilani McCarthy, UST Class B Global Operator
Steven Shelton, UST Class B Global Operator
Mike Ventling, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	26	5/18/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1515			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		6/14/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		1/8/2012	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	26	5/18/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1516			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/14/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		1/2/2012	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	26	5/18/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1517			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/14/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		1/2/2012	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CARBON County in the City of BRIDGER

Location: TOWN & COUNTRY SUPPLY BRIDGER
209 MAIN ST
BRIDGER, MT 59014 CARBON
Contact: (406) 662-3623

Sys Fac ID: 05-04498
Last Inspected On: 5/15/2015
Operating Permit Renewal Date: 10/27/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	13	7/1/2003	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4849			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
2,000		12/31/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CARBON County in the City of JOLIET

Location: TOWN OF JOLIET
116 S MAIN ST
JOLIET, MT 59041 CARBON

Contact: Gayle Langlois, (406) 962-3567

Sys Fac ID: 05-00189
Last Inspected On: 3/17/2014
Operating Permit Renewal Date: 5/16/2017

Owners/Operators: Town of Joliet, Owner (406)-962-3567 PO BOX 210
JOLIET MT 59041-0210

Dale Limberhand, UST Class A Operator
Dale Limberhand, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	19	9/1/1997	Steel Clad	Steel	Flapper Valve (Auto Shutoff)
2127			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		3/17/2014	Manual Interstitial Monitor	Deferred	
560					

Facility Summary in CARBON County in the City of JOLIET

Location: CARBON COUNTY DIST 2 SHOP
201 STATE ST
JOLIET, MT 59041 CARBON

Contact: Alvin Swigert, (406) 962-3546

Sys Fac ID: 05-01853
Last Inspected On: 2/10/2016
Operating Permit Renewal Date: 2/23/2019

Owners/Operators: Carbon County Road Dist, Owner (406)-446-1595 ATTN DAVID DAVIDSON
PO BOX 887
RED LODGE MT 59068-0887

Shawn Maines, UST Class A Operator
Jerrid E Bergum, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	1/30/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
518			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		2/11/2016	Automatic Tank Gauging 0.2	Deferred	
1,000			Gilbarco EMC Basic , Gilbarco		
2	24	1/30/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
519			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		2/11/2016	Automatic Tank Gauging 0.2	Deferred	
1,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in CARBON County in the City of JOLIET

Location: JOLIET SCHOOL DIST 7
131 N MAIN ST
JOLIET, MT 59041 CARBON

Contact: Russ Salo, (406) 962-3541

Sys Fac ID: 05-05353
Last Inspected On: 4/24/2014
Operating Permit Renewal Date: 6/25/2017

Owners/Operators: School Dist 7 Joliet, Owner (406)-962-3541 PO BOX 590
JOLIET MT 59041-0590

Dale Limberhand, UST Class A Operator
Flint Salo, UST Class A Operator
Dale Limberhand, UST Class B Operator
Flint Salo, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	17	7/1/1999	Steel Clad	Steel	Flapper Valve (Auto Shutoff)
4091			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		4/6/2011	Manual Interstitial Monitor	Deferred	
1,000					

Facility Summary in CARBON County in the City of JOLIET

Location: COUNTRY CORNER JOLIET
110 E FRONT ST
JOLIET, MT 59041 CARBON

Contact: Dennis Whitmore, (406) 962-3435

Sys Fac ID: 05-05577
Last Inspected On: 2/14/2014
Operating Permit Renewal Date: 4/22/2017

Owners/Operators: Dennis Whitmore, Owner (406)-651-5101 PO BOX 80391
BILLINGS MT 59108-7901

Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Ken Jackson, UST Class A Operator
Charlie McHenry, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Roberta Brooks, UST Class B Operator
Laura Geffre, UST Class B Operator
Kristi Johnson, UST Class B Operator
Roger Schmechel, UST Class B Operator
Stacy Shalosky, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	29	2/22/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3925			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/19/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		2/14/2014	Gilbarco EMC Basic , Gilbarco		
4	28	2/22/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3926			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		2/19/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
1,500		2/14/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in CARBON County in the City of JOLIET

Location: COUNTRY CORNER JOLIET
110 E FRONT ST
JOLIET, MT 59041 CARBON

Contact: Dennis Whitmore, (406) 962-3435

Sys Fac ID: 05-05577
Last Inspected On: 2/14/2014
Operating Permit Renewal Date: 4/22/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	28	2/22/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3927			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/19/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,500		2/14/2014	Gilbarco EMC Basic , Gilbarco		
6	17	2/1/1999	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3928			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/19/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		2/14/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in CARBON County in the City of RED LODGE

Location: RAY JUDD FORD INC
120 N BROADWAY AVE
RED LODGE, MT 59068 CARBON

Contact: David Judd, (406) 855-9164

Sys Fac ID: 05-05655
Last Inspected On: 12/4/2014
Operating Permit Renewal Date: 2/19/2018

Owners/Operators: Raymond Judd Ford Inc, Owner (406)-446-1332 PO BOX 1190 RED LODGE MT 59068

David Judd, UST Class A Operator
Lauri Judd, UST Class B Operator
Evelyn Roy, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	33	4/19/1983	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1834			Lined Interior/Impressed Current	None	Yes
Currently in Use		1/1/2008	Not Required	Safe Suction	Impressed Current
Diesel		12/4/2014	Tank Tightness Testing, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		2/27/2002			
3	33	4/19/1983	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1835			Lined Interior/Impressed Current	None	Yes
Currently in Use		1/1/2008	Not Required	Safe Suction	Impressed Current
Diesel		12/4/2014	Tank Tightness Testing, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000					
4	33	4/19/1983	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1833			Lined Interior/Impressed Current	None	Yes
Currently in Use		1/1/2008	Not Required	Safe Suction	Impressed Current
Gasoline		12/4/2014	Tank Tightness Testing, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000					

Facility Summary in CARBON County in the City of RED LODGE

Location: CIRCLE 17
1022 S ADAMS AVE
RED LODGE, MT 59068 CARBON

Contact: Stephen Alexander, (406) 425-3997

Sys Fac ID: 05-09748
Last Inspected On: 1/14/2015
Operating Permit Renewal Date: 3/5/2018

Owners/Operators: Circle 17 LLC, Owner (406)-425-0395 PO BOX 1922 RED LODGE MT 59068

Mackenzie Alexander, UST Class A Operator
Stephen Alexander, UST Class A Operator
Joel Lindgren, UST Class A Operator
Mackenzie Alexander, UST Class B Operator
Stephen Alexander, UST Class B Operator
Julie Lindgren, UST Class B Operator
Julie Lindgren, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	20	7/1/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3389			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
8,000		4/10/2015	Gilbarco EMC Basic , Gilbarco		
5	20	7/1/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3390			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		4/10/2015	Gilbarco EMC Basic , Gilbarco		

Facility Summary in CARBON County in the City of RED LODGE

Location: 6 ASSISTED LLC
600 21ST ST W
RED LODGE, MT 59068 CARBON

Contact: Marie Doman, (646) 380-8748

Sys Fac ID: 05-09926
Last Inspected On: 10/31/2013
Operating Permit Renewal Date: 11/5/2013

Owners/Operators: 6 Assisted LLC, Owner (917)-635-8856 408 W 58 ST
JAMAICA NY 11435

Bob Miner, UST Class A Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	18	10/8/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3103			Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		8/4/2010	Not Listed	Not Listed	
1,000					

Facility Summary in CARBON County in the City of RED LODGE

Location: Cenex Zip Trip 74
902 N BROADWAY AVE
RED LODGE, MT 59068 CARBON
Contact: Rick Bates, (509) 535-7701

Sys Fac ID: 56-13935
Last Inspected On: 11/22/2016
Operating Permit Renewal Date: 8/6/2018

Owners/Operators: CHS Inc - Spokane Valley, Owner/Operator (509)-535-7701 16124 E MARIETTA LANE SPOKANE WA 99213
Sean Hurley, UST Class A Operator
Julie Lindgren, UST Class A Operator
ROBERT HAYS, UST Class B Operator
Julie Lindgren, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	01	4/10/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5566		3/12/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		4/13/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
6	01	4/10/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5567		3/12/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		4/13/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
7	01	4/10/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5568		3/12/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
7,000		4/13/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in CARBON County in the City of RED LODGE

Location: Cenex Zip Trip 74
902 N BROADWAY AVE
RED LODGE, MT 59068 CARBON
Contact: Rick Bates, (509) 535-7701

Sys Fac ID: 56-13935
Last Inspected On: 11/22/2016
Operating Permit Renewal Date: 8/6/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	01	4/10/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5569		3/12/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		4/13/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in CARBON County in the City of RED LODGE

Location: TOWN PUMP OF RED LODGE
615 N BROADWAY
RED LODGE, MT 59068 CARBON

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15212
Last Inspected On: 6/3/2016
Operating Permit Renewal Date: 7/29/2019

Owners/Operators: Town Pump Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-2534

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	03	1/16/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5377			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
2	03	1/16/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5378			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
14,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
3	03	1/16/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5379			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in CARBON County in the City of RED LODGE

Location: TOWN PUMP OF RED LODGE
615 N BROADWAY
RED LODGE, MT 59068 CARBON

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15212
Last Inspected On: 6/3/2016
Operating Permit Renewal Date: 7/29/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
4	03	1/16/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5380			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
5	03	1/16/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5381			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in CARBON County in the City of ROBERTS

Location: Y STOP C STORE INC
4 COONEY RD
ROBERTS, MT 59070 CARBON

Contact: Roxie Melton, (406) 445-2203

Sys Fac ID: 05-06599
Last Inspected On: 2/12/2015
Operating Permit Renewal Date: 2/20/2018

Owners/Operators: Melton Enterprises Inc, Owner (406)-445-2203 DBA Y STOP
4 COONEY RD
ROBERTS MT 59070-9624

Rodney Melton, UST Class A Operator
Rodney Melton, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	24	6/20/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3329			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		2/12/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
5,000			TLS-300 , Veeder Root		
6	24	6/20/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3330			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		2/12/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
3,000			TLS-300 , Veeder Root		
7	24	6/20/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3331			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		2/12/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
3,000			TLS-300 , Veeder Root		
8	24	6/20/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3332			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		2/12/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
5,000			TLS-300 , Veeder Root		

Facility Summary in CARBON County in the City of SILESIA

Location: ROCKVALE TRAVEL PLAZA UST
US HIGHWAY 212 & US HIGHWAY 310
SILESIA, MT 59041 CARBON

Contact: (406) 962-3886

Sys Fac ID: 05-07633
Last Inspected On: 12/10/2014
Operating Permit Renewal Date: 2/27/2018

Owners/Operators: Thomas H McNew, Owner (406)-962-3886 PO BOX 80002 BILLINGS MT 59108-0002

Thomas H McNew, UST Class A Operator
Thomas H McNew, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	17	7/1/1999	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4112		12/10/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/10/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
7	17	7/1/1999	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4113		12/10/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/10/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000		7/13/2016	Gilbarco EMC Basic , Gilbarco		
8	17	7/1/1999	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4114		12/10/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/10/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000		7/13/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in CARTER County in the City of ALZADA

Location: B & J CONVENIENCE STORE
US HIGHWAY 212
ALZADA, MT 59311 CARTER
Contact: Bill Walker, (406) 828-4400

Sys Fac ID: 56-13910
Last Inspected On: 5/18/2015
Operating Permit Renewal Date: 9/17/2018

Owners/Operators: William Walker, Owner (406)-828-4400 PO BOX 74
ALZADA MT 59311-0074

William Walker, UST Class A Operator
Janet Walker, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	17	12/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3564			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Manual Interstitial Monitor	Deferred	
8,000					
2	17	12/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3565			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Interstitial Monitor	Deferred	
4,000					

Facility Summary in CARTER County in the City of EKALAKA

Location: HOSPITAL COURTHOUSE
101 PARK ST
EKALAKA, MT 59324 CARTER
Contact: Edward McBride, (406) 775-8749

Sys Fac ID: 06-00863
Last Inspected On: 7/28/2015
Operating Permit Renewal Date: 8/3/2018

Owners/Operators: Carter County, Owner (406)-775-6298 PO BOX 315
EKALAKA MT 59324-0315

Robert D. Jacobs, UST Class A Operator
Robert D. Jacobs, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	7/1/1991	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
532			Double-Walled	none	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Heating Oil		7/28/2015	Manual Interstitial Monitor	Manual Interstitial Monitor	
6,000					

Facility Summary in CARTER County in the City of EKALAKA

Location: FRUIT SERVICE & REPAIR INC MAIN ST
40 MAIN ST
EKALAKA, MT 59324 CARTER

Contact: Troy Fruit, (406) 775-6541

Sys Fac ID: 06-01681
Last Inspected On: 7/28/2015
Operating Permit Renewal Date: 8/17/2018

Owners/Operators: Fruit Service & Repair Inc, Owner (406)-775-6541 PO BOX 318
EKALAKA MT 59324-0318

Troy Fruit, UST Class A Operator
Mikel Fruit, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	26	4/26/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1132			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Continuous Interstitial Monitor	Deferred	
1,000					
4	26	4/26/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1133			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Continuous Interstitial Monitor	Deferred	
1,000					
5	26	4/26/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1134			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Deferred	
1,000					

Facility Summary in CARTER County in the City of EKALAKA

Location: FRUIT SERVICE & REPAIR INC SR 323
31 MT HIGHWAY 323
EKALAKA, MT 59324 CARTER
Contact: Troy Fruit, (406) 775-6541

Sys Fac ID: 06-03234
Last Inspected On: 7/28/2015
Operating Permit Renewal Date: 8/17/2018

Owners/Operators: Fruit Service & Repair Inc, Owner (406)-775-6541 PO BOX 318
EKALAKA MT 59324-0318

Troy Fruit, UST Class A Operator
Dana Blutt, UST Class B Operator
Mikel Fruit, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	18	4/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3617			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Deferred	
5,565					
7	18	4/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1135			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Deferred	
4,590					
8	18	4/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1136			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Continuous Interstitial Monitor	Deferred	
2,365					
9	18	4/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1137			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Continuous Interstitial Monitor	Deferred	
9,627					

Facility Summary in CARTER County in the City of EKALAKA

Location: EKALAKA ELEMENTARY SCHOOL
106 E PARK ST
EKALAKA, MT 59324 CARTER

Contact: Ed McBride, (406) 775-8767

Sys Fac ID: 06-04710
Last Inspected On: 7/28/2015
Operating Permit Renewal Date: 8/3/2018

Owners/Operators: School Dist 15 Ekalaka Elementary, Owner (406)-775-8765 PO BOX 458
EKALAKA MT 59324-0458

Shay Beyer, UST Class A Operator
Shay Beyer, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	8/1/1991	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
859			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Heating Oil		7/28/2015	Manual Interstitial Monitor	Manual Interstitial Monitor	
6,000					

Facility Summary in CASCADE County in the City of BELT

Location: BELT PUBLIC SCHOOLS DIST 29 UST
1 CHURCH ST
BELT, MT 59412 CASCADE

Contact: Kelvin Johnson, (406) 277-3351

Sys Fac ID: 07-04613
Last Inspected On: 4/2/2014
Operating Permit Renewal Date: 8/4/2017

Owners/Operators: School Dist 29 Belt, Owner (406)-277-3351 PO BOX 197
BELT MT 59412-0197

Kathleen Prody, UST Class A Operator
April Wells, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	28	10/1/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
422		6/6/2013	None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Heating Oil		6/6/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			EECO 1500 , EMCO Electronics		

Facility Summary in CASCADE County in the City of BELT

Location: MALMSTROM AFB A 2
US HIGHWAY 87/89
BELT, MT 59412 CASCADE

Sys Fac ID: 07-08976
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 10/7/2017

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Leigland, UST Class A Operator
James Leigland, UST Class B Operator
Lana Hedlund, UST Class B Global Operator
Mark W Johnson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
109		4/21/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of BELT

Location: MALMSTROM AFB A 10
US HIGHWAY 87/89
BELT, MT 59412 CASCADE

Sys Fac ID: 07-08984
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 10/7/2017

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
115		4/7/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of BELT

Location: MALMSTROM AFB A 11
US HIGHWAY 87/89
BELT, MT 59412 CASCADE

Sys Fac ID: 07-08985
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 9/25/2017

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
116		4/14/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of BELT

Location: BELT VALLEY GROCERY
65 CASTNER STREET
BELT, MT 59412 CASCADE

Contact: Reed Throckmorton, (406) 277-3523

Sys Fac ID: 07-13653
Last Inspected On: 11/28/2016
Operating Permit Renewal Date: 11/29/2019

Owners/Operators:

Harry L Throckmorton, Owner	(406)-277-3523	PO BOX 441 BELT MT 59412-0441
Reed Throckmorton, Owner/Operator	(406)-277-3523	PO BOX 441 BELT MT 59412
Reed Throckmorton, UST Class A Operator		
Reed Throckmorton, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	10/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4469		11/28/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			OPW 1500 , OPW		
2	21	10/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4468		11/28/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			OPW 1500 , OPW		

Facility Summary in CASCADE County in the City of BLACK EAGLE

Location: MOUNTAIN VIEW COOP BLACK EAGLE
2200 OLD HAVRE HWY
BLACK EAGLE, MT 59414 CASCADE
Contact: Pat Trainor, (406) 453-2435

Sys Fac ID: 07-04232
Last Inspected On: 6/15/2016
Operating Permit Renewal Date: 8/4/2019

Owners/Operators: Mountain View Coop, Owner (406)-453-2435 ATTN DAVE DOUGLAS
2200 OLD HAVRE HWY
BLACK EAGLE MT 59414-1043

Dan Morano, UST Class A Operator
Pat Trainor, UST Class A Operator
Pat Trainor, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	18	12/2/1997	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
1015			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
12,000			TLS-350/Gilbarco EMC , Veeder Root		
8	18	12/2/1997	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
1016			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
9	18	12/2/1997	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
1017			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
4,000			TLS-350/Gilbarco EMC , Veeder Root		
10	18	12/2/1997	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
1018			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of BLACK EAGLE

Location: MOUNTAIN VIEW COOP BLACK EAGLE
2200 OLD HAVRE HWY
BLACK EAGLE, MT 59414 CASCADE

Contact: Pat Trainor, (406) 453-2435

Sys Fac ID: 07-04232
Last Inspected On: 6/15/2016
Operating Permit Renewal Date: 8/4/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	18	12/2/1997	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
1019			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
12	18	12/2/1997	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
1020			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of CASCADE

Location: TOMS IGA
130 1ST ST N
CASCADE, MT 59421 CASCADE
Contact: Dale Klock, (406) 468-2252

Sys Fac ID: 07-04148
Last Inspected On: 8/12/2016
Operating Permit Renewal Date: 9/20/2019

Owners/Operators: DTK Foods Inc, Owner (406)-468-2252 PO BOX 268
CASCADE MT 59421-0268

Irene Strandell, UST Class A Operator
Irene Strandell, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	19	5/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1490		8/8/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		
5	19	5/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1491		8/8/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			Gilbarco EMC Basic , Gilbarco		
6	19	5/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1492		8/8/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			Gilbarco EMC Basic , Gilbarco		
7	19	5/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1493		8/8/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in CASCADE County in the City of CASCADE

Location: TOMS IGA
130 1ST ST N
CASCADE, MT 59421 CASCADE
Contact: Dale Klock, (406) 468-2252

Sys Fac ID: 07-04148
Last Inspected On: 8/12/2016
Operating Permit Renewal Date: 9/20/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	19	5/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1494		8/8/2016	None	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in CASCADE County in the City of CASCADE

Location: OLSON FARM
430 KLOCK RD
CASCADE, MT 59421 CASCADE

Contact: Cory Olson, (406) 899-8525

Sys Fac ID: 07-04520
Last Inspected On: 9/9/2014
Operating Permit Renewal Date: 3/7/2018

Owners/Operators: Cory Olson, Owner/Operator — 1040 10 MILE ROAD, CASCADE MT 59421
Cory Olson, UST Class A Operator
Cory Olson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	17	4/1/1999	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4053			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		9/9/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		10/16/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB G 3
INTERSTATE 15
CASCADE, MT 59421 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-09043
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	27	6/21/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
118		9/9/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB G 4
INTERSTATE 15
CASCADE, MT 59421 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-09044
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	5/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
119		8/3/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB G 5
INTERSTATE 15
CASCADE, MT 59421 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-09045
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	5/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
120		9/9/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB I 1
HIGHWAY 330
CASCADE, MT 59421 CASCADE

Sys Fac ID: 07-09063
Last Inspected On: 9/8/2015
Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Ricardo Andrillon, UST Class B Operator
Glen Beck, UST Class B Operator
Allen Brooks, UST Class B Operator
Jonathan Buesch, UST Class B Operator
John Corbett, UST Class B Operator
David Cosner, UST Class B Operator
Ryan Cox, UST Class B Operator
Brian Day, UST Class B Operator
David Degolier, UST Class B Operator
Patrick Ellis, UST Class B Operator
Hudson English, UST Class B Operator
Paul Floyd, UST Class B Operator
Dustin Hemingway, UST Class B Operator
Aaron Hill, UST Class B Operator
Shane Hofstad, UST Class B Operator
Bethany Kent, UST Class B Operator
James Knudsen, UST Class B Operator
Ryan Kofoed, UST Class B Operator
Jeff Laird, UST Class B Operator
Damon McCarty, UST Class B Operator
Kieth McIlwain, UST Class B Operator
Brian McVay, UST Class B Operator
Ronald Miller, UST Class B Operator
Michael Murieen, UST Class B Operator
Jeff Nelson, UST Class B Operator
Patrick Noppenberg, UST Class B Operator
Shawn O'Grady, UST Class B Operator
Chris Ploof, UST Class B Operator
Issac Price, UST Class B Operator
Brian Rayner, UST Class B Operator

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB I 1
HIGHWAY 330
CASCADE, MT 59421 CASCADE

Sys Fac ID: 07-09063
Last Inspected On: 9/8/2015
Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Cameron Smith, UST Class B Operator
Jimmy Sonefelt, UST Class B Operator
Michael Stokes, UST Class B Operator
Jason Vike, UST Class B Operator
James Wooderchak, UST Class B Operator
Paul Ziemba, UST Class B Operator
Paul Floyd, UST Class B Global Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	54	6/2/1962	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
125		6/16/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Impressed Current
Diesel		9/28/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Vapor Monitoring	

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB I 3
ROAD 330
CASCADE, MT 59421 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-09065
Last Inspected On: 9/8/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	10/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
127		6/16/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB I 4
ROAD 330
CASCADE, MT 59421 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-09066
Last Inspected On: 9/8/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	10/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
128		6/16/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB I 5
ROAD 330
CASCADE, MT 59421 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-09067
Last Inspected On: 9/8/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	10/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
129		6/16/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of CASCADE

Location: MALMSTROM AFB I 6
INTERSTATE 15
CASCADE, MT 59421 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-09068
Last Inspected On: 9/8/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
130		6/13/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of FLOWEREE

Location: MALMSTROM AFB J 6
17333 BOOTLEGGER TRAIL
FLOWEREE, MT 59440 CASCADE
Contact: Rudy Verzuh, (406) 731-6440

Sys Fac ID: 08-09079
Last Inspected On: 11/4/2015
Operating Permit Renewal Date: 11/9/2018

Owners/Operators: Malmstrom AFB, Owner (406)-731-6167 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	01	7/6/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Auto Limiter, High Level Alarm
5590		6/29/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	Yes

Facility Summary in CASCADE County in the City of FORT SHAW

Location: MALMSTROM AFB H 6
MT HIGHWAY 21
FORT SHAW, MT 59443 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-09057
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	9/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
123		6/10/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of FORT SHAW

Location: MALMSTROM AFB I 9
MT HIGHWAY 21
FORT SHAW, MT 59443 CASCADE

Sys Fac ID: 07-09071
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	10/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
132		8/10/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of FORT SHAW

Location: MALMSTROM AFB I 08
MT HIGHWAY 21
FORT SHAW, MT 59443 CASCADE

Sys Fac ID: 07-10840
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
William Hoffmeister, UST Class B Operator
Kyle Topp, UST Class B Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	27	9/26/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
152		6/13/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MOUNTAIN VIEW COOP GREAT FALLS
1000 SMELTER AVE NW
GREAT FALLS, MT 59404 CASCADE
Contact: Pat Trainor, (406) 453-2435

Sys Fac ID: 07-00004
Last Inspected On: 6/27/2016
Operating Permit Renewal Date: 8/4/2019

Owners/Operators: Mountain View Coop, Owner (406)-453-2435 ATTN DAVE DOUGLAS
2200 OLD HAVRE HWY
BLACK EAGLE MT 59414-1043

David Douglas, UST Class A Operator
Gary Boysun, UST Class B Operator
John Malley, UST Class B Operator
Jasmin Nguyen, UST Class B Operator
David Douglas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	11/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1012			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
2	21	11/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1013			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
3	21	11/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1014			None	None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MOUNTAIN VIEW COOP GREAT FALLS
1000 SMELTER AVE NW
GREAT FALLS, MT 59404 CASCADE

Contact: Pat Trainor, (406) 453-2435

Sys Fac ID: 07-00004
Last Inspected On: 6/27/2016
Operating Permit Renewal Date: 8/4/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	21	11/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1009			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
12	21	11/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1010			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
13	21	11/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1011			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: BISON FORD
500 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Contact: Buckmiller Steve, (406) 731-5264

Sys Fac ID: 07-00077
Last Inspected On: 12/15/2015
Operating Permit Renewal Date: 4/30/2019

Owners/Operators: Bison Motors, Owner (406)-727-2552 500 10TH AVE S
GREAT FALLS MT 59405-4085

RYAN CHRISTENSEN, UST Class A Operator
RYAN CHRISTENSEN, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	28	8/5/1988	Fiberglass Reinforced Plastic	Flexible Plastic	
3908		4/10/2013	None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Waste Oil			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
3,000		4/10/2013	Other , Other		
8	28	8/5/1988	Fiberglass Reinforced Plastic	Flexible Plastic	
4303		4/10/2013	None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Waste Oil			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
1,000		4/10/2013			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GENERAL DISTRIBUTING CO INC
430 17TH AVE NE
GREAT FALLS, MT 59404 CASCADE

Contact: Ramona Ehnes, (406) 454-1351

Sys Fac ID: 07-00081
Last Inspected On: 3/28/2014
Operating Permit Renewal Date: 8/5/2017

Owners/Operators: General Distributing Co Inc, Owner (406)-454-1351 PO BOX 2606
GREAT FALLS MT 59403-2606

Jake Schrock, UST Class A Operator
Aaron Timmons, UST Class A Operator
Jake Schrock, UST Class B Operator
Aaron Timmons, UST Class B Operator
Aaron Timmons, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	38	2/14/1978	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1206			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Stat. Inventory Reconcilitation	Deferred	
2,000					
2	38	2/14/1978	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1207			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Stat. Inventory Reconcilitation	Deferred	
4,000					
3	38	2/14/1978	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1208			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Stat. Inventory Reconcilitation	Deferred	
6,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: NOONS 574
1300 12TH AVE S
GREAT FALLS, MT 59405 CASCADE
Contact: Harinder Singh, (406) 452-2471

Sys Fac ID: 07-00082
Last Inspected On: 3/20/2015
Operating Permit Renewal Date: 5/29/2018

Owners/Operators: Singh Inc, Owner (406)-868-2062 ATTN HARINDER SINGH
PO BOX 7208
GREAT FALLS MT 59406-7208

H & R Inc, Operator (406)-868-2062 3601 10TH AVE S
GREAT FALLS MT 59405-3449

Harinder Singh, UST Class A Operator
Rajinder Singh, UST Class A Operator
Frank Kruse, UST Class B Operator
Frank Kruse, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	05	11/1/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5339			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/13/2010	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		9/13/2010	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes
4	05	11/1/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5340			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/13/2010	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		9/13/2010	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: NOON'S 572
5600 3RD AVE S
GREAT FALLS, MT 59405 CASCADE

Contact: H & R, INC, (406) 452-1041

Sys Fac ID: 07-00090
Last Inspected On: 12/5/2013
Operating Permit Renewal Date: 3/14/2017

Owners/Operators: Singh Inc, Owner (406)-868-2062 ATTN HARINDER SINGH
PO BOX 7208
GREAT FALLS MT 59406-7208

H & R Inc, Operator (406)-868-2062 3601 10TH AVE S
GREAT FALLS MT 59405-3449

Harinder Singh, UST Class A Operator
Rajinder Singh, UST Class A Operator
Frank Kruse, UST Class B Operator
Frank Kruse, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	45	12/31/1970	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4439			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/11/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	45	12/31/1970	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3838			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/11/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: NOONS 571
3200 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Contact: Harinder Singh, (406) 452-1041

Sys Fac ID: 07-00092
Last Inspected On: 8/1/2016
Operating Permit Renewal Date: 11/20/2019

Owners/Operators: Singh Inc, Owner (406)-868-2062 ATTN HARINDER SINGH
PO BOX 7208
GREAT FALLS MT 59406-7208

H & R Inc, Operator (406)-868-2062 3601 10TH AVE S
GREAT FALLS MT 59405-3449

Harinder Singh, UST Class A Operator
Rajinder Singh, UST Class A Operator
Frank Kruse, UST Class B Operator
Frank Kruse, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	45	12/31/1970	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3839			Lined Interior/Impressed Current	None	Yes
Currently in Use		12/21/2008	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		6/15/2013	TLS-350/Gilbarco EMC , Veeder Root		
2	45	12/31/1970	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3840			Lined Interior/Impressed Current	None	Yes
Currently in Use		12/21/2008	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		6/15/2013	TLS-350/Gilbarco EMC , Veeder Root		
3	45	12/31/1970	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4440			Lined Interior/Impressed Current	None	Yes
Currently in Use		12/21/2008	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		9/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		6/15/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GAS N SHOP 2
101 TRUMAN AVE
GREAT FALLS, MT 59404 CASCADE
Contact: Kevin Joyce, (406) 965-2336

Sys Fac ID: 07-00097
Last Inspected On: 12/10/2014
Operating Permit Renewal Date: 3/13/2018

Owners/Operators: Sandeep Muhar, Owner (406)-624-6912 1001 34TH AVE NE GREAT FALLS MT 59404

Perry Joyce, UST Class A Operator
Gurinderbir Muhar, UST Class A Operator
Maureen Pettis, UST Class B Operator
Kevin Joyce, UST Class B Global Operator
Gurinderbir Muhar, UST Class B Global Operator
Sandeep Muhar, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	3/4/1990	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3546			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/14/2005	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					
3	26	3/4/1990	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3547			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/14/2005	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					
4	26	3/4/1990	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3545			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/14/2005	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: CARL'S AUTOCARE INC
2300 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Contact: Carl Halcro, (406) 761-1342

Sys Fac ID: 07-00621
Last Inspected On: 9/23/2014
Operating Permit Renewal Date: 3/18/2018

Owners/Operators: Carl Halcro, Owner (406)-761-1342 2300 10TH AVE S
GREAT FALLS MT 59405-2968

Carl Halcro, UST Class A Operator
Paul Halcro, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	30	1/27/1986	Steel Clad	Fiberglass Reinforced Plastic	Ball Float Valve
1264			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/23/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		3/24/2014	TLS-250 , Veeder Root		
6	30	1/27/1986	Steel Clad	Fiberglass Reinforced Plastic	Ball Float Valve
1265			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		9/23/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/24/2014	TLS-250 , Veeder Root		
7	30	1/27/1986	Steel Clad	Fiberglass Reinforced Plastic	Ball Float Valve
1266			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/23/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/24/2014	TLS-250 , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GREAT FALLS FIRE STATION 1 GREAT FALLS
105 9TH ST S
GREAT FALLS, MT 59401 CASCADE

Contact: Dale Clavert, (406) 781-8993

Sys Fac ID: 07-00680
Last Inspected On: 5/16/2016
Operating Permit Renewal Date: 9/18/2019

Owners/Operators: City of Great Falls, Owner (406)-771-1180 PO BOX 5021
GREAT FALLS MT 59403

Doug Alm, UST Class A Operator
Dale Calvert, UST Class A Operator
Doug Alm, UST Class B Global Operator
Dale Calvert, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	4/22/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
636			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		7/30/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,086		2/11/2016	TLS-450 , Veeder Root		
2	25	4/22/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
637			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		7/30/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,086		2/11/2016	TLS-450 , Veeder Root		
3	25	4/22/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
638			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		7/30/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		2/11/2016	TLS-450 , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: ZIP TRIP 45
625 1ST AVE N
GREAT FALLS, MT 59401 CASCADE

Contact: Mike Baumgartner, (406) 761-2175

Sys Fac ID: 07-01057
Last Inspected On: 1/21/2016
Operating Permit Renewal Date: 3/30/2019

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Sean Hurley, UST Class A Operator
Luci Tuttle, UST Class B Operator
Karina Serrano, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	34	4/27/1982	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1610			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/29/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	34	4/27/1982	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1611			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/29/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	34	4/27/1982	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1612			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/29/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: RAINBOW SHOP
6700 RAINBOW DAM ROAD
GREAT FALLS, MT 59404 CASCADE
Contact: Beth Stimatz, (406) 497-2687

Sys Fac ID: 07-01189
Last Inspected On: 9/27/2016
Operating Permit Renewal Date: 9/30/2019

Owners/Operators: Northwestern Energy, Owner/Operator (406)-655-2521 405 S 20TH ST W BILLINGS MT 59102

Scott Cleveland, UST Class A Operator
Michael Holzwarth, UST Class A Operator
Scott Cleveland, UST Class B Operator
Kevin Holden, UST Class B Operator
Zane Shaulis, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1674			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel		6/1/2016	Automatic Tank Gauging 0.2	Deferred	
550			Gilbarco EMC Basic , Gilbarco		
2	24	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1675			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline		6/1/2016	Automatic Tank Gauging 0.2	Deferred	
2,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: BLACK EAGLE SERVICE CENTER
1501 N RIVER RD
GREAT FALLS, MT 59403 CASCADE
Contact: Beth Stimatz, (406) 497-2687

Sys Fac ID: 07-01190
Last Inspected On: 11/21/2016
Operating Permit Renewal Date: 1/28/2020

Owners/Operators: Northwestern Energy, Owner (406)-655-2521 405 S 20TH ST W BILLINGS MT 59102

John Habeger, UST Class A Operator
Charles Roth, UST Class B Operator
Michael Broderick, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	12/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1676			None	none	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
2,086			TLS-300 , Veeder Root		
2	24	12/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1677			None	none	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Deferred	
2,086			TLS-300 , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: KEITHS COUNTY STORE
1621 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Contact: David Keith, (406) 727-7114

Sys Fac ID: 07-01418
Last Inspected On: 7/2/2014
Operating Permit Renewal Date: 12/2/2017

Owners/Operators:

Keith's Country Store, Owner	(406)-727-7114	1621 10TH AVE S GREAT FALLS MT 59405
David Keith, Operator	(406)-862-2578	933 4TH ST WHITEFISH MT 59937-2707

David Keith, UST Class A Operator
Theresa Keith, UST Class A Operator
Anna Dion, UST Class B Operator
David Keith, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	17	4/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
3988			None	None	Yes
Currently in Use		4/1/2009	Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		4/27/2011	TLS-350/Gilbarco EMC , Veeder Root		
4	17	4/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
3989			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		4/27/2011	TLS-350/Gilbarco EMC , Veeder Root		
5	17	4/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
3990			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		4/27/2011	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: PHILLIPS 66 GREAT FALLS TERMINAL
1401 52ND ST N
GREAT FALLS, MT 59405 CASCADE

Contact: Mark Becker, (406) 441-4747

Sys Fac ID: 07-01845
Last Inspected On: 4/6/2016
Operating Permit Renewal Date: 6/9/2019

Owners/Operators:

Phillips 66 Great Falls Terminal, Owner	(406)-255-5714	2626 LILLIAN AVENUE BILLINGS MT 59101
Phillips 66 Pipeline LLC, Operator	(406)-255-5714	2626 LILLIAN AVENUE BILLINGS MT 59101

Brian Buckley, UST Class A Operator
Ryan Norwood, UST Class A Operator
John Stampfli, UST Class A Operator
Steve Thomas, UST Class A Operator
Earl Anderson, UST Class B Operator
Brian Buckley, UST Class B Operator
Theodore Hagemo, UST Class B Operator
Ryan Norwood, UST Class B Operator
Scott Parker, UST Class B Operator
Clifford Pearce, UST Class B Operator
Gail Pierce, UST Class B Operator
Steven Sheldon, UST Class B Operator
Steve Thomas, UST Class B Operator
Michael Crawford, UST Class B Global Operator
James Olson, UST Class B Global Operator
John Stampfli, UST Class B Global Operator
Dane Whittaker, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	56	1/1/1960	Unknown	Steel	
707	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		5/13/2015	Deferred	MLLD Line Tightness Testing	
1,512,000		12/4/2015			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: PHILLIPS 66 GREAT FALLS TERMINAL
1401 52ND ST N
GREAT FALLS, MT 59405 CASCADE
Contact: Mark Becker, (406) 441-4747

Sys Fac ID: 07-01845
Last Inspected On: 4/6/2016
Operating Permit Renewal Date: 6/9/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
5	56	1/1/1960	Unknown	Steel - Terminal Piping	
704	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Gasoline		5/13/2015	Deferred	MLLD Line Tightness Testing	
2,520,000		12/4/2015			
11	56	1/1/1960	Unknown	Steel	
714	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Gasoline		5/13/2015	Deferred	MLLD Line Tightness Testing	
1,512,000		12/4/2015			
14	56	1/1/1960	Unknown	Steel	
713	Yes		None	None	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable, Impressed Current
Kerosene		5/13/2015	Deferred	MLLD Line Tightness Testing	
21,000		11/3/2009			
17	56	1/1/1960	Unknown	Steel - Terminal Piping	
711	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		5/13/2015	Deferred	MLLD Line Tightness Testing	
1,050,000		12/4/2015			
18	56	1/1/1960	Unknown	Steel - Terminal Piping	
709	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Kerosene		5/13/2015	Deferred	MLLD Line Tightness Testing	
1,512,000		12/4/2015			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GREAT FALLS SINCLAIR
620 57TH ST S
GREAT FALLS, MT 59405 CASCADE

Contact: Greg Hanes, (406) 727-5746

Sys Fac ID: 07-02087
Last Inspected On: 1/19/2015
Operating Permit Renewal Date: 2/26/2018

Owners/Operators:

Set Five LLC, Owner	(719)-510-8778	PO BOX 827 HARLOWTON MT 59036
Great Falls Sinclair, Operator	(406)-727-5746	620 57TH ST S GREAT FALLS MT 59405-3940

Greg Haines, UST Class A Operator
Derek Richardson, UST Class A Operator
Roberta Gresham, UST Class B Operator
Greg Haines, UST Class B Operator
Norm Jensen, UST Class B Operator
Mitzi McIntosh, UST Class B Operator
NayOmie Bean, UST Class B Global Operator
Thomas O'Hagan, UST Class B Global Operator
Derek Richardson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	38	4/4/1978	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1933			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		1/19/2015	Automatic Tank Gauging 0.1, Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
8,000		9/3/2014	Gilbarco EMC Basic , Gilbarco		
2	38	4/4/1978	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1934			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/19/2015	Automatic Tank Gauging 0.1, Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
8,000		9/3/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GREAT FALLS SINCLAIR
620 57TH ST S
GREAT FALLS, MT 59405 CASCADE

Contact: Greg Hanes, (406) 727-5746

Sys Fac ID: 07-02087
Last Inspected On: 1/19/2015
Operating Permit Renewal Date: 2/26/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	38	4/4/1978	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1935			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/19/2015	Automatic Tank Gauging 0.1, Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
12,000		9/3/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MONTANA AIR NATIONAL GUARD UST
2800 AIRPORT AVENUE B
GREAT FALLS, MT 59404 CASCADE

Contact: Robert Tester, (406) 791-0316

Sys Fac ID: 07-02294
Last Inspected On: 9/28/2016
Operating Permit Renewal Date: 3/11/2020

Owners/Operators: Montana Air National Guard, Owner (406)-791-6330 2800 AIRPORT AVENUE B GREAT FALLS MT 59404-5570

Robin T Atkison, UST Class A Operator
Briana Boggio, UST Class A Operator
Cassie Clark, UST Class A Operator
Ted Clark, UST Class A Operator
Danny Collins, UST Class A Operator
Joe Kerkes, UST Class A Operator
Scott Kohles, UST Class A Operator
Joseph Leggett, UST Class A Operator
Mark Payton, UST Class A Operator
James Robertson, UST Class A Operator
Clint Tyler, UST Class A Operator
Dale Vig, UST Class A Operator
Briana Boggio, UST Class B Operator
Cassie Clark, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	61	1/1/1955	Bare Steel	No Piping	High Level Alarm
4783			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Jet Fuel		7/11/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
25,000			Other , Other		
3	61	1/1/1955	Bare Steel	No Piping	High Level Alarm
1667			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Jet Fuel		7/11/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
25,000			Other , Other		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MONTANA AIR NATIONAL GUARD UST
2800 AIRPORT AVENUE B
GREAT FALLS, MT 59404 CASCADE

Contact: Robert Tester, (406) 791-0316

Sys Fac ID: 07-02294
Last Inspected On: 9/28/2016
Operating Permit Renewal Date: 3/11/2020

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	61	1/1/1955	Bare Steel	No Piping	High Level Alarm
1665			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Jet Fuel		7/11/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
25,000			Other , Other		
5	61	1/1/1955	Bare Steel	No Piping	High Level Alarm
1664			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Jet Fuel		7/11/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
25,000			Other , Other		
6	61	1/1/1955	Bare Steel	No Piping	High Level Alarm
1663			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Jet Fuel		7/11/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
25,000			Other , Other		
7	61	1/1/1955	Bare Steel	No Piping	High Level Alarm
1662			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Jet Fuel		7/11/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
25,000			Other , Other		
18	22	10/1/1994	Fiberglass Reinforced Plastic	No Piping	
			Double-Walled	None	Yes
Currently in Use				Not Listed	Not Applicable
Oil/Water Separator		9/19/2007	Continuous Interstitial Monitor, Deferred		
500					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MONTANA AIR NATIONAL GUARD UST
2800 AIRPORT AVENUE B
GREAT FALLS, MT 59404 CASCADE

Contact: Robert Tester, (406) 791-0316

Sys Fac ID: 07-02294
Last Inspected On: 9/28/2016
Operating Permit Renewal Date: 3/11/2020

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
19	22	10/1/1994	Fiberglass Reinforced Plastic	No Piping	
			Double-Walled	None	Yes
Currently in Use				Gravity Feed	Not Applicable
Oil/Water Separator		9/19/2007	Continuous Interstitial Monitor, Deferred		
500					
20	22	10/1/1994	Fiberglass Reinforced Plastic	No Piping	
			Double-Walled	None	Yes
Currently in Use				Gravity Feed	Not Applicable
Oil/Water Separator		9/19/2007	Continuous Interstitial Monitor, Deferred		
500					
21	22	10/1/1994	Fiberglass Reinforced Plastic	No Piping	
			Double-Walled	None	Yes
Currently in Use				Gravity Feed	Not Applicable
Oil/Water Separator		9/19/2007	Continuous Interstitial Monitor		
500					
22			Steel Clad	No Piping	
			None	None	Yes
Currently in Use				Gravity Feed	
Oil/Water Separator		9/19/2007	Deferred		
110					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: FEDERAL AVIATION ADMIN AIRWAY TERMINAL
2830 AIRPORT AVENUE A
GREAT FALLS, MT 59404 CASCADE

Contact: Joe Konesky, (406) 453-1429

Sys Fac ID: 07-02558
Last Inspected On: 1/26/2015
Operating Permit Renewal Date: 3/26/2018

Owners/Operators: Federal Aviation Admin Great Falls, Owner (406)-788-8041 2830 AIRPORT AVENUE A GREAT FALLS MT 59404-5544

Joe Konesky, UST Class A Operator
Joe Konesky, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	19	7/31/1997	Unknown	Flexible Plastic	
1048	Yes	5/7/2012	None	Double-Walled	Yes
Currently in Use		7/31/2007	Not Required	U.S. Suction	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
1,500			Other , Other	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 4
700 10TH AVE S
GREAT FALLS, MT 59405 CASCADE
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 07-03217
Last Inspected On: 6/10/2016
Operating Permit Renewal Date: 8/13/2019

Owners/Operators: Billings Holdings LLC, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	8/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4805			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	21	8/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4806			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	21	8/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4804			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
2,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 4
700 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 07-03217
Last Inspected On: 6/10/2016
Operating Permit Renewal Date: 8/13/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	14	8/18/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4708			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	14	8/18/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4709			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: BENEFIS HEALTH CARE WEST CAMPUS
500 15TH AVE S
GREAT FALLS, MT 59405 CASCADE

Contact: Walt Williams, (406) 455-2512

Sys Fac ID: 07-03298
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 1/29/2018

Owners/Operators: Benefis Health Care, Owner (406)-455-5135 ATTN MIKE BATTLESON MAINTENANCE
PO BOX 5013
GREAT FALLS MT 59403-5013

Mike Battleson, UST Class A Operator
Louis D'Antuono, UST Class A Operator
Mike Battleson, UST Class B Operator
Louis D'Antuono, UST Class B Operator
Kim Frank, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	20	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3401		9/22/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1	Continuous Interstitial Monitor	
2,000			EECO 1500 , EMCO Electronics		
6	17	5/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4003		9/22/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1	Continuous Interstitial Monitor	
15,000			EECO 1500 , EMCO Electronics		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 5
3700 31ST ST SW SUITE 1
GREAT FALLS, MT 59404 CASCADE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 07-03463
Last Inspected On: 6/10/2016
Operating Permit Renewal Date: 8/13/2019

Owners/Operators: Great Falls Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	27	1/15/1989	Steel Clad	Fiberglass Reinforced Plastic	Ball Float Valve
2223			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		2/17/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	27	1/15/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2224			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/17/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
14,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	23	4/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2225			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/17/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 5
3700 31ST ST SW SUITE 1
GREAT FALLS, MT 59404 CASCADE
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 07-03463
Last Inspected On: 6/10/2016
Operating Permit Renewal Date: 8/13/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	23	4/1/1993	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2226			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		2/17/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	23	4/1/1993	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2227			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		2/17/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
11	10	4/25/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5080			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/12/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
12	10	4/26/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5081			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/12/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
13	10	4/25/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5082			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/12/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: LOAF 'N JUG #765
3726 2ND AVE N
GREAT FALLS, MT 59401 CASCADE
Contact: Shirley Treece, (719) 948-5976

Sys Fac ID: 07-03920
Last Inspected On: 5/18/2016
Operating Permit Renewal Date: 8/13/2019

Owners/Operators: Mini Mart Inc dba Loaf 'N Jug, Owner (719)-948-3071 442 KEELER PKWY PUEBLO CO 81001-4813

Randal Liebnow, UST Class A Operator
John Sumowski, UST Class A Operator
Derrick Trimble, UST Class A Operator
Anthony Mosmiller, UST Class B Operator
Timothy Osterman, UST Class B Operator
Stevie Ulstad, UST Class B Operator
JENNIFER COLEMAN, UST Class B Global Operator
Dustin Harpster, UST Class B Global Operator
Casey Jambretz, UST Class B Global Operator
Randal Liebnow, UST Class B Global Operator
Anthony Mosmiller, UST Class B Global Operator
Toni Mullen, UST Class B Global Operator
Hiede Richardson, UST Class B Global Operator
Derrick Trimble, UST Class B Global Operator
Stevie Ulstad, UST Class B Global Operator
DeWayne Young, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	3/24/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1624			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: LOAF 'N JUG #765
3726 2ND AVE N
GREAT FALLS, MT 59401 CASCADE
Contact: Shirley Treece, (719) 948-5976

Sys Fac ID: 07-03920
Last Inspected On: 5/18/2016
Operating Permit Renewal Date: 8/13/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	32	3/24/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1625			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	32	3/24/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1626			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: H&R Inc #5
3601 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Contact: Harinder Singh, (406) 868-2062

Sys Fac ID: 07-03973
Last Inspected On: 12/9/2014
Operating Permit Renewal Date: 3/27/2018

Owners/Operators:

Singh Inc, Owner	(406)-868-2062	ATTN HARINDER SINGH PO BOX 7208 GREAT FALLS MT 59406-7208
H & R Inc, Operator	(406)-868-2062	3601 10TH AVE S GREAT FALLS MT 59405-3449

Harinder Singh, UST Class A Operator
Rajinder Singh, UST Class A Operator
Frank Kruse, UST Class B Operator
Frank Kruse, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	25	6/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1248			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		6/22/2011			
7	25	6/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1249			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		5/18/2011			
8	25	6/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1250			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		5/18/2011			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MDOT 31 0701 GREAT FALLS
200 SMELTER AVE NE
GREAT FALLS, MT 59404 CASCADE
Contact: Joe Radonich, (406) 444-9204

Sys Fac ID: 07-04047
Last Inspected On: 12/9/2014
Operating Permit Renewal Date: 3/25/2018

Owners/Operators:

MDOT Helena, Owner	(406)-444-6200	KIM JANZEN PO BOX 201001 HELENA MT 59620-1001
Joseph J Radonich, Operator	(406)-444-9204	MDT DEADHEAD HELENA MT 59620-0901

Jeff Gleason, UST Class A Operator
Brittany Hrgich, UST Class A Operator
Walt Kerttula, UST Class A Operator
James Lamm, UST Class A Operator
Mike Murolo, UST Class A Operator
Joe Radonich, UST Class A Operator
Brian Boettcher, UST Class B Operator
Lucas Cowan, UST Class B Operator
Mark Goldstein, UST Class B Operator
James Lamm, UST Class B Operator
Victor Scott, UST Class B Operator
Brittany Hrgich, UST Class B Global Operator
Joe Radonich, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	26	11/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3704			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		12/9/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MDOT 31 0701 GREAT FALLS
200 SMELTER AVE NE
GREAT FALLS, MT 59404 CASCADE

Contact: Joe Radonich, (406) 444-9204

Sys Fac ID: 07-04047
Last Inspected On: 12/9/2014
Operating Permit Renewal Date: 3/25/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	24	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3705			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/9/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: KERNAGHANS SERVICE 8TH AVE N
1507 8TH AVE N
GREAT FALLS, MT 59401 CASCADE
Contact: Bob Burns, (406) 452-9505

Sys Fac ID: 07-04508
Last Inspected On: 8/31/2016
Operating Permit Renewal Date: 10/26/2019

Owners/Operators: James Kernaghan, Owner (406)-452-9505 PO BOX 1711
GREAT FALLS MT 59403-1711

Jeff Rearden, UST Class A Operator
Dennis Albrecht, UST Class B Operator
Bob Burns, UST Class B Operator
Steve Monaco, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	27	7/28/1989	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1473			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
7,500			TLS-350/Gilbarco EMC , Veeder Root		
4	27	7/28/1989	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1474			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-350/Gilbarco EMC , Veeder Root		
5	27	7/28/1989	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1475			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
7,500			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: KERNAGHANS SERVICE 8TH AVE N
1507 8TH AVE N
GREAT FALLS, MT 59401 CASCADE
Contact: Bob Burns, (406) 452-9505

Sys Fac ID: 07-04508
Last Inspected On: 8/31/2016
Operating Permit Renewal Date: 10/26/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	27	7/28/1989	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1476			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
7	27	7/28/1989	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1477			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
8	27	7/28/1989	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1478			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
9	34	7/29/1982	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1479			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
2,500			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: KERNAGHANS SERVICE 9TH AVE N
1504 9TH AVE N
GREAT FALLS, MT 59401 CASCADE
Contact: (406) 452-9505

Sys Fac ID: 07-04509
Last Inspected On: 8/29/2014
Operating Permit Renewal Date: 9/3/2017

Owners/Operators: James Kernaghan, Owner (406)-452-9505 PO BOX 1711
GREAT FALLS MT 59403-1711

Jeff Rearden, UST Class A Operator
Dennis Albrecht, UST Class B Operator
Bob Burns, UST Class B Operator
Steve Monaco, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	18	5/23/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1480			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
2,000			TLS-350/Gilbarco EMC , Veeder Root		
6	18	5/23/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1481			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
1,000			TLS-350/Gilbarco EMC , Veeder Root		
7	18	5/23/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1482			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
2,000			TLS-350/Gilbarco EMC , Veeder Root		
8	18	5/23/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1483			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
3,500			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: KERNAGHANS SERVICE 9TH AVE N
1504 9TH AVE N
GREAT FALLS, MT 59401 CASCADE
Contact: (406) 452-9505

Sys Fac ID: 07-04509
Last Inspected On: 8/29/2014
Operating Permit Renewal Date: 9/3/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	18	5/23/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1484			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
1,500			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOLAN DISTRIBUTING INC
2201 VAUGHN RD
GREAT FALLS, MT 59404 CASCADE

Contact: Darron Tolan, (406) 453-8810

Sys Fac ID: 07-04511
Last Inspected On: 5/28/2014
Operating Permit Renewal Date: 9/15/2017

Owners/Operators: Tolan Distributing Inc, Owner (406)-453-8810 PO BOX 2923
GREAT FALLS MT 59403-2923

Derrick Tolan, UST Class A Operator
Derrick Tolan, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	17	9/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4098		9/28/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			EECO 1500 , EMCO Electronics		
7	17	9/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4099		9/28/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000			EECO 1500 , EMCO Electronics		
8	17	9/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4100		9/28/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			EECO 1500 , EMCO Electronics		
9	17	9/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4101		9/28/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000			EECO 1500 , EMCO Electronics		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: ZIP TRIP 44
1608 FOX FARM RD
GREAT FALLS, MT 59404 CASCADE
Contact: (406) 761-6421

Sys Fac ID: 07-04945
Last Inspected On: 3/14/2014
Operating Permit Renewal Date: 9/3/2017

Owners/Operators: CHS Inc - Spokane Valley, Owner (509)-535-7701 16124 E MARIETTA LANE SPOKANE WA 99213

Cenex Zip Trip, Operator (509)-535-7701 16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Tom Savas, UST Class A Operator
Luci Tuttle, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	48	1/1/1968	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1972			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		3/19/2008	TLS-350/Gilbarco EMC , Veeder Root		
3	48	1/1/1968	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1973			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		3/19/2008	TLS-350/Gilbarco EMC , Veeder Root		
5	19	11/3/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1974			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000		3/19/2008	TLS-350/Gilbarco EMC , Veeder Root		
6	19	11/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1975			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		3/19/2008	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GREAT FALLS TRANSIT DISTRICT
3905 N STAR BLVD PO BOX 2353
GREAT FALLS, MT 59405 CASCADE

Contact: Jim Hegleson, (406) 727-0382

Sys Fac ID: 07-05346
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 6/2/2019

Owners/Operators: Great Falls Transit District, Owner (406)-727-0382 PO BOX 2353
GREAT FALLS MT 59403-2353

James Helgeson, UST Class A Operator
Jack Hoffman, UST Class A Operator
James Helgeson, UST Class B Operator
Jack Hoffman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	5/6/1985	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
1233			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,380		2/21/2007	TLS-350/Gilbarco EMC , Veeder Root		
2	31	5/6/1985	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1234			None	None	Yes
Currently in Use			Not Required	Gravity Feed	Not Applicable
Waste Oil			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
1,000		2/26/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: CITY SHOP COMPLEX
1025 25TH AVE NE
GREAT FALLS, MT 59404 CASCADE
Contact: Doug Alm, (406) 781-8993

Sys Fac ID: 07-05558
Last Inspected On: 5/16/2016
Operating Permit Renewal Date: 8/11/2019

Owners/Operators: City of Great Falls, Owner (406)-771-1180 PO BOX 5021
GREAT FALLS MT 59403

Doug Alm, UST Class A Operator
Dale Calvert, UST Class A Operator
Doug Alm, UST Class B Global Operator
Dale Calvert, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	26	2/23/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
640			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		7/31/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		4/16/2016	TLS-450 , Veeder Root		
7	26	2/23/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
641			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		7/31/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		4/16/2016	TLS-450 , Veeder Root		
8	26	2/23/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
642			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		7/31/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/18/2013	TLS-450 , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: LOAF 'N JUG #766
900 1ST AVE N
GREAT FALLS, MT 59401 CASCADE
Contact: Shirley Treece, (719) 948-5976

Sys Fac ID: 07-05775
Last Inspected On: 5/18/2016
Operating Permit Renewal Date: 8/13/2019

Owners/Operators: Mini Mart Inc dba Loaf 'N Jug, Owner (719)-948-3071 442 KEELER PKWY PUEBLO CO 81001-4813

Randal Liebnow, UST Class A Operator
John Sumowski, UST Class A Operator
Derrick Trimble, UST Class A Operator
Sarah Mosmiller, UST Class B Operator
Timothy Osterman, UST Class B Operator
Stevie Ulstad, UST Class B Operator
JENNIFER COLEMAN, UST Class B Global Operator
Dustin Harpster, UST Class B Global Operator
Casey Jambretz, UST Class B Global Operator
Randal Liebnow, UST Class B Global Operator
Anthony Mosmiller, UST Class B Global Operator
Toni Mullen, UST Class B Global Operator
Hiede Richardson, UST Class B Global Operator
Derrick Trimble, UST Class B Global Operator
Stevie Ulstad, UST Class B Global Operator
DeWayne Young, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	33	4/27/1983	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1627			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: LOAF 'N JUG #766
900 1ST AVE N
GREAT FALLS, MT 59401 CASCADE
Contact: Shirley Treece, (719) 948-5976

Sys Fac ID: 07-05775
Last Inspected On: 5/18/2016
Operating Permit Renewal Date: 8/13/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	33	4/27/1983	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1628			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	33	4/27/1983	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1629			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: LOAF 'N JUG #767
601 SMELTER AVE NW
GREAT FALLS, MT 59404 CASCADE
Contact: Shirley Treece, (719) 948-5976

Sys Fac ID: 07-05776
Last Inspected On: 5/18/2016
Operating Permit Renewal Date: 8/6/2019

Owners/Operators: Mini Mart Inc dba Loaf 'N Jug, Owner (719)-948-3071 442 KEELER PKWY PUEBLO CO 81001-4813

Randal Liebnow, UST Class A Operator
John Sumowski, UST Class A Operator
Derrick Trimble, UST Class A Operator
Frank Headley, UST Class B Operator
Timothy Osterman, UST Class B Operator
Stevie Ulstad, UST Class B Operator
JENNIFER COLEMAN, UST Class B Global Operator
Dustin Harpster, UST Class B Global Operator
Casey Jambretz, UST Class B Global Operator
Randal Liebnow, UST Class B Global Operator
Anthony Mosmiller, UST Class B Global Operator
Toni Mullen, UST Class B Global Operator
Hiede Richardson, UST Class B Global Operator
Derrick Trimble, UST Class B Global Operator
DeWayne Young, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	33	4/27/1983	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
3638			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: LOAF 'N JUG #767
601 SMELTER AVE NW
GREAT FALLS, MT 59404 CASCADE
Contact: Shirley Treece, (719) 948-5976

Sys Fac ID: 07-05776
Last Inspected On: 5/18/2016
Operating Permit Renewal Date: 8/6/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	33	4/27/1983	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
3639			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
3	33	4/27/1983	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
3640			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: LOAF 'N JUG #768
1225 CENTRAL AVE W
GREAT FALLS, MT 59404 CASCADE
Contact: Shirley Treece, (719) 948-5976

Sys Fac ID: 07-05777
Last Inspected On: 5/18/2016
Operating Permit Renewal Date: 8/6/2019

Owners/Operators: Mini Mart Inc dba Loaf 'N Jug, Owner (719)-948-3071 442 KEELER PKWY PUEBLO CO 81001-4813

Randal Liebnow, UST Class A Operator
John Sumowski, UST Class A Operator
Derrick Trimble, UST Class A Operator
Casey Jambretz, UST Class B Operator
Anthony Mosmiller, UST Class B Operator
Timothy Osterman, UST Class B Operator
Stevie Ulstad, UST Class B Operator
Dustin Harpster, UST Class B Global Operator
Casey Jambretz, UST Class B Global Operator
Randal Liebnow, UST Class B Global Operator
Anthony Mosmiller, UST Class B Global Operator
Toni Mullen, UST Class B Global Operator
Hiede Richardson, UST Class B Global Operator
Derrick Trimble, UST Class B Global Operator
DeWayne Young, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	44	4/26/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1630		8/29/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		1/7/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	44	4/26/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1631		8/29/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		1/7/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: LOAF 'N JUG #768
1225 CENTRAL AVE W
GREAT FALLS, MT 59404 CASCADE
Contact: Shirley Treece, (719) 948-5976

Sys Fac ID: 07-05777
Last Inspected On: 5/18/2016
Operating Permit Renewal Date: 8/6/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	44	4/26/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1632		8/29/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		1/7/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GAS N SHOP
101 SMELTER AVE NW
GREAT FALLS, MT 59404 CASCADE
Contact: Harinder Singh, (406) 771-0730

Sys Fac ID: 07-05851
Last Inspected On: 12/8/2014
Operating Permit Renewal Date: 3/27/2018

Owners/Operators: Muhar LLC, Owner (406)-624-6912 1001 34TH AVE NE GREAT FALLS MT 59404

Gurinderbir Muhar, UST Class A Operator
Harinder Singh, UST Class A Operator
Frank Kruse, UST Class B Operator
Gurinderbir Muhar, UST Class B Global Operator
Sandeep Muhar, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	28	7/21/1988	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1251			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Approved Remote Monitoring	
4,000		2/28/2006			
2	28	7/21/1988	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1252			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		2/28/2006			
3	28	7/21/1988	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1253			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		2/28/2006			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: BEST OIL DISTRIBUTING INC
5401 RIVER DR N
GREAT FALLS, MT 59405 CASCADE

Contact: Thomas Schimerowski, (406) 453-0971

Sys Fac ID: 07-05852
Last Inspected On: 2/5/2015
Operating Permit Renewal Date: 4/11/2018

Owners/Operators: BEST OIL DISTRIBUTING INC, Owner (406)-453-0971 ATTN THOMAS SCHIMEROWSKI
5401 RIVER DR N
GREAT FALLS MT 59405-1081

Thomas Schimerowski, UST Class A Operator
Jeff Slininger, UST Class A Operator
Brian McNeil, UST Class B Operator
Eddie Parker, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	35	5/1/1981	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1254			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		6/4/2003	TLS-350/Gilbarco EMC , Veeder Root		
3	35	5/1/1981	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1255			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		5/3/2002	TLS-350/Gilbarco EMC , Veeder Root		
4	35	5/1/1981	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1256			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		7/1/2001	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: BEST OIL DISTRIBUTING INC
5401 RIVER DR N
GREAT FALLS, MT 59405 CASCADE

Contact: Thomas Schimerowski, (406) 453-0971

Sys Fac ID: 07-05852
Last Inspected On: 2/5/2015
Operating Permit Renewal Date: 4/11/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	35	5/1/1981	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1257			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		5/29/2003	TLS-350/Gilbarco EMC , Veeder Root		
7	18	4/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1258			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		7/20/2001	TLS-350/Gilbarco EMC , Veeder Root		
8	18	4/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1259			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		9/24/2004	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: CITY MOTOR CO INC
3900 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Contact: Robert H Oakland, (406) 761-4900

Sys Fac ID: 07-05853
Last Inspected On: 3/24/2014
Operating Permit Renewal Date: 7/1/2017

Owners/Operators: City Motors, Owner (406)-761-4900 3900 10TH AVE S
GREAT FALLS MT 59405-3695

Ken Myers, UST Class A Operator
Ken Myers, UST Class B Operator
Casey O'Neill, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	27	9/1/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2365			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		3/20/2008	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
3,000		7/2/2014	EECO 1500 , EMCO Electronics		
7	27	9/1/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2366			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Waste Oil		3/20/2008	Automatic Tank Gauging 0.2	Deferred	
3,000		6/12/2014	EECO 1500 , EMCO Electronics		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: HALL TRANSIT CO
2620 UPPER RIVER RD
GREAT FALLS, MT 59405 CASCADE

Contact: Don Hall, (406) 452-0082

Sys Fac ID: 07-06402
Last Inspected On: 7/31/2014
Operating Permit Renewal Date: 8/6/2017

Owners/Operators: Hall Transit Co, Owner (406)-452-0082 2620 UPPER RIVER RD GREAT FALLS MT 59405-7231
Gary Walker, UST Class A Operator
Gary Walker, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	11/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1268			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		7/31/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		7/31/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: BENEFIS HEALTH CARE EAST CAMPUS UST
1101 26TH ST S
GREAT FALLS, MT 59405 CASCADE

Contact: Mike Battelson, (406) 727-3333

Sys Fac ID: 07-06552
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 3/20/2018

Owners/Operators: Benefis Health Care, Owner (406)-455-5135 ATTN MIKE BATTLESON MAINTENANCE
PO BOX 5013
GREAT FALLS MT 59403-5013

Mike Battleson, UST Class A Operator
Louis D'Antuono, UST Class A Operator
Troy England, UST Class A Operator
Kim Frank, UST Class A Operator
Mike Battleson, UST Class B Operator
Louis D'Antuono, UST Class B Operator
Kim Frank, UST Class B Operator
Troy England, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	15	3/30/2001	Concrete	Flexible Plastic	
4584	Yes	9/22/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel		12/12/2005	Deferred	Continuous Interstitial Monitor	
20,000			ILS-350 , Veeder Root		
4	08	8/22/2008	Fiberglass Reinforced Plastic	Steel	High Level Alarm
5190			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Jet Fuel			Automatic Tank Gauging 0.2	Deferred	
2,500			TLS-300 , Veeder Root		Yes

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: 15TH STREET SERVICE
1501 10TH AVE S
GREAT FALLS, MT 59405 CASCADE
Contact: Gary Maki, (406) 453-2070

Sys Fac ID: 07-07573
Last Inspected On: 12/8/2014
Operating Permit Renewal Date: 3/27/2018

Owners/Operators: Gary Maki, Owner (406)-453-2070 15TH STREET SERVICE
1501 10TH AVE S
GREAT FALLS MT 59405-2625

Gary Maki, UST Class A Operator
Gary Maki, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	27	1/16/1989	Steel Clad	Steel	Flapper Valve (Auto Shutoff)
3824			None	none	Yes
Currently in Use		1/16/1999	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/8/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
6,000		12/13/2011			
6	27	1/16/1989	Steel Clad	Steel	Flapper Valve (Auto Shutoff)
3825			None	none	Yes
Currently in Use		1/16/1999	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/8/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		12/13/2011			
7	27	1/16/1989	Steel Clad	Steel	Flapper Valve (Auto Shutoff)
3826			None	none	Yes
Currently in Use		1/16/1999	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/8/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		12/13/2011			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: 15TH STREET SERVICE
1501 10TH AVE S
GREAT FALLS, MT 59405 CASCADE
Contact: Gary Maki, (406) 453-2070

Sys Fac ID: 07-07573
Last Inspected On: 12/8/2014
Operating Permit Renewal Date: 3/27/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	27	1/16/1989	Steel Clad	Steel	Flapper Valve (Auto Shutoff)
3827			None	none	Yes
Currently in Use		1/16/1999	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/8/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		12/13/2011			

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: HOLIDAY STATIONSTORE 273
1021 15TH ST N
GREAT FALLS, MT 59401 CASCADE
Contact: Jack Krueger, (406) 860-9083

Sys Fac ID: 07-08069
Last Inspected On: 9/3/2014
Operating Permit Renewal Date: 12/4/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Stephen Reckinger, UST Class A Operator
Dean Townsend, UST Class A Operator
Ronald VanDenBroeke, UST Class A Operator
Christine Banach, UST Class B Operator
Jason Miksell, UST Class B Operator
Stephen Reckinger, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator
Dean Townsend, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	5/15/1998	Steel Clad	Flexible Plastic	Ball Float Valve
2995			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/16/2009	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		3/27/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	
5	18	5/15/1998	Steel Clad	Flexible Plastic	Ball Float Valve
2996			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/16/2009	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		5/13/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	
6	18	5/15/1998	Steel Clad	Flexible Plastic	Ball Float Valve
2997			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/16/2009	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		6/16/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: THE STORE GREAT FALLS
3800 3RD AVE S
GREAT FALLS, MT 59405 CASCADE

Contact: Mark Schulte, (406) 453-3450

Sys Fac ID: 07-08480
Last Inspected On: 1/26/2015
Operating Permit Renewal Date: 3/24/2018

Owners/Operators: Mark Schulte, Owner (406)-453-3450 3800 3RD AVE S
GREAT FALLS MT 59405-3613

Judy Schulte, UST Class A Operator
Judy Schulte, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	30	12/7/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1906			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		1/15/2015	TLS-300 , Veeder Root		
2	30	12/7/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1907			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		1/15/2015	TLS-300 , Veeder Root		
3	26	12/7/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1908			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		1/15/2015	TLS-300 , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 1
401 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 07-08700
Last Inspected On: 6/10/2016
Operating Permit Renewal Date: 8/13/2019

Owners/Operators: Town Pump Inc Butte, Owner (406)-782-9121 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	30	1/1/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2391			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/19/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	30	1/1/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2392			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/19/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	28	8/18/1988	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2393			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/19/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 1
401 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 07-08700
Last Inspected On: 6/10/2016
Operating Permit Renewal Date: 8/13/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2394			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		3/16/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2395			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/16/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 2
1400 10TH AVE S
GREAT FALLS, MT 59405 CASCADE
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 07-08701
Last Inspected On: 6/10/2016
Operating Permit Renewal Date: 8/13/2019

Owners/Operators: Town Pump of Great Falls Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Megan Gretch, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Megan Gretch, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	1/4/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2396			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
3	26	1/4/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2397			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
4	26	1/4/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2398			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 2
1400 10TH AVE S
GREAT FALLS, MT 59405 CASCADE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 07-08701
Last Inspected On: 6/10/2016
Operating Permit Renewal Date: 8/13/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	26	1/4/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2399			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
6	26	1/4/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2400			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: HOLIDAY STATIONSTORE 10
1601 FOX FARM RD
GREAT FALLS, MT 59404 CASCADE

Contact: Bary Moore, (406) 827-4314

Sys Fac ID: 07-09914
Last Inspected On: 9/3/2014
Operating Permit Renewal Date: 12/4/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Jack Krueger Jr, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Jolene Edmisten, UST Class B Operator
Casey Light, UST Class B Operator
Debbie Osweiler, UST Class B Operator
Joseph Wanago, UST Class B Operator
Travis Struckman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	18	6/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Ball Float Valve
1697			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
15,000		5/21/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	
7	18	6/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Ball Float Valve
1698			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
8,000		5/11/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	
8	18	6/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Ball Float Valve
1699			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		8/15/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: Lithia Real Estate Inc
26 9TH ST S
GREAT FALLS, MT 59401 CASCADE

Contact: Brian Belderrain, (406) 727-2100

Sys Fac ID: 07-10262
Last Inspected On: 5/9/2014
Operating Permit Renewal Date: 7/5/2017

Owners/Operators: Bennett Motors Inc, Owner (406)-727-2100 PO BOX 2267
GREAT FALLS MT 59403-2267

Dan Noland, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	40	1/27/1976	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
430			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Gasoline			Stat. Inventory Reconcilitation	Deferred	
1,998					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GREAT FALLS INTERNATIONAL AIRPORT FUEL FARM 1
1931 AIRPORT CT
GREAT FALLS, MT 59404 CASCADE

Contact: Rodney Hall, (406) 727-3404

Sys Fac ID: 07-10676
Last Inspected On: 6/15/2016
Operating Permit Renewal Date: 10/11/2019

Owners/Operators: Great Falls International Airport, Owner (406)-727-3404 2800 TERMINAL DR GREAT FALLS MT 59404-5501

Mike Cunningham, UST Class A Operator
Kent Funyak, UST Class A Operator
Rod Hall, UST Class A Operator
Jeremy Hill, UST Class A Operator
Chris Houghton, UST Class A Operator
LeeRoy Bollich, UST Class B Operator
Mike Cunningham, UST Class B Operator
Kent Funyak, UST Class B Operator
Rod Hall, UST Class B Operator
Jeremy Hill, UST Class B Operator
Jeff Hoock, UST Class B Operator
Chris Houghton, UST Class B Operator
Robert Konigsfeld, UST Class B Operator
Paul Puckett, UST Class B Operator
Stefan Reese, UST Class B Operator
Scott E Mee, UST Class B Global Operator
Michael Sullivan, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	42	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3747			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Jet Fuel		9/4/2014	Automatic Tank Gauging 0.2	Deferred	
25,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GREAT FALLS INTERNATIONAL AIRPORT FUEL FARM 1
1931 AIRPORT CT
GREAT FALLS, MT 59404 CASCADE

Contact: Rodney Hall, (406) 727-3404

Sys Fac ID: 07-10676
Last Inspected On: 6/15/2016
Operating Permit Renewal Date: 10/11/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	42	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3748			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Jet Fuel		9/4/2014	Automatic Tank Gauging 0.2	Deferred	
25,000			TLS-350/Gilbarco EMC , Veeder Root		
3	42	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3746			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Jet Fuel		9/4/2014	Automatic Tank Gauging 0.2	Deferred	
19,000			TLS-350/Gilbarco EMC , Veeder Root		
4	42	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3740			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Aviation Gas		9/4/2014	Automatic Tank Gauging 0.2	Deferred	
15,275			TLS-350/Gilbarco EMC , Veeder Root		
5	42	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3741			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Aviation Gas		9/4/2014	Automatic Tank Gauging 0.2	Deferred	
15,275			TLS-350/Gilbarco EMC , Veeder Root		
6	42	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3743			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Jet Fuel		9/4/2014	Automatic Tank Gauging 0.2	Deferred	
15,275			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GREAT FALLS INTERNATIONAL AIRPORT FUEL FARM 1
1931 AIRPORT CT
GREAT FALLS, MT 59404 CASCADE

Contact: Rodney Hall, (406) 727-3404

Sys Fac ID: 07-10676
Last Inspected On: 6/15/2016
Operating Permit Renewal Date: 10/11/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	42	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3742			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Gasoline		9/4/2014	Automatic Tank Gauging 0.2	Deferred	
15,275			TLS-350/Gilbarco EMC , Veeder Root		
8	42	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3745			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Jet Fuel		9/4/2014	Automatic Tank Gauging 0.2	Deferred	
15,000			TLS-350/Gilbarco EMC , Veeder Root		
9	42	4/3/1974	Cathodically Protected Steel	No Piping	High Level Alarm
3744			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Jet Fuel		9/4/2014	Automatic Tank Gauging 0.2	Deferred	
15,275			TLS-350/Gilbarco EMC , Veeder Root		
10	21	11/1/1995	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
3749			None	None	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Jet Fuel		8/31/2006	Automatic Tank Gauging 0.2	Deferred	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
11	21	11/1/1995	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
3750			None	None	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Aviation Gas		8/31/2006	Automatic Tank Gauging 0.2		
20,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MEADOWLARK COUNTRY CLUB
300 COUNTRY CLUB BLVD
GREAT FALLS, MT 59404 CASCADE

Contact: Tim Furan, (406) 899-6846

Sys Fac ID: 07-11234
Last Inspected On: 1/12/2016
Operating Permit Renewal Date: 3/1/2019

Owners/Operators: Meadowlark Country Club, Owner (406)-453-6531 300 COUNTRY CLUB BLVD GREAT FALLS MT 59404-3355

Tim Furan, UST Class A Operator
Tim Furan, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	5/23/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2317			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		1/12/2016	Automatic Tank Gauging 0.2	Deferred	
1,000			OPW 1500 , OPW		
3	25	5/23/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2318			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		1/12/2016	Automatic Tank Gauging 0.2	Deferred	
1,000			OPW 1500 , OPW		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: RENTAL CAR SERVICE BUILDING
2700 AIRPORT DR
GREAT FALLS, MT 59404 CASCADE

Contact: Rod Hall, (406) 727-3404

Sys Fac ID: 07-12300
Last Inspected On: 5/27/2016
Operating Permit Renewal Date: 7/20/2019

Owners/Operators: Great Falls International Airport, Owner (406)-727-3404 2800 TERMINAL DR GREAT FALLS MT 59404-5501

Kent Funyak, UST Class A Operator
Rod Hall, UST Class A Operator
Chris Houghton, UST Class A Operator
Kent Funyak, UST Class B Operator
Rod Hall, UST Class B Operator
Chris Houghton, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	11/27/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2704			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
8,000			TLS-300 , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: MCLAUGHLIN RESEARCH INSTITUTE
1520 23RD ST S
GREAT FALLS, MT 59405 CASCADE

Contact: James R Toms, (406) 452-6208

Sys Fac ID: 07-12790
Last Inspected On: 2/16/2016
Operating Permit Renewal Date: 7/16/2019

Owners/Operators: Joe Amato, Owner (406)-799-4595 1520 23RD ST S
GREAT FALLS MT 59405-4900

Joe Amato, UST Class A Operator
Joe Amato, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	5/23/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2977			Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
1,000		2/16/2016	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: SUCH GROUP INTERNATIONAL INC
2224 VAUGHN RD
GREAT FALLS, MT 59404 CASCADE

Contact: Will Bernhagon, (406) 252-9440

Sys Fac ID: 07-13632
Last Inspected On: 4/30/2015
Operating Permit Renewal Date:

Owners/Operators: Such Group International Inc, Owner/Operator (406)-727-4144 PO BOX 2589
GREAT FALLS MT 59403

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	8/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4389			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000					
2	21	8/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4390			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: FEDERAL AVIATION ADMIN ARSR 4
BOOTLEGGER RIDGE
GREAT FALLS, MT 59401 CASCADE

Contact: Joe Konesky, (406) 788-8041

Sys Fac ID: 07-13710
Last Inspected On: 6/9/2015
Operating Permit Renewal Date: 6/15/2018

Owners/Operators: Federal Aviation Admin Great Falls, Owner (406)-788-8041 2830 AIRPORT AVENUE A
GREAT FALLS MT 59404-5544

Joe Konesky, UST Class A Operator
Joe Konesky, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	4/1/1996	Unknown	Flexible Plastic	
4564	Yes	6/9/2015	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
2,000			Other , Other		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: HOLIDAY STATION STORE 59
601 NORTHWEST BYP
GREAT FALLS, MT 59404 CASCADE
Contact: Bary Moore, (406) 827-3498

Sys Fac ID: 07-13729
Last Inspected On: 9/3/2014
Operating Permit Renewal Date: 12/4/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Jack Krueger Jr, UST Class A Operator
Stephen Reckinger, UST Class A Operator
FOSTER SENSIBAUGH, UST Class B Operator
Stephen Reckinger, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	7/17/1996	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3359			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/6/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
12,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	
2	20	7/17/1996	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3360			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/6/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
8,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	
3	20	7/17/1996	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3361			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/6/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: CASCADE COUNTY SHERIFFS OFFICE
3800 ULM NORTH FRONTAGE RD
GREAT FALLS, MT 59404 CASCADE

Contact: Douglas Daniels, (406) 454-6834

Sys Fac ID: 07-13772
Last Inspected On: 9/2/2014
Operating Permit Renewal Date: 9/12/2017

Owners/Operators: Cascade County Sheriffs/Adult Detention, Owner/Operator (406)-454-6834 3800 ULM N FRONTAGE RD GREAT FALLS MT 59404

Doug Daniels, UST Class A Operator
Charles Livingston, UST Class A Operator
Doug Daniels, UST Class B Operator
Billie Gaines, UST Class B Operator
Charles Livingston, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	5/6/1997	Unknown	Flexible Plastic	Flapper Valve (Auto Shutoff)
537	Yes	9/2/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel		9/2/2009	Deferred	Continuous Interstitial Monitor	
2,000			TLS-350/Gilbarco EMC , Veeder Root		
2	19	5/6/1997	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4489			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Waste Oil		8/1/2014	Continuous Interstitial Monitor	Deferred	
600		9/2/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: HOLIDAY #730
1428 3RD ST NW
GREAT FALLS, MT 59404 CASCADE

Contact: Reckenger Steve, (952) 830-8028

Sys Fac ID: 56-13970
Last Inspected On: 11/5/2015
Operating Permit Renewal Date: 3/30/2019

Owners/Operators:

Rocky Mountain Oil Inc, Owner	(952)-830-8700	ATTN: ENVIRONMENTAL DIRECTOR 4567 AMERICAN BLVD W BLOOMINGTON MN 55437
Holiday #730, Operator	(952)-830-8747	1428 3RD ST NW GREAT FALLS MT 59404

Robert Deninno, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Dan Baker, UST Class B Operator
Curt Seaman, UST Class B Operator
James Sneed, UST Class B Operator
Greg Brewer, UST Class B Global Operator
Jim Dundas, UST Class B Global Operator
Stephen Reckinger, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	16	7/7/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4203			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		10/20/2015	TLS-450 , Veeder Root	Continuous Interstitial Monitor	
2	16	7/7/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4204			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		8/10/2015	TLS-450 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: HOLIDAY #724
2260 10TH AVE S
GREAT FALLS, MT 59405 CASCADE
Contact: (952) 830-8899

Sys Fac ID: 56-13975
Last Inspected On: 12/7/2015
Operating Permit Renewal Date: 3/30/2019

Owners/Operators: Rocky Mountain Oil Inc, Owner (952)-830-8700 ATTN: ENVIRONMENTAL DIRECTOR
4567 AMERICAN BLVD W
BLOOMINGTON MN 55437

Holiday #724, Operator (952)-830-8747 2260 10TH AVE S
GREAT FALLS MT 59405

Robert Deninno, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Kevin Dyke, UST Class B Operator
Peter Garth, UST Class B Operator
Greg Brewer, UST Class B Global Operator
Stephen Reckinger, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	16	10/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4219			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		8/23/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	16	10/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4220			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		8/23/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 3
505 NORTHWEST BYP
GREAT FALLS, MT 59404 CASCADE
Contact: (406) 260-1700

Sys Fac ID: 56-14016
Last Inspected On: 6/10/2016
Operating Permit Renewal Date: 8/13/2019

Owners/Operators: Billings Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	15	10/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4453			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/30/2005	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
15,000		10/12/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	15	10/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4454			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/30/2005	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		10/12/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	15	10/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4455			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/30/2005	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		10/12/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: TOWN PUMP INC GREAT FALLS 3
505 NORTHWEST BYP
GREAT FALLS, MT 59404 CASCADE
Contact: (406) 260-1700

Sys Fac ID: 56-14016
Last Inspected On: 6/10/2016
Operating Permit Renewal Date: 8/13/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	15	10/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4456			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/30/2005	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		10/12/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	15	10/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4457			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/30/2005	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		10/12/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: SAMS CLUB 6379
401 NORTHWEST BYP
GREAT FALLS, MT 59404 CASCADE

Contact: Mark Johnson, (406) 585-8005

Sys Fac ID: 56-14065
Last Inspected On: 7/11/2014
Operating Permit Renewal Date: 10/16/2017

Owners/Operators: Sams West Inc, Owner (479)-204-2330 702 SW 8TH ST
BENTONVILLE AR 72716-6209

Kevin E Allen, UST Class A Operator
Bobbi Brown, UST Class A Operator
JOHNNY CAVILL, UST Class A Operator
Donald Elderbaum, UST Class A Operator
Steven Hodge, UST Class A Operator
Josh Kelly, UST Class A Operator
Joseph Khan, UST Class A Operator
Michael Lawson, UST Class A Operator
Teddy Moulton, UST Class A Operator
Denise Purvis, UST Class A Operator
Bobbi Brown, UST Class B Operator
Michael Lawson, UST Class B Operator
Phillip Patat, UST Class B Operator
Denise Purvis, UST Class B Operator
Kevin E Allen, UST Class B Global Operator
JOHNNY CAVILL, UST Class B Global Operator
Donald Elderbaum, UST Class B Global Operator
Steven Hodge, UST Class B Global Operator
Josh Kelly, UST Class B Global Operator
Joseph Khan, UST Class B Global Operator
Michael Lawson, UST Class B Global Operator
Teddy Moulton, UST Class B Global Operator
James Ray, UST Class B Global Operator
Rick Weaver, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: SAMS CLUB 6379
401 NORTHWEST BYP
GREAT FALLS, MT 59404 CASCADE
Contact: Mark Johnson, (406) 585-8005

Sys Fac ID: 56-14065
Last Inspected On: 7/11/2014
Operating Permit Renewal Date: 10/16/2017

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
1	14	8/5/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4702			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
20,000		3/4/2014	EECO 2000 , EMCO Electronics	Continuous Interstitial Monitor	
2	14	8/5/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4703			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
20,000		3/4/2014	EECO 2000 , EMCO Electronics	Continuous Interstitial Monitor	
3	14	8/5/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4704			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
20,000		3/4/2014	EECO 2000 , EMCO Electronics	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GREAT FALLS FLYING J
3715 31ST ST SW
GREAT FALLS, MT 59404 CASCADE
Contact: Shane Swiegert, (406) 497-6700

Sys Fac ID: 56-14148
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 4/9/2019

Owners/Operators: Montana Innovations LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000
Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	11	2/25/2005	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4956			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000		2/29/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	11	2/25/2005	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4957			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000		2/24/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	11	2/25/2005	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4958			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000		2/24/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: GREAT FALLS FLYING J
3715 31ST ST SW
GREAT FALLS, MT 59404 CASCADE

Contact: Shane Swiegert, (406) 497-6700

Sys Fac ID: 56-14148
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 4/9/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	11	1/25/2005	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4959			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		2/23/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: SMITH'S 166 FUEL CENTER
1601 MARKET PLACE DR
GREAT FALLS, MT 59401 CASCADE

Contact: David Harris, (801) 974-1206

Sys Fac ID: 60-15217
Last Inspected On: 11/12/2015
Operating Permit Renewal Date: 4/16/2019

Owners/Operators: David Harris, Owner (801)-974-1206 PO BOX 244
WINNETT MT 59087-0244

Kerry Busey, UST Class A Operator
Gary Dotseth, UST Class A Operator
Todd Dotseth, UST Class A Operator
David Harris, UST Class A Operator
Steven Perkins, UST Class A Operator
Todd Dotseth, UST Class B Operator
Kerry Busey, UST Class B Global Operator
Gary Dotseth, UST Class B Global Operator
David Harris, UST Class B Global Operator
Steven Perkins, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	03	12/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5395			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-450 , Veeder Root	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Not Listed	Yes
2	03	12/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5396			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in CASCADE County in the City of GREAT FALLS

Location: SMITH'S 166 FUEL CENTER
1601 MARKET PLACE DR
GREAT FALLS, MT 59401 CASCADE

Contact: David Harris, (801) 974-1206

Sys Fac ID: 60-15217
Last Inspected On: 11/12/2015
Operating Permit Renewal Date: 4/16/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	03	12/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5397			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in CASCADE County in the City of MALMSTROM A F B

Location: MALMSTROM AFB BLDG 500
21 77TH ST N
MALMSTROM A F B, MT 59402 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-08954
Last Inspected On: 8/1/2015
Operating Permit Renewal Date: 12/16/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
David Degolier, UST Class B Operator
Lana Hedlund, UST Class B Global Operator
James Hodges, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	16	11/22/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4227		7/31/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of MALMSTROM A F B

Location: MALMSTROM AFB BLDG 1480 1482
6705 FLIGHTLINE DR
MALMSTROM A F B, MT 59402 CASCADE

Contact: Jim Hodges, (406) 731-6167

Sys Fac ID: 07-10733
Last Inspected On: 8/1/2015
Operating Permit Renewal Date: 12/16/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
RODNEY BORGER, UST Class B Global Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	20	8/1/1996	Fiberglass Reinforced Plastic	Steel	Positive Shutoff, High Level Alarm
4325		7/31/2015	Double-Walled	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Jet Fuel		7/31/2015	Continuous Interstitial Monitor	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
4,000		11/26/2012	Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of MALMSTROM A F B

Location: MILITARY VEHICLE REFUELING SITE BLDG 448
7832 FLIGHTLINE DR
MALMSTROM A F B, MT 59402 CASCADE

Contact: (406) 731-6175

Sys Fac ID: 56-14116
Last Inspected On: 8/1/2015
Operating Permit Renewal Date: 12/16/2018

Owners/Operators: Malmstrom AFB, Owner (406)-731-6167 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	11	6/15/2005	Concrete	Flexible Plastic	High Level Alarm
4971	Yes	7/31/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
>B20			Deferred	Continuous Interstitial Monitor	
60,000			TLS-350/Gilbarco EMC , Veeder Root		
3	11	8/5/2005	Concrete	Flexible Plastic	High Level Alarm
4972	Yes	7/31/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
4	11	8/5/2005	Concrete	Flexible Plastic	High Level Alarm
5037	Yes	7/31/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
>E15			Deferred	Continuous Interstitial Monitor	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of MALMSTROM A F B

Location: AAFES SHOPPING CENTER BLDG 1340
7200 PERIMETER ROAD
MALMSTROM A F B, MT 59402 CASCADE

Contact: Lana Hedlund, (406) 731-6175

Sys Fac ID: 60-15199
Last Inspected On: 8/1/2015
Operating Permit Renewal Date: 1/2/2019

Owners/Operators:

Malmstrom AFB, Owner	(406)-731-6167	39 78TH ST N MALMSTROM AFB MT 59402-7536
Josh Probst, Operator	(214)-312-4616	3911 SO. WALTON WALKER BLVD. DALLAS TX 75236

Sonya Coker, UST Class A Operator
Lana Hedland, UST Class A Operator
Fatima Quintanilla, UST Class A Operator
Sonya Coker, UST Class B Operator
Fatima Quintanilla, UST Class B Operator
Sonya Coker, UST Class B Global Operator
Lana Hedland, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	05	9/1/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
5329			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/11/2012	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
2	05	9/1/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
5330			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/11/2012	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in CASCADE County in the City of MONARCH

Location: COUGAR CANYON LODGE & ESCAPE
5012 US HIGHWAY 89 S
MONARCH, MT 59463 CASCADE

Contact: Brett Smith, (406) 277-3314

Sys Fac ID: 07-01874
Last Inspected On: 7/17/2016
Operating Permit Renewal Date: 7/25/2019

Owners/Operators:

Mark Properties LLC, Owner	(406)-236-5922	PO BOX 884 MONARCH MT 59463
Three Rivers Petroleum Services, Operator	(406)-439-1805	PO BOX 4172 HELENA MT 59604-4172

Kurt Gallagher, UST Class A Operator
Richard Hatanpaa, UST Class A Operator
Kurt Gallagher, UST Class B Operator
Richard Hatanpaa, UST Class B Operator
Judy McCurdie, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	9/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2979			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
2,000		7/17/2016			

Facility Summary in CASCADE County in the City of MONARCH

Location: MALMSTROM AFB A 5
US HIGHWAY 89
MONARCH, MT 59463 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-08979
Last Inspected On: 9/19/2014
Operating Permit Renewal Date: 9/25/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
110		5/12/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of MONARCH

Location: MALMSTROM AFB A 6
US HIGHWAY 89
MONARCH, MT 59463 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-08980
Last Inspected On: 9/19/2014
Operating Permit Renewal Date: 9/25/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
111		5/19/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of MONARCH

Location: MALMSTROM AFB A 7
US HIGHWAY 89
MONARCH, MT 59463 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-08981
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 10/7/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
112		5/26/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of MONARCH

Location: MALMSTROM AFB A 8
US HIGHWAY 89
MONARCH, MT 59463 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-08982
Last Inspected On: 9/19/2014
Operating Permit Renewal Date: 9/25/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
113		6/2/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of NEIHART

Location: BOBS BAR UST
107 MAIN ST
NEIHART, MT 59465 CASCADE

Contact: Tony Juntunen, (406) 236-5955

Sys Fac ID: 07-09274
Last Inspected On: 11/25/2014
Operating Permit Renewal Date: 5/16/2018

Owners/Operators: Anthony E Juntunen, Owner (406)-236-5955 PO BOX 37
NEIHART MT 59465-0037

Anthony E Juntunen, UST Class A Operator
Anthony E Juntunen, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	2/16/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1455			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
1,500					
2	29	2/16/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1456			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
1,500					

Facility Summary in CASCADE County in the City of SAND COULEE

Location: CENTERVILLE ELEMENTARY SCHOOL
693 STOCKETT RD
SAND COULEE, MT 59472 CASCADE

Contact: Ed Cutlip, (406) 736-5123

Sys Fac ID: 07-11037
Last Inspected On: 3/28/2014
Operating Permit Renewal Date: 4/3/2017

Owners/Operators: Centerville School, Owner (406)-736-5123 693 STOCKETT RD
SAND COULEE MT 59472-9757

Steve Beaumont, UST Class A Operator
Steve Beaumont, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	30	4/30/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
606			None	Double-Walled	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Heating Oil		3/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/28/2014		Continuous Interstitial Monitor	

Facility Summary in CASCADE County in the City of SIMMS

Location: CURTISS SERVICE CENTER
12742 MT HIGHWAY 200
SIMMS, MT 59477 CASCADE

Contact: Robert Curtiss, (406) 264-5222

Sys Fac ID: 07-01612
Last Inspected On: 4/24/2014
Operating Permit Renewal Date: 7/30/2017

Owners/Operators: Robert D Curtiss, Owner (406)-264-5640 PO BOX 306
SIMMS MT 59477-0306

Robert D Curtiss, UST Class A Operator
Robert D Curtiss, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	17	11/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4124			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/10/2014	TLS-350/Gilbarco EMC , Veeder Root		
7	17	11/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4125			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/10/2014	TLS-350/Gilbarco EMC , Veeder Root		
8	17	11/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4126			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		4/10/2014	TLS-350/Gilbarco EMC , Veeder Root		
9	17	11/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4127			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		4/10/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB G 2
MT HIGHWAY 200
SIMMS, MT 59477 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-09042
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
117		9/9/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB H 7
MT HIGHWAY 200
SIMMS, MT 59477 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-09058
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	9/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
124		6/10/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB G 01
MT HIGHWAY 200
SIMMS, MT 59477 CASCADE

Contact: Jim Hodges, (406) 731-6167

Sys Fac ID: 25-09041
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Ricardo Andrillon, UST Class B Operator
Glen Beck, UST Class B Operator
Allen Brooks, UST Class B Operator
Jonathan Buesch, UST Class B Operator
John Corbett, UST Class B Operator
David Cosner, UST Class B Operator
Ryan Cox, UST Class B Operator
Brian Day, UST Class B Operator
David Degolier, UST Class B Operator
Patrick Ellis, UST Class B Operator
Hudson English, UST Class B Operator
Paul Floyd, UST Class B Operator
Dustin Hemingway, UST Class B Operator
Aaron Hill, UST Class B Operator
William Hoffmeister, UST Class B Operator
Shane Hofstad, UST Class B Operator
Bethany Kent, UST Class B Operator
James Knudsen, UST Class B Operator
Ryan Kofoed, UST Class B Operator
Jeff Laird, UST Class B Operator
Damon McCarty, UST Class B Operator
Kieth McIlwain, UST Class B Operator
Brian McVay, UST Class B Operator
Ronald Miller, UST Class B Operator
Michael Murieen, UST Class B Operator
Jeff Nelson, UST Class B Operator
Patrick Noppenberg, UST Class B Operator
Shawn O'Grady, UST Class B Operator
Chris Ploof, UST Class B Operator
Issac Price, UST Class B Operator
Brian Rayner, UST Class B Operator

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB G 01
MT HIGHWAY 200
SIMMS, MT 59477 CASCADE

Sys Fac ID: 25-09041
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges, (406) 731-6167

Cameron Smith, UST Class B Operator
Jimmy Sonefelt, UST Class B Operator
Michael Stokes, UST Class B Operator
Kyle Topp, UST Class B Operator
Jason Vike, UST Class B Operator
James Wooderchak, UST Class B Operator
Paul Ziemba, UST Class B Operator
Paul Floyd, UST Class B Global Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	54	6/2/1962	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
250		9/9/2015	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Impressed Current
Diesel		7/31/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB G 6
ROAD 287
SIMMS, MT 59477 CASCADE
Contact: Jim Hodges, (406) 731-6167

Sys Fac ID: 25-09046
Last Inspected On: 9/18/2015
Operating Permit Renewal Date: 9/23/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
251		9/16/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB G 7
MT HIGHWAY 200
SIMMS, MT 59477 CASCADE

Contact: Jim Hodges, (406) 731-6167

Sys Fac ID: 25-09047
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4271		9/16/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB G 8
MT HIGHWAY 200
SIMMS, MT 59477 CASCADE

Contact: Jim Hodges, (406) 731-6167

Sys Fac ID: 25-09048
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
253		9/16/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB G 11
MT HIGHWAY 200
SIMMS, MT 59477 CASCADE

Contact: Jim Hodges, (406) 731-6167

Sys Fac ID: 25-09051
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	27	5/21/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
256		9/9/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of SIMMS

Location: MALMSTROM AFB H 8
MT HIGHWAY 21
SIMMS, MT 59477 CASCADE

Contact: Jim Hodges, (406) 731-6167

Sys Fac ID: 25-09059
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	9/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
257		6/10/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of STOCKETT

Location: MALMSTROM AFB A 9
ROAD 227
STOCKETT, MT 59480 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-08983
Last Inspected On: 9/19/2014
Operating Permit Renewal Date: 9/25/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator
James Hodges, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
114		6/9/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of STOCKETT

Location: MALMSTROM AFB I 2
ROAD 226
STOCKETT, MT 59480 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-09064
Last Inspected On: 9/8/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	10/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
126		6/16/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of SUN RIVER

Location: MALMSTROM AFB H 4
US HIGHWAY 89
SUN RIVER, MT 59483 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-09055
Last Inspected On: 9/18/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	9/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
121		9/14/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000		4/17/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of SUN RIVER

Location: MALMSTROM AFB H 5
US HIGHWAY 89
SUN RIVER, MT 59483 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-09056
Last Inspected On: 9/18/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	9/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
122		9/11/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of ULM

Location: MALMSTROM AFB I 7
INTERSTATE 15
ULM, MT 59485 CASCADE

Sys Fac ID: 07-09069
Last Inspected On: 9/9/2015
Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
131		6/16/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of ULM

Location: MALMSTROM AFB I 11
INTERSTATE 15
ULM, MT 59485 CASCADE

Sys Fac ID: 07-09073
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	10/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
134		6/12/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of ULM

Location: MOUNTAIN VIEW CO OP
2 MILLEGAN RD
ULM, MT 59485 CASCADE
Contact: Dan Morano, (406) 453-2435

Sys Fac ID: 56-13797
Last Inspected On: 8/17/2014
Operating Permit Renewal Date: 11/14/2017

Owners/Operators: Mountain View Coop, Owner/Operator (406)-453-2435 ATTN DAVE DOUGLAS
2200 OLD HAVRE HWY
BLACK EAGLE MT 59414-1043

David Douglas, UST Class A Operator
Charles Niswanger, UST Class A Operator
Robin Niswanger, UST Class A Operator
John Malley, UST Class B Operator
Charles Niswanger, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	10/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4428			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		7/21/2011	TLS-350/Gilbarco EMC , Veeder Root		
2	19	10/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4429			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		7/21/2011	TLS-350/Gilbarco EMC , Veeder Root		
3	19	10/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4430			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		7/21/2011	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of VAUGHN

Location: VALLEY COUNTRY STORE INC
133 US HIGHWAY 89
VAUGHN, MT 59487 CASCADE

Contact: Cory Eli, (406) 799-0128

Sys Fac ID: 07-05008
Last Inspected On: 5/10/2016
Operating Permit Renewal Date: 6/30/2019

Owners/Operators: Valley Country Store Inc, Owner (406)-965-3962 PO BOX 65 VAUGHN MT 59487-0065

Cory Eli, UST Class A Operator
Cory Eli, UST Class B Operator
Cory Eli, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	19	4/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2208			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		1/20/2010	Gilbarco EMC Basic , Gilbarco		
6	19	4/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2209			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		1/20/2010	Gilbarco EMC Basic , Gilbarco		
7	19	4/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2210			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		1/20/2010	Gilbarco EMC Basic , Gilbarco		

Facility Summary in CASCADE County in the City of VAUGHN

Location: MALMSTROM AFB I 10
INTERSTATE 15
VAUGHN, MT 59487 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-09072
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
133		6/12/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of VAUGHN

Location: MALMSTROM AFB J 8
INTERSTATE 15
VAUGHN, MT 59487 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-09081
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
135		9/14/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of VAUGHN

Location: MALMSTROM AFB J 9
INTERSTATE 15
VAUGHN, MT 59487 CASCADE

Contact: Jim Hodges,

Sys Fac ID: 07-09082
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	8/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
136		9/15/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of VAUGHN

Location: MALMSTROM AFB H 3
INTERSTATE 15
VAUGHN, MT 59487 CASCADE

Contact: Jim Hodges, (406) 731-6167

Sys Fac ID: 50-09054
Last Inspected On: 9/14/2015
Operating Permit Renewal Date: 9/23/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	9/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
313		6/9/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CASCADE County in the City of VAUGHN

Location: MALMSTROM AFB J 10
INTERSTATE 15
VAUGHN, MT 59487 CASCADE

Contact: Jim Hodges, (406) 731-6167

Sys Fac ID: 50-09083
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	8/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
319		9/15/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000		5/29/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CASCADE County in the City of VAUGHN

Location: GLACIER GATEWAY
99 US HIGHWAY 89
VAUGHN, MT 59487 CASCADE

Contact: Jake Neil, (406) 799-6499

Sys Fac ID: 56-13783
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 4/9/2018

Owners/Operators:

NCI Tech Company LLC, Owner	(406)-965-9014	PO BOX 509 VAUGHN MT 59487
Glacier Gateway, Operator	(406)-965-9014	PO BOX 509 VAUGHN MT 59487

Eric Bucher, UST Class A Operator
Kevin Enochs, UST Class A Operator
KEVIN FRANCIS, UST Class A Operator
Jake Neil, UST Class A Operator
Kay Neil, UST Class A Operator
Shalina Abrams, UST Class B Operator
JENNA BLAIR, UST Class B Operator
Bridget Bowen, UST Class B Operator
Andrea Bowie, UST Class B Operator
Jenifer Colden, UST Class B Operator
Amy Evans, UST Class B Operator
Vicki Ferda, UST Class B Operator
Christine Igel, UST Class B Operator
Janet Jensen, UST Class B Operator
Vicki Kriedeman, UST Class B Operator
Barbara Matthews, UST Class B Operator
Aaron McConnell, UST Class B Operator
Jake Neil, UST Class B Operator
Kay Neil, UST Class B Operator
Debbie Pengilly, UST Class B Operator
Roy Powell, UST Class B Operator
Matthew Schnittgen, UST Class B Operator
Justin Vallier, UST Class B Operator
Allicia Wick, UST Class B Operator
Josh Wick, UST Class B Operator
Leigh Wilson, UST Class B Operator
Marilyn Hutton, UST Class B Global Operator
BRENDA PISCHKE, UST Class B Global Operator
Helen Taylor, UST Class B Global Operator

Facility Summary in CASCADE County in the City of VAUGHN

Location: GLACIER GATEWAY
99 US HIGHWAY 89
VAUGHN, MT 59487 CASCADE

Contact: Jake Neil, (406) 799-6499

Sys Fac ID: 56-13783
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 4/9/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	6/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3444			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
2	19	6/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3445			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
3	19	6/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3446			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
4	19	6/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3447			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CHOUTEAU County in the City of BIG SANDY

Location: EZZIES WHOLESALE BIG SANDY
FERRY STAR ROUTE PO BOX 236
BIG SANDY, MT 59520 CHOUTEAU
Contact: (406) 378-2101

Sys Fac ID: 08-00855
Last Inspected On: 3/22/2016
Operating Permit Renewal Date: 7/9/2019

Owners/Operators: EZZIES WHOLESALE INC, Owner (406)-654-2331 PO BOX 1770 MALTA MT 59538-9640

David Skiff, UST Class A Operator
Kenneth Martin, UST Class B Operator
David Skiff, UST Class B Operator
David Skiff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	6/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1841			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	26	5/18/1990	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1842			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	24	6/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1844			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CHOUTEAU County in the City of BIG SANDY

Location: EZZIES WHOLESALE BIG SANDY
FERRY STAR ROUTE PO BOX 236
BIG SANDY, MT 59520 CHOUTEAU
Contact: (406) 378-2101

Sys Fac ID: 08-00855
Last Inspected On: 3/22/2016
Operating Permit Renewal Date: 7/9/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	24	6/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1845			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
11	26	5/18/1990	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1843			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
2,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CHOUTEAU County in the City of BIG SANDY

Location: MOUNTAIN VIEW COOP BIG SANDY
79211 US HIGHWAY 87
BIG SANDY, MT 59520 CHOUTEAU

Contact: Chester Kallem, (406) 453-2435

Sys Fac ID: 56-14150
Last Inspected On: 1/2/2014
Operating Permit Renewal Date: 4/27/2017

Owners/Operators: Mountain View Coop, Owner (406)-453-2435 ATTN DAVE DOUGLAS
2200 OLD HAVRE HWY
BLACK EAGLE MT 59414-1043

David Douglas, UST Class A Operator
David Douglas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	11	1/31/2005	Bare Steel	Flexible Plastic	High Level Alarm
4965	Yes	4/9/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
5,000		9/10/2014			
2	11	1/31/2005	Bare Steel	Flexible Plastic	High Level Alarm
4966	Yes	4/9/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
5,000		9/10/2014			
3			Bare Steel	Flexible Plastic	
4967	Yes	4/15/2013	None	Double-Walled	Yes
Temporarily Out of Use				Pressurized	
Unknown			Deferred	Continuous Interstitial Monitor	
1					
4			Bare Steel	Flexible Plastic	
4968	Yes	4/15/2013	None	Double-Walled	Yes
Temporarily Out of Use				Not Listed	
Unknown			Deferred	Continuous Interstitial Monitor	
1					

Facility Summary in CHOUTEAU County in the City of CARTER

Location: SCHULER LANDS EAST FARM
17105 DENT BRIDGE RD
CARTER, MT 59420 CHOUTEAU

Contact: Dale Schuler, (406) 734-5404

Sys Fac ID: 08-03976
Last Inspected On: 8/8/2015
Operating Permit Renewal Date: 11/21/2018

Owners/Operators:

Schuler Lands Inc, Owner	(406)-734-5404	17105 DENT BRIDGE RD CARTER MT 59420-0036
Schuler Bros, Operator	(406)-734-5404	17105 DENT BRIDGE RD CARTER MT 59420
Dale Schuler, UST Class A Operator		
Dale Schuler, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	34	4/22/1982	Fiberglass Reinforced Plastic	No Piping	Flapper Valve (Auto Shutoff)
4133			None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2		
9,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in CHOUTEAU County in the City of CARTER

Location: MALMSTROM AFB J 3
US HIGHWAY 87
CARTER, MT 59420 CHOUTEAU

Contact: Jim Hodges,

Sys Fac ID: 08-09076
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
157		9/15/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CHOUTEAU County in the City of CARTER

Location: MALMSTROM AFB J 5
US HIGHWAY 87
CARTER, MT 59420 CHOUTEAU

Contact: Jim Hodges,

Sys Fac ID: 08-09078
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	8/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
159		9/15/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CHOUTEAU County in the City of FORT BENTON

Location: MOUNTAIN VIEW COOP FORT BENTON
1820 SAINT CHARLES ST
FORT BENTON, MT 59442 CHOUTEAU
Contact: Buck Pandis, (406) 622-5121

Sys Fac ID: 08-00005
Last Inspected On: 2/14/2014
Operating Permit Renewal Date: 6/19/2017

Owners/Operators: Mountain View Coop, Owner (406)-453-2435 ATTN DAVE DOUGLAS
2200 OLD HAVRE HWY
BLACK EAGLE MT 59414-1043

Patricia Holskey, UST Class A Operator
Pat Trainor, UST Class A Operator
Patricia Holskey, UST Class B Operator
David Douglas, UST Class B Global Operator
Pat Trainor, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	39	12/11/1976	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1021			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		5/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
6	24	12/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1025			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		5/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
7	24	12/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1023			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		5/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
8	24	12/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1024			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		5/29/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CHOUTEAU County in the City of FORT BENTON

Location: MOUNTAIN VIEW COOP FORT BENTON
1820 SAINT CHARLES ST
FORT BENTON, MT 59442 CHOUTEAU
Contact: Buck Pandis, (406) 622-5121

Sys Fac ID: 08-00005
Last Inspected On: 2/14/2014
Operating Permit Renewal Date: 6/19/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	24	12/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1022			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		5/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
16	14	3/28/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4628		4/12/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000		3/3/2008	TLS-350/Gilbarco EMC , Veeder Root		
17	14	3/28/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4629		4/12/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000		3/3/2008	TLS-350/Gilbarco EMC , Veeder Root		
18	14	3/28/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4630		4/12/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000		3/3/2008	TLS-350/Gilbarco EMC , Veeder Root		
19	14	3/28/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4631		4/12/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000		3/3/2008	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CHOUTEAU County in the City of FORT BENTON

Location: MOUNTAIN VIEW COOP FORT BENTON
1820 SAINT CHARLES ST
FORT BENTON, MT 59442 CHOUTEAU
Contact: Buck Pandis, (406) 622-5121

Sys Fac ID: 08-00005
Last Inspected On: 2/14/2014
Operating Permit Renewal Date: 6/19/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
20	14	3/28/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4632		4/12/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
30,000		3/3/2008	TLS-350/Gilbarco EMC , Veeder Root		
21	14	3/28/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4633		4/12/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
30,000		3/3/2008	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CHOUTEAU County in the City of FORT BENTON

Location: JOYCE STORE 1
1221 MAIN ST
FORT BENTON, MT 59442 CHOUTEAU
Contact: Kevin Joyce, (406) 622-3381

Sys Fac ID: 08-00093
Last Inspected On: 10/3/2016
Operating Permit Renewal Date: 11/20/2019

Owners/Operators: Riverside Business Inc, Owner (406)-586-3531 5809 GOOCH HILL RD BOZEMAN MT 59718-9060

Perry Joyce, UST Class A Operator
Teresa Sparks, UST Class A Operator
Jennifer Ritland, UST Class B Operator
Teresa Sparks, UST Class B Operator
Kevin Joyce, UST Class B Global Operator
Jessica Smith, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	17	6/1/1999	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4134			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/4/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
5	17	6/1/1999	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4135			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/4/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
6	17	6/1/1999	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4136			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/10/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in CHOUTEAU County in the City of FORT BENTON

Location: COUNTY COURTHOUSE & JAIL
1215 WASHINGTON ST
FORT BENTON, MT 59442 CHOUTEAU
Contact: Bob Stevenson, (406) 622-3631

Sys Fac ID: 08-05930
Last Inspected On: 4/3/2014
Operating Permit Renewal Date: 9/9/2017

Owners/Operators: Choteau County, Owner (406)-622-3631 PO BOX 459
FORT BENTON MT 59442-0459

Robert C Stevenson, UST Class A Operator
Michael Hingiss, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	28	6/1/1988	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4118		6/13/2014	None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Manual Tank Gauging	Manual Interstitial Monitor	
550					

Facility Summary in CHOUTEAU County in the City of FORT BENTON

Location: JOYCE FUEL & FEEDS FORT BENTON
2118 SAINT CHARLES ST
FORT BENTON, MT 59442 CHOUTEAU

Contact: Brad Bramlette, (406) 622-3363

Sys Fac ID: 56-13981
Last Inspected On: 12/8/2014
Operating Permit Renewal Date: 1/14/2018

Owners/Operators: Perry Joyce, Owner (406)-737-4561 PO BOX 66
GERALDINE MT 59446-0066

Perry Joyce, UST Class A Operator
Bradley Bramlette, UST Class B Operator
Cody Joyce, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	16	7/27/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4210			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
3,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	16	7/27/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4211			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
3,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	16	7/27/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4212			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
3,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in CHOUTEAU County in the City of GERALDINE

Location: CENTRAL MONTANA COOP GERALDINE
MT HIGHWAY 80
GERALDINE, MT 59446 CHOUTEAU

Contact: Bruce Clark, (406) 737-4480

Sys Fac ID: 08-06615
Last Inspected On: 2/17/2016
Operating Permit Renewal Date:

Owners/Operators: Central Montana Coop Geraldine, Owner (406)-737-4480 PO BOX 330
GERALDINE MT 59446-0330

Danny Rowland, UST Class A Operator
Tom Burtchett, UST Class B Operator
Matthew Little, UST Class B Operator
Jon Mcomber, UST Class B Operator
Peter Rice, UST Class B Operator
Danny Rowland, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	42	4/29/1974	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
864	Yes		None	None	No
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
2,000		5/13/2013			
2	42	4/29/1974	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
865	Yes		None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
2,000		5/13/2013			

Facility Summary in CHOUTEAU County in the City of HIGHWOOD

Location: HIGHWOOD SERVICE CENTER UST
277 BROADWAY AVE W
HIGHWOOD, MT 59450 CHOUTEAU

Sys Fac ID: 08-12320
Last Inspected On: 10/22/2015
Operating Permit Renewal Date: 11/25/2018

Contact: Richard Schott, (406) 733-5251

Owners/Operators: Richard L Schott, Owner (406)-733-6072 3199 BURLEY HILL RD HIGHWOOD MT 59450-0026

Richard L Schott, UST Class A Operator
Richard L Schott, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	9/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3112			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, Deferred	
1,000					
2	25	9/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3113			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, Deferred	
1,000					

Facility Summary in CHOUTEAU County in the City of LOMA

Location: PA'S MART
204 BROADWAY
LOMA, MT 59460 CHOUTEAU

Sys Fac ID: 08-01445
Last Inspected On: 6/4/2015
Operating Permit Renewal Date:

Contact: Gregory Bouchard, (406) 739-4422

Owners/Operators: Gregory Bouchard, Owner (406)-739-4422 204 BROADWAY AVE LOMA MT 59460

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	12/30/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3957			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/29/2012	Inventory Reconciliation, Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
6,000					
2	29	12/30/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3958			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/29/2012	Inventory Reconciliation, Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
6,000					

Facility Summary in CHOUTEAU County in the City of RURAL LOCATION

Location: MALMSTROM AFB J 4
US HIGHWAY 87
RURAL LOCATION, MT CHOUTEAU

Contact: Jim Hodges,

Sys Fac ID: 08-09077
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
158		9/15/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CHOUTEAU County in the City of RURAL LOCATION

Location: MALMSTROM AFB J 7
US HIGHWAY 87
RURAL LOCATION, MT CHOUTEAU

Contact: Jim Hodges,

Sys Fac ID: 08-09080
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
161		9/15/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in CUSTER County in the City of MILES CITY

Location: FRANKS QUICK STOP LLC
1308 S HAYNES AVE
MILES CITY, MT 59301 CUSTER

Contact: Franks NGO, (406) 853-1991

Sys Fac ID: 09-00624
Last Inspected On: 10/29/2014
Operating Permit Renewal Date: 2/13/2018

Owners/Operators:

Franks Quick Stop LLC, Owner	(406)-234-6661	1308 SOUTH HAYNES AVE MILES CITY MT 59301
Frank Alan Ngo, Operator	(406)-234-6661	16 N 7TH ST MILES CITY MT 59301-3110

Frank Alan Ngo, UST Class A Operator
Daria Mann, UST Class B Operator
Jenny Moran, UST Class B Operator
Gerald Mace, UST Class B Global Operator
Jason South, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	26	7/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1788			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		8/9/2011	TLS-350/Gilbarco EMC , Veeder Root		
9	26	7/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1789			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		10/8/2011	TLS-350/Gilbarco EMC , Veeder Root		
10	26	7/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1790			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		10/29/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		10/8/2011	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CUSTER County in the City of MILES CITY

Location: M & H GAS MILES CITY
1019 MAIN ST
MILES CITY, MT 59301 CUSTER

Contact: Brandy Winkley, (406) 232-6838

Sys Fac ID: 09-01058
Last Inspected On: 4/8/2015
Operating Permit Renewal Date: 6/23/2018

Owners/Operators: Miller & Holmes Inc, Owner (715)-377-1730 2311 ONEIL RD HUDSON WI 54016-8168

Kevin Junker, UST Class A Operator
Kevin Junker, UST Class B Operator
Dave Lunder, UST Class B Operator
Sandy Maine, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	22	10/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1613			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/8/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		11/11/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	22	10/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1614			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/8/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		11/11/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	22	10/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1615			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/8/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
7,500		11/11/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CUSTER County in the City of MILES CITY

Location: M & H GAS MILES CITY
1019 MAIN ST
MILES CITY, MT 59301 CUSTER

Contact: Brandy Winkley, (406) 232-6838

Sys Fac ID: 09-01058
Last Inspected On: 4/8/2015
Operating Permit Renewal Date: 6/23/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	22	10/1/1994	Cathodically Protected Steel	Flexible Plastic	Positive Shutoff
1616			None	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Not Listed	
Diesel		4/8/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
7,500			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	

Facility Summary in CUSTER County in the City of MILES CITY

Location: MILES CITY BULK PLANT
S 4TH ST & PACIFIC AVE PO BOX 1440
MILES CITY, MT 59301 CUSTER

Contact: Dave Corbin, (406) 234-1350

Sys Fac ID: 09-03211
Last Inspected On: 7/30/2015
Operating Permit Renewal Date: 8/3/2018

Owners/Operators: Cenex Harvest States, Owner/Operator (406)-433-1401 PO BOX 1440 MILES CITY MT 59301

David Corbin, UST Class A Operator
Rick Harwood, UST Class A Operator
Dwayne Taylor, UST Class A Operator
David Corbin, UST Class B Operator
Dwayne Taylor, UST Class B Operator
Rick Harwood, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	39	3/26/1977	Bare Steel	No Piping	Flapper Valve (Auto Shutoff)
3586			Impressed Current	None	Yes
Currently in Use		3/1/2009	Not Required	Pressurized	Impressed Current
Diesel		7/9/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
11,000			TLS-300 , Veeder Root		
2	39	3/26/1977	Bare Steel	No Piping	Flapper Valve (Auto Shutoff)
3587			Impressed Current	None	Yes
Currently in Use		3/1/2009	Not Required	Pressurized	Impressed Current
Gasoline		7/9/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
11,000			TLS-300 , Veeder Root		
3	39	3/26/1977	Bare Steel	No Piping	Flapper Valve (Auto Shutoff)
3764			Impressed Current	None	Yes
Currently in Use		3/1/2009	Not Required	Pressurized	Impressed Current
Diesel		7/9/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
11,000			TLS-300 , Veeder Root		

Facility Summary in CUSTER County in the City of MILES CITY

Location: MILES CITY BULK PLANT
S 4TH ST & PACIFIC AVE PO BOX 1440
MILES CITY, MT 59301 CUSTER

Contact: Dave Corbin, (406) 234-1350

Sys Fac ID: 09-03211
Last Inspected On: 7/30/2015
Operating Permit Renewal Date: 8/3/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	39	3/26/1977	Bare Steel	No Piping	Flapper Valve (Auto Shutoff)
3588			Impressed Current	None	Yes
Currently in Use		3/1/2009	Not Required	Pressurized	Impressed Current
Gasoline		7/9/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
11,000			TLS-300 , Veeder Root		
5	39	3/26/1977	Bare Steel	No Piping	Flapper Valve (Auto Shutoff)
3589			Impressed Current	None	Yes
Currently in Use		3/1/2009	Not Required	Pressurized	Impressed Current
Diesel		7/9/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
11,000			TLS-300 , Veeder Root		
6	39	3/26/1977	Bare Steel	No Piping	Flapper Valve (Auto Shutoff)
3590			Impressed Current	None	Yes
Currently in Use		3/1/2009	Not Required	Pressurized	Impressed Current
Diesel		7/9/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
11,000			TLS-300 , Veeder Root		

Facility Summary in CUSTER County in the City of MILES CITY

Location: THE SHORT STOP STORE
16 N 7TH ST
MILES CITY, MT 59301 CUSTER

Contact: Teresa Newby, (406) 234-6661

Sys Fac ID: 09-04443
Last Inspected On: 3/18/2014
Operating Permit Renewal Date: 6/19/2017

Owners/Operators: Frank Alan Ngo, Owner (406)-234-6661 16 N 7TH ST MILES CITY MT 59301-3110

Frank A Ngo, UST Class A Operator
Frankie Meade, UST Class B Operator
Frank A Ngo, UST Class B Operator
Tony Russo, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	05	12/17/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5284			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/1/2010	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		12/23/2010	TLS-350/Gilbarco EMC , Veeder Root		Yes
8	05	12/17/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5285			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/1/2010	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
5,000		12/21/2010	TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in CUSTER County in the City of MILES CITY

Location: GM PETROLEUM DISTRIBUTORS
500 N 5TH ST
MILES CITY, MT 59301 CUSTER

Contact: Jay Brookie, (406) 252-4661

Sys Fac ID: 09-05859
Last Inspected On: 7/12/2016
Operating Permit Renewal Date: 11/15/2019

Owners/Operators: City Service Valcon LLC DBA GM Petroleum Distributors, Owner/Operator (406)-252-4661 PO BOX 30335 BILLINGS MT 59107
Bill Grunstead, UST Class A Operator
Roger Schmechel, UST Class A Operator
Laura Geffre, UST Class B Operator
Roger Schmechel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	18	11/1/1998	Bare Steel	Steel	
4009	Yes		None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		7/12/2016	Deferred	MLLD Line Tightness Testing	
17,335		7/12/2016			
6	18	11/1/1998	Bare Steel	Steel	
4010	Yes		None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		7/12/2016	Deferred	MLLD Line Tightness Testing	
17,335		7/12/2016			
7	18	11/1/1998	Bare Steel	Steel	
4011	Yes		None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		7/12/2016	Deferred	MLLD Line Tightness Testing	
17,335		7/12/2016			
8	18	11/1/1998	Bare Steel	Steel	
4012	Yes		None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		7/12/2016	Deferred	MLLD Line Tightness Testing	
10,123		7/12/2016			

Facility Summary in CUSTER County in the City of MILES CITY

Location: TOWN PUMP OF MILES CITY
1210 S HAYNES AVE
MILES CITY, MT 59301 CUSTER

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 09-07081
Last Inspected On: 3/30/2016
Operating Permit Renewal Date: 4/27/2019

Owners/Operators: Western Catering Services Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	5/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2401			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/18/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
2	22	5/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2402			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/18/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root		
3	22	5/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2403			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/18/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CUSTER County in the City of MILES CITY

Location: TOWN PUMP OF MILES CITY
1210 S HAYNES AVE
MILES CITY, MT 59301 CUSTER

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 09-07081
Last Inspected On: 3/30/2016
Operating Permit Renewal Date: 4/27/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
4	21	1/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2404			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/17/2009	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	21	1/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4890			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/17/2009	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
6	21	1/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4891			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/17/2009	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
16	16	11/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4232			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/17/2009	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CUSTER County in the City of MILES CITY

Location: TOWN PUMP OF MILES CITY
1210 S HAYNES AVE
MILES CITY, MT 59301 CUSTER

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 09-07081
Last Inspected On: 3/30/2016
Operating Permit Renewal Date: 4/27/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
17	16	11/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4233			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/17/2009	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root		
18	16	11/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4234			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/17/2009	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root		
19	16	11/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4235			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/17/2009	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
20	16	11/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4236			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/17/2009	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CUSTER County in the City of MILES CITY

Location: FRANK'S SHORT STOP II
301 MAIN ST
MILES CITY, MT 59301 CUSTER
Contact: Frank Ngo, (406) 853-1991

Sys Fac ID: 09-07083
Last Inspected On: 3/17/2014
Operating Permit Renewal Date: 6/8/2017

Owners/Operators: Frank's Short Stop, Owner/Operator (406)-853-1991 305 MAIN ST MILES CITY MT 59301

Frank Alan Ngo, UST Class A Operator
Dyna Bennett, UST Class B Operator
Theresa Bradshaw, UST Class B Operator
Gordon Dorothy, UST Class B Operator
Randall Morgan, UST Class B Operator
Jodien Twardoski, UST Class B Operator
Amy Stinson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	19	10/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
595			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/17/2014	Automatic Tank Gauging 0.2	ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root		
11	19	10/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
596			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/17/2014	Automatic Tank Gauging 0.2	ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
12	19	10/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
597			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/17/2014	Automatic Tank Gauging 0.2	ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CUSTER County in the City of MILES CITY

Location: VA MEDICAL CENTER MILES CITY
210 S WINCHESTER AVE
MILES CITY, MT 59301 CUSTER

Contact: Joe Dejong, (406) 232-8565

Sys Fac ID: 09-07784
Last Inspected On: 5/13/2016
Operating Permit Renewal Date: 8/2/2019

Owners/Operators: VA Medical Center, Owner (406)-232-3060 210 S WINCHESTER AVE
MILES CITY MT 59301-4757

James L Arneson, UST Class A Operator
Joseph Dejong, UST Class A Operator
James L Arneson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	11/17/1992	Fiberglass Reinforced Plastic	Steel	High Level Alarm
2194			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
2,000					
4	35	4/22/1981	Fiberglass Reinforced Plastic	Steel	High Level Alarm
2191			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		5/13/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	35	4/22/1981	Fiberglass Reinforced Plastic	Steel	High Level Alarm
2192			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		5/13/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	24	4/20/1992	Fiberglass Reinforced Plastic	Steel	High Level Alarm
2193			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		5/13/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CUSTER County in the City of MILES CITY

Location: ZIP TRIP 59
1321 S HAYNES AVE
MILES CITY, MT 59301 CUSTER
Contact: (406) 232-4549

Sys Fac ID: 09-08212
Last Inspected On: 3/18/2015
Operating Permit Renewal Date: 3/25/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Ian Johnstone, UST Class A Operator
Tom Savas, UST Class A Operator
Chuck Crane, UST Class B Operator
Darcy Ziegler, UST Class B Operator
Roderick Crane, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	25	5/3/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
547			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/15/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
9	25	5/3/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
4347			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/15/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
10	25	5/3/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
552			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/15/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in CUSTER County in the City of MILES CITY

Location: ZIP TRIP 59
1321 S HAYNES AVE
MILES CITY, MT 59301 CUSTER
Contact: (406) 232-4549

Sys Fac ID: 09-08212
Last Inspected On: 3/18/2015
Operating Permit Renewal Date: 3/25/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	25	5/3/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4348			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/15/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root		
12	25	5/3/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4349			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/15/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root		
13	25	5/3/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
551			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/15/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		12/21/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	

Facility Summary in CUSTER County in the City of MILES CITY

Location: QWEST MILES CITY CENTRAL OFFICE
811 PLEASANT ST PO BOX 1178
MILES CITY, MT 59301 CUSTER

Contact: kevin robison, (406) 232-4890

Sys Fac ID: 09-08778
Last Inspected On: 10/21/2014
Operating Permit Renewal Date: 3/5/2018

Owners/Operators:

Qwest Corporation, Owner	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111
Qwest Corporation, Operator	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111

Thomas J Pitts, UST Class A Operator
Kevin Robison, UST Class A Operator
Thomas J Pitts, UST Class B Operator
Kevin Robison, UST Class B Operator
Thomas J Pitts, UST Class B Global Operator
Kevin Robison, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	5/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1725			Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
553		7/29/2016	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in CUSTER County in the City of MILES CITY

Location: HOLY ROSARY HOSPITAL WILSON ST
2600 WILSON ST
MILES CITY, MT 59301 CUSTER

Contact: Clyde Leischner, (406) 233-2600

Sys Fac ID: 09-13574
Last Inspected On: 1/13/2016
Operating Permit Renewal Date: 2/10/2019

Owners/Operators: Holy Rosary Hospital, Owner (406)-233-2600 2600 WILSON ST STOP 1
MILES CITY MT 59301-5016

Mike Ryan, UST Class A Operator
Douglas Treu, UST Class A Operator
Shad Waldo, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	8/1/1994	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4284		12/8/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
8,000			ILS-350 , Veeder Root		

Facility Summary in CUSTER County in the City of MILES CITY

Location: ENTERPRISE SYSTEMS SERVICE CENTER
114 S HAYNES AVE
MILES CITY, MT 59301 CUSTER

Contact: Michael Krings, (406) 444-1815

Sys Fac ID: 60-15140
Last Inspected On: 7/29/2016
Operating Permit Renewal Date: 9/18/2019

Owners/Operators: MT Dept of Administration ITSD, Owner (406)-444-2700 ITSD
DEADHEAD
HELENA MT 59620-0113

Michael Krings, UST Class A Operator
John Salazar, UST Class A Operator
Ed Sivils, UST Class A Operator
John Salazar, UST Class B Operator
Ed Sivils, UST Class B Operator
Rennette Waldo, UST Class B Operator
Randy Anderson, UST Class B Global Operator
Mike Kennell, UST Class B Global Operator
Zane Rudolph, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	07	7/21/2009	Unknown	Flexible Plastic	High Level Alarm
5215	Yes	7/29/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in DANIELS County in the City of FLAXVILLE

Location: PRO CO-OP 3
MT HIGHWAY 5 & MAIN ST
FLAXVILLE, MT 59222 DANIELS
Contact: Tanner Trower, (406) 487-2741

Sys Fac ID: 10-01331
Last Inspected On: 8/19/2015
Operating Permit Renewal Date: 9/28/2018

Owners/Operators: Pro Co-op, Owner (406)-487-2741 PO BOX 847
SCOBEY MT 59263

Tanner Trower, UST Class A Operator
Richard Carrier, UST Class B Operator
Kent Cromwell, UST Class B Operator
Tanner Trower, UST Class B Operator
Tanner Trower, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	25	7/31/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1225			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		8/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
2,000			TLS-350/Gilbarco EMC , Veeder Root		
5	25	7/31/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1226			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		8/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
2,000			TLS-350/Gilbarco EMC , Veeder Root		
6	03	2/1/2013	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
5408	Yes	2/1/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	Yes

Facility Summary in DANIELS County in the City of FLAXVILLE

Location: PRO CO-OP 3
MT HIGHWAY 5 & MAIN ST
FLAXVILLE, MT 59222 DANIELS
Contact: Tanner Trower, (406) 487-2741

Sys Fac ID: 10-01331
Last Inspected On: 8/19/2015
Operating Permit Renewal Date: 9/28/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	03	2/1/2013	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
5409	Yes	2/1/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	Yes
8	03	2/1/2013	Bare Steel	Fiberglass Reinforced Plastic	
5453	Yes	2/1/2015	None	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	Yes

Facility Summary in DANIELS County in the City of SCOBEY

Location: CROMWELLS CONVENIENCE & PETROLEUM
3 MAIN ST
SCOBEY, MT 59263 DANIELS

Contact: Shane Cromwell, (406) 487-2441

Sys Fac ID: 10-01223
Last Inspected On: 6/14/2016
Operating Permit Renewal Date: 6/15/2019

Owners/Operators: Cromwells Convenience & Petroleum, Owner (406)-487-2441 PO BOX 990 SCOBEY MT 59263-0990

Shane Cromwell, UST Class A Operator
Kent Cromwell, UST Class B Operator
Shane Cromwell, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	20	5/1/1996	Aboveground Tank	Flexible Plastic	
2176	Yes	6/7/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
5,800			EECO 1500 , EMCO Electronics		
5	20	5/1/1996	Aboveground Tank	Flexible Plastic	
2177	Yes	6/7/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
12,000			EECO 1500 , EMCO Electronics		
6	20	5/1/1996	Aboveground Tank	Flexible Plastic	
2178	Yes	6/7/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000			EECO 1500 , EMCO Electronics		
7	20	5/1/1996	Aboveground Tank	Flexible Plastic	
2179	Yes	6/7/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
10,000			EECO 1500 , EMCO Electronics		

Facility Summary in DANIELS County in the City of SCOBEY

Location: PRO CO-OP 2
108 1ST ST
SCOBEY, MT 59263 DANIELS
Contact: Tanner Trower, (406) 487-2741

Sys Fac ID: 10-03710
Last Inspected On: 10/5/2015
Operating Permit Renewal Date: 2/23/2019

Owners/Operators: Pro Co-op, Owner (406)-487-2741 PO BOX 847
SCOBEY MT 59263

Tanner Trower, UST Class A Operator
Kent Cromwell, UST Class B Operator
Tanner Trower, UST Class B Operator
Tanner Trower, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	22	10/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1227		8/18/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		8/18/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		
5	22	10/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1228		8/18/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		8/18/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		
6	22	10/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1229		8/18/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		8/18/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		
7	22	10/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1230		8/18/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		8/18/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in DANIELS County in the City of SCOBEY

Location: PRO CO-OP 2
108 1ST ST
SCOBEY, MT 59263 DANIELS
Contact: Tanner Trower, (406) 487-2741

Sys Fac ID: 10-03710
Last Inspected On: 10/5/2015
Operating Permit Renewal Date: 2/23/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	22	10/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1231		8/18/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		8/18/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			Gilbarco EMC Basic , Gilbarco		
9	22	10/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1232		8/18/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		8/18/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in DANIELS County in the City of SCOBEY

Location: PRO CO-OP 1
3 DANIELS ST
SCOBEY, MT 59263 DANIELS

Contact: Tanner Trower, (406) 487-2741

Sys Fac ID: 10-04159
Last Inspected On: 10/5/2015
Operating Permit Renewal Date: 2/23/2019

Owners/Operators: Pro Co-op, Owner (406)-487-2741 PO BOX 847
SCOBEY MT 59263

Tanner Trower, UST Class A Operator
Kent Cromwell, UST Class B Operator
Tanner Trower, UST Class B Operator
Tanner Trower, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	08	10/10/2008	Unknown	Fiberglass Reinforced Plastic	
5699	Yes	8/18/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasohol/Ethanol			Deferred	Continuous Interstitial Monitor	
3,000					Yes
11	08	10/10/2008	Unknown	Fiberglass Reinforced Plastic	
5134	Yes	8/18/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
3,000					Yes

Facility Summary in DANIELS County in the City of SCOBEY

Location: NEMONT COMMUNICATIONS INC
MT HIGHWAY 13 S
SCOBEY, MT 59263 DANIELS

Contact: Thomas M Halverson, (800) 636-6680

Sys Fac ID: 10-13610
Last Inspected On: 8/28/2015
Operating Permit Renewal Date: 2/23/2019

Owners/Operators: Nemont Communications Inc, Owner (406)-783-5654 PO BOX 600
SCOBEY MT 59263-0600

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	4/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
3293			None	None	Yes
Currently in Use		4/1/2005	Not Required	Gravity Feed	Not Applicable
Waste Oil			Deferred	Deferred	
100					

Facility Summary in DAWSON County in the City of GLENDIVE

Location: EAST END CONOCO GLENDIVE
I1801 MARILL AVE
GLENDIVE, MT 59330 DAWSON
Contact: Ron Serpe, (800) 540-8325

Sys Fac ID: 11-00033
Last Inspected On: 1/4/2012
Operating Permit Renewal Date: 7/21/2018

Owners/Operators: Gregory Cross, Owner (406)-252-5519 PO BOX 1078
BILLINGS MT 59103-1078

Gregory Cross, UST Class A Operator
Timothy Fife, UST Class A Operator
RJ Serpe, UST Class A Operator
RJ Serpe, UST Class B Global Operator
Ron Serpe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	01	2/9/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5535		2/5/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		3/20/2015	TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	Yes
9	01	2/9/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5536		2/5/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		3/20/2015	TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	Yes
10	01	2/9/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5537		2/5/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		3/20/2015	TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in DAWSON County in the City of GLENDIVE

Location: EAST END CONOCO GLENDIVE
I1801 MARILL AVE
GLENDIVE, MT 59330 DAWSON
Contact: Ron Serpe, (800) 540-8325

Sys Fac ID: 11-00033
Last Inspected On: 1/4/2012
Operating Permit Renewal Date: 7/21/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	01	2/9/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5538		2/5/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		3/20/2015	TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in DAWSON County in the City of GLENDIVE

Location: DAWSON COMMUNITY AIRPORT
402 DRY CREEK RD
GLENDIVE, MT 59330 DAWSON

Contact: Craig Hostetler, (406) 687-3372

Sys Fac ID: 11-02455
Last Inspected On: 6/15/2015
Operating Permit Renewal Date: 9/29/2018

Owners/Operators:

Dawson County, Owner	(406)-687-3372	ATTN: AIRPORT MANAGER 207 W BELL ST GLENDIVE MT 59330-1616
Leon Baker, Operator	(406)-687-3372	318 S TAYLOR AVE GLENDIVE MT 59330-2440

Leon Baker, UST Class A Operator
Craig Hostetler, UST Class A Operator
Leon Baker, UST Class B Operator
Craig Hostetler, UST Class B Operator
Bill Stebbins, UST Class B Operator
Leon Baker, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	22	11/21/1994	Cathodically Protected Steel	Other	Positive Shutoff
824		7/29/2012	None	Secondary Containment Chase	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Aviation Gas		9/5/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000		9/30/2016	EECO 1500 , EMCO Electronics		
5	42	1/1/1974	Unknown	Steel	
825	Yes		None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable, Galvanic
Jet Fuel		9/5/2013	Deferred	MLLD Line Tightness Testing	
200		9/30/2016			

Facility Summary in DAWSON County in the City of GLENDIVE

Location: BERGS TIRE INC
2111 W TOWNE ST
GLENDIVE, MT 59330 DAWSON
Contact: Jay Berg, (406) 377-5286

Sys Fac ID: 11-03214
Last Inspected On: 4/26/2016
Operating Permit Renewal Date: 7/20/2019

Owners/Operators: Berg Tire, Owner (406)-377-5286 2111 W TOWNE ST
GLENDIVE MT 59330-3214

James Berg, UST Class A Operator
James Berg, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	3/26/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
601			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		4/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		4/26/2016	TLS-350/Gilbarco EMC , Veeder Root		
2	29	3/26/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
600			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current, Galvanic
Diesel		4/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		4/26/2016	TLS-350/Gilbarco EMC , Veeder Root		
3	29	3/26/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
599			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		4/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		4/26/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in DAWSON County in the City of GLENDIVE

Location: BERGS TIRE INC
2111 W TOWNE ST
GLENDIVE, MT 59330 DAWSON
Contact: Jay Berg, (406) 377-5286

Sys Fac ID: 11-03214
Last Inspected On: 4/26/2016
Operating Permit Renewal Date: 7/20/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	29	3/26/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
598			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current, Galvanic
Diesel		4/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		4/26/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in DAWSON County in the City of GLENDIVE

Location: T & E WHISTLE STOP INC
1320 N MERRILL AVE
GLENDIVE, MT 59330 DAWSON
Contact: Tim Mort, (406) 365-2177

Sys Fac ID: 11-04213
Last Inspected On: 4/14/2016
Operating Permit Renewal Date: 6/9/2019

Owners/Operators: T & E Whistle Stop Inc, Owner (406)-365-2177 PO BOX 1313
GLENDIVE MT 59330-1313

Lynn Becker, UST Class A Operator
Timothy Mort, UST Class A Operator
Whitney Ripley, UST Class A Operator
Lynn Becker, UST Class B Operator
Evelyn Mort, UST Class B Operator
Timothy Mort, UST Class B Operator
Victoria Shoopman, UST Class B Operator
Whitney Ripley, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	5/6/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
4308			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		4/4/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		9/8/2012	TLS-350/Gilbarco EMC , Veeder Root		
2	32	5/6/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
4309			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/4/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		10/14/2011	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in DAWSON County in the City of GLENDIVE

Location: T & E WHISTLE STOP INC
1320 N MERRILL AVE
GLENDIVE, MT 59330 DAWSON

Contact: Tim Mort, (406) 365-2177

Sys Fac ID: 11-04213
Last Inspected On: 4/14/2016
Operating Permit Renewal Date: 6/9/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	32	5/6/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
4310			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/4/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		9/12/2012	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in DAWSON County in the City of GLENDIVE

Location: LOAF 'N JUG #710
322 E BARRY ST
GLENDIVE, MT 59330 DAWSON
Contact: Shirley Treece, (719) 948-5976

Sys Fac ID: 11-05093
Last Inspected On: 8/25/2016
Operating Permit Renewal Date: 10/4/2019

Owners/Operators: Mini Mart Inc dba Loaf 'N Jug, Owner (719)-948-3071 442 KEELER PKWY PUEBLO CO 81001-4813

Randal Liebnow, UST Class A Operator
John Sumowski, UST Class A Operator
Shirley Treece, UST Class A Operator
Derrick Trimble, UST Class A Operator
Wanda Koffler, UST Class B Operator
Richie Lesser, UST Class B Operator
Timothy Osterman, UST Class B Operator
Stevie Ulstad, UST Class B Operator
CARL WATKINS, UST Class B Operator
Casey Jambretz, UST Class B Global Operator
Randal Liebnow, UST Class B Global Operator
Anthony Mosmiller, UST Class B Global Operator
Toni Mullen, UST Class B Global Operator
Hiede Richardson, UST Class B Global Operator
Derrick Trimble, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1636			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/22/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in DAWSON County in the City of GLENDIVE

Location: LOAF 'N JUG #710
322 E BARRY ST
GLENDIVE, MT 59330 DAWSON
Contact: Shirley Treece, (719) 948-5976

Sys Fac ID: 11-05093
Last Inspected On: 8/25/2016
Operating Permit Renewal Date: 10/4/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1637			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/22/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1638			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasohol/Ethanol		11/22/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in DAWSON County in the City of GLENDIVE

Location: TRAIL STAR CAR AND TRUCK STOP
EXIT 213 MT HIGHWAY 16
GLENDIVE, MT 59330 DAWSON

Sys Fac ID: 11-05754
Last Inspected On: 5/14/2015
Operating Permit Renewal Date: 9/29/2018

Contact: Cheryl Haggerty, (406) 377-3901

Owners/Operators: Trailstar Truck Stop Inc, Owner (406)-377-3901 2275 W KOCH BOZEMAN MT 59718

CHERYL HAGGERY, UST Class A Operator
CHERYL HAGGERY, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	17	11/30/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4274			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	17	11/30/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4275			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	17	11/30/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4276			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in DAWSON County in the City of GLENDIVE

Location: TRAIL STAR CAR AND TRUCK STOP
EXIT 213 MT HIGHWAY 16
GLENDIVE, MT 59330 DAWSON
Contact: Cheryl Haggerty, (406) 377-3901

Sys Fac ID: 11-05754
Last Inspected On: 5/14/2015
Operating Permit Renewal Date: 9/29/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	17	11/30/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4277			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	17	11/30/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4278			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in DAWSON County in the City of GLENDIVE

Location: QWEST GLENDIVE CENTRAL OFFICE
119 W VALENTINE ST
GLENDIVE, MT 59330 DAWSON

Contact: Kevin Robison, (801) 237-3006

Sys Fac ID: 11-06870
Last Inspected On: 11/11/2015
Operating Permit Renewal Date: 11/16/2018

Owners/Operators:

Qwest Corporation, Owner	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111
Qwest Corporation, Operator	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111

Thomas J Pitts, UST Class A Operator
Kevin Robison, UST Class A Operator
Thomas J Pitts, UST Class B Operator
Dennis A Franks, UST Class B Global Operator
Thomas J Pitts, UST Class B Global Operator
Kevin Robison, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	4/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1726			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
553		11/11/2015	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in DAWSON County in the City of GLENDIVE

Location: JOYS GLENDIVE SERVICE INC
74 HIGHWAY 16
GLENDIVE, MT 59330 DAWSON

Sys Fac ID: 11-07770
Last Inspected On: 11/6/2014
Operating Permit Renewal Date:

Contact: Bill Clemens, (608) 575-8642

Owners/Operators: William Clemens, Owner (608)-575-8642 PO BOX 457 WAUNAKEE WI 53597

Glenn Lawres, UST Class A Operator
Glenn Lawres, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	18	5/28/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1511			Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/14/2013	Not Listed	Continuous Interstitial Monitor	
8,000					
7	18	5/28/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1512			Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/14/2013	Not Listed	Continuous Interstitial Monitor	
4,000					
8	18	5/28/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1513			Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		6/14/2013	Not Listed	Continuous Interstitial Monitor	
6,000					
9	18	5/28/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1514			Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		6/14/2013	Not Listed	Continuous Interstitial Monitor	
2,000					

Facility Summary in DAWSON County in the City of GLENDIVE

Location: HOLIDAY STATIONSTORE 271
701 N MERRILL AVE
GLENDIVE, MT 59330 DAWSON
Contact: Bruce Anthony, (406) 365-2221

Sys Fac ID: 11-08061
Last Inspected On: 2/2/2016
Operating Permit Renewal Date: 7/12/2019

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Stephen Reckinger, UST Class A Operator
Dean Townsend, UST Class A Operator
Ronald VanDenBroeke, UST Class A Operator
Jeremiah French, UST Class B Operator
Greg Brewer, UST Class B Global Operator
Stephen Reckinger, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator
Dean Townsend, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	37	10/1/1979	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3002			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/7/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
12,000		9/25/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	37	10/1/1979	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3003			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/7/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		9/25/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	37	10/1/1979	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3004			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		7/7/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		9/25/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in DAWSON County in the City of GLENDIVE

Location: HOLIDAY STATIONSTORE 271
701 N MERRILL AVE
GLENDIVE, MT 59330 DAWSON
Contact: Bruce Anthony, (406) 365-2221

Sys Fac ID: 11-08061
Last Inspected On: 2/2/2016
Operating Permit Renewal Date: 7/12/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	37	10/1/1979	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3001			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/7/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
12,000		9/25/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in DAWSON County in the City of GLENDIVE

Location: West Park Cenex
2200 W TOWNE ST
GLENDIVE, MT 59330 DAWSON
Contact: Charli Green, (406) 365-6282

Sys Fac ID: 11-08908
Last Inspected On: 7/6/2015
Operating Permit Renewal Date: 10/9/2018

Owners/Operators: Cross Petroleum Services Glendive, Owner (406)-377-8325 PO BOX 1388 GLENDIVE MT 59330-1388
Gregory Cross, UST Class A Operator
RJ Serpe, UST Class A Operator
RJ Serpe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	17	9/1/1999	Unknown	Fiberglass Reinforced Plastic	High Level Alarm
553	Yes		None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		3/11/2015	TLS-350/Gilbarco EMC , Veeder Root		
5	17	9/1/1999	Unknown	Fiberglass Reinforced Plastic	High Level Alarm
554	Yes		None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		2/5/2015	TLS-350/Gilbarco EMC , Veeder Root		
6	17	9/1/1999	Unknown	Fiberglass Reinforced Plastic	High Level Alarm
555	Yes		None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		2/7/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in DAWSON County in the City of GLENDIVE

Location: WESTGATE CENEX
56 HIWY 16
GLENDIVE, MT 59330 DAWSON
Contact: Teala Kinsey, (406) 377-8325

Sys Fac ID: 11-08909
Last Inspected On: 7/7/2015
Operating Permit Renewal Date: 10/31/2018

Owners/Operators: Cross Petroleum Service, Owner/Operator (406)-377-8325 PO BOX 1388 GLENDIVE MT 59330
Gregory Cross, UST Class A Operator
Timothy Fife, UST Class A Operator
RJ Serpe, UST Class A Operator
RJ Serpe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	55	5/22/1961	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff, Ball Float Valve
556		7/13/2012	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/7/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		7/6/2012	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	55	5/22/1961	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
557		7/13/2012	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		7/7/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		8/9/2011	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
5	24	2/7/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
558		7/13/2012	Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/7/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		7/4/2012	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in DAWSON County in the City of GLENDIVE

Location: GLENDIVE COMBUSTION TURBINE
366 FAS 355
GLENDIVE, MT 59330 DAWSON
Contact: Gary Flakker, (406) 365-2551

Sys Fac ID: 11-09400
Last Inspected On: 8/4/2015
Operating Permit Renewal Date: 11/17/2018

Owners/Operators: Montana Dakota Utilities Co, Owner (701)-222-7865 400 N 4TH ST BISMARCK ND 58501-4022

Kalle Kuether, UST Class A Operator
Jim Shields, UST Class A Operator
Chad Miller, UST Class B Operator
Terry Ringen, UST Class B Operator
Jody Gustafson, UST Class B Global Operator
Jim Shields, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	7/1/1987	Cathodically Protected Steel	Steel	
1692	Yes	10/4/2012	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
75,000			ILS-350 , Veeder Root	Manual Interstitial Monitor	

Facility Summary in DAWSON County in the City of GLENDIVE

Location: BN GLENDIVE FUELING FACILITY
310 N MERRILL AVE
GLENDIVE, MT 59330 DAWSON
Contact: (406) 265-0483

Sys Fac ID: 11-09528
Last Inspected On: 9/15/2016
Operating Permit Renewal Date: 12/4/2019

Owners/Operators: Michael J Perrodin, Owner (406)-265-0483 BURLINGTON NORTHERN RAILROAD
235 MAIN ST
HAVRE MT 59501-3523

Brett Bailey, UST Class A Operator
Tim Christianson, UST Class A Operator
Lloyd Roberts, UST Class A Operator
Michael Lovato, UST Class B Operator
Leslie Metzger, UST Class B Operator
Loren Music, UST Class B Operator
Randall Sorkness, UST Class B Operator
Robin Utgaard, UST Class B Operator
Richard Wegmann, UST Class B Operator
Travis White, UST Class B Operator
Travis White, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	25	9/1/1991	Bare Steel	Steel	
505	Yes		None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Galvanic, Impressed Current
Diesel		9/15/2016	Deferred	Continuous Interstitial Monitor	
680,000					
12	26	12/28/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	
504			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Galvanic, Impressed Current
Mixture		9/15/2016	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
16,000			Other , Other		

Facility Summary in DAWSON County in the City of GLENDIVE

Location: GLENDIVE MEDICAL CENTER
202 PROSPECT DR
GLENDIVE, MT 59330 DAWSON

Contact: Larry Perkins, (406) 345-3306

Sys Fac ID: 11-09735
Last Inspected On: 8/19/2014
Operating Permit Renewal Date: 12/19/2017

Owners/Operators: Glendive Medical Center, Owner (406)-345-3306 202 PROSPECT DR GLENDIVE MT 59330-1999

Sam Durham, UST Class A Operator
Mike Ryan, UST Class A Operator
Craig Torno, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	11/16/1995	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1223		8/28/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,010			TLS-300 , Veeder Root		

Facility Summary in DAWSON County in the City of GLENDIVE

Location: CROSSROADS CONOCO GLENDIVE
58 HIGHWAY 16
GLENDIVE, MT 59330 DAWSON
Contact: Jim Steffon, (406) 365-2728

Sys Fac ID: 56-13872
Last Inspected On: 12/29/2014
Operating Permit Renewal Date: 3/14/2018

Owners/Operators: Gregory Cross, Owner (406)-252-5519 PO BOX 1078
BILLINGS MT 59103-1078

Gregory Cross, UST Class A Operator
Timothy Fife, UST Class A Operator
RJ Serpe, UST Class A Operator
RJ Serpe, UST Class B Global Operator
Ron Serpe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	17	6/26/1999	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4043			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel			Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Approved Remote Monitoring	
10,000		3/8/2012	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	17	6/26/1999	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4044			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline			Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		3/8/2012	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	17	6/26/1999	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4045			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline			Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		3/8/2012	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in DAWSON County in the City of RICHEY

Location: FARMERS ELEVATOR/RICHEY
111 RAILROAD AVE
RICHEY, MT 59259 DAWSON

Contact: David Corbin, (406) 951-0997

Sys Fac ID: 11-05898
Last Inspected On: 8/31/2015
Operating Permit Renewal Date: 2/2/2019

Owners/Operators: CHS Inc - Richey, Owner/Operator (406)-773-5758 PO BOX 37 RICHEY MT 59259

David Corbin, UST Class A Operator
David Corbin, UST Class B Operator
Jana Olson, UST Class B Operator
Lance Schipman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	15	7/11/2001	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4314			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline		10/29/2012	Manual Interstitial Monitor	Deferred	
4,000					
6	15	7/11/2001	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4315			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline		10/29/2012	Manual Interstitial Monitor	Deferred	
4,000					
7	15	7/11/2001	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4316			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel		10/29/2012	Continuous Interstitial Monitor, Manual Interstitial Monitor	Deferred	
4,000					

Facility Summary in DAWSON County in the City of RICHEY

Location: FARMERS ELEVATOR/RICHEY
111 RAILROAD AVE
RICHEY, MT 59259 DAWSON
Contact: David Corbin, (406) 951-0997

Sys Fac ID: 11-05898
Last Inspected On: 8/31/2015
Operating Permit Renewal Date: 2/2/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	01	4/1/2015	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Positive Shutoff
5572		5/4/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Deferred	
8,000			Other , Other	Not Listed	

Facility Summary in DEER LODGE County in the City of ANACONDA

Location: THRIFTWAY SUPER STOP 7
2035 W PARK AVE
ANACONDA, MT 59711 DEER LODGE
Contact: Daivd Sutey, (406) 494-2305

Sys Fac ID: 12-00101
Last Inspected On: 6/22/2016
Operating Permit Renewal Date: 11/13/2019

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE BUTTE MT 59701-3553

Brian Clemons, UST Class A Operator
Jack Hook, UST Class A Operator
Linda Otonicar, UST Class A Operator
Louie Sutey, UST Class A Operator
Brian Clemons, UST Class B Operator
Toni Clemons, UST Class B Operator
Vickie Hall, UST Class B Operator
Jack Hook, UST Class B Operator
Allyn Moses, UST Class B Operator
Jack Hook, UST Class B Global Operator
Louie Sutey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	7/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2047			None	Double-Walled	Yes
Currently in Use		7/1/2003	Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		6/6/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		4/21/2016	Gilbarco EMC Basic , Gilbarco		
3	23	7/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2046			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/6/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		4/21/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in DEER LODGE County in the City of ANACONDA

Location: THRIFTWAY SUPER STOP 7
2035 W PARK AVE
ANACONDA, MT 59711 DEER LODGE

Contact: Daivd Sutey, (406) 494-2305

Sys Fac ID: 12-00101
Last Inspected On: 6/22/2016
Operating Permit Renewal Date: 11/13/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	44	12/31/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2045			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/6/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		4/21/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in DEER LODGE County in the City of ANACONDA

Location: A & A TECHNICAL REPAIR INC
701 E PARK AVE
ANACONDA, MT 59711 DEER LODGE

Contact: John Atkerson, (406) 563-5779

Sys Fac ID: 12-01470
Last Inspected On: 2/10/2016
Operating Permit Renewal Date:

Owners/Operators: John Atkerson, Owner (406)-494-5683 701 E PARK AVE
ANACONDA MT 59711-2550

John Atkerson, UST Class A Operator
Lorna Atkerson, UST Class A Operator
John Atkerson, UST Class B Global Operator
Lorna Atkerson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	5/1/1994	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
2096		7/20/2010	None	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, Deferred	
5,000					
7	22	5/1/1994	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2095		7/20/2010	None	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000					
8	22	5/1/1994	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2094		7/20/2010	None	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000					

Facility Summary in DEER LODGE County in the City of ANACONDA

Location: THRIFTWAY SUPER STOP 3
1420 E PARK AVE
ANACONDA, MT 59711 DEER LODGE
Contact: David Sutey, (406) 494-2305

Sys Fac ID: 12-07938
Last Inspected On: 6/4/2016
Operating Permit Renewal Date: 6/12/2019

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE BUTTE MT 59701-3553

Jack Hook, UST Class A Operator
Linda Otonicar, UST Class A Operator
Louie Sutey, UST Class A Operator
Jack Hook, UST Class B Operator
Ted Weinman, UST Class B Operator
Theresa Weinman, UST Class B Operator
Jack Hook, UST Class B Global Operator
Louie Sutey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	9/1/1990	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2050		10/17/2012	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	26	9/1/1990	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2049		10/17/2012	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in DEER LODGE County in the City of ANACONDA

Location: THRIFTWAY SUPER STOP 3
1420 E PARK AVE
ANACONDA, MT 59711 DEER LODGE
Contact: David Sutey, (406) 494-2305

Sys Fac ID: 12-07938
Last Inspected On: 6/4/2016
Operating Permit Renewal Date: 6/12/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	26	9/1/1990	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2048		10/24/2012	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	26	9/1/1990	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2052		10/17/2012	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
10	26	9/1/1990	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2051		10/17/2012	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in DEER LODGE County in the City of ANACONDA

Location: TOWN PUMP INC ANACONDA 2
819 W PARK AVE
ANACONDA, MT 59711 DEER LODGE

Contact: Kevin Kenneally, (406) 563-6707

Sys Fac ID: 12-08668
Last Inspected On: 2/3/2015
Operating Permit Renewal Date: 2/6/2018

Owners/Operators: Town Pump of Anaconda Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	4/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2410			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		10/31/2006	TLS-350/Gilbarco EMC , Veeder Root		
2	25	4/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2409			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		10/31/2006	TLS-350/Gilbarco EMC , Veeder Root		
5	25	4/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2407			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		10/31/2006	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in DEER LODGE County in the City of ANACONDA

Location: TOWN PUMP INC ANACONDA 2
819 W PARK AVE
ANACONDA, MT 59711 DEER LODGE

Contact: Kevin Kenneally, (406) 563-6707

Sys Fac ID: 12-08668
Last Inspected On: 2/3/2015
Operating Permit Renewal Date: 2/6/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	25	4/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2408			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		10/31/2006	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in DEER LODGE County in the City of ANACONDA

Location: TOWN PUMP INC ANACONDA 1
6940 MT HWY 1 SUITE A
ANACONDA, MT 59711 DEER LODGE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 12-09326
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 5/31/2018

Owners/Operators: Town Pump Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-2534

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	11/1/1994	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2414			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/24/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		9/1/2005	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	21	12/1/1994	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2413			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/24/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		9/1/2005	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	25	5/1/1991	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2412			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/24/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		9/1/2005	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in DEER LODGE County in the City of ANACONDA

Location: TOWN PUMP INC ANACONDA 1
6940 MT HWY 1 SUITE A
ANACONDA, MT 59711 DEER LODGE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 12-09326
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 5/31/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	25	5/1/1991	Bare Steel	Flexible Plastic	Ball Float Valve
2411			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/24/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		9/1/2005	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	15	7/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4574			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		5/5/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		9/1/2005	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
10	15	7/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4575			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		5/5/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		9/1/2005	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in DEER LODGE County in the City of ANACONDA

Location: MAIN GRANULATES SLAG PILE - ANACONDA SMELTER SITE
105 N SILVER ST
ANACONDA, MT 59711 DEER LODGE

Contact: Tim Ledford, (406) 560-0375

Sys Fac ID: 12-10912
Last Inspected On: 7/27/2016
Operating Permit Renewal Date: 9/8/2019

Owners/Operators: U.S. Minerals Inc, Owner/Operator (219)-864-0909 2105 NORTH WINDS DRIVE DYER IN 46311

John Gentry, UST Class A Operator
Don Haney, UST Class A Operator
Shadd Kauffman, UST Class A Operator
Glenn Spotted Eagle, UST Class A Operator
John Gentry, UST Class B Global Operator
Timothy J Ledford, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	4/16/1985	Bare Steel	Steel	
1836	Yes	5/6/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
12,800		7/27/2016	ILS-350 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in DEER LODGE County in the City of WARM SPRINGS

Location: XANTHOPOULOS BLDG
2 C ST
WARM SPRINGS, MT 59756 DEER LODGE
Contact: Woody Casey, (406) 693-7110

Sys Fac ID: 12-07585
Last Inspected On: 6/19/2014
Operating Permit Renewal Date: 11/26/2017

Owners/Operators: Montana Dept of Corrections, Owner (406)-444-4931 MIKE FERRITER
PO BOX 201301
HELENA MT 59620-1301

Jerry Hancock, UST Class A Operator
Jerry Hancock, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	29	1/1/1987	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
829		8/7/2015	None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1	Continuous Interstitial Monitor	
2,000			TLS-300 , Veeder Root		

Facility Summary in FALLON County in the City of BAKER

Location: Muffy's
19 E MONTANA AVE
BAKER, MT 59313 FALLON

Contact: Monica Stark, (406) 778-3144

Sys Fac ID: 13-00227
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 5/11/2019

Owners/Operators: Monica Stark, Owner (406)-778-3144 PO BOX 498
BAKER MT 59313-0498

Monica Stark, UST Class A Operator
Roxann Janz, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	27	4/13/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3519			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/26/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		11/12/2015	Gilbarco EMC Basic , Gilbarco		
6	18	10/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3520			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/26/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		11/12/2015	Gilbarco EMC Basic , Gilbarco		

Facility Summary in FALLON County in the City of BAKER

Location: J & A MINI STORE
116 W MONTANA AVE
BAKER, MT 59313 FALLON

Contact: Arlene Heim, (406) 778-2411

Sys Fac ID: 13-00685
Last Inspected On: 10/28/2014
Operating Permit Renewal Date: 3/25/2018

Owners/Operators: Arlene Heim, Owner (406)-778-2411 PO BOX 1300
BAKER MT 59313-1300

Rose Morast, UST Class A Operator
Rose Morast, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	27	5/24/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1447			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		9/25/2013	Automatic Tank Gauging 0.2	Deferred	
4,042			TLS-350/Gilbarco EMC , Veeder Root		
6	27	5/24/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1448			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		9/25/2013	Automatic Tank Gauging 0.2	Deferred	
9,954			TLS-350/Gilbarco EMC , Veeder Root		
7	27	5/24/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1449			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		9/25/2013	Automatic Tank Gauging 0.2	Deferred	
10,003			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FALLON County in the City of BAKER

Location: FALLON COUNTY RD DEPT
122 E CENTER AVE
BAKER, MT 59313 FALLON

Contact: Reiny Barth, (406) 778-2019

Sys Fac ID: 13-01687
Last Inspected On: 7/29/2015
Operating Permit Renewal Date: 8/3/2018

Owners/Operators: Fallon County Road Dept, Owner (406)-778-2019 PO BOX 1155 BAKER MT 59313-1155

Alba Higgins, UST Class A Operator
Alba Higgins, UST Class B Operator
Mitch Overn, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	23	6/9/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
896			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		9/13/2012	Manual Interstitial Monitor	Deferred	
6,000					
6	23	6/1/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
897			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		9/13/2012	Manual Interstitial Monitor	Deferred	
6,000					
7	23	6/1/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
898			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		9/13/2012	Manual Interstitial Monitor	Deferred	
3,000					

Facility Summary in FALLON County in the City of BAKER

Location: PRAIRIE FUELS
176 E MILWAUKEE AVE
BAKER, MT 59313 FALLON
Contact: Sharon Tronstad, (406) 778-3245

Sys Fac ID: 13-07740
Last Inspected On: 7/29/2015
Operating Permit Renewal Date: 10/1/2018

Owners/Operators: Prairie Fuels, Owner (406)-778-3245 PO BOX 1272
BAKER MT 59313-1272

Sharon Tronstad, UST Class A Operator
Sharon Tronstad, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	20	9/1/1996	Bare Steel	Fiberglass	
3197	Yes	12/12/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable, Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
17,000			Other , Other		
6	20	9/1/1996	Bare Steel	Fiberglass	
3198	Yes	12/12/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable, Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
8,500			Other , Other		
7	20	9/1/1996	Bare Steel	Fiberglass	
3199	Yes	12/12/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable, Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000			Other , Other		
8	20	9/1/1996	Bare Steel	Fiberglass	
3200	Yes	12/12/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable, Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000			Other , Other		

Facility Summary in FALLON County in the City of BAKER

Location: PRAIRIE FUELS
176 E MILWAUKEE AVE
BAKER, MT 59313 FALLON
Contact: Sharon Tronstad, (406) 778-3245

Sys Fac ID: 13-07740
Last Inspected On: 7/29/2015
Operating Permit Renewal Date: 10/1/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	20	9/1/1996	Bare Steel	Fiberglass	
3201	Yes	12/12/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable, Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
2,000			Other , Other		
10	20	9/1/1996	Bare Steel	Fiberglass	
3202	Yes	12/12/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable, Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
2,000			Other , Other		

Facility Summary in FALLON County in the City of BAKER

Location: UNIVERSAL TIRE & ALIGNMENT
908 E MONTANA AVE
BAKER, MT 59313 FALLON

Contact: John Geving, (406) 978-2990

Sys Fac ID: 13-08221
Last Inspected On: 7/29/2015
Operating Permit Renewal Date: 8/3/2018

Owners/Operators: John Geving, Owner (406)-978-2990 PO BOX 500
BAKER MT 59313-0500

John Geving, UST Class A Operator
John Geving, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	17	8/1/1999	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4083			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		7/29/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
8,000			Gilbarco EMC Basic , Gilbarco		
5	17	8/1/1999	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4084			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		7/29/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
4,000			Gilbarco EMC Basic , Gilbarco		
6	17	8/1/1999	Bare Steel	Flexible Plastic	
4085	Yes		None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel		7/29/2015	Deferred	Continuous Interstitial Monitor	
5,500			Gilbarco EMC Basic , Gilbarco		

Facility Summary in FALLON County in the City of BAKER

Location: BAKERS FARMER UNION OIL
303 W MONTANA AVE
BAKER, MT 59313 FALLON
Contact: Travis Mashak, (406) 778-2519

Sys Fac ID: 13-09960
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 2/23/2019

Owners/Operators: Farmers Union Oil Baker, Owner (406)-778-2519 PO BOX 1000
BAKER MT 59313-1000

Tonya England, UST Class A Operator
Calvin Huether, UST Class A Operator
Travis Mashak, UST Class A Operator
Barbara Stanhope, UST Class A Operator
Tonya England, UST Class B Operator
Calvin Huether, UST Class B Operator
Travis Mashak, UST Class B Operator
Barbara Stanhope, UST Class B Operator
Tonya England, UST Class B Global Operator
Travis Mashak, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	11/1/1995	Cathodically Protected Steel	Flexible Plastic	Positive Shutoff
977			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/28/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-450 , Veeder Root		
2	21	11/1/1995	Cathodically Protected Steel	Flexible Plastic	Positive Shutoff
978			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/28/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-450 , Veeder Root		

Facility Summary in FALLON County in the City of BAKER

Location: BAKERS FARMER UNION OIL
303 W MONTANA AVE
BAKER, MT 59313 FALLON
Contact: Travis Mashak, (406) 778-2519

Sys Fac ID: 13-09960
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 2/23/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	21	11/1/1995	Cathodically Protected Steel	Flexible Plastic	Positive Shutoff
976			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/28/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-450 , Veeder Root		
9	21	11/1/1995	Cathodically Protected Steel	Flexible Plastic	Positive Shutoff
975			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/28/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-450 , Veeder Root		
10	21	11/1/1995	Cathodically Protected Steel	Flexible Plastic	Positive Shutoff
973			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/28/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-450 , Veeder Root		
11	21	11/1/1995	Cathodically Protected Steel	Flexible Plastic	Positive Shutoff
974			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/28/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-450 , Veeder Root		

Facility Summary in FALLON County in the City of BAKER

Location: FALLON COUNTY AIRPORT
FALLON COUNTY AIRPORT
BAKER, MT 59313 FALLON
Contact: Roger Meggers, (406) 778-3508

Sys Fac ID: 13-10696
Last Inspected On: 10/7/2015
Operating Permit Renewal Date: 2/9/2019

Owners/Operators: Fallon County, Owner (406)-778-3508 PO BOX 846
BAKER MT 59313-0846

Roger Meggers, UST Class A Operator
Roger Meggers, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	28	1/1/1988	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
894			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Kerosene		9/13/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing, ELLD Line Tightness Testing	
10,000		10/7/2015	OPW 1500 , OPW	Automatic Tank Gauging 0.1	
2	28	1/1/1988	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
895			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/13/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing, ELLD Line Tightness Testing	
10,000		10/7/2015	OPW 1500 , OPW	Automatic Tank Gauging 0.1	

Facility Summary in FALLON County in the City of BAKER

Location: FALLON COUNTY MEDICAL COMPLEX
225 S 3RD ST W
BAKER, MT 59313 FALLON

Contact: Brad Kings, (406) 778-5126

Sys Fac ID: 60-15072
Last Inspected On: 6/24/2014
Operating Permit Renewal Date: 7/13/2017

Owners/Operators: Fallon Medical Complex Inc, Owner/Operator (406)-778-3331 PO BOX 820
BAKER MT 59313-0820

Brad Kings, UST Class A Operator
John Zook, UST Class B Operator
John Zook, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	10	1/2/2006	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5125			Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,500		6/24/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of DENTON

Location: CENTRAL MONTANA COOP DENTON
609 BROADWAY AVE
DENTON, MT 59430 FERGUS

Contact: Bill Spainhower, (406) 567-2273

Sys Fac ID: 14-01360
Last Inspected On: 6/2/2014
Operating Permit Renewal Date: 8/27/2017

Owners/Operators: Central Montana Coop Denton, Owner (406)-567-2273 PO BOX 955
DENTON MT 59430-0955

Harold Clark, UST Class A Operator
Donald Weinheimer, UST Class A Operator
Harold Clark, UST Class B Operator
Donald Weinheimer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	1/19/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
903			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		9/12/2013	TLS-250 , Veeder Root		
3	26	1/19/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
904			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		9/12/2013	TLS-250 , Veeder Root		
4	26	1/19/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
905			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		9/12/2013	TLS-250 , Veeder Root		

Facility Summary in FERGUS County in the City of DENTON

Location: WOODHALL DISTRIBUTING
603 BROADWAY AVE
DENTON, MT 59430 FERGUS

Contact: Steve Woodhall, (406) 567-2266

Sys Fac ID: 14-06219
Last Inspected On: 6/2/2014
Operating Permit Renewal Date: 8/22/2017

Owners/Operators: Woodhall Distributing - Denton, Owner (406)-567-2266 PO BOX 1018 DENTON MT 59430-1018

Greg Econom, UST Class A Operator
Greg Econom, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	19	7/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4253			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/19/2011	Manual Interstitial Monitor	Deferred	
2,000					
11	19	7/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4254			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/19/2011	Manual Interstitial Monitor	Deferred	
2,000					
12	19	7/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4255			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		4/19/2011	Manual Interstitial Monitor	Deferred	
2,000					

Facility Summary in FERGUS County in the City of DENTON

Location: MALMSTROM AFB D 1
BEAR SPRINGS ROAD
DENTON, MT 59430 FERGUS

Contact: Lana Hedlund, (406) 731-6175

Sys Fac ID: 14-09008
Last Inspected On: 2/22/2016
Operating Permit Renewal Date: 2/23/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Chris Amann, UST Class B Operator
Ricardo Andrillon, UST Class B Operator
Glen Beck, UST Class B Operator
Allen Brooks, UST Class B Operator
Jonathan Buesch, UST Class B Operator
John Corbett, UST Class B Operator
David Cosner, UST Class B Operator
Ryan Cox, UST Class B Operator
Brian Day, UST Class B Operator
David Degolier, UST Class B Operator
Hudson English, UST Class B Operator
Dustin Hemingway, UST Class B Operator
Aaron Hill, UST Class B Operator
William Hoffmeister, UST Class B Operator
Shane Hofstad, UST Class B Operator
Bethany Kent, UST Class B Operator
James Knudsen, UST Class B Operator
Ryan Kofoed, UST Class B Operator
Jeff Laird, UST Class B Operator
Damon McCarty, UST Class B Operator
Kieth McIlwain, UST Class B Operator
Brian McVay, UST Class B Operator
Ronald Miller, UST Class B Operator
Michael Murieen, UST Class B Operator
Jeff Nelson, UST Class B Operator
Shawn O'Grady, UST Class B Operator
John Oldham, UST Class B Operator
Chris Ploof, UST Class B Operator
Issac Price, UST Class B Operator
Brian Rayner, UST Class B Operator

Facility Summary in FERGUS County in the City of DENTON

Location: MALMSTROM AFB D 1
BEAR SPRINGS ROAD
DENTON, MT 59430 FERGUS

Sys Fac ID: 14-09008
Last Inspected On: 2/22/2016
Operating Permit Renewal Date: 2/23/2019

Contact: Lana Hedlund, (406) 731-6175

Adam Reathaford, UST Class B Operator
Cameron Smith, UST Class B Operator
Jimmy Sonefelt, UST Class B Operator
Michael Stokes, UST Class B Operator
Kyle Topp, UST Class B Operator
Jason Vike, UST Class B Operator
James Wooderchak, UST Class B Operator
Paul Ziemba, UST Class B Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	01	9/7/2015	Steel Clad	Flexible Plastic	Positive Shutoff, High Level Alarm
5591		8/21/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Impressed Current
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	Yes

Facility Summary in FERGUS County in the City of DENTON

Location: MALMSTROM AFB D 2
MT HIGHWAY 81
DENTON, MT 59430 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09009
Last Inspected On: 9/24/2014
Operating Permit Renewal Date: 10/7/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
166		4/14/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of DENTON

Location: MALMSTROM AFB D 03
MT HIGHWAY 81
DENTON, MT 59430 FERGUS

Sys Fac ID: 14-09010
Last Inspected On: 10/29/2014
Operating Permit Renewal Date: 9/15/2017

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	27	6/21/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
167		4/22/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of DENTON

Location: MALMSTROM AFB D 5
MT HIGHWAY 81
DENTON, MT 59430 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09012
Last Inspected On: 10/30/2014
Operating Permit Renewal Date: 9/15/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
168		5/6/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of DENTON

Location: MALMSTROM AFB D 6
MT HIGHWAY 81
DENTON, MT 59430 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09013
Last Inspected On: 9/24/2014
Operating Permit Renewal Date: 10/7/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
169		4/1/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of DENTON

Location: MALMSTROM AFB D 07
MT HIGHWAY 81
DENTON, MT 59430 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09014
Last Inspected On: 9/24/2014
Operating Permit Renewal Date: 10/7/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	27	6/21/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
170		4/9/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor, Approved Remote Monitoring	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of DENTON

Location: MALMSTROM AFB D 8
MT HIGHWAY 81
DENTON, MT 59430 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09015
Last Inspected On: 9/24/2014
Operating Permit Renewal Date: 10/7/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	8/12/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
171		4/16/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of DENTON

Location: MALMSTROM AFB D 9
MT HIGHWAY 81
DENTON, MT 59430 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09016
Last Inspected On: 9/24/2014
Operating Permit Renewal Date: 10/7/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
172		6/4/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of DENTON

Location: MALMSTROM AFB D 10
MT HIGHWAY 81
DENTON, MT 59430 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09017
Last Inspected On: 11/10/2014
Operating Permit Renewal Date: 9/15/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
173		5/28/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of DENTON

Location: MALMSTROM AFB D 11
MT HIGHWAY 81
DENTON, MT 59430 FERGUS

Sys Fac ID: 14-09018
Last Inspected On: 10/27/2014
Operating Permit Renewal Date: 9/15/2017

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
174		5/22/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of DENTON

Location: MALMSTROM AFB D 4
MT HIGHWAY 81
DENTON, MT 59430 FERGUS

Contact: Walter Gibbings, (406) 731-6188

Sys Fac ID: 14-10841
Last Inspected On: 4/7/2015
Operating Permit Renewal Date: 4/14/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	02	10/1/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Flapper Valve (Auto Shutoff)
5544		10/24/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000		10/22/2014	TLS-350/Gilbarco EMC , Veeder Root	Not Listed	

Facility Summary in FERGUS County in the City of FOREST GROVE

Location: MALMSTROM AFB N 4
ROAD 238
FOREST GROVE, MT 59441 FERGUS

Sys Fac ID: 14-09121
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/14/2019

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	8/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
201		4/27/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of FOREST GROVE

Location: MALMSTROM AFB N 5
ROAD 238
FOREST GROVE, MT 59441 FERGUS

Sys Fac ID: 14-09122
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/14/2019

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	8/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
202		4/27/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of FOREST GROVE

Location: MALMSTROM AFB N 6
ROAD 238
FOREST GROVE, MT 59441 FERGUS

Sys Fac ID: 14-09123
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/14/2019

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	8/13/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
203		4/28/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of GARNEILL

Location: MALMSTROM AFB L 10
US HIGHWAY 191
GARNEILL, MT 59453 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09105
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	5/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
188		4/8/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of GRASS RANGE

Location: LITTLE MONTANA TRUCK STOP
US HIGHWAY 87
GRASS RANGE, MT 59032 FERGUS
Contact: Jolene Smith, (406) 428-2270

Sys Fac ID: 14-06338
Last Inspected On: 7/7/2016
Operating Permit Renewal Date: 9/6/2019

Owners/Operators: GS Oil Inc Roy, Owner (406)-464-2221 PO BOX 149
ROY MT 59471-0149

Jolene Smith, UST Class A Operator
Jolene Smith, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	18	9/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1138			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	18	9/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1139			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	18	9/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1140			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		7/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	18	9/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1141			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		7/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FERGUS County in the City of GRASS RANGE

Location: LITTLE MONTANA TRUCK STOP
US HIGHWAY 87
GRASS RANGE, MT 59032 FERGUS

Contact: Jolene Smith, (406) 428-2270

Sys Fac ID: 14-06338
Last Inspected On: 7/7/2016
Operating Permit Renewal Date: 9/6/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	18	9/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1142			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		7/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FERGUS County in the City of GRASS RANGE

Location: MALMSTROM AFB N 1
US HIGHWAY 87
GRASS RANGE, MT 59032 FERGUS

Sys Fac ID: 14-09118
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/14/2019

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Ricardo Andrillon, UST Class B Operator
Glen Beck, UST Class B Operator
Allen Brooks, UST Class B Operator
Jonathan Buesch, UST Class B Operator
John Corbett, UST Class B Operator
David Cosner, UST Class B Operator
Ryan Cox, UST Class B Operator
Brian Day, UST Class B Operator
David Degolier, UST Class B Operator
Hudson English, UST Class B Operator
Michael Harris, UST Class B Operator
Eric Haumschild, UST Class B Operator
Dustin Hemingway, UST Class B Operator
Aaron Hill, UST Class B Operator
William Hoffmeister, UST Class B Operator
Shane Hofstad, UST Class B Operator
Bethany Kent, UST Class B Operator
James Knudsen, UST Class B Operator
Ryan Kofoed, UST Class B Operator
Jeff Laird, UST Class B Operator
Damon McCarty, UST Class B Operator
Kieth McIlwain, UST Class B Operator
Brian McVay, UST Class B Operator
Ronald Miller, UST Class B Operator
Michael Murieen, UST Class B Operator
Jeff Nelson, UST Class B Operator
Shawn O'Grady, UST Class B Operator
Chris Ploof, UST Class B Operator
Issac Price, UST Class B Operator
Brian Rayner, UST Class B Operator

Facility Summary in FERGUS County in the City of GRASS RANGE

Location: MALMSTROM AFB N 1
US HIGHWAY 87
GRASS RANGE, MT 59032 FERGUS

Sys Fac ID: 14-09118
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/14/2019

Contact: Jim Hodges,

Cameron Smith, UST Class B Operator
Jimmy Sonefelt, UST Class B Operator
Michael Stokes, UST Class B Operator
Kyle Topp, UST Class B Operator
Jason Vike, UST Class B Operator
Mark Wight, UST Class B Operator
James Wooderchak, UST Class B Operator
Paul Ziemba, UST Class B Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	54	6/2/1962	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
198		4/29/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Impressed Current
Diesel		4/30/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of GRASS RANGE

Location: MALMSTROM AFB N 2
US HIGHWAY 87
GRASS RANGE, MT 59032 FERGUS

Sys Fac ID: 14-09119
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/14/2019

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	7/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
199		4/27/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of GRASS RANGE

Location: MALMSTROM AFB N 3
MT HIGHWAY 19
GRASS RANGE, MT 59032 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09120
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/14/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	3/26/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
200		4/27/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of HILGER

Location: MALMSTROM AFB E 6
ROAD 236
HILGER, MT 59451 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09024
Last Inspected On: 11/6/2014
Operating Permit Renewal Date: 9/15/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	7/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
180		10/23/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of HILGER

Location: MALMSTROM AFB E 7
ROAD 236
HILGER, MT 59451 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09025
Last Inspected On: 11/4/2014
Operating Permit Renewal Date: 9/15/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	27	8/1/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
181		11/6/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of HILGER

Location: MALMSTROM AFB E 8
MT HIGHWAY 81
HILGER, MT 59451 FERGUS

Contact: William McLaughlin, (406) 731-6188

Sys Fac ID: 14-09026
Last Inspected On: 9/24/2014
Operating Permit Renewal Date: 10/7/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	02	12/1/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
5465		4/4/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	Yes

Facility Summary in FERGUS County in the City of HILGER

Location: MALMSTROM AFB E 9
ROAD 236
HILGER, MT 59451 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09027
Last Inspected On: 11/4/2014
Operating Permit Renewal Date: 9/15/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	7/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4270		10/30/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000		5/1/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of HILGER

Location: MALMSTROM AFB M 2
MT HIGHWAY 81
HILGER, MT 59451 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09108
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/24/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	8/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
191		4/6/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of HILGER

Location: MALMSTROM AFB M 3
US HIGHWAY 191
HILGER, MT 59451 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09109
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/24/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	8/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
192		4/4/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of HILGER

Location: MALMSTROM AFB O 8
US HIGHWAY 191
HILGER, MT 59451 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09136
Last Inspected On: 4/15/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	8/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
216		4/15/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of HILGER

Location: MALMSTROM AFB O 9
US HIGHWAY 191
HILGER, MT 59451 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09137
Last Inspected On: 4/14/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	8/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
217		6/6/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: RINDALS FORT LEWIS TRADING POST
1502 W MAIN ST
LEWISTOWN, MT 59457 FERGUS

Contact: Chris Rindal, (406) 535-7532

Sys Fac ID: 14-00095
Last Inspected On: 2/22/2016
Operating Permit Renewal Date: 6/16/2019

Owners/Operators: Rindal Oil Co, Owner/Operator (406)-535-2752 PO BOX 504
LEWISTOWN MT 59457-2202

Chris Rindal, UST Class A Operator
Mito Allen, UST Class B Operator
Kelly Davis, UST Class B Operator
Robert Heller, UST Class B Operator
Joni Hartford, UST Class B Global Operator
Chris Rindal, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	37	6/1/1979	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3923			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/4/2015	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
10,000		6/4/2015			
2	37	12/31/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3924			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/4/2015	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
10,000		6/4/2015			

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: CENTRAL MONTANA MEDICAL CENTER
408 WENDELL AVE
LEWISTOWN, MT 59457 FERGUS

Contact: Ron Baumann, (406) 538-7711

Sys Fac ID: 14-01228
Last Inspected On: 12/21/2015
Operating Permit Renewal Date: 2/9/2019

Owners/Operators: Central Montana Medical Center, Owner (406)-538-6231 408 WENDELL AVE LEWISTOWN MT 59457-2261

Ronald Baumann, UST Class A Operator
Gary Godbey, UST Class A Operator
Brad Johnson, UST Class A Operator
Eric Wichman, UST Class B Operator
Mary Curnyn, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	20	7/1/1996	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
607		12/21/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Diesel		10/8/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-300 , Veeder Root		

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: COUNTRY CORNER LEWISTOWN
102 W MAIN ST
LEWISTOWN, MT 59457 FERGUS

Contact: Chris Rindal, (406) 535-2752

Sys Fac ID: 14-01969
Last Inspected On: 1/15/2015
Operating Permit Renewal Date: 2/28/2018

Owners/Operators:

Rindal Oil Co, Owner	(406)-535-2752	PO BOX 504 LEWISTOWN MT 59457-2202
Chris Rindal, Operator	(406)-535-2752	PO BOX 504 LEWISTOWN MT 59457

Chris Rindal, UST Class A Operator
Tina Blair, UST Class B Operator
Christina Heller, UST Class B Global Operator
Chris Rindal, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	26	5/6/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1501			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		1/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
6,000			TLS-300 , Veeder Root		
5	26	5/6/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1502			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		1/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
6,000			TLS-300 , Veeder Root		
6	26	5/6/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1503			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		1/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
8,000			TLS-300 , Veeder Root		

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: RINDALS WEST END SERVICE
1015 TRUCK BYP
LEWISTOWN, MT 59457 FERGUS

Contact: Chris Rindall, (406) 538-2752

Sys Fac ID: 14-03118
Last Inspected On: 6/18/2013
Operating Permit Renewal Date:

Owners/Operators: Paul Reese, Owner (406)-538-8384 PO BOX 102
LEWISTOWN MT 59457-0102

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	18	11/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1838			None	None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/18/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
8,000					
9	18	11/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1839			None	None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		6/18/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000					
10	18	11/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1840			None	None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/18/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
8,000					

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: MDOT 53 1409 LEWISTOWN AIRPORT RD
1620 AIRPORT RD
LEWISTOWN, MT 59457 FERGUS

Contact: Joe Radonich, (406) 444-9204

Sys Fac ID: 14-04062
Last Inspected On: 2/7/2014
Operating Permit Renewal Date: 5/12/2017

Owners/Operators:

MDOT Helena, Owner	(406)-444-6200	KIM JANZEN PO BOX 201001 HELENA MT 59620-1001
Joseph J Radonich, Operator	(406)-444-9204	MDT DEADHEAD HELENA MT 59620-0901

Jeff Gleason, UST Class A Operator
Walt Kerttula, UST Class A Operator
Mike Murolo, UST Class A Operator
Joe Radonich, UST Class A Operator
Gary Cecrie, UST Class B Operator
Stephen Foy, UST Class B Operator
Douglas Robbins, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	23	10/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4771			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		2/7/2014	Automatic Tank Gauging 0.2	Not Listed	
10,000					
6	23	10/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4772			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		2/7/2014	Automatic Tank Gauging 0.2	Not Listed	
10,000					

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: SKYLINE AVIATION
410 SKYLINE DRIVE
LEWISTOWN, MT 59457 FERGUS

Contact: Greg Smith, (406) 538-8150

Sys Fac ID: 14-04561
Last Inspected On: 12/21/2015
Operating Permit Renewal Date: 4/30/2019

Owners/Operators: Skyline Aviation LLC, Owner/Operator (406)-538-8150 410 SKYLINE DRIVE LEWISTOWN MT 59457

Donald Newton, UST Class A Operator
Greg Smith, UST Class A Operator
Donald Newton, UST Class B Global Operator
Greg Smith, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	34	4/13/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
444			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use		7/8/2008	Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/21/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		12/21/2015	Soil Sentry Liquid 330 , Arizona Instrument	Manual Interstitial Monitor	

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: MONTANA MENTAL HEALTH NURSING CARE
800 CASINO CREEK DR
LEWISTOWN, MT 59457 FERGUS

Contact: Paul Grensten, (406) 538-7451

Sys Fac ID: 14-05032
Last Inspected On: 6/18/2014
Operating Permit Renewal Date: 7/1/2017

Owners/Operators: Montana Mental Health Nursing Care, Owner (406)-538-7451 800 CASINO CREEK DR LEWISTOWN MT 59457-3359

Henry Berry, UST Class A Operator
Jason Fry, UST Class A Operator
Mike Schenck, UST Class A Operator
Henry Berry, UST Class B Operator
Charlie Craven, UST Class B Operator
Jason Fry, UST Class B Operator
Don Taylor, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	09	6/25/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5128		9/3/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Heating Oil			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,500					

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: RINDAL OIL CO LEWISTOWN
1011 JOYLAND RD
LEWISTOWN, MT 59457 FERGUS

Contact: Chris Rindal, (406) 535-3396

Sys Fac ID: 14-05108
Last Inspected On: 8/19/2015
Operating Permit Renewal Date: 2/4/2019

Owners/Operators: Donald A Rindal, Owner
PO BOX 504
LEWISTOWN MT 59457-0504

Chris Rindal, UST Class A Operator
Chris Rindal, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	17	1/1/1999	Aboveground Tank	Flexible Plastic	
3931	Yes	7/14/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
1,000					
12	17	1/1/1999	Aboveground Tank	Flexible Plastic	
3932	Yes	7/14/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
1,000					
13	17	1/1/1999	Aboveground Tank	Flexible Plastic	
3933	Yes	7/14/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
2,000					

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: PJG MOTORSPORTS UST
624 W MAIN ST
LEWISTOWN, MT 59457 FERGUS

Contact: Paul Granot, (406) 535-8000

Sys Fac ID: 14-08126
Last Inspected On: 4/29/2015
Operating Permit Renewal Date:

Owners/Operators: Paul J Granot, Owner (406)-538-4271 511 4TH AVE S
LEWISTOWN MT 59457-3117

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	37	4/1/1979	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3717			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use		4/1/2001	Not Required	Safe Suction	Impressed Current
Gasoline		6/6/2012	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000					
3	37	4/25/1979	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
4686			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use		4/1/2001	Not Required	Safe Suction	Impressed Current
Gasoline		6/6/2012	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
6,000					
4	36	4/24/1980	Bare Steel	Steel	
4687			Impressed Current	None	Yes
Temporarily Out of Use			Not Required	Gravity Feed	Impressed Current
Waste Oil		6/6/2012	Manual Tank Gauging	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
550					

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: TOWN PUMP INC LEWISTOWN
622 1/2 NE MAIN ST
LEWISTOWN, MT 59457 FERGUS

Contact: Roger Hovis, (406) 538-2217

Sys Fac ID: 14-08711
Last Inspected On: 6/10/2016
Operating Permit Renewal Date: 8/13/2019

Owners/Operators: Idaho Washington Pole Oil Co, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	46	4/14/1970	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2415			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/15/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	25	6/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2419			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/9/2006	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	39	4/14/1977	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2418			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/15/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: TOWN PUMP INC LEWISTOWN
622 1/2 NE MAIN ST
LEWISTOWN, MT 59457 FERGUS

Contact: Roger Hovis, (406) 538-2217

Sys Fac ID: 14-08711
Last Inspected On: 6/10/2016
Operating Permit Renewal Date: 8/13/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	46	4/14/1970	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2416			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/15/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	39	4/14/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2417			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		2/15/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	15	9/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4521			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/9/2006	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	15	9/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4522			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/9/2006	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: TOWN PUMP INC LEWISTOWN
622 1/2 NE MAIN ST
LEWISTOWN, MT 59457 FERGUS

Contact: Roger Hovis, (406) 538-2217

Sys Fac ID: 14-08711
Last Inspected On: 6/10/2016
Operating Permit Renewal Date: 8/13/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	15	9/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4523			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/9/2006	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	15	9/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4524			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/9/2006	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: MALMSTROM AFB M 4
ROAD 505
LEWISTOWN, MT 59457 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09110
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/24/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	8/11/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
193		4/6/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: MALMSTROM AFB M 5
US HIGHWAY 87
LEWISTOWN, MT 59457 FERGUS

Sys Fac ID: 14-09111
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/24/2019

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	5/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
194		4/6/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: MALMSTROM AFB N 7
ROAD 238
LEWISTOWN, MT 59457 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09124
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/14/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	8/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
204		4/28/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: MALMSTROM AFB N 8
US HIGHWAY 87
LEWISTOWN, MT 59457 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09125
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/15/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	7/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
205		4/28/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: MALMSTROM AFB N 9
US HIGHWAY 87
LEWISTOWN, MT 59457 FERGUS

Sys Fac ID: 14-09126
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/14/2019

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	7/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
206		4/28/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: MALMSTROM AFB N 10
US HIGHWAY 87
LEWISTOWN, MT 59457 FERGUS

Sys Fac ID: 14-09127
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/14/2019

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	8/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
207		8/2/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: MALMSTROM AFB N 11
US HIGHWAY 87
LEWISTOWN, MT 59457 FERGUS

Sys Fac ID: 14-09128
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/14/2019

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	8/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
208		4/29/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: DEPOT EXPRESS
513 1ST AVE N
LEWISTOWN, MT 59457 FERGUS
Contact: Kevin Rector, (406) 535-9459

Sys Fac ID: 14-12547
Last Inspected On: 7/5/2016
Operating Permit Renewal Date: 2/13/2017

Owners/Operators: Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756
BILLINGS MT 59103-1756

Mykel Stockton, UST Class A Operator
James Brown, UST Class B Operator
Kevin Rector, UST Class B Operator
Joey McConnell, UST Class B Global Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	10/29/1991	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
2721			None	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		11/18/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
2	25	10/29/1991	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
2722			None	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		11/18/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
3	25	10/29/1991	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
2723			None	Double-Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/18/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: DEPOT EXPRESS
513 1ST AVE N
LEWISTOWN, MT 59457 FERGUS
Contact: Kevin Rector, (406) 535-9459

Sys Fac ID: 14-12547
Last Inspected On: 7/5/2016
Operating Permit Renewal Date: 2/13/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	22	10/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2724			None	Double-Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Not Listed	Galvanic
Diesel		11/18/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	14	3/18/2002	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4617			None	Double-Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/18/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
6	14	3/18/2002	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4618			None	Double-Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/18/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
3,000			TLS-350/Gilbarco EMC , Veeder Root		
7	14	3/18/2002	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4619			None	Double-Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/18/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
3,000			TLS-350/Gilbarco EMC , Veeder Root		
8	14	5/15/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4659			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/18/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		6/7/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of LEWISTOWN

Location: DEPOT EXPRESS
513 1ST AVE N
LEWISTOWN, MT 59457 FERGUS

Contact: Kevin Rector, (406) 535-9459

Sys Fac ID: 14-12547
Last Inspected On: 7/5/2016
Operating Permit Renewal Date: 2/13/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	14	5/15/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4660			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/18/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		5/29/2010	TLS-350/Gilbarco EMC , Veeder Root		
10	14	5/15/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4661			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/18/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
9,000		6/9/2010	TLS-350/Gilbarco EMC , Veeder Root		
11	14	5/15/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4662			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/18/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
3,000		6/1/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of MOORE

Location: EDDIES CORNER INC
US HIGHWAY 87 & US HIGHWAY 191
MOORE, MT 59464 FERGUS

Contact: Joe Bauman, (406) 374-2471

Sys Fac ID: 14-02832
Last Inspected On: 1/31/2014
Operating Permit Renewal Date: 5/8/2017

Owners/Operators: Eddies Corner Inc, Owner (406)-374-2471 65000 US HIGHWAY 87
MOORE MT 59464-9472

Joseph Bauman, UST Class A Operator
Joseph Bauman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	24	4/17/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
853			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/2/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		8/8/2013	Gilbarco EMC Basic , Gilbarco		
4	24	4/17/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
854			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/2/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		8/8/2013	Gilbarco EMC Basic , Gilbarco		
5	24	4/17/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
855			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/2/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		8/8/2013	Gilbarco EMC Basic , Gilbarco		
6	26	7/11/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
852			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		6/2/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		8/8/2013	Gilbarco EMC Basic , Gilbarco		

Facility Summary in FERGUS County in the City of MOORE

Location: MALMSTROM AFB L 2
US HIGHWAY 87
MOORE, MT 59464 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09097
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/7/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
187		4/25/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of MOORE

Location: MALMSTROM AFB L 11
US HIGHWAY 191
MOORE, MT 59464 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09106
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/6/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
189		4/26/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of MOORE

Location: MALMSTROM AFB M 1
US HIGHWAY 87
MOORE, MT 59464 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09107
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/24/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Ricardo Andrillon, UST Class B Operator
Glen Beck, UST Class B Operator
Allen Brooks, UST Class B Operator
Jonathan Buesch, UST Class B Operator
John Corbett, UST Class B Operator
David Cosner, UST Class B Operator
Ryan Cox, UST Class B Operator
Brian Day, UST Class B Operator
David Degolier, UST Class B Operator
Hudson English, UST Class B Operator
Eric Haumschild, UST Class B Operator
Dustin Hemingway, UST Class B Operator
Aaron Hill, UST Class B Operator
William Hoffmeister, UST Class B Operator
Shane Hofstad, UST Class B Operator
Bethany Kent, UST Class B Operator
James Knudsen, UST Class B Operator
Ryan Kofoed, UST Class B Operator
Jeff Laird, UST Class B Operator
Damon McCarty, UST Class B Operator
Kieth McIlwain, UST Class B Operator
Brian McVay, UST Class B Operator
Ronald Miller, UST Class B Operator
Michael Murieen, UST Class B Operator
Jeff Nelson, UST Class B Operator
Shawn O'Grady, UST Class B Operator
Chris Ploof, UST Class B Operator
Issac Price, UST Class B Operator
Brian Rayner, UST Class B Operator
Cameron Smith, UST Class B Operator

Facility Summary in FERGUS County in the City of MOORE

Location: MALMSTROM AFB M 1
US HIGHWAY 87
MOORE, MT 59464 FERGUS

Sys Fac ID: 14-09107
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/24/2019

Contact: Jim Hodges,

Jimmy Sonefelt, UST Class B Operator
Michael Stokes, UST Class B Operator
Kyle Topp, UST Class B Operator
Jason Vike, UST Class B Operator
Mark Wight, UST Class B Operator
James Wooderchak, UST Class B Operator
Paul Ziemba, UST Class B Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	54	5/2/1962	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
190		4/7/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Impressed Current
Diesel		3/31/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Vapor Monitoring	

Facility Summary in FERGUS County in the City of MOORE

Location: MALMSTROM AFB M 6
US HIGHWAY 87
MOORE, MT 59464 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09112
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/24/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	5/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
195		4/7/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of MOORE

Location: MALMSTROM AFB M 7
US HIGHWAY 87
MOORE, MT 59464 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09113
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/24/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	5/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
196		4/7/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of MOORE

Location: MALMSTROM AFB M 11
US HIGHWAY 87
MOORE, MT 59464 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09117
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	5/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
197		4/4/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of MOORE

Location: MOORE FARMERS OIL CO 5613901
113 FERGUS AVE
MOORE, MT 59464 FERGUS

Contact: Gary Marxer, (406) 374-2555

Sys Fac ID: 56-13901
Last Inspected On: 12/19/2013
Operating Permit Renewal Date: 1/8/2017

Owners/Operators: Moore Farmers Oil Co, Owner (406)-374-2555 PO BOX 120
MOORE MT 59464-0120

Shawn Auck, UST Class A Operator
Richard Brottem, UST Class B Operator
Ron Greene, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	18	10/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1693			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/5/2010	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		10/10/2011	TLS-350/Gilbarco EMC , Veeder Root		
2	18	10/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1694			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/5/2010	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		10/10/2011	TLS-350/Gilbarco EMC , Veeder Root		
3	18	10/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1695			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/5/2010	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		10/10/2011	TLS-350/Gilbarco EMC , Veeder Root		
4	18	10/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1696			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/5/2010	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		10/10/2011	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of ROY

Location: MALMSTROM AFB O 1
US HIGHWAY 191
ROY, MT 59471 FERGUS

Sys Fac ID: 14-09129
Last Inspected On: 4/13/2016
Operating Permit Renewal Date: 7/31/2019

Contact:

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Ricardo Andrillon, UST Class B Operator
Glen Beck, UST Class B Operator
Allen Brooks, UST Class B Operator
John Corbett, UST Class B Operator
David Degolier, UST Class B Operator
Eric Haumschild, UST Class B Operator
Shane Hofstad, UST Class B Operator
Bethany Kent, UST Class B Operator
Ryan Kofoed, UST Class B Operator
Kieth McIlwain, UST Class B Operator
Ronald Miller, UST Class B Operator
Michael Murieen, UST Class B Operator
Jeff Nelson, UST Class B Operator
Chris Ploof, UST Class B Operator
Issac Price, UST Class B Operator
Brian Rayner, UST Class B Operator
Jimmy Sonefelt, UST Class B Operator
Michael Stokes, UST Class B Operator
Jason Vike, UST Class B Operator
Mark Wight, UST Class B Operator
James Wooderchak, UST Class B Operator
Paul Ziemba, UST Class B Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**

Facility Summary in FERGUS County in the City of ROY

Location: MALMSTROM AFB O 1
US HIGHWAY 191
ROY, MT 59471 FERGUS

Sys Fac ID: 14-09129
Last Inspected On: 4/13/2016
Operating Permit Renewal Date: 7/31/2019

Contact:

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	54	6/2/1962	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
209		4/13/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Impressed Current
Diesel		12/31/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of ROY

Location: MALMSTROM AFB O 2
US HIGHWAY 191
ROY, MT 59471 FERGUS

Sys Fac ID: 14-09130
Last Inspected On: 4/13/2016
Operating Permit Renewal Date: 7/31/2019

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Dustin Hemingway, UST Class B Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	7/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
210		4/13/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of ROY

Location: MALMSTROM AFB O 3
US HIGHWAY 191
ROY, MT 59471 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09131
Last Inspected On: 4/12/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	7/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
211		4/12/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of ROY

Location: MALMSTROM AFB O 4
MT HIGHWAY 19
ROY, MT 59471 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09132
Last Inspected On: 4/12/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	7/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
212		4/12/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of ROY

Location: MALMSTROM AFB O 5
MT HIGHWAY 19
ROY, MT 59471 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09133
Last Inspected On: 4/11/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	7/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
213		4/11/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of ROY

Location: MALMSTROM AFB O 6
MT HIGHWAY 19
ROY, MT 59471 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09134
Last Inspected On: 4/11/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	7/15/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
214		4/11/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of ROY

Location: MALMSTROM AFB O 7
US HIGHWAY 191
ROY, MT 59471 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09135
Last Inspected On: 4/13/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	7/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
215		4/13/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of ROY

Location: MALMSTROM AFB O 10
US HIGHWAY 191
ROY, MT 59471 FERGUS

Sys Fac ID: 14-09138
Last Inspected On: 4/14/2016
Operating Permit Renewal Date: 8/14/2019

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Aaron Hill, UST Class B Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	7/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
218		4/14/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of ROY

Location: MALMSTROM AFB O 11
US HIGHWAY 191
ROY, MT 59471 FERGUS

Sys Fac ID: 14-09139
Last Inspected On: 4/14/2016
Operating Permit Renewal Date: 8/14/2019

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
William Hoffmeister, UST Class B Operator
Brian McVay, UST Class B Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	8/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
219		4/14/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of WINIFRED

Location: CHS BIG SKY WINIFRED
108 MAIN ST
WINIFRED, MT 59489 FERGUS

Contact: Ed Heggem, (406) 462-5428

Sys Fac ID: 14-01292
Last Inspected On: 2/17/2014
Operating Permit Renewal Date: 5/16/2017

Owners/Operators: CHS Big Sky, Owner (406)-462-5428 PO BOX 182 WINIFRED MT 59489

Ed Heggem, UST Class A Operator
Brendon Jerke, UST Class A Operator
John Blazicevich, UST Class B Operator
Ed Heggem, UST Class B Operator
Brendon Jerke, UST Class B Operator
Brendon Jerke, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	9/1/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
2289			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		4/29/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
4,000		5/1/2013	EECO 2000 , EMCO Electronics		
2	20	9/1/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
2290			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		4/29/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
4,000		5/1/2013	EECO 2000 , EMCO Electronics		
3	20	9/1/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
2291			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		4/29/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
12,000		5/1/2013	EECO 2000 , EMCO Electronics		

Facility Summary in FERGUS County in the City of WINIFRED

Location: CHS BIG SKY WINIFRED
108 MAIN ST
WINIFRED, MT 59489 FERGUS

Contact: Ed Heggem, (406) 462-5428

Sys Fac ID: 14-01292
Last Inspected On: 2/17/2014
Operating Permit Renewal Date: 5/16/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	20	9/1/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
2292			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		4/29/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
4,000		5/1/2013	EECO 2000 , EMCO Electronics		
5	20	9/1/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
2293			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/29/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
8,000		5/1/2013	EECO 2000 , EMCO Electronics		
6	20	9/1/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
2294			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/29/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
12,000		5/1/2013	EECO 2000 , EMCO Electronics		
8	20	9/1/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
2288			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/29/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
4,000		5/1/2013	EECO 2000 , EMCO Electronics		

Facility Summary in FERGUS County in the City of WINIFRED

Location: MALMSTROM AFB E 1
COUNTY ROAD 236
WINIFRED, MT 59489 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09019
Last Inspected On: 11/6/2014
Operating Permit Renewal Date: 9/15/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Chris Amann, UST Class B Operator
Ricardo Andrillon, UST Class B Operator
Glen Beck, UST Class B Operator
Allen Brooks, UST Class B Operator
Jonathan Buesch, UST Class B Operator
John Corbett, UST Class B Operator
David Cosner, UST Class B Operator
Ryan Cox, UST Class B Operator
Brian Day, UST Class B Operator
David Degolier, UST Class B Operator
Hudson English, UST Class B Operator
Dustin Hemingway, UST Class B Operator
Aaron Hill, UST Class B Operator
William Hoffmeister, UST Class B Operator
Shane Hofstad, UST Class B Operator
Bethany Kent, UST Class B Operator
James Knudsen, UST Class B Operator
Ryan Kofoed, UST Class B Operator
Jeff Laird, UST Class B Operator
Damon McCarty, UST Class B Operator
Kieth McIlwain, UST Class B Operator
Brian McVay, UST Class B Operator
Ronald Miller, UST Class B Operator
Michael Murieen, UST Class B Operator
Jeff Nelson, UST Class B Operator
Shawn O'Grady, UST Class B Operator
Chris Ploof, UST Class B Operator
Issac Price, UST Class B Operator
Brian Rayner, UST Class B Operator
Adam Reathaford, UST Class B Operator

Facility Summary in FERGUS County in the City of WINIFRED

Location: MALMSTROM AFB E 1
COUNTY ROAD 236
WINIFRED, MT 59489 FERGUS

Sys Fac ID: 14-09019
Last Inspected On: 11/6/2014
Operating Permit Renewal Date: 9/15/2017

Contact: Jim Hodges,

Cameron Smith, UST Class B Operator
Jimmy Sonefelt, UST Class B Operator
Michael Stokes, UST Class B Operator
Kyle Topp, UST Class B Operator
Jason Vike, UST Class B Operator
James Wooderchak, UST Class B Operator
Paul Ziemba, UST Class B Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	54	5/2/1962	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
175		9/26/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Diesel		7/21/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					

Facility Summary in FERGUS County in the City of WINIFRED

Location: MALMSTROM AFB E 2
ROAD 236
WINIFRED, MT 59489 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09020
Last Inspected On: 11/5/2014
Operating Permit Renewal Date: 9/15/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	7/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
176		9/25/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000					

Facility Summary in FERGUS County in the City of WINIFRED

Location: MALMSTROM AFB E 3
ROAD 236
WINIFRED, MT 59489 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09021
Last Inspected On: 11/5/2014
Operating Permit Renewal Date: 9/15/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	7/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
177		9/25/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of WINIFRED

Location: MALMSTROM AFB E 4
ROAD 236
WINIFRED, MT 59489 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09022
Last Inspected On: 11/5/2014
Operating Permit Renewal Date: 9/15/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	7/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4273		9/25/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of WINIFRED

Location: MALMSTROM AFB E 5
ROAD 236
WINIFRED, MT 59489 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09023
Last Inspected On: 11/6/2014
Operating Permit Renewal Date: 9/15/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4269		10/9/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of WINIFRED

Location: MALMSTROM AFB E 10
ROAD 236
WINIFRED, MT 59489 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09028
Last Inspected On: 11/5/2014
Operating Permit Renewal Date: 9/15/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	7/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
184		10/16/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FERGUS County in the City of WINIFRED

Location: MALMSTROM AFB E 11
ROAD 236
WINIFRED, MT 59489 FERGUS

Contact: Jim Hodges,

Sys Fac ID: 14-09029
Last Inspected On: 11/5/2014
Operating Permit Renewal Date: 9/15/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	7/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
185		11/5/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: YOUR TURN CONVENIENCE STOP
7505 MT HIGHWAY 35
BIGFORK, MT 59911 FLATHEAD

Contact: Doug White, (406) 837-6170

Sys Fac ID: 15-02482
Last Inspected On: 7/17/2014
Operating Permit Renewal Date: 8/8/2017

Owners/Operators: White Enterprises, Owner (406)-837-6170 7505 MT HIGHWAY 35
BIGFORK MT 59911-6215

Angela Tull, UST Class A Operator
Alison Wallen, UST Class A Operator
Angela Tull, UST Class B Operator
Alison Wallen, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	19	1/10/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3185			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		2/3/2011	TS-1000 , Incon		
7	19	1/10/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3186			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		2/3/2011	TS-1000 , Incon		
8	19	1/10/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3187			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		2/3/2011	TS-1000 , Incon		
9	19	11/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3188			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		2/3/2011	TS-1000 , Incon		

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: MARINA CAY RESORT
180 VISTA DR
BIGFORK, MT 59911 FLATHEAD

Contact: Ronald Fetveit, (406) 837-5861

Sys Fac ID: 15-03002
Last Inspected On: 9/10/2015
Operating Permit Renewal Date: 10/14/2018

Owners/Operators:

Elk LLC, Owner	(406)-837-5861	PO BOX 709 BIGFORK MT 59911
Marina Cay Resort, Operator	(406)-837-5861	PO BOX 663 BIGFORK MT 59911-0663

Mark Maliniak, UST Class A Operator
Jessica Yevich, UST Class A Operator
Mark Maliniak, UST Class B Operator
Jessica Yevich, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	17	5/5/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4067			None	Double-Walled	Yes
Currently in Use		5/1/2009	Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000					
3	09	7/25/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5110		9/8/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1	Continuous Interstitial Monitor	
4,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: FLATHEAD LAKE LODGE
150 FLATHEAD LODGE RD
BIGFORK, MT 59911 FLATHEAD
Contact: Doug Averill, (406) 837-4391

Sys Fac ID: 15-04551
Last Inspected On: 12/1/2015
Operating Permit Renewal Date:

Owners/Operators: Flathead Lake Lodge, Owner (406)-837-3815 DOUG AVERILL
PO BOX 248
BIGFORK MT 59911-0248

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	5/14/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1826			None	None	Yes
Temporarily Out of Use		5/14/2002	Not Required	Safe Suction	Not Applicable
Gasoline		1/10/2013	Manual Tank Gauging, Tank Tightness Testing	Not Listed	
1,000					
2	22	6/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1827			None	None	Yes
Temporarily Out of Use		6/1/2004	Not Required	Safe Suction	Not Applicable
Gasoline		1/10/2013	Manual Tank Gauging, Tank Tightness Testing	Not Listed	
600					

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: KAY GB PROPERTIES LLC
8089 MT HIGHWAY 35
BIGFORK, MT 59911 FLATHEAD
Contact: (406) 250-2344

Sys Fac ID: 15-06086
Last Inspected On: 8/6/2014
Operating Permit Renewal Date:

Owners/Operators: Kay G B Properties LLC, Owner (406)-250-2344 235 BLACK BEARLANE BIGFORK MT 59911
Fred Burnham, UST Class A Operator
Kelly Johns, UST Class A Operator
Kelly Johns, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	25	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2283			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/20/2007			
7	25	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2284			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/20/2007			
8	25	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2285			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		12/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/20/2007			

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: KAY GB PROPERTIES LLC
8089 MT HIGHWAY 35
BIGFORK, MT 59911 FLATHEAD
Contact: (406) 250-2344

Sys Fac ID: 15-06086
Last Inspected On: 8/6/2014
Operating Permit Renewal Date:

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	22	3/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	
2286			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		12/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		3/20/2007			

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: FERNDALE MARKET
1845 MT HIGHWAY 209
BIGFORK, MT 59911 FLATHEAD

Contact: Jason Griggs, (406) 314-8234

Sys Fac ID: 15-07199
Last Inspected On: 5/6/2014
Operating Permit Renewal Date: 8/8/2017

Owners/Operators:

Griggs Ferndale LLC, Owner	(406)-837-5597	1845 MT HWY 209 BIGFORK MT 59911
Jason Griggs, Operator	(406)-314-8234	965 SWAN RIVER RD BIGFORK MT 59911
Ray Kleiv, UST Class A Operator		
Ray Kleiv, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	40	4/28/1976	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3254			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/5/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
2	39	4/28/1977	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3255			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/5/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
3	23	6/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3256			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/5/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
4	23	6/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3257			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/5/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: ECHO LAKE STORE
110 SWAN RIVER RD
BIGFORK, MT 59911 FLATHEAD
Contact: Frances Forkin, (406) 837-4727

Sys Fac ID: 15-07361
Last Inspected On: 8/10/2015
Operating Permit Renewal Date:

Owners/Operators: Forkins Echo Lake Store, Owner (406)-249-9043 135 MARKEN LOOP
BIGFORK MT 59911-6435

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	21	11/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3498			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		8/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
6,000			EECO 1500 , EMCO Electronics		
7	21	11/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3499			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		8/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
3,000			EECO 1500 , EMCO Electronics		
8	21	11/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3500			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		8/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
3,000			EECO 1500 , EMCO Electronics		

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: CALUMET CARDLOCK
8111 MT HIGHWAY 35
BIGFORK, MT 59911 FLATHEAD

Contact: Drew Pikes, (406) 249-1545

Sys Fac ID: 15-09801
Last Inspected On: 9/19/2016
Operating Permit Renewal Date: 9/23/2019

Owners/Operators:

Bigfork Properties LLC, Owner	(406)-837-4550	300 BRIDGE STREET BIGFORK MT 59911
City Service Valcon LLC, Operator	(406)-294-0865	640 W MONTANA ST KALISPELL MT 59904
Kary Tonjum, UST Class A Operator		
Kary Tonjum, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	35	5/1/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
481			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current, Galvanic
Gasoline		3/5/2014	Automatic Tank Gauging 0.2	Deferred	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
2	35	5/1/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
482			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current, Galvanic
Diesel		3/5/2014	Automatic Tank Gauging 0.2	Deferred	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
3	23	7/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
483			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		3/5/2014	Automatic Tank Gauging 0.2	Deferred	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: CALUMET CARDLOCK
8111 MT HIGHWAY 35
BIGFORK, MT 59911 FLATHEAD

Contact: Drew Pikes, (406) 249-1545

Sys Fac ID: 15-09801
Last Inspected On: 9/19/2016
Operating Permit Renewal Date: 9/23/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	21	4/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
484			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		3/5/2014	Automatic Tank Gauging 0.2	Deferred	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
5	21	4/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
485			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		3/5/2014	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: EAGLE BEND YACHT HARBOR
371 EAGLE BEND DR
BIGFORK, MT 59911 FLATHEAD

Contact: Dave Roberts, (406) 253-2840

Sys Fac ID: 15-13152
Last Inspected On: 3/14/2016
Operating Permit Renewal Date: 6/1/2019

Owners/Operators:

Eagle Bend Yacht Harbor Boat Slip Owners Association, Owner	(406)-837-4536	PO BOX 463 BIGFORK MT 59911-0463
Dave Roberts, Operator	(406)-257-1302	WESTERN MOUNTAINS PROPERTY MANAGEMENT ADDRESS UNKNOWN MT
Sharla Ferron, UST Class A Operator		
Jessica Glazier, UST Class A Operator		
Edward Mitchke, UST Class A Operator		
Jessica Glazier, UST Class B Operator		
Edward Mitchke, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	7/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4013			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000		8/2/2010	TLS-250 , Veeder Root		
2	23	7/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4014			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
1,000		8/2/2010	TLS-250 , Veeder Root		

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: SWAN LAKE STAGE STOP INC
21385 MT HIGHWAY 83
BIGFORK, MT 59911 FLATHEAD

Sys Fac ID: 24-05644
Last Inspected On: 7/28/2016
Operating Permit Renewal Date:

Contact: Linda Bosworth, (406) 886-2500

Owners/Operators:

Mike Huddleston, Operator	(406)-886-2300	21385 MT HIGHWAY 83 SWAN LAKE MT 59911
Tracy Huddleston, Operator	(406)-886-2300	21385 MT HIGHWAY 83 SWAN LAKE MT 59911
Sell It All LLC, Owner/Operator	(406)-886-2500	23296 BOSWORTH LANE SWAN LAKE MT 59911

Linda Bosworth, UST Class A Operator
Chris Cox, UST Class A Operator
Tracy Gardner-Huddleston, UST Class A Operator
Michael Huddleston, UST Class A Operator
Linda Bosworth, UST Class B Operator
Chris Cox, UST Class B Operator
Tracy Gardner-Huddleston, UST Class B Operator
Michael Huddleston, UST Class B Operator
Thomas Pelican, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	30	5/7/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3325			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		3/31/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		3/8/2011	TS-1000 , Incon		
2	30	5/7/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3326			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		3/31/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		3/8/2011	TS-1000 , Incon		

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: SWAN LAKE STAGE STOP INC
21385 MT HIGHWAY 83
BIGFORK, MT 59911 FLATHEAD

Sys Fac ID: 24-05644
Last Inspected On: 7/28/2016
Operating Permit Renewal Date:

Contact: Linda Bosworth, (406) 886-2500

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	20	7/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3327			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		3/31/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		7/24/2012	TS-1000 , Incon		
4	20	7/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3328			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		3/31/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/8/2011	TS-1000 , Incon		

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: BIGFORK STAGE STOP INC
8263 MT HIGHWAY 35
BIGFORK, MT 59911 FLATHEAD

Contact: Steve Harris, (406) 837-1551

Sys Fac ID: 56-13885
Last Inspected On: 10/4/2016
Operating Permit Renewal Date: 12/6/2019

Owners/Operators: Bigfork Stage Stop Inc, Owner (406)-837-5858 PO BOX 243
BIGFORK MT 59911-0243

Ronald Brevik, UST Class A Operator
Alexander Olson, UST Class A Operator
Ronald Brevik, UST Class B Operator
Nancy Kitzenberg, UST Class B Operator
Alexander Olson, UST Class B Operator
Liana Rowe, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	18	10/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3531			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	18	10/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3532			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	18	10/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3533			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of BIGFORK

Location: Montana Ranch LLC
1463 HWY 83
BIGFORK, MT 59911 FLATHEAD
Contact: Matt Cottle, (406) 253-8403

Sys Fac ID: 60-15198
Last Inspected On: 1/15/2015
Operating Permit Renewal Date: 3/23/2018

Owners/Operators:

Montana Ranch LLC, Owner	(406)-755-0264	1463 HWY 83 BIGFORK MT 59911
Matt Cottle, Operator	(406)-253-8403	1463 HWY 83 BIGFORK MT 59911
Matt Cottle, UST Class A Operator		
Matt Cottle, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	05	8/29/2011	Fiberglass Reinforced Plastic	Steel	Ball Float Valve
5327			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Deferred	
2,500		10/6/2011	Gilbarco EMC Basic , Gilbarco		Yes
2	05	8/29/2011	Fiberglass Reinforced Plastic	Steel	Ball Float Valve
5328			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Deferred	
2,500		10/6/2011	Gilbarco EMC Basic , Gilbarco		Yes

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: JUNCTION GAS
7322 US HIGHWAY 2 E
COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Ramdeep Kaur, (406) 890-5047

Sys Fac ID: 15-02820
Last Inspected On: 11/19/2013
Operating Permit Renewal Date: 12/24/2016

Owners/Operators:

RKR LLC, Owner	(406)-890-5047	2100 US HWY 2 E KALISPELL MT 59901
Aries Enterprises LLC, Operator	(406)-890-5047	2100 US HWY 2 E KALISPELL MT 59901

David M Brotnov, UST Class A Operator
Ramdeep Kaur, UST Class A Operator
Ramdeep Kaur, UST Class B Operator
Ramdeep Kaur, UST Class B Global Operator
Marlene Sevesind, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	39	7/1/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
496		1/25/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Gasoline		7/31/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000		6/29/2010	TLS-350/Gilbarco EMC , Veeder Root		
2	39	7/1/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
497			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/31/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/5/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	39	7/1/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
498		1/25/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Diesel		7/31/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000		6/29/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: JUNCTION GAS
7322 US HIGHWAY 2 E
COLUMBIA FALLS, MT 59912 FLATHEAD
Contact: Ramdeep Kaur, (406) 890-5047

Sys Fac ID: 15-02820
Last Inspected On: 11/19/2013
Operating Permit Renewal Date: 12/24/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	28	11/17/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
499			Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		7/31/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		7/13/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: COLUMBIA FALLS ALUMINUM CO LLC
2000 ALUMINUM DR
COLUMBIA FALLS, MT 59912 FLATHEAD
Contact: Cliff Boyd, (406) 360-0751

Sys Fac ID: 15-04003
Last Inspected On: 3/17/2016
Operating Permit Renewal Date:

Owners/Operators: Calbag Resources LLC, Owner (503)-226-3441 PO BOX 10067 PORTLAND OR 97296-0067
Stephen Wright, UST Class A Operator
Stephen Wright, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	27	7/18/1989	Steel Clad	Fiberglass Reinforced Plastic	Ball Float Valve
3413		11/28/2012	Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
12,000					
9	27	7/18/1989	Steel Clad	Fiberglass Reinforced Plastic	Ball Float Valve
3415		11/28/2012	Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
3,000		11/20/2014			
10	27	7/18/1989	Steel Clad	Fiberglass Reinforced Plastic	Ball Float Valve
3414		11/28/2012	Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
5,000		11/20/2014			

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: MIKES OF COLUMBIA FALLS
1645 9TH ST W
COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Sean Hurley, (509) 535-7701

Sys Fac ID: 15-06839
Last Inspected On: 5/20/2014
Operating Permit Renewal Date: 7/31/2017

Owners/Operators:

KMR LLC, Owner	(406)-892-2078	1645 9TH ST W COLUMBIA FALLS MT 59912
Mikes of Columbia Falls Inc, Operator	(406)-892-2078	1645 9TH ST W COLUMBIA FALLS MT 59912-4406

Ronda Heil, UST Class A Operator
Ronald May, UST Class A Operator
Michael W Robinson, UST Class A Operator
Joe Stenzel, UST Class A Operator
Jennifer Davis, UST Class B Operator
Kristy Stevenson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	20	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4466			None	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	20	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3366			None	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	20	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3367			None	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: MIKES OF COLUMBIA FALLS
1645 9TH ST W
COLUMBIA FALLS, MT 59912 FLATHEAD
Contact: Sean Hurley, (509) 535-7701

Sys Fac ID: 15-06839
Last Inspected On: 5/20/2014
Operating Permit Renewal Date: 7/31/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	20	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3368			None	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	20	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3369			None	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: TOWN PUMP INC COLUMBIA FALLS 1
502 9TH ST W
COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Roger Hovis, (406) 892-2245

Sys Fac ID: 15-08690
Last Inspected On: 1/16/2016
Operating Permit Renewal Date: 4/21/2019

Owners/Operators: Town Pump of Columbia Falls Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	35	7/14/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2420			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/13/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	31	10/1/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4380			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/13/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
10,000			TLS-350/Gilbarco EMC , Veeder Root		
6	27	7/14/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4381			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/13/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: TOWN PUMP INC COLUMBIA FALLS 1
502 9TH ST W
COLUMBIA FALLS, MT 59912 FLATHEAD
Contact: Roger Hovis, (406) 892-2245

Sys Fac ID: 15-08690
Last Inspected On: 1/16/2016
Operating Permit Renewal Date: 4/21/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	27	7/14/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2423			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/13/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: WILCO ENTERTAINMENT LLC
7356 US HIGHWAY 2 E
COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Keith Brown, (406) 270-6530

Sys Fac ID: 15-11333
Last Inspected On: 7/28/2016
Operating Permit Renewal Date: 8/2/2019

Owners/Operators: Wilco Entertainment LLC, Owner/Operator (406)-270-6530 PO BOX 701 LAKESIDE MT 59922
Wade Lindsay, UST Class A Operator
Wade Lindsay, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	1/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
686			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		3/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/24/2016	TLS-350/Gilbarco EMC , Veeder Root		
2	26	1/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
687			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		3/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		3/24/2016	TLS-350/Gilbarco EMC , Veeder Root		
3	26	1/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
688			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		3/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/24/2016	TLS-350/Gilbarco EMC , Veeder Root		
4	26	1/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
689			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		3/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/24/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: CITY SERVICE VALCON
195 TRUCK ROUTE RD
COLUMBIA FALLS, MT 59912 FLATHEAD
Contact: Corey Edens, (406) 755-6611

Sys Fac ID: 15-12972
Last Inspected On: 6/6/2014
Operating Permit Renewal Date: 10/2/2017

Owners/Operators: Valcon Distributing LTD, Owner (406)-755-6611 PO BOX 9200
KALISPELL MT 59904-2200

Kary Tonjum, UST Class A Operator
Kary Tonjum, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	12/15/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4404		9/4/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000		9/29/2014	TS-1000 , Incon	Continuous Interstitial Monitor	
2	24	11/15/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4405		9/4/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000		9/29/2014	TS-1000 , Incon	Continuous Interstitial Monitor	
3	24	11/15/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4406		9/4/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000		9/29/2014	TS-1000 , Incon	Continuous Interstitial Monitor	
4	24	11/15/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4407		9/4/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		9/29/2014	TS-1000 , Incon	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: CITY SERVICE VALCON
195 TRUCK ROUTE RD
COLUMBIA FALLS, MT 59912 FLATHEAD
Contact: Corey Edens, (406) 755-6611

Sys Fac ID: 15-12972
Last Inspected On: 6/6/2014
Operating Permit Renewal Date: 10/2/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	24	11/15/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4408		9/4/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		9/29/2014	TS-1000 , Incon	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: TOWN PUMP INC COLUMBIA FALLS 2
6102 US HWY 2 W
COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-13825
Last Inspected On: 11/17/2015
Operating Permit Renewal Date: 11/19/2018

Owners/Operators: Columbia Falls Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, Ball Float Valve
2674			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	19	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4670			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	19	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2676			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: TOWN PUMP INC COLUMBIA FALLS 2
6102 US HWY 2 W
COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-13825
Last Inspected On: 11/17/2015
Operating Permit Renewal Date: 11/19/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	19	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2677			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing, Approved Remote Monitoring	
10,000		11/12/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	19	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2678			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing, Approved Remote Monitoring	
6,000		11/12/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	19	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2679		10/7/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing, Approved Remote Monitoring	
6,000		11/12/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	16	10/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4249			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	16	10/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4250			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of COLUMBIA FALLS

Location: TOWN PUMP INC COLUMBIA FALLS 2
6102 US HWY 2 W
COLUMBIA FALLS, MT 59912 FLATHEAD

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-13825
Last Inspected On: 11/17/2015
Operating Permit Renewal Date: 11/19/2018

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
9	01	10/2/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5600		9/17/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
10	01	10/2/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5601		9/17/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in FLATHEAD County in the City of CORAM

Location: GLACIER CENTER
10049 US HIGHWAY 2 E
CORAM, MT 59913 FLATHEAD

Contact: Matt Kinsella, (406) 387-5090

Sys Fac ID: 15-10895
Last Inspected On: 5/28/2014
Operating Permit Renewal Date: 6/3/2017

Owners/Operators: High Altitude Enterprises Inc, Owner/Operator (406)-387-5090 PO BOX 130296 CORAM MT 59913-9060

Matt Kinsella, UST Class A Operator
ShariLyn Gronitz, UST Class B Operator
Matt Kinsella, UST Class B Operator
ShariLyn Gronitz, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	28	4/17/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1883			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		5/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		1/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
5	21	5/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1884			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		1/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
6	21	5/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1885			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		1/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
7	21	5/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1886			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		5/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		1/29/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of HUNGRY HORSE

Location: BOBS GENERAL STORE
8930 US HIGHWAY 2 E
HUNGRY HORSE, MT 59919 FLATHEAD

Contact: Jeff Johnson, (406) 387-5504

Sys Fac ID: 15-07506
Last Inspected On: 3/5/2015
Operating Permit Renewal Date: 3/24/2018

Owners/Operators: Swiss Chalet Rentals, Owner (406)-387-5504 PO BOX 190010
HUNGRY HORSE MT 59919-0010

Robert Johnson, UST Class A Operator
Robert Johnson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	36	9/1/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4180			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		2/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		2/25/2015	TS-1001 , Incon		
2	36	9/1/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4181			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		2/25/2015	TS-1001 , Incon		
3	36	9/1/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4182			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		2/25/2015	TS-1001 , Incon		
4	36	9/1/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4183			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		2/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		2/25/2015	TS-1001 , Incon		

Facility Summary in FLATHEAD County in the City of HUNGRY HORSE

Location: CENEX ZIP TRIP #71
8840 US HIGHWAY 2 E
HUNGRY HORSE, MT 59919 FLATHEAD

Contact: Sean Hurley, (509) 535-7701

Sys Fac ID: 15-09708
Last Inspected On: 5/8/2014
Operating Permit Renewal Date: 7/31/2017

Owners/Operators: CHS Inc - Spokane Valley, Owner/Operator (509)-535-7701 16124 E MARIETTA LANE SPOKANE WA 99213

Sean Hurley, UST Class A Operator
Ronald May, UST Class A Operator
Michael W Robinson, UST Class A Operator
Joe Stenzel, UST Class A Operator
Andrew Duffie, UST Class B Operator
Justin Mace, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	28	5/2/1988	Cathodically Protected Steel	Steel	High Level Alarm
3239			None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/18/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	28	5/2/1988	Cathodically Protected Steel	Steel	High Level Alarm
3240			None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/18/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	28	5/2/1988	Cathodically Protected Steel	Steel	High Level Alarm
3241			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/18/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		3/19/2015	TLS-350/Gilbarco EMC , Veeder Root		
4	28	5/2/1988	Cathodically Protected Steel	Steel	High Level Alarm
3242			None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		6/18/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/29/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: FLATHEAD ELECTRIC COOP KALISPELL
2510 US HIGHWAY 2 E
KALISPELL, MT 59901 FLATHEAD

Contact: Terry Tintzman, (406) 752-4483

Sys Fac ID: 15-00044
Last Inspected On: 4/8/2014
Operating Permit Renewal Date: 8/8/2017

Owners/Operators: Flathead Electric Coop, Owner (406)-751-4483 2510 US HIGHWAY 2 E
KALISPELL MT 59901-2397

Brenda Butler, UST Class A Operator
Terry Tintzman, UST Class A Operator
Brenda Butler, UST Class B Operator
Brent Senner, UST Class B Operator
Terry Tintzman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	4/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1090			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
5	18	4/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1091			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
6	18	4/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1092			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: EVERGREEN GAS & DELI
2100 US HIGHWAY 2 E
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-00108
Last Inspected On: 11/17/2014
Operating Permit Renewal Date: 12/2/2017

Contact: Aries Enterprises LLC, (803) 522-5352

Owners/Operators: Aries Enterprises LLC, Owner/Operator (406)-890-5047 2100 US HWY 2 E KALISPELL MT 59901

Ramdeep Kaur, UST Class A Operator
Ramdeep Kaur, UST Class B Operator
Ramdeep Kaur, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	6/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3180			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/20/2015			
5	18	6/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3181			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		3/20/2015			

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: KAL'S FOOD STORES #102
1090 N MERIDIAN RD
KALISPELL, MT 59901 FLATHEAD
Contact: (406) 554-4717

Sys Fac ID: 15-00110
Last Inspected On: 1/8/2016
Operating Permit Renewal Date: 3/23/2019

Owners/Operators:

Brar Brothers LLC, Owner	(559)-554-4717	1645 HWY 93 S SUITE K KALISPELL MT 59901
Kals Food Stores Inc, Operator	(559)-554-4717	1645 HWY 93 S SUITE K KALISPELL MT 59901

Kari Barnhouse, UST Class A Operator
Janelle Gentry, UST Class A Operator
Tiaja Hintz, UST Class A Operator
Ronda Mahaffy, UST Class A Operator
Tina Engebritson, UST Class B Operator
Janelle Gentry, UST Class B Operator
Tiaja Hintz, UST Class B Operator
Ronda Mahaffy, UST Class B Operator
Kari Barnhouse, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	19	11/1/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3171			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/7/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/6/2016	Gilbarco EMC Basic , Gilbarco		
5	19	11/1/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3172			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		1/7/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		1/6/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: KAL'S FOOD STORES #102
1090 N MERIDIAN RD
KALISPELL, MT 59901 FLATHEAD
Contact: (406) 554-4717

Sys Fac ID: 15-00110
Last Inspected On: 1/8/2016
Operating Permit Renewal Date: 3/23/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	19	11/1/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3173			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/7/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		1/6/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: APPLEWAY CONOCO
100 N MERIDIAN RD
KALISPELL, MT 59901 FLATHEAD

Contact: James Cunnimgham, (406) 257-1732

Sys Fac ID: 15-00113
Last Inspected On: 3/10/2014
Operating Permit Renewal Date: 4/10/2017

Owners/Operators: Appleway Conoco, Owner (406)-257-1732 100 N MERIDIAN RD KALISPELL MT 59901-3848

Jim Cuningham, UST Class A Operator
Jim Cuningham, UST Class B Operator
Jim Cuningham, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	36	12/31/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3141			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/6/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/6/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	36	12/31/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3142			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/6/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/6/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	36	12/31/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3143			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/6/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/6/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: WOODLAND QUIKSTOP
81 WOODLAND PARK DR
KALISPELL, MT 59901 FLATHEAD

Contact: Scott E Curry, (406) 755-5075

Sys Fac ID: 15-00115
Last Inspected On: 10/3/2016
Operating Permit Renewal Date: 12/6/2019

Owners/Operators: Scott E Curry, Owner (406)-755-5075 PO BOX 323
KALISPELL MT 59903-0323

Scott E Curry, UST Class A Operator
Scott E Curry, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	18	7/23/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3524			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
4	18	7/23/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3525			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: KALISPELL REGIONAL MEDICAL CENTER
325 CLAREMONT ST
KALISPELL, MT 59901 FLATHEAD

Contact: Mark Chitwood, (406) 756-3695

Sys Fac ID: 15-00800
Last Inspected On: 9/26/2016
Operating Permit Renewal Date: 9/29/2019

Owners/Operators: Northwest Healthcare, Owner (406)-752-5111 ATTN MARK CHITWOOD AT PLANT OPERATIONS
310 SUNNYVIEW LN
KALISPELL MT 59901-3129

Mark Chitwood, UST Class A Operator
Steve Herman, UST Class A Operator
Kyle Hovey, UST Class A Operator
Steve Herman, UST Class B Operator
Kyle Hovey, UST Class B Operator
Mark Chitwood, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	11/6/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1465			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Jet Fuel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		8/31/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CONOCO CAR CARE CENTER
292 3RD AVENUE EAST N
KALISPELL, MT 59901 FLATHEAD
Contact: Lynn Tripp, (406) 755-3797

Sys Fac ID: 15-01677
Last Inspected On: 10/24/2014
Operating Permit Renewal Date: 12/12/2017

Owners/Operators: Valcon Distributing LTD, Owner (406)-755-6611 PO BOX 9200 KALISPELL MT 59904-2200

Shawn Norby, UST Class A Operator
Kary Tonjum, UST Class A Operator
Shawn Norby, UST Class B Operator
Kary Tonjum, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	30	4/23/1986	Cathodically Protected Steel	No Piping	High Level Alarm
2202			None	None	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Waste Oil		3/30/2012	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
1,000		4/25/2012	TLS-350/Gilbarco EMC , Veeder Root		
8	40	4/23/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2201			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		9/24/2012	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		10/23/2014	TLS-350/Gilbarco EMC , Veeder Root		
9	45	4/24/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2199			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/24/2012	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		10/23/2014	TLS-350/Gilbarco EMC , Veeder Root		
10	45	4/24/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2200			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/24/2012	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		10/23/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CITY SERVICE VALCON LLC
52 5TH AVENUE WEST N
KALISPELL, MT 59901 FLATHEAD

Contact: Kary Tonjum, (406) 755-4321

Sys Fac ID: 15-01680
Last Inspected On: 9/19/2016
Operating Permit Renewal Date: 11/1/2019

Owners/Operators: City Service Valcon LLC, Owner (406)-294-0865 640 W MONTANA ST KALISPELL MT 59904

Drew Pike, UST Class A Operator
Drew Pike, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	18	11/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3689			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
25,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
10	18	11/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3690			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
25,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
11	18	11/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3691			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
12	18	11/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3692			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CITY SERVICE VALCON LLC
52 5TH AVENUE WEST N
KALISPELL, MT 59901 FLATHEAD
Contact: Kary Tonjum, (406) 755-4321

Sys Fac ID: 15-01680
Last Inspected On: 9/19/2016
Operating Permit Renewal Date: 11/1/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
13	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3693			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Heating Oil			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: KALS FOOD STORES #101
1645 US HIGHWAY 93 S
KALISPELL, MT 59901 FLATHEAD

Contact: Kal Brar, (559) 554-4717

Sys Fac ID: 15-02014
Last Inspected On: 12/17/2015
Operating Permit Renewal Date: 2/13/2019

Owners/Operators:

Brar Brothers LLC, Owner	(559)-554-4717	1645 HWY 93 S SUITE K KALISPELL MT 59901
Kals Food Stores Inc, Operator	(559)-554-4717	1645 HWY 93 S SUITE K KALISPELL MT 59901

Kari Barnhouse, UST Class A Operator
Michael Hayes, UST Class A Operator
Ronda Mahaffy, UST Class A Operator
Ashley Anderson, UST Class B Operator
Stu Brickey, UST Class B Operator
Jimmy Bromgard, UST Class B Operator
Laura Cummings, UST Class B Operator
GORDON GUTHRIE, UST Class B Operator
Tiffany Howard, UST Class B Operator
Karen McLellan, UST Class B Operator
Alice Reeves, UST Class B Operator
ERICKA SCHAARSCHMIDT, UST Class B Operator
SHAWN SCHMIDT, UST Class B Operator
Tinisha Sederlin, UST Class B Operator
Tazarae Smith, UST Class B Operator
Jenny Tuck, UST Class B Operator
Jennifer Watt, UST Class B Operator
Cari Webb, UST Class B Operator
Kari Barnhouse, UST Class B Global Operator
Ashley Bloomfield, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: KALS FOOD STORES #101
1645 US HIGHWAY 93 S
KALISPELL, MT 59901 FLATHEAD
Contact: Kal Brar, (559) 554-4717

Sys Fac ID: 15-02014
Last Inspected On: 12/17/2015
Operating Permit Renewal Date: 2/13/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
11	19	5/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
650			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
12	19	5/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
651			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
13	19	5/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
652			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
14	19	5/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
653			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: MICHAELS EXXON
1011 US HIGHWAY 2 W
KALISPELL, MT 59901 FLATHEAD
Contact: Michael Hayes, (406) 755-4075

Sys Fac ID: 15-02330
Last Inspected On: 1/26/2015
Operating Permit Renewal Date: 3/31/2018

Owners/Operators: Beargrass Holdings LLC, Owner (406)-752-5250 PO BOX 7505
KALISPELL MT 59904-0505

Michael Hayes, UST Class A Operator
Tiffany Howard, UST Class A Operator
Ashley Anderson, UST Class B Operator
Stu Brickey, UST Class B Operator
Jimmy Bromgard, UST Class B Operator
Laura Cummings, UST Class B Operator
Nicole Ferrari, UST Class B Operator
GORDON GUTHRIE, UST Class B Operator
Tiffany Howard, UST Class B Operator
Alice Reeves, UST Class B Operator
ERICKA SCHAARSCHMIDT, UST Class B Operator
SHAWN SCHMIDT, UST Class B Operator
Tinisha Sederlin, UST Class B Operator
Tazarae Smith, UST Class B Operator
Jenny Tuck, UST Class B Operator
Jennifer Watt, UST Class B Operator
Cari Webb, UST Class B Operator
Ashley Bloomfield, UST Class B Global Operator
Sherry Doyle, UST Class B Global Operator
Nicole Ferrari, UST Class B Global Operator
Tiffany Howard, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
15	23	12/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
654			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: MICHAELS EXXON
1011 US HIGHWAY 2 W
KALISPELL, MT 59901 FLATHEAD
Contact: Michael Hayes, (406) 755-4075

Sys Fac ID: 15-02330
Last Inspected On: 1/26/2015
Operating Permit Renewal Date: 3/31/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
16	23	12/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
655			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
17	23	12/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
656			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		3/12/2015	TLS-350/Gilbarco EMC , Veeder Root		
18	23	4/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
657			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
19	23	4/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
658			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
20	23	4/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
659			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: MICHAELS EXXON
1011 US HIGHWAY 2 W
KALISPELL, MT 59901 FLATHEAD

Contact: Michael Hayes, (406) 755-4075

Sys Fac ID: 15-02330
Last Inspected On: 1/26/2015
Operating Permit Renewal Date: 3/31/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
21	23	6/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
660			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: ZIP TRIP 40
1420 1ST AVE E
KALISPELL, MT 59901 FLATHEAD
Contact: (406) 755-5713

Sys Fac ID: 15-02331
Last Inspected On: 11/22/2016
Operating Permit Renewal Date: 3/14/2020

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Tom Savas, UST Class A Operator
Andrew Duffie, UST Class B Operator
Justin Mace, UST Class B Operator
Luci Tuttle, UST Class B Operator
Alex Henson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	34	4/30/1982	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1303			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/16/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	34	4/30/1982	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1304			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/16/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	34	4/30/1982	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1305			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/16/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: DIAMOND AIRE LLC LEASEE
1893 AIRPORT RD
KALISPELL, MT 59901 FLATHEAD
Contact: (406) 752-5092

Sys Fac ID: 15-03172
Last Inspected On: 10/23/2013
Operating Permit Renewal Date: 12/20/2016

Owners/Operators: Montana Diamond Aire Inc, Owner (406)-752-5092 1893 AIRPORT RD KALISPELL MT 59901-7501
John Talmage, UST Class A Operator
John Talmage, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	21	5/24/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3285		10/23/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					
8	21	5/24/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3286		10/23/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: ZIP TRIP 39
305 E IDAHO ST
KALISPELL, MT 59901 FLATHEAD

Contact: Jan Robison, (406) 755-3664

Sys Fac ID: 15-03915
Last Inspected On: 11/13/2015
Operating Permit Renewal Date: 3/30/2019

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Pete Nussbaum, UST Class A Operator
Tom Savas, UST Class A Operator
Andrew Duffie, UST Class B Operator
Justin Mace, UST Class B Operator
Luci Tuttle, UST Class B Operator
Ian Johnstone, UST Class B Global Operator
Pete Nussbaum, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	10/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
1306			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
5	18	10/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
1307			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: ZIP TRIP 39
305 E IDAHO ST
KALISPELL, MT 59901 FLATHEAD

Contact: Jan Robison, (406) 755-3664

Sys Fac ID: 15-03915
Last Inspected On: 11/13/2015
Operating Permit Renewal Date: 3/30/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	18	10/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
1308			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
7	18	10/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
1309			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: RMC KALISPELL SHOP
2214 US HIGHWAY 2 E
KALISPELL, MT 59901 FLATHEAD

Contact: Dave Stremel, (406) 752-4280

Sys Fac ID: 15-04359
Last Inspected On: 4/15/2014
Operating Permit Renewal Date: 9/3/2017

Owners/Operators: Rocky Mountain Contractors Inc, Owner (406)-752-4280 2214 US HIGHWAY 2 E KALISPELL MT 59901-2816

Leona Prezeau, UST Class A Operator
Marvin Stone, UST Class A Operator
David Stremel, UST Class A Operator
Leona Prezeau, UST Class B Operator
Marvin Stone, UST Class B Operator
David Stremel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	22	1/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1284			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
12,000			Auto Stik II , EBW		
4	22	1/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1285			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
12,000			Auto Stik II , EBW		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: UNITED PARCEL SERVICES KALISPELL
1151 N MERIDIAN RD
KALISPELL, MT 59901 FLATHEAD
Contact: Dino Ostow, (503) 978-7678

Sys Fac ID: 15-04535
Last Inspected On: 8/1/2016
Operating Permit Renewal Date: 10/11/2019

Owners/Operators:

United Parcel Service, Inc, Owner	(503)-978-7678	6707 N BASIN AVE PORTLAND OR 97217
United Parcel Service Plant Engineering Dept, Operator	(206)-621-6261	4455 7TH AVE S SEATTLE WA 98108

Teri Burrows, UST Class A Operator
Robert Counts, UST Class A Operator
Dino Ostrow, UST Class A Operator
Treair Smith, UST Class A Operator
Russell Stott, UST Class A Operator
Paul Vandehey, UST Class A Operator
Teri Burrows, UST Class B Operator
Robert Counts, UST Class B Operator
Dino Ostrow, UST Class B Operator
Russell Stott, UST Class B Operator
Treair Smith, UST Class B Global Operator
Paul Vandehey, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	23	8/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2180			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
12,000		7/27/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CLASSICAL GAS CHICKEN NOODLE
343 S MAIN ST
KALISPELL, MT 59901 FLATHEAD

Sys Fac ID: 15-04894
Last Inspected On: 10/17/2016
Operating Permit Renewal Date:

Contact: Margret Rowe, (949) 887-0254

Owners/Operators: Brenda Rowe, Owner (714)-642-5001 23271 VIA PARDAL TRABUCO CANYON CA 92679

Lisa Shriver, UST Class A Operator
Lisa Shriver, UST Class B Operator
Lisa Shriver, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	21	9/14/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
438			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/17/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000			TS-1000 , Incon		
4	21	9/14/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
439			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/17/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000			TS-1000 , Incon		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CHS - WEST
120 W IDAHO ST
KALISPELL, MT 59901 FLATHEAD

Contact: Ken Sederdahl, (406) 755-7400

Sys Fac ID: 15-05069
Last Inspected On: 8/26/2014
Operating Permit Renewal Date: 1/14/2018

Owners/Operators:

CHS Inc - Kalispell, Owner	(406)-755-7400	PO BOX 579 KALISPELL MT 59903
Ken Sederdahl, Operator	(406)-755-7400	PO BOX 579 KALISPELL MT 59903
Victor Hannam, UST Class A Operator		
Victor Hannam, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	3/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
868			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		8/25/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000		9/8/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	
2	20	3/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
866			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/25/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		9/9/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	
3	20	3/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
867			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/25/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		9/9/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: Warden Hutterian Brethren
295 MIDDLE RD
KALISPELL, MT 59901 FLATHEAD

Contact: Steve Streich, (406) 253-2276

Sys Fac ID: 15-05344
Last Inspected On: 12/1/2015
Operating Permit Renewal Date: 2/12/2019

Owners/Operators: Warden Hutterian Brethren, Owner (406)-253-2276 1054 W HARDER RD WARDEN WA 98857

Steve Streich, UST Class A Operator
Steve Streich, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	11/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
870			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		11/19/2015	Manual Tank Gauging	Deferred	
1,000					
2	21	11/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
869			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/19/2015	Manual Tank Gauging	Deferred	
1,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: WOODYS COUNTRY STORE INC
3333 MT HIGHWAY 35
KALISPELL, MT 59901 FLATHEAD

Contact: Chuck Weis, (406) 755-5544

Sys Fac ID: 15-05801
Last Inspected On: 2/19/2015
Operating Permit Renewal Date: 3/17/2018

Owners/Operators: Woodys Country Store Inc, Owner (406)-755-5544 3333 MT HIGHWAY 35 KALISPELL MT 59901-7724

Charles Weiss, UST Class A Operator
Charles Weiss, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	12/5/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2243			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			EECO 1500 , EMCO Electronics		
2	31	12/5/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2244			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			EECO 1500 , EMCO Electronics		
3	31	12/5/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2245			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		1/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		1/4/2012	EECO 1500 , EMCO Electronics		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: KELLY RAES INC
25 BATAVIA LN
KALISPELL, MT 59901 FLATHEAD
Contact: Jim Long, (406) 752-5880

Sys Fac ID: 15-06101
Last Inspected On: 8/22/2016
Operating Permit Renewal Date: 10/26/2019

Owners/Operators: Tab Young, Owner (406)-752-5880 25 BATAVIA LN KALISPELL MT 59901-7280

Dawn Brown, UST Class A Operator
Lisa Myers, UST Class A Operator
Marcie Riley, UST Class A Operator
Tab Young, UST Class A Operator
Dawn Brown, UST Class B Operator
Stephanie Brussels, UST Class B Operator
Tish Keck, UST Class B Operator
Lisa Meyers, UST Class B Operator
Lisa Myers, UST Class B Operator
Connie Parker, UST Class B Operator
Kayla Weisz, UST Class B Operator
Mona Woodruff, UST Class B Operator
Dawn Brown, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	2/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4505			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		8/16/2016	Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
6,000		8/16/2016			
4	51	1/1/1965	Bare Steel	Fiberglass Reinforced Plastic	
4506	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/3/2013	Deferred	MLLD Line Tightness Testing	
10,000		8/16/2016			

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: KELLY RAES INC
25 BATAVIA LN
KALISPELL, MT 59901 FLATHEAD

Contact: Jim Long, (406) 752-5880

Sys Fac ID: 15-06101
Last Inspected On: 8/22/2016
Operating Permit Renewal Date: 10/26/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	51	1/1/1965	Bare Steel	Fiberglass Reinforced Plastic	
4507	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/3/2013	Deferred	MLLD Line Tightness Testing	
8,000		8/16/2016			

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: FLATHEAD COUNTY ROAD DEPT
1249 WILLOW GLEN DR
KALISPELL, MT 59901 FLATHEAD

Contact: Ted Gilbertson, (406) 758-5790

Sys Fac ID: 15-06286
Last Inspected On: 8/24/2016
Operating Permit Renewal Date: 11/18/2019

Owners/Operators: Flathead County Commissioners, Owner (406)-758-5790 800 S MAIN ST KALISPELL MT 59901-5435

Corey Pilsch, UST Class A Operator
Corey Pilsch, UST Class B Operator

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
8	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1088		12/19/2013	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
9	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1089		12/19/2013	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
3,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: ZIP TRIP 41
2490 US HIGHWAY 93 N
KALISPELL, MT 59901 FLATHEAD
Contact: Stephen Golleher, (406) 752-7555

Sys Fac ID: 15-07432
Last Inspected On: 9/2/2016
Operating Permit Renewal Date: 11/9/2019

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Sean Hurley, UST Class A Operator
Andrew Duffie, UST Class B Operator
Justin Mace, UST Class B Operator
Luci Tuttle, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	4/23/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
382			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/29/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/11/2016	TLS-300 , Veeder Root		
2	31	4/23/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
383			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/29/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/11/2016	TLS-300 , Veeder Root		
3	14	6/21/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4685			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/29/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/11/2016	TLS-300 , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: LANES FOOD AND FUEL
1454 MT HIGHWAY 35
KALISPELL, MT 59901 FLATHEAD
Contact: (406) 752-4962

Sys Fac ID: 15-08357
Last Inspected On: 6/12/2014
Operating Permit Renewal Date: 8/20/2017

Owners/Operators: Lanes Enterprises LLC, Owner (406)-756-0399 903 CONRAD DR KALISPELL MT 59901-7802
Stephen Symington, UST Class A Operator
Stephen Symington, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	34	5/8/1982	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
1420			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/24/2014			
2	34	5/8/1982	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
1421			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/24/2014			

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: TOWN PUMP INC KALISPELL 1
445 W IDAHO ST
KALISPELL, MT 59901 FLATHEAD

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 15-08709
Last Inspected On: 1/19/2016
Operating Permit Renewal Date: 4/21/2019

Owners/Operators: Town Pump Inc Butte, Owner (406)-782-9121 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	34	4/14/1982	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4679			Impressed Current	Double-Walled	Yes
Currently in Use		6/13/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/13/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
2	34	4/14/1982	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2425			Impressed Current	None	Yes
Currently in Use		6/13/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/13/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
6	19	5/28/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff, Ball Float Valve
2426			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/13/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: TOWN PUMP INC KALISPELL 1
445 W IDAHO ST
KALISPELL, MT 59901 FLATHEAD

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 15-08709
Last Inspected On: 1/19/2016
Operating Permit Renewal Date: 4/21/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	19	5/28/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4680			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/13/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
8	12	8/18/2004	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4939			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/13/2016	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: MDOT KALISPELL
85 5TH AVENUE EAST N
KALISPELL, MT 59901 FLATHEAD
Contact: Joe Radonich, (406) 444-9204

Sys Fac ID: 15-08733
Last Inspected On: 5/4/2016
Operating Permit Renewal Date: 10/26/2019

Owners/Operators:

MDOT Helena, Owner	(406)-444-6200	KIM JANZEN PO BOX 201001 HELENA MT 59620-1001
Joseph J Radonich, Operator	(406)-444-9204	MDT DEADHEAD HELENA MT 59620-0901

Jeff Gleason, UST Class A Operator
Walt Kerttula, UST Class A Operator
Mike Murolo, UST Class A Operator
Joe Radonich, UST Class A Operator
Paul Eggum, UST Class B Operator
Andrea Wyman, UST Class B Operator
Chance Guckenberg, UST Class B Global Operator
Joe Radonich, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	24	12/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2892			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
10,000			Gilbarco EMC Basic , Gilbarco		
4	24	12/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2893			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Deferred	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: FLATHEAD COUNTY JUSTICE CENTER
920 S MAIN ST
KALISPELL, MT 59901 FLATHEAD

Contact: Alan Marble, (406) 758-5561

Sys Fac ID: 15-09279
Last Inspected On: 10/17/2016
Operating Permit Renewal Date: 3/16/2020

Owners/Operators: Flathead County Commissioners, Owner (406)-758-5790 800 S MAIN ST KALISPELL MT 59901-5435

Michael Hovila, UST Class A Operator
Don Mills, UST Class A Operator
Michael Hovila, UST Class B Operator
Don Mills, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	3/11/1987	Cathodically Protected Steel	No Piping	Flapper Valve (Auto Shutoff)
3810		10/4/2016	None	None	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Diesel		10/6/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CHS - CENTRAL
55 4TH AVENUE EAST N
KALISPELL, MT 59901 FLATHEAD

Contact: Ken Sederdahl, (406) 755-7400

Sys Fac ID: 15-09705
Last Inspected On: 10/9/2014
Operating Permit Renewal Date: 3/9/2018

Owners/Operators:

CHS Inc - Kalispell, Owner	(406)-755-7400	PO BOX 579 KALISPELL MT 59903
Ken Sederdahl, Operator	(406)-755-7400	PO BOX 579 KALISPELL MT 59903

Victor Hannam, UST Class A Operator
Victor Hannam, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	35	3/26/1981	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3786			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		8/14/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
20,000		9/17/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	
2	35	3/26/1981	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3787			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/14/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
20,000		9/17/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	
3	35	3/26/1981	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3788			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		8/14/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
20,000		9/17/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	
8	17	3/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4075			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		9/17/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CHS - CENTRAL
55 4TH AVENUE EAST N
KALISPELL, MT 59901 FLATHEAD
Contact: Ken Sederdahl, (406) 755-7400

Sys Fac ID: 15-09705
Last Inspected On: 10/9/2014
Operating Permit Renewal Date: 3/9/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	17	3/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4076			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000		9/17/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: MICHEALS EAST
1278 US HIGHWAY 2 E
KALISPELL, MT 59901 FLATHEAD
Contact: Michael Hays, (406) 752-6299

Sys Fac ID: 15-09707
Last Inspected On: 5/27/2014
Operating Permit Renewal Date: 9/4/2017

Owners/Operators: Michaels East Inc, Owner/Operator (406)-752-6299 1278 HWY 2 EAST KALISPELL MT 59901
Tiffany Howard, UST Class A Operator
Tiffany Howard, UST Class B Operator
Sherry Doyle, UST Class B Global Operator
Tiffany Howard, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	6/1/1985	Cathodically Protected Steel	Steel	Ball Float Valve
3005			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
12,000			TLS-350/Gilbarco EMC , Veeder Root		
2	31	6/1/1985	Cathodically Protected Steel	Steel	Ball Float Valve
3006			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
12,000			TLS-350/Gilbarco EMC , Veeder Root		
3	31	6/1/1985	Cathodically Protected Steel	Steel	Ball Float Valve
3007			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
10,000			TLS-350/Gilbarco EMC , Veeder Root		
4	31	6/1/1985	Cathodically Protected Steel	Steel	Ball Float Valve
3008			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: BRIANS INC
1319 US HIGHWAY 93 S
KALISPELL, MT 59901 FLATHEAD

Contact: Brian Kahler, (406) 755-7447

Sys Fac ID: 15-09820
Last Inspected On: 5/28/2014
Operating Permit Renewal Date: 6/28/2017

Owners/Operators: DJL LLC, Owner (406)-755-7447 PO BOX 9200
KALISPELL MT 59904-2200

Brian Kahler, UST Class A Operator
Brian Kahler, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	9/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1847			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		5/27/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
15,000		5/27/2014	TS-1000 , Incon		
2	21	9/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1848			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/27/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
15,000		5/27/2014	TS-1000 , Incon		
3	21	9/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1849			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/27/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
7,500		5/27/2014	TS-1000 , Incon		
4	21	9/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1850			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		5/27/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
7,500		5/27/2014	TS-1000 , Incon		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: WEST VALLEY SCHOOL DIST 1
2290 FARM TO MARKET RD
KALISPELL, MT 59901 FLATHEAD

Contact: Todd A Fisk, (406) 755-7239

Sys Fac ID: 15-10295
Last Inspected On: 12/29/2014
Operating Permit Renewal Date: 12/31/2017

Owners/Operators: School Dist 1 West Valley, Owner (406)-755-7239 2290 FARM TO MARKET RD KALISPELL MT 59901-7108

Phillip Jackson, UST Class A Operator
Phillip Jackson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	21	8/9/1995	Fiberglass Reinforced Plastic	Copper	Flapper Valve (Auto Shutoff)
2249		7/23/2015	None	Secondary Containment Chase	Yes
Temporarily Out of Use			Not Required	U.S. Suction	Not Applicable
Heating Oil			Manual Tank Gauging	Not Listed	
1,000					

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: RED EAGLE AVIATION INC
1880 US HIGHWAY 93 S
KALISPELL, MT 59901 FLATHEAD
Contact: Mike Strand, (406) 755-2376

Sys Fac ID: 15-11166
Last Inspected On: 10/24/2014
Operating Permit Renewal Date: 3/24/2018

Owners/Operators: Red Eagle Aviation Inc, Owner (406)-755-2376 1880 US HWY 93 S
KALISPELL MT 59901-5729
Paige Pitz, UST Class A Operator
Paige Pitz, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	35	1/1/1981	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
4173			Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Aviation Gas		10/23/2014	Automatic Tank Gauging 0.2	Deferred	
12,000		11/28/2011	TS-1000 , Incon		
3	35	1/1/1981	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
4144			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Aviation Gas		10/23/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		10/23/2014	TS-1000 , Incon		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: WHITE OAK MARKET INC
4810 US HIGHWAY 93 S
KALISPELL, MT 59901 FLATHEAD

Contact: Howard Brearey, (406) 857-2344

Sys Fac ID: 15-13287
Last Inspected On: 8/25/2014
Operating Permit Renewal Date: 10/17/2017

Owners/Operators: White Oak of Montana LLC, Owner (406)-857-2344 4810 US HIGHWAY 93 S KALISPELL MT 59901-7985

Amber Terrell, UST Class A Operator
Wendy Works, UST Class A Operator
Wendy Works, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	33	10/1/1983	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4481			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/27/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	33	11/1/1983	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4482			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/27/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	33	11/1/1983	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4483			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		5/27/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: ARIES GAS AND GROCERY
7254 US HIGHWAY 93
KALISPELL, MT 59922 FLATHEAD

Contact: Ramdeep Kaur, (406) 890-5047

Sys Fac ID: 15-13487
Last Inspected On: 11/15/2016
Operating Permit Renewal Date: 12/6/2019

Owners/Operators:

RKR LLC, Owner	(406)-890-5047	2100 US HWY 2 E KALISPELL MT 59901
Aries Enterprises LLC, Operator	(406)-890-5047	2100 US HWY 2 E KALISPELL MT 59901

Janet Heinze, UST Class A Operator
Steven Heinze, UST Class A Operator
Ramdeep Kaur, UST Class A Operator
Rod Phillips, UST Class A Operator
Janet Heinze, UST Class B Operator
Rod Phillips, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
669			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		11/11/2016	TS-2000 , Incon		
2	22	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
667			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		11/11/2016	TS-2000 , Incon		
3	22	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
668			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
7,000		11/11/2016	TS-2000 , Incon		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: ARIES GAS AND GROCERY
7254 US HIGHWAY 93
KALISPELL, MT 59922 FLATHEAD
Contact: Ramdeep Kaur, (406) 890-5047

Sys Fac ID: 15-13487
Last Inspected On: 11/15/2016
Operating Permit Renewal Date: 12/6/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	22	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
666			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		11/11/2016	TS-2000 , Incon		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: BRIANS C STORE
2075 US HIGHWAY 2 E
KALISPELL, MT 59901 FLATHEAD
Contact: Brian Kahler, (406) 755-7447

Sys Fac ID: 15-13730
Last Inspected On: 11/14/2014
Operating Permit Renewal Date: 1/14/2018

Owners/Operators: DJL LLC, Owner (406)-755-7447 PO BOX 9200
KALISPELL MT 59904-2200

Brian Kahler, UST Class A Operator
Brian Kahler, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	6/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3353			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		9/10/2014		Continuous Interstitial Monitor	
2	20	6/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3354			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		9/10/2014		Continuous Interstitial Monitor	
3	20	6/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3357			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		9/10/2014		Continuous Interstitial Monitor	
4	20	6/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3355			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		9/10/2014		Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: BRIANS C STORE
2075 US HIGHWAY 2 E
KALISPELL, MT 59901 FLATHEAD
Contact: Brian Kahler, (406) 755-7447

Sys Fac ID: 15-13730
Last Inspected On: 11/14/2014
Operating Permit Renewal Date: 1/14/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	20	6/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3356			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		9/10/2014		Continuous Interstitial Monitor	
6	20	6/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3352			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		9/10/2014		Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: TOWN PUMP INC KALISPELL 3
2605 US HIGHWAY 2 E
KALISPELL, MT 59901 FLATHEAD

Contact: Doug Dodge, (406) 755-1306

Sys Fac ID: 15-13732
Last Inspected On: 1/15/2016
Operating Permit Renewal Date: 5/7/2019

Owners/Operators:

Kalispell Holdings LLC, Owner	(406)-497-6700	PO BOX 6000 BUTTE MT 59702-6000
Kalispell Holdings LLC, Operator	(406)-497-6700	PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4766		7/20/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	20	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4767		7/20/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: TOWN PUMP INC KALISPELL 3
2605 US HIGHWAY 2 E
KALISPELL, MT 59901 FLATHEAD

Contact: Doug Dodge, (406) 755-1306

Sys Fac ID: 15-13732
Last Inspected On: 1/15/2016
Operating Permit Renewal Date: 5/7/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
3	20	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4768		7/20/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	20	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4769		7/20/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	20	7/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4770		7/20/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: TOWN PUMP INC KALISPELL 2
1100 E IDAHO ST
KALISPELL, MT 59901 FLATHEAD

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 15-13764
Last Inspected On: 1/18/2016
Operating Permit Renewal Date: 4/21/2019

Owners/Operators: Kalispell Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	4/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4814			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	19	4/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4815			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	19	4/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4816			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: TOWN PUMP INC KALISPELL 2
1100 E IDAHO ST
KALISPELL, MT 59901 FLATHEAD
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 15-13764
Last Inspected On: 1/18/2016
Operating Permit Renewal Date: 4/21/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	19	4/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
4817			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	19	4/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4818			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: TOWN PUMP INC KALISPELL 5
2910 US HIGHWAY 93 S
KALISPELL, MT 59901 FLATHEAD

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 15-13765
Last Inspected On: 9/29/2015
Operating Permit Renewal Date: 1/7/2019

Owners/Operators: Main Street Holdings LLC, Owner (406)-497-6700 600 S MAIN ST BUTTE MT 59701-2534

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3430			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	
2	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3431			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	
3	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3432			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CITY SERVICE BULK PLANT
1841 3RD AVE E
KALISPELL, MT 59901 FLATHEAD
Contact: Kary Tonjum, (406) 755-4321

Sys Fac ID: 56-13824
Last Inspected On: 9/19/2016
Operating Permit Renewal Date: 12/24/2019

Owners/Operators: City Service Inc, Owner (406)-755-4321 640 W MONTANA
KALISPELL MT 59901-5775

Margaret Flynn, UST Class A Operator
Drew Pike, UST Class A Operator
Kary Tonjum, UST Class A Operator
Margaret Flynn, UST Class B Operator
Drew Pike, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	8/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
681			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	19	8/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
682			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	19	8/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
683			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: CITY SERVICE BULK PLANT
1841 3RD AVE E
KALISPELL, MT 59901 FLATHEAD

Contact: Kary Tonjum, (406) 755-4321

Sys Fac ID: 56-13824
Last Inspected On: 9/19/2016
Operating Permit Renewal Date: 12/24/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	19	8/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
684			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	19	8/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
685			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: HOLIDAY #722
840 W IDAHO ST
KALISPELL, MT 59901 FLATHEAD
Contact: (952) 830-8899

Sys Fac ID: 56-13985
Last Inspected On: 11/4/2015
Operating Permit Renewal Date: 3/30/2019

Owners/Operators: Rocky Mountain Oil Inc, Owner (952)-830-8700 ATTN: ENVIRONMENTAL DIRECTOR
4567 AMERICAN BLVD W
BLOOMINGTON MN 55437

Holiday #722, Operator (952)-830-8747 840 W IDAHO ST
KALISPELL MT 59901

Jason Cocke, UST Class A Operator
Robert Deninno, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Jeffrey Brown, UST Class B Operator
Jason Cocke, UST Class B Operator
John Collins, UST Class B Operator
Jason Cocke, UST Class B Global Operator
Mathew McConaughey, UST Class B Global Operator
Todd White, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	16	10/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4239			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		7/6/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	16	10/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4240			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		7/6/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: EAGLE FUELS LLC
3150 US HIGHWAY 2
KALISPELL, MT 59901 FLATHEAD
Contact: Wayne Morgan, (406) 862-5422

Sys Fac ID: 56-14014
Last Inspected On: 9/26/2016
Operating Permit Renewal Date: 12/31/2019

Owners/Operators: Eagle Fuels LLC, Owner (406)-862-5422 1079 HODGSON RD
COLUMBIA FALLS MT 59912-9027

Kary Tonjum, UST Class A Operator
Kary Tonjum, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	15	7/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4605			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	15	7/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4606			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	15	7/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4607			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	15	7/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4608			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: FLATHEAD COUNTY SOLID WASTE DIST
4098 US HIGHWAY 93 N
KALISPELL, MT 59901 FLATHEAD
Contact: (406) 758-5918

Sys Fac ID: 56-14041
Last Inspected On: 8/24/2016
Operating Permit Renewal Date: 12/26/2019

Owners/Operators: Flathead County Commissioners, Owner (406)-758-5790 800 S MAIN ST KALISPELL MT 59901-5435
James Chilton, UST Class A Operator
James Chilton, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	15	11/26/2001	Fiberglass Reinforced Plastic	No Piping	Ball Float Valve
4559		8/24/2016	Double-Walled	None	Yes
Currently in Use			Not Required	Not Listed	Not Applicable
Waste Oil			Continuous Interstitial Monitor	Manual Interstitial Monitor	
1,000			ILS-350 , Veeder Root		
2	13	2/25/2003	Concrete	Flexible Plastic	High Level Alarm
4802	Yes	8/24/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
15,000			ILS-350 , Veeder Root		
3	13	2/25/2003	Concrete	Flexible Plastic	High Level Alarm
4803	Yes	8/24/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
3,000			ILS-350 , Veeder Root		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: SMITHS FUEL CENTER 172
195 3RD AVENUE WEST N
KALISPELL, MT 59901 FLATHEAD
Contact: (406) 752-5705

Sys Fac ID: 56-14062
Last Inspected On: 6/9/2014
Operating Permit Renewal Date: 11/4/2017

Owners/Operators: Smiths Food and Drug, Owner (801)-974-1529 1550 S REDWOOD RD
SALT LAKE CITY UT 84104-5105

Kerry Busey, UST Class A Operator
Michael D Crumley, UST Class A Operator
Gary Dotseth, UST Class A Operator
Todd Dotseth, UST Class A Operator
David Harris, UST Class A Operator
Steven Perkins, UST Class A Operator
Todd Dotseth, UST Class B Operator
Kerry Busey, UST Class B Global Operator
Michael D Crumley, UST Class B Global Operator
Gary Dotseth, UST Class B Global Operator
David Harris, UST Class B Global Operator
Steven Perkins, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	14	8/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4742			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	14	8/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4743			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: SMITHS FUEL CENTER 172
195 3RD AVENUE WEST N
KALISPELL, MT 59901 FLATHEAD
Contact: (406) 752-5705

Sys Fac ID: 56-14062
Last Inspected On: 6/9/2014
Operating Permit Renewal Date: 11/4/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	14	8/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4744			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: HEALTH CENTER NORTHWEST
320 SUNNYVIEW LN
KALISPELL, MT 59901 FLATHEAD
Contact: Mark Chitwood, (406) 756-3695

Sys Fac ID: 56-14072
Last Inspected On: 9/26/2016
Operating Permit Renewal Date: 9/29/2019

Owners/Operators: Flathead Hospital Development Co, Owner (406)-752-5111 ATTN PLANT OPERATIONS
320 SUNNYVIEW LN
KALISPELL MT 59901-3129

Mark Chitwood, UST Class A Operator
Steve Herman, UST Class A Operator
Kyle Hovey, UST Class A Operator
Steve Herman, UST Class B Operator
Kyle Hovey, UST Class B Operator
Mark Chitwood, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	12	12/16/2003	Concrete	Flexible Plastic	
4880	Yes	8/19/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
6,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: COSTCO WHOLESALE
2330 US HIGHWAY 93 N
KALISPELL, MT 59901 FLATHEAD
Contact: (406) 758-2500

Sys Fac ID: 60-15012
Last Inspected On: 6/9/2014
Operating Permit Renewal Date: 11/12/2017

Owners/Operators: Costco Wholesale, Owner (425)-313-8100 ATTN: LICENSING
PO BOX 35005
SEATTLE WA 98124-8990

Dennis Bock, UST Class A Operator
Trevor Eagleton, UST Class A Operator
David Ely, UST Class A Operator
Dan Martinez, UST Class A Operator
Michael Schaeffer, UST Class A Operator
Chuck Shillington, UST Class A Operator
Shawn Slack, UST Class A Operator
Trevor Eagleton, UST Class B Operator
David Ely, UST Class B Operator
Michael Williams, UST Class B Operator
Dennis Bock, UST Class B Global Operator
Michael Schaeffer, UST Class B Global Operator
Chuck Shillington, UST Class B Global Operator
Shawn Slack, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	11	10/7/2005	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5033			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
20,000		5/6/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	11	10/7/2005	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5034			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
20,000		5/6/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: COSTCO WHOLESALE
2330 US HIGHWAY 93 N
KALISPELL, MT 59901 FLATHEAD
Contact: (406) 758-2500

Sys Fac ID: 60-15012
Last Inspected On: 6/9/2014
Operating Permit Renewal Date: 11/12/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	11	10/7/2005	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5035			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
20,000		5/6/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	05	4/19/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5280			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Hazardous Substance			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
1,500		11/15/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: Town Pump Kalispell #7
859 W RESERVE ST
KALISPELL, MT 59901 FLATHEAD
Contact: Osmun Arnold, (406) 497-6700

Sys Fac ID: 60-15262
Last Inspected On: 9/5/2016
Operating Permit Renewal Date: 9/8/2019

Owners/Operators: Town Pump Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-2534

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	01	11/4/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5604		12/3/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation	Yes
30,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring, Not Listed	Yes
2	01	11/4/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5605		12/3/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation	Yes
6,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring, Not Listed	Yes

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: Town Pump Kalispell #7
859 W RESERVE ST
KALISPELL, MT 59901 FLATHEAD
Contact: Osmun Arnold, (406) 497-6700

Sys Fac ID: 60-15262
Last Inspected On: 9/5/2016
Operating Permit Renewal Date: 9/8/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
3	01	11/4/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5606		12/3/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation	Yes
15,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring, Not Listed	Yes
5	01	11/4/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5608		12/3/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation	Yes
6,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring, Not Listed	Yes
6	01	11/4/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5609		12/3/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation	Yes
15,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring, Not Listed	Yes

Facility Summary in FLATHEAD County in the City of KALISPELL

Location: Town Pump Kalispell #7
859 W RESERVE ST
KALISPELL, MT 59901 FLATHEAD

Contact: Osmun Arnold, (406) 497-6700

Sys Fac ID: 60-15262
Last Inspected On: 9/5/2016
Operating Permit Renewal Date: 9/8/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	01	11/4/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5610		12/3/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation	Yes
6,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring, Not Listed	Yes

Facility Summary in FLATHEAD County in the City of LAKESIDE

Location: ARSR GATR BLDG
BLACKTAIL MOUNTAIN RD
LAKESIDE, MT 59922 FLATHEAD

Contact: Larry Conrad, (406) 755-5499

Sys Fac ID: 15-03618
Last Inspected On: 1/28/2015
Operating Permit Renewal Date: 2/19/2018

Owners/Operators: Federal Aviation Admin Missoula, Owner (406)-549-8300 4955 W BROADWAY ST MISSOULA MT 59808-8706

Rob Jodsaas, UST Class A Operator
Rob Jodsaas, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	20	9/25/1996	Unknown	Flexible Plastic	
4565	Yes	12/8/2014	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
2,000			Other , Other		

Facility Summary in FLATHEAD County in the City of LAKESIDE

Location: JOE BLOGZ
7170 US HIGHWAY 93 S
LAKESIDE, MT 59922 FLATHEAD
Contact: Robert Lincoln, (406) 844-3372

Sys Fac ID: 15-10513
Last Inspected On: 12/17/2015
Operating Permit Renewal Date: 2/20/2019

Owners/Operators: Cruiser LLC, Owner/Operator (406)-844-3372 PO BOX 225 LAKESIDE MT 59922
Robert C Lincoln, UST Class A Operator
Robert C Lincoln, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	3/7/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3798			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use		1/1/2008	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/3/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	31	3/7/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3799			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use		1/1/2008	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/3/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of LAKESIDE

Location: DR VAN KIRKE NELSON
616 LUTHERAN CAMP RD
LAKESIDE, MT 59922 FLATHEAD
Contact: (406) 752-5252

Sys Fac ID: 56-14069
Last Inspected On: 10/9/2014
Operating Permit Renewal Date: 2/19/2018

Owners/Operators: Van Kirke Nelson, Owner
PO BOX 1175
KALISPELL MT 59903

Greg Nelson, UST Class A Operator
Van Kirke Nelson, UST Class A Operator
Greg Nelson, UST Class B Operator
Van Kirke Nelson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	13	12/30/2002	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4781		10/9/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Heating Oil			Manual Tank Gauging	Continuous Interstitial Monitor	
800			ILS-350 , Veeder Root		

Facility Summary in FLATHEAD County in the City of MARION

Location: MOOSE CROSSING INC
8405 US HIGHWAY 2 W
MARION, MT 59925 FLATHEAD
Contact: (406) 854-2070

Sys Fac ID: 15-10015
Last Inspected On: 4/20/2016
Operating Permit Renewal Date: 4/28/2019

Owners/Operators: Vern Taber Moose Crossing Inc, Owner (406)-854-2070 8405 US HIGHWAY 2 W MARION MT 59925-9701
Rebecca Taber, UST Class A Operator
Vern Taber, UST Class A Operator
Rebecca Taber, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	19	9/25/1997	Unknown	Flexible Plastic	
1245	Yes	4/19/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
4,000			Gilbarco EMC Basic , Gilbarco		
4	19	9/25/1997	Unknown	Flexible Plastic	
1246	Yes	4/19/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
3,000			Gilbarco EMC Basic , Gilbarco		
5	19	9/25/1997	Unknown	Flexible Plastic	
1247	Yes	4/19/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
1,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in FLATHEAD County in the City of MARION

Location: CANI INC
8205 US HIGHWAY 2 W
MARION, MT 59925 FLATHEAD

Contact: Tonia May, (406) 854-2992

Sys Fac ID: 56-13803
Last Inspected On: 10/7/2016
Operating Permit Renewal Date: 11/6/2019

Owners/Operators: CANI Inc, Owner (406)-854-2992 PO BOX 9633
KALISPELL MT 59904-2633

Tonia Gardner, UST Class A Operator
Tonia Gardner, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	8/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
834			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/6/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			EECO 1500 , EMCO Electronics	Continuous Interstitial Monitor	
2	19	8/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
835			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/6/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			EECO 1500 , EMCO Electronics	Continuous Interstitial Monitor	
3	19	8/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
836			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		10/6/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000		2/12/2015	EECO 1500 , EMCO Electronics	Continuous Interstitial Monitor	

Facility Summary in FLATHEAD County in the City of MARION

Location: CABIN CREEK LANDING LLC
166 WRIGHT WAY
MARION, MT 59925 FLATHEAD

Contact: Russell Olsen, (406) 752-0051

Sys Fac ID: 56-14102
Last Inspected On: 3/21/2014
Operating Permit Renewal Date: 4/4/2017

Owners/Operators: Cabin Creek Landing LLC, Owner (406)-752-0051 2820 HELENA FLATS RD KALISPELL MT 59901-6535
Russell Olsen, UST Class A Operator
Russell Olsen, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	12	2/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4883		3/21/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Aviation Gas			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of OLNEY

Location: GLACIER GOLD LLC
255 GOOD CREEK RD
OLNEY, MT 59927 FLATHEAD

Contact: (406) 881-3033

Sys Fac ID: 15-02973
Last Inspected On: 4/16/2015
Operating Permit Renewal Date:

Owners/Operators: Glacier Gold LLC, Owner (406)-881-3030 PO BOX 128
OLNEY MT 59927-9999

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	28	3/29/1988	Cathodically Protected Steel	No Piping	
3583			None	None	Yes
Temporarily Out of Use				Pressurized	Galvanic
Gasoline		5/11/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Vapor Monitoring		
9,000					

Facility Summary in FLATHEAD County in the City of OLNEY

Location: OLNEY STORE
105 OLNEY LOOP RD
OLNEY, MT 59927 FLATHEAD

Contact: Fred Peters, (406) 881-9988

Sys Fac ID: 56-13849
Last Inspected On: 9/1/2016
Operating Permit Renewal Date: 9/17/2019

Owners/Operators:

Fred Peters, Owner	(406)-881-4010	PO BOX 79 OLNEY MT 59927
Donna Briggs, Operator	(406)-881-2009	9 RR STREET OLNEY MT 59927
Reggie Briggs, Operator	(406)-881-2009	9 RR STREET OLNEY MT 59927

Donna M Briggs, UST Class A Operator
Sandra Mayert, UST Class A Operator
Fred Peters, UST Class A Operator
Donna M Briggs, UST Class B Operator
Sandra Mayert, UST Class B Operator
Fred Peters, UST Class B Operator
Ruth Prince, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	18	6/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3504			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/17/2016	Automatic Tank Gauging 0.2	Deferred	
1,000			EECO 1500 , EMCO Electronics		
4	18	6/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3505			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/17/2016	Automatic Tank Gauging 0.2	Deferred	
500			EECO 1500 , EMCO Electronics		
5	18	6/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3506			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		6/17/2016	Automatic Tank Gauging 0.2	Deferred	
500			EECO 1500 , EMCO Electronics		

Facility Summary in FLATHEAD County in the City of POLEBRIDGE

Location: HOME RANCH STORE
8950 N FORK RD
POLEBRIDGE, MT 59928 FLATHEAD

Contact: Gregory Puckett, (513) 505-5716

Sys Fac ID: 15-12800
Last Inspected On: 3/30/2015
Operating Permit Renewal Date:

Owners/Operators: Mountain Fever LLC, Owner/Operator (406)-888-5572 8950 NORTH FORK RD POLEBRIDGE MT 59928

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	6/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2978			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		5/12/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
2,000					

Facility Summary in FLATHEAD County in the City of WEST GLACIER

Location: MRC GAS STATION
200 GOING TO THE SUN RD
WEST GLACIER, MT 59936 FLATHEAD
Contact: Ron Behney, (406) 892-6705

Sys Fac ID: 15-03288
Last Inspected On: 9/27/2014
Operating Permit Renewal Date: 12/2/2017

Owners/Operators: Glacier Park INC, Owner/Operator (620)-207-1077 1850 NORTH CENTRAL AVENUE SUITE 1900 PHOENIX AZ 85004

Charles Krasselt, UST Class A Operator
Richard Kreienheder, UST Class A Operator
Cassandra Pyles, UST Class A Operator
Richard Kreienheder, UST Class B Operator
Cassandra Pyles, UST Class B Operator
Charles Krasselt, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	27	10/23/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2246			Double-Walled	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/10/2014	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
10,000		9/10/2014	TLS-300 , Veeder Root		
5	27	10/23/1989	Cathodically Protected Steel	No Piping	Ball Float Valve
2247			Double-Walled	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/10/2014	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
8,000		9/10/2014	TLS-300 , Veeder Root		
6	27	10/23/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2248			Double-Walled	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/10/2014	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
6,000		9/10/2014	TLS-300 , Veeder Root		

Facility Summary in FLATHEAD County in the City of WEST GLACIER

Location: GLACIER PARK HDQTRS GAS PUMPS
PO BOX 128
WEST GLACIER, MT 59936 FLATHEAD

Contact: Del Zimmerli, (406) 888-7978

Sys Fac ID: 15-09491
Last Inspected On: 5/29/2014
Operating Permit Renewal Date: 8/2/2017

Owners/Operators: Glacier National Park, Owner (406)-732-7718 PO BOX 128
WEST GLACIER MT 59936-0128

Lori King, UST Class A Operator
Franklin Thompson, UST Class A Operator
Lori King, UST Class B Operator
Franklin Thompson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	26	11/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1219		12/12/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		5/28/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000					
6	26	11/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1220		12/12/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		5/28/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					

Facility Summary in FLATHEAD County in the City of WEST GLACIER

Location: GLACIER HIGHLAND RESORT
US 12555 HIGHWAY 2 E
WEST GLACIER, MT 59936 FLATHEAD

Contact: Joe Hoff, (406) 888-5427

Sys Fac ID: 15-10685
Last Inspected On: 5/29/2014
Operating Permit Renewal Date: 9/17/2017

Owners/Operators: Glacier Highland Resort, Owner (406)-888-5427 PO BOX 397
WEST GLACIER MT 59936-0397

Joe Hoff, UST Class A Operator
Joe Hoff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	18	10/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3214			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		9/25/2013	EECO 1500 , EMCO Electronics		
4	18	10/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3215			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/28/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		9/25/2013	EECO 1500 , EMCO Electronics		

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: WESTSIDE EXXON
145 2ND ST W
WHITEFISH, MT 59937 FLATHEAD

Contact: Frank Barnes, (406) 862-4556

Sys Fac ID: 15-00112
Last Inspected On: 4/16/2015
Operating Permit Renewal Date: 9/6/2018

Owners/Operators: Barnes Enterprises Inc, Owner (406)-862-4535 PO BOX 4269
WHITEFISH MT 59937-4269

Franklin Barnes, UST Class A Operator
Franklin Barnes, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	20	11/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3421			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
12,000			TLS-300 , Veeder Root		
4	20	11/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3422			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
12,000			TLS-300 , Veeder Root		

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: CENEX ZIP TRIP #69
6585 US HIGHWAY 93 S
WHITEFISH, MT 59937 FLATHEAD
Contact: Ian Johnstone, (509) 535-7701

Sys Fac ID: 15-04903
Last Inspected On: 7/8/2016
Operating Permit Renewal Date: 12/27/2019

Owners/Operators: CHS Inc - Spokane Valley, Owner/Operator (509)-535-7701 16124 E MARIETTA LANE SPOKANE WA 99213

Ronald May, UST Class A Operator
Michael W Robinson, UST Class A Operator
Joe Stenzel, UST Class A Operator
Andrew Duffie, UST Class B Operator
Suzan Hughes, UST Class B Operator
Justin Mace, UST Class B Operator
Justin Mace, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	25	11/4/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2956			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/24/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
8	25	11/4/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2957			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		8/24/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
9	25	11/4/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2958			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		8/24/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: CENEX ZIP TRIP #69
6585 US HIGHWAY 93 S
WHITEFISH, MT 59937 FLATHEAD

Contact: Ian Johnstone, (509) 535-7701

Sys Fac ID: 15-04903
Last Inspected On: 7/8/2016
Operating Permit Renewal Date: 12/27/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	25	11/4/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2959			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/24/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: BIG MOUNTAIN SKI RESORT SHOP
3910 BIG MOUNTAIN RD
WHITEFISH, MT 59937 FLATHEAD

Contact: Rory Kazer, (406) 862-2981

Sys Fac ID: 15-05579
Last Inspected On: 10/3/2016
Operating Permit Renewal Date: 10/22/2019

Owners/Operators: Winter Sports Inc, Owner (406)-862-2987 PO BOX 1400
WHITEFISH MT 59937-1400

Rory Kizer, UST Class A Operator
Rory Kizer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	24	9/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
2295			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		9/19/2016	TLS-350/Gilbarco EMC , Veeder Root		
9	18	7/14/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2296			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Deferred	
12,000		11/1/2006	TLS-350/Gilbarco EMC , Veeder Root		
10	18	7/14/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2297			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
2,000		11/1/2006	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: MIDWAY MINI MART
4899 US HIGHWAY 93 S
WHITEFISH, MT 59937 FLATHEAD
Contact: Dan Scheffer, (406) 862-1451

Sys Fac ID: 15-07766
Last Inspected On: 3/20/2014
Operating Permit Renewal Date: 8/7/2017

Owners/Operators: Daniel Scheffer, Owner (406)-862-1451 818 BOULDER LN WHITEFISH MT 59937-3233
Daniel Scheffer, UST Class A Operator
Daniel Scheffer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	20	4/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3384			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/20/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		10/25/2010	TLS-350/Gilbarco EMC , Veeder Root		
5	20	4/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3385			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/20/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
7,000		1/13/2010	TLS-350/Gilbarco EMC , Veeder Root		
6	20	4/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3386			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/20/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000		1/14/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: TOWN PUMP INC WHITEFISH 2
6600 US HIGHWAY 93 S
WHITEFISH, MT 59937 FLATHEAD

Contact: Kevin Kenneally, (406) 862-7204

Sys Fac ID: 15-10105
Last Inspected On: 1/19/2016
Operating Permit Renewal Date: 4/21/2019

Owners/Operators:

Troy Town Pump Inc, Owner	(406)-497-6700	600 S MAIN ST BUTTE MT 59701-2534
Troy Town Pump Inc, Operator	(406)-497-6700	600 S MAIN ST BUTTE MT 59701-2534

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	1/17/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2428			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
2	26	1/17/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4306			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
3	26	1/17/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2430			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: TOWN PUMP INC WHITEFISH 2
6600 US HIGHWAY 93 S
WHITEFISH, MT 59937 FLATHEAD

Contact: Kevin Kenneally, (406) 862-7204

Sys Fac ID: 15-10105
Last Inspected On: 1/19/2016
Operating Permit Renewal Date: 4/21/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	26	1/17/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2431			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	12	10/1/2004	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4941			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: ALPINE VILLAGE MARKET
721 WISCONSIN AVE
WHITEFISH, MT 59937 FLATHEAD

Contact: Alan Reisch, (406) 862-5025

Sys Fac ID: 15-10944
Last Inspected On: 9/12/2014
Operating Permit Renewal Date: 12/31/2017

Owners/Operators: Super Grocer Corp, Owner/Operator (406)-862-5025 721 WISCONSIN AVE WHITEFISH MT 59937

Alan Reisch, UST Class A Operator
Brent Silcox, UST Class A Operator
Alan Reisch, UST Class B Operator
Brent Silcox, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	35	4/21/1981	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4692			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/12/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		9/10/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	
2	35	4/21/1981	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4693			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/12/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		8/15/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	
3	25	10/1/1991	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4694			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		11/12/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000		8/2/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: WHITEFISH LAKE LODGE
1399 WISCONSIN AVE
WHITEFISH, MT 59937 FLATHEAD
Contact: Will Stock, (406) 863-4043

Sys Fac ID: 15-12719
Last Inspected On: 7/23/2014
Operating Permit Renewal Date: 9/29/2017

Owners/Operators: Whitefish Lake Lodge, Owner (406)-837-7050 DAN AVERILL CFO
PO BOX 2040
WHITEFISH MT 59937-2040

Chris Gulick, UST Class A Operator
Heath Howell, UST Class A Operator
Chris Gulick, UST Class B Operator
Heath Howell, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	4/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4898		8/25/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000		7/22/2014	Other , Other		

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: NORTH VALLEY HOSPITAL
1600 HOSPITAL WAY
WHITEFISH, MT 59937 FLATHEAD

Contact: Joe Grabowski, (406) 862-2501

Sys Fac ID: 60-15034
Last Inspected On: 4/5/2016
Operating Permit Renewal Date: 9/6/2019

Owners/Operators: North Valley Hospital, Owner (460)-863-3561 JOE GRABOWSKI
1600 HOSPITAL WAY
WHITEFISH MT 59937-2990

Joseph Grabowski, UST Class A Operator
Joseph Grabowski, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	09	1/17/2007	Aboveground Tank	Flexible Plastic	
5123	Yes	3/23/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Heating Oil			Deferred	Continuous Interstitial Monitor	
4,000			TLS-300 , Veeder Root		

Facility Summary in FLATHEAD County in the City of WHITEFISH

Location: SAFEWAY FUEL STATION #2106
110 WEST 13TH ST
WHITEFISH, MT 59937 FLATHEAD

Contact: Randy Bebee, (406) 862-3006

Sys Fac ID: 60-15151
Last Inspected On: 8/17/2016
Operating Permit Renewal Date: 12/28/2019

Owners/Operators:

Safeway# 2106, Owner	(623)-869-3573	PO BOX 29096 MS 6531 PHOENIX AZ 85038-9096
Aaron Nelson, Operator	(425)-201-6301	1121 124TH AVE NE BELLEVUE WA 98005-2101

Rachel Jones, UST Class A Operator
Aaron Nelson, UST Class A Operator
Lynn Pehrson, UST Class A Operator
Debbie Dull, UST Class B Global Operator
Rachel Jones, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	06	4/28/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5233			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
2	06	4/28/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5234			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
3	06	4/28/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
5235			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in GALLATIN County in the City of BELGRADE

Location: YELLOWSTONE JET CENTER LLC
490 GALLATIN FIELD RD
BELGRADE, MT 59714 GALLATIN

Contact: Kent Foster, (406) 388-4152

Sys Fac ID: 16-04440
Last Inspected On: 6/5/2015
Operating Permit Renewal Date: 8/4/2018

Owners/Operators:

Signature Flight Support, Owner	(407)-648-7200	201 S ORANGE AVE SUITE 1100 ORLANDO FL 32801-3478
Signature Flight Support, Operator	(407)-648-7200	201 S ORANGE AVE SUITE 1100 ORLANDO FL 32801-3478

Michael Russell, UST Class A Operator
Al Sandvold, UST Class A Operator
Robert Lemon, UST Class B Operator
Tom Melum, UST Class B Operator
Dennis A Franks, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	39	4/11/1977	Cathodically Protected Steel	Steel	High Level Alarm
2037			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Jet Fuel		4/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
2	39	4/11/1977	Cathodically Protected Steel	Steel	High Level Alarm
2038			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Jet Fuel		4/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
3	41	4/12/1975	Cathodically Protected Steel	Steel	High Level Alarm
2039			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Jet Fuel		4/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BELGRADE

Location: YELLOWSTONE JET CENTER LLC
490 GALLATIN FIELD RD
BELGRADE, MT 59714 GALLATIN

Contact: Kent Foster, (406) 388-4152

Sys Fac ID: 16-04440
Last Inspected On: 6/5/2015
Operating Permit Renewal Date: 8/4/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	41	4/12/1975	Cathodically Protected Steel	Steel	High Level Alarm
2040			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Jet Fuel		4/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	41	4/12/1975	Cathodically Protected Steel	Steel	High Level Alarm
2041			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Jet Fuel		4/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
6	41	4/12/1975	Bare Steel	Steel	High Level Alarm
2042			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Jet Fuel		4/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
7	39	4/11/1977	Cathodically Protected Steel	Steel	High Level Alarm
2036			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Aviation Gas		9/12/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BELGRADE

Location: FLYING J INC BELGRADE
6505 JACKRABBIT LN
BELGRADE, MT 59714 GALLATIN

Contact: Damon Borden, (509) 534-1502

Sys Fac ID: 16-05753
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 12/17/2017

Owners/Operators: A & H Investments LLC, Owner (509)-534-1502 PO BOX 14646 SPOKANE WA 99214

Don Edmisten, UST Class A Operator
Randell Goff, UST Class A Operator
Tina Guyett-Creason, UST Class A Operator
Kasey Maes, UST Class A Operator
Michael Smith, UST Class A Operator
Frieda Holloway, UST Class B Operator
Don Edmisten, UST Class B Global Operator
Randell Goff, UST Class B Global Operator
Tina Guyett-Creason, UST Class B Global Operator
Kasey Maes, UST Class B Global Operator
Katherine E Waeckerlin, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	40	4/1/1976	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm, Flapper Valve (Auto Shutoff)
3796			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		9/22/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		9/22/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	40	4/26/1976	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm, Flapper Valve (Auto Shutoff)
3795			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/22/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		9/22/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BELGRADE

Location: FLYING J INC BELGRADE
6505 JACKRABBIT LN
BELGRADE, MT 59714 GALLATIN
Contact: Damon Borden, (509) 534-1502

Sys Fac ID: 16-05753
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 12/17/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	40	4/26/1976	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
3797			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		9/22/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
28,000		9/2/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	
4	40	4/26/1976	Bare Steel	Flexible Plastic	High Level Alarm, Flapper Valve (Auto Shutoff)
3793			Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/22/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
28,000		9/22/2014	TLS-350/Gilbarco EMC , Veeder Root		
5	40	4/26/1976	Bare Steel	Flexible Plastic	High Level Alarm
3794			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		9/22/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
28,000		9/4/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	

Facility Summary in GALLATIN County in the City of BELGRADE

Location: TOWN PUMP INC BELGRADE 3
305 E MAIN ST
BELGRADE, MT 59714 GALLATIN

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 16-07788
Last Inspected On: 2/9/2015
Operating Permit Renewal Date: 5/31/2018

Owners/Operators: Great Falls Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	11	8/29/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5016			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		9/11/2005	TLS-350/Gilbarco EMC , Veeder Root		
8	11	8/29/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5017			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000		9/11/2005	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BELGRADE

Location: TOWN PUMP INC BELGRADE 3
305 E MAIN ST
BELGRADE, MT 59714 GALLATIN

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 16-07788
Last Inspected On: 2/9/2015
Operating Permit Renewal Date: 5/31/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	11	8/29/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5026			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000		9/11/2005	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BELGRADE

Location: ROCKY MOUNTAIN SUPPLY INC BELGRADE
350 JACKRABBIT LN
BELGRADE, MT 59714 GALLATIN

Contact: (406) 388-4008

Sys Fac ID: 16-12101
Last Inspected On: 12/18/2014
Operating Permit Renewal Date: 2/26/2018

Owners/Operators: Rocky Mountain Supply Inc, Owner (406)-388-4008 JASON RORABAUGH PETROLEUM MGR
PO BOX 129
BELGRADE MT 59714-3035

Jason Rorabaugh, UST Class A Operator
Jerrod Eller, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	9/20/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1189			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/13/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		10/10/2011	TLS-350/Gilbarco EMC , Veeder Root		
2	26	9/20/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1190			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/13/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		5/17/2011	TLS-350/Gilbarco EMC , Veeder Root		
3	26	9/20/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1191			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/13/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		10/12/2011	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BELGRADE

Location: ROCKY MOUNTAIN SUPPLY INC BELGRADE
350 JACKRABBIT LN
BELGRADE, MT 59714 GALLATIN
Contact: (406) 388-4008

Sys Fac ID: 16-12101
Last Inspected On: 12/18/2014
Operating Permit Renewal Date: 2/26/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	26	9/20/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1192			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/13/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		10/14/2011	TLS-350/Gilbarco EMC , Veeder Root		
5	13	10/24/2003	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4867			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/13/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		10/26/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of BELGRADE

Location: GALLATIN FIELD CARDLOCK
GALLATIN FIELD
BELGRADE, MT 59714 GALLATIN

Contact: Jason Shanley, (406) 587-0702

Sys Fac ID: 16-12952
Last Inspected On: 6/15/2016
Operating Permit Renewal Date: 7/22/2019

Owners/Operators: Story Distributing Co, Owner (406)-587-0702 PO BOX 1201
BOZEMAN MT 59771-1201

Gary Scales, UST Class A Operator
Jason Shanley, UST Class A Operator
Jason Shanley, UST Class B Operator
Gary Scales, UST Class B Global Operator
Kelly Scott Shutes, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	11/1/1992	Bare Steel	Fiberglass Reinforced Plastic	
2032	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
4,000		6/15/2016			

Facility Summary in GALLATIN County in the City of BELGRADE

Location: TOWN PUMP INC BELGRADE
203 W JEFFERSON AVE
BELGRADE, MT 59714 GALLATIN
Contact: Kevin Kenneally, (406) 388-0129

Sys Fac ID: 16-13625
Last Inspected On: 7/3/2015
Operating Permit Renewal Date: 10/27/2018

Owners/Operators: Belgrade Town Pump Inc, Owner — 600 S MAIN ST, BUTTE MT 59701-2534

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	5/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2454			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
10,000		6/30/2015	TLS-350/Gilbarco EMC , Veeder Root		
2	21	5/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2455			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
10,000		6/30/2015	TLS-350/Gilbarco EMC , Veeder Root		
3	21	5/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2456			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BELGRADE

Location: TOWN PUMP INC BELGRADE
203 W JEFFERSON AVE
BELGRADE, MT 59714 GALLATIN

Contact: Kevin Kenneally, (406) 388-0129

Sys Fac ID: 16-13625
Last Inspected On: 7/3/2015
Operating Permit Renewal Date: 10/27/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	21	5/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4371			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
12,000		6/30/2015	TLS-350/Gilbarco EMC , Veeder Root		
5	21	5/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2458			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		6/30/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BELGRADE

Location: QWEST COMMUNICATIONS
95 N BROADWAY
BELGRADE, MT 59714 GALLATIN

Contact: Kevin Robison, (801) 237-3006

Sys Fac ID: 56-13996
Last Inspected On: 10/28/2014
Operating Permit Renewal Date: 3/14/2018

Owners/Operators:

Qwest Corporation, Owner	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111
Qwest Corporation, Operator	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111

Thomas J Pitts, UST Class A Operator
Kevin Robison, UST Class A Operator
Thomas J Pitts, UST Class B Operator
Thomas J Pitts, UST Class B Global Operator
Kevin Robison, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	15	11/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4266			Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
1,000		10/6/2015	TLS-300 , Veeder Root		

Facility Summary in GALLATIN County in the City of BELGRADE

Location: BELGRADE CARD LOCK
163 THUNDER RD
BELGRADE, MT 59714 GALLATIN

Contact: Gary Scales, (406) 587-7438

Sys Fac ID: 56-14162
Last Inspected On: 1/9/2015
Operating Permit Renewal Date: 3/16/2018

Owners/Operators:

Story Distributing Company, Owner	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771
Jason Shanley, Operator	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771-1201

Jason Shanley, UST Class A Operator
Jason Shanley, UST Class B Global Operator
Kelly Scott Shutes, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	11	9/5/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4999			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		
2	11	9/5/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5000			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
20,000			Gilbarco EMC Basic , Gilbarco		
3	11	9/5/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5001			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in GALLATIN County in the City of BELGRADE

Location: BELGRADE CARD LOCK
163 THUNDER RD
BELGRADE, MT 59714 GALLATIN
Contact: Gary Scales, (406) 587-7438

Sys Fac ID: 56-14162
Last Inspected On: 1/9/2015
Operating Permit Renewal Date: 3/16/2018

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
4	11	9/5/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5002			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000			Gilbarco EMC Basic , Gilbarco		
5	11	9/16/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5003			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
15,000			Gilbarco EMC Basic , Gilbarco		
6	11	9/5/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5004			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000			Gilbarco EMC Basic , Gilbarco		
7	11	9/5/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5063			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
20,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in GALLATIN County in the City of BELGRADE

Location: TOWN PUMP INC BELGRADE 2
691 JACKRABBIT LN
BELGRADE, MT 59714 GALLATIN
Contact: (406) 388-7060

Sys Fac ID: 60-15008
Last Inspected On: 2/9/2015
Operating Permit Renewal Date: 5/31/2018

Owners/Operators: Great Falls Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	11	9/20/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, Ball Float Valve
5019			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
25,000			TLS-350/Gilbarco EMC , Veeder Root		
2	11	9/20/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5020			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BELGRADE

Location: TOWN PUMP INC BELGRADE 2
691 JACKRABBIT LN
BELGRADE, MT 59714 GALLATIN
Contact: (406) 388-7060

Sys Fac ID: 60-15008
Last Inspected On: 2/9/2015
Operating Permit Renewal Date: 5/31/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	11	9/20/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5021			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
4	11	9/20/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, Ball Float Valve
5022			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root		
5	11	9/20/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5023			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BELGRADE

Location: GALLATIN FIELD AIRPORT
633 GALLATIN FIELD RD
BELGRADE, MT 59714 GALLATIN

Contact: Scales Gary, (406) 587-0702

Sys Fac ID: 60-15152
Last Inspected On: 6/1/2016
Operating Permit Renewal Date: 7/3/2019

Owners/Operators: Story Distributing Co, Owner (406)-587-0702 PO BOX 1201
BOZEMAN MT 59771-1201

Gary Scales, UST Class A Operator
Jason Shanley, UST Class A Operator
Gary Scales, UST Class B Global Operator
Jason Shanley, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	06	4/13/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5236		12/26/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Not Listed	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
12,000		5/13/2016	TLS-300 , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in GALLATIN County in the City of BELGRADE

Location: CENTRAL COPTER
395 JET WAY DR
BELGRADE, MT 59714 GALLATIN

Contact: Mark Duffy, (406) 586-9185

Sys Fac ID: 60-15232
Last Inspected On: 8/5/2016
Operating Permit Renewal Date: 8/24/2019

Owners/Operators: Central Copter, Owner (406)-586-9185 PO BOX 7300
BOZEMAN MT 59771-7300

Mark Duffy, UST Class A Operator
Brian Geary, UST Class A Operator
Mark Duffy, UST Class B Operator
Brian Geary, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	00	3/1/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff, High Level Alarm
5547		10/21/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Jet Fuel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
10,000			TLS-300 , Veeder Root	Not Listed	Yes

Facility Summary in GALLATIN County in the City of BELGRADE

Location: TOWN PUMP INC BELGRADE 4
561 BUSINESS HUB DRIVE
BELGRADE, MT 59714 GALLATIN

Contact: Charlie Armstrong, (406) 497-6700

Sys Fac ID: 60-15245
Last Inspected On: 1/5/2015
Operating Permit Renewal Date: 1/22/2018

Owners/Operators: Town and Country Supply and Management, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	02	4/14/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5484		6/3/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	
2	02	4/14/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5485		6/3/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	
3	02	4/14/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5486		6/3/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	

Facility Summary in GALLATIN County in the City of BELGRADE

Location: TOWN PUMP INC BELGRADE 4
561 BUSINESS HUB DRIVE
BELGRADE, MT 59714 GALLATIN

Contact: Charlie Armstrong, (406) 497-6700

Sys Fac ID: 60-15245
Last Inspected On: 1/5/2015
Operating Permit Renewal Date: 1/22/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	02	4/14/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5487		6/3/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	
5	02	4/14/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5488		6/3/2014	Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Vapor Monitoring, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	
6	02	4/14/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5489		6/3/2014	Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	
7	02	4/14/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5490		6/3/2014	Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	

Facility Summary in GALLATIN County in the City of BIG SKY

Location: BIG SKY CONOCO
91 LONE MOUNTAIN TRL
BIG SKY, MT 59716 GALLATIN

Contact: Renae Schumacher, (406) 995-4275

Sys Fac ID: 16-03801
Last Inspected On: 7/5/2016
Operating Permit Renewal Date: 10/24/2019

Owners/Operators: Nevermore Inc, Owner (406)-995-4275 PO BOX 160640
BIG SKY MT 59716-0640

Renae Schumacher, UST Class A Operator
Steve Schumacher, UST Class A Operator
Dennis A Franks, UST Class B Operator
Steve Schumacher, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	19	5/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3155			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/5/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
7	19	5/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3156			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/5/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
8	19	5/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3157			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	U.S. Suction	Galvanic
Diesel		9/10/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
1,000			TLS-300 , Veeder Root		

Facility Summary in GALLATIN County in the City of BIG SKY

Location: BIG SKY CONOCO
91 LONE MOUNTAIN TRL
BIG SKY, MT 59716 GALLATIN

Contact: Renae Schumacher, (406) 995-4275

Sys Fac ID: 16-03801
Last Inspected On: 7/5/2016
Operating Permit Renewal Date: 10/24/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
4488			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/5/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
2,500			TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of BIG SKY

Location: TOM GERRARD
2300 N FORK RD
BIG SKY, MT 59716 GALLATIN
Contact: Scott Hammond, (406) 995-9100

Sys Fac ID: 16-13672
Last Inspected On: 10/12/2016
Operating Permit Renewal Date: 12/6/2019

Owners/Operators: William Tom Gerrard, Owner (406)-995-9100 PO BOX 160777 BIG SKY MT 59716-0777
Jay Reader, UST Class A Operator
Dennis A Franks, UST Class B Global Operator
Jay Reader, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	9/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3936		10/12/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
1,000			TLS-300 , Veeder Root		
2	18	10/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3726			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor, Deferred	
1,000			TLS-300 , Veeder Root		

Facility Summary in GALLATIN County in the City of BIG SKY

Location: WATERMARK HOME
341 ANDESITE RIDGE ROAD
BIG SKY, MT 59716 GALLATIN

Contact: Bill Rode, (406) 209-1400

Sys Fac ID: 60-15032
Last Inspected On: 9/28/2016
Operating Permit Renewal Date: 1/11/2020

Owners/Operators: Watermark Services, Owner (406)-209-1400 BILL RODE
PO BOX 161864
BIG SKY MT 59716-1864

Edd Gryder, UST Class A Operator
Edd Gryder, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	10	10/24/2006	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5133		9/28/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
3,000			TLS-300 , Veeder Root		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: COLLEGE EXXON SERVICE STATION
723 S 8TH AVE
BOZEMAN, MT 59715 GALLATIN

Contact: Harold Sappington, (406) 587-4453

Sys Fac ID: 16-00472
Last Inspected On: 10/15/2015
Operating Permit Renewal Date: 2/25/2019

Owners/Operators: College Chevron of Bozeman Inc, Owner (406)-587-4453 723 S 8TH AVE BOZEMAN MT 59715-4414

David Lapinski, UST Class A Operator
David Lapinski, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	18	4/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
694		10/1/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		10/1/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			TLS-300 , Veeder Root		
7	18	4/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
695		10/1/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		10/1/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000			TLS-300 , Veeder Root		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: Willie J Figgins
1404 BOHART LN
BOZEMAN, MT 59715 GALLATIN
Contact: (406) 586-3372

Sys Fac ID: 16-00543
Last Inspected On: 5/7/2015
Operating Permit Renewal Date: 8/30/2018

Owners/Operators: Willie J Figgins, Owner (406)-586-3372 1404 BOHART LN BOZEMAN MT 59715-2413
Robert Figgins, UST Class A Operator
Robert Figgins, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	22	3/11/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1060			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		5/7/2015	Manual Interstitial Monitor	Not Listed	
1,000					
5	22	3/11/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1059			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		5/7/2015	Manual Interstitial Monitor	Not Listed	
1,000					

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: WILLIAMS PUMP & PAK INC
2020 N 7TH AVE
BOZEMAN, MT 59715 GALLATIN

Contact: Alan Williams, (406) 587-0485

Sys Fac ID: 16-00758
Last Inspected On: 9/15/2014
Operating Permit Renewal Date: 11/6/2017

Owners/Operators: Williams Pump & Pak Inc, Owner (406)-587-0485 2020 N 7TH AVE BOZEMAN MT 59715-2516
Alan Williams, UST Class A Operator
Alan Williams, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	19	6/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2275			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/22/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
5	19	6/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2276			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/22/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: GRANTREE CONOCO
1417 N 7TH AVE
BOZEMAN, MT 59715 GALLATIN

Contact: Jacob Marks, (406) 587-0651

Sys Fac ID: 16-01254
Last Inspected On: 11/1/2016
Operating Permit Renewal Date: 12/24/2019

Owners/Operators: Grantree Conoco, Owner (406)-587-5261 1417 N 7TH AVE
BOZEMAN MT 59715-2513

Missy Tallman, UST Class A Operator
Missy Tallman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	21	9/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Auto Limiter
3299		4/5/2016	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
12,000		4/14/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	21	9/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Auto Limiter
3300		4/5/2016	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
12,000		4/14/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	21	9/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Auto Limiter
3301		4/5/2016	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
8,000		4/14/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	21	9/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Auto Limiter
3302		4/5/2016	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		4/14/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: BRIDGER BOWL INC
15795 BRIDGER CANYON RD
BOZEMAN, MT 59715 GALLATIN

Contact: Robert Allen, (406) 587-2111

Sys Fac ID: 16-01793
Last Inspected On: 9/8/2015
Operating Permit Renewal Date: 10/1/2018

Owners/Operators: Bridger Bowl Inc, Owner (406)-587-2111 15795 BRIDGER CANYON RD BOZEMAN MT 59715-8282

Robert Allen, UST Class A Operator
Daniel Doehring, UST Class A Operator
Daniel Doehring, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	21	11/1/1995	Cathodically Protected Steel	Flexible Plastic	
491			None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Diesel		8/11/2015	Deferred	Deferred	
100					
8	18	10/30/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
492			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		8/11/2015	Manual Interstitial Monitor	Continuous Interstitial Monitor	
2,000					
9	18	10/30/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
493			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		8/11/2015	Manual Interstitial Monitor	Continuous Interstitial Monitor	
1,000					

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: PHILLIPS 66 BOZEMAN TERMINAL
318 W GRIFFIN DR
BOZEMAN, MT 59715 GALLATIN

Contact: Steve Thomas, (406) 441-4747

Sys Fac ID: 16-01844
Last Inspected On: 7/10/2014
Operating Permit Renewal Date: 10/31/2017

Owners/Operators:

Phillips 66 Bozeman Terminal, Owner	(406)-255-5714	2626 LILLIAN AVENUE BILLINGS MT 59101
Phillips 66 Pipeline LLC, Operator	(406)-255-5714	2626 LILLIAN AVENUE BILLINGS MT 59101

Brian Buckley, UST Class A Operator
CHARLES HEINAMAN, UST Class A Operator
Chase Keith, UST Class A Operator
Ryan Norwood, UST Class A Operator
John Stampfli, UST Class A Operator
Steve Thomas, UST Class A Operator
Earl Anderson, UST Class B Operator
Brian Buckley, UST Class B Operator
Theodore Hagemo, UST Class B Operator
Ryan Norwood, UST Class B Operator
Clifford Pearce, UST Class B Operator
Steven Sheldon, UST Class B Operator
Steve Thomas, UST Class B Operator
Michael Crawford, UST Class B Global Operator
CHARLES HEINAMAN, UST Class B Global Operator
Chase Keith, UST Class B Global Operator
Richard Leeds, UST Class B Global Operator
Jeb Pedrazzi, UST Class B Global Operator
John Stampfli, UST Class B Global Operator
Dane Whittaker, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: PHILLIPS 66 BOZEMAN TERMINAL
318 W GRIFFIN DR
BOZEMAN, MT 59715 GALLATIN

Contact: Steve Thomas, (406) 441-4747

Sys Fac ID: 16-01844
Last Inspected On: 7/10/2014
Operating Permit Renewal Date: 10/31/2017

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
12	61	1/1/1955	Unknown	Steel - Terminal Piping	
715	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Gasoline		5/23/2014	Deferred	MLLD Line Tightness Testing	
840,000		6/26/2014			
14	61	1/1/1955	Unknown	Steel - Terminal Piping	
717	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Gasoline		5/23/2014	Deferred	MLLD Line Tightness Testing	
840,000		6/26/2014			
17	50	1/1/1966	Unknown	Steel - Terminal Piping	
722	Yes		None	None	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable, Impressed Current
Gasoline		5/23/2014	Deferred	MLLD Line Tightness Testing	
1,680,000		5/13/2011			
18	61	1/1/1955	Unknown	Steel - Terminal Piping	
716	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		5/23/2014	Deferred	MLLD Line Tightness Testing	
840,000		6/26/2014			
20	61	1/1/1955	Unknown	Steel - Terminal Piping	
720	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		5/23/2014	Deferred	MLLD Line Tightness Testing	
840,000		6/26/2014			

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: PHILLIPS 66 BOZEMAN TERMINAL
318 W GRIFFIN DR
BOZEMAN, MT 59715 GALLATIN

Contact: Steve Thomas, (406) 441-4747

Sys Fac ID: 16-01844
Last Inspected On: 7/10/2014
Operating Permit Renewal Date: 10/31/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
23	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4698		6/24/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Mixture		5/23/2014	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
1,500		6/24/2014	Other , Other		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: BOZEMAN AUDI
1800 W MAIN ST
BOZEMAN, MT 59715 GALLATIN

Contact: Michael Parsons, (406) 586-1772

Sys Fac ID: 16-03430
Last Inspected On: 3/12/2015
Operating Permit Renewal Date:

Owners/Operators: BOZEMAN AUDI, Owner/Operator (406)-586-1772 1800 W MAIN ST
BOZEMAN MT 59715-4016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	23	7/1/1993	Cathodically Protected Steel	Copper	
3104			Double-Walled	Secondary Containment Chase	Yes
Temporarily Out of Use			Not Required	U.S. Suction	Galvanic
Waste Oil		3/4/2015	Continuous Interstitial Monitor	MLLD Line Tightness Testing	
2,000					

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: THRIFTWAY SUPER STOP 10
919 W COLLEGE ST
BOZEMAN, MT 59715 GALLATIN
Contact: (406) 587-9661

Sys Fac ID: 16-03432
Last Inspected On: 5/30/2016
Operating Permit Renewal Date: 6/12/2019

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE BUTTE MT 59701-3553

Bryan Kelsey, UST Class A Operator
Louie Sutey, UST Class A Operator
Ryan Foreman, UST Class B Operator
Dan Franti, UST Class B Operator
Bryan Kelsey, UST Class B Operator
Dave Stine, UST Class B Operator
Louie Sutey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	33	7/1/1983	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
812			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/18/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		4/19/2016	TLS-350/Gilbarco EMC , Veeder Root		
2	33	7/1/1983	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
4434			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/18/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		4/19/2016	TLS-350/Gilbarco EMC , Veeder Root		
3	33	7/1/1983	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
814			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/18/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		4/19/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: THRIFTWAY SUPER STOP 11
621 W MAIN ST
BOZEMAN, MT 59715 GALLATIN

Contact: Mike Uphus, (406) 494-2305

Sys Fac ID: 16-03800
Last Inspected On: 5/31/2016
Operating Permit Renewal Date: 6/12/2019

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE BUTTE MT 59701-3553

Bryan Kelsey, UST Class A Operator
Louie Sutey, UST Class A Operator
Bryan Kelsey, UST Class B Operator
Joy Richardson, UST Class B Operator
Dave Stine, UST Class B Operator
Louie Sutey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	26	5/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
815			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		4/19/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		4/19/2016	TLS-350/Gilbarco EMC , Veeder Root		
7	26	5/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
816			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		4/19/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/19/2016	TLS-350/Gilbarco EMC , Veeder Root		
8	26	5/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
817			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		4/19/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/19/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: LOAF 'N JUG #729
1910 W MAIN ST
BOZEMAN, MT 59718 GALLATIN

Contact: Shirley Treece, (719) 948-5976

Sys Fac ID: 16-03913
Last Inspected On: 5/17/2016
Operating Permit Renewal Date: 6/14/2019

Owners/Operators: Mini Mart Inc dba Loaf 'N Jug, Owner (719)-948-3071 442 KEELER PKWY PUEBLO CO 81001-4813

William Jones, UST Class A Operator
Randal Liebnow, UST Class A Operator
John Sumowski, UST Class A Operator
Derrick Trimble, UST Class A Operator
Scott Huether, UST Class B Operator
Timothy Osterman, UST Class B Operator
Stevie Ulstad, UST Class B Operator
JENNIFER COLEMAN, UST Class B Global Operator
Dustin Harpster, UST Class B Global Operator
Casey Jambretz, UST Class B Global Operator
Randal Liebnow, UST Class B Global Operator
Anthony Mosmiller, UST Class B Global Operator
Toni Mullen, UST Class B Global Operator
Hiede Richardson, UST Class B Global Operator
Derrick Trimble, UST Class B Global Operator
DeWayne Young, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	11/1/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1642			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/18/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: LOAF 'N JUG #729
1910 W MAIN ST
BOZEMAN, MT 59718 GALLATIN

Contact: Shirley Treece, (719) 948-5976

Sys Fac ID: 16-03913
Last Inspected On: 5/17/2016
Operating Permit Renewal Date: 6/14/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
2	31	11/1/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1639			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/18/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
3	31	11/1/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1640			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/18/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
4	31	11/1/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1641			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/18/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: THRIFTWAY SUPER STOP 8
8192 HUFFINE LN
BOZEMAN, MT 59718 GALLATIN

Contact: Nora Pipkin, (406) 586-8488

Sys Fac ID: 16-05064
Last Inspected On: 5/30/2016
Operating Permit Renewal Date: 11/13/2019

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE
BUTTE MT 59701-3553

Bryan Kelsey, UST Class A Operator
Louie Sutey, UST Class A Operator
Viki Clayton, UST Class B Operator
Connie Hajenga, UST Class B Operator
Bryan Kelsey, UST Class B Operator
Deza Rae Pitt, UST Class B Operator
Dave Stine, UST Class B Operator
Louie Sutey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	18	8/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2053			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	18	8/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2054			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	18	8/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2055			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: LOAF 'N JUG #728
717 W COLLEGE ST
BOZEMAN, MT 59715 GALLATIN

Contact: Shirley Treece, (719) 948-5976

Sys Fac ID: 16-05778
Last Inspected On: 5/17/2016
Operating Permit Renewal Date: 9/13/2019

Owners/Operators: Mini Mart Inc dba Loaf 'N Jug, Owner (719)-948-3071 442 KEELER PKWY PUEBLO CO 81001-4813

William Jones, UST Class A Operator
Randal Liebnow, UST Class A Operator
John Sumowski, UST Class A Operator
Derrick Trimble, UST Class A Operator
Timothy Osterman, UST Class B Operator
Stevie Ulstad, UST Class B Operator
Pamela Upton, UST Class B Operator
JENNIFER COLEMAN, UST Class B Global Operator
Dustin Harpster, UST Class B Global Operator
Casey Jambretz, UST Class B Global Operator
Randal Liebnow, UST Class B Global Operator
Anthony Mosmiller, UST Class B Global Operator
Toni Mullen, UST Class B Global Operator
Hiede Richardson, UST Class B Global Operator
Derrick Trimble, UST Class B Global Operator
DeWayne Young, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	35	4/25/1981	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3641		12/11/2014	Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/22/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		12/18/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: LOAF 'N JUG #728
717 W COLLEGE ST
BOZEMAN, MT 59715 GALLATIN

Contact: Shirley Treece, (719) 948-5976

Sys Fac ID: 16-05778
Last Inspected On: 5/17/2016
Operating Permit Renewal Date: 9/13/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	35	4/25/1981	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3642		12/11/2014	Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/22/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		12/18/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	35	4/25/1981	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3643		12/11/2014	Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/22/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		12/18/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: ZIP TRIP 46
1210 E MAIN ST
BOZEMAN, MT 59715 GALLATIN

Contact: Harry Huntsinger, (406) 633-2359

Sys Fac ID: 16-06596
Last Inspected On: 1/7/2016
Operating Permit Renewal Date: 5/26/2019

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Ian Johnstone, UST Class A Operator
Nicholas Merritt, UST Class A Operator
Nicholas Merritt, UST Class B Operator
Darcy Ziegler, UST Class B Operator
Ian Johnstone, UST Class B Global Operator
Nicholas Merritt, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	4/3/1985	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2105			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		4/17/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	31	4/3/1985	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2106			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		4/17/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: ZIP TRIP 46
1210 E MAIN ST
BOZEMAN, MT 59715 GALLATIN

Contact: Harry Huntsinger, (406) 633-2359

Sys Fac ID: 16-06596
Last Inspected On: 1/7/2016
Operating Permit Renewal Date: 5/26/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	31	4/3/1985	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2107			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Diesel		4/17/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: CASEYS CORNER #1
81855 GALLATIN RD
BOZEMAN, MT 59718 GALLATIN
Contact: Jason Shanley, (406) 587-0702

Sys Fac ID: 16-06922
Last Inspected On: 6/20/2016
Operating Permit Renewal Date: 7/22/2019

Owners/Operators: Story Distributing Co, Owner/Operator (406)-587-0702 PO BOX 1201
BOZEMAN MT 59771-1201

Gary Scales, UST Class A Operator
Jason Shanley, UST Class A Operator
Angelina Matthews, UST Class B Operator
Brandis Moe, UST Class B Operator
Samantha Riffe, UST Class B Operator
Jason Shanley, UST Class B Operator
Nancy Kennedy, UST Class B Global Operator
Gary Scales, UST Class B Global Operator
Kelly Scott Shutes, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	5/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2024			None	Double-Walled	Yes
Currently in Use		5/1/2006	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/2/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	25	4/10/1991	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2018			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/2/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: CASEYS CORNER #1
81855 GALLATIN RD
BOZEMAN, MT 59718 GALLATIN

Contact: Jason Shanley, (406) 587-0702

Sys Fac ID: 16-06922
Last Inspected On: 6/20/2016
Operating Permit Renewal Date: 7/22/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	25	4/10/1991	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2019			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/2/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	25	4/10/1991	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2020			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/2/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	20	5/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2021			None	Double-Walled	Yes
Currently in Use		5/1/2006	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/2/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
2,000			TLS-350/Gilbarco EMC , Veeder Root		
9	20	5/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2022			None	Double-Walled	Yes
Currently in Use		5/1/2006	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/2/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: CASEYS CORNER #1
81855 GALLATIN RD
BOZEMAN, MT 59718 GALLATIN

Contact: Jason Shanley, (406) 587-0702

Sys Fac ID: 16-06922
Last Inspected On: 6/20/2016
Operating Permit Renewal Date: 7/22/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	20	5/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2023			None	Double-Walled	Yes
Currently in Use		5/1/2006	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/2/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: STRAIGHTAWAY MOTORS
5 E MENDENHALL ST
BOZEMAN, MT 59715 GALLATIN

Contact: Peter H Colvin, (406) 586-2569

Sys Fac ID: 16-07197
Last Inspected On: 2/3/2015
Operating Permit Renewal Date: 5/4/2018

Owners/Operators: Straightaway Motors, Owner (406)-586-2569 5 E MENDENHALL ST
BOZEMAN MT 59715-3666

Eric Colvin, UST Class A Operator
Peter H Colvin, UST Class A Operator
Peter H Colvin, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	24	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	
1387			Double-Walled	None	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Waste Oil		2/3/2015	Manual Interstitial Monitor	MLLD Line Tightness Testing	
2,000		2/3/2015			

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: CASEYS #2
1211 E MAIN ST
BOZEMAN, MT 59715 GALLATIN

Contact: Gary Scales, (406) 587-7438

Sys Fac ID: 16-08188
Last Inspected On: 10/25/2016
Operating Permit Renewal Date: 12/31/2019

Owners/Operators:

Story Distributing Company, Owner	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771
Jason Shanley, Operator	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771-1201

Gary Scales, UST Class A Operator
Jason Shanley, UST Class A Operator
Pam Diamond, UST Class B Operator
Thomas Dickson, UST Class B Operator
Randall Greene, UST Class B Operator
Jessika Hensley, UST Class B Operator
Elizabeth Hickman, UST Class B Operator
Edye Macrow, UST Class B Operator
Jason Shanley, UST Class B Global Operator
Kelly Scott Shutes, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	4/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4576			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/25/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	18	4/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4577			None	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		10/25/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: CASEYS #2
1211 E MAIN ST
BOZEMAN, MT 59715 GALLATIN
Contact: Gary Scales, (406) 587-7438

Sys Fac ID: 16-08188
Last Inspected On: 10/25/2016
Operating Permit Renewal Date: 12/31/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	18	4/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2030			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		10/25/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	18	4/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2031			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/25/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: CASEYS CORNER #3
1420 N 7TH AVE
BOZEMAN, MT 59715 GALLATIN

Contact: Jason Shanley, (406) 587-0702

Sys Fac ID: 16-08190
Last Inspected On: 10/25/2016
Operating Permit Renewal Date: 12/31/2019

Owners/Operators: Story Distributing Co, Owner/Operator (406)-587-0702 PO BOX 1201
BOZEMAN MT 59771-1201

Gary Scales, UST Class A Operator
Jason Shanley, UST Class A Operator
Ryan Allen, UST Class B Operator
Randall Greene, UST Class B Operator
Ladonna Lambert, UST Class B Operator
Ginny Strobel, UST Class B Operator
Gary Scales, UST Class B Global Operator
Jason Shanley, UST Class B Global Operator
Kelly Scott Shutes, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	17	12/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3687			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/25/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1	
10,000		7/26/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	17	12/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3688			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/25/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1	
14,000		10/16/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	10	12/28/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5054			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		10/7/2010	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1	
8,000		10/15/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: BOZEMAN KARDLOCK
300 E GRIFFIN DR
BOZEMAN, MT 59715 GALLATIN

Contact: Gary Scales, (406) 587-0702

Sys Fac ID: 16-08191
Last Inspected On: 12/26/2013
Operating Permit Renewal Date: 1/15/2017

Owners/Operators: Story Distributing Co, Owner/Operator (406)-587-0702 PO BOX 1201 BOZEMAN MT 59771-1201

Jason Shanley, UST Class A Operator
Jason Shanley, UST Class B Global Operator
Kelly Scott Shutes, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	38	5/2/1978	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3864			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/26/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					
2	38	5/2/1978	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3865			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/26/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000					
3	38	5/2/1978	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3866			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/26/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, MLLD Line Tightness Testing	
8,000		11/16/2010			

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: BOZEMAN KARDLOCK
300 E GRIFFIN DR
BOZEMAN, MT 59715 GALLATIN

Contact: Gary Scales, (406) 587-0702

Sys Fac ID: 16-08191
Last Inspected On: 12/26/2013
Operating Permit Renewal Date: 1/15/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	30	1/1/1986	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3867			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/26/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					
5	30	1/1/1986	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3868			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/26/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: TOWN PUMP INC BOZEMAN 1
803 E MAIN ST
BOZEMAN, MT 59715 GALLATIN

Contact: Trent Biggers, (406) 497-6936

Sys Fac ID: 16-08674
Last Inspected On: 8/12/2015
Operating Permit Renewal Date: 8/25/2018

Owners/Operators: Town Pump Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-2534

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	01	4/1/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), Ball Float Valve
5520		3/3/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	
10	01	4/1/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), Ball Float Valve
5521		3/3/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: TOWN PUMP INC BOZEMAN 1
803 E MAIN ST
BOZEMAN, MT 59715 GALLATIN

Contact: Trent Biggers, (406) 497-6936

Sys Fac ID: 16-08674
Last Inspected On: 8/12/2015
Operating Permit Renewal Date: 8/25/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	01	4/1/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), Ball Float Valve
5522		3/3/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	
12	01	4/1/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), Ball Float Valve
5523		3/3/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	
13	01	4/1/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), Ball Float Valve
5524		3/3/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: TOWN PUMP INC BOZEMAN 2
2607 W MAIN ST
BOZEMAN, MT 59718 GALLATIN

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 16-08675
Last Inspected On: 2/9/2015
Operating Permit Renewal Date: 5/31/2018

Owners/Operators: Bozeman Town Pump Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	4/11/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2441			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/7/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	32	4/11/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2442			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/7/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
3	32	4/11/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2443			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		7/7/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: TOWN PUMP INC BOZEMAN 2
2607 W MAIN ST
BOZEMAN, MT 59718 GALLATIN

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 16-08675
Last Inspected On: 2/9/2015
Operating Permit Renewal Date: 5/31/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	27	4/1/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2444			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		7/7/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: EXXONMOBIL BOZEMAN PRODUCTS TERMINAL
220 W GRIFFIN DR
BOZEMAN, MT 59715 GALLATIN

Contact: Chris Martin, (406) 586-6927

Sys Fac ID: 16-08730
Last Inspected On: 2/23/2016
Operating Permit Renewal Date: 5/27/2019

Owners/Operators: Exxon Mobil Corporation, Owner (832)-625-7781 220 W GRIFFIN DR BOZEMAN MT 59715

Bob Kolp, UST Class A Operator
James Vokral Sup, UST Class A Operator
Christopher Scott Martin, UST Class B Operator
Jim Gullon, UST Class B Global Operator
Bob Kolp, UST Class B Global Operator
Marc Larson, UST Class B Global Operator
James Vokral Sup, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	62	6/1/1954	Bare Steel	Steel	
2815	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Other		12/5/2015	Deferred	MLLD Line Tightness Testing	
420,000		10/6/2015			
4	28	6/1/1988	Fiberglass Reinforced Plastic	Steel	High Level Alarm
3702			Double-Walled	None	Yes
Currently in Use		6/1/1998	Not Required	Gravity Feed	Not Applicable, Impressed Current
Gasoline		12/5/2015	Continuous Interstitial Monitor	MLLD Line Tightness Testing	
2,000		10/6/2015	Other , Other		
7	62	6/1/1954	Bare Steel	Steel - Terminal Piping	
2813	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		12/5/2015	Deferred	MLLD Line Tightness Testing	
420,000		10/6/2015			

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: EXXONMOBIL BOZEMAN PRODUCTS TERMINAL
220 W GRIFFIN DR
BOZEMAN, MT 59715 GALLATIN

Contact: Chris Martin, (406) 586-6927

Sys Fac ID: 16-08730
Last Inspected On: 2/23/2016
Operating Permit Renewal Date: 5/27/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	62	6/1/1954	Bare Steel	Steel - Terminal Piping	
2811	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		12/5/2015	Deferred	MLLD Line Tightness Testing	
630,000		10/6/2015			
12	62	6/1/1954	Bare Steel	Steel - Terminal Piping	
2809	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		12/5/2015	Deferred	MLLD Line Tightness Testing	
420,000		10/6/2015			
13	62	6/1/1954	Bare Steel	Steel - Terminal Piping	
4851	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		12/5/2015	Deferred	MLLD Line Tightness Testing	
1,260,000		10/6/2015			
15	62	6/1/1954	Bare Steel	Steel - Terminal Piping	
2805	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		12/5/2015	Deferred	MLLD Line Tightness Testing	
630,000		10/6/2015			
19	62	1/1/1954	Bare Steel	Steel	
2817	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		12/5/2015	Deferred	MLLD Line Tightness Testing	
110		10/6/2015			

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: EXXONMOBIL BOZEMAN PRODUCTS TERMINAL
220 W GRIFFIN DR
BOZEMAN, MT 59715 GALLATIN

Contact: Chris Martin, (406) 586-6927

Sys Fac ID: 16-08730
Last Inspected On: 2/23/2016
Operating Permit Renewal Date: 5/27/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
21	62	1/1/1954	Bare Steel	Steel	
2819	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		12/5/2015	Deferred	MLLD Line Tightness Testing	
110		10/6/2015			
30	22	5/1/1994	Bare Steel	Steel	
2828	Yes		None	Secondary Containment Chase	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Hazardous Substance			Deferred	Continuous Interstitial Monitor	
1,000					
34	25	4/1/1991	Bare Steel	Steel	
2824	Yes		None	Secondary Containment Chase	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Hazardous Substance			Deferred	Continuous Interstitial Monitor	
10,000					
35	29	9/1/1987	Bare Steel	Steel	
2825	Yes		None	Secondary Containment Chase	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Hazardous Substance			Deferred	Continuous Interstitial Monitor	
3,000					

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: KAGY KORNER INC
1809 S TRACY AVE
BOZEMAN, MT 59715 GALLATIN

Contact: Gary Tschache, (406) 586-1079

Sys Fac ID: 16-09672
Last Inspected On: 4/8/2014
Operating Permit Renewal Date: 7/15/2017

Owners/Operators: Kagy Korner Store Inc, Owner (406)-586-1079 1809 S TRACY AVE BOZEMAN MT 59715-5736

Cathy Tafelmeyer, UST Class A Operator
Rhett Tschache, UST Class A Operator
Amber Wilkinson, UST Class A Operator
Jason Fellows, UST Class B Operator
Victoria Lynn, UST Class B Operator
Brittany Matthews, UST Class B Operator
Dee McCoy, UST Class B Operator
Megan Pielaet, UST Class B Operator
Joseph Rogers, UST Class B Operator
Trudy Smith, UST Class B Operator
Shelley Thomas, UST Class B Operator
Rhett Tschache, UST Class B Operator
Amber Wilkinson, UST Class B Operator
Ricky Yozamp, UST Class B Operator
Jennifer Ness, UST Class B Global Operator
C. Lee-Brokus Schans, UST Class B Global Operator
Lisa Tiewater, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	11/15/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1462			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		4/8/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		4/8/2014			

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: KAGY KORNER INC
1809 S TRACY AVE
BOZEMAN, MT 59715 GALLATIN

Contact: Gary Tschache, (406) 586-1079

Sys Fac ID: 16-09672
Last Inspected On: 4/8/2014
Operating Permit Renewal Date: 7/15/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	29	11/15/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1463			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		4/8/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		4/8/2014			
3	29	11/15/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1464			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		4/8/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		4/8/2014			

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: BOZEMAN DEACONESS HOSPITAL
915 HIGHLAND BLVD
BOZEMAN, MT 59715 GALLATIN

Contact: Phil Sparks, (406) 585-5089

Sys Fac ID: 16-09771
Last Inspected On: 2/13/2014
Operating Permit Renewal Date: 4/5/2017

Owners/Operators: Deaconess Hospital Bozeman, Owner (406)-585-5089 915 HIGHLAND BLVD BOZEMAN MT 59715-6902

William Buhl, UST Class A Operator
Jason Cocke, UST Class A Operator
William Buhl, UST Class B Operator
Jason Cocke, UST Class B Operator
Michael Dawson, UST Class B Operator
Jason Cocke, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	12	7/15/2004	Concrete	Flexible Plastic	High Level Alarm
4940	Yes	10/18/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor, Approved Remote Monitoring	
8,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: PANDA C STORE
621 BRIDGER DR
BOZEMAN, MT 59715 GALLATIN

Contact: William Harston, (406) 587-6280

Sys Fac ID: 16-10193
Last Inspected On: 2/17/2014
Operating Permit Renewal Date: 7/31/2017

Owners/Operators: Panda Enterprises, Owner (406)-587-6280 621 BRIDGER DR BOZEMAN MT 59715-2205

Panda Harston, UST Class A Operator
William P Harston, UST Class A Operator
Panda Harston, UST Class B Operator
William P Harston, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	1/5/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3067			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Not Listed	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
2	26	1/5/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3068			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Not Listed	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
3	26	1/5/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4542			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Not Listed	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: BLUE BASKET # 4
1035 REEVES RD
BOZEMAN, MT 59718 GALLATIN
Contact: Michele LaVigne, (406) 586-5770

Sys Fac ID: 16-13115
Last Inspected On: 2/15/2016
Operating Permit Renewal Date: 6/30/2019

Owners/Operators: Blue Basket Markets Billings, Owner (406)-252-0166 PO BOX 531
BILLINGS MT 59103-0531

Brit Miller, UST Class A Operator
Lori Anderson, UST Class B Operator
Caroline Hargis, UST Class B Operator
Carrie Hodges, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	4/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
456			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco		
2	23	4/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
457			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco		
3	23	4/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
458			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		1/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: CASEYS #5
4135 VALLEY COMMONS DR
BOZEMAN, MT 59718 GALLATIN

Contact: Gary Scales, (406) 587-0702

Sys Fac ID: 16-13775
Last Inspected On: 11/11/2013
Operating Permit Renewal Date: 2/19/2017

Owners/Operators:

Story Distributing Company, Owner	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771
Jason Shanley, Operator	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771-1201

Jason Shanley, UST Class A Operator
Lisa Anderson, UST Class B Operator
David Lingenfelter, UST Class B Operator
Damian Lewis, UST Class B Global Operator
Jason Shanley, UST Class B Global Operator
Kelly Scott Shutes, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	18	3/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3407			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000		8/7/2013			
2	18	3/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3408			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000		8/7/2013			
3	18	3/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3409			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000		8/7/2013			

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: HOLIDAY STATIONSTORE 305
1951 DURSTON RD
BOZEMAN, MT 59718 GALLATIN
Contact: Ed Huber, (406) 585-3460

Sys Fac ID: 56-13937
Last Inspected On: 9/30/2016
Operating Permit Renewal Date: 12/20/2019

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Jack Krueger Jr, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Ed Huber, UST Class B Operator
Steve Ulery, UST Class B Operator
Jeff Reed, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	17	6/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4047			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		10/2/2007	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		5/14/2010	TLS-350/Gilbarco EMC , Veeder Root		
2	17	6/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4048			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		10/2/2007	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		5/14/2010	TLS-350/Gilbarco EMC , Veeder Root		
3	17	6/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4566			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		10/2/2007	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		5/14/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: HOLIDAY STATIONSTORE 305
1951 DURSTON RD
BOZEMAN, MT 59718 GALLATIN

Contact: Ed Huber, (406) 585-3460

Sys Fac ID: 56-13937
Last Inspected On: 9/30/2016
Operating Permit Renewal Date: 12/20/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	17	6/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4567			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		10/2/2007	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		5/14/2010	TLS-350/Gilbarco EMC , Veeder Root		
5	17	6/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4051			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		10/2/2007	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		5/14/2010	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: SIME CONSTRUCTION
190 RAMSHORN DR
BOZEMAN, MT 59718 GALLATIN

Contact: Shawn Sime, (406) 580-1109

Sys Fac ID: 56-13960
Last Inspected On: 1/18/2016
Operating Permit Renewal Date: 6/29/2019

Owners/Operators: Sime Construction, Owner (406)-582-9841 190 RAMSHORN DRIVE BOZEMAN MT 59718-8181

Shawn Sime, UST Class A Operator
Matthew Wilmeth, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	16	1/1/2000	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4487		5/15/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Waste Oil		2/25/2013	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,000			LDE Series , Pneumercator		

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: COSTCO WHOLESALE GASOLINE BOZEMAN
2505 CATRON ST
BOZEMAN, MT 59718 GALLATIN
Contact: (406) 585-0383

Sys Fac ID: 60-15075
Last Inspected On: 12/19/2013
Operating Permit Renewal Date: 4/30/2017

Owners/Operators: Costco Wholesale, Owner (425)-313-8100 ATTN: LICENSING
PO BOX 35005
SEATTLE WA 98124-8990

Dennis Bock, UST Class A Operator
Kent Cramer, UST Class A Operator
Dan Martinez, UST Class A Operator
Mark Medrano, UST Class A Operator
Michael Schaeffer, UST Class A Operator
Bruce Thompson, UST Class A Operator
Nicholas White, UST Class A Operator
Pamela Williams, UST Class A Operator
Kent Cramer, UST Class B Operator
Mark Medrano, UST Class B Operator
Bruce Thompson, UST Class B Operator
Nicholas White, UST Class B Operator
Pamela Williams, UST Class B Operator
Mike Wilson, UST Class B Operator
Dennis Bock, UST Class B Global Operator
Michael Schaeffer, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	09	10/24/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5130			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
30,000					Yes

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: COSTCO WHOLESALE GASOLINE BOZEMAN
2505 CATRON ST
BOZEMAN, MT 59718 GALLATIN
Contact: (406) 585-0383

Sys Fac ID: 60-15075
Last Inspected On: 12/19/2013
Operating Permit Renewal Date: 4/30/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	09	10/24/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5131			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
30,000					Yes
3	09	10/24/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5132			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
30,000					Yes
4	05	3/25/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5282			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Hazardous Substance			Continuous Interstitial Monitor	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
1,500		11/12/2013			Yes

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: RESSLER MOTOR COMPANY
8470 HUFFINE LANE
BOZEMAN, MT 59718 GALLATIN

Contact: Richard Thomas, (406) 587-5501

Sys Fac ID: 60-15102
Last Inspected On: 6/18/2015
Operating Permit Renewal Date: 8/18/2018

Owners/Operators: Ressler Motors Company, Owner (406)-587-5501 PO BOX 400
BOZEMAN MT 59771-0400

Chad Karch, UST Class A Operator
Dennis A Franks, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	08	7/8/2008	Unknown	Flexible Plastic	
5178	Yes		None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Waste Oil			Deferred	Continuous Interstitial Monitor	
1,100			ILS-350 , Veeder Root		Yes
2	08	7/8/2008	Unknown	Flexible Plastic	High Level Alarm
5179	Yes		None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Waste Oil			Deferred	Continuous Interstitial Monitor	
1,100			ILS-350 , Veeder Root		Yes

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: TOWN PUMP INC BOZEMAN 5
29001 NORRIS RD
BOZEMAN, MT 59718 GALLATIN
Contact: (406) 587-0163

Sys Fac ID: 60-15119
Last Inspected On: 6/23/2015
Operating Permit Renewal Date: 10/27/2018

Owners/Operators: Billings Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000
Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	07	12/8/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Positive Shutoff
5191			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
14,000			TLS-350/Gilbarco EMC , Veeder Root		Yes
2	07	12/8/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Positive Shutoff
5192			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		Yes
3	07	12/8/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Positive Shutoff
5193			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
14,000			TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: TOWN PUMP INC BOZEMAN 5
29001 NORRIS RD
BOZEMAN, MT 59718 GALLATIN
Contact: (406) 587-0163

Sys Fac ID: 60-15119
Last Inspected On: 6/23/2015
Operating Permit Renewal Date: 10/27/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	07	12/8/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Positive Shutoff
5194			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		Yes
5	07	12/8/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Positive Shutoff
5195			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: TOWN PUMP BOZEMAN 7
1871 BAXTER LN
BOZEMAN, MT 59715 GALLATIN

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15205
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 7/16/2019

Owners/Operators:

Montana Growth Opportunities LLC, Owner	(406)-497-6700	600 SOUTH MAIN BUTTE MT 59701
Arnold Osmun, Operator	( )-497-6946	2917 STATE ST BUTTE MT 59701

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	03	12/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5348			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Stat. Inventory Reconcilitation	Yes
3	03	12/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5349			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
4	03	12/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5350			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: TOWN PUMP BOZEMAN 7
1871 BAXTER LN
BOZEMAN, MT 59715 GALLATIN

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15205
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 7/16/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	03	12/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5351			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
6	03	12/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5352			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: SMITHS #170 FUEL CENTER
1735 W OAK STREET
BOZEMAN, MT 59715 GALLATIN

Contact: David Harris, (801) 974-1206

Sys Fac ID: 60-15234
Last Inspected On: 3/24/2014
Operating Permit Renewal Date: 6/16/2017

Owners/Operators:

Smiths Food and Drug, Owner	(801)-974-1529	1550 S REDWOOD RD SALT LAKE CITY UT 84104-5105
David Harris, Operator	(801)-974-1206	PO BOX 244 WINNETT MT 59087-0244

Gary Dotseth, UST Class A Operator
Todd Dotseth, UST Class A Operator
David Harris, UST Class A Operator
Todd Dotseth, UST Class B Operator
Gary Dotseth, UST Class B Global Operator
David Harris, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	03	11/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5443		11/14/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/19/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
20,000		12/17/2013	TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
2	03	11/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5444		11/14/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/19/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000		12/17/2013	TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
3	03	11/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5445		11/14/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/19/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000		12/17/2013	TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: Bozeman #8 Town Pump
5050 S COTTONWOOD RD
BOZEMAN, MT 59718 GALLATIN

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15244
Last Inspected On: 2/25/2015
Operating Permit Renewal Date: 3/5/2018

Owners/Operators: Park Street Holdings LLC, Owner (406)-467-6700 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	02	8/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5479		9/15/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
20,000			TLS-450 , Veeder Root	Not Listed	
2	02	8/14/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5480		9/15/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
15,000			TLS-450 , Veeder Root	Not Listed	
3	02	8/14/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5481		9/15/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
6,000			TLS-450 , Veeder Root	Not Listed	
4	02	8/14/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5482		9/15/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
15,000			TLS-450 , Veeder Root	Not Listed	

Facility Summary in GALLATIN County in the City of BOZEMAN

Location: Bozeman #8 Town Pump
5050 S COTTONWOOD RD
BOZEMAN, MT 59718 GALLATIN

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15244
Last Inspected On: 2/25/2015
Operating Permit Renewal Date: 3/5/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	02	8/14/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5483		9/15/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
6,000			TLS-450 , Veeder Root	Not Listed	

Facility Summary in GALLATIN County in the City of GALLATIN GATEWAY

Location: CASEYS #6
47650 GALLATIN RD
GALLATIN GATEWAY, MT 59730 GALLATIN
Contact: Gary Scales, (406) 587-7438

Sys Fac ID: 16-06923
Last Inspected On: 7/1/2014
Operating Permit Renewal Date: 9/10/2017

Owners/Operators:

Story Distributing Company, Owner	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771
Jason Shanley, Operator	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771-1201

Damian Lewis, UST Class A Operator
Jason Shanley, UST Class A Operator
Cheryl Caton, UST Class B Operator
Damian Lewis, UST Class B Operator
Barbara Pozega, UST Class B Operator
Jason Shanley, UST Class B Operator
Amber Wiatt, UST Class B Operator
Kelly Scott Shutes, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	9/1/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4556			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/1/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
2	31	9/1/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4557			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/1/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of GALLATIN GATEWAY

Location: CASEYS #6
47650 GALLATIN RD
GALLATIN GATEWAY, MT 59730 GALLATIN
Contact: Gary Scales, (406) 587-7438

Sys Fac ID: 16-06923
Last Inspected On: 7/1/2014
Operating Permit Renewal Date: 9/10/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	31	9/1/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4558			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		7/1/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of GALLATIN GATEWAY

Location: CASEYS #9
76250 GALLATIN RD
GALLATIN GATEWAY, MT 59730 GALLATIN

Contact: Gary Scales, (406) 587-7438

Sys Fac ID: 16-09998
Last Inspected On: 12/3/2014
Operating Permit Renewal Date: 2/20/2018

Owners/Operators:

Story Distributing Company, Owner	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771
Jason Shanley, Operator	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771-1201

Jason Shanley, UST Class A Operator
Kristy Saul, UST Class B Operator
Jason Shanley, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	11/19/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4496			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/3/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		4/8/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	23	11/19/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4494			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		12/3/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		4/8/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	23	11/19/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4495			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/3/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/8/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of GALLATIN GATEWAY

Location: CASEYS #9
76250 GALLATIN RD
GALLATIN GATEWAY, MT 59730 GALLATIN
Contact: Gary Scales, (406) 587-7438

Sys Fac ID: 16-09998
Last Inspected On: 12/3/2014
Operating Permit Renewal Date: 2/20/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	23	11/19/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4492			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/3/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		4/8/2014	TLS-350/Gilbarco EMC , Veeder Root		
5	23	11/19/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4493			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		12/3/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		4/8/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of MANHATTAN

Location: DANHOF CHEVROLET INC
6605 AMSTERDAM RD
MANHATTAN, MT 59741 GALLATIN

Contact: Joe Danhof, (406) 282-7231

Sys Fac ID: 16-01367
Last Inspected On: 4/12/2015
Operating Permit Renewal Date: 4/16/2018

Owners/Operators: Danhof Chevrolet Inc, Owner (406)-282-7231 6605 AMSTERDAM RD MANHATTAN MT 59741-8315

Wayne Klompien, UST Class A Operator
Dennis A Franks, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	30	6/13/1986	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
800			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		4/14/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/14/2015	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
10	30	6/13/1986	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
801			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		4/14/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/14/2015	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
11	30	6/13/1986	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
802			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		4/14/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/14/2015	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of MANHATTAN

Location: DANHOF CHEVROLET INC
6605 AMSTERDAM RD
MANHATTAN, MT 59741 GALLATIN
Contact: Joe Danhof, (406) 282-7231

Sys Fac ID: 16-01367
Last Inspected On: 4/12/2015
Operating Permit Renewal Date: 4/16/2018

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
12	17	12/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3592			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		4/14/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/14/2015	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
13	17	12/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3593			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		4/14/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		4/14/2015	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of MANHATTAN

Location: THRIFTWAY SUPER STOP 12 (ME & JAN'S MINI MART III)
404 S BROADWAY ST
MANHATTAN, MT 59741 GALLATIN

Contact: (406) 284-3343

Sys Fac ID: 16-03431
Last Inspected On: 6/1/2016
Operating Permit Renewal Date: 6/12/2019

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE BUTTE MT 59701-3553

Bryan Kelsey, UST Class A Operator
Louie Sutey, UST Class A Operator
Melissa Damuth, UST Class B Operator
Jennifer Gleason, UST Class B Operator
Bryan Kelsey, UST Class B Operator
Sadye Macrow, UST Class B Operator
Dottie Nichols, UST Class B Operator
Kristin Petersen, UST Class B Operator
Dave Stine, UST Class B Operator
Faith Wiedeman, UST Class B Operator
Louie Sutey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	19	5/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
809			None	Double-Walled	Yes
Currently in Use		5/1/2007	Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	19	5/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
810			None	Double-Walled	Yes
Currently in Use		5/1/2007	Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of MANHATTAN

Location: THRIFTWAY SUPER STOP 12 (ME & JAN'S MINI MART III)
404 S BROADWAY ST
MANHATTAN, MT 59741 GALLATIN
Contact: (406) 284-3343

Sys Fac ID: 16-03431
Last Inspected On: 6/1/2016
Operating Permit Renewal Date: 6/12/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	19	5/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
811			None	Double-Walled	Yes
Currently in Use		5/1/2007	Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
5,000			TLS-350/Gilbarco EMC , Veeder Root		
7	08	12/4/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5124			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
15,000			TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in GALLATIN County in the City of MANHATTAN

Location: SCHUTTER SEED FARM, INC
3627 WOODEN SHOE RD
MANHATTAN, MT 59741 GALLATIN

Contact: Sid Schutter, (406) 284-6478

Sys Fac ID: 16-10184
Last Inspected On: 10/22/2014
Operating Permit Renewal Date: 3/26/2018

Owners/Operators:

Schutter Seed Farm, Inc, Owner	(406)-284-6478	3627 WOODEN SHOE RD MANHATTAN MT 59741-8108
Sid Schutter, Operator	(406)-284-6478	3131 WOODEN SHOE ROAD MANHATTAN MT 59741
Sid Schutter, UST Class A Operator		
Dennis A Franks, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	22	1/1/1994	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1909			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/22/2014	Automatic Tank Gauging 0.2	Deferred	
2,000			TLS-350/Gilbarco EMC , Veeder Root		
3	22	1/1/1994	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1910			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/22/2014	Automatic Tank Gauging 0.2	Deferred	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of MANHATTAN

Location: HARLOWS SCHOOL BUS SVC
1085 YADON RD
MANHATTAN, MT 59741 GALLATIN

Contact: Justin Hageness, (406) 284-4055

Sys Fac ID: 56-13969
Last Inspected On: 4/11/2014
Operating Permit Renewal Date:

Owners/Operators: HJJ Properties LLC, Owner (406)-284-4055 1085 YADON ROAD MANHATTAN MT 59741
Justin Hageness, Operator (406)-284-4055 1085 YADON ROAD MANHATTAN MT 59741

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	16	12/30/1999	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4142			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		4/14/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
1,000					
2	16	12/30/1999	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4143			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		4/14/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
500					

Facility Summary in GALLATIN County in the City of THREE FORKS

Location: THRIFTWAY CONOCO 15
5 S MAIN ST
THREE FORKS, MT 59752 GALLATIN

Contact: Fred R Norman, (406) 285-3710

Sys Fac ID: 16-00987
Last Inspected On: 5/31/2016
Operating Permit Renewal Date: 6/12/2019

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE BUTTE MT 59701-3553

Bryan Kelsey, UST Class A Operator
Louie Sutey, UST Class A Operator
Melissa Damuth, UST Class B Operator
Bryan Kelsey, UST Class B Operator
Gayle Ross, UST Class B Operator
Dave Stine, UST Class B Operator
Louie Sutey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	4/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
523			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		4/20/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		4/20/2016	TLS-350/Gilbarco EMC , Veeder Root		
2	22	4/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
524			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		4/20/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		4/20/2016	TLS-350/Gilbarco EMC , Veeder Root		
3	22	4/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
525			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		4/20/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		4/20/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of THREE FORKS

Location: THRIFTWAY CONOCO 15
5 S MAIN ST
THREE FORKS, MT 59752 GALLATIN

Contact: Fred R Norman, (406) 285-3710

Sys Fac ID: 16-00987
Last Inspected On: 5/31/2016
Operating Permit Renewal Date: 6/12/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	22	4/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
526			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		4/20/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		4/20/2016	TLS-350/Gilbarco EMC , Veeder Root		
11	22	4/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
520			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		4/20/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		4/20/2016	TLS-350/Gilbarco EMC , Veeder Root		
12	22	4/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
521			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		4/20/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
3,000		4/20/2016	TLS-350/Gilbarco EMC , Veeder Root		
13	22	4/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
522			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		4/20/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
3,000		4/20/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: CORNER CENEX
136 N CANYON ST
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: Tim Heideman, (406) 539-7111

Sys Fac ID: 16-00055
Last Inspected On: 5/13/2014
Operating Permit Renewal Date: 9/5/2017

Owners/Operators:

Jerrys Enterprises Inc, Owner	(406)-646-7735	PO BOX 669 WEST YELLOWSTONE MT 59758-0669
Timothy Heideman, Operator	(406)-646-7112	PO BOX 648 WEST YELLOWSTONE MT 59758-0648
Timothy Heideman, UST Class A Operator		
Timothy Heideman, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2263			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/13/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		5/13/2014	Gilbarco EMC Basic , Gilbarco		
2	25	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2264			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/13/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		5/13/2014	Gilbarco EMC Basic , Gilbarco		
3	25	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2265			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/13/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		5/13/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: CORNER CENEX
136 N CANYON ST
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: Tim Heideman, (406) 539-7111

Sys Fac ID: 16-00055
Last Inspected On: 5/13/2014
Operating Permit Renewal Date: 9/5/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	25	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2266			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/13/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		5/13/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: WESTGATE STATION
11 YELLOWSTONE AVE
WEST YELLOWSTONE, MT 59758 GALLATIN
Contact: (406) 646-7654

Sys Fac ID: 16-03734
Last Inspected On: 10/8/2014
Operating Permit Renewal Date: 1/14/2018

Owners/Operators: Westgate Station, Owner (406)-646-7651 PO BOX 1769
WEST YELLOWSTONE MT 59758-1769

Cole Parker, UST Class A Operator
Cole Parker, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	18	10/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3108			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		10/8/2014	TLS-350/Gilbarco EMC , Veeder Root		
10	18	10/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3109			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		4/8/2015	TLS-350/Gilbarco EMC , Veeder Root		
11	18	10/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3110			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		10/8/2014	TLS-350/Gilbarco EMC , Veeder Root		
12	18	10/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3111			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		10/8/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: MDOT WEST YELLOWSTONE
US HIGHWAY 191
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: Joe Radonich, (406) 444-9204

Sys Fac ID: 16-04057
Last Inspected On: 10/8/2014
Operating Permit Renewal Date: 3/25/2018

Owners/Operators:

MDOT Helena, Owner	(406)-444-6200	KIM JANZEN PO BOX 201001 HELENA MT 59620-1001
Joe Radonich, Operator		2701 PROSPECT AVE HELENA MT 59601
Joseph J Radonich, Operator	(406)-444-9204	MDT DEADHEAD HELENA MT 59620-0901
Jeff Gleason, UST Class A Operator		
Walt Kerttula, UST Class A Operator		
Mike Murolo, UST Class A Operator		
Joe Radonich, UST Class A Operator		
Jacob Holthues, UST Class B Operator		
Dan Stroud, UST Class B Operator		
Greg Johnson, UST Class B Global Operator		
Joe Radonich, UST Class B Global Operator		
Ken Whitaker, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	24	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4323			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/8/2014	Continuous Interstitial Monitor	Deferred	
2,000			ILS-350 , Veeder Root		
7	24	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4324			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/8/2014	Continuous Interstitial Monitor	Deferred	
6,000			ILS-350 , Veeder Root		

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: TWO TOP SNOWMOBILE RENTAL
645 GIBBON AVE
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: David McCray, (406) 646-7802

Sys Fac ID: 16-04445
Last Inspected On: 10/8/2014
Operating Permit Renewal Date: 2/27/2018

Owners/Operators: Two Top Snowmobile Rental Inc, Owner (406)-646-7802 PO BOX 798
WEST YELLOWSTONE MT 59758-0798

David McCray, UST Class A Operator
Kennedy Brown, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	9/1/1992	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1598			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/8/2014	Automatic Tank Gauging 0.2	Not Listed	
4,000			TLS-300 , Veeder Root		

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: RIVERSIDE STATION
215 CANYON ST
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: Brad or Doug Schmier, (406) 646-7735

Sys Fac ID: 16-04500
Last Inspected On: 5/12/2014
Operating Permit Renewal Date: 8/2/2017

Owners/Operators:

Jerrys Enterprises Inc, Owner	(406)-646-7735	PO BOX 669 WEST YELLOWSTONE MT 59758-0669
Bradley Schmier, Operator	(406)-646-7735	PO BOX 669 WEST YELLOWSTONE MT 59758-0669
Bradley Schmier, UST Class A Operator		
Bradley Schmier, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	17	1/1/1999	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3684			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
12,000		4/13/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	17	1/1/1999	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3685			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
8,000		4/11/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	17	1/1/1999	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3686			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		4/11/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: JERRYS ENTERPRISES INC
138 FIREHOLE LN
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: J Douglas Schmier, (406) 646-7735

Sys Fac ID: 16-04501
Last Inspected On: 5/12/2014
Operating Permit Renewal Date: 8/2/2017

Owners/Operators: Jerrys Enterprises Inc, Owner (406)-646-7735 PO BOX 669
WEST YELLOWSTONE MT 59758-0669

Bradley Schmier, UST Class A Operator
Bradley Schmier, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	26	12/11/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1414			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		10/8/2013			
6	26	12/11/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4302			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		10/8/2013			
7	26	12/11/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1416			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		10/8/2013			
8	22	6/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1417			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		5/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		10/8/2013			

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: DELAWARE NORTH PARKS SERVICES AT YELLOWSTONE LLC
1 HAMILTON LN
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: Robbie Hermanson, (406) 586-7593

Sys Fac ID: 16-06367
Last Inspected On: 6/9/2016
Operating Permit Renewal Date: 10/1/2019

Owners/Operators: Delaware North Parks Services at Yellowstone LLC, Owner (716)-858-5000 DENISE M WOOD
40 FOUNTAIN PLZ
BUFFALO NY 14202-2229

Jason Fatouros, UST Class A Operator
Debbie Friedel, UST Class A Operator
Justin Cook, UST Class B Operator
Jason Fatouros, UST Class B Operator
Debbie Friedel, UST Class B Operator
William Rawlins, UST Class B Operator
Cedar Shannon, UST Class B Operator
Ron Wilkes, UST Class B Operator
Jason Fatouros, UST Class B Global Operator
Debbie Friedel, UST Class B Global Operator
William Rawlins, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	23	6/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1277			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/9/2016	Manual Interstitial Monitor	MLLD Line Tightness Testing	
6,000		10/14/2015			
6	23	6/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1278			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		6/9/2016	Manual Interstitial Monitor	MLLD Line Tightness Testing	
2,000		10/14/2015			

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: EAGLE STORE UST
3 CANYON ST
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: Eva Eagle, (406) 646-9300

Sys Fac ID: 16-08570
Last Inspected On: 10/7/2014
Operating Permit Renewal Date: 10/8/2017

Owners/Operators: Eagle Company Inc, Owner (406)-646-9300 PO BOX 280
WEST YELLOWSTONE MT 59758-0280

Eva Eagle, UST Class A Operator
Anna Kessler, UST Class A Operator
JOSH BABROS, UST Class B Operator
JAMIE BENES, UST Class B Operator
Lee Sloan, UST Class B Operator
Anna Kessler, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	27	4/28/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3986			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/7/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		10/7/2014	TLS-300 , Veeder Root		
7	27	4/28/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3987			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/7/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		10/7/2014	TLS-300 , Veeder Root		
8	19	10/20/1997	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
843			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		10/7/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		10/7/2014	TLS-300 , Veeder Root		

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: EAGLE SERVICE UST
17 CANYON ST
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: Karen Eagle, (406) 646-9300

Sys Fac ID: 16-08571
Last Inspected On: 10/7/2014
Operating Permit Renewal Date: 10/8/2017

Owners/Operators: Eagle Company Inc, Owner (406)-646-9300 PO BOX 280
WEST YELLOWSTONE MT 59758-0280

Eva Eagle, UST Class A Operator
Marlys Merna, UST Class A Operator
JOSH BABROS, UST Class B Operator
JAMIE BENES, UST Class B Operator
Marlys Merna, UST Class B Operator
Lee Sloan, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	10/5/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
844			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/7/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		10/7/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	26	10/5/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
845			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		10/7/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		10/7/2014	TLS-350/Gilbarco EMC , Veeder Root		
7	17	6/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4018			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/7/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		10/7/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: EAGLE SERVICE UST
17 CANYON ST
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: Karen Eagle, (406) 646-9300

Sys Fac ID: 16-08571
Last Inspected On: 10/7/2014
Operating Permit Renewal Date: 10/8/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	17	6/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4019			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/7/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		10/7/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: WEST ENTRANCE BLDG 458
WEST ENTRANCE, BLDG 458
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: Tim Hudson, (307) 344-7381

Sys Fac ID: 16-08870
Last Inspected On: 6/2/2016
Operating Permit Renewal Date: 9/13/2019

Owners/Operators: National Park Service, Owner (307)-344-2333 PO BOX 168
YELLOWSTONE NATIONAL PARK WY 82190-0168

Harry Laney, UST Class A Operator
Claude W Long, UST Class A Operator
Harry Laney, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	28	8/24/1988	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1740			Double-Walled	PVC	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		5/19/2016	Continuous Interstitial Monitor	Deferred	
4,000			EECO 1000 , EMCO Electronics		
2	28	8/24/1988	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1739			Double-Walled	PVC	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		5/19/2016	Continuous Interstitial Monitor	Deferred	
4,000			EECO 1000 , EMCO Electronics		

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: TRAVELERS SERVICE CENTER
26 ELECTRIC ST
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: Brad Loomis, (406) 646-9332

Sys Fac ID: 16-09852
Last Inspected On: 7/1/2014
Operating Permit Renewal Date: 8/6/2017

Owners/Operators: Loomis Enterprises Inc, Owner (406)-646-7773 PO BOX 1110
WEST YELLOWSTONE MT 59758-1110

Bradley Loomis, UST Class A Operator
Bradley Loomis, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	4/21/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1555			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/1/2014	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
5	18	4/21/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1556			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/1/2014	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
6	18	4/21/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1557			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		7/1/2014	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: ECONO MART
307 FIREHOLE AVE
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: Merrick Young, (406) 648-1704

Sys Fac ID: 16-10356
Last Inspected On: 10/7/2014
Operating Permit Renewal Date: 3/3/2018

Owners/Operators: Firehole Holdings LLC, Owner (406)-646-7887 PO BOX 257
WEST YELLOWSTONE MT 59758-0257

Merrick Young, UST Class A Operator
Merrick Young, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	41	2/11/1975	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
847			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/9/2012	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		10/7/2014	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
2	41	2/11/1975	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
848			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/9/2012	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		10/7/2014	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
4	41	2/11/1975	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
850			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		10/9/2012	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		10/7/2014	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
5	41	2/11/1975	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
851			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Other		10/9/2012	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		10/7/2014	TLS-300 , Veeder Root		

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: ECONO MART
307 FIREHOLE AVE
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: Merrick Young, (406) 648-1704

Sys Fac ID: 16-10356
Last Inspected On: 10/7/2014
Operating Permit Renewal Date: 3/3/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	15	10/1/2001	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4438			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		10/6/2009	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		10/7/2014	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: THREE BEAR LODGE INC
217 YELLOWSTONE AVE
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: Clyde Seely, (406) 646-7353

Sys Fac ID: 16-10357
Last Inspected On: 5/12/2014
Operating Permit Renewal Date: 7/3/2017

Owners/Operators: Clyde Seely, Owner (406)-646-7365 PO BOX 1590
WEST YELLOWSTONE MT 59758-1590

Merrick Young, UST Class A Operator
Merrick Young, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	10/1/1993	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2114			None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		10/9/2013			

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: YELLOWSTONE ARCTIC YAMAHA ELECTRIC ST
208 ELECTRIC ST
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: Bill Howell, (406) 646-9636

Sys Fac ID: 16-10358
Last Inspected On: 6/15/2015
Operating Permit Renewal Date: 10/14/2018

Owners/Operators: William Howell, Owner (406)-646-9636 PO BOX 350
WEST YELLOWSTONE MT 59758-0350

William Howell, UST Class A Operator
William Howell, UST Class B Operator
William Howell, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	9/1/1992	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2305			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		10/9/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Approved Remote Monitoring	
6,000			TLS-300 , Veeder Root		

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: KIRKWOOD RANCH MOTEL TRAILER PARK
35 KIRKWOOD CRK
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: Craig Svienson, (406) 646-7200

Sys Fac ID: 16-10793
Last Inspected On: 9/9/2014
Operating Permit Renewal Date: 1/9/2018

Owners/Operators: Kirkwood Ranch LTD Partnership, Owner (406)-646-7200 35 KIRKWOOD CRK
WEST YELLOWSTONE MT 59758-9770

Kyle Burden, UST Class A Operator
Douglas Sveinson, UST Class A Operator
Kyle Burden, UST Class B Operator
Douglas Sveinson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	16	8/1/2000	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4237		6/19/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		6/19/2014	Automatic Tank Gauging 0.1	Continuous Interstitial Monitor	
6,000			TLS-300 , Veeder Root		
6	16	8/1/2000	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4580		6/19/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		6/19/2014	Automatic Tank Gauging 0.1	Continuous Interstitial Monitor	
2,000			TLS-300 , Veeder Root		

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: YELLOWSTONE HOLIDAY RESORT
16990 HEBGEN LAKE RD PO BOX 759
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: Ellen Hodsgon, (801) 467-3600

Sys Fac ID: 16-11066
Last Inspected On: 2/17/2016
Operating Permit Renewal Date: 3/9/2019

Owners/Operators: Grayling Partners LC, Owner (801)-467-3600 2159 S 700 E STE 200
SALT LAKE CITY UT 84106

Bradley Campbell, UST Class A Operator
James Hynes, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	17	10/1/1999	Concrete	Fiberglass	
4132	Yes	6/3/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable, Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
1,500			Gilbarco EMC Basic , Gilbarco		

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: RENDEZVOUS SNOWMOBILE RENTALS
429 YELLOWSTONE AVE
WEST YELLOWSTONE, MT 59758 GALLATIN

Contact: Randall Roberson, (406) 646-9564

Sys Fac ID: 16-11619
Last Inspected On: 11/6/2015
Operating Permit Renewal Date: 4/5/2019

Owners/Operators: Rendezvous Snowmobile Rentals, Owner (406)-646-9564 PO BOX 580
WEST YELLOWSTONE MT 59758-0580

Scott Johnson, UST Class A Operator
Scott Johnson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	10/1/1993	Cathodically Protected Steel	Unknown	Flapper Valve (Auto Shutoff)
2350			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/6/2015	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-300 , Veeder Root		

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: LIONSHEAD RESORT
1545 TARGHEE PASS HWY
WEST YELLOWSTONE, MT 59758 GALLATIN

Sys Fac ID: 16-12923
Last Inspected On: 5/18/2015
Operating Permit Renewal Date:

Contact: Jerry Oksa, (406) 646-9584

Owners/Operators: Yellowstone Rental Properties LLC, Owner (406)-646-7606 547 GARDEN AVE
BILLINGS MT 59101-5735

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	11/1/1992	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3391			None	none	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		5/18/2015	Vapor Monitoring	Deferred	
10,000					

Facility Summary in GALLATIN County in the City of WEST YELLOWSTONE

Location: DNC Parks & Resorts of West Yellowstone
315 YELLOWSTONE AVE
WEST YELLOWSTONE, MT 59758 GALLATIN

Sys Fac ID: 16-13528
Last Inspected On: 3/30/2016
Operating Permit Renewal Date: 3/30/2019

Contact: Jason Fatouros, (406) 580-9652

Owners/Operators: DNC Parks & Resorts Of West Yellowstone Inc, Owner (716)-858-5000 ATTN: LICENSING
40 FOUNTAIN PLZ
BUFFALO NY 14202-2229

Karmon Bryant, UST Class A Operator
Jason Fatouros, UST Class A Operator
Debbie Friedel, UST Class A Operator
Karmon Bryant, UST Class B Operator
Paul Campbell, UST Class B Operator
Justin Cook, UST Class B Operator
Jason Fatouros, UST Class B Operator
Debbie Friedel, UST Class B Operator
Cedar Shannon, UST Class B Operator
William Watson, UST Class B Operator
Karmon Bryant, UST Class B Global Operator
Jason Fatouros, UST Class B Global Operator
Debbie Friedel, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	9/10/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2306			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		5/18/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		12/29/2015	TLS-300 , Veeder Root		

Facility Summary in GARFIELD County in the City of JORDAN

Location: FARMERS UNION OIL CO JORDAN
MT HIGHWAY 200
JORDAN, MT 59337 GARFIELD
Contact: Robert Wilson, (406) 557-2215

Sys Fac ID: 17-05702
Last Inspected On: 7/21/2014
Operating Permit Renewal Date: 8/19/2017

Owners/Operators: Farmers Union Oil Co Jordan, Owner (406)-557-2215 PO BOX 449
JORDAN MT 59337-0449

David Del Moro, UST Class A Operator
Robert K Wilson, UST Class A Operator
Robert K Wilson, UST Class B Operator
David Del Moro, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	17	12/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
941			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/30/2008	Manual Interstitial Monitor	Automatic Tank Gauging 0.2	
12,000		1/16/2015	TS-550 EVO , Incon	Continuous Interstitial Monitor	
7	17	12/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
942			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/30/2008	Manual Interstitial Monitor	Automatic Tank Gauging 0.2	
4,100		1/17/2015	TS-550 EVO , Incon	Continuous Interstitial Monitor	
8	17	12/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
943			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		1/30/2008	Manual Interstitial Monitor	Continuous Interstitial Monitor	
4,100					

Facility Summary in GARFIELD County in the City of JORDAN

Location: FARMERS UNION OIL CO JORDAN
MT HIGHWAY 200
JORDAN, MT 59337 GARFIELD
Contact: Robert Wilson, (406) 557-2215

Sys Fac ID: 17-05702
Last Inspected On: 7/21/2014
Operating Permit Renewal Date: 8/19/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	17	12/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
944			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		1/30/2008	Manual Interstitial Monitor	Automatic Tank Gauging 0.2	
3,760		1/19/2015	TS-550 EVO , Incon	Continuous Interstitial Monitor	
10	17	12/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
945			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		1/30/2008	Manual Interstitial Monitor	Continuous Interstitial Monitor	
7,900					
11	17	12/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
946			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		1/30/2008	Manual Interstitial Monitor	Automatic Tank Gauging 0.2	
4,100		1/17/2015	TS-550 EVO , Incon	Continuous Interstitial Monitor	

Facility Summary in GARFIELD County in the City of JORDAN

Location: FELLMANS HARDWARE INC
MT HIGHWAY 200
JORDAN, MT 59337 GARFIELD
Contact: Richard Galla, (406) 557-2392

Sys Fac ID: 17-10707
Last Inspected On: 9/27/2016
Operating Permit Renewal Date: 11/7/2016

Owners/Operators: Fellmans Hardware Inc, Owner (406)-557-2206 C CORP
PO BOX 344
JORDAN MT 59337-0344

Kenneth Ellington, UST Class A Operator
Kenneth Ellington, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4311		10/17/2013	None	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000					
6	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4312		10/17/2013	None	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
7	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4313		10/17/2013	None	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000					

Facility Summary in GARFIELD County in the City of JORDAN

Location: FARMERS UNION OIL CO JORDAN 2
BRUSETT RD WEST
JORDAN, MT 59337 GARFIELD
Contact: Robert Wilson, (406) 557-2215

Sys Fac ID: 60-15243
Last Inspected On: 5/21/2015
Operating Permit Renewal Date: 6/1/2018

Owners/Operators: Farmers Union Oil Co Jordan, Owner (406)-557-2215 PO BOX 449
JORDAN MT 59337-0449

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	02	10/28/2014	Aboveground Tank	Flexible Plastic	
5498	Yes	10/28/2014	None	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
15,000		10/28/2014	TS-550 EVO , Incon	Not Listed	
2	02	10/28/2014	Aboveground Tank	Flexible Plastic	
5499	Yes	10/28/2014	None	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
15,000		10/28/2014	TS-550 EVO , Incon	Not Listed	
3	02	10/28/2014	Aboveground Tank	Flexible Plastic	
5500	Yes	10/28/2014	None	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
15,000		10/28/2014	TS-550 EVO , Incon	Not Listed	

Facility Summary in GLACIER County in the City of BABB

Location: THRONSONS STORE
US HIGHWAY 89
BABB, MT 59411 GLACIER
Contact: Michael Thronson, (406) 732-5530

Sys Fac ID: 18-03871
Last Inspected On: 6/12/2014
Operating Permit Renewal Date: 9/3/2017

Owners/Operators: Thronsons Store, Owner (406)-732-5530 PO BOX 169
BABB MT 59411-0169

Michael Thronson, UST Class A Operator
Michael Thronson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	12/31/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4401			Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/28/2014	Manual Interstitial Monitor	MLLD Line Tightness Testing	
7,000		5/28/2014			
2	26	12/31/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4402			Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/28/2014	Manual Interstitial Monitor	MLLD Line Tightness Testing	
3,000		5/28/2014			
3	26	12/31/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4403			Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/28/2014	Manual Interstitial Monitor	MLLD Line Tightness Testing	
8,000		5/28/2014			

Facility Summary in GLACIER County in the City of BROWNING

Location: SCHOOL DIST 9 MAINTENANCE COMPLEX
BOUNDARY ST
BROWNING, MT 59417 GLACIER

Contact: Wayne Hall, (406) 338-2952

Sys Fac ID: 18-03868
Last Inspected On: 3/16/2016
Operating Permit Renewal Date: 3/22/2019

Owners/Operators:

School Dist 9 Browning, Owner	(406)-338-2952	PO BOX 610 BROWNING MT 59417-0610
Wayne Hall, Operator	(406)-338-2952	742 BOARDING SCHOOL RD BROWNING MT 59417
Wayne Hall, UST Class A Operator		
Wayne Hall, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	30	11/29/1986	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
4130			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/5/2013	Automatic Tank Gauging 0.2	Deferred	
8,000			Gilbarco EMC Basic , Gilbarco		
3	27	11/28/1989	Steel Clad	Steel	Flapper Valve (Auto Shutoff)
4131			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		4/5/2013	Automatic Tank Gauging 0.2	Deferred	
8,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in GLACIER County in the City of BROWNING

Location: PARK CAFE AND GROCERY
3147 US HWY 89 W HC 72 BOX 5
BROWNING, MT 59417 GLACIER

Contact: Keith Hilton, (406) 892-2121

Sys Fac ID: 18-06436
Last Inspected On: 5/26/2015
Operating Permit Renewal Date: 12/31/2017

Owners/Operators:

Hilton Family Corporation, Owner	(406)-892-5589	PO BOX 2895 COLUMBIA FALLS MT 59912
Keith Hilton, Operator	(406)-250-1193	HC 72 BOX 5 BROWNING MT 59417
Keith Hilton, UST Class A Operator		
Keith Hilton, UST Class B Operator		

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
1	25	11/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1382			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		5/7/2015	TLS-350/Gilbarco EMC , Veeder Root		
2	25	11/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1380			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		5/7/2015	TLS-350/Gilbarco EMC , Veeder Root		
3	25	11/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1381			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		5/7/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GLACIER County in the City of BROWNING

Location: TOWN PUMP INC BROWNING 2
US HIGHWAY 89
BROWNING, MT 59417 GLACIER

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 18-08677
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 4/1/2019

Owners/Operators: Major Brands Distributing Imports Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	6/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2467			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/26/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		11/30/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	21	6/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2465			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/26/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		11/30/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	21	6/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2466			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/4/2009	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		11/30/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GLACIER County in the City of BROWNING

Location: TOWN PUMP INC BROWNING 2
US HIGHWAY 89
BROWNING, MT 59417 GLACIER

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 18-08677
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 4/1/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	21	6/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4888			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/26/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		11/30/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
13	21	6/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2463			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/26/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		12/1/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
14	13	8/14/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4859			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/4/2009	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		12/1/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
15	13	8/14/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4860			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/26/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		12/1/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GLACIER County in the City of BROWNING

Location: SCHOOL DIST 9 TRANSPORTATION DEPT
829 SW BOUNDARY ST
BROWNING, MT 59417 GLACIER

Contact: Wayne Hall, (406) 338-2952

Sys Fac ID: 18-12747
Last Inspected On: 3/19/2016
Operating Permit Renewal Date: 3/22/2019

Owners/Operators:

School Dist 9 Browning, Owner	(406)-338-2952	PO BOX 610 BROWNING MT 59417-0610
Wayne Hall, Operator	(406)-338-2952	742 BOARDING SCHOOL RD BROWNING MT 59417
Wayne Hall, UST Class A Operator		
Wayne Hall, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	7/1/1992	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1900		3/16/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Waste Oil		3/16/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
1,000		9/8/2009	Gilbarco EMC Basic , Gilbarco		
2	24	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1898			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/16/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		9/8/2009	Gilbarco EMC Basic , Gilbarco		
3	24	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1899			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/16/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		9/8/2009	Gilbarco EMC Basic , Gilbarco		

Facility Summary in GLACIER County in the City of BROWNING

Location: GLACIER WAY CONVENIENCE STORE
STARR SCHOOL RD & DUCK LAKE RD 200 MT HWY 464
BROWNING, MT 59417 GLACIER

Contact: toney sitzman, (406) 338-7163

Sys Fac ID: 18-13768
Last Inspected On: 10/21/2014
Operating Permit Renewal Date: 12/20/2017

Owners/Operators:

Pat Schildt, Owner	(406)-338-7163	PO BOX 1777 BROWNING MT 59417-1777
Violet Schildt, Owner	(406)-338-7163	PO BOX 1777 BROWNING MT 59417-1777

Stacey Keller, UST Class A Operator
Charles Lafley, UST Class A Operator
Harold Schildt, UST Class A Operator
Stacey Keller, UST Class B Global Operator
Charles Lafley, UST Class B Global Operator
Harold Schildt, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	9/25/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3425		4/23/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline		7/9/2008	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
2	20	9/25/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3426		4/23/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel		7/9/2008	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
15,000			TLS-350/Gilbarco EMC , Veeder Root		
3	20	9/25/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3427		4/23/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline		7/9/2008	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GLACIER County in the City of BROWNING

Location: GLACIER FAMILY FOODS
601 SE BOUNDARY ST
BROWNING, MT 59417 GLACIER

Contact: Joseph Bremner, (406) 338-3132

Sys Fac ID: 60-15286
Last Inspected On: 10/12/2016
Operating Permit Renewal Date: 10/14/2019

Owners/Operators: Siyeh Development Corporation, Owner (406)-338-5669 PO BOX 1989 BROWNING MT 59417

Joseph Bremner, UST Class A Operator
Joseph Bremner, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	01	10/1/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5673		6/27/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
12,000			TS-550 EVO , Incon	Not Listed	Yes
2	01	10/1/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5674		6/27/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
8,000			TS-550 EVO , Incon	Not Listed	Yes
3	01	10/1/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5675		6/27/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	Yes
20,000			TS-550 EVO , Incon	Not Listed	Yes
4	01	10/1/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5676		6/27/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	Yes
8,000			TS-550 EVO , Incon	Not Listed	Yes

Facility Summary in GLACIER County in the City of CUT BANK

Location: CUT BANK MUNICIPAL AIRPORT
2705 VALIER HIGHWAY
CUT BANK, MT 59427 GLACIER

Contact: Dan McCoy, (406) 873-8683

Sys Fac ID: 18-00137
Last Inspected On: 8/12/2016
Operating Permit Renewal Date: 1/31/2017

Owners/Operators: Cut Bank Airport Authority, Owner (406)-873-8683 2705 VALIER HWY CUT BANK MT 59427

Roy Nollkamper, UST Class A Operator
David Ries, UST Class A Operator
Roy Nollkamper, UST Class B Operator
David Ries, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	19	11/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
793		4/19/2013	None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Jet Fuel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-300 , Veeder Root		
9	19	11/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
794		4/19/2013	None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Aviation Gas			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-300 , Veeder Root		

Facility Summary in GLACIER County in the City of CUT BANK

Location: KENNYS SUPER SERVICE
401 E MAIN ST
CUT BANK, MT 59427 GLACIER

Contact: Randy Fetters, (406) 873-2432

Sys Fac ID: 18-00321
Last Inspected On: 8/20/2014
Operating Permit Renewal Date: 11/4/2017

Owners/Operators: Kennys Super Service, Owner (406)-873-2432 401 E MAIN ST
CUT BANK MT 59427-3014

Randall Fetters, UST Class A Operator
Randall Fetters, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	6/13/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1471			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		3/12/2014	Automatic Tank Gauging 0.2	Deferred	
6,000			EECO 1500 , EMCO Electronics		
2	31	6/13/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1472			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		3/12/2014	Automatic Tank Gauging 0.2	Deferred	
6,000			EECO 1500 , EMCO Electronics		

Facility Summary in GLACIER County in the City of CUT BANK

Location: TOWN PUMP INC CUT BANK 2
510 W MAIN ST
CUT BANK, MT 59427 GLACIER

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 18-03417
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 4/1/2019

Owners/Operators: Town Pump O Mat of Cut Bank Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	3/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2459			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		12/2/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	23	3/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2460			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		12/2/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	23	3/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2461			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		12/2/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GLACIER County in the City of CUT BANK

Location: TOWN PUMP INC CUT BANK 2
510 W MAIN ST
CUT BANK, MT 59427 GLACIER

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 18-03417
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 4/1/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	23	3/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2462			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		12/2/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	16	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4185			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		12/2/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	16	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4186			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		12/2/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GLACIER County in the City of CUT BANK

Location: BEN TAYLOR INC UST
201 BN INDUSTRIAL SITE
CUT BANK, MT 59427 GLACIER

Contact: Pete Barbie, (406) 873-2812

Sys Fac ID: 18-04137
Last Inspected On: 11/11/2016
Operating Permit Renewal Date: 11/17/2019

Owners/Operators: Ben Taylor Inc, Owner (800)-824-8366 PO BOX 810 SHELBY MT 59474-0810

Shannon Gabbard, UST Class A Operator
Shannon Gabbard, UST Class B Operator
Gail Mullennax, UST Class B Operator
Gregory Taylor, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
16	16	10/29/2000	Unknown	Flexible Plastic	
4241	Yes	4/18/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
34,000			Gilbarco EMC Basic , Gilbarco		
17	16	10/29/2000	Unknown	Flexible Plastic	
4242	Yes	4/18/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
11,700			Gilbarco EMC Basic , Gilbarco		
18	16	10/29/2000	Unknown	Flexible Plastic	
4243	Yes	4/18/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,500			Gilbarco EMC Basic , Gilbarco		
19	16	10/29/2000	Unknown	Flexible Plastic	
4244	Yes	4/18/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
34,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in GLACIER County in the City of CUT BANK

Location: BEN TAYLOR INC UST
201 BN INDUSTRIAL SITE
CUT BANK, MT 59427 GLACIER

Contact: Pete Barbie, (406) 873-2812

Sys Fac ID: 18-04137
Last Inspected On: 11/11/2016
Operating Permit Renewal Date: 11/17/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
20	16	10/29/2000	Unknown	Flexible Plastic	
4245	Yes	4/18/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,500			Gilbarco EMC Basic , Gilbarco		
21	16	10/29/2000	Unknown	Flexible Plastic	
4246	Yes	4/18/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
11,700			Gilbarco EMC Basic , Gilbarco		

Facility Summary in GLACIER County in the City of CUT BANK

Location: SIMONS PETROLEUM
813 E RAILROAD ST
CUT BANK, MT 59427 GLACIER
Contact: Steve Nelson, (406) 873-4612

Sys Fac ID: 56-13775
Last Inspected On: 4/3/2014
Operating Permit Renewal Date: 7/30/2017

Owners/Operators: Ben Taylor Inc, Owner (800)-824-8366 PO BOX 810
SHELBY MT 59474-0810

Pat Simons, UST Class A Operator
Joseph Pehan, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	10/31/1997	Bare Steel	Flexible Plastic	
1928	Yes	3/2/2012	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	19	10/31/1997	Bare Steel	Flexible Plastic	
1929	Yes	3/2/2012	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	04	3/1/2012	Unknown	Flexible Plastic	
5494	Yes	3/2/2012	None	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.2	
11,800			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GLACIER County in the City of CUT BANK

Location: TOWN PUMP OF CUT BANK #3
1119 E MAIN ST
CUT BANK, MT 59427 GLACIER

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15144
Last Inspected On: 7/18/2015
Operating Permit Renewal Date: 12/11/2018

Owners/Operators: Manhattan Holdings LLC, Owner (406)-497-6946 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	06	7/3/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5227			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	06	7/3/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5228			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	06	7/3/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5229			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in GLACIER County in the City of EAST GLACIER PARK

Location: SEARS MOTEL & GIFT SHOP
1023 HIGHWAY 49 N
EAST GLACIER PARK, MT 59434 GLACIER

Sys Fac ID: 18-03870
Last Inspected On: 5/26/2015
Operating Permit Renewal Date: 12/31/2017

Contact: Judy Jones, (406) 226-4432

Owners/Operators: Judy Jones, Owner (406)-226-4432 PO BOX 275
EAST GLACIER PARK MT 59434-0275

Judy Jones, UST Class A Operator
Judy Jones, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	9/28/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1453			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
2,000			Gilbarco EMC Basic , Gilbarco		
3	26	9/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1454			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
2,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in GLACIER County in the City of EAST GLACIER PARK

Location: GLACIER WAY C-STORE #2
330 W CENTRAL AVE PO BOX 129
EAST GLACIER PARK, MT 59434 GLACIER

Contact: (406) 338-2575

Sys Fac ID: 18-05813
Last Inspected On: 1/13/2015
Operating Permit Renewal Date: 3/13/2018

Owners/Operators:

Glacier Park 66 INC, Owner	(406)-338-2575	PO BOX 1609 BROWNING MT 59417
Tony Sitzmann, Operator	(406)-226-5504	PO BOX 129 EAST GLACIER PARK MT 59434-0129

Randy Livingston, UST Class A Operator
Michael Sherwood, UST Class A Operator
Troy Wilson, UST Class A Operator
Randy Livingston, UST Class B Operator
Michael Sherwood, UST Class B Operator
Troy Wilson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	19	1/3/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4441			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/10/2008	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	ELLD Line Tightness Testing, Not Listed	
20,000		12/10/2008	Gilbarco EMC Basic , Gilbarco		
5	19	1/3/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4442			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/10/2008	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	ELLD Line Tightness Testing, Not Listed	
12,000		12/10/2008	Gilbarco EMC Basic , Gilbarco		

Facility Summary in GLACIER County in the City of EAST GLACIER PARK

Location: GLACIER WAY C-STORE #2
330 W CENTRAL AVE PO BOX 129
EAST GLACIER PARK, MT 59434 GLACIER

Contact: (406) 338-2575

Sys Fac ID: 18-05813
Last Inspected On: 1/13/2015
Operating Permit Renewal Date: 3/13/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	19	1/3/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4443			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/10/2008	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	ELLD Line Tightness Testing, Not Listed	
12,000		12/10/2008	Gilbarco EMC Basic , Gilbarco		

Facility Summary in GLACIER County in the City of EAST GLACIER PARK

Location: BEAR TRACK TRAVEL CENTER
20958 US HIGHWAY 2
EAST GLACIER PARK, MT 59434 GLACIER

Contact: Clifford Fortune, (406) 226-5504

Sys Fac ID: 56-13933
Last Inspected On: 3/24/2016
Operating Permit Renewal Date: 6/30/2019

Owners/Operators:

Fortune Development Corp, Owner	(406)-226-5504	PO BOX 468 EAST GLACIER PARK MT 59434-0468
Clifford J Fortune, Operator	(406)-226-5504	20958 HIGHWAY 2 EAST GLACIER PARK MT 59434
Julie Fortune, UST Class A Operator		
Jim Fortune, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	17	6/1/1999	Unknown	Flexible Plastic	High Level Alarm
4068	Yes		Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-300 , Veeder Root		
2	17	6/1/1999	Unknown	Flexible Plastic	High Level Alarm
4069	Yes		Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-300 , Veeder Root		
3	09	9/14/2007	Concrete	Flexible Plastic	High Level Alarm
5126	Yes		Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-300 , Veeder Root		Yes

Facility Summary in GLACIER County in the City of SAINT MARY

Location: ST MARY LODGE
US HIGHWAY 89 ST MARY LAKE
SAINT MARY, MT 59417 GLACIER

Contact: Walter Kochansky, (406) 732-4431

Sys Fac ID: 18-01907
Last Inspected On: 6/12/2014
Operating Permit Renewal Date: 10/20/2017

Owners/Operators:

Glacier Park Inc, Owner	(406)-226-5631	PO BOX 147 EAST GLACIER PARK MT 59434
Glacier Park Inc, Operator	(406)-226-5631	PO BOX 147 EAST GLACIER PARK MT 59434

Jon Noe, UST Class A Operator
Bob Hines, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	6/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
453			None	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/29/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
7,000		10/17/2007	TLS-350/Gilbarco EMC , Veeder Root		
2	26	6/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
454			None	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/29/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
3,000		10/17/2011	TLS-350/Gilbarco EMC , Veeder Root		
3	26	6/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
451			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/29/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000		10/17/2007	TLS-350/Gilbarco EMC , Veeder Root		
4	26	6/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
452			None	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/29/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000		10/17/2007	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in GLACIER County in the City of SAINT MARY

Location: SAINT MARY RANGER STATION
73 HUDSON BAY RD
SAINT MARY, MT 59417 GLACIER

Contact: Mark Hickcox, (406) 732-7724

Sys Fac ID: 18-02745
Last Inspected On: 3/24/2016
Operating Permit Renewal Date: 4/4/2019

Owners/Operators: National Park Service, Owner (406)-732-7724 DEPT OF INTERIOR
73 HUDSON BAY RD
BROWNING MT 59417

Mark Hickcox, UST Class A Operator
Jeff Wysong, UST Class A Operator
Mark Hickcox, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	29	7/1/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1221		12/20/2012	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/28/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		11/3/2015	TLS-350/Gilbarco EMC , Veeder Root		
6	01	10/1/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5620		10/28/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Deferred	
10,000			TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in GOLDEN VALLEY County in the City of LAVINA

Location: FARMERS UNION TRADING CO - LAVINA
4666 MT HIGHWAY 3
LAVINA, MT 59046 GOLDEN VALLEY
Contact: Sid Boe, (406) 636-4005

Sys Fac ID: 19-13681
Last Inspected On: 6/15/2016
Operating Permit Renewal Date: 10/24/2019

Owners/Operators: Farmers Union Trading Co Columbus, Owner (406)-322-5618 PO BOX 509
COLUMBUS MT 59019-0509

Jennifer Calovis, UST Class A Operator
Jacob Granger, UST Class B Operator
Jennifer Calovis, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	3/1/1996	Unknown	Flexible Plastic	
3381	Yes	10/16/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
10,000			ILS-350 , Veeder Root		
2	20	3/1/1996	Unknown	Flexible Plastic	
3382	Yes	10/16/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
10,000			ILS-350 , Veeder Root		

Facility Summary in GOLDEN VALLEY County in the City of RYEGATE

Location: RYEGATE PUBLIC SCHOOLS DIST 1
207 2ND AVE W PO BOX 129
RYEGATE, MT 59074 GOLDEN VALLEY

Contact: Penny Stradtman, (406) 568-2211

Sys Fac ID: 19-07975
Last Inspected On: 4/19/2016
Operating Permit Renewal Date: 6/4/2019

Owners/Operators: School Dist 1 Ryegate, Owner (406)-568-2211 PO BOX 129
RYEGATE MT 59074-0129

Thomas Bracha, UST Class A Operator
Penny Stradtman, UST Class A Operator
Thomas Bracha, UST Class B Operator
Penny Stradtman, UST Class B Operator
Thomas Bracha, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	20	8/1/1996	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1870	Yes	4/19/2016	None	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
5,000		7/31/2014	TLS-300 , Veeder Root		

Facility Summary in GOLDEN VALLEY County in the City of RYEGATE

Location: SUPER D GROCERY
203 E RAILWAY AVE
RYEGATE, MT 59074 GOLDEN VALLEY

Sys Fac ID: 19-13735
Last Inspected On: 9/22/2015
Operating Permit Renewal Date: 12/10/2018

Contact: Super D, (406) 568-2378

Owners/Operators:

Super D Grocery Inc, Owner	(406)-568-2378	PO BOX 170 RYEGATE MT 59074
Super D Grocery Inc, Operator	(406)-568-2378	PO BOX 170 RYEGATE MT 59074
Peggy Sutton, UST Class A Operator		
Peggy Sutton, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	4/8/1996	Unknown	Flexible Plastic	High Level Alarm
3462	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	17	12/1/1998	Unknown	Flexible Plastic	High Level Alarm
3727	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	17	12/1/1998	Unknown	Flexible Plastic	High Level Alarm
3728	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in GRANITE County in the City of DRUMMOND

Location: FICS KWIK SIX
410 E FRONT ST
DRUMMOND, MT 59832 GRANITE
Contact: Todd Fickler, (406) 846-3970

Sys Fac ID: 20-03192
Last Inspected On: 7/19/2016
Operating Permit Renewal Date: 10/14/2019

Owners/Operators: Fickler Oil Co Inc Deer Lodge, Owner (406)-846-3970 725 MAVERICK LN
DEER LODGE MT 59722-2347

Bonnie Cyr, UST Class A Operator
Deanna Huberg, UST Class A Operator
Judy Rasmussen, UST Class A Operator
Bonnie Cyr, UST Class B Operator
Todd Flicker, UST Class B Operator
Deanna Huberg, UST Class B Operator
Judy Rasmussen, UST Class B Operator
Dolly Brewer, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	06	7/1/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5264			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		11/18/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
11	06	7/1/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5265			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000		11/18/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in GRANITE County in the City of DRUMMOND

Location: FICS KWIK SIX
410 E FRONT ST
DRUMMOND, MT 59832 GRANITE

Contact: Todd Fickler, (406) 846-3970

Sys Fac ID: 20-03192
Last Inspected On: 7/19/2016
Operating Permit Renewal Date: 10/14/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
12	06	7/1/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5266			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		11/18/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
13	06	7/1/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5267			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000		11/18/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in GRANITE County in the City of DRUMMOND

Location: MOUNTAIN WEST CO OP
350 E FRONT ST
DRUMMOND, MT 59832 GRANITE

Contact: Chuck Thompson, (406) 543-8383

Sys Fac ID: 20-03611
Last Inspected On: 1/20/2016
Operating Permit Renewal Date: 1/25/2019

Owners/Operators:

Mountain West Coop - Drummond, Owner	(406)-288-3219	PO BOX 297 DRUMMOND MT 59832
John Thompson, Operator	(406)-665-1728	4570 N RESERVE MISSOULA MT 59808

John Thompson, UST Class A Operator
Robin Cochrell, UST Class B Operator
Robin McCurdy, UST Class B Operator
John Thompson, UST Class B Operator
John Thompson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	56	6/15/1960	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4461			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		3/9/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		1/19/2016	Gilbarco EMC Basic , Gilbarco		
6	56	6/15/1960	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1458			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/9/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		1/19/2016	Gilbarco EMC Basic , Gilbarco		
7	45	6/16/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
1459			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/9/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		1/19/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in GRANITE County in the City of DRUMMOND

Location: MOUNTAIN WEST CO OP
350 E FRONT ST
DRUMMOND, MT 59832 GRANITE

Contact: Chuck Thompson, (406) 543-8383

Sys Fac ID: 20-03611
Last Inspected On: 1/20/2016
Operating Permit Renewal Date: 1/25/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	25	5/13/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1460			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		3/9/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		1/19/2016	Gilbarco EMC Basic , Gilbarco		
9	25	5/13/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1461			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		3/9/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		1/19/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in GRANITE County in the City of PHILIPSBURG

Location: SUNSHINE STATION 417
3830 MT HIGHWAY 1
PHILIPSBURG, MT 59858 GRANITE

Contact: Bob Derosia, (406) 859-3450

Sys Fac ID: 20-05771
Last Inspected On: 11/14/2014
Operating Permit Renewal Date: 2/11/2018

Owners/Operators: Hi Noon Petroleum Missoula, Owner (406)-532-0381 PO BOX 7578 MISSOULA MT 59807-7578

Randy Livingston, UST Class A Operator
Keith Dowling, UST Class B Operator
Bill Dirkes, UST Class B Global Operator
Randy Livingston, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	33	4/27/1983	Bare Steel	Flexible Plastic	High Level Alarm
1313			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/26/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					
2	33	4/27/1983	Bare Steel	Flexible Plastic	High Level Alarm
4516			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/26/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					
3	17	9/20/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4517			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/26/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					

Facility Summary in GRANITE County in the City of PHILIPSBURG

Location: PINTLER PETROLEUM INC
906 W BROADWAY RD
PHILIPSBURG, MT 59858 GRANITE

Contact: Bill Antonioli, (406) 859-3164

Sys Fac ID: 56-13983
Last Inspected On: 9/18/2014
Operating Permit Renewal Date: 10/7/2017

Owners/Operators: William Antonioli, Owner (406)-859-3164 PO BOX 486
PHILIPSBURG MT 59858-0486

William Antonioli, UST Class A Operator
William Antonioli, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	16	9/1/2000	Unknown	Flexible Plastic	
4215	Yes	9/17/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
12,000					
2	16	9/1/2000	Unknown	Flexible Plastic	
4216	Yes	9/17/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000					
3	16	9/1/2000	Unknown	Flexible Plastic	
4217	Yes	9/17/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
20,000					
4	16	9/1/2000	Unknown	Flexible Plastic	
4218	Yes	9/17/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
24,000					

Facility Summary in HILL County in the City of HAVRE

Location: ZIP TRIP 48
911 11TH ST W
HAVRE, MT 59501 HILL

Contact: Rick Bates, (509) 535-7701

Sys Fac ID: 21-00089
Last Inspected On: 4/8/2015
Operating Permit Renewal Date: 6/27/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Sean Hurley, UST Class A Operator
Tom Savas, UST Class A Operator
Luci Tuttle, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	05	10/1/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5341			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
15,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes
4	05	10/1/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5342			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes
5	05	10/1/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5343			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes

Facility Summary in HILL County in the City of HAVRE

Location: ZIP TRIP 49
1004 1ST ST
HAVRE, MT 59501 HILL
Contact: (406) 265-9812

Sys Fac ID: 21-00103
Last Inspected On: 11/10/2016
Operating Permit Renewal Date: 12/4/2019

Owners/Operators: CHS Inc - Spokane Valley, Owner (509)-535-7701 16124 E MARIETTA LANE SPOKANE WA 99213

Cenex Zip Trip, Operator (509)-535-7701 16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Sean Hurley, UST Class A Operator
Tom Savas, UST Class A Operator
Luci Tuttle, UST Class B Operator
Alex Henson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	03	5/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5405		5/1/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
5	03	5/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5406		5/1/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
6	03	5/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5407		5/1/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in HILL County in the City of HAVRE

Location: STROMBERGS SINCLAIR
1200 1ST ST
HAVRE, MT 59501 HILL

Contact: Howard Stromberg, (406) 265-3441

Sys Fac ID: 21-02166
Last Inspected On: 11/10/2016
Operating Permit Renewal Date: 12/13/2019

Owners/Operators: Stromberg Enterprises Inc, Owner (406)-265-2824 PO BOX 608
HAVRE MT 59501-0608

Howard O Stromberg, UST Class A Operator
Howard O Stromberg, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	17	3/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3965			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
9	17	3/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3966			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
10	17	3/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3967			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in HILL County in the City of HAVRE

Location: EZZIES CENEX CARDTROL
5 1ST ST
HAVRE, MT 59501 HILL
Contact: Larry Poulton, (406) 265-7636

Sys Fac ID: 21-07467
Last Inspected On: 9/5/2014
Operating Permit Renewal Date: 1/7/2018

Owners/Operators: EZZIES WHOLESALE INC, Owner (406)-654-2331 PO BOX 1770
MALTA MT 59538-9640

David Skiff, UST Class A Operator
Harold Anderson, UST Class B Operator
Jimmy Kimberling, UST Class B Operator
David Skiff, UST Class B Operator
Harold Anderson, UST Class B Global Operator
David Skiff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	19	6/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
538			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	19	6/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
539			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
10	19	6/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
540			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
11	19	6/28/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
541			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in HILL County in the City of HAVRE

Location: EZZIES CENEX CARDTROL
5 1ST ST
HAVRE, MT 59501 HILL
Contact: Larry Poulton, (406) 265-7636

Sys Fac ID: 21-07467
Last Inspected On: 9/5/2014
Operating Permit Renewal Date: 1/7/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
12	19	6/28/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
542			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
13	19	6/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
543			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in HILL County in the City of HAVRE

Location: HOLIDAY STATIONSTORE 272
200 1ST ST W
HAVRE, MT 59501 HILL
Contact: (406) 265-8421

Sys Fac ID: 21-08068
Last Inspected On: 9/4/2014
Operating Permit Renewal Date: 12/4/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Stephen Reckinger, UST Class A Operator
Dean Townsend, UST Class A Operator
Ronald VanDenBroeke, UST Class A Operator
Todd Boucher, UST Class B Operator
Stephen Reckinger, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator
Dean Townsend, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	10/1/1985	Cathodically Protected Steel	Steel	Ball Float Valve
3013			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/4/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
12,000		7/8/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	
2	31	10/1/1985	Cathodically Protected Steel	Steel	Ball Float Valve
3014			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/4/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
12,000		2/28/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	
3	31	10/1/1985	Cathodically Protected Steel	Steel	Ball Float Valve
3015			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/4/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
10,000		2/26/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	

Facility Summary in HILL County in the City of HAVRE

Location: HOLIDAY STATIONSTORE 272
200 1ST ST W
HAVRE, MT 59501 HILL
Contact: (406) 265-8421

Sys Fac ID: 21-08068
Last Inspected On: 9/4/2014
Operating Permit Renewal Date: 12/4/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	31	10/1/1985	Cathodically Protected Steel	Steel	Ball Float Valve
3016			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		9/4/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		3/2/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	

Facility Summary in HILL County in the City of HAVRE

Location: TOWN PUMP INC HAVRE
136 1ST ST W
HAVRE, MT 59501 HILL

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 21-08705
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 4/1/2019

Owners/Operators: Town Pump of Havre Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	27	11/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2472		2/4/2015	None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		1/29/2015	TLS-350/Gilbarco EMC , Veeder Root		
4	27	11/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2473		2/4/2015	None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		1/29/2015	TLS-350/Gilbarco EMC , Veeder Root		
5	27	11/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2474		2/4/2015	None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		1/29/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in HILL County in the City of HAVRE

Location: TOWN PUMP INC HAVRE
136 1ST ST W
HAVRE, MT 59501 HILL
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 21-08705
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 4/1/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	27	11/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2475		2/4/2015	None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		1/29/2015	TLS-350/Gilbarco EMC , Veeder Root		
7	02	8/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
5510		2/4/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000		1/29/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	
8	02	8/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
5514		2/4/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000		1/29/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	

Facility Summary in HILL County in the City of HAVRE

Location: BN HAVRE WWTP
235 MAIN ST
HAVRE, MT 59501 HILL

Contact: Harry Rencurel, (406) 265-0483

Sys Fac ID: 21-09548
Last Inspected On: 6/17/2014
Operating Permit Renewal Date: 8/26/2017

Owners/Operators: BNSF Railway Havre, Owner (406)-265-0483 235 MAIN ST HAVRE MT 59501-3523

Michael J Perrodin, UST Class A Operator
Ed Hill, UST Class B Operator
Michael J Perrodin, UST Class B Operator
Tom Swinney, UST Class B Operator
Dwayne Whitaker, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	23	6/21/1993	Cathodically Protected Steel	No Piping	High Level Alarm
506			Double-Walled	None	Yes
Currently in Use			Not Required	Not Listed	Impressed Current
Waste Oil		3/28/2014	Manual Interstitial Monitor	Deferred	
20,000					
17	12	1/22/2004	Concrete	Steel - Terminal Piping	
4877	Yes		None	none	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		3/28/2014	Deferred	MLLD Line Tightness Testing, ELLD Line Tightness Testing	
640,000		9/30/2014	LDE Series , Pneumercator	Continuous Interstitial Monitor	
18	12	1/22/2004	Concrete	Steel - Terminal Piping	
4878	Yes		None	none	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		3/28/2014	Deferred	MLLD Line Tightness Testing, ELLD Line Tightness Testing	
640,000		9/30/2014	LDE Series , Pneumercator	Continuous Interstitial Monitor	

Facility Summary in HILL County in the City of HAVRE

Location: EZZIES WHOLESALE HAVRE
726 1ST ST W
HAVRE, MT 59501 HILL
Contact: Harold Andersen, (406) 265-7636

Sys Fac ID: 21-12751
Last Inspected On: 3/22/2016
Operating Permit Renewal Date: 7/9/2019

Owners/Operators: EZZIES WHOLESALE INC, Owner (406)-654-2331 PO BOX 1770
MALTA MT 59538-9640

David Skiff, UST Class A Operator
Harold Anderson, UST Class B Operator
Jimmy Kimberling, UST Class B Operator
David Skiff, UST Class B Operator
Harold Anderson, UST Class B Global Operator
David Skiff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	7/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
883			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/22/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		8/29/2007	Gilbarco EMC Basic , Gilbarco		
2	24	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
884			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/22/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		8/29/2007	Gilbarco EMC Basic , Gilbarco		
3	24	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
882			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/22/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		8/29/2007	Gilbarco EMC Basic , Gilbarco		

Facility Summary in HILL County in the City of HAVRE

Location: EZZIES WHOLESALE HAVRE
726 1ST ST W
HAVRE, MT 59501 HILL
Contact: Harold Andersen, (406) 265-7636

Sys Fac ID: 21-12751
Last Inspected On: 3/22/2016
Operating Permit Renewal Date: 7/9/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	24	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
885			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/22/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		8/29/2007	Gilbarco EMC Basic , Gilbarco		
5	24	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
878			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Solvents		3/22/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		3/21/2013	Gilbarco EMC Basic , Gilbarco		
6	24	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
879			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/22/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		8/29/2007	Gilbarco EMC Basic , Gilbarco		
7	24	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
880			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/22/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		8/29/2007	Gilbarco EMC Basic , Gilbarco		
8	24	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
881			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/22/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		8/29/2007	Gilbarco EMC Basic , Gilbarco		

Facility Summary in HILL County in the City of HAVRE

Location: EMPORIUM FOOD & FUEL
1415 1ST ST
HAVRE, MT 59501 HILL
Contact: Bill Dritshulas, (406) 265-8861

Sys Fac ID: 21-12763
Last Inspected On: 3/25/2016
Operating Permit Renewal Date: 6/30/2019

Owners/Operators: William Dritshulas, Owner (406)-265-8861 PO BOX 1430 HAVRE MT 59501-1430
Tami Carlson, UST Class A Operator
Jonathan Wells, UST Class A Operator
Cindy Lee, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2971			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		3/22/2016	Gilbarco EMC Basic , Gilbarco		
2	24	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2972			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		3/22/2016	Gilbarco EMC Basic , Gilbarco		
3	24	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2973			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		3/22/2016	Gilbarco EMC Basic , Gilbarco		
4	24	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2974			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		3/22/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in HILL County in the City of HAVRE

Location: HILL COUNTY JUSTICE CENTER
1450 2ND ST W
HAVRE, MT 59501 HILL

Contact: Anez Daryl, (406) 262-3467

Sys Fac ID: 56-13886
Last Inspected On: 3/30/2016
Operating Permit Renewal Date: 4/30/2019

Owners/Operators: Hill County Commissioners, Owner (406)-265-5481 315 4TH ST HAVRE MT 59501-3923

Daryl Anez, UST Class A Operator
Richard Ricci, UST Class A Operator
Daryl Anez, UST Class B Operator
Daryl Anez, UST Class B Global Operator
Richard Ricci, UST Class B Global Operator
Mike Winchell, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	18	7/20/1998	Concrete	Steel	High Level Alarm
1377	Yes		None	Secondary Containment Chase	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor, Not Listed	
2,000			LDE Series , Pneumercator		

Facility Summary in HILL County in the City of HINGHAM

Location: HINGHAM MOTORS
CENTRAL AVE & 1ST ST N
HINGHAM, MT 59528 HILL

Contact: Gary Sudan, (406) 397-3215

Sys Fac ID: 21-00783
Last Inspected On: 4/9/2014
Operating Permit Renewal Date: 5/14/2017

Owners/Operators:

G & D Hingham Motors LLC, Owner	(406)-397-3217	PO BOX 226 HINGHAM MT 59528
Gary Sudan, Operator	(406)-397-3215	297 ROAD 155 N HINGHAM MT 59528
Robert Spicher, UST Class A Operator		
Robert Spicher, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	21	7/25/1995	Unknown	Flexible Plastic	
1383	Yes	5/13/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
7	18	10/1/1998	Unknown	Flexible Plastic	
1384	Yes	5/13/2014	None	Double-Walled	Yes
Currently in Use		1/1/2008	Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
12,000			Other , Other		
8	18	10/1/1998	Unknown	Flexible Plastic	
1385	Yes	5/13/2014	None	Double-Walled	Yes
Currently in Use		1/1/2008	Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
12,000			Other , Other		
9	18	10/1/1998	Unknown	Flexible Plastic	
1386	Yes	5/13/2014	None	Double-Walled	Yes
Currently in Use		1/1/2008	Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000			Other , Other		

Facility Summary in HILL County in the City of INVERNESS

Location: FRASER OIL INC INVERNESS
US HIGHWAY 2
INVERNESS, MT 59530 HILL

Contact: Duane Fraser, (406) 292-3833

Sys Fac ID: 21-07327
Last Inspected On: 12/11/2014
Operating Permit Renewal Date: 3/27/2018

Owners/Operators: Fraser Oil Inc, Owner (406)-292-3833 PO BOX 770
INVERNESS MT 59530-0770

Cory Fraser, UST Class A Operator
Cory Fraser, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	24	10/15/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1120			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/11/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000		12/11/2008	Gilbarco EMC Basic , Gilbarco		
5	24	10/15/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1121			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		12/11/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000		12/11/2008	Gilbarco EMC Basic , Gilbarco		
6	24	10/15/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1122			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/11/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000		12/11/2008	Gilbarco EMC Basic , Gilbarco		

Facility Summary in HILL County in the City of RUDYARD

Location: TONERS TIRE RAMA
103 MAIN ST
RUDYARD, MT 59540 HILL
Contact: Robert Toner, (406) 355-4131

Sys Fac ID: 21-02475
Last Inspected On: 4/14/2016
Operating Permit Renewal Date: 9/24/2019

Owners/Operators: Toners Tire Rama, Owner (406)-355-4131 PO BOX 266
RUDYARD MT 59540-0266

Rick Pester, UST Class A Operator
David Toner, UST Class A Operator
Robert T Toner, UST Class A Operator
Rick Pester, UST Class B Operator
David Toner, UST Class B Operator
Robert T Toner, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	19	11/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2108			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel		4/14/2016	Automatic Tank Gauging 0.1	Deferred	
2,000			Other , Other		
6	19	11/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2109			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline		4/14/2016	Automatic Tank Gauging 0.1	Deferred	
2,000			Other , Other		

Facility Summary in HILL County in the City of RUDYARD

Location: FARMERS UNION OIL CO RUDYARD
1 MAIN ST PO BOX C
RUDYARD, MT 59540 HILL

Contact: Larry Horinek, (406) 355-4543

Sys Fac ID: 21-03509
Last Inspected On: 7/29/2016
Operating Permit Renewal Date: 9/28/2019

Owners/Operators: Farmers Union Oil Co Rudyard, Owner (406)-355-4543 PO BOX 290 RUDYARD MT 59540-0290
Larry Horinek, UST Class A Operator
Larry Horinek, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	50	4/23/1966	Bare Steel	Fiberglass Reinforced Plastic	
947	Yes	3/21/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
2,000			Other , Other		
5	50	4/23/1966	Bare Steel	Fiberglass Reinforced Plastic	
948	Yes	3/21/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
10,000			Other , Other		
6	50	4/23/1966	Bare Steel	Fiberglass Reinforced Plastic	
949	Yes	3/21/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
5,000			Other , Other		

Facility Summary in JEFFERSON County in the City of BOULDER

Location: TOWN PUMP INC BOULDER
703 N MAIN
BOULDER, MT 59632 JEFFERSON
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 22-08673
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 6/29/2019

Owners/Operators: Major Brands Distributing Imports Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000
Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	27	1/1/1989	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4477			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/1/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		9/26/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	27	5/10/1989	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4478			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/1/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
9,000		9/26/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	39	5/10/1977	Bare Steel	Flexible Plastic	Ball Float Valve
2486			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Diesel		12/1/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000		9/26/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in JEFFERSON County in the City of BOULDER

Location: TOWN PUMP INC BOULDER
703 N MAIN
BOULDER, MT 59632 JEFFERSON
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 22-08673
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 6/29/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	39	5/10/1977	Bare Steel	Flexible Plastic	Ball Float Valve
2487			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		12/1/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000		9/26/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	39	5/10/1977	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2485			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		12/1/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		9/26/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	15	4/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4479			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		9/26/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	15	4/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4480			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		9/26/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in JEFFERSON County in the City of BOULDER

Location: HARLOWS SCHOOL BUS SERVICE INC BOULDER
101 N MAIN ST
BOULDER, MT 59632 JEFFERSON

Contact: Mike Benson, (406) 225-3344

Sys Fac ID: 22-12378
Last Inspected On: 1/13/2015
Operating Permit Renewal Date:

Owners/Operators: Harlows School Bus Service Inc, Owner (406)-293-8845 30772 US HIGHWAY 2
LIBBY MT 59923-3130

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	25	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2710			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		8/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
2,000					
7	25	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2711			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		8/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
2,000					

Facility Summary in JEFFERSON County in the City of CARDWELL

Location: CARDWELL STORE LLC
770 MT HIGHWAY 2 E
CARDWELL, MT 59721 JEFFERSON
Contact: Kipp Huckaba, (406) 287-5092

Sys Fac ID: 22-13424
Last Inspected On: 4/15/2014
Operating Permit Renewal Date: 9/3/2017

Owners/Operators: Kipp Huckaba, Owner (406)-287-5092 PO BOX 55
CARDWELL MT 59721-0055
Kipp Huckaba, UST Class A Operator
Kipp Huckaba, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	4/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3193			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		4/10/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
9,000		4/10/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	22	4/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3194			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		4/10/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
3,000		4/10/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	22	4/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3195			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		4/10/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		4/10/2014	TLS-350/Gilbarco EMC , Veeder Root		
4	22	4/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3196			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		4/10/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		4/10/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JEFFERSON County in the City of CLANCY

Location: MONTANA CITY STORE LLC
1 JACKSON CREEK RD
CLANCY, MT 59634 JEFFERSON
Contact: Charles Hunter, (406) 443-0150

Sys Fac ID: 22-01822
Last Inspected On: 4/22/2016
Operating Permit Renewal Date: 6/1/2019

Owners/Operators: Montana City Properties Inc, Owner (406)-443-0150 ATTN CHARLES L HUNTER
1 JACKSON CREEK RD
CLANCY MT 59634-9714

Jennifer Graybeal, UST Class A Operator
Ed Field, UST Class B Operator
Jennifer Graybeal, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	28	7/1/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1668			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		4/5/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		4/12/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	28	7/1/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1669			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/5/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		4/12/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	28	7/1/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1670			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/5/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		4/12/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in JEFFERSON County in the City of CLANCY

Location: CLANCY STORE UST
10 E CLANCY ST
CLANCY, MT 59634 JEFFERSON
Contact: Melva Fowler, (406) 933-8278

Sys Fac ID: 22-02898
Last Inspected On: 8/14/2016
Operating Permit Renewal Date:

Owners/Operators: EMMK LLC, Owner (406)-442-4804 PO BOX 316
CLANCY MT 59634-0316

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	32	4/26/1984	Bare Steel	Steel	High Level Alarm
3534			Impressed Current	None	Yes
Temporarily Out of Use		5/10/2003	Not Required	Safe Suction	Impressed Current
Gasoline		11/12/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000					
3	23	4/10/1993	Bare Steel	Steel	High Level Alarm
4647			Impressed Current	None	Yes
Temporarily Out of Use		5/10/2003	Not Required	Safe Suction	Impressed Current
Gasoline		11/12/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
1,000					

Facility Summary in JEFFERSON County in the City of CLANCY

Location: ASH GROVE CEMENT WEST INC
100 STATE HIGHWAY 518
CLANCY, MT 59634 JEFFERSON
Contact: Joseph Scheeler, (406) 442-8855

Sys Fac ID: 22-02928
Last Inspected On: 9/24/2015
Operating Permit Renewal Date: 12/8/2018

Owners/Operators: Ash Grove Cement Company, Owner (406)-442-8855 100 STATE HIGHWAY 518 CLANCY MT 59634-9665
Jeff Briggs, UST Class A Operator
Jeff Briggs, UST Class B Operator
Robert Johnson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	26	3/30/1990	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
392			None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/15/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		6/14/2012	TLS-350/Gilbarco EMC , Veeder Root		
5	26	3/30/1990	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
393			None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		6/15/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		6/14/2012	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JEFFERSON County in the City of WHITEHALL

Location: THE CORNER STORE WHITEHALL
203 W LEGION AVE
WHITEHALL, MT 59759 JEFFERSON

Contact: Dave Sutey, (406) 287-3746

Sys Fac ID: 22-00980
Last Inspected On: 5/31/2016
Operating Permit Renewal Date: 10/9/2019

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE
BUTTE MT 59701-3553

Timothy Mulligan, UST Class A Operator
Timothy Mulligan, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	10/15/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
529			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/2/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		4/20/2016	TLS-350/Gilbarco EMC , Veeder Root		
2	23	10/15/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
527			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/2/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		4/20/2016	TLS-350/Gilbarco EMC , Veeder Root		
3	23	10/15/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
528			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/2/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		4/20/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JEFFERSON County in the City of WHITEHALL

Location: TOWN PUMP INC WHITEHALL
417 N WHITEHALL ST
WHITEHALL, MT 59759 JEFFERSON

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 22-03645
Last Inspected On: 7/1/2015
Operating Permit Renewal Date: 10/14/2018

Owners/Operators: Town Pump of Whitehall Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	48	1/1/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2476			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	48	1/1/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2477			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
3	38	1/1/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2478			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, MLLD Line Tightness Testing, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JEFFERSON County in the City of WHITEHALL

Location: TOWN PUMP INC WHITEHALL
417 N WHITEHALL ST
WHITEHALL, MT 59759 JEFFERSON

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 22-03645
Last Inspected On: 7/1/2015
Operating Permit Renewal Date: 10/14/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	40	1/1/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2479			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, MLLD Line Tightness Testing, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	38	1/1/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2480			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
6	38	1/1/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2481			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JEFFERSON County in the City of WHITEHALL

Location: TOWN PUMP INC WHITEHALL
417 N WHITEHALL ST
WHITEHALL, MT 59759 JEFFERSON

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 22-03645
Last Inspected On: 7/1/2015
Operating Permit Renewal Date: 10/14/2018

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
7	30	1/1/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2482			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
8	29	1/1/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2483			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
9	29	1/1/1987	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2484			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JEFFERSON County in the City of WHITEHALL

Location: TOWN PUMP INC WHITEHALL
417 N WHITEHALL ST
WHITEHALL, MT 59759 JEFFERSON

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 22-03645
Last Inspected On: 7/1/2015
Operating Permit Renewal Date: 10/14/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	16	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4198			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		5/4/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root		
11	16	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, Not Applicable
4199			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		5/4/2012	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JEFFERSON County in the City of WHITEHALL

Location: GOLDEN SUNLIGHT MINES INC UST
453 MT HIGHWAY 2 E
WHITEHALL, MT 59759 JEFFERSON

Sys Fac ID: 22-04689
Last Inspected On: 8/20/2015
Operating Permit Renewal Date: 12/17/2018

Contact: Debbie Johnson-Horne, (406) 287-2016

Owners/Operators: Golden Sunlight Mines Inc, Owner (406)-287-3257 453 MT HIGHWAY 2 E WHITEHALL MT 59759-8637

Rick Henderson, UST Class A Operator
Debby Horne, UST Class A Operator
Darrell Scharf, UST Class A Operator
Seth Slatter, UST Class B Operator
George Clements, UST Class B Global Operator
John C Clements, UST Class B Global Operator
Joseph Dillon, UST Class B Global Operator
Dave Lawrence, UST Class B Global Operator
Travis Nielsen, UST Class B Global Operator
Ray Panisko, UST Class B Global Operator
John Perigo, UST Class B Global Operator
Donald M Pippin Jr, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	08	6/12/2008	Unknown	Other	
5218	Yes	8/9/2012	None	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Oil Substance			Deferred	Continuous Interstitial Monitor	
1,000			LDE Series , Pneumercator		Yes
7	08	6/12/2008	Unknown	Flexible Plastic	
5219	Yes	8/9/2012	None	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Oil Substance			Deferred	Continuous Interstitial Monitor	
1,000			LDE Series , Pneumercator		Yes

Facility Summary in JEFFERSON County in the City of WHITEHALL

Location: GOLDEN SUNLIGHT MINES INC UST
453 MT HIGHWAY 2 E
WHITEHALL, MT 59759 JEFFERSON

Contact: Debbie Johnson-Horne, (406) 287-2016

Sys Fac ID: 22-04689
Last Inspected On: 8/20/2015
Operating Permit Renewal Date: 12/17/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	07	6/12/2009	Unknown	Flexible Plastic	
5220	Yes	8/9/2012	None	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Oil Substance			Deferred	Continuous Interstitial Monitor	
1,500			LDE Series , Pneumercator		Yes
9	08	6/12/2008	Unknown	Steel - Terminal Piping	
5221	Yes	8/9/2012	None	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	
Oil Substance			Deferred	Continuous Interstitial Monitor	
2,000			LDE Series , Pneumercator		Yes
10	08	6/12/2008	Unknown	Flexible Plastic	
5222	Yes	8/9/2012	None	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Oil Substance			Deferred	Continuous Interstitial Monitor	
2,000			LDE Series , Pneumercator		Yes

Facility Summary in JUDITH BASIN County in the City of GEYSER

Location: GEYSER SCHOOL DIST 58
103 3RD ST E PO BOX 70
GEYSER, MT 59447 JUDITH BASIN
Contact: (406) 735-4368

Sys Fac ID: 23-03795
Last Inspected On: 10/15/2014
Operating Permit Renewal Date: 3/26/2018

Owners/Operators: School Dist 58 Geyser, Owner (406)-735-4368 PO BOX 70 GEYSER MT 59447-0070
Jamie Stahl, UST Class A Operator
Jamie Stahl, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	7/19/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4609			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
2,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of GEYSER

Location: MALMSTROM AFB A 3
US HIGHWAY 87
GEYSER, MT 59447 JUDITH BASIN

Contact: Jim Hodges,

Sys Fac ID: 23-08977
Last Inspected On: 9/19/2014
Operating Permit Renewal Date: 9/25/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	10/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
223		5/26/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of GEYSER

Location: MALMSTROM AFB B 1
US HIGHWAY 87
GEYSER, MT 59447 JUDITH BASIN

Contact: Jim Hodges,

Sys Fac ID: 23-08986
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 9/25/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Chris Amann, UST Class B Operator
Ricardo Andrillon, UST Class B Operator
Glen Beck, UST Class B Operator
Allen Brooks, UST Class B Operator
Jonathan Buesch, UST Class B Operator
John Corbett, UST Class B Operator
David Cosner, UST Class B Operator
Ryan Cox, UST Class B Operator
Brian Day, UST Class B Operator
David Degolier, UST Class B Operator
Hudson English, UST Class B Operator
Dustin Hemingway, UST Class B Operator
Aaron Hill, UST Class B Operator
William Hoffmeister, UST Class B Operator
Shane Hofstad, UST Class B Operator
Bethany Kent, UST Class B Operator
James Knudsen, UST Class B Operator
Ryan Kofoed, UST Class B Operator
Jeff Laird, UST Class B Operator
Damon McCarty, UST Class B Operator
Kieth McIlwain, UST Class B Operator
Brian McVay, UST Class B Operator
Ronald Miller, UST Class B Operator
Michael Murieen, UST Class B Operator
Jeff Nelson, UST Class B Operator
Shawn O'Grady, UST Class B Operator
Chris Ploof, UST Class B Operator
Issac Price, UST Class B Operator
Brian Rayner, UST Class B Operator
Adam Reathaford, UST Class B Operator
Cameron Smith, UST Class B Operator

Facility Summary in JUDITH BASIN County in the City of GEYSER

Location: MALMSTROM AFB B 1
US HIGHWAY 87
GEYSER, MT 59447 JUDITH BASIN

Sys Fac ID: 23-08986
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 9/25/2017

Contact: Jim Hodges,

Jimmy Sonefelt, UST Class B Operator
Michael Stokes, UST Class B Operator
Kyle Topp, UST Class B Operator
Jason Vike, UST Class B Operator
James Wooderchak, UST Class B Operator
Paul Ziemba, UST Class B Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	54	5/2/1962	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
224		9/5/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Impressed Current
Diesel		7/1/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of GEYSER

Location: MALMSTROM AFB B 7
US HIGHWAY 87
GEYSER, MT 59447 JUDITH BASIN

Contact: Jim Hodges,

Sys Fac ID: 23-08992
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 9/26/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	10/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
227		10/8/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of GEYSER

Location: MALMSTROM AFB B 8
US HIGHWAY 87
GEYSER, MT 59447 JUDITH BASIN

Contact: William McLaughlin, (406) 731-6188

Sys Fac ID: 23-08993
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 9/26/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	02	1/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
5466		9/5/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	Yes

Facility Summary in JUDITH BASIN County in the City of GEYSER

Location: MALMSTROM AFB B 9
US HIGHWAY 87
GEYSER, MT 59447 JUDITH BASIN

Contact: Jim Hodges,

Sys Fac ID: 23-08994
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 9/26/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	10/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
229		10/15/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of GEYSER

Location: MALMSTROM AFB B 10
US HIGHWAY 87
GEYSER, MT 59447 JUDITH BASIN

Contact: Jim Hodges,

Sys Fac ID: 23-08995
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 9/26/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	10/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
230		10/29/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of GEYSER

Location: MALMSTROM AFB B 11
US HIGHWAY 87
GEYSER, MT 59447 JUDITH BASIN

Contact: Jim Hodges,

Sys Fac ID: 23-08996
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 9/26/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	27	6/21/1989	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
231		6/8/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of HOBSON

Location: HOBSON SCHOOL DIST 25
CENTRAL AVE
HOBSON, MT 59452 JUDITH BASIN

Contact: Mike Woods, (406) 423-5483

Sys Fac ID: 23-05904
Last Inspected On: 5/26/2015
Operating Permit Renewal Date: 8/22/2018

Owners/Operators: School Dist 25 Hobson, Owner (406)-423-5483 PO BOX 410
HOBSON MT 59452-0410

Michael Woods, UST Class A Operator
Michael Woods, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	26	8/18/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1388		6/26/2015	None	Secondary Containment Chase	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil		5/26/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			TLS-300 , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of HOBSON

Location: WOODHALL DISTRIBUTING
21 SAWMILL RD
HOBSON, MT 59452 JUDITH BASIN

Contact: Wyatt Woodhall, (406) 366-0308

Sys Fac ID: 23-06450
Last Inspected On: 3/24/2014
Operating Permit Renewal Date: 7/10/2017

Owners/Operators: Woodhall Distributing - Stanford, Owner (406)-566-2671 PO BOX 9
STANFORD MT 59479-0009

Greg Econom, UST Class A Operator
Wyatt Woodhall, UST Class A Operator
Greg Econom, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	18	4/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4745			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		3/24/2014	Automatic Tank Gauging 0.2	Deferred	
6,000			Gilbarco EMC Basic , Gilbarco		
6	18	4/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4746			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		3/24/2014	Automatic Tank Gauging 0.2	Deferred	
6,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in JUDITH BASIN County in the City of HOBSON

Location: MALMSTROM AFB L 9
ROAD 400
HOBSON, MT 59452 JUDITH BASIN

Contact: Jim Hodges,

Sys Fac ID: 23-09104
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	5/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
243		4/8/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of HOBSON

Location: MALMSTROM AFB M 8
ROAD 400
HOBSON, MT 59452 JUDITH BASIN

Contact: Jim Hodges,

Sys Fac ID: 23-09114
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/24/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	5/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
244		4/7/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of MOCCASIN

Location: MALMSTROM AFB C 4
US HIGHWAY 87
MOCCASIN, MT 59462 JUDITH BASIN

Contact: Jim Hodges,

Sys Fac ID: 23-09000
Last Inspected On: 3/31/2014
Operating Permit Renewal Date: 7/8/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	9/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
235		6/18/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of MOCCASIN

Location: MALMSTROM AFB C 5
US HIGHWAY 87
MOCCASIN, MT 59462 JUDITH BASIN

Contact: Jim Hodges,

Sys Fac ID: 23-09001
Last Inspected On: 4/1/2014
Operating Permit Renewal Date: 7/22/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	9/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
236		7/2/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of MOCCASIN

Location: MALMSTROM AFB C 6
ROAD 239
MOCCASIN, MT 59462 JUDITH BASIN
Contact: Jim Hodges,

Sys Fac ID: 23-09002
Last Inspected On: 4/2/2014
Operating Permit Renewal Date: 7/8/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	9/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
237		7/16/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of MOCCASIN

Location: MALMSTROM AFB C 7
ROAD 239
MOCCASIN, MT 59462 JUDITH BASIN
Contact: Jim Hodges,

Sys Fac ID: 23-09003
Last Inspected On: 4/2/2014
Operating Permit Renewal Date: 7/8/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	9/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
238		7/9/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of MOCCASIN

Location: MALMSTROM AFB M 9
US HIGHWAY 87
MOCCASIN, MT 59462 JUDITH BASIN

Contact: Jim Hodges,

Sys Fac ID: 23-09115
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/24/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	5/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
245		4/7/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of MOCCASIN

Location: MALMSTROM AFB M 10
US HIGHWAY 87
MOCCASIN, MT 59462 JUDITH BASIN

Contact: Jim Hodges,

Sys Fac ID: 23-09116
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 8/6/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	5/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
246		4/4/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of RAYNESFORD

Location: MALMSTROM AFB A 4
ROAD 427
RAYNESFORD, MT 59469 JUDITH BASIN
Contact: Jim Hodges, (406) 731-6163

Sys Fac ID: 20-08978
Last Inspected On: 9/19/2014
Operating Permit Renewal Date: 9/25/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
221		5/5/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of RAYNESFORD

Location: KIBBEY KORNER TRUCK STOP
US HIGHWAY 87 & ROUTE 427 PO BOX 197
RAYNESFORD, MT 59469 JUDITH BASIN
Contact: Pat Trainor, (406) 738-4400

Sys Fac ID: 23-03301
Last Inspected On: 7/14/2016
Operating Permit Renewal Date: 8/4/2019

Owners/Operators: Mountain View Coop, Owner (406)-453-2435 ATTN DAVE DOUGLAS
2200 OLD HAVRE HWY
BLACK EAGLE MT 59414-1043

David Douglas, UST Class A Operator
David Douglas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	20	9/1/1996	Bare Steel	Fiberglass Reinforced Plastic	
1030	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
10,000		6/22/2016			
5	20	9/1/1996	Bare Steel	Fiberglass Reinforced Plastic	
1029	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
10,000		6/22/2016			
6	20	9/1/1996	Bare Steel	Fiberglass Reinforced Plastic	
1028	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
8,000		6/22/2016			
7	20	9/1/1996	Bare Steel	Fiberglass Reinforced Plastic	
1027	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
8,000		6/22/2016			

Facility Summary in JUDITH BASIN County in the City of RAYNESFORD

Location: KIBBEY KORNER TRUCK STOP
US HIGHWAY 87 & ROUTE 427 PO BOX 197
RAYNESFORD, MT 59469 JUDITH BASIN

Contact: Pat Trainor, (406) 738-4400

Sys Fac ID: 23-03301
Last Inspected On: 7/14/2016
Operating Permit Renewal Date: 8/4/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	20	9/1/1996	Bare Steel	Fiberglass Reinforced Plastic	, Not Applicable
1026	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
25,000		6/22/2016			

Facility Summary in JUDITH BASIN County in the City of RAYNESFORD

Location: MALMSTROM AFB A 1
US HIGHWAY 87
RAYNESFORD, MT 59469 JUDITH BASIN

Sys Fac ID: 23-08974
Last Inspected On: 9/19/2014
Operating Permit Renewal Date: 9/19/2017

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Chris Amann, UST Class B Operator
Ricardo Andrillon, UST Class B Operator
Glen Beck, UST Class B Operator
Allen Brooks, UST Class B Operator
Jonathan Buesch, UST Class B Operator
John Corbett, UST Class B Operator
David Cosner, UST Class B Operator
Ryan Cox, UST Class B Operator
Brian Day, UST Class B Operator
David Degolier, UST Class B Operator
Hudson English, UST Class B Operator
Dustin Hemingway, UST Class B Operator
Aaron Hill, UST Class B Operator
William Hoffmeister, UST Class B Operator
Shane Hofstad, UST Class B Operator
Bethany Kent, UST Class B Operator
James Knudsen, UST Class B Operator
Ryan Kofoed, UST Class B Operator
Jeff Laird, UST Class B Operator
Damon McCarty, UST Class B Operator
Kieth McIlwain, UST Class B Operator
Brian McVay, UST Class B Operator
Ronald Miller, UST Class B Operator
Michael Murieen, UST Class B Operator
Jeff Nelson, UST Class B Operator
Shawn O'Grady, UST Class B Operator
Chris Ploof, UST Class B Operator
Issac Price, UST Class B Operator
Brian Rayner, UST Class B Operator
Adam Reathaford, UST Class B Operator

Facility Summary in JUDITH BASIN County in the City of RAYNESFORD

Location: MALMSTROM AFB A 1
US HIGHWAY 87
RAYNESFORD, MT 59469 JUDITH BASIN

Sys Fac ID: 23-08974
Last Inspected On: 9/19/2014
Operating Permit Renewal Date: 9/19/2017

Contact: Jim Hodges,

Cameron Smith, UST Class B Operator
Jimmy Sonefelt, UST Class B Operator
Michael Stokes, UST Class B Operator
Kyle Topp, UST Class B Operator
Jason Vike, UST Class B Operator
James Wooderchak, UST Class B Operator
Paul Ziemba, UST Class B Operator
Lana Hedlund, UST Class B Global Operator
James Hodges, UST Class B Global Operator
Mark W Johnson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	54	5/2/1962	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
222		9/3/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Impressed Current
Diesel		7/1/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of STANFORD

Location: MALMSTROM AFB B 3
MT HIGHWAY 81
STANFORD, MT 59479 JUDITH BASIN
Contact: Jim Hodges, (406) 731-6167

Sys Fac ID: 14-08988
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 9/26/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
163		9/3/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of STANFORD

Location: MALMSTROM AFB B 4
MT HIGHWAY 80
STANFORD, MT 59479 JUDITH BASIN
Contact: Jim Hodges, (406) 731-6167

Sys Fac ID: 14-08989
Last Inspected On: 12/5/2014
Operating Permit Renewal Date: 9/15/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	9/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
164		9/24/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of STANFORD

Location: BY WAY SERVICE STATION
MT HIGHWAY 80 & US HIGHWAY 87
STANFORD, MT 59479 JUDITH BASIN

Contact: Shirley Froberg, (406) 566-2203

Sys Fac ID: 23-01526
Last Inspected On: 9/2/2014
Operating Permit Renewal Date: 10/23/2017

Owners/Operators: Shirley Woodhall, Owner (406)-566-2203 PO BOX 485 STANFORD MT 59479-0485

Shirley Woodhall, UST Class A Operator
Wyatt Woodhall, UST Class A Operator
Gloria Hungate, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	9/1/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4410			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel		9/2/2014	Automatic Tank Gauging 0.2	Deferred	
5,000		9/1/2011	TLS-350/Gilbarco EMC , Veeder Root		
7	18	10/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4411			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/2/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		9/2/2014	TLS-350/Gilbarco EMC , Veeder Root		
8	18	10/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4412			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/2/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		9/2/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of STANFORD

Location: STANFORD SCHOOL DIST 12
104 4TH AVE S
STANFORD, MT 59479 JUDITH BASIN

Contact: Arnie Smith, (406) 566-2265

Sys Fac ID: 23-01938
Last Inspected On: 7/13/2016
Operating Permit Renewal Date: 10/11/2019

Owners/Operators: School Dist 12 Stanford, Owner (406)-566-2265 PO BOX 506
STANFORD MT 59479-0506

Arnie Smith, UST Class A Operator
Arnie Smith, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	18	10/9/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1893			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Heating Oil			Manual Interstitial Monitor	MLLD Line Tightness Testing	
8,000		7/13/2016		Manual Interstitial Monitor	

Facility Summary in JUDITH BASIN County in the City of STANFORD

Location: WOODHALL DISTRIBUTING
MT HIGHWAY 80 & MAIN ST
STANFORD, MT 59479 JUDITH BASIN
Contact: Wyatt Woodhall, (406) 566-2671

Sys Fac ID: 23-03303
Last Inspected On: 7/11/2016
Operating Permit Renewal Date: 8/4/2019

Owners/Operators: Woodhall Distributing - Denton, Owner (406)-567-2266 PO BOX 1018 DENTON MT 59430-1018
Wyatt Woodhall, UST Class A Operator
Greg Econom, UST Class B Operator
Gloria Hungate, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	7/6/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1031			None	None	Yes
Currently in Use		7/6/2008	Not Required	Safe Suction	Not Applicable
Gasoline			Vapor Monitoring	Deferred	
2,000					
5	18	7/6/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1032			None	None	Yes
Currently in Use		7/6/2008	Not Required	Safe Suction	Not Applicable
Gasoline			Vapor Monitoring	Deferred	
2,000					

Facility Summary in JUDITH BASIN County in the City of STANFORD

Location: MALMSTROM AFB B 2
MT HIGHWAY 80
STANFORD, MT 59479 JUDITH BASIN

Contact: Jim Hodges,

Sys Fac ID: 23-08987
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 9/26/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	9/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
225		9/17/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of STANFORD

Location: MALMSTROM AFB B 6
US HIGHWAY 87
STANFORD, MT 59479 JUDITH BASIN

Contact: Jim Hodges,

Sys Fac ID: 23-08991
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 9/26/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	10/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
226		10/1/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of STANFORD

Location: MALMSTROM AFB C 1
US HIGHWAY 87
STANFORD, MT 59479 JUDITH BASIN
Contact: Jim Hodges, (406) 731-3247

Sys Fac ID: 23-08997
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 9/26/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Chris Amann, UST Class B Operator
Ricardo Andrillon, UST Class B Operator
Glen Beck, UST Class B Operator
Allen Brooks, UST Class B Operator
Jonathan Buesch, UST Class B Operator
John Corbett, UST Class B Operator
David Cosner, UST Class B Operator
Ryan Cox, UST Class B Operator
Brian Day, UST Class B Operator
David Degolier, UST Class B Operator
Hudson English, UST Class B Operator
Dustin Hemingway, UST Class B Operator
Aaron Hill, UST Class B Operator
William Hoffmeister, UST Class B Operator
Shane Hofstad, UST Class B Operator
Bethany Kent, UST Class B Operator
James Knudsen, UST Class B Operator
Ryan Kofoed, UST Class B Operator
Jeff Laird, UST Class B Operator
Damon McCarty, UST Class B Operator
Kieth McIlwain, UST Class B Operator
Brian McVay, UST Class B Operator
Ronald Miller, UST Class B Operator
Michael Murieen, UST Class B Operator
Jeff Nelson, UST Class B Operator
Shawn O'Grady, UST Class B Operator
Chris Ploof, UST Class B Operator
Issac Price, UST Class B Operator
Brian Rayner, UST Class B Operator
Adam Reathaford, UST Class B Operator
Cameron Smith, UST Class B Operator

Facility Summary in JUDITH BASIN County in the City of STANFORD

Location: MALMSTROM AFB C 1
US HIGHWAY 87
STANFORD, MT 59479 JUDITH BASIN

Sys Fac ID: 23-08997
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 9/26/2017

Contact: Jim Hodges, (406) 731-3247

Jimmy Sonefelt, UST Class B Operator
Michael Stokes, UST Class B Operator
Kyle Topp, UST Class B Operator
Jason Vike, UST Class B Operator
James Wooderchak, UST Class B Operator
Paul Ziemba, UST Class B Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	54	5/2/1962	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
232		9/10/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Impressed Current
Diesel		7/1/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of STANFORD

Location: MALMSTROM AFB C 2
US HIGHWAY 87
STANFORD, MT 59479 JUDITH BASIN

Sys Fac ID: 23-08998
Last Inspected On: 3/31/2014
Operating Permit Renewal Date: 7/8/2017

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	9/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
233		6/11/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of STANFORD

Location: MALMSTROM AFB C 3
US HIGHWAY 87
STANFORD, MT 59479 JUDITH BASIN

Sys Fac ID: 23-08999
Last Inspected On: 3/31/2014
Operating Permit Renewal Date: 7/8/2017

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	9/11/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
234		8/21/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of STANFORD

Location: MALMSTROM AFB C 8
US HIGHWAY 87
STANFORD, MT 59479 JUDITH BASIN

Contact: Jim Hodges,

Sys Fac ID: 23-09004
Last Inspected On: 9/24/2014
Operating Permit Renewal Date: 10/7/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	9/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
239		7/30/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of STANFORD

Location: MALMSTROM AFB C 9
US HIGHWAY 87
STANFORD, MT 59479 JUDITH BASIN

Contact: Jim Hodges,

Sys Fac ID: 23-09005
Last Inspected On: 9/24/2014
Operating Permit Renewal Date: 10/7/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	10/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
240		8/6/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of STANFORD

Location: MALMSTROM AFB C 10
US HIGHWAY 87
STANFORD, MT 59479 JUDITH BASIN

Sys Fac ID: 23-09006
Last Inspected On: 9/24/2014
Operating Permit Renewal Date: 10/7/2017

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	9/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
241		12/2/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of STANFORD

Location: MALMSTROM AFB C 11
US HIGHWAY 87
STANFORD, MT 59479 JUDITH BASIN

Contact: Jim Hodges,

Sys Fac ID: 23-09007
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 9/26/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	10/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
242		6/25/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in JUDITH BASIN County in the City of STANFORD

Location: MALMSTROM AFB B 5
MT HIGHWAY 80
STANFORD, MT 59479 JUDITH BASIN
Contact: Jim Hodges, (406) 731-6167

Sys Fac ID: 26-08990
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 9/26/2017

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536
Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	9/10/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
258		9/24/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of ARLEE

Location: WILSON FOODS
US HIGHWAY 93 N
ARLEE, MT 59821 LAKE
Contact: Rowan Wilson, (406) 726-7777

Sys Fac ID: 24-06788
Last Inspected On: 10/10/2014
Operating Permit Renewal Date: 3/21/2018

Owners/Operators:

Wilson Foods Inc, Owner		92345 US HIGHWAY 93 ARLEE MT 59821-9433
Dara Wilson, Operator	(406)-745-4285	DBA WILSON FOODS 92345 US HIGHWAY 93 ARLEE MT 59821-9433
Rowan Wilson, Operator	(406)-745-4285	DBA WILSON FOODS 92345 US HIGHWAY 93 ARLEE MT 59821-9433
John Carranco, UST Class A Operator		
John Carranco, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	18	11/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
3320			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		5/22/2014	TLS-350/Gilbarco EMC , Veeder Root		
11	18	11/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
3321			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		5/22/2014	TLS-350/Gilbarco EMC , Veeder Root		
12	18	11/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
3322			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		5/22/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of BIGFORK

Location: PAPA'S WOODSBAY MARKET
14535 MT HWY 35
BIGFORK, MT 59911 LAKE

Contact: Diane Williams, (406) 837-4884

Sys Fac ID: 24-06085
Last Inspected On: 1/26/2015
Operating Permit Renewal Date: 3/28/2018

Owners/Operators:

Randy Williams dba Papa's Woodsbay Market, Owner	(406)-837-4884	14535 MT HIGHWAY 35 BIGFORK MT 59911
Diane Williams, Operator	(406)-837-4884	14535 MT HIGHWAY 35 BIGFORK MT 59911
Randy Williams, Operator	(406)-837-4884	14535 MT HIGHWAY 35 BIGFORK MT 59911

Diane Williams, UST Class A Operator
Teri Bales, UST Class B Global Operator
Shawn Kneeland, UST Class B Global Operator
Vicky Miller, UST Class B Global Operator
Tami Pasha, UST Class B Global Operator
Rod Serres, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	1/30/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
1279			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Not Listed	Impressed Current
Gasoline		3/20/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		5/13/2016	EECO 1000 , EMCO Electronics		
2	32	1/30/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
1280			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Not Listed	Impressed Current
Gasoline		3/20/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		5/13/2016	EECO 1000 , EMCO Electronics		

Facility Summary in LAKE County in the City of BIGFORK

Location: PAPA'S WOODSBAY MARKET
14535 MT HWY 35
BIGFORK, MT 59911 LAKE
Contact: Diane Williams, (406) 837-4884

Sys Fac ID: 24-06085
Last Inspected On: 1/26/2015
Operating Permit Renewal Date: 3/28/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	22	5/1/1994	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1281			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		3/20/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
4,000		5/13/2016	EECO 1000 , EMCO Electronics		

Facility Summary in LAKE County in the City of BIGFORK

Location: ROE HATLEN
20221 MT HIGHWAY 35
BIGFORK, MT 59911 LAKE

Contact: Kari Aiken, (406) 982-9922

Sys Fac ID: 56-14137
Last Inspected On: 5/8/2014
Operating Permit Renewal Date: 7/1/2017

Owners/Operators: Roe Hatlen, Owner (406)-982-9922 PO BOX 2825
BIGFORK MT 59911-2801

Roe Hatlen, UST Class A Operator
Roe Hatlen, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	11	3/21/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5024		11/12/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline		3/11/2011	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
1,000					

Facility Summary in LAKE County in the City of CHARLO

Location: CHARLO SCHOOL DIST 7 J
405 2ND AVE E
CHARLO, MT 59824 LAKE

Contact: Gary Scott, (406) 644-2207

Sys Fac ID: 24-02789
Last Inspected On: 10/20/2014
Operating Permit Renewal Date: 3/27/2018

Owners/Operators: School Dist 7 J Charlo, Owner (406)-644-2207 PO BOX 10
CHARLO MT 59824-0010

Terry Wersonick, UST Class A Operator
Terry Wersonick, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	18	7/1/1998	Unknown	Flexible Plastic	
611	Yes	10/15/2014	None	Double-Walled	Yes
Currently in Use		1/1/2008	Auto Dialer	U.S. Suction	Not Applicable
Heating Oil			Deferred	Continuous Interstitial Monitor	
10,000		8/27/2012	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of CHARLO

Location: COULTER AUTOMOTIVE INC
S MAIN PO BOX 97
CHARLO, MT 59824 LAKE

Contact: Curtis Colter, (406) 644-2215

Sys Fac ID: 24-04615
Last Inspected On: 4/26/2016
Operating Permit Renewal Date: 10/5/2019

Owners/Operators: Coulter Automotive Inc, Owner (406)-644-2215 PO BOX 97
CHARLO MT 59824-0097

Sandra Coulter, UST Class A Operator
Nathan Dumont, UST Class A Operator
Sandra Coulter, UST Class B Operator
Nathan Dumont, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	21	7/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2281			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		3/6/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		4/25/2016	EECO 1500 , EMCO Electronics		
4	21	7/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2282			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		3/6/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		4/25/2016	EECO 1500 , EMCO Electronics		

Facility Summary in LAKE County in the City of CHARLO

Location: MOIESE MERCANTILE
64620 MT HIGHWAY 212
CHARLO, MT 59824 LAKE

Contact: Tim Hall, (406) 644-3454

Sys Fac ID: 24-06382
Last Inspected On: 10/6/2016
Operating Permit Renewal Date: 12/17/2019

Owners/Operators: Moiese Mercantile, Owner (406)-644-2385 PO BOX 501
CHARLO MT 59824-0501

Timothy H Hall, UST Class A Operator
Leslie Muth, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	17	3/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3968			None	None	Yes
Currently in Use		3/1/2009	Not Required	Safe Suction	Not Applicable
Gasoline			Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
1,000		10/25/2004			

Facility Summary in LAKE County in the City of PABLO

Location: PABLO ELEMENTARY SCHOOL
608 4TH AVE
PABLO, MT 59855 LAKE

Contact: Don Arnett, (406) 676-3390

Sys Fac ID: 24-04823
Last Inspected On: 7/3/2014
Operating Permit Renewal Date: 9/25/2017

Owners/Operators: School Dist 30 Ronan, Owner (406)-644-2448 PO BOX R
RONAN MT 59864-0799

Rob Tougas, UST Class A Operator
Rob Tougas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	50	4/28/1966	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1903		5/15/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Heating Oil		6/9/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			TLS-300 , Veeder Root		

Facility Summary in LAKE County in the City of PABLO

Location: JOES JIFFY STOP
51356 US HIGHWAY 93
PABLO, MT 59855 LAKE

Contact: Margaret Bowman, (406) 676-3570

Sys Fac ID: 24-07562
Last Inspected On: 5/27/2015
Operating Permit Renewal Date: 10/1/2018

Owners/Operators:

Margaret M Bowman, Owner	(406)-675-3570	PO BOX 277 PABLO MT 59855
Joes Jiffy Stop Inc, Operator	(406)-675-3570	PO BOX 277 PABLO MT 59855-0277

Geneva Behnke, UST Class A Operator
Tom Hoyt, UST Class A Operator
Angela Talbott, UST Class A Operator
Ezra Wilson, UST Class A Operator
Jackie Wilson, UST Class A Operator
Geneva Behnke, UST Class B Operator
Tom Hoyt, UST Class B Operator
Gail Matt, UST Class B Operator
Angela Talbott, UST Class B Operator
Ezra Wilson, UST Class B Operator
Jackie Wilson, UST Class B Operator
Gail Matt, UST Class B Global Operator
Angela Talbott, UST Class B Global Operator
Ezra Wilson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	26	10/4/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1269			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in LAKE County in the City of PABLO

Location: JOES JIFFY STOP
51356 US HIGHWAY 93
PABLO, MT 59855 LAKE

Contact: Margaret Bowman, (406) 676-3570

Sys Fac ID: 24-07562
Last Inspected On: 5/27/2015
Operating Permit Renewal Date: 10/1/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	26	10/4/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1270			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		
5	26	10/4/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1271			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in LAKE County in the City of PABLO

Location: QUICKSILVER EXPRESS
52001 US HIGHWAY 93
PABLO, MT 59855 LAKE

Contact: Corky Sias, (406) 675-5000

Sys Fac ID: 24-11124
Last Inspected On: 8/5/2014
Operating Permit Renewal Date: 10/25/2017

Owners/Operators:

Quick Silver Express, Owner	(406)-675-5000	PO BOX 278 PABLO MT 59855
Corky Sias, Operator	(406)-675-5000	PO BOX 278 PABLO MT 59855

Lisa Vollin-Christensen, UST Class A Operator
Lisa Vollin-Christensen, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	1/1/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3296			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		8/5/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		8/2/2007	TLS-350/Gilbarco EMC , Veeder Root		
2	29	1/1/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3297			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/5/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		8/2/2007	TLS-350/Gilbarco EMC , Veeder Root		
3	29	1/1/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3298			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		8/5/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		8/2/2007	TLS-350/Gilbarco EMC , Veeder Root		
4	05	5/1/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5344			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in LAKE County in the City of POLSON

Location: U OF M FLATHEAD LAKE BIOLOGICAL STATION
32125 BIO STATION LN
POLSON, MT 59860 LAKE

Contact: Mark Potter, (406) 982-3301

Sys Fac ID: 24-00507
Last Inspected On: 9/18/2014
Operating Permit Renewal Date: 1/14/2018

Owners/Operators: University of Montana Flathead Lake Biological Station, Owner (406)-982-3301 32125 BIO STATION LANE POLSON MT 59860
Eric Anderson, UST Class A Operator
C. Eric Anderson, UST Class B Operator
Reggie Heiser, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	25	3/15/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2185			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Gasoline		9/19/2014	Manual Interstitial Monitor	MLLD Line Tightness Testing, ELLD Line Tightness Testing	
1,000		9/7/2011			
5	25	3/15/1991	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2186		10/20/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Heating Oil		9/19/2014	Manual Interstitial Monitor	Manual Interstitial Monitor	
2,000					

Facility Summary in LAKE County in the City of POLSON

Location: CHERRY VALLEY SCHOOL
107 8TH AVE W
POLSON, MT 59860 LAKE

Contact: Frank Clement, (406) 883-6329

Sys Fac ID: 24-02867
Last Inspected On: 9/5/2014
Operating Permit Renewal Date: 2/19/2018

Owners/Operators: School Dist 23 Polson, Owner (406)-883-6333 111 4TH AVE E POLSON MT 59860-2132

John Hipp, UST Class A Operator
Dan Kinyon, UST Class A Operator
John Hipp, UST Class B Operator
Dan Kinyon, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	8/1/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1805			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Heating Oil		10/13/2011	Continuous Interstitial Monitor	Deferred	
4,000		10/13/2011	Other , Other		

Facility Summary in LAKE County in the City of POLSON

Location: MOUNTAIN WEST CO OP POLSON
808 MAIN ST
POLSON, MT 59860 LAKE

Contact: Michael Svoboda, (406) 883-5600

Sys Fac ID: 24-04560
Last Inspected On: 6/16/2014
Operating Permit Renewal Date: 12/2/2017

Owners/Operators: Mountain West Coop - Missoula, Owner (406)-543-8383 4570 N RESERVE ST MISSOULA MT 59808-1411

Will Dukart, UST Class A Operator
Dusty Smith, UST Class A Operator
John Thompson, UST Class A Operator
John Adams, UST Class B Operator
John Thompson, UST Class B Operator
Will Dukart, UST Class B Global Operator
Dusty Smith, UST Class B Global Operator
John Thompson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4155		3/11/2014	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
6	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4156		3/11/2014	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			TLS-350/Gilbarco EMC , Veeder Root		
7	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4741		3/11/2014	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of POLSON

Location: MOUNTAIN WEST CO OP POLSON
808 MAIN ST
POLSON, MT 59860 LAKE
Contact: Michael Svoboda, (406) 883-5600

Sys Fac ID: 24-04560
Last Inspected On: 6/16/2014
Operating Permit Renewal Date: 12/2/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4648		3/11/2014	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of POLSON

Location: POLSON BAY GROCERY 425
50451 US HIGHWAY 93
POLSON, MT 59860 LAKE

Contact: George Mahoney, (406) 571-2055

Sys Fac ID: 24-05770
Last Inspected On: 3/19/2014
Operating Permit Renewal Date: 8/9/2017

Owners/Operators:

George Mahoney, Owner		PO BOX 1127 POLSON MT 59860-1127
Ramona Mahoney, Owner	(406)-571-2055	PO BOX 1127 POLSON MT 59860-1127

George Mahoney, UST Class A Operator
George Mahoney, UST Class B Operator
Ramona Mahoney, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	14	5/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4664		6/23/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
5	14	5/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4665		6/23/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
6	14	5/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4666		6/23/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
7	14	5/23/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4667		6/23/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of POLSON

Location: PIER 93
49433 HWY 93
POLSON, MT 59860 LAKE
Contact: Jacob Miller, (406) 883-5768

Sys Fac ID: 24-05957
Last Inspected On: 3/14/2016
Operating Permit Renewal Date: 6/30/2019

Owners/Operators: Jacks Pier 93, Owner (406)-883-5768 49433 US HIGHWAY 93 POLSON MT 59860-2162
Donald Miller, UST Class A Operator
Donald Miller, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	30	4/23/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1802			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		8/1/2009	EECO 1000 , EMCO Electronics		
4	30	4/23/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1803			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		8/1/2009	EECO 1000 , EMCO Electronics		
6	26	11/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1804			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		8/1/2009	EECO 1000 , EMCO Electronics		

Facility Summary in LAKE County in the City of POLSON

Location: JETTE STORE
44613 US HIGHWAY 93
POLSON, MT 59860 LAKE
Contact: Gloria Schumaker, (406) 883-3861

Sys Fac ID: 24-07247
Last Inspected On: 12/1/2014
Operating Permit Renewal Date: 12/2/2017

Owners/Operators: Grits Inc, Owner (406)-883-3861 44613 US HIGHWAY 93
POLSON MT 59860-7585

Paul Bonelli, UST Class A Operator
Jeff Schumaker, UST Class A Operator
Paul Bonelli, UST Class B Operator
Jeff Schumaker, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	20	4/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1215			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000			TS-1000 , Incon		
5	20	4/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1216			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000			TS-1000 , Incon		
6	20	4/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1217			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000			TS-1000 , Incon		

Facility Summary in LAKE County in the City of POLSON

Location: TOWN PUMP INC POLSON
50667 US HIGHWAY 93
POLSON, MT 59860 LAKE
Contact: Roger Hovis, (406) 883-9445

Sys Fac ID: 24-08717
Last Inspected On: 1/28/2016
Operating Permit Renewal Date: 5/14/2019

Owners/Operators: Town Pump Inc Butte, Owner (406)-782-9121 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	34	9/1/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2490			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	34	9/1/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2491			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	34	9/1/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2492			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LAKE County in the City of POLSON

Location: TOWN PUMP INC POLSON
50667 US HIGHWAY 93
POLSON, MT 59860 LAKE
Contact: Roger Hovis, (406) 883-9445

Sys Fac ID: 24-08717
Last Inspected On: 1/28/2016
Operating Permit Renewal Date: 5/14/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	34	9/1/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2493			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	34	9/1/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2494			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
11	14	10/24/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4819			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/4/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
12	14	10/24/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4820			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/4/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LAKE County in the City of POLSON

Location: POLSON COUNTRY CLUB
111 BAYVIEW DR
POLSON, MT 59860 LAKE

Contact: Lawrence Newlin, (406) 883-2131

Sys Fac ID: 24-11824
Last Inspected On: 9/19/2016
Operating Permit Renewal Date: 11/8/2019

Owners/Operators: City of Polson, Owner (406)-883-2131 106 1ST ST E POLSON MT 59860-2137

Patrick Nowlen, UST Class A Operator
Patrick Nowlen, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	8/14/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
647			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		9/16/2016	Manual Tank Gauging	Deferred	
500					

Facility Summary in LAKE County in the City of POLSON

Location: KWATAQNUK RESORT
49708 US HIGHWAY 93
POLSON, MT 59860 LAKE

Contact: Robert R Jr DePoe, (406) 883-3636

Sys Fac ID: 56-13869
Last Inspected On: 5/9/1997
Operating Permit Renewal Date:

Owners/Operators: Confederated Salish & Kootenai Tribe, Owner (406)-675-2700 PO BOX 278
PABLO MT 59855-0278

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	5/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
			Double-Walled	Double-Walled	Yes
Currently in Use				Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
10,000					

Facility Summary in LAKE County in the City of POLSON

Location: SAFEWAY FUEL STATION 1646
40772 MT HIGHWAY 35
POLSON, MT 59860 LAKE

Contact: Aaron Nelson, (425) 201-6301

Sys Fac ID: 60-15097
Last Inspected On: 10/21/2014
Operating Permit Renewal Date: 3/28/2018

Owners/Operators: Safeway Stores Inc, Owner (425)-455-6545 1121 124TH AVE NE BELLEVUE WA 98005-2101

Rachel Jones, UST Class A Operator
Aaron Nelson, UST Class A Operator
Lynn Pehrson, UST Class A Operator
Rachel Jones, UST Class B Global Operator
Heidi Morgan, UST Class B Global Operator
Cindy Stankbrook, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	08	5/22/2008	Steel Clad	Flexible Plastic	High Level Alarm
5164			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
2	08	5/22/2008	Steel Clad	Flexible Plastic	High Level Alarm
5165			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
3	08	5/22/2008	Steel Clad	Flexible Plastic	High Level Alarm
5166			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in LAKE County in the City of POLSON

Location: GOLDES
33537 MONTANA HWY 35
POLSON, MT 59860 LAKE
Contact: Elizabeth Goldes, (406) 439-0454

Sys Fac ID: 60-15208
Last Inspected On: 4/13/2016
Operating Permit Renewal Date: 5/29/2019

Owners/Operators:

Elizabeth Goldes, Owner/Operator	(406)-443-0454	704 STUART STREET HELENA MT 59601
Jeffry Goldes, Owner/Operator	(406)-443-0454	704 STUART STREET HELENA MT 59601

Screna Keller, UST Class A Operator
Travis Schenck, UST Class A Operator
Screna Keller, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	04	5/1/2012	Aboveground Tank	Flexible Plastic	
5365	Yes	4/13/2016	None	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
500			ILS-350 , Veeder Root		Yes

Facility Summary in LAKE County in the City of RAVALLI

Location: RAVALLI STORE
205 BUFFALO ST
RAVALLI, MT 59863 LAKE

Sys Fac ID: 24-09997
Last Inspected On: 7/10/2015
Operating Permit Renewal Date:

Contact: Stacy Harris, (406) 239-0655

Owners/Operators: Days Rest LLC, Owner (406)-239-0655 143 APPLE VALLEY WAY FLORENCE MT 59833

Stacy Harris, Operator (406)-239-0655 143 APPLE VALLEY WAY FLORENCE MT 59833

Stacy Harris, UST Class A Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	27	9/1/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
3464			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Gasoline		7/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
1,000					
2	27	9/1/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
3465			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Gasoline		7/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
1,000					
3	27	9/1/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
3466			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Gasoline		7/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
1,000					

Facility Summary in LAKE County in the City of ROLLINS

Location: POINTS NORTH TRADING CO
87867 US HIGHWAY 93
ROLLINS, MT 59931 LAKE

Contact: Michael Serra, (406) 250-7058

Sys Fac ID: 24-12730
Last Inspected On: 6/27/2016
Operating Permit Renewal Date: 7/22/2019

Owners/Operators:

Points North of Rollins LLC, Owner	(406)-250-7058	PO BOX 220 ROLLINS MT 59931
Mountain Bears Inc, Operator	(406)-250-9547	22571 HWY 93 SOUTH ROLLINS MT 59931

Thomas A Gay, UST Class A Operator
Michael Serra, UST Class A Operator
Thomas A Gay, UST Class B Operator
Michael Serra, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	6/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3095			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		6/26/2016	EECO 1500 , EMCO Electronics		
2	21	6/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3096			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		6/26/2016	EECO 1500 , EMCO Electronics		
3	21	6/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3097			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		6/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		6/26/2016	EECO 1500 , EMCO Electronics		

Facility Summary in LAKE County in the City of RONAN

Location: ST LUKE COMMUNITY CLINIC- RONAN
107 6TH AVE SW
RONAN, MT 59864 LAKE

Contact: Gary Burdett, (406) 676-4441

Sys Fac ID: 24-03736
Last Inspected On: 5/15/2014
Operating Permit Renewal Date: 10/16/2017

Owners/Operators: Saint Luke Hospital, Owner/Operator (406)-676-4441 107 6TH AVE SW RONAN MT 59864-2634

Gary Burdett, UST Class A Operator
Steven DeLay, UST Class A Operator
Nicholas Emerson, UST Class A Operator
Gary Burdett, UST Class B Operator
Steven DeLay, UST Class B Operator
Nicholas Emerson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	17	11/1/1999	Unknown	Copper	
4369	Yes		None	Secondary Containment Chase	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Not Listed	Deferred	
2,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of RONAN

Location: MOUNTAIN WEST CO OP RONAN
63932 US HIGHWAY 93
RONAN, MT 59864 LAKE

Contact: Dusty Smith, (406) 676-2201

Sys Fac ID: 24-04530
Last Inspected On: 2/28/2014
Operating Permit Renewal Date: 7/1/2017

Owners/Operators: Mountain West Coop - Missoula, Owner (406)-543-8383 4570 N RESERVE ST MISSOULA MT 59808-1411

Will Dukart, UST Class A Operator
Dusty Smith, UST Class A Operator
John Thompson, UST Class A Operator
Carrie Clairmont, UST Class B Operator
John Thompson, UST Class B Operator
Will Dukart, UST Class B Global Operator
Dusty Smith, UST Class B Global Operator
John Thompson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	19	5/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2829			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		9/29/2016	TLS-350/Gilbarco EMC , Veeder Root		
10	19	5/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2830			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		9/29/2016	TLS-350/Gilbarco EMC , Veeder Root		
11	19	5/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2831			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		9/29/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of RONAN

Location: MOUNTAIN WEST CO OP RONAN
63932 US HIGHWAY 93
RONAN, MT 59864 LAKE

Contact: Dusty Smith, (406) 676-2201

Sys Fac ID: 24-04530
Last Inspected On: 2/28/2014
Operating Permit Renewal Date: 7/1/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
12	19	5/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2832			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		9/29/2016	TLS-350/Gilbarco EMC , Veeder Root		
13	19	5/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2833			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		9/29/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of RONAN

Location: RONAN AIRPORT
35564 RONAN AIRPORT RD
RONAN, MT 59864 LAKE
Contact: (406) 676-3461

Sys Fac ID: 24-04649
Last Inspected On: 2/23/2016
Operating Permit Renewal Date: 4/26/2019

Owners/Operators: Lake County Joint Airport Board, Owner (406)-883-7214 LAKE COUNTY COURTHOUSE
106 4TH AVE E
POLSON MT 59860-2133

Vinson Jennison, UST Class A Operator
Vinson Jennison, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	17	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3984			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Jet Fuel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			EECO 1500 , EMCO Electronics		
3	17	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3985			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Aviation Gas			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			EECO 1500 , EMCO Electronics		

Facility Summary in LAKE County in the City of RONAN

Location: EAST OF RONAN MIDDLE SCHOOL
200 ROUND BUTTE ROAD E
RONAN, MT 59864 LAKE

Contact: Gene Conklin, (406) 676-3390

Sys Fac ID: 24-04824
Last Inspected On: 5/19/2014
Operating Permit Renewal Date: 9/13/2017

Owners/Operators: School Dist 30 Ronan, Owner (406)-644-2448 PO BOX R
RONAN MT 59864-0799

Rob Tougas, UST Class A Operator
Matt Gaut, UST Class B Operator
Rob Tougas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	20	8/1/1996	Fiberglass Reinforced Plastic	Copper	Flapper Valve (Auto Shutoff)
1904		4/9/2014	None	Secondary Containment Chase	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Heating Oil			Automatic Tank Gauging 0.2	Deferred	
10,000			TS-1000 , Incon		

Facility Summary in LAKE County in the City of RONAN

Location: ARNIES GAS AND TIRE CENTER INC
63145 US HIGHWAY 93
RONAN, MT 59864 LAKE

Contact: Kim Aipperspach, (406) 676-0400

Sys Fac ID: 24-05517
Last Inspected On: 6/12/2014
Operating Permit Renewal Date: 8/15/2017

Owners/Operators: Arnies Gas and Tire Center Inc, Owner (406)-676-0400 63145 US HIGHWAY 93 RONAN MT 59864-2808

Denise Aipperspach, UST Class A Operator
Amanda Hackman, UST Class A Operator
Denise Aipperspach, UST Class B Operator
Denise Aipperspach, UST Class B Global Operator
Amanda Hackman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	38	5/7/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3888			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		6/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		12/11/2013	TLS-350/Gilbarco EMC , Veeder Root		
5	45	5/8/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3889			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		12/11/2013	TLS-350/Gilbarco EMC , Veeder Root		
6	45	5/8/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3890			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		12/11/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of RONAN

Location: ARNIES GAS AND TIRE CENTER INC
63145 US HIGHWAY 93
RONAN, MT 59864 LAKE

Contact: Kim Aipperspach, (406) 676-0400

Sys Fac ID: 24-05517
Last Inspected On: 6/12/2014
Operating Permit Renewal Date: 8/15/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	45	5/8/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3891			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		12/11/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of RONAN

Location: DYNO MART
303 US HIGHWAY 93 N
RONAN, MT 59864 LAKE
Contact: Tom Hoyt, (406) 676-3570

Sys Fac ID: 24-05768
Last Inspected On: 6/12/2014
Operating Permit Renewal Date: 9/9/2017

Owners/Operators: Joes Jiffy Stop Inc, Owner (406)-675-3570 PO BOX 277
PABLO MT 59855-0277

Tom Hoyt, UST Class A Operator
Maureen McCrea, UST Class A Operator
Tom Hoyt, UST Class B Operator
Gail Matt, UST Class B Operator
Gail Matt, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1317			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/30/2013	TLS-350/Gilbarco EMC , Veeder Root		
2	32	11/13/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1315			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/30/2013	TLS-350/Gilbarco EMC , Veeder Root		
3	32	11/13/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1316			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/12/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		7/30/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of RONAN

Location: JOHNS FUEL FARM & ENERGY
14 CLEVELAND ST SE
RONAN, MT 59864 LAKE

Contact: Hans Lund, (406) 261-7956

Sys Fac ID: 24-07437
Last Inspected On: 2/23/2016
Operating Permit Renewal Date: 4/26/2019

Owners/Operators: Johns Fuel Farm & Energy, Owner (406)-676-3461 14 CLEVELAND ST SE RONAN MT 59864-3027

John Noel, UST Class A Operator
Leevi Wadsworth, UST Class A Operator
Leevi Wadsworth, UST Class B Operator
John Noel, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	55	4/23/1961	Cathodically Protected Steel	Steel	High Level Alarm
3394			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/23/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		12/18/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	55	4/23/1961	Cathodically Protected Steel	Steel	High Level Alarm
3395			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		2/23/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		12/18/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	45	4/24/1971	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
3397			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/23/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		12/18/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LAKE County in the City of RONAN

Location: JOHNS FUEL FARM & ENERGY
14 CLEVELAND ST SE
RONAN, MT 59864 LAKE
Contact: Hans Lund, (406) 261-7956

Sys Fac ID: 24-07437
Last Inspected On: 2/23/2016
Operating Permit Renewal Date: 4/26/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	45	4/24/1971	Fiberglass Reinforced Plastic	Steel	High Level Alarm
3398			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Impressed Current
Gasoline		2/23/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		12/18/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	55	4/23/1961	Cathodically Protected Steel	Steel	High Level Alarm
3399			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Heating Oil		2/23/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		12/18/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
11	45	4/24/1971	Fiberglass Reinforced Plastic	Steel	High Level Alarm
3396			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Impressed Current
Diesel		2/23/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		12/18/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LAKE County in the City of RONAN

Location: TOWN PUMP INC RONAN
63459 US HIGHWAY 93
RONAN, MT 59864 LAKE
Contact: Roger Hovis, (406) 676-5290

Sys Fac ID: 24-08718
Last Inspected On: 1/28/2016
Operating Permit Renewal Date: 5/14/2019

Owners/Operators: Town Pump Inc Butte, Owner (406)-782-9121 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	44	4/14/1972	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4822			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
2	44	4/14/1972	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4823			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
3	44	4/14/1972	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4824			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LAKE County in the City of RONAN

Location: TOWN PUMP INC RONAN
63459 US HIGHWAY 93
RONAN, MT 59864 LAKE
Contact: Roger Hovis, (406) 676-5290

Sys Fac ID: 24-08718
Last Inspected On: 1/28/2016
Operating Permit Renewal Date: 5/14/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	36	4/14/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4825			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
5	09	7/5/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5073			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LAKE County in the City of RONAN

Location: KICKING HORSE JOB CORPS CENTER
33091 MOLLMANN PASS TRL
RONAN, MT 59864 LAKE

Contact: Joe Conley, (406) 644-2217

Sys Fac ID: 24-10386
Last Inspected On: 5/15/1998
Operating Permit Renewal Date:

Owners/Operators: Confederated Salish & Kootenai Tribe, Owner (406)-675-2700 PO BOX 278
PABLO MT 59855-0278

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	3/27/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Tank Gauging, Tank Tightness Testing, Automatic Tank Gauging 0.1	Continuous Interstitial Monitor	
1,000					
2	21	3/27/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Manual Tank Gauging, Tank Tightness Testing, Automatic Tank Gauging 0.1	Continuous Interstitial Monitor	
1,000					
3	21	3/27/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Tank Gauging, Tank Tightness Testing, Automatic Tank Gauging 0.1	Continuous Interstitial Monitor	
1,000					

Facility Summary in LAKE County in the City of SAINT IGNATIUS

Location: SAINT IGNATIUS SCHOOL
4TH & BLAINE ST
SAINT IGNATIUS, MT 59865 LAKE
Contact: Roy Martin, (406) 745-3811

Sys Fac ID: 24-03762
Last Inspected On: 10/23/2014
Operating Permit Renewal Date: 2/26/2018

Owners/Operators: School Dist 28 Saint Ignatius, Owner (406)-745-3811 PO BOX 1540
SAINT IGNATIUS MT 59865-1540

Stephen McCollum, UST Class A Operator
Stephen McCollum, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	19	6/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4563		10/15/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Heating Oil		10/22/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			EECO 1500 , EMCO Electronics		

Facility Summary in LAKE County in the City of SAINT IGNATIUS

Location: ALLARDS GENERAL STORE
77579 US HIGHWAY 93 N
SAINT IGNATIUS, MT 59865 LAKE
Contact: Ken Scott, (406) 544-3433

Sys Fac ID: 24-05769
Last Inspected On: 1/7/2015
Operating Permit Renewal Date: 3/13/2018

Owners/Operators: Intermountain Oasis Inc, Owner (406)-544-3433 61574 HILLSIDE RD SAINT IGNATIUS MT 59865

Keith Dowling, UST Class A Operator
Randy Livingston, UST Class A Operator
Kenneth Scott, UST Class A Operator
Keith Dowling, UST Class B Operator
Randy Livingston, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	10	12/1/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5042			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
10,000			TLS-300 , Veeder Root		
5	10	12/1/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5043			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
10,000			TLS-300 , Veeder Root		

Facility Summary in LAKE County in the City of SAINT IGNATIUS

Location: STUARTS SERVICE CENTER INC
240 MOUNTAIN VIEW DR
SAINT IGNATIUS, MT 59865 LAKE
Contact: (406) 745-3696

Sys Fac ID: 24-10647
Last Inspected On: 9/24/2014
Operating Permit Renewal Date: 1/22/2018

Owners/Operators: Morton & Coffman LLC, Owner (406)-745-3634 PO BOX 400
SAINT IGNATIUS MT 59865-0507

Darren Orr, UST Class A Operator
Darren Orr, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	5/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4595			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/6/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		3/17/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	21	5/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4596			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/6/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		3/17/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	21	5/1/1995	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4597			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		10/6/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/17/2014	TLS-350/Gilbarco EMC , Veeder Root		
8	01	10/1/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5619		10/23/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
8,000		10/23/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

Location: AUGUSTA SERVICE STATION LLP
MAIN ST
AUGUSTA, MT 59410 LEWIS AND CLARK

Contact: Ben E Arps, (406) 562-3377

Sys Fac ID: 25-02114
Last Inspected On: 6/13/2014
Operating Permit Renewal Date: 8/22/2017

Owners/Operators: Ben E Arps Exxon, Owner (406)-562-3377 PO BOX 58
AUGUSTA MT 59410-0058

Benjamin E Arps, UST Class A Operator
Benjamin E Arps, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	27	6/6/1989	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3950			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		7/8/2008	Stat. Inventory Reconcilitation	Deferred	
1,500					
2	27	6/6/1989	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3951			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		7/8/2008	Stat. Inventory Reconcilitation	Deferred	
750					
6	27	6/6/1989	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3952			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		7/8/2008	Stat. Inventory Reconcilitation	Deferred	
750					

Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

Location: MALMSTROM AFB F 5
MT HIGHWAY 21
AUGUSTA, MT 59410 LEWIS AND CLARK

Contact: Jim Hodges,

Sys Fac ID: 25-09034
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
247		6/11/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			ILS-350 , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

Location: MALMSTROM AFB F 6
US HIGHWAY 287
AUGUSTA, MT 59410 LEWIS AND CLARK

Contact: Jim Hodges,

Sys Fac ID: 25-09035
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	5/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
248		6/11/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			ILS-350 , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

Location: MALMSTROM AFB F 7
ROAD 434
AUGUSTA, MT 59410 LEWIS AND CLARK

Contact: Jim Hodges,

Sys Fac ID: 25-09036
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
249		6/11/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

Location: MALMSTROM AFB G 9
US HIGHWAY 287
AUGUSTA, MT 59410 LEWIS AND CLARK

Contact: Jim Hodges,

Sys Fac ID: 25-09049
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/23/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	10/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
254		9/16/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

Location: MALMSTROM AFB G 10
US HIGHWAY 287
AUGUSTA, MT 59410 LEWIS AND CLARK

Contact: Jim Hodges,

Sys Fac ID: 25-09050
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/23/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
255		9/16/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

Location: MALMSTROM AFB F 1
US HIGHWAY 287
AUGUSTA, MT 59410 LEWIS AND CLARK

Sys Fac ID: 50-09030
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Ricardo Andrillon, UST Class B Operator
Glen Beck, UST Class B Operator
Allen Brooks, UST Class B Operator
Jonathan Buesch, UST Class B Operator
John Corbett, UST Class B Operator
David Cosner, UST Class B Operator
Ryan Cox, UST Class B Operator
Brian Day, UST Class B Operator
David Degolier, UST Class B Operator
Patrick Ellis, UST Class B Operator
Hudson English, UST Class B Operator
Paul Floyd, UST Class B Operator
Dustin Hemingway, UST Class B Operator
Aaron Hill, UST Class B Operator
William Hoffmeister, UST Class B Operator
Shane Hofstad, UST Class B Operator
Bethany Kent, UST Class B Operator
James Knudsen, UST Class B Operator
Ryan Kofoed, UST Class B Operator
Jeff Laird, UST Class B Operator
Damon McCarty, UST Class B Operator
Kieth McIlwain, UST Class B Operator
Brian McVay, UST Class B Operator
Ronald Miller, UST Class B Operator
Michael Murieen, UST Class B Operator
Jeff Nelson, UST Class B Operator
Patrick Noppenberg, UST Class B Operator
Shawn O'Grady, UST Class B Operator
Chris Ploof, UST Class B Operator
Issac Price, UST Class B Operator
Brian Rayner, UST Class B Operator

Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

Location: MALMSTROM AFB F 1
US HIGHWAY 287
AUGUSTA, MT 59410 LEWIS AND CLARK

Sys Fac ID: 50-09030
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Cameron Smith, UST Class B Operator
Jimmy Sonefelt, UST Class B Operator
Michael Stokes, UST Class B Operator
Kyle Topp, UST Class B Operator
Jason Vike, UST Class B Operator
James Wooderchak, UST Class B Operator
Paul Ziemba, UST Class B Operator
Paul Floyd, UST Class B Global Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	54	6/2/1962	Cathodically Protected Steel	Flexible Plastic	Positive Shutoff, High Level Alarm
303		6/11/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Impressed Current
Diesel		7/31/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of EAST HELENA

Location: CANYON FERRY MINI BASKET
3012 CANYON FERRY RD
EAST HELENA, MT 59635 LEWIS AND CLARK

Contact: Robert Merzlak, (406) 227-8506

Sys Fac ID: 25-03122
Last Inspected On: 2/5/2016
Operating Permit Renewal Date: 3/30/2019

Owners/Operators: Big Sky Food and Fuel Inc, Owner (406)-443-3608 ROBER J MERZLAK
3012 CANYON FERRY RD
EAST HELENA MT 59635-3025

Robert J Merzlak, UST Class A Operator
Robert J Merzlak, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	6/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2319			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/13/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		3/30/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	09	10/16/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5151			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		10/13/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
5	09	10/16/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5152			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		10/13/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in LEWIS AND CLARK County in the City of EAST HELENA

Location: TOWN PUMP INC EAST HELENA
418 W MAIN ST
EAST HELENA, MT 59635 LEWIS AND CLARK
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 25-08697
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 6/29/2019

Owners/Operators: Town Pump of East Helena Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	48	4/14/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4672			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/25/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
2	48	4/14/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4673			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/25/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
3	48	4/14/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4674			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		9/25/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of EAST HELENA

Location: TOWN PUMP INC EAST HELENA
418 W MAIN ST
EAST HELENA, MT 59635 LEWIS AND CLARK
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 25-08697
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 6/29/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
4	48	4/14/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4675			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		9/25/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
3,000			TLS-350/Gilbarco EMC , Veeder Root		
5	48	4/14/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4676			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		9/25/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
6	39	4/14/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4677			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		9/25/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
7	39	4/14/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4678			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/25/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of EAST HELENA

Location: TOWN PUMP OF EAST HELENA #2
116 LANE AVE
EAST HELENA, MT 59635 LEWIS AND CLARK
Contact: Roger Hovis, (406) 227-9170

Sys Fac ID: 56-13915
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 6/29/2019

Owners/Operators: Miles City Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000
Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4028			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4029			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
3	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4030			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of EAST HELENA

Location: TOWN PUMP OF EAST HELENA #2
116 LANE AVE
EAST HELENA, MT 59635 LEWIS AND CLARK
Contact: Roger Hovis, (406) 227-9170

Sys Fac ID: 56-13915
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 6/29/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
4	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4031			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
5	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4032			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
6	17	3/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4033			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
7	13	8/18/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4861			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of FORT HARRISON

Location: VETERANS HEALTH ADMINISTRATION
3687 VETERANS DRIVE BLDG 141
FORT HARRISON, MT 59636 LEWIS AND CLARK

Contact: Kailen Collette, (406) 447-7382

Sys Fac ID: 25-05908
Last Inspected On: 1/7/2015
Operating Permit Renewal Date: 2/3/2018

Owners/Operators:

US Dept of Veterans Affairs, Owner	(406)-447-7121	FORT HARRISON 3687 VETERANS DRIVE 085B FORT HARRISON MT 59636
Kailen Collette, Operator	(406)-447-7382	3687 VETERANS DRIVE FORT HARRISON MT 59636
Michael Harris, UST Class A Operator		
Leslie Holz, UST Class A Operator		
Steven Felter, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	22	12/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2214			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
1,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	22	12/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2216			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
4,000		6/13/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
13	06	10/1/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5278		7/1/2011	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		6/13/2013	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.2	Yes

Facility Summary in LEWIS AND CLARK County in the City of FORT HARRISON

Location: VETERANS HEALTH ADMINISTRATION
3687 VETERANS DRIVE BLDG 141
FORT HARRISON, MT 59636 LEWIS AND CLARK
Contact: Kailen Collette, (406) 447-7382

Sys Fac ID: 25-05908
Last Inspected On: 1/7/2015
Operating Permit Renewal Date: 2/3/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
14	04	5/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5366		5/24/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
10,000		3/30/2015	TLS-450 , Veeder Root		Yes

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: EXEC AIR MONTANA INC 1
2430 AIRPORT RD
HELENA, MT 59601 LEWIS AND CLARK

Contact: John Maxness, (406) 442-2190

Sys Fac ID: 25-00642
Last Inspected On: 4/11/2016
Operating Permit Renewal Date: 4/11/2019

Owners/Operators: Exec Air Montana Inc, Owner (406)-442-2190 2560 AIRPORT RD HELENA MT 59601-1207

John Maxness, UST Class A Operator
John Maxness, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	25	6/1/1991	Cathodically Protected Steel	No Piping	High Level Alarm
3344			Double-Walled	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Aviation Gas		9/11/2013	Continuous Interstitial Monitor	Deferred	
12,000					
6	25	6/1/1991	Cathodically Protected Steel	No Piping	High Level Alarm
3345			Double-Walled	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Jet Fuel		9/11/2013	Continuous Interstitial Monitor	Deferred	
12,000					

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: COMBINED CRIMINAL JUSTICE FACILITY
221 BRECKENRIDGE ST
HELENA, MT 59601 LEWIS AND CLARK

Contact: Dave Schmited, (406) 447-8299

Sys Fac ID: 25-00945
Last Inspected On: 5/3/2016
Operating Permit Renewal Date: 5/3/2019

Owners/Operators: Lewis & Clark County Jail, Owner (406)-447-8299 228 E BROADWAY ST RM 5
HELENA MT 59601-4263

Kirk Ketchum, UST Class A Operator
Robert McCarley, UST Class A Operator
David Schmitz, UST Class A Operator
Kirk Ketchum, UST Class B Global Operator
Robert McCarley, UST Class B Global Operator
David Schmitz, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	4/21/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4060		5/3/2016	None	Double-Walled	Yes
Currently in Use		4/21/1995	Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Diesel		7/11/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
3,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: KIMS MARINA & RESORT
8015 CANYON FERRY RD
HELENA, MT 59602 LEWIS AND CLARK
Contact: Greg Axtman, (406) 475-3195

Sys Fac ID: 25-01091
Last Inspected On: 3/13/2014
Operating Permit Renewal Date: 5/10/2017

Owners/Operators: Greg Axtman, Owner (406)-475-3195 3980 LAKE HILLS LN HELENA MT 59602-8503
Greg Axtman, UST Class A Operator
Maryann Axtman, UST Class A Operator
Greg Axtman, UST Class B Operator
Maryann Axtman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	23	5/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3516			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
3,782		5/5/2014		Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: HELENA SERVICE CENTER
1315 N LAST CHANCE GULCH
HELENA, MT 59601 LEWIS AND CLARK

Sys Fac ID: 25-01183
Last Inspected On: 3/14/2014
Operating Permit Renewal Date: 8/12/2017

Contact: Beth Stimatz, (406) 497-2687

Owners/Operators: Northwestern Energy, Owner (406)-655-2521 405 S 20TH ST W BILLINGS MT 59102

Kellen Gilreath, UST Class A Operator
John Habeger, UST Class A Operator
Phil Hatfield, UST Class A Operator
Eric Brass, UST Class B Operator
Joyce Walczak, UST Class B Operator
Kellen Gilreath, UST Class B Global Operator
Phil Hatfield, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1678			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1679			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: FRIENDLYS SINCLAIR
1831 11TH AVE
HELENA, MT 59601 LEWIS AND CLARK
Contact: Barb Leland, (406) 442-4865

Sys Fac ID: 25-01314
Last Inspected On: 5/28/2014
Operating Permit Renewal Date: 7/26/2017

Owners/Operators: Barbara Leland, Owner (406)-442-4865 1831 11TH AVE
HELENA MT 59601-4769

Edward Dimock, UST Class A Operator
Ginny Helfert, UST Class A Operator
Barbara Leland, UST Class A Operator
Edward Dimock, UST Class B Operator
Scott Leland, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	14	1/2/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4611			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		6/15/2014	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
6	14	1/2/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4612			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		6/15/2014	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
7	14	1/2/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4613			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
20,000		6/15/2014	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: PHILLIPS 66 HELENA TERMINAL
3180 E US HWY 12
HELENA, MT 59601 LEWIS AND CLARK

Contact: Dale Waltrip, (406) 442-6395

Sys Fac ID: 25-01846
Last Inspected On: 11/11/2015
Operating Permit Renewal Date: 11/13/2018

Owners/Operators:

Phillips 66 Helena Terminal, Owner	(406)-255-5714	2626 LILLIAN AVENUE BILLINGS MT 59101
Phillips 66 Pipeline LLC, Operator	(406)-255-5714	2626 LILLIAN AVENUE BILLINGS MT 59101

Brian Buckley, UST Class A Operator
CHARLES HEINAMAN, UST Class A Operator
Ryan Norwood, UST Class A Operator
John Stampfli, UST Class A Operator
Steve Thomas, UST Class A Operator
Brian Buckley, UST Class B Operator
Theodore Hagemo, UST Class B Operator
Ryan Norwood, UST Class B Operator
James Olson, UST Class B Operator
Clifford Pearce, UST Class B Operator
Steven Sheldon, UST Class B Operator
Steve Thomas, UST Class B Operator
Michael Crawford, UST Class B Global Operator
CHARLES HEINAMAN, UST Class B Global Operator
Richard Leeds, UST Class B Global Operator
Jeb Pedrazzi, UST Class B Global Operator
John Stampfli, UST Class B Global Operator
Dane Whittaker, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	1/1/1993	Fiberglass Reinforced Plastic	Steel	High Level Alarm
4919			Double-Walled	None	Yes
Currently in Use			Not Required	Gravity Feed	Not Applicable, Impressed Current
Mixture		5/12/2015	Continuous Interstitial Monitor	MLLD Line Tightness Testing	
10,000		11/11/2015	Other , Other		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: EXEC AIR MONTANA INC 2
2430 AIRPORT RD
HELENA, MT 59601 LEWIS AND CLARK

Contact: John Maxness, (406) 442-2190

Sys Fac ID: 25-02123
Last Inspected On: 4/11/2016
Operating Permit Renewal Date: 6/12/2019

Owners/Operators: Exec Air Montana Inc, Owner (406)-442-2190 2560 AIRPORT RD HELENA MT 59601-1207

John Maxness, UST Class A Operator
John Maxness, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	50	4/1/1966	Bare Steel	No Piping	High Level Alarm
3646			Impressed Current	None	Yes
Currently in Use			Not Required	Not Listed	Impressed Current
Jet Fuel		9/11/2013	Vapor Monitoring	Deferred	
15,000					
2	50	4/1/1966	Bare Steel	No Piping	High Level Alarm
3647			Impressed Current	None	Yes
Currently in Use			Not Required	Not Listed	Impressed Current
Jet Fuel		9/11/2013	Vapor Monitoring	Deferred	
15,000					
3	50	4/1/1966	Bare Steel	No Piping	High Level Alarm
3648			Impressed Current	None	Yes
Currently in Use			Not Required	Not Listed	Impressed Current
Gasoline		9/11/2013	Vapor Monitoring	Deferred	
15,000					
4	50	4/1/1966	Bare Steel	No Piping	High Level Alarm
3649			Impressed Current	None	Yes
Currently in Use			Not Required	Not Listed	Impressed Current
Gasoline		9/11/2013	Vapor Monitoring	Deferred	
15,000					

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: CEDAR STREET CONOCO
1701 CEDAR ST
HELENA, MT 59601 LEWIS AND CLARK

Contact: Mike Salois, (406) 459-8719

Sys Fac ID: 25-03466
Last Inspected On: 5/8/2015
Operating Permit Renewal Date: 6/11/2018

Owners/Operators:

Cedar Street Conoco, Owner	(406)-495-0953	1701 CEDAR STREET HELENA MT 59601
Michael Salois, Operator	(406)-459-8719	2965 SUNNYSIDE HELENA MT 59602

Michael Salois, UST Class A Operator
Daren Griffeth, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	18	9/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2228			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
6	18	9/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2229			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
7	18	9/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2230			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: UNITED PARCEL SERVICES HELENA
3029 AIRPORT RD
HELENA, MT 59601 LEWIS AND CLARK
Contact: Dino Ostrow, (503) 978-7678

Sys Fac ID: 25-04538
Last Inspected On: 2/10/2016
Operating Permit Renewal Date: 6/1/2019

Owners/Operators:

United Parcel Service, Inc, Owner	(503)-978-7678	6707 N BASIN AVE PORTLAND OR 97217
United Parcel Service Plant Engineering Dept, Operator	(206)-621-6261	4455 7TH AVE S SEATTLE WA 98108

Robert Counts, UST Class A Operator
Treair Smith, UST Class A Operator
Russell Stott, UST Class A Operator
Paul Vandehey, UST Class A Operator
Robert Counts, UST Class B Operator
Russell Stott, UST Class B Operator
Treair Smith, UST Class B Global Operator
Paul Vandehey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	22	12/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4446			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
12,000		4/14/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: JOLLY OS GAS N GO
1200 CEDAR ST
HELENA, MT 59601 LEWIS AND CLARK
Contact: (406) 442-5621

Sys Fac ID: 25-04966
Last Inspected On: 2/24/2016
Operating Permit Renewal Date:

Owners/Operators: Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756
BILLINGS MT 59103-1756

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	3/26/1985	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
4784			None	none	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/24/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
8,000					
2	31	3/26/1985	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
4785			None	none	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/24/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
8,000					
4	25	9/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
4786			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/24/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
4,000					

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: JERRYS HIWAY SERVICE
1901 N LAST CHANCE GULCH
HELENA, MT 59601 LEWIS AND CLARK

Contact: Jerry Fetters, (406) 207-3729

Sys Fac ID: 25-05099
Last Inspected On: 6/22/2016
Operating Permit Renewal Date:

Owners/Operators: Jerold Fetters, Owner (406)-442-5087 1901 N LAST CHANCE GULCH HELENA MT 59601-0742

Sharon Fetters, UST Class A Operator
Sharon Fetters, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	44	11/22/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1053			Lined Interior/Impressed Current	Double-Walled	Yes
Temporarily Out of Use		6/1/2008	Continuous Interstitial Monitoring	Pressurized	Impressed Current
Gasoline		11/3/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000					
2	44	11/22/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4419			Lined Interior/Impressed Current	Double-Walled	Yes
Temporarily Out of Use		6/1/2008	Continuous Interstitial Monitoring	Pressurized	Impressed Current
Diesel		11/3/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000					
3	44	11/22/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1055			Lined Interior/Impressed Current	Double-Walled	Yes
Temporarily Out of Use		6/1/2008	Continuous Interstitial Monitoring	Pressurized	Impressed Current
Gasoline		11/3/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000					

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: GREEN MEADOW MARKET
3300 GREEN MEADOW DR
HELENA, MT 59602 LEWIS AND CLARK
Contact: John J Rule, (406) 442-7095

Sys Fac ID: 25-05688
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 8/13/2019

Owners/Operators: JTA Inc, Owner (406)-442-7095 3300 GREEN MEADOW DR HELENA MT 59602-7707

Todd Adams, UST Class A Operator
John Rule, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	37	10/1/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3243			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/14/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/14/2016	Gilbarco EMC Basic , Gilbarco		
2	37	10/1/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3244			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/14/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		4/14/2016	Gilbarco EMC Basic , Gilbarco		
3	09	8/8/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5135			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		4/14/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/14/2016	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
4	09	8/8/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5136			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		4/14/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
7,000		4/14/2016	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: ZIP TRIP 43
1318 EUCLID AVE
HELENA, MT 59601 LEWIS AND CLARK
Contact: Monte Means, (406) 442-9402

Sys Fac ID: 25-05774
Last Inspected On: 10/7/2014
Operating Permit Renewal Date: 3/13/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216
Tom Savas, UST Class A Operator		
Luci Tuttle, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	4/26/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4518			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/20/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		6/19/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	33	4/26/1983	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4519			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/20/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		6/19/2014	TLS-350/Gilbarco EMC , Veeder Root		
4	19	4/23/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4520			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/20/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		6/19/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: GATES OF THE MOUNTAINS INC
3106 GATES OF THE MOUNTAINS RD PO BOX 4478
HELENA, MT 59604 LEWIS AND CLARK

Contact: Tim Crawford, (406) 458-5241

Sys Fac ID: 25-06619
Last Inspected On: 4/6/2016
Operating Permit Renewal Date: 4/30/2019

Owners/Operators: Gates of The Mountains Inc, Owner (406)-458-5241 PO BOX 4478
HELENA MT 59604-4478

Timothy Crawford, UST Class A Operator
Timothy Crawford, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	30	4/29/1986	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1202			Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		4/6/2016	Manual Interstitial Monitor	MLLD Line Tightness Testing	
5,000		4/6/2016			
4	30	4/29/1986	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1203			Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current, Galvanic
Diesel		4/6/2016	Manual Interstitial Monitor	MLLD Line Tightness Testing	
1,000		4/6/2016			

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: MDOT HELENA HEADQUARTERS
2701 PROSPECT AVE
HELENA, MT 59601 LEWIS AND CLARK

Contact: Joe Radonich, (406) 444-9204

Sys Fac ID: 25-06849
Last Inspected On: 6/11/2014
Operating Permit Renewal Date: 11/19/2017

Owners/Operators:

MDOT Helena, Owner	(406)-444-6200	KIM JANZEN PO BOX 201001 HELENA MT 59620-1001
Joseph J Radonich, Operator	(406)-444-9204	MDT DEADHEAD HELENA MT 59620-0901

Jeff Gleason, UST Class A Operator
Walt Kerttula, UST Class A Operator
Mike Murolo, UST Class A Operator
Joe Radonich, UST Class A Operator
Tim Clark, UST Class B Operator
Walter Jester, UST Class B Operator
Bob Maphies, UST Class B Operator
Jim Adolph, UST Class B Global Operator
Bradley Becker, UST Class B Global Operator
Dennis Grimm, UST Class B Global Operator
Joe Radonich, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	20	3/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2911			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1	
12,000		6/10/2014	TLS-350/Gilbarco EMC , Veeder Root		
5	20	3/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2912			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1	
12,000		6/10/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: SOUTHS COUNTRY STORE
3105 YORK RD
HELENA, MT 59602 LEWIS AND CLARK

Contact: Lonnie Bennett, (406) 227-5757

Sys Fac ID: 25-07353
Last Inspected On: 7/26/2016
Operating Permit Renewal Date: 9/23/2019

Owners/Operators: L&B LLP, Owner (406)-227-5757 3487 BIRKLAND DR
HELENA MT 59602-9196

Lonnie Bennett, UST Class A Operator
Lonnie Bennett, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	23	5/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3562			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		7/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/26/2016	TLS-350/Gilbarco EMC , Veeder Root		
4	23	5/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3563			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		7/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/26/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: BOBS VALLEY SERVICE INC UST
7507 N MONTANA AVE
HELENA, MT 59602 LEWIS AND CLARK

Sys Fac ID: 25-07404
Last Inspected On: 12/9/2014
Operating Permit Renewal Date: 3/26/2018

Contact: Steve Bartmess, (406) 458-5140

Owners/Operators: Bobs Valley Service Inc, Owner (406)-458-5140 7507 N MONTANA AVE HELENA MT 59602-9389

Stephen Bartmess, UST Class A Operator
Craig Sprankle, UST Class B Operator
Stephen Bartmess, UST Class B Global Operator
Steve Nummerdor, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	28	3/27/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
474			None	Double-Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	ELLD Line Tightness Testing, Not Listed	
6,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes
5	28	3/27/1988	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
475			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/15/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes
6	24	6/1/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
476			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/15/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: BOBS VALLEY SERVICE INC UST
7507 N MONTANA AVE
HELENA, MT 59602 LEWIS AND CLARK

Contact: Steve Bartmess, (406) 458-5140

Sys Fac ID: 25-07404
Last Inspected On: 12/9/2014
Operating Permit Renewal Date: 3/26/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	18	11/15/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
477			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/15/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
20,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: Queen City Exxon LLC
1721 CEDAR ST
HELENA, MT 59601 LEWIS AND CLARK
Contact: Mike Bakker, (406) 442-0540

Sys Fac ID: 25-07848
Last Inspected On: 3/16/2015
Operating Permit Renewal Date: 8/27/2018

Owners/Operators: Queen City Exxon LLC, Owner (406)-439-4469 5755 OGLE VIEW RD HELENA MT 59601

Timothy C Hornbacher, UST Class A Operator
Vaughn Ogle, UST Class A Operator
Mike Bakker, UST Class B Operator
Timothy C Hornbacher, UST Class B Operator
Jacob Ogle, UST Class B Operator
Vaughn Ogle, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	11/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	
1399			None	None	Yes
Currently in Use		9/4/2006	Not Required	Gravity Feed	Galvanic
Waste Oil		3/16/2015	Automatic Tank Gauging 0.2	Deferred	
1,000		9/1/2004	Gilbarco EMC Basic , Gilbarco		
3	28	12/29/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1398			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		9/1/2004	Gilbarco EMC Basic , Gilbarco		
4	28	12/29/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1396			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		9/1/2004	Gilbarco EMC Basic , Gilbarco		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: Queen City Exxon LLC
1721 CEDAR ST
HELENA, MT 59601 LEWIS AND CLARK
Contact: Mike Bakker, (406) 442-0540

Sys Fac ID: 25-07848
Last Inspected On: 3/16/2015
Operating Permit Renewal Date: 8/27/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	28	12/29/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1397			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		9/1/2004	Gilbarco EMC Basic , Gilbarco		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: THRIFTWAY SUPER STOP 9
1405 EUCLID AVE
HELENA, MT 59601 LEWIS AND CLARK
Contact: (406) 449-0017

Sys Fac ID: 25-07931
Last Inspected On: 6/1/2016
Operating Permit Renewal Date: 6/12/2019

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE BUTTE MT 59701-3553

Jack Hook, UST Class A Operator
Linda Otonicar, UST Class A Operator
Louie Sutey, UST Class A Operator
Mike Uphus, UST Class A Operator
Jack Hook, UST Class B Operator
Peggy Johnson, UST Class B Operator
Lisa Weist, UST Class B Operator
Jack Hook, UST Class B Global Operator
Louie Sutey, UST Class B Global Operator
Lisa Weist, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2056			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2057			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, Not Applicable
2058			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: HOLIDAY STATIONSTORE 270
401 EUCLID AVE
HELENA, MT 59601 LEWIS AND CLARK
Contact: (406) 443-0135

Sys Fac ID: 25-08067
Last Inspected On: 6/10/2014
Operating Permit Renewal Date: 9/9/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Jack Krueger Jr, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Dave Samson, UST Class B Operator
Jack Krueger Jr, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	5/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
3017			Impressed Current	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/11/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
12,000		1/5/2011	TLS-350/Gilbarco EMC , Veeder Root		
2	29	5/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
3018			Impressed Current	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/11/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		1/22/2011	TLS-350/Gilbarco EMC , Veeder Root		
3	29	11/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
3019			Impressed Current	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/11/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
10,000		11/28/2010	TLS-350/Gilbarco EMC , Veeder Root		
4	29	11/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
3020			Impressed Current	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/11/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
10,000		11/4/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: MONROE'S HIGH COUNTRY TRAVEL PLAZA
3122 E US HIGHWAY 12
HELENA, MT 59601 LEWIS AND CLARK

Contact: Jirsa Patricia, (406) 442-3259

Sys Fac ID: 25-08659
Last Inspected On: 1/17/2014
Operating Permit Renewal Date: 3/15/2017

Owners/Operators:

Monroes High Country Travel Plaza LLC, Owner	(406)-459-6633	3122 E US HIGHWAY 12 HELENA MT 59601-9701
Marvin Monroe, Operator	(406)-459-6633	5400 SILVER CREEK RD HELENA MT 59602

DEBRA MONROE, UST Class A Operator
Marvin Monroe, UST Class A Operator
William J Monroe, UST Class A Operator
DEBRA MONROE, UST Class B Operator
Marvin Monroe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	6/19/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4526			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		2/24/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		
2	26	6/19/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4527			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		2/24/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		
8	20	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4528			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/24/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		
9	20	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4529			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/24/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: MONROE'S HIGH COUNTRY TRAVEL PLAZA
3122 E US HIGHWAY 12
HELENA, MT 59601 LEWIS AND CLARK

Contact: Jirsa Patricia, (406) 442-3259

Sys Fac ID: 25-08659
Last Inspected On: 1/17/2014
Operating Permit Renewal Date: 3/15/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	20	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4530			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/24/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		
11	20	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4531			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		2/24/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
15,000		8/5/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: TOWN PUMP INC HELENA 1
1240 PROSPECT AVE
HELENA, MT 59601 LEWIS AND CLARK
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 25-08706
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 6/29/2019

Owners/Operators: Town Pump of Helena Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	33	4/15/1983	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2506			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/25/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	33	4/15/1983	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2507			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/25/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	33	4/15/1983	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2508			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/25/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: TOWN PUMP INC HELENA 1
1240 PROSPECT AVE
HELENA, MT 59601 LEWIS AND CLARK

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 25-08706
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 6/29/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
7	18	11/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2509			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		9/25/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	18	11/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2510			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		9/25/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: TOWN PUMP INC HELENA 2
1140 EUCLID AVE
HELENA, MT 59601 LEWIS AND CLARK

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 25-08707
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 6/29/2019

Owners/Operators: Town Pump of Helena Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	32	4/14/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
4832			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		4/24/2013	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
4	25	7/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
4833			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/29/2005	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
5	25	7/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
4834			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/29/2005	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: TOWN PUMP INC HELENA 2
1140 EUCLID AVE
HELENA, MT 59601 LEWIS AND CLARK

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 25-08707
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 6/29/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	25	7/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
4835			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: EXXONMOBIL HELENA PRODUCTS TERMINAL
3120 E US HWY 12
HELENA, MT 59601 LEWIS AND CLARK

Contact: Mike James, (406) 442-4190

Sys Fac ID: 25-08728
Last Inspected On: 2/24/2016
Operating Permit Renewal Date: 5/25/2019

Owners/Operators: Exxon Mobil Corporation, Owner (832)-625-7781 PO BOX 4849 HELENA MT 59604

Michael James, UST Class A Operator
Robert Ochsenbein, UST Class A Operator
James Vokral Sup, UST Class A Operator
Christopher Scott Martin, UST Class B Operator
Jim Gullon, UST Class B Global Operator
Marc Larson, UST Class B Global Operator
Robert Ochsenbein, UST Class B Global Operator
James Vokral Sup, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	66	1/1/1950	Bare Steel	Steel - Terminal Piping	
2774	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		11/18/2015	Deferred	MLLD Line Tightness Testing	
638,000		12/8/2015			
12	66	1/1/1950	Bare Steel	Steel - Terminal Piping	
2772	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		11/18/2015	Deferred	MLLD Line Tightness Testing	
1,200,000		12/8/2015			
14	66	1/1/1950	Bare Steel	Steel - Terminal Piping	
2770	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		11/18/2015	Deferred	MLLD Line Tightness Testing	
604,000		12/8/2015			

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: EXXONMOBIL HELENA PRODUCTS TERMINAL
3120 E US HWY 12
HELENA, MT 59601 LEWIS AND CLARK

Contact: Mike James, (406) 442-4190

Sys Fac ID: 25-08728
Last Inspected On: 2/24/2016
Operating Permit Renewal Date: 5/25/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
16	66	1/1/1950	Bare Steel	Steel - Terminal Piping	
2768	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		11/18/2015	Deferred	MLLD Line Tightness Testing	
603,330		12/8/2015			
26	29	1/1/1987	Bare Steel	Flexible Plastic	
2786	Yes		Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance			Deferred	Continuous Interstitial Monitor	
1,000					
28	29	1/1/1987	Bare Steel	Flexible Plastic	
2783	Yes		Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance			Deferred	Continuous Interstitial Monitor	
3,000					
30	29	1/1/1987	Bare Steel	Flexible Plastic	
2780	Yes		Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Hazardous Substance			Deferred	Continuous Interstitial Monitor	
10,000					
32	29	1/1/1987	Cathodically Protected Steel	Steel	High Level Alarm
2767			Double-Walled	none	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Mixture		11/18/2015	Continuous Interstitial Monitor	MLLD Line Tightness Testing	
2,000		12/8/2015			

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: EXXONMOBIL HELENA PRODUCTS TERMINAL
3120 E US HWY 12
HELENA, MT 59601 LEWIS AND CLARK

Contact: Mike James, (406) 442-4190

Sys Fac ID: 25-08728
Last Inspected On: 2/24/2016
Operating Permit Renewal Date: 5/25/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
35	66	1/1/1950	Bare Steel	Steel - Terminal Piping	
2778	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		11/18/2015	Deferred	MLLD Line Tightness Testing	
633,000		12/8/2015			

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: HELENA MAIN CENTRAL OFFICE
441 N PARK AVE
HELENA, MT 59601 LEWIS AND CLARK

Contact: kevin robison, (801) 237-5334

Sys Fac ID: 25-08775
Last Inspected On: 6/10/2014
Operating Permit Renewal Date: 10/18/2017

Owners/Operators:

Qwest Corporation, Owner	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111
Qwest Corporation, Operator	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111
Kevin Robison, UST Class A Operator		
Kevin Robison, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	1/1/1992	Fiberglass Reinforced Plastic	Steel	High Level Alarm
1728			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Deferred	
2,500		11/12/2015	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: FEDERAL RESERVE BANK HELENA
100 NEILL AVE
HELENA, MT 59601 LEWIS AND CLARK

Contact: Ron Hicks, (406) 447-3946

Sys Fac ID: 25-11291
Last Inspected On: 7/21/2014
Operating Permit Renewal Date: 1/9/2018

Owners/Operators: Federal Reserve Bank, Owner (406)-447-3940 100 NEILL AVE HELENA MT 59601-3329
Ron Hicks Jr, UST Class A Operator
Ron Hicks Jr, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	27	10/1/1989	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2322			None	Double-Walled	Yes
Currently in Use			Not Required	Pressurized	Galvanic
Heating Oil		7/21/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000		11/27/2012	TLS-300 , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: ZIP TRIP 42
3100 N MONTANA AVE
HELENA, MT 59602 LEWIS AND CLARK
Contact: (406) 449-8766

Sys Fac ID: 25-12353
Last Inspected On: 10/7/2014
Operating Permit Renewal Date: 3/2/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Tom Savas, UST Class A Operator
Luci Tuttle, UST Class B Operator
Karina Serrano, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	6/7/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
561			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		5/17/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		6/19/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	25	6/7/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
559			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/17/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		6/19/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	25	6/7/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
560			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/17/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		6/19/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: LAST CHANCE RENTAL & LEASING LLP
3122 AIRPORT ROAD
HELENA, MT 59601 LEWIS AND CLARK

Contact: John Maxness, (406) 442-2190

Sys Fac ID: 25-12834
Last Inspected On: 7/10/2014
Operating Permit Renewal Date: 8/19/2017

Owners/Operators:

Last Chance Rental & Leasing LLP, Owner	(406)-442-2190	2430 AIRPORT ROAD HELENA MT 59601
John Maxness, Operator	(406)-422-2190	2430 AIRPORT RD HELENA MT 59601
John Maxness, UST Class A Operator		
John Maxness, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	9/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4444			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		7/1/2014	TS-1000 , Incon	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: WATKINS & SHEPARD TRUCKING HELENA
1500 BLAINE ST
HELENA, MT 59601 LEWIS AND CLARK
Contact: Farren Flynn, (406) 442-9536

Sys Fac ID: 25-12917
Last Inspected On: 7/2/2014
Operating Permit Renewal Date: 7/18/2017

Owners/Operators: Watkins & Shepard Trucking, Owner (406)-728-6121 PO BOX 5328
MISSOULA MT 59806-5328

Brandon Dulaney, UST Class A Operator
Brandon Dulaney, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	2/3/1993	Cathodically Protected Steel	Steel	
4458		7/2/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Waste Oil		6/11/2014	Manual Interstitial Monitor	Continuous Interstitial Monitor	
2,000			TLS-300 , Veeder Root		
2	23	2/3/1993	Cathodically Protected Steel	Steel	
4459		7/2/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Waste Oil		6/11/2014	Manual Interstitial Monitor	Continuous Interstitial Monitor	
500			TLS-300 , Veeder Root		
3	21	11/1/1995	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4460		7/2/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel		6/11/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-300 , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: LAKESIDE GENERAL STORE
5330 YORK RD
HELENA, MT 59602 LEWIS AND CLARK

Contact: Thomas Morrison, (406) 443-1040

Sys Fac ID: 25-13657
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 3/30/2018

Owners/Operators:

Juniper Hill Farm LLC, Owner	(406)-443-1040	111 N LAST CHANCE GULCH STE 3B HELENA MT 59601-4144
Lakeside General Store LLC, Operator	(406)-443-1040	111 N LAST CHANCE GULCH, 3B HELENA MT 59601

Penny Hunsaker, UST Class A Operator
JoAnn Priebe, UST Class A Operator
Kathleen Schendel, UST Class A Operator
Penny Hunsaker, UST Class B Operator
Kathleen Schendel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	7/24/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4552			None	None	Yes
Currently in Use		7/24/2005	Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		2/3/2015	TLS-300 , Veeder Root		
2	21	7/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4553			None	None	Yes
Currently in Use		7/1/2005	Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		2/3/2015	TLS-300 , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: LITHIA CHRYSLER JEEP DODGE RAM OF HELENA
3401 US HWY 12 E
HELENA, MT 59601 LEWIS AND CLARK

Sys Fac ID: 25-13687
Last Inspected On: 8/21/2014
Operating Permit Renewal Date: 8/28/2017

Contact: Amanda Stewart, (406) 495-3203

Owners/Operators:

Helena Auto Center LLC, Operator	(406)-442-5810	PO BOX 6549 HELENA MT 59604
Lithia Chrysler Jeep Dodge Ram of Helena, Owner/Operator	(406)-442-9994	PO BOX 5298 HELENA MT 59604

Deann Horning, UST Class A Operator
Howard Reed, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	3/15/1996	Cathodically Protected Steel	Steel	
1244			Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Waste Oil		3/25/2014	Manual Interstitial Monitor	Deferred	
8,000		8/22/2014			

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: SLEEPING GIANT CONVENIENCE STORE
3425 E US HIGHWAY 12
HELENA, MT 59601 LEWIS AND CLARK

Sys Fac ID: 25-13763
Last Inspected On: 7/30/2016
Operating Permit Renewal Date: 8/13/2019

Contact: Todd Bachmeier, (406) 422-9034

Owners/Operators: Sleeping Giant Holding LLC, Owner — PO BOX 5807, HELENA MT 59604

Sleeping Giant Convenience Store LLC, Operator (406)-443-5050 — 3423 E US HWY 12, WASHINGTON DC 56901

Todd Bachmeier, UST Class A Operator
Mike Clasby, UST Class A Operator
Mike Clasby, UST Class B Operator
Todd Bachmeier, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
365			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		7/30/2016	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	20	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
366			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		7/30/2016	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	20	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4333			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		7/30/2016	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
4	20	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
368			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		7/30/2016	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: TOWN PUMP INC HELENA 6
2401 N MONTANA AVE
HELENA, MT 59601 LEWIS AND CLARK

Contact: Todd Fickler, (406) 443-5068

Sys Fac ID: 56-13818
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 6/29/2019

Owners/Operators: Park Street Holdings LLC, Owner (406)-467-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	9/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4610			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	19	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3443			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: ARMY AVIATION SUPPORT FACILITY
3333 SKYWAY DR
HELENA, MT 59602 LEWIS AND CLARK

Contact: Adel Johnson, (406) 324-3089

Sys Fac ID: 56-13821
Last Inspected On: 9/29/2015
Operating Permit Renewal Date: 2/9/2019

Owners/Operators: US Dept of Military Affairs Helena, Owner/Operator (406)-324-3000 PO BOX 4789
FORT HARRISON MT 59636-4789

Howard Eich, UST Class A Operator
Adel Johnson, UST Class A Operator
Thad Waples, UST Class A Operator
Kenneth Brug, UST Class B Operator
Michonne Cronquist, UST Class B Operator
Dave Goroski, UST Class B Operator
James Grigsby, UST Class B Operator
Mark Hall, UST Class B Operator
Adel Johnson, UST Class B Operator
David Johnson, UST Class B Operator
Adam Mckinlay, UST Class B Operator
James Scott, UST Class B Operator
Michael Steinberg, UST Class B Operator
Michael Young, UST Class B Operator
Braiden Burns, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	3/1/1997	Fiberglass Reinforced Plastic	No Piping	Positive Shutoff, High Level Alarm
827			Double-Walled	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Aviation Gas			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor		
25,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: ARMY AVIATION SUPPORT FACILITY
3333 SKYWAY DR
HELENA, MT 59602 LEWIS AND CLARK

Contact: Adel Johnson, (406) 324-3089

Sys Fac ID: 56-13821
Last Inspected On: 9/29/2015
Operating Permit Renewal Date: 2/9/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	19	3/1/1997	Fiberglass Reinforced Plastic	No Piping	Positive Shutoff, High Level Alarm
828			Double-Walled	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Aviation Gas			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor		
25,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: DAVES EXPRESS LUBE
4990 N MONTANA AVE
HELENA, MT 59602 LEWIS AND CLARK

Contact: David Clemens, (406) 449-9667

Sys Fac ID: 56-13828
Last Inspected On: 4/11/2016
Operating Permit Renewal Date: 7/27/2019

Owners/Operators: Dave's Express Lube Inc, Owner (406)-449-9667 4990 N MONTANA AVE HELENA MT 59602-7268

Dave Clemens, UST Class A Operator
Dave Clemens, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	18	1/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
372			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	18	1/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
373			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	18	1/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
374			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
4	18	1/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
375			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: MERGENTHALER TRANSFER & STORAGE CARTER DR
1430 CARTER DR
HELENA, MT 59601 LEWIS AND CLARK

Contact: Travis Sandau, (406) 443-7964

Sys Fac ID: 56-13831
Last Inspected On: 12/10/2014
Operating Permit Renewal Date: 3/19/2018

Owners/Operators: Mergenthaler Transfer & Storage, Owner (406)-443-7964 1430 CARTER DR HELENA MT 59601-6429
Dave Gardner, UST Class A Operator
Dave Gardner, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	11/1/1997	Cathodically Protected Steel	Flexible Plastic	
1609			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Waste Oil		12/10/2014	Manual Interstitial Monitor	Manual Interstitial Monitor	
3,000		12/10/2014		MLLD Line Tightness Testing	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: TOWN PUMP INC HELENA 4
2900 N MONTANA AVE
HELENA, MT 59601 LEWIS AND CLARK

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-13846
Last Inspected On: 3/14/2016
Operating Permit Renewal Date: 6/29/2019

Owners/Operators: Capitol Town Pump Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Megan Gretch, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Megan Gretch, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	18	6/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2680			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	
2	18	6/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2681			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	18	6/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2682			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: TOWN PUMP INC HELENA 4
2900 N MONTANA AVE
HELENA, MT 59601 LEWIS AND CLARK

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-13846
Last Inspected On: 3/14/2016
Operating Permit Renewal Date: 6/29/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	6/16/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2683			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	
5	18	7/24/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2684			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	
6	15	9/7/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4671			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: HOLIDAY #723
600 N FEE ST
HELENA, MT 59601 LEWIS AND CLARK
Contact: (952) 830-8899

Sys Fac ID: 56-13956
Last Inspected On: 11/2/2015
Operating Permit Renewal Date: 3/30/2019

Owners/Operators:

Rocky Mountain Oil Inc, Owner	(952)-830-8700	ATTN: ENVIRONMENTAL DIRECTOR 4567 AMERICAN BLVD W BLOOMINGTON MN 55437
Holiday #723, Operator	(952)-830-8747	606 N FEE ST HELENA MT 59601

Robert Deninno, UST Class A Operator
Kegan Krueger, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Ryan Coey, UST Class B Operator
Craig Hagmeier, UST Class B Operator
Cynthia Hellwitz, UST Class B Operator
Stephen Reckinger, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	17	10/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
4128			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
15,000		8/2/2015	TLS-450 , Veeder Root		
2	17	10/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
4129			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
10,000		12/22/2015	TLS-450 , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: SAFEWAY GASOLINE HELENA
611 N MONTANA AVE
HELENA, MT 59601 LEWIS AND CLARK
Contact: (406) 442-6631

Sys Fac ID: 56-14000
Last Inspected On: 8/16/2016
Operating Permit Renewal Date: 1/29/2020

Owners/Operators: Safeway Stores Inc, Owner (425)-455-6545 1121 124TH AVE NE BELLEVUE WA 98005-2101

Heath Brown, UST Class A Operator
Rachel Jones, UST Class A Operator
Aaron Nelson, UST Class A Operator
Lynn Pehrson, UST Class A Operator
Heath Brown, UST Class B Operator
ANITA L JOHNSON, UST Class B Operator
Rachel Jones, UST Class B Global Operator
Page Rost, UST Class B Global Operator
Justin W Smith, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	15	6/1/2001	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4330			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	15	6/1/2001	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4331			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: SAFEWAY GASOLINE HELENA
611 N MONTANA AVE
HELENA, MT 59601 LEWIS AND CLARK
Contact: (406) 442-6631

Sys Fac ID: 56-14000
Last Inspected On: 8/16/2016
Operating Permit Renewal Date: 1/29/2020

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	15	6/1/2001	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4332			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: SPRINT HELENA POP
1100 PHOENIX AVE
HELENA, MT 59601 LEWIS AND CLARK

Sys Fac ID: 56-14011
Last Inspected On: 3/17/2014
Operating Permit Renewal Date: 8/8/2017

Contact: Sara Cullen-Crafton, (913) 315-8624

Owners/Operators: Sprint Communications Co LLP, Owner (913)-762-5957 PO BOX 7994
SHAWNEE MISSION KS 66251-6106

Brian Wiedower, UST Class A Operator
Doug Dickinson, UST Class B Operator
Scott Hallesy, UST Class B Operator
Brandon Hyde, UST Class B Operator
Nikki Lattin, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4322			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,500		2/17/2014			

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: TOWN PUMP INC HELENA 5
1822 E CUSTER AVE
HELENA, MT 59602 LEWIS AND CLARK
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15029
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 6/19/2019

Owners/Operators: Main Street Holdings LLC, Owner (406)-497-6700 600 S MAIN ST BUTTE MT 59701-2534
Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	09	12/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5064			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000		12/7/2006	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	09	12/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5065			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		12/7/2006	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	09	12/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5066			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000		12/11/2006	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: TOWN PUMP INC HELENA 5
1822 E CUSTER AVE
HELENA, MT 59602 LEWIS AND CLARK
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15029
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 6/19/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	09	12/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5067			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		12/11/2006	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
5	09	12/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5068			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000		12/15/2006	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
6	09	12/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5074			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		12/15/2006	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: Costco Gasoline 633
CUSTER AVE & WASHINGTON ST
HELENA, MT 59602 LEWIS AND CLARK
Contact: Dennis Bock, (425) 427-7653

Sys Fac ID: 60-15051
Last Inspected On: 7/10/2014
Operating Permit Renewal Date: 11/13/2017

Owners/Operators: Costco Wholesale, Owner (425)-313-8100 ATTN: LICENSING
PO BOX 35005
SEATTLE WA 98124-8990

Dennis Bock, UST Class A Operator
Andrew Erdahl, UST Class A Operator
Chris Hazelett, UST Class A Operator
Jonathan Listar, UST Class A Operator
Daniel Manibusan, UST Class A Operator
Dan Martinez, UST Class A Operator
Stan Murray, UST Class A Operator
Dave Preston, UST Class A Operator
Michael Schaeffer, UST Class A Operator
Patrick Brand, UST Class B Operator
Andrew Erdahl, UST Class B Operator
Chris Hazelett, UST Class B Operator
Daniel Manibusan, UST Class B Operator
Steve Miller, UST Class B Operator
Stan Murray, UST Class B Operator
Dave Preston, UST Class B Operator
Dennis Bock, UST Class B Global Operator
Andrew Erdahl, UST Class B Global Operator
Jonathan Listar, UST Class B Global Operator
Michael Schaeffer, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	10	10/5/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5095			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
30,000		11/14/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: Costco Gasoline 633
CUSTER AVE & WASHINGTON ST
HELENA, MT 59602 LEWIS AND CLARK
Contact: Dennis Bock, (425) 427-7653

Sys Fac ID: 60-15051
Last Inspected On: 7/10/2014
Operating Permit Renewal Date: 11/13/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	10	10/5/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5096			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
30,000		11/14/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	10	10/5/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5097			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
30,000		11/14/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	05	4/12/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5281			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Hazardous Substance			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
1,500		11/14/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: MDT EQUIPMENT DEVELOPMENT BUILDING
490 18TH ST
HELENA, MT 59601 LEWIS AND CLARK

Contact: Doug Olson, (406) 444-3060

Sys Fac ID: 60-15139
Last Inspected On: 4/7/2014
Operating Permit Renewal Date: 5/15/2017

Owners/Operators: Montana Dept of Administration, Owner (406)-444-3060 CAPITOL ANNEX GENERAL SERVICES DIVISION
1310 E LOCKEY
HELENA MT 59620

Tom Russ, UST Class A Operator
Ed Sivils, UST Class A Operator
Carl Edgar, UST Class B Operator
Tom Mandeville, UST Class B Operator
Daniel Messerli, UST Class B Operator
Edward Naccarato, UST Class B Operator
James Simmons, UST Class B Operator
Ed Sivils, UST Class B Operator
David Spradlin, UST Class B Operator
Brian Taylor, UST Class B Operator
Zane Rudolph, UST Class B Global Operator
Tom Russ, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	07	10/1/2009	Aboveground Tank	Flexible Plastic	
5214	Yes	4/7/2014	None	Double-Walled	No
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
4,000					Yes
2	04	10/1/2012	Aboveground Tank	Flexible Plastic	
5386	Yes	10/31/2012	None	Double-Walled	No
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
4,000				Not Listed	Yes

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: TOWN PUMP INC HELENA #3
3161 N SANDERS
HELENA, MT 59602 LEWIS AND CLARK
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15210
Last Inspected On: 12/2/2015
Operating Permit Renewal Date: 3/18/2019

Owners/Operators: Capitol Town Pump Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000
Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	04	5/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5367			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
2	04	5/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5369			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
3	04	5/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5370			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Location: TOWN PUMP INC HELENA #3
3161 N SANDERS
HELENA, MT 59602 LEWIS AND CLARK
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15210
Last Inspected On: 12/2/2015
Operating Permit Renewal Date: 3/18/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	04	5/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5371			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
5	04	5/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5372			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in LEWIS AND CLARK County in the City of LINCOLN

Location: MOUNTAIN VIEW COOP LINCOLN
525 MAIN STREET
LINCOLN, MT 59639 LEWIS AND CLARK

Contact: Chester Kallem, (406) 453-2435

Sys Fac ID: 25-03995
Last Inspected On: 8/19/2014
Operating Permit Renewal Date: 10/16/2017

Owners/Operators: Mountain View Coop, Owner (406)-453-2435 ATTN DAVE DOUGLAS
2200 OLD HAVRE HWY
BLACK EAGLE MT 59414-1043

David Douglas, UST Class A Operator
Sharon Bell, UST Class B Operator
Ranae Brown, UST Class B Operator
David Douglas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	7/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2255		7/19/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		8/14/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	20	7/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2252		7/19/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		8/14/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
6	20	7/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2253		7/19/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		8/14/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of LINCOLN

Location: MOUNTAIN VIEW COOP LINCOLN
525 MAIN STREET
LINCOLN, MT 59639 LEWIS AND CLARK

Contact: Chester Kallem, (406) 453-2435

Sys Fac ID: 25-03995
Last Inspected On: 8/19/2014
Operating Permit Renewal Date: 10/16/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	20	7/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2254		7/19/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		8/14/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LEWIS AND CLARK County in the City of WOLF CREEK

Location: CANYON STORE EXXON
175 RECREATION RD
WOLF CREEK, MT 59648 LEWIS AND CLARK

Contact: Shawn Otheim, (775) 527-4507

Sys Fac ID: 25-04132
Last Inspected On: 10/16/2014
Operating Permit Renewal Date: 3/27/2018

Owners/Operators:

Otheim Family LLC, Owner	(406)-235-4111	175 RECREATION ROAD WOLF CREEK MT 59648
Shawn Otheim, Operator	(406)-235-4111	175 RECREATION ROAD WOLF CREEK MT 59648
Shawn Otheim, UST Class A Operator		
Shawn Otheim, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	17	11/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3483			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
3,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	17	11/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3484			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
7,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	17	11/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3946			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LEWIS AND CLARK County in the City of WOLF CREEK

Location: BOAT LOFT
1460 BEARTOOTH RD
WOLF CREEK, MT 59648 LEWIS AND CLARK
Contact: Marshall Trainor, (406) 452-3622

Sys Fac ID: 25-05921
Last Inspected On: 11/4/2014
Operating Permit Renewal Date: 1/8/2018

Owners/Operators: Driftwood Enterprises LLC, Owner (406)-235-4435 PO BOX 3386
GREAT FALLS MT 59403-3386

Marshall J Trainor, UST Class A Operator
Mike Liggett, UST Class B Operator
Chris Ryan, UST Class B Operator
Marshall J Trainor, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	4/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
473			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
4,000				Continuous Interstitial Monitor	

Facility Summary in LIBERTY County in the City of CHESTER

Location: AG AIR INC
LIBERTY COUNTY AIRPORT PO BOX 670
CHESTER, MT 59522 LIBERTY
Contact: Buster or Dana Ness, (406) 355-4257

Sys Fac ID: 26-02182
Last Inspected On: 4/14/2016
Operating Permit Renewal Date: 9/24/2019

Owners/Operators: Ag Air Inc, Owner (406)-759-5191 LIBERTY COUNTY AIRPORT
PO BOX 670
CHESTER MT 59522-0670

Dana Ness, UST Class A Operator
James Briden, UST Class B Operator
Dana Ness, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	22	5/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
358			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Aviation Gas			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		4/14/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LIBERTY County in the City of CHESTER

Location: TIBER MARINA
669 TIBER MARINA RD
CHESTER, MT 59522 LIBERTY

Contact: Mike Hilliard, (406) 759-5080

Sys Fac ID: 26-03877
Last Inspected On: 6/2/2016
Operating Permit Renewal Date: 9/29/2019

Owners/Operators:

Bureau of Reclamation Billings, Owner	(406)-247-7310	PO BOX 30137 BILLINGS MT 59107-0137
RuthAnn Norick, Operator	(406)-759-5476	PO BOX 655 CHESTER MT 59522
Michael Hilliard, UST Class A Operator		
Michael Hilliard, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	30	5/1/1986	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3997			Excavation Liner	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Gasoline		6/2/2016	Automatic Tank Gauging 0.2	Deferred	
1,000			EECO 1500 , EMCO Electronics		

Facility Summary in LIBERTY County in the City of CHESTER

Location: ROOSEVELT SERVICE INC
US HIGHWAY 2 PO BOX 389
CHESTER, MT 59522 LIBERTY

Contact: Bob Nordstrom, (406) 759-5278

Sys Fac ID: 26-06061
Last Inspected On: 4/14/2016
Operating Permit Renewal Date: 9/29/2019

Owners/Operators:

Barbara Nordstrom, Owner	(406)-759-5278	ROOSEVELT SERVICE INC PO BOX 389 CHESTER MT 59522-0389
Robert Nordstrom, Owner	(406)-759-5278	ROOSEVELT SERVICE INC PO BOX 389 CHESTER MT 59522-0389
Robert Nordstrom, UST Class A Operator		
Duane Aitken, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	25	6/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1752			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		4/14/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		9/15/2015	OPW 1500 , OPW		
7	25	6/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1753			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		4/14/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		9/15/2015	OPW 1500 , OPW		

Facility Summary in LIBERTY County in the City of CHESTER

Location: FRASER OIL INC CHESTER
US HIGHWAY 2
CHESTER, MT 59522 LIBERTY

Contact: Jim Fraser, (406) 292-3833

Sys Fac ID: 26-13006
Last Inspected On: 12/11/2014
Operating Permit Renewal Date: 3/17/2018

Owners/Operators: Fraser Oil Inc, Owner (406)-292-3833 PO BOX 770
INVERNESS MT 59530-0770

Cory Fraser, UST Class A Operator
Cory Fraser, UST Class B Operator
Craig Fraser, UST Class B Operator
Jerry Fraser, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	22	10/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1123			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/11/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		12/11/2014			
5	22	10/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1124			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		12/11/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
1,000		12/11/2014			
6	22	10/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1125			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/11/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
1,000		12/11/2014			

Facility Summary in LIBERTY County in the City of CHESTER

Location: CHESTER SUPERMARKET
1498 US HIGHWAY 2
CHESTER, MT 59522 LIBERTY

Contact: Harinder Singh, (406) 759-5538

Sys Fac ID: 26-13532
Last Inspected On: 12/11/2014
Operating Permit Renewal Date: 3/13/2018

Owners/Operators:

Indian Brothers LLC, Owner	(406)-759-5538	1498 US HWY 2 CHESTER MT 59522
Chester Supermarket INC, Operator	(406)-759-5538	1498 US HWY 2 CHESTER MT 59522
Mike Scott, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	9/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3223			None	Double-Walled	Yes
Currently in Use		9/1/2005	Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000			OPW 1500 , OPW		
2	21	9/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3224			None	Double-Walled	Yes
Currently in Use		9/1/2005	Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
5,000			OPW 1500 , OPW		
3	21	9/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3225			None	Double-Walled	Yes
Currently in Use		9/1/2005	Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
7,000			OPW 1500 , OPW		

Facility Summary in LINCOLN County in the City of EUREKA

Location: BIG SKY TIRE & AUTO
495 US HIGHWAY 93 N
EUREKA, MT 59917 LINCOLN

Contact: Ernie Roo, (406) 297-2623

Sys Fac ID: 27-02343
Last Inspected On: 2/19/2015
Operating Permit Renewal Date: 3/21/2018

Owners/Operators: EJ Properties LLC, Owner (406)-297-2623 PO BOX 629 EUREKA MT 59917

Joey Burgess, UST Class A Operator
Kary Tonjum, UST Class A Operator
Joey Burgess, UST Class B Operator
Kary Tonjum, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	10/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
1856			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic, Impressed Current
Diesel		2/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		11/14/2005	Gilbarco EMC Basic , Gilbarco		
6	36	5/6/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1851			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		11/14/2005	Gilbarco EMC Basic , Gilbarco		
7	36	5/6/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1852			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		11/14/2005	Gilbarco EMC Basic , Gilbarco		

Facility Summary in LINCOLN County in the City of EUREKA

Location: BIG SKY TIRE & AUTO
495 US HIGHWAY 93 N
EUREKA, MT 59917 LINCOLN

Contact: Ernie Roo, (406) 297-2623

Sys Fac ID: 27-02343
Last Inspected On: 2/19/2015
Operating Permit Renewal Date: 3/21/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	36	5/6/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1853			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		11/14/2005	Gilbarco EMC Basic , Gilbarco		
9	34	5/6/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1854			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		2/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		11/14/2005	Gilbarco EMC Basic , Gilbarco		
10	27	5/6/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
1855			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic, Impressed Current
Diesel		2/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		11/14/2005	Gilbarco EMC Basic , Gilbarco		

Facility Summary in LINCOLN County in the City of EUREKA

Location: EUREKA MIDDLE SCHOOL
335 6TH ST E
EUREKA, MT 59917 LINCOLN

Contact: Warren Powell, (406) 297-5729

Sys Fac ID: 27-04550
Last Inspected On: 3/11/2014
Operating Permit Renewal Date: 5/22/2017

Owners/Operators: Eureka Public Schools LCHS, Owner (406)-265-2525 PO BOX 2000 EUREKA MT 59917-2000

Warren M Powell, UST Class A Operator
Warren M Powell, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	19	8/1/1997	Fiberglass Reinforced Plastic	Copper	Flapper Valve (Auto Shutoff)
1540		12/12/2012	None	Secondary Containment Chase	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Heating Oil			Automatic Tank Gauging 0.2	Manual Interstitial Monitor	
12,000			TS-1000 , Incon		
6	19	8/1/1997	Fiberglass Reinforced Plastic	Copper	Flapper Valve (Auto Shutoff)
1541			None	Secondary Containment Chase	Yes
Temporarily Out of Use			Not Required	U.S. Suction	Not Applicable
Heating Oil			Automatic Tank Gauging 0.2	Not Listed	
8,000			TS-1000 , Incon		

Facility Summary in LINCOLN County in the City of EUREKA

Location: KSANKA MOTEL & MINI MART
US HIGHWAY 93 & MT HIGHWAY 37
EUREKA, MT 59917 LINCOLN

Contact: Andre Hofstee, (406) 297-3127

Sys Fac ID: 27-05303
Last Inspected On: 9/2/2014
Operating Permit Renewal Date: 9/25/2017

Owners/Operators: Ksanka Enterprises, Owner (406)-297-3127 PO BOX 857
EUREKA MT 59917-0857

Andre Hofstee, UST Class A Operator
Andre Hofstee, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	26	4/20/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3308			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		4/13/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/29/2014	TLS-250 , Veeder Root		
5	26	4/20/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3309			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		7/29/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		7/29/2014	TLS-250 , Veeder Root		

Facility Summary in LINCOLN County in the City of EUREKA

Location: TOWN PUMP INC EUREKA
US HIGHWAY 93
EUREKA, MT 59917 LINCOLN

Contact: Roger Hovis, (406) 296-2431

Sys Fac ID: 27-08699
Last Inspected On: 9/24/2014
Operating Permit Renewal Date: 10/16/2017

Owners/Operators: Eureka Town Pump Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Don Edmisten, UST Class B Operator
Charles A Armstrong, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	25	11/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2517			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		3/25/2010	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
5	25	11/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2518			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		3/25/2010	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
6	25	11/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2519			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		3/25/2010	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LINCOLN County in the City of EUREKA

Location: TOWN PUMP INC EUREKA
US HIGHWAY 93
EUREKA, MT 59917 LINCOLN
Contact: Roger Hovis, (406) 296-2431

Sys Fac ID: 27-08699
Last Inspected On: 9/24/2014
Operating Permit Renewal Date: 10/16/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	25	11/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2520			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		3/25/2010	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
8	25	11/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2521			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/25/2010	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
9	16	11/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4251			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/25/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
10	16	11/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4252			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/25/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LINCOLN County in the City of EUREKA

Location: TOWN PUMP INC EUREKA
US HIGHWAY 93
EUREKA, MT 59917 LINCOLN
Contact: Roger Hovis, (406) 296-2431

Sys Fac ID: 27-08699
Last Inspected On: 9/24/2014
Operating Permit Renewal Date: 10/16/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	02	3/14/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5467		3/19/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
12	02	3/14/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5468		3/19/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
13	02	3/14/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5469		3/19/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in LINCOLN County in the City of EUREKA

Location: RANCH HAND INC
1000 US HIGHWAY 93 N
EUREKA, MT 59917 LINCOLN

Sys Fac ID: 27-12713
Last Inspected On: 1/26/2016
Operating Permit Renewal Date: 3/19/2019

Contact: Michael Stoken, (406) 297-2342

Owners/Operators:

Michael Stoken, Owner	(406)-296-2342	PO BOX 749 EUREKA MT 59917-0749
Pat Stoken, Owner	(406)-296-2342	PO BOX 749 EUREKA MT 59917-0749

Dorothy Bickel, UST Class A Operator
Destin Stoken, UST Class A Operator
Dorothy Bickel, UST Class B Operator
Destin Stoken, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	18	5/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2960			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
20,000		1/13/2016	Gilbarco EMC Basic , Gilbarco		
9	18	5/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2961			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
15,000		1/13/2016	Gilbarco EMC Basic , Gilbarco		
10	18	5/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2962			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
15,000		1/13/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in LINCOLN County in the City of EUREKA

Location: RANCH HAND INC
1000 US HIGHWAY 93 N
EUREKA, MT 59917 LINCOLN

Contact: Michael Stoken, (406) 297-2342

Sys Fac ID: 27-12713
Last Inspected On: 1/26/2016
Operating Permit Renewal Date: 3/19/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	18	5/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2963			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/13/2016	Gilbarco EMC Basic , Gilbarco		
12	18	5/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2964			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/13/2016	Gilbarco EMC Basic , Gilbarco		
13	18	5/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2965			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		1/13/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in LINCOLN County in the City of FORTINE

Location: CRYSTAL LAKES RESORT INC
CRYSTAL LAKES RD
FORTINE, MT 59918 LINCOLN

Contact: Robert LeBlanc, (406) 752-7662

Sys Fac ID: 27-03824
Last Inspected On: 3/10/2016
Operating Permit Renewal Date: 4/2/2019

Owners/Operators: James E Smith, Owner (406)-882-4432 PO BOX 255
FORTINE MT 59918-0255

James E Smith, UST Class A Operator
James E Smith, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	30	6/1/1986	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3892			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Jet Fuel		1/22/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/22/2016	TS-1000 , Incon		
2	30	6/1/1986	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3893			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Aviation Gas		1/22/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/22/2016	TS-1000 , Incon		

Facility Summary in LINCOLN County in the City of FORTINE

Location: FORTINE MERCANTILE US 93
12000 US HIGHWAY 93 S
FORTINE, MT 59918 LINCOLN

Contact: Betty Stinger, (406) 882-4446

Sys Fac ID: 27-13725
Last Inspected On: 2/17/2015
Operating Permit Renewal Date: 3/26/2018

Owners/Operators: Betty Stinger, Owner (406)-882-4446 PO BOX 215
TREGO MT 59934-0215

Debbie Peterson, UST Class A Operator
Debbie Peterson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	4/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4705			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		2/16/2015	Gilbarco EMC Basic , Gilbarco		
2	20	4/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4706			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		2/16/2015	Gilbarco EMC Basic , Gilbarco		
3	20	4/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4707			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		2/16/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		2/16/2015	Gilbarco EMC Basic , Gilbarco		

Facility Summary in LINCOLN County in the City of LIBBY

Location: SAVE RITE WEST
31978 US HIGHWAY 2
LIBBY, MT 59923 LINCOLN

Contact: Rob Uithof, (406) 293-4119

Sys Fac ID: 27-01239
Last Inspected On: 8/24/2016
Operating Permit Renewal Date: 10/17/2019

Owners/Operators: Golden State Oil, Owner (406)-293-4119 31978 US HIGHWAY 2 LIBBY MT 59923-3026

Lloyd Holcomb, UST Class A Operator
Jesse Knapp, UST Class A Operator
Lloyd Holcomb, UST Class B Operator
Jesse Knapp, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	22	3/1/1994	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2158		9/16/2013	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Gasoline		5/18/2007	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			TS-1000 , Incon		
4	22	3/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2159		9/16/2013	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Gasoline		5/20/2010	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			TS-1000 , Incon		
5	22	3/1/1994	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2160		9/16/2013	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel		5/20/2010	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			TS-1000 , Incon		
12	19	6/1/1997	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2161		9/16/2013	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Galvanic
Gasoline		8/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000		9/12/2013	Gilbarco EMC Basic , Gilbarco		

Facility Summary in LINCOLN County in the City of LIBBY

Location: SAVE RITE WEST
31978 US HIGHWAY 2
LIBBY, MT 59923 LINCOLN
Contact: Rob Uithof, (406) 293-4119

Sys Fac ID: 27-01239
Last Inspected On: 8/24/2016
Operating Permit Renewal Date: 10/17/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
13	19	6/1/1997	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2162		9/16/2013	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Galvanic
Gasoline		8/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000		9/12/2013	Gilbarco EMC Basic , Gilbarco		
14	19	6/1/1997	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2163		9/16/2013	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Galvanic
Diesel		8/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000		9/12/2013	Gilbarco EMC Basic , Gilbarco		
15	19	6/1/1997	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2164		9/16/2013	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Galvanic
Diesel		8/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000		9/12/2013	Gilbarco EMC Basic , Gilbarco		
16	19	6/1/1997	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2165		9/16/2013	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Galvanic
Diesel		8/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000		9/12/2013	Gilbarco EMC Basic , Gilbarco		
17	19	6/1/1997	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2166		9/16/2013	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Galvanic
Diesel		8/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
3,000		9/12/2013	Gilbarco EMC Basic , Gilbarco		

Facility Summary in LINCOLN County in the City of LIBBY

Location: SAVE RITE SOUTH
33934 US HIGHWAY 2
LIBBY, MT 59923 LINCOLN

Contact: Robert Uithof, (406) 293-4119

Sys Fac ID: 27-01240
Last Inspected On: 8/24/2016
Operating Permit Renewal Date: 10/17/2019

Owners/Operators: Golden State Oil, Owner (406)-293-4119 31978 US HIGHWAY 2
LIBBY MT 59923-3026

Lloyd Holcomb, UST Class A Operator
Jesse Knapp, UST Class A Operator
Lloyd Holcomb, UST Class B Operator
Jesse Knapp, UST Class B Operator
Lloyd Holcomb, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	27	5/1/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2168		10/3/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Gasoline		5/18/2007	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
6,000		11/18/2010	TLS-350/Gilbarco EMC , Veeder Root		
2	27	5/1/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2169		10/3/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Gasoline		5/18/2007	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000		11/18/2010	TLS-350/Gilbarco EMC , Veeder Root		
6	27	5/1/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2167		10/3/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Gasoline		5/18/2007	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
10,000		11/18/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LINCOLN County in the City of LIBBY

Location: SAVE RITE SOUTH
33934 US HIGHWAY 2
LIBBY, MT 59923 LINCOLN

Contact: Robert Uithof, (406) 293-4119

Sys Fac ID: 27-01240
Last Inspected On: 8/24/2016
Operating Permit Renewal Date: 10/17/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	21	6/3/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2170		10/3/2016	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Galvanic
Diesel		8/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000		7/18/2007	TLS-350/Gilbarco EMC , Veeder Root		
8	21	6/3/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2171		10/3/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Galvanic
Diesel		8/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000		7/18/2007	TLS-350/Gilbarco EMC , Veeder Root		
9	21	6/3/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2172		10/3/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Galvanic
Gasoline		8/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000		7/18/2007	TLS-350/Gilbarco EMC , Veeder Root		
10	21	6/23/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2173		10/3/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Galvanic
Diesel		8/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000		7/18/2007	TLS-350/Gilbarco EMC , Veeder Root		
11	21	6/23/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2174		10/3/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Galvanic
Diesel		8/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000		7/18/2007	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LINCOLN County in the City of LIBBY

Location: SAVE RITE SOUTH
33934 US HIGHWAY 2
LIBBY, MT 59923 LINCOLN

Contact: Robert Uithof, (406) 293-4119

Sys Fac ID: 27-01240
Last Inspected On: 8/24/2016
Operating Permit Renewal Date: 10/17/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
12	21	6/23/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2175		10/3/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Galvanic
Gasoline		8/24/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000		7/18/2007	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LINCOLN County in the City of LIBBY

Location: ST JOHNS LUTHERAN HOSPITAL
350 LOUISIANA AVE
LIBBY, MT 59923 LINCOLN

Contact: Tony Rebo, (406) 293-0785

Sys Fac ID: 27-01695
Last Inspected On: 9/4/2014
Operating Permit Renewal Date: 9/25/2017

Owners/Operators:

Cabinet Peaks Medical Center, Owner	(406)-283-7000	209 HEALTH PARK DRIVE LIBBY MT 59923
Tony Rebo, Operator	(406)-283-7339	209 HEALTH PARK DRIVE LIBBY MT 59923-2130
Tony Rebo, UST Class A Operator		
Tony Rebo, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	18	7/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1952		7/29/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Heating Oil			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-300 , Veeder Root		

Facility Summary in LINCOLN County in the City of LIBBY

Location: SEWER PLANT
750 CITY SERVICE RD
LIBBY, MT 59923 LINCOLN

Contact: Dan Burns, (406) 293-2775

Sys Fac ID: 27-03164
Last Inspected On: 11/19/2014
Operating Permit Renewal Date: 3/12/2018

Owners/Operators: City Of Libby, Owner (406)-293-2775 PO BOX 1428
LIBBY MT 59923-1428

Lucas Backen, UST Class A Operator
Mike Voorhies, UST Class A Operator
Mike Voorhies, UST Class B Operator
Lucas Backen, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	29	12/1/1986	Fiberglass Reinforced Plastic	Steel	Flapper Valve (Auto Shutoff)
4089			None	none	Yes
Currently in Use		12/1/1996	Not Required	U.S. Suction	Not Applicable, Galvanic
Diesel		11/9/2011	Manual Tank Gauging	MLLD Line Tightness Testing	
550		11/9/2011			

Facility Summary in LINCOLN County in the City of LIBBY

Location: ASA WOOD SCHOOL
700 IDAHO AVE
LIBBY, MT 59923 LINCOLN

Contact: Kirby Maki, (406) 293-2791

Sys Fac ID: 27-05434
Last Inspected On: 1/12/2015
Operating Permit Renewal Date: 3/4/2018

Owners/Operators: School Dist 4 Libby, Owner (406)-293-2791 724 LOUISIANA AVE LIBBY MT 59923-2106

Louie Mysse, UST Class A Operator
Louie Mysse, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	10/1/1993	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1528			Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil		5/28/2015	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
10,000		7/16/2015	EECO 1000 , EMCO Electronics	Continuous Interstitial Monitor	

Facility Summary in LINCOLN County in the City of LIBBY

Location: MCGRADE SCHOOL UST
933 FARM TO MARKET RD STE C
LIBBY, MT 59923 LINCOLN

Contact: Kirby Maki, (406) 293-8811

Sys Fac ID: 27-05435
Last Inspected On: 1/12/2015
Operating Permit Renewal Date: 3/4/2018

Owners/Operators: School Dist 4 Libby, Owner (406)-293-2791 724 LOUISIANA AVE LIBBY MT 59923-2106

Louie Mysse, UST Class A Operator
Louie Mysse, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	8/1/1995	Cathodically Protected Steel	Steel	High Level Alarm
1529			Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil		1/9/2015	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
4,000		7/16/2015	EECO 1500 , EMCO Electronics	Continuous Interstitial Monitor	

Facility Summary in LINCOLN County in the City of LIBBY

Location: PLUMMER ELEMENTARY SCHOOL
263 INDIAN HEAD RD
LIBBY, MT 59923 LINCOLN

Contact: Kirby Maki, (406) 293-8811

Sys Fac ID: 27-05436
Last Inspected On: 1/12/2015
Operating Permit Renewal Date: 2/19/2018

Owners/Operators: School Dist 4 Libby, Owner (406)-293-2791 724 LOUISIANA AVE LIBBY MT 59923-2106

Louie Mysse, UST Class A Operator
Louie Mysse, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	20	8/1/1996	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1530			Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil		1/9/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
4,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in LINCOLN County in the City of LIBBY

Location: LIBBY HIGH SCHOOL DIST 4
150 EDUCATION WAY
LIBBY, MT 59923 LINCOLN

Contact: Kirby Maki, (406) 293-8811

Sys Fac ID: 27-05437
Last Inspected On: 1/12/2015
Operating Permit Renewal Date: 3/4/2018

Owners/Operators: School Dist 4 Libby, Owner (406)-293-2791 724 LOUISIANA AVE LIBBY MT 59923-2106

Louie Mysse, UST Class A Operator
Louie Mysse, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	2/5/1990	Unknown	Copper	
1531	Yes		None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Heating Oil		11/4/2011	Deferred	Continuous Interstitial Monitor	
2,000			Gilbarco EMC Basic , Gilbarco		
3	26	2/5/1990	Unknown	Copper	
1532	Yes		None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Heating Oil		11/4/2011	Deferred	Continuous Interstitial Monitor	
2,000			Gilbarco EMC Basic , Gilbarco		
4	22	7/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1533			Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Galvanic
Heating Oil		1/9/2015	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
10,000		5/28/2015	Gilbarco EMC Basic , Gilbarco		

Facility Summary in LINCOLN County in the City of LIBBY

Location: HAPPY'S ROADHOUSE INN
72576 US HWY 2
LIBBY, MT 59923 LINCOLN

Contact: Gerald Mick, (406) 293-4079

Sys Fac ID: 27-05998
Last Inspected On: 1/21/2014
Operating Permit Renewal Date: 3/18/2017

Owners/Operators:

Carry L Mick, Owner/Operator	(406)-293-4079	57 SMITH DRIVE LIBBY MT 59923
Gerald L Mick, Owner/Operator	(406)-293-4079	57 SMITH DRIVE LIBBY MT 59923

Carry Mick, UST Class A Operator
Gerald Mick, UST Class A Operator
Deb Steinke, UST Class A Operator
Gerald Mick, UST Class B Operator
Deb Steinke, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	3/23/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1282			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		1/16/2014	Automatic Tank Gauging 0.2	Deferred	
8,000			TS-1000 , Incon		
2	32	3/23/1984	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1283			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		1/16/2014	Automatic Tank Gauging 0.2	Deferred	
8,000			TS-1000 , Incon		

Facility Summary in LINCOLN County in the City of LIBBY

Location: ST JOSEPH PARISH
719 UTAH AVE
LIBBY, MT 59923 LINCOLN

Contact: (406) 293-4322

Sys Fac ID: 27-07289
Last Inspected On: 9/7/2015
Operating Permit Renewal Date: 12/11/2018

Owners/Operators: Diocese of Helena, Owner (406)-293-4322 PO BOX 1729
HELENA MT 59624-1729

Lauri A Youso, UST Class A Operator
Lauri Youso, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	22	11/30/1993	Fiberglass Reinforced Plastic	Copper	Flapper Valve (Auto Shutoff)
833			Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Heating Oil			Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
1,000			LDE Series , Pneumercator		

Facility Summary in LINCOLN County in the City of LIBBY

Location: LIBBY CENTRAL OFFICE 9080 B01
114 E 4TH ST
LIBBY, MT 59923 LINCOLN

Contact: Ed Winkler, (406) 293-5848

Sys Fac ID: 27-07386
Last Inspected On: 7/9/2014
Operating Permit Renewal Date: 7/31/2017

Owners/Operators: Citizens Communications Company, Owner (916)-686-3499 ATTN BRIAN MCGUINNESS
9260 E STOCKTON BLVD
ELK GROVE CA 95624-1456

Alan Kelly, UST Class A Operator
Brian McGuinness, UST Class A Operator
Alan Kelly, UST Class B Operator
Brian McGuinness, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	8/1/1991	Fiberglass Reinforced Plastic	Steel	High Level Alarm
4307		7/9/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Gravity Feed	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
600			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LINCOLN County in the City of LIBBY

Location: HARLOWS SCHOOL BUS SERVICE INC LIBBY
30772 US HIGHWAY 2
LIBBY, MT 59923 LINCOLN

Contact: Dan Zachreson, (406) 293-8845

Sys Fac ID: 27-07523
Last Inspected On: 7/29/2014
Operating Permit Renewal Date: 12/17/2017

Owners/Operators: Harlows School Bus Service Inc, Owner (406)-293-8845 30772 US HIGHWAY 2 LIBBY MT 59923-3130

Wesley Tangen, UST Class A Operator
Hugh Taylor, UST Class A Operator
Wesley Tangen, UST Class B Operator
Hugh Taylor, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	23	2/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3101			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Deferred	
2,000			TLS-300 , Veeder Root		
4	23	2/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3102			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Deferred	
2,000			TLS-300 , Veeder Root		

Facility Summary in LINCOLN County in the City of LIBBY

Location: AITKENS QUIK STOP INC
120 W 9TH ST
LIBBY, MT 59923 LINCOLN

Sys Fac ID: 27-08831
Last Inspected On: 1/8/2016
Operating Permit Renewal Date: 3/2/2019

Contact: Steve Bryant, (406) 293-6715

Owners/Operators: Aitkens Quik Stop Inc, Owner (406)-847-4080 ATTN JEFF AITKEN
1402 MT HIGHWAY 200
NOXON MT 59853-9750

Jeffrey Aitken, UST Class A Operator
Jeffrey Aitken, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	42	11/21/1974	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1274			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/19/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		1/6/2016	TLS-300 , Veeder Root		
4	42	11/21/1974	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4881			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/19/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/6/2016	TLS-300 , Veeder Root		
5	42	11/21/1974	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1276			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/19/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		5/9/2012	TLS-300 , Veeder Root		

Facility Summary in LINCOLN County in the City of LIBBY

Location: MOORE OIL INC KARDGUARD
E 1ST ST & MONTANA AVE
LIBBY, MT 59923 LINCOLN

Contact: Larry Kelly, (406) 293-5947

Sys Fac ID: 27-10130
Last Inspected On: 11/22/2016
Operating Permit Renewal Date: 12/21/2016

Owners/Operators: Moore Oil Inc, Owner (406)-827-4314 2718 TRADEWINDS WAY
THOMPSON FALLS MT 59873-9706

Larry Kelly, UST Class A Operator
Larry Kelly, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	12/19/1984	Bare Steel	Flexible Plastic	
1700	Yes	12/20/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
20,000					
2	31	12/19/1984	Bare Steel	Flexible Plastic	
1701	Yes	12/20/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
20,000					
4	42	7/1/1974	Bare Steel	Flexible Plastic	
1702	Yes	12/20/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000					

Facility Summary in LINCOLN County in the City of LIBBY

Location: MOORE OIL INC KEYLOCK
1328 US HIGHWAY 2 S
LIBBY, MT 59923 LINCOLN

Contact: Bary Moore, (406) 827-3498

Sys Fac ID: 27-10131
Last Inspected On: 9/13/2013
Operating Permit Renewal Date: 11/12/2016

Owners/Operators: Moore Oil Inc, Owner (406)-827-4314 2718 TRADEWINDS WAY
THOMPSON FALLS MT 59873-9706

Larry Kelly, UST Class A Operator
Larry Kelly, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	19	10/17/1997	Unknown	Flexible Plastic	
1703	Yes	12/20/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
12,000					
5	19	11/17/1997	Unknown	Flexible Plastic	
1704	Yes	12/20/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000					
6	19	10/17/1997	Unknown	Flexible Plastic	
1705	Yes	12/20/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
17,000					
7	19	10/17/1997	Unknown	Flexible Plastic	
1706	Yes	12/20/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000					

Facility Summary in LINCOLN County in the City of LIBBY

Location: MACS PLACE
1427 MT HIGHWAY 37
LIBBY, MT 59923 LINCOLN

Contact: Bill Avants, (406) 293-7799

Sys Fac ID: 27-10660
Last Inspected On: 8/17/2016
Operating Permit Renewal Date: 10/11/2019

Owners/Operators:

Northside Enterprises LLC, Owner	(406)-293-7799	1423 MT HIGHWAY 37 LIBBY MT 59923-9309
William Avants, Operator	(406)-293-7799	1423 MT HIGHWAY 37 LIBBY MT 59923-9309
William Avants, UST Class A Operator		
William Avants, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	41	3/23/1975	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1272			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		8/17/2016	Automatic Tank Gauging 0.2	Deferred	
4,000		12/30/2005	TLS-300 , Veeder Root		
2	41	3/23/1975	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1273			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		8/17/2016	Automatic Tank Gauging 0.2	Deferred	
12,000		12/30/2005	TLS-300 , Veeder Root		

Facility Summary in LINCOLN County in the City of LIBBY

Location: AITKENS QUIK STOP LIBBY
3490 US HIGHWAY 2 S
LIBBY, MT 59923 LINCOLN

Contact: Jeff Aitken, (406) 293-9411

Sys Fac ID: 27-10863
Last Inspected On: 11/19/2014
Operating Permit Renewal Date: 3/31/2018

Owners/Operators: Aitkens Quik Stop Inc, Owner (406)-847-4080 ATTN JEFF AITKEN
1402 MT HIGHWAY 200
NOXON MT 59853-9750

Jeffrey Aitken, UST Class A Operator
Jeffrey Aitken, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	25	4/29/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
676			None	None	Yes
Currently in Use		10/2/2001	Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		11/18/2014	Tank Tightness Testing, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
17,000		11/17/2014			
5	25	4/29/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
677			None	None	Yes
Currently in Use		10/2/2001	Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		11/18/2014	Tank Tightness Testing, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
17,000		11/17/2014			
6	25	4/29/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
678			None	None	Yes
Currently in Use		10/2/2001	Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/18/2014	Tank Tightness Testing, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		11/17/2014			
7	25	4/29/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
679			None	None	Yes
Currently in Use		10/2/2001	Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/18/2014	Tank Tightness Testing, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		11/17/2014			

Facility Summary in LINCOLN County in the City of LIBBY

Location: AITKENS QUIK STOP LIBBY
3490 US HIGHWAY 2 S
LIBBY, MT 59923 LINCOLN

Contact: Jeff Aitken, (406) 293-9411

Sys Fac ID: 27-10863
Last Inspected On: 11/19/2014
Operating Permit Renewal Date: 3/31/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	25	4/29/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
680			None	None	Yes
Currently in Use		10/2/2001	Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/18/2014	Tank Tightness Testing, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		11/17/2014			

Facility Summary in LINCOLN County in the City of LIBBY

Location: TOWN PUMP INC LIBBY 2
US HIGHWAY 2 & E POPLAR ST
LIBBY, MT 59923 LINCOLN

Contact: (406) 293-2222

Sys Fac ID: 56-14121
Last Inspected On: 11/27/2015
Operating Permit Renewal Date: 3/5/2019

Owners/Operators: Columbia Falls Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	12	6/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4922			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	12	6/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4923			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	12	6/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4924			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LINCOLN County in the City of LIBBY

Location: TOWN PUMP INC LIBBY 2
US HIGHWAY 2 & E POPLAR ST
LIBBY, MT 59923 LINCOLN
Contact: (406) 293-2222

Sys Fac ID: 56-14121
Last Inspected On: 11/27/2015
Operating Permit Renewal Date: 3/5/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	12	6/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4925			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	12	6/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4927			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	12	6/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4928			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in LINCOLN County in the City of LIBBY

Location: CABINET PEAKS MEDICAL CENTER
209 HEALTH PARK DR
LIBBY, MT 59923 LINCOLN

Contact: Tony Rebo, (406) 293-0785

Sys Fac ID: 60-15252
Last Inspected On: 12/5/2014
Operating Permit Renewal Date: 12/19/2017

Owners/Operators: Cabinet Peaks Medical Center, Owner (406)-283-7000 209 HEALTH PARK DRIVE LIBBY MT 59923

Tony Rebo, UST Class A Operator
Tony Rebo, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	03	11/29/2013	Bare Steel	Flexible Plastic	High Level Alarm
5414	Yes	11/29/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	
Diesel			Continuous Interstitial Monitor, Deferred	Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Not Listed	

Facility Summary in LINCOLN County in the City of TROY

Location: TROY HIGH SCHOOL MISSOULA AVE
204 MISSOULA AVE
TROY, MT 59935 LINCOLN

Contact: Dan Wendt, (406) 295-4606

Sys Fac ID: 27-00763
Last Inspected On: 1/6/2016
Operating Permit Renewal Date: 3/2/2019

Owners/Operators: School Dist 1 Troy, Owner (406)-295-4606 PO BOX 867
TROY MT 59935-0867

John L Daniel, UST Class A Operator
Keith Haggerty, UST Class A Operator
John L Daniel, UST Class B Global Operator
Keith Haggerty, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	8/1/1987	Cathodically Protected Steel	Copper	Flapper Valve (Auto Shutoff)
2147			Excavation Liner	PVC	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Heating Oil		1/6/2016	Manual Interstitial Monitor	Manual Interstitial Monitor	
10,000					
3	29	8/1/1987	Cathodically Protected Steel	Copper	Flapper Valve (Auto Shutoff)
2148			Double-Walled	PVC	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Heating Oil		10/17/2012	Manual Interstitial Monitor	Manual Interstitial Monitor	
10,000					

Facility Summary in LINCOLN County in the City of TROY

Location: TROY ELEMENTARY SCHOOL
318 KALISPELL AVE
TROY, MT 59935 LINCOLN

Contact: Dan Wendt, (406) 295-4606

Sys Fac ID: 27-00764
Last Inspected On: 1/6/2016
Operating Permit Renewal Date: 3/2/2019

Owners/Operators: School Dist 1 Troy, Owner (406)-295-4606 PO BOX 867
TROY MT 59935-0867

John L Daniel, UST Class A Operator
Keith Haggerty, UST Class A Operator
John L Daniel, UST Class B Global Operator
Keith Haggerty, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	8/1/1987	Cathodically Protected Steel	Copper	Flapper Valve (Auto Shutoff)
2149			Excavation Liner	PVC	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Heating Oil		1/6/2016	Manual Interstitial Monitor	Manual Interstitial Monitor	
10,000					

Facility Summary in LINCOLN County in the City of TROY

Location: CENEX/TROY MINI MART
217 E MISSOULA AVE
TROY, MT 59935 LINCOLN

Contact: Joseph Lapham, (208) 263-7606

Sys Fac ID: 27-03253
Last Inspected On: 8/24/2016
Operating Permit Renewal Date: 9/11/2019

Owners/Operators: Joseph Lapham, Owner/Operator (208)-263-7606 1229 W ODEN BAY RD SANDPOINT ID 83864

Valerie Brown, UST Class A Operator
Mike DuPerault, UST Class A Operator
Kayla Eberly, UST Class A Operator
Joseph Lapham, UST Class A Operator
Paula Paasch, UST Class A Operator
Mark Roesler-Begalke, UST Class A Operator
Keith Wagner, UST Class A Operator
Nancy Wagner, UST Class A Operator
Joseph Lapham, UST Class B Operator
Keith Wagner, UST Class B Operator
Nancy Wagner, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	4/12/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3132			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		8/15/2016	TLS-350/Gilbarco EMC , Veeder Root		
8	23	4/12/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3129			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		8/15/2016	TLS-350/Gilbarco EMC , Veeder Root		
9	23	4/12/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3130			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		8/15/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LINCOLN County in the City of TROY

Location: CENEX/TROY MINI MART
217 E MISSOULA AVE
TROY, MT 59935 LINCOLN

Contact: Joseph Lapham, (208) 263-7606

Sys Fac ID: 27-03253
Last Inspected On: 8/24/2016
Operating Permit Renewal Date: 9/11/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	23	4/12/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3131			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		8/15/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in LINCOLN County in the City of TROY

Location: LINCOLN COUNTY SHOP TROY
1210 E MISSOULA AVE
TROY, MT 59935 LINCOLN

Contact: Cyris Dave, (406) 295-4420

Sys Fac ID: 27-06716
Last Inspected On: 5/17/2016
Operating Permit Renewal Date: 7/2/2019

Owners/Operators: Lincoln County Road Dept, Owner (406)-295-4420 512 CALIFORNIA AVE LIBBY MT 59923-1942

Dave Kyriss, UST Class A Operator
Dave Kyriss, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	26	5/1/1990	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1538			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		5/16/2016	Continuous Interstitial Monitor	Deferred	
2,000			Other , Other		
4	26	5/1/1990	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1539			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		5/16/2016	Continuous Interstitial Monitor	Deferred	
2,000			Other , Other		

Facility Summary in LINCOLN County in the City of TROY

Location: TROY CENTRAL OFFICE 9140 B01
KOOTENAI AVE & 2ND ST
TROY, MT 59935 LINCOLN

Contact: Allan Kelly, (406) 293-0010

Sys Fac ID: 27-08082
Last Inspected On: 4/28/2016
Operating Permit Renewal Date: 6/1/2019

Owners/Operators: Citizens Communications Company, Owner (916)-686-3499 ATTN BRIAN MCGUINNESS
9260 E STOCKTON BLVD
ELK GROVE CA 95624-1456

John Jones, UST Class A Operator
Brian McGuinness, UST Class A Operator
Alan Kelly, UST Class B Operator
John Jones, UST Class B Global Operator
Brian McGuinness, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	8/1/1991	Unknown	Steel	
3272	Yes	4/28/2016	None	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
500			TLS-250 , Veeder Root		

Facility Summary in LINCOLN County in the City of TROY

Location: TOWN PUMP INC TROY
112 E MISSOULA AVE
TROY, MT 59935 LINCOLN

Contact: Roger Hovis, (406) 295-4921

Sys Fac ID: 27-08722
Last Inspected On: 12/14/2015
Operating Permit Renewal Date: 4/1/2019

Owners/Operators: Troy Town Pump Inc, Owner (406)-497-6700 600 S MAIN ST BUTTE MT 59701-2534

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	36	4/14/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2524			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/24/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
2	44	4/14/1972	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2523			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		9/24/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
3	44	4/14/1972	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2522			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/24/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MADISON County in the City of ALDER

Location: ALDER MARKET LLC
1ST & MAIN ST
ALDER, MT 59710 MADISON
Contact: Carolyn Gaddy, (406) 842-5679

Sys Fac ID: 28-04167
Last Inspected On: 9/5/2014
Operating Permit Renewal Date: 10/31/2017

Owners/Operators: Alder Market LLC, Owner (406)-842-5679 PO BOX 235
ALDER MT 59710
William Caldwell, UST Class A Operator
William Caldwell, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	28	7/1/1988	Unknown	Flexible Plastic	
386	Yes	12/16/2011	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
2,900			Other , Other		
3	28	7/1/1988	Unknown	Flexible Plastic	
385	Yes	12/16/2011	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
3,000			Other , Other		

Facility Summary in MADISON County in the City of ENNIS

Location: TOWN PUMP INC ENNIS
116 W MAIN ST
ENNIS, MT 59729 MADISON
Contact: Roger Hovis, (406) 682-7439

Sys Fac ID: 28-08698
Last Inspected On: 7/15/2015
Operating Permit Renewal Date: 10/27/2018

Owners/Operators: Town Pump of Ennis Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000
Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	36	4/14/1980	Cathodically Protected Steel	Flexible Plastic	Positive Shutoff
2529			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/18/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	24	4/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
2530			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing, Approved Remote Monitoring	
12,000		7/13/2015	TLS-350/Gilbarco EMC , Veeder Root		
5	24	4/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
2531			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing, Approved Remote Monitoring	
12,000		7/13/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MADISON County in the City of ENNIS

Location: TOWN PUMP INC ENNIS
116 W MAIN ST
ENNIS, MT 59729 MADISON
Contact: Roger Hovis, (406) 682-7439

Sys Fac ID: 28-08698
Last Inspected On: 7/15/2015
Operating Permit Renewal Date: 10/27/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	24	4/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
2532			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
7	14	10/16/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4734			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		5/3/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	14	10/16/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4735			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MADISON County in the City of ENNIS

Location: ROCKY MOUNTAIN SUPPLY INC ENNIS
4997 US HIGHWAY 287 N
ENNIS, MT 59729 MADISON

Contact: George Munson, (406) 682-4315

Sys Fac ID: 56-13826
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 11/29/2017

Owners/Operators: Rocky Mountain Supply Inc, Owner (406)-388-4008 JASON RORABAUGH PETROLEUM MGR
PO BOX 129
BELGRADE MT 59714-3035

Jason Rorabaugh, UST Class A Operator
Greg Stearman, UST Class A Operator
Greg Stearman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	7/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1768			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		4/9/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	
2	19	7/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1769			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000		4/9/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	
3	19	7/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1770			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		4/9/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	
4	19	7/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1771			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000		4/13/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	

Facility Summary in MADISON County in the City of ENNIS

Location: ROCKY MOUNTAIN SUPPLY INC ENNIS
4997 US HIGHWAY 287 N
ENNIS, MT 59729 MADISON

Contact: George Munson, (406) 682-4315

Sys Fac ID: 56-13826
Last Inspected On: 9/22/2014
Operating Permit Renewal Date: 11/29/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	19	7/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1772			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		4/11/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	
6	19	7/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1773			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		4/10/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	

Facility Summary in MADISON County in the City of NORRIS

Location: MCLEOD MERCANTILE SW CORNER
6533 US HIGHWAY 287 S
NORRIS, MT 59745 MADISON

Contact: Tim Hokanson, (406) 685-3372

Sys Fac ID: 56-14138
Last Inspected On: 1/25/2016
Operating Permit Renewal Date: 2/28/2019

Owners/Operators: A M Welles Inc, Owner (406)-685-3372 PO BOX 2808 NORRIS MT 59745-2808

Katie Burtchett, UST Class A Operator
Patricia Lehman, UST Class A Operator
Marvena Rice, UST Class A Operator
Katie Burtchett, UST Class B Operator
Patricia Lehman, UST Class B Operator
Marvena Rice, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	7/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
2716			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		7/17/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000		11/2/2009	TLS-350/Gilbarco EMC , Veeder Root		
2	25	7/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
2717			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		7/17/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000		11/2/2009	TLS-350/Gilbarco EMC , Veeder Root		
10	25	7/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2712			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/27/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
2,000		11/2/2009	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MADISON County in the City of NORRIS

Location: MCLEOD MERCANTILE SW CORNER
6533 US HIGHWAY 287 S
NORRIS, MT 59745 MADISON
Contact: Tim Hokanson, (406) 685-3372

Sys Fac ID: 56-14138
Last Inspected On: 1/25/2016
Operating Permit Renewal Date: 2/28/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	25	7/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2714			None	None	Yes
Currently in Use			Not Required	Pressurized	Galvanic
Gasoline		7/27/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	ELLD Line Tightness Testing, Deferred	
2,000		11/2/2009	TLS-350/Gilbarco EMC , Veeder Root		
12	25	7/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2713			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/27/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
2,000		11/2/2009	TLS-350/Gilbarco EMC , Veeder Root		
13	25	7/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2715			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/27/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		11/2/2009	TLS-350/Gilbarco EMC , Veeder Root		
14	12	7/2/2004	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4892			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/17/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		11/2/2009	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MADISON County in the City of SHERIDAN

Location: MCLEOD MERCANTILE 2802043
202 S MAIN ST
SHERIDAN, MT 59749 MADISON

Contact: Larrie R Elser, (406) 842-5477

Sys Fac ID: 28-02043
Last Inspected On: 10/10/2016
Operating Permit Renewal Date: 11/8/2019

Owners/Operators: A M Welles Inc, Owner (406)-685-3372 PO BOX 2808
NORRIS MT 59745-2808

Sandy Flager, UST Class A Operator
Sandy Flager, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	11/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2951			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
2	21	11/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2952			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
3	21	11/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2953			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
8	21	11/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2950			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MADISON County in the City of SHERIDAN

Location: A M WELLES
95 TUKE LANE
SHERIDAN, MT 59749 MADISON

Contact: Alfred Hokanson, (406) 685-3372

Sys Fac ID: 60-15002
Last Inspected On: 9/6/2016
Operating Permit Renewal Date: 9/9/2019

Owners/Operators: A M Welles Inc, Owner (406)-685-3372 PO BOX 2808 NORRIS MT 59745-2808

Sandy Flager, UST Class A Operator
Tim Nicholls, UST Class A Operator
Sandy Flager, UST Class B Operator
Tim Nicholls, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	11	9/15/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5044			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		12/9/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	11	9/15/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5007			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		12/9/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	11	9/15/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5008			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		12/9/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MADISON County in the City of SHERIDAN

Location: A M WELLES
95 TUKE LANE
SHERIDAN, MT 59749 MADISON

Contact: Alfred Hokanson, (406) 685-3372

Sys Fac ID: 60-15002
Last Inspected On: 9/6/2016
Operating Permit Renewal Date: 9/9/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	11	9/15/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5009			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
7,000		12/9/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	11	9/15/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5010			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		12/9/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	11	9/15/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5011			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		12/9/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MADISON County in the City of TWIN BRIDGES

Location: BOS CHEVRON AND TIRE SERVICE
100 S MAIN ST
TWIN BRIDGES, MT 59754 MADISON
Contact: Bo Mailey, (406) 684-5611

Sys Fac ID: 28-07478
Last Inspected On: 10/4/2016
Operating Permit Renewal Date: 11/8/2019

Owners/Operators: Bo Mailey, Owner (406)-684-5611 PO BOX 434
TWIN BRIDGES MT 59754-0434
Bo Mailey, UST Class A Operator
Bo Mailey, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	17	1/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3913			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Manual Interstitial Monitor	Deferred	
1,000					
6	17	1/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3914			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Manual Interstitial Monitor	Deferred	
1,000					

Facility Summary in MADISON County in the City of TWIN BRIDGES

Location: THREE RIVERS QUICK STOP
325 S MAIN ST
TWIN BRIDGES, MT 59754 MADISON
Contact: Danny Hanson, (406) 684-5733

Sys Fac ID: 28-10708
Last Inspected On: 4/6/2016
Operating Permit Renewal Date: 6/9/2019

Owners/Operators: Danny Hanson, Owner (406)-684-5733 3538 MT HIGHWAY 287 SHERIDAN MT 59749-9564
Danny Hanson, UST Class A Operator
Gena Nordquist, UST Class A Operator
Gena Nordquist, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	24	10/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1816			None	None	Yes
Currently in Use		10/1/2002	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/6/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
3,000			Gilbarco EMC Basic , Gilbarco		
5	24	10/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1817			None	None	Yes
Currently in Use		10/1/2002	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/6/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in MADISON County in the City of VIRGINIA CITY

Location: COURTHOUSE & THOMPSON HICKMAN LIBRARY
110 E WALLACE ST
VIRGINIA CITY, MT 59755 MADISON

Contact: (406) 843-4277

Sys Fac ID: 28-00401
Last Inspected On: 5/5/2016
Operating Permit Renewal Date: 6/21/2019

Owners/Operators: Madison County Sanitarian, Owner (406)-843-5392 PO BOX 278
VIRGINIA CITY MT 59755-0278

Van Puckett, UST Class A Operator
Wano Urbonas, UST Class A Operator
Van Puckett, UST Class B Operator
Van Puckett, UST Class B Global Operator
Wano Urbonas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	18	8/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1570		5/5/2016	None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Manual Interstitial Monitor	
2,000			EECO 1500 , EMCO Electronics		

Facility Summary in MCCONE County in the City of CIRCLE

Location: CARLSEN SINCLAIR & SERVICE LLC
210 A AVE
CIRCLE, MT 59215 MCCONE

Contact: Les Carlsen, (406) 485-3645

Sys Fac ID: 29-00041
Last Inspected On: 10/26/2015
Operating Permit Renewal Date: 3/30/2019

Owners/Operators: Carlsen Sinclair & Service LLC, Owner/Operator (406)-485-3645 PO BOX 375 CIRCLE MT 59215

Cody Carlsen, UST Class A Operator
Les Carlsen, UST Class A Operator
Leonard J Kuntz, UST Class A Operator
Cody Carlsen, UST Class B Global Operator
Cory Hirschfeld, UST Class B Global Operator
Denny Hogan, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	19	10/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
612			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Manual Interstitial Monitor	Deferred	
6,000					
9	19	10/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
613			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Interstitial Monitor	Deferred	
2,000					
10	19	10/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
614			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Interstitial Monitor	Deferred	
2,000					

Facility Summary in MCCONE County in the City of CIRCLE

Location: CARLSEN SINCLAIR & SERVICE LLC
210 A AVE
CIRCLE, MT 59215 MCCONE

Contact: Les Carlsen, (406) 485-3645

Sys Fac ID: 29-00041
Last Inspected On: 10/26/2015
Operating Permit Renewal Date: 3/30/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	19	10/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
615			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Interstitial Monitor	Deferred	
6,000					
12	19	10/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
616			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Manual Interstitial Monitor	Deferred	
4,000					
13	19	10/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
617			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Interstitial Monitor	Deferred	
2,000					

Facility Summary in MCCONE County in the City of CIRCLE

Location: CIRCLE COUNTRY MARKET
105 10TH STREET
CIRCLE, MT 59215 MCCONE
Contact: Les Carlson, (406) 485-3645

Sys Fac ID: 29-00042
Last Inspected On: 10/26/2015
Operating Permit Renewal Date: 3/30/2019

Owners/Operators: Carlsen Sinclair & Service LLC, Owner/Operator (406)-485-3645 PO BOX 375 CIRCLE MT 59215

Cody Carlsen, UST Class A Operator
Les Carlsen, UST Class A Operator
Leonard J Kuntz, UST Class A Operator
Cody Carlsen, UST Class B Global Operator
Les Carlsen, UST Class B Global Operator
Cory Hirschfeld, UST Class B Global Operator
Denny Hogan, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	19	10/1/1997	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
618			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/26/2015	Manual Interstitial Monitor	Deferred	
4,000					
4	19	10/1/1997	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
619			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/26/2015	Manual Interstitial Monitor	Deferred	
4,000					

Facility Summary in MCCONE County in the City of CIRCLE

Location: CIRCLE PUBLIC SCHOOL DIST 1
307 S MERIDIAN AVE
CIRCLE, MT 59215 MCCONE

Contact: Willie Tebow, (406) 485-3600

Sys Fac ID: 29-00874
Last Inspected On: 4/25/2016
Operating Permit Renewal Date: 6/4/2019

Owners/Operators: School Dist 1 Circle, Owner/Operator (406)-485-3600 307 MERIDIAN AVE CIRCLE MT 59215

Gary Fisher, UST Class A Operator
Dwain Jensen, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	19	8/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1890		4/25/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil		4/10/2013	Manual Interstitial Monitor	Continuous Interstitial Monitor	
8,000			ILS-350 , Veeder Root		

Facility Summary in MCCONE County in the City of CIRCLE

Location: CIRCLE EXXON
706 B AVE
CIRCLE, MT 59215 MCCONE

Contact: Brandon Curtis, (406) 939-3474

Sys Fac ID: 29-03433
Last Inspected On: 7/15/2014
Operating Permit Renewal Date: 8/11/2017

Owners/Operators: BMC LLC, Owner (406)-939-3474 BRANDON CURTIS
PO BOX 227
CIRCLE MT 59215

Megan Curtiss, UST Class A Operator
Megan Curtiss, UST Class B Operator
Tonya Kleppelid, UST Class B Operator
Kacie Sikveland, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	18	11/1/1998	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3802			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		7/6/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	18	11/1/1998	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3803			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		7/6/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	18	11/1/1998	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3804			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		7/6/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MCCONE County in the City of CIRCLE

Location: HALES DISTRIBUTING
901 AVE B
CIRCLE, MT 59215 MCCONE

Contact: William Hale, (406) 485-2510

Sys Fac ID: 29-03684
Last Inspected On: 8/19/2014
Operating Permit Renewal Date: 1/8/2018

Owners/Operators: Hales Distributing, Owner (406)-485-2510 PO BOX 142
CIRCLE MT 59215-0142

William Hale, UST Class A Operator
William Hale, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	9/12/1990	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1267			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		8/19/2014	Manual Interstitial Monitor	Deferred	
5,000					

Facility Summary in MCCONE County in the City of CIRCLE

Location: FARMERS UNION OIL CO CIRCLE
906 AVENUE A
CIRCLE, MT 59215 MCCONE

Contact: Shonda Heidi, (406) 485-3476

Sys Fac ID: 29-06376
Last Inspected On: 10/26/2015
Operating Permit Renewal Date: 3/4/2019

Owners/Operators: Farmers Union Oil Co Circle, Owner (406)-485-3475 PO BOX 460 CIRCLE MT 59215-0460

Jeffrey P Schaefer, UST Class A Operator
Larry Kwasney, UST Class B Operator
Jeffrey P Schaefer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	18	11/1/1998	Unknown	Fiberglass Reinforced Plastic	
951	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		8/17/2015	ILS-350 , Veeder Root	Continuous Interstitial Monitor	
9	18	11/1/1998	Unknown	Fiberglass Reinforced Plastic	
952	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		8/15/2015	ILS-350 , Veeder Root	Continuous Interstitial Monitor	
10	18	11/1/1998	Unknown	Fiberglass Reinforced Plastic	
953	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		8/19/2015	ILS-350 , Veeder Root	Continuous Interstitial Monitor	
11	18	11/1/1998	Unknown	Fiberglass Reinforced Plastic	
954	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		8/15/2015	ILS-350 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MCCONE County in the City of CIRCLE

Location: FARMERS UNION OIL CO CIRCLE
906 AVENUE A
CIRCLE, MT 59215 MCCONE

Contact: Shonda Heidi, (406) 485-3476

Sys Fac ID: 29-06376
Last Inspected On: 10/26/2015
Operating Permit Renewal Date: 3/4/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
12	10	10/6/2006	Unknown	Flexible Plastic	
5108	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000		8/15/2015	ILS-350 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MCCONE County in the City of CIRCLE

Location: FARMERS UNION OIL C-STORE
200 B AVENUE
CIRCLE, MT 59215 MCCONE
Contact: Sadie Idland, (406) 485-3333

Sys Fac ID: 60-15206
Last Inspected On: 10/26/2015
Operating Permit Renewal Date: 4/9/2019

Owners/Operators: Farmers Union Oil C-Store, Owner (406)-485-3333 200 B AVENUE CIRCLE MT 59215
Jeffrey P Schaefer, UST Class A Operator
Sadie Idland, UST Class B Operator
Dorothy Johnson, UST Class B Operator
Jeffrey P Schaefer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	04	6/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5356		8/12/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		10/9/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
3	04	6/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5357		8/12/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
14,000		10/9/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
4	04	6/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5358		8/12/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
14,000		10/13/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in MCCONE County in the City of CIRCLE

Location: FARMERS UNION OIL C-STORE
200 B AVENUE
CIRCLE, MT 59215 MCCONE

Contact: Sadie Idland, (406) 485-3333

Sys Fac ID: 60-15206
Last Inspected On: 10/26/2015
Operating Permit Renewal Date: 4/9/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	04	6/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5359		8/12/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		10/15/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
6	04	6/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5360		8/12/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		10/7/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in MCCONE County in the City of FORT PECK

Location: ROCK CREEK MARINA
652 S ROCK CREEK RD
FORT PECK, MT 59223 MCCONE

Contact: William Hinrichs, (406) 485-2560

Sys Fac ID: 29-11049
Last Inspected On: 7/7/2015
Operating Permit Renewal Date: 11/11/2018

Owners/Operators: Rock Creek Marina Inc, Owner (406)-485-2560 652 S ROCK CREEK RD
FORT PECK MT 59223-7001

William Hinrichs, UST Class A Operator
William Hinrichs, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	5/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1846			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		7/7/2015	Automatic Tank Gauging 0.2	Approved Remote Monitoring	
4,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in MCCONE County in the City of VIDA

Location: AGLAND COOP
MT HIGHWAY 13
VIDA, MT 59274 MCCONE

Contact: Dennis Vinger, (406) 525-3207

Sys Fac ID: 56-14042
Last Inspected On: 5/14/2015
Operating Permit Renewal Date: 8/7/2018

Owners/Operators: Farmers Union Oil Co Wolf Point, Owner (406)-653-1510 DBA AGLAND COOP
60 US HIGHWAY 2 E
WOLF POINT MT 59201-1942

Waldo Wall, UST Class A Operator
Michael Pallvoda, UST Class B Operator
Allen Richard, UST Class B Operator
Waldo Wall, UST Class B Operator
Allen Richard, UST Class B Global Operator
Weston Smith, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	14	12/1/2001	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4560			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		7/31/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	14	12/1/2001	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4561			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		7/31/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
3	14	12/1/2001	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4562			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		7/31/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MEAGHER County in the City of WHITE SULPHUR SPRINGS

Location: VAN OIL CO 12 W MAIN ST
12 W MAIN ST
WHITE SULPHUR SPRINGS, MT 59645 MEAGHER

Sys Fac ID: 30-00478
Last Inspected On: 1/26/2016
Operating Permit Renewal Date: 2/17/2019

Contact: Gary Walter, (406) 547-9998

Owners/Operators: Van Oil Co, Owner (406)-547-3636 PO BOX E
WHITE SULPHUR SPRINGS MT 59645-0805

Gary Walter, UST Class A Operator
Gary Walter, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	25	6/6/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2211			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		8/17/2015	TLS-250 , Veeder Root		
7	25	6/6/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2212			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		8/17/2015	TLS-250 , Veeder Root		
8	25	6/6/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2213			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		8/17/2015	TLS-250 , Veeder Root		

Facility Summary in MEAGHER County in the City of WHITE SULPHUR SPRINGS

Location: WHITE SULPHUR SPRINGS SCHOOL DIST 8
209 CENTRAL AVE S
WHITE SULPHUR SPRINGS, MT 59645 MEAGHER

Contact: Lonnie Briggs, (406) 547-3351

Sys Fac ID: 30-04720
Last Inspected On: 7/23/2014
Operating Permit Renewal Date: 12/16/2017

Owners/Operators: School Dist 8 White Sulphur Springs, Owner (406)-547-3351 PO BOX C
WHITE SULPHUR SPRINGS MT 59645-0803

Hal Haugan, UST Class A Operator
Hal Haugan, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	18	8/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
2261		10/10/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Heating Oil			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000		7/23/2014	TLS-300 , Veeder Root		
7	18	8/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
2262			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Heating Oil			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000		7/24/2014	TLS-300 , Veeder Root		

Facility Summary in MEAGHER County in the City of WHITE SULPHUR SPRINGS

Location: BERG GARAGE INC
11 W MAIN ST
WHITE SULPHUR SPRINGS, MT 59645 MEAGHER
Contact: Jay Berg, (406) 547-3514

Sys Fac ID: 30-07694
Last Inspected On: 10/28/2016
Operating Permit Renewal Date: 12/19/2019

Owners/Operators: Berg Garage Inc, Owner (406)-547-3514 PO BOX 470
WHITE SULPHUR SPRINGS MT 59645-0470
Jay Berg, UST Class A Operator
Jay Berg, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	26	1/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
434			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/26/2016	Manual Tank Gauging	Deferred	
500					
4	26	1/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
435			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/26/2016	Manual Tank Gauging	Deferred	
500					
5	26	1/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
436			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/26/2016	Manual Tank Gauging	Deferred	
500					
6	26	1/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
437			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/26/2016	Manual Tank Gauging	Deferred	
500					

Facility Summary in MEAGHER County in the City of WHITE SULPHUR SPRINGS

Location: TOWN PUMP INC WHITE SULPHUR SPRINGS MAIN RD
215 MAIN ST
WHITE SULPHUR SPRINGS, MT 59645 MEAGHER

Contact: Roger Hovis, (406) 547-3310

Sys Fac ID: 30-08724
Last Inspected On: 6/10/2016
Operating Permit Renewal Date: 8/13/2019

Owners/Operators: Town Pump of White Sulphur Springs Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Robert Keele, UST Class B Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	44	5/10/1972	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2533			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/19/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
3	44	5/10/1972	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2534			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/19/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
4	36	5/10/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2535			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/19/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MEAGHER County in the City of WHITE SULPHUR SPRINGS

Location: TOWN PUMP INC WHITE SULPHUR SPRINGS MAIN RD
215 MAIN ST
WHITE SULPHUR SPRINGS, MT 59645 MEAGHER

Contact: Roger Hovis, (406) 547-3310

Sys Fac ID: 30-08724
Last Inspected On: 6/10/2016
Operating Permit Renewal Date: 8/13/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	27	5/10/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2536			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/19/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
6	24	10/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2537			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/5/2010	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
7	17	9/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4119			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/5/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	17	9/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4120			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/5/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MINERAL County in the City of ALBERTON

Location: MOUNTAIN WEST CO OP ALBERTON
415 RAILROAD AVE
ALBERTON, MT 59820 MINERAL
Contact: (406) 543-8383

Sys Fac ID: 56-13785
Last Inspected On: 2/1/2016
Operating Permit Renewal Date: 4/30/2019

Owners/Operators: Mountain West Coop - Missoula, Owner (406)-543-8383 4570 N RESERVE ST MISSOULA MT 59808-1411

Will Dukart, UST Class A Operator
Dave Otto, UST Class A Operator
John Thompson, UST Class A Operator
Mike Dunlon, UST Class B Operator
John Thompson, UST Class B Operator
Will Dukart, UST Class B Global Operator
Dave Otto, UST Class B Global Operator
John Thompson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	8/1/1997	Bare Steel	Fiberglass Reinforced Plastic	
3858	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
12,000		1/20/2016			
2	19	8/1/1997	Bare Steel	Fiberglass Reinforced Plastic	
3859	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
12,000		1/20/2016			
3	19	8/1/1997	Bare Steel	Fiberglass Reinforced Plastic	
3860	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
10,000		1/20/2016			

Facility Summary in MINERAL County in the City of ALBERTON

Location: MOUNTAIN WEST CO OP ALBERTON
415 RAILROAD AVE
ALBERTON, MT 59820 MINERAL
Contact: (406) 543-8383

Sys Fac ID: 56-13785
Last Inspected On: 2/1/2016
Operating Permit Renewal Date: 4/30/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	19	8/1/1997	Bare Steel	Fiberglass Reinforced Plastic	
3861	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
4,000		1/20/2016			

Facility Summary in MINERAL County in the City of HAUGAN

Location: SILVER EXPRESS EXXON
EXIT 16 & INTERSTATE 90
HAUGAN, MT 59842 MINERAL

Contact: Brenda Lincoln, (406) 678-4242

Sys Fac ID: 31-13289
Last Inspected On: 7/25/2016
Operating Permit Renewal Date: 8/28/2019

Owners/Operators: Silver Dollar Ventures Inc, Owner (406)-678-4242 PO BOX 420038 HAUGAN MT 59842-0038

Brooke Lincoln, UST Class A Operator
Brooke Lincoln, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	4/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3161			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		7/20/2016	TLS-350/Gilbarco EMC , Veeder Root		
2	22	4/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3162			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		7/20/2016	TLS-350/Gilbarco EMC , Veeder Root		
3	22	4/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3163			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		7/20/2016	TLS-350/Gilbarco EMC , Veeder Root		
4	22	4/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3164			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/20/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MINERAL County in the City of SAINT REGIS

Location: SAINT REGIS EXXON
MULLAN ROAD & MT HIGHWAY 135 N
SAINT REGIS, MT 59866 MINERAL
Contact: Gary Bullock, (406) 649-2407

Sys Fac ID: 31-05827
Last Inspected On: 3/26/2014
Operating Permit Renewal Date: 6/3/2017

Owners/Operators: Lincoln Development Co Inc, Owner (406)-649-2407 DBA ST REGIS EXXON EXPRESS
PO BOX 190
SAINT REGIS MT 59866-0190

Gary Bullock, UST Class A Operator
Gary Bullock, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	43	1/1/1973	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3630			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		5/27/2011	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
8,000					
2	34	4/22/1982	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3631			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/27/2011	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000					
3	34	4/22/1982	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3632			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/27/2011	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000					
4	43	4/23/1973	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3633			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/27/2011	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
6,000					

Facility Summary in MINERAL County in the City of SAINT REGIS

Location: STANGS FOOD CITY
85 OLD US HIGHWAY 10 E
SAINT REGIS, MT 59866 MINERAL
Contact: Kirk Hoskins, (406) 531-5160

Sys Fac ID: 31-07503
Last Inspected On: 4/6/2016
Operating Permit Renewal Date: 9/7/2019

Owners/Operators: Ponderosa Investments, Owner (406)-649-2414 PO BOX 433
SAINT REGIS MT 59866

Kirk Hoskins, UST Class A Operator
Kirk Hoskins, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	17	8/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4105			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
6	17	8/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4106			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
7	17	8/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4107			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in MINERAL County in the City of SAINT REGIS

Location: SAINT REGIS TRAVEL CENTER
100 MULLAN ROAD W
SAINT REGIS, MT 59866 MINERAL
Contact: Gary Bullock, (406) 649-2407

Sys Fac ID: 31-07690
Last Inspected On: 3/26/2014
Operating Permit Renewal Date: 3/28/2017

Owners/Operators: Lindevco Inc, Owner (406)-649-2407 PO BOX 190
SAINT REGIS MT 59866-0190
Gary Bullock, UST Class A Operator
Gary Bullock, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	31	4/22/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3813		4/15/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/27/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		4/18/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	31	4/22/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3814		4/15/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		5/27/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		4/18/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	31	4/22/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3815		4/15/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/27/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		4/18/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MINERAL County in the City of SALTESE

Location: TAFT SUBSTATION
RANDOLPH CREEK RD
SALTESE, MT 59867 MINERAL

Contact: Ken Owen, (406) 257-4385

Sys Fac ID: 31-07747
Last Inspected On: 6/28/2016
Operating Permit Renewal Date: 8/18/2019

Owners/Operators: Bonneville Power Administration Kalispell, Owner (406)-751-7800 2520 US HIGHWAY 2 E KALISPELL MT 59901-2312

Emery Barnhill, UST Class A Operator
Emery Barnhill, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	26	10/1/1990	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
478		6/28/2016	Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Continuous Interstitial Monitoring	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MINERAL County in the City of SUPERIOR

Location: MINERAL COUNTY COURTHOUSE UST
300 RIVER ST
SUPERIOR, MT 59872 MINERAL
Contact: Sam Viche, (406) 822-3525

Sys Fac ID: 31-02302
Last Inspected On: 2/4/2015
Operating Permit Renewal Date: 7/25/2018

Owners/Operators: Mineral County Health Dept, Owner (406)-822-4632 PO BOX 396
SUPERIOR MT 59872-0396

Roy Kay, UST Class A Operator
Roy Kay, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	22	5/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4450		2/4/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil		2/9/2015	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
5,000			ILS-350 , Veeder Root		

Facility Summary in MINERAL County in the City of SUPERIOR

Location: DURANGOS INC
204 4TH AVE E
SUPERIOR, MT 59872 MINERAL
Contact: Joseph Hendrick, (406) 822-4967

Sys Fac ID: 31-07433
Last Inspected On: 2/10/2015
Operating Permit Renewal Date: 4/26/2018

Owners/Operators: Jo-Joe Investments, Owner (406)-822-4967 PO BOX 413
SAINT REGIS MT 59866-0413

Jolie Skelton, UST Class A Operator
Jolie Skelton, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	4/23/1984	Cathodically Protected Steel	Steel	Positive Shutoff
3816			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/9/2015	Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
10,000		2/9/2015		Stat. Inventory Reconcilitation	
2	32	4/23/1984	Cathodically Protected Steel	Steel	Positive Shutoff
3817			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/9/2015	Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
10,000		2/9/2015		Stat. Inventory Reconcilitation	

Facility Summary in MINERAL County in the City of SUPERIOR

Location: TOWN PUMP INC SUPERIOR
3961 DIAMOND MATCH RD
SUPERIOR, MT 59872 MINERAL
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 31-08719
Last Inspected On: 4/28/2016
Operating Permit Renewal Date: 5/14/2019

Owners/Operators: Town Pump of Superior Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	46	1/22/1970	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2538			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/29/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	46	1/22/1970	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2539			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/29/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
3	30	1/1/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2540			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/29/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MINERAL County in the City of SUPERIOR

Location: TOWN PUMP INC SUPERIOR
3961 DIAMOND MATCH RD
SUPERIOR, MT 59872 MINERAL

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 31-08719
Last Inspected On: 4/28/2016
Operating Permit Renewal Date: 5/14/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	44	1/1/1972	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2541			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/29/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	35	1/1/1981	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4840			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/29/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	27	1/1/1989	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2543			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/20/2010	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	27	1/1/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4841			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/20/2010	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MINERAL County in the City of SUPERIOR

Location: TOWN PUMP INC SUPERIOR
3961 DIAMOND MATCH RD
SUPERIOR, MT 59872 MINERAL

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 31-08719
Last Inspected On: 4/28/2016
Operating Permit Renewal Date: 5/14/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	13	6/9/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4842			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/20/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	13	6/9/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4843			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		2/20/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
3,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MINERAL County in the City of SUPERIOR

Location: MOUNTAIN WEST CO OP SUPERIOR
211 RIVER ST
SUPERIOR, MT 59872 MINERAL

Contact: Thompson Chuck, (406) 543-8383

Sys Fac ID: 31-08916
Last Inspected On: 2/2/2016
Operating Permit Renewal Date: 4/30/2019

Owners/Operators: Mountain West Coop - Missoula, Owner (406)-543-8383 4570 N RESERVE ST MISSOULA MT 59808-1411

Will Dukart, UST Class A Operator
Dusty Smith, UST Class A Operator
John Thompson, UST Class A Operator
John Thompson, UST Class B Operator
Will Dukart, UST Class B Global Operator
Dusty Smith, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	30	5/1/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
1063			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		2/1/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		1/14/2016	Gilbarco EMC Basic , Gilbarco		
4	30	5/1/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
1064			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/1/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		1/14/2016	Gilbarco EMC Basic , Gilbarco		
5	30	5/1/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
1065			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		2/1/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		1/14/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in MINERAL County in the City of SUPERIOR

Location: S & S FOODS
205 4TH AVE E
SUPERIOR, MT 59872 MINERAL
Contact: Dale Bullock, (406) 822-4837

Sys Fac ID: 31-12870
Last Inspected On: 7/20/2016
Operating Permit Renewal Date: 9/25/2019

Owners/Operators:

D and T Properties LLC, Owner	(406)-822-3342	PO BOX 158 SUPERIOR MT 59872
Dale Bullock, Operator	(406)-822-3342	PO BOX 158 SUPERIOR MT 59872

Dale Bullock, UST Class A Operator
Gary Bullock, UST Class A Operator
Dale Bullock, UST Class B Operator
Gary Bullock, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	10/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1971			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
3,000		7/20/2016	TLS-300 , Veeder Root		
2	24	10/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1970			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		7/20/2016	TLS-300 , Veeder Root		
3	24	10/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1968			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		7/20/2016	TLS-300 , Veeder Root		
4	24	10/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1969			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		7/20/2016	TLS-300 , Veeder Root		

Facility Summary in MISSOULA County in the City of BONNER

Location: CULLY'S
29344 MT HIGHWAY 200 E
BONNER, MT 59823 MISSOULA

Contact: Joe Johnson, (406) 261-3569

Sys Fac ID: 32-12400
Last Inspected On: 12/10/2013
Operating Permit Renewal Date: 4/19/2017

Owners/Operators:

JMBC, Owner		319 MONTCLAIRE DR KALISPELL MT 59901
Joe Johnson, Operator	(406)-261-3569	29344 HWY 200 BONNER MT 59823

JIM FRY, UST Class A Operator
Joe Johnson, UST Class A Operator
Doug Zimmerman, UST Class A Operator
JIM FRY, UST Class B Operator
Joe Johnson, UST Class B Operator
Doug Zimmerman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	5/28/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3488			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/9/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		10/20/2010			
2	25	5/28/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3489			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/9/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000		10/20/2010			
3	25	5/28/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3490			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/9/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000		10/20/2010			

Facility Summary in MISSOULA County in the City of BONNER

Location: CULLY'S
29344 MT HIGHWAY 200 E
BONNER, MT 59823 MISSOULA

Contact: Joe Johnson, (406) 261-3569

Sys Fac ID: 32-12400
Last Inspected On: 12/10/2013
Operating Permit Renewal Date: 4/19/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	25	5/28/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3491			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		12/9/2013	Automatic Tank Gauging 0.2	Deferred	
3,000		10/20/2010			

Facility Summary in MISSOULA County in the City of CLINTON

Location: BEARMOUTH EXPRESS
16595 US HIGHWAY 10 E
CLINTON, MT 59825 MISSOULA
Contact: Gene Tripp, (406) 825-4000

Sys Fac ID: 32-01572
Last Inspected On: 2/25/2014
Operating Permit Renewal Date: 5/16/2017

Owners/Operators: Gene Tripp Jr, Owner (406)-825-4000 PO BOX 7103
MISSOULA MT 59807-7103

Bryan Tripp, UST Class A Operator
Jeff Tripp, UST Class A Operator
Bryan Tripp, UST Class B Operator
Jeff Tripp, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	37	4/29/1979	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1205			Lined Interior/Impressed Current	None	Yes
Currently in Use		7/1/2008	Not Required	Safe Suction	Impressed Current
Diesel		2/25/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
12,000					

Facility Summary in MISSOULA County in the City of CLINTON

Location: TURAH STORE & CAMPGROUND
13555 TURAH RD
CLINTON, MT 59825 MISSOULA

Contact: Kathleen Marshall, (406) 258-9773

Sys Fac ID: 32-04899
Last Inspected On: 8/31/2016
Operating Permit Renewal Date: 11/1/2019

Owners/Operators: Turah Store & Campground LLC, Owner (406)-258-9773 13555 TURAH RD CLINTON MT 59825-9775

Kathleen M Marshall, UST Class A Operator
Pamela Asbridge, UST Class B Operator
Jerry Kinney, UST Class B Operator
Kathleen M Marshall, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	44	4/18/1972	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
4007			Lined Interior/Impressed Current	None	Yes
Currently in Use		5/17/2009	Not Required	Safe Suction	Impressed Current
Gasoline		9/1/2016	Stat. Inventory Reconcilitation	Deferred	
3,000		10/10/2007			
2	44	4/18/1972	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
4008			Lined Interior/Impressed Current	None	Yes
Currently in Use		5/17/2009	Not Required	Safe Suction	Impressed Current
Gasoline		9/1/2016	Stat. Inventory Reconcilitation	Deferred	
1,000		10/10/2007			

Facility Summary in MISSOULA County in the City of CLINTON

Location: ROCK CREEK LODGE
7 ROCK CREEK RD
CLINTON, MT 59825 MISSOULA

Contact: Frank Mcgraw, (406) 825-4868

Sys Fac ID: 32-11093
Last Inspected On: 9/10/2014
Operating Permit Renewal Date: 1/8/2018

Owners/Operators: Rock Creek Entertainment Inc, Owner (406)-825-4868 7 ROCK CREEK RD CLINTON MT 59825-9629

Frank McGraw, UST Class A Operator
Nel-Lani Powers, UST Class A Operator
Frank McGraw, UST Class B Operator
Nel-Lani Powers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	22	5/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4572			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000			TLS-300 , Veeder Root		
4	22	5/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4573			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		11/29/2011	TLS-300 , Veeder Root		

Facility Summary in MISSOULA County in the City of CLINTON

Location: CLINTON MARKET US 10 E
20500 WALLACE CREEK RD
CLINTON, MT 59825 MISSOULA

Contact: Kelly Larson, (406) 825-9920

Sys Fac ID: 56-14040
Last Inspected On: 2/8/2016
Operating Permit Renewal Date: 4/9/2019

Owners/Operators: Clinton Market, Owner (406)-825-9920 PO BOX 256 CLINTON MT 59825-0256

Kelly Larson, UST Class A Operator
Kelly Larson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	14	5/16/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4651			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	14	5/16/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4652			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	14	5/16/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4653			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
4	07	10/29/2009	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5223			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes

Facility Summary in MISSOULA County in the City of CONDON

Location: MISSION MOUNTAINS MERCANTILE
MT HIGHWAY 83
CONDON, MT 59826 MISSOULA

Contact: Len Kobylenski, (406) 754-2387

Sys Fac ID: 32-01619
Last Inspected On: 8/27/2014
Operating Permit Renewal Date: 9/10/2017

Owners/Operators: Leonard (Len) Kobylenski, Owner (406)-754-2233 PO BOX 1100 CONDON MT 59826-1100
Leonard (Len) Kobylenski, UST Class A Operator
Leonard (Len) Kobylenski, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	24	5/20/1992	Cathodically Protected Steel	Steel	High Level Alarm
1495			None	none	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		8/25/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		8/5/2015	TLS-350/Gilbarco EMC , Veeder Root		
5	24	5/20/1992	Cathodically Protected Steel	Steel	High Level Alarm
1496			None	none	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		8/25/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		8/5/2015	TLS-350/Gilbarco EMC , Veeder Root		
6	24	5/20/1992	Cathodically Protected Steel	Steel	High Level Alarm
1497			None	none	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		8/25/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		8/5/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of FRENCHTOWN

Location: BRONCS GROCERIES INC
16600 BECKWITH ST
FRENCHTOWN, MT 59834 MISSOULA
Contact: (406) 626-4402

Sys Fac ID: 32-05767
Last Inspected On: 9/26/2014
Operating Permit Renewal Date: 3/3/2018

Owners/Operators: G & S Distributing Inc, Owner (406)-626-4402 18750 HOULE CREEK RD FRENCHTOWN MT 59834-9726
Glenn Green, UST Class A Operator
Glenn Green, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2702			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		12/18/2014	TLS-350/Gilbarco EMC , Veeder Root		
5	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2703			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		12/18/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of FRENCHTOWN

Location: FRENCHIES
16875 BECKWITH ST
FRENCHTOWN, MT 59834 MISSOULA
Contact: Frank Tabish, (406) 626-5279

Sys Fac ID: 32-11177
Last Inspected On: 5/23/2016
Operating Permit Renewal Date: 11/1/2019

Owners/Operators: Tabish Brothers Distributors Inc, Owner (406)-543-7621 GW PETROLEUM
PO BOX 8448
MISSOULA MT 59807-8448

Amber Goodsell, UST Class A Operator
Joe Heuchert, UST Class A Operator
Karly Shafer, UST Class A Operator
Amber Goodsell, UST Class B Operator
Linda Zuraff, UST Class B Operator
Karly Shafer, UST Class B Global Operator
Heather M Stiles, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	26	6/25/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4372			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		5/17/2016	TLS-300 , Veeder Root		
6	26	6/25/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4373			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		5/17/2016	TLS-300 , Veeder Root		
7	26	6/25/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4374			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		5/17/2016	TLS-300 , Veeder Root		

Facility Summary in MISSOULA County in the City of FRENCHTOWN

Location: FRENCHIES
16875 BECKWITH ST
FRENCHTOWN, MT 59834 MISSOULA
Contact: Frank Tabish, (406) 626-5279

Sys Fac ID: 32-11177
Last Inspected On: 5/23/2016
Operating Permit Renewal Date: 11/1/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	26	6/25/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4375			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		5/17/2016	TLS-300 , Veeder Root		

Facility Summary in MISSOULA County in the City of GREENOUGH

Location: STONEYS KWIK STOP LLC
44676 MT HIGHWAY 200 E
GREENOUGH, MT 59823 MISSOULA

Contact: Gloria Cline, (406) 244-5598

Sys Fac ID: 32-07114
Last Inspected On: 10/7/2016
Operating Permit Renewal Date: 12/5/2019

Owners/Operators:

Stoneys Kwik Stop LLC, Owner	(406)-244-5598	44676 HIGHWAY 200 E GREENOUGH MT 59823
Gloria Cline, Operator	(406)-244-5598	44676 HIGHWAY 200 E GREENOUGH MT 59823
Gloria Cline, UST Class A Operator		
Gloria Cline, UST Class B Operator		
Gloria Cline, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	17	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4474			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		1/14/2016	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
5	17	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4475			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		1/14/2016	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
6	17	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4476			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000		1/14/2016	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of LOLO

Location: TOWN PUMP INC LOLO 2
11882 US HIGHWAY 93 S
LOLO, MT 59847 MISSOULA
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 32-01639
Last Inspected On: 4/27/2016
Operating Permit Renewal Date: 5/14/2019

Owners/Operators: Lolo Town Pump Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000
Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
13	19	9/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2545			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/5/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
14	19	9/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2546			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/5/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
15	19	9/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4289			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/5/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of LOLO

Location: TOWN PUMP INC LOLO 2
11882 US HIGHWAY 93 S
LOLO, MT 59847 MISSOULA
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 32-01639
Last Inspected On: 4/27/2016
Operating Permit Renewal Date: 5/14/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
16	19	9/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4290			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/5/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
17	19	9/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2549			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/5/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
18	19	9/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2550			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/5/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
20	12	9/15/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4942			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring, Deferred	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
21	12	9/15/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4943			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring, Deferred	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of LOLO

Location: TOWN PUMP INC LOLO 1
10955 US HIGHWAY 93 S
LOLO, MT 59847 MISSOULA
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 32-09414
Last Inspected On: 1/18/2016
Operating Permit Renewal Date: 5/14/2019

Owners/Operators: Town Pump O Mat of Cut Bank Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Shawn Gelling, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Shawn Gelling, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	7/1/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2555			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/30/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
12,000			TLS-350/Gilbarco EMC , Veeder Root		
2	29	7/1/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2556			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/30/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
3	29	7/1/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2557			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/30/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of LOLO

Location: TOWN PUMP INC LOLO 1
10955 US HIGHWAY 93 S
LOLO, MT 59847 MISSOULA

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 32-09414
Last Inspected On: 1/18/2016
Operating Permit Renewal Date: 5/14/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	29	7/1/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2558			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/30/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of LOLO

Location: TRAVELS REST COUNTRY STORE
10565 LOLO CREEK RD
LOLO, MT 59847 MISSOULA
Contact: (406) 273-7800

Sys Fac ID: 32-11303
Last Inspected On: 7/21/2015
Operating Permit Renewal Date: 12/12/2018

Owners/Operators: Travels Rest Country Store, Owner (406)-273-2037 PO BOX 730 LOLO MT 59847-0730

Glen Doty, UST Class A Operator
Steve Mortenson, UST Class A Operator
Terri Sullivan, UST Class A Operator
Glen Doty, UST Class B Operator
Steve Mortenson, UST Class B Operator
Terri Sullivan, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	13	8/13/2003	Concrete	Flexible Plastic	High Level Alarm
4854	Yes		None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Deferred	MLLD Line Tightness Testing	
12,000		11/23/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	13	8/13/2003	Concrete	Flexible Plastic	High Level Alarm
4855	Yes		None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Deferred	MLLD Line Tightness Testing	
12,000		11/23/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	13	6/23/2003	Concrete	Flexible Plastic	High Level Alarm
4856	Yes		None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Deferred	MLLD Line Tightness Testing	
4,000		11/23/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	13	6/23/2003	Concrete	Flexible Plastic	High Level Alarm
4857	Yes		None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Deferred	MLLD Line Tightness Testing	
4,000		11/23/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of LOLO

Location: TRAVELS REST COUNTRY STORE
10565 LOLO CREEK RD
LOLO, MT 59847 MISSOULA
Contact: (406) 273-7800

Sys Fac ID: 32-11303
Last Inspected On: 7/21/2015
Operating Permit Renewal Date: 12/12/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	13	6/23/2003	Concrete	Flexible Plastic	High Level Alarm
4858	Yes		None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Deferred	MLLD Line Tightness Testing	
4,000		11/23/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of LOLO

Location: LOLO SUPERSTOP
12011 US HIGHWAY 93 S
LOLO, MT 59847 MISSOULA

Contact: Frank Tabish, (406) 728-8026

Sys Fac ID: 56-13795
Last Inspected On: 7/15/2016
Operating Permit Renewal Date: 10/3/2019

Owners/Operators: Tabish Brothers Distributors Inc, Owner (406)-543-7621 GW PETROLEUM
PO BOX 8448
MISSOULA MT 59807-8448

Caleb Campbell, UST Class A Operator
Michelle Cleek, UST Class A Operator
Nicholas Dyer, UST Class A Operator
William Komotios, UST Class A Operator
Karly Shafer, UST Class A Operator
Michelle Cleek, UST Class B Operator
Nicholas Dyer, UST Class B Operator
James Fortier, UST Class B Operator
William Komotios, UST Class B Operator
Memory Smith, UST Class B Operator
Tracy Snyder, UST Class B Operator
Caleb Campbell, UST Class B Global Operator
Karly Shafer, UST Class B Global Operator
Heather M Stiles, UST Class B Global Operator
Vaughn Wells, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	18	1/15/1998	Steel Clad	Flexible Plastic	Ball Float Valve
2086			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of LOLO

Location: LOLO SUPERSTOP
12011 US HIGHWAY 93 S
LOLO, MT 59847 MISSOULA
Contact: Frank Tabish, (406) 728-8026

Sys Fac ID: 56-13795
Last Inspected On: 7/15/2016
Operating Permit Renewal Date: 10/3/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	18	1/15/1998	Steel Clad	Flexible Plastic	Ball Float Valve
2087			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	18	1/15/1998	Steel Clad	Flexible Plastic	Ball Float Valve
2088			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	18	1/15/1998	Steel Clad	Flexible Plastic	Ball Float Valve
2089			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	18	1/15/1998	Steel Clad	Flexible Plastic	Ball Float Valve
2090			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MILLTOWN

Location: TOWN PUMP INC BONNER-MILLTOWN
7985 MT HIGHWAY 200 E
MILLTOWN, MT 59851 MISSOULA

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 32-13629
Last Inspected On: 4/28/2016
Operating Permit Renewal Date: 5/14/2019

Owners/Operators: Bonner Town Pump & Casino Inc, Owner (406)-497-6700 600 S MAIN ST BUTTE MT 59701-2534

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	9/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4889		3/4/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
2	21	9/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Not Applicable
2574		3/4/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
3	21	9/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2564		3/4/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MILLTOWN

Location: TOWN PUMP INC BONNER-MILLTOWN
7985 MT HIGHWAY 200 E
MILLTOWN, MT 59851 MISSOULA

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 32-13629
Last Inspected On: 4/28/2016
Operating Permit Renewal Date: 5/14/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	21	9/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4260		3/4/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
5	21	9/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4261		3/4/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
6	21	9/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4262		3/4/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
7	21	9/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2568		3/4/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
8	21	9/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4263		3/4/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MILLTOWN

Location: TOWN PUMP INC BONNER-MILLTOWN
7985 MT HIGHWAY 200 E
MILLTOWN, MT 59851 MISSOULA

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 32-13629
Last Inspected On: 4/28/2016
Operating Permit Renewal Date: 5/14/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	21	9/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2570		3/4/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
10	21	9/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2571		3/4/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
11	21	9/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2572		3/4/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
12	12	12/3/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4871		3/4/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
13	12	12/3/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4872		3/4/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: WIMETT TRUCKING
6600 WIMMETT LN
MISSOULA, MT 59808 MISSOULA

Contact: Robert J Wimett, (406) 549-6401

Sys Fac ID: 32-00053
Last Inspected On: 1/19/2015
Operating Permit Renewal Date: 3/24/2018

Owners/Operators: Wimett Trucking, Owner (406)-549-6401 PO BOX 5660
MISSOULA MT 59806-5660

Norm Meitner, UST Class A Operator
Norm Meitner, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	2/3/1985	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
2287			Impressed Current	None	Yes
Currently in Use		5/1/2004	Not Required	Safe Suction	Impressed Current
Diesel		3/1/2015	Tank Tightness Testing, Inventory Reconciliation, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
12,000		3/6/2003			

Facility Summary in MISSOULA County in the City of MISSOULA

Location: HELLGATE CONOCO SERVICE CENTER
711 E BROADWAY ST
MISSOULA, MT 59802 MISSOULA
Contact: Ross Grenfell, (406) 549-7504

Sys Fac ID: 32-00144
Last Inspected On: 1/31/2014
Operating Permit Renewal Date: 6/14/2017

Owners/Operators: Hellgate Conoco Service Center, Owner (406)-728-9966 711 E BROADWAY ST MISSOULA MT 59802-4609
Ross Grenfell, UST Class A Operator
Ross Grenfell, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	50	3/31/1966	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3765		10/6/2012	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use		1/1/2009	Continuous Interstitial Monitoring	Pressurized	Impressed Current
Gasoline		3/15/2011	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
2	50	3/31/1966	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3766		10/6/2012	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use		1/1/2009	Continuous Interstitial Monitoring	Pressurized	Impressed Current
Gasoline		3/15/2011	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
3	50	3/31/1966	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3767		10/6/2012	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use		1/1/2009	Continuous Interstitial Monitoring	Pressurized	Impressed Current
Diesel		3/15/2011	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
8	05	12/16/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5279		10/6/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline		3/15/2011	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	Yes
8,000			TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in MISSOULA County in the City of MISSOULA

Location: MURALTS TRUCK PLAZA
8800 TRUCK STOP RD
MISSOULA, MT 59808 MISSOULA
Contact: Walt Murault, (406) 728-4700

Sys Fac ID: 32-00146
Last Inspected On: 1/6/2015
Operating Permit Renewal Date: 1/14/2018

Owners/Operators: Muralts Inc, Owner (406)-728-4700 8800 TRUCK STOP RD MISSOULA MT 59808-9708

WILLY BAKER, UST Class A Operator
Laci Carvey, UST Class A Operator
WILLY BAKER, UST Class B Operator
Laci Carvey, UST Class B Operator
Christopher Smith, UST Class B Operator
Curtis Wilson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	48	3/26/1968	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3650			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Diesel		3/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000		3/23/2012	TLS-350/Gilbarco EMC , Veeder Root		
2	48	3/26/1968	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3651			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Diesel		3/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000		3/23/2012	TLS-350/Gilbarco EMC , Veeder Root		
3	48	3/26/1968	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3652			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Diesel		3/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000		3/23/2012	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: MURALTS TRUCK PLAZA
8800 TRUCK STOP RD
MISSOULA, MT 59808 MISSOULA

Contact: Walt Murault, (406) 728-4700

Sys Fac ID: 32-00146
Last Inspected On: 1/6/2015
Operating Permit Renewal Date: 1/14/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	48	3/26/1968	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3653			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		6/20/2014	TLS-350/Gilbarco EMC , Veeder Root		
5	48	3/26/1968	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3654			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/23/2012	TLS-350/Gilbarco EMC , Veeder Root		
6	43	3/26/1973	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3655			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/23/2012	TLS-350/Gilbarco EMC , Veeder Root		
10	21	11/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1734			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		5/19/2009	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		3/23/2012	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: MURALTS TRUCK PLAZA
8800 TRUCK STOP RD
MISSOULA, MT 59808 MISSOULA
Contact: Walt Murault, (406) 728-4700

Sys Fac ID: 32-00146
Last Inspected On: 1/6/2015
Operating Permit Renewal Date: 1/14/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	21	11/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1735			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		5/19/2009	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
5,000		3/23/2012	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: HELLGATE TRADING POST INC
6265 MULLAN RD
MISSOULA, MT 59808 MISSOULA
Contact: (406) 728-8644

Sys Fac ID: 32-00211
Last Inspected On: 10/5/2016
Operating Permit Renewal Date: 12/7/2019

Owners/Operators: Tabish Brothers Distributors Inc, Owner (406)-543-7621 GW PETROLEUM
PO BOX 8448
MISSOULA MT 59807-8448

Malinda R Davis, UST Class A Operator
Karly Shafer, UST Class A Operator
Jennifer Snyder, UST Class A Operator
Katherine Ritter, UST Class B Operator
Jennifer Snyder, UST Class B Operator
Malinda R Davis, UST Class B Global Operator
Karly Shafer, UST Class B Global Operator
Heather M Stiles, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	22	9/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1425			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		10/4/2016	Gilbarco EMC Basic , Gilbarco		
4	22	9/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1426			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		10/4/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: HEATING PLANT
PHYSICAL PLANT BLDG #32
MISSOULA, MT 59812 MISSOULA
Contact: Mike Burke, (406) 243-2190

Sys Fac ID: 32-00505
Last Inspected On: 11/1/2016
Operating Permit Renewal Date: 2/22/2020

Owners/Operators: University of Montana, Owner (406)-243-2190 ATTN MIKE BURKE
32 CAMPUS DRIVE
MISSOULA MT 59812-6815

Michael Burke, UST Class A Operator
Michael Burke, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	18	11/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4221		11/1/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
20,000			TLS-300 , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: WATKINS & SHEPARD TRUCKING MISSOULA
6400 US HIGHWAY 10 W
MISSOULA, MT 59808 MISSOULA

Contact: Chuck Wieck, (406) 728-6121

Sys Fac ID: 32-00920
Last Inspected On: 4/10/2014
Operating Permit Renewal Date: 6/6/2017

Owners/Operators: Watkins & Shepard Trucking, Owner (406)-728-6121 PO BOX 5328
MISSOULA MT 59806-5328

Brian Lease, UST Class A Operator
Kelly O'Toole, UST Class A Operator
Brian Lease, UST Class B Operator
Kelly O'Toole, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	18	4/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1967		4/10/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
15,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: MISSOULA SERVICE CENTER
1900 S RUSSELL ST
MISSOULA, MT 59801 MISSOULA

Contact: Beth Stimatz, (406) 497-2687

Sys Fac ID: 32-01182
Last Inspected On: 4/16/2014
Operating Permit Renewal Date: 6/13/2017

Owners/Operators: Northwestern Energy, Owner (406)-655-2521 405 S 20TH ST W BILLINGS MT 59102

John Habeger, UST Class A Operator
Bruce Schlichenmayer, UST Class B Operator
Greg Sponseller, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	26	7/27/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1681			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Safe Suction	Galvanic
Diesel		10/12/2011	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Deferred	
3,000				Continuous Interstitial Monitor	
5	26	7/27/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1680			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Safe Suction	Galvanic
Gasoline		10/12/2011	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Deferred	
13,000				Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: WESTERN TRANSPORT
9310 CARTAGE RD
MISSOULA, MT 59808 MISSOULA

Contact: Scott Allen, (406) 493-7876

Sys Fac ID: 32-01348
Last Inspected On: 3/29/2016
Operating Permit Renewal Date: 6/9/2019

Owners/Operators:

Western Land Investments LLC, Owner	(307)-674-6305	PO BOX 671 SHERIDAN WY 82801
Scott Allen, Operator	(406)-493-7876	9310 CARTAGE RD MISSOULA MT 59808

Scott Allen, UST Class A Operator
Neil Hanson, UST Class A Operator
Scott Allen, UST Class B Operator
Jeff Drushel, UST Class B Operator
Neil Hanson, UST Class B Global Operator
Robin Titus, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	48	1/17/1968	Cathodically Protected Steel	Steel	High Level Alarm
1654			Lined Interior/Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		3/18/2015	Automatic Tank Gauging 0.2	Deferred	
10,000		9/12/2012	TLS-250 , Veeder Root		
4	48	1/17/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1655			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		3/18/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		12/14/2015	TLS-250 , Veeder Root		
5	35	1/16/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1656			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		3/18/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		5/27/2010	TLS-250 , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: GILLYS GAS & GROCERY
2340 S 3RD ST W
MISSOULA, MT 59801 MISSOULA

Contact: Justin McKay, (406) 542-0550

Sys Fac ID: 32-02179
Last Inspected On: 6/27/2016
Operating Permit Renewal Date: 8/28/2019

Owners/Operators:

JM & JM Enterprise, Owner	(406)-293-1873	317 LIBBY CREEK LANE LIBBY MT 59923-8553
John R McKay, Operator	(406)-293-1873	317 LIBBY CREEK LANE LIBBY MT 59923-8553

John R McKay, UST Class A Operator
Justin McKay, UST Class A Operator
Charles Weight, UST Class A Operator
John R McKay, UST Class B Operator
Justin McKay, UST Class B Operator
Charles Weight, UST Class B Operator
Amy Williams, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	40	4/23/1976	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3624			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TS-1000 , Incon	Continuous Interstitial Monitor	
2	40	4/23/1976	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3625			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TS-1000 , Incon	Continuous Interstitial Monitor	
3	40	4/23/1976	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3626			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		8/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TS-1000 , Incon	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: FINEST OIL CO MISSOULA NORTHGATE
3665 GRANT CREEK RD
MISSOULA, MT 59808 MISSOULA
Contact: Steve Hanson, (406) 543-6969

Sys Fac ID: 32-02295
Last Inspected On: 7/29/2014
Operating Permit Renewal Date: 8/9/2017

Owners/Operators: Finest Oil Co, Owner (406)-543-6969 PO BOX 17077
MISSOULA MT 59808-7077

James Brady, UST Class A Operator
James DeWaters, UST Class A Operator
Christopher Glasser, UST Class A Operator
David Peyton, UST Class A Operator
Stephen Hanson, UST Class B Operator
David Peyton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	5/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1073			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/29/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000					
2	23	6/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1071			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		7/29/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000					
3	22	5/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1072			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/29/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000					

Facility Summary in MISSOULA County in the City of MISSOULA

Location: FINEST OIL CO MISSOULA NORTHGATE
3665 GRANT CREEK RD
MISSOULA, MT 59808 MISSOULA

Contact: Steve Hanson, (406) 543-6969

Sys Fac ID: 32-02295
Last Inspected On: 7/29/2014
Operating Permit Renewal Date: 8/9/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	23	6/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1070			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/29/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000					
9	25	7/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1066			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		7/29/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000					
10	25	7/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1067			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		7/29/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000					
11	23	6/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1068			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		7/29/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000					

Facility Summary in MISSOULA County in the City of MISSOULA

Location: FINEST OIL CO MISSOULA NORTHGATE
3665 GRANT CREEK RD
MISSOULA, MT 59808 MISSOULA

Contact: Steve Hanson, (406) 543-6969

Sys Fac ID: 32-02295
Last Inspected On: 7/29/2014
Operating Permit Renewal Date: 8/9/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
12	23	6/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1069			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		7/29/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000					

Facility Summary in MISSOULA County in the City of MISSOULA

Location: MOUNTAIN WEST CO OP MISSOULA RESERVE ST
4570 N RESERVE ST
MISSOULA, MT 59808 MISSOULA

Contact: Chuck Thompson, (406) 543-8383

Sys Fac ID: 32-02437
Last Inspected On: 6/11/2015
Operating Permit Renewal Date: 6/15/2018

Owners/Operators: Mountain West Coop - Missoula, Owner (406)-543-8383 4570 N RESERVE ST MISSOULA MT 59808-1411

Will Dukart, UST Class A Operator
Dave Otto, UST Class A Operator
Dusty Smith, UST Class A Operator
John Thompson, UST Class A Operator
Mike Dunlon, UST Class B Operator
Bill Griffin, UST Class B Operator
John Thompson, UST Class B Operator
Dave Otto, UST Class B Global Operator
Dusty Smith, UST Class B Global Operator
John Thompson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	21	3/29/1995	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve, High Level Alarm
2859			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/16/2014	Automatic Tank Gauging 0.2	ELLD Line Tightness Testing, Not Listed	
4,000		6/12/2014	TLS-350/Gilbarco EMC , Veeder Root		
17	02	11/1/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Auto Limiter, High Level Alarm
5554		12/11/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
25,000		1/16/2015	TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in MISSOULA County in the City of MISSOULA

Location: MOUNTAIN WEST CO OP MISSOULA RESERVE ST
4570 N RESERVE ST
MISSOULA, MT 59808 MISSOULA

Contact: Chuck Thompson, (406) 543-8383

Sys Fac ID: 32-02437
Last Inspected On: 6/11/2015
Operating Permit Renewal Date: 6/15/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
18	02	11/1/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Auto Limiter, High Level Alarm
5555		12/11/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
25,000		1/16/2015	TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
19	02	11/1/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Auto Limiter, High Level Alarm
5556		12/11/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
10,000		1/16/2015	TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
20	02	11/1/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Auto Limiter, High Level Alarm
5557		12/11/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
6,000		1/16/2015	TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
21	02	11/1/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Auto Limiter, High Level Alarm
5558		12/11/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
10,000		1/16/2015	TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in MISSOULA County in the City of MISSOULA

Location: MOUNTAIN WEST CO OP MISSOULA RESERVE ST
4570 N RESERVE ST
MISSOULA, MT 59808 MISSOULA

Contact: Chuck Thompson, (406) 543-8383

Sys Fac ID: 32-02437
Last Inspected On: 6/11/2015
Operating Permit Renewal Date: 6/15/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
22	02	11/1/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Auto Limiter, High Level Alarm
5559		12/11/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
10,000		1/16/2015	TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in MISSOULA County in the City of MISSOULA

Location: OLES COUNTRY STORE 12 & DIXIES DINER
3705 MT HIGHWAY 200 E
MISSOULA, MT 59802 MISSOULA

Contact: Gary Louquet, (406) 728-7500

Sys Fac ID: 32-03190
Last Inspected On: 11/29/2016
Operating Permit Renewal Date: 2/9/2017

Owners/Operators: JGL Distributing Inc, Owner (406)-728-7736 PO BOX 2758 MISSOULA MT 59806-2758

Peggy Wolfe, UST Class A Operator
Peggy Wolfe, UST Class B Operator
LeeAnn Dean, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	52	5/1/1964	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1427			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/14/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/31/2013			
2	52	5/1/1964	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1428			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		11/14/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/31/2013			
3	52	5/1/1964	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1429			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		11/14/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/31/2013			
4	52	5/1/1964	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1430			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/14/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/31/2013			

Facility Summary in MISSOULA County in the City of MISSOULA

Location: OLES COUNTRY STORE 12 & DIXIES DINER
3705 MT HIGHWAY 200 E
MISSOULA, MT 59802 MISSOULA

Contact: Gary Louquet, (406) 728-7500

Sys Fac ID: 32-03190
Last Inspected On: 11/29/2016
Operating Permit Renewal Date: 2/9/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	37	5/2/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1431			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/14/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		7/31/2013			

Facility Summary in MISSOULA County in the City of MISSOULA

Location: PHILLIPS 66/EXXON MOBIL JOINTLY OWNED MISSOULA TERMINAL
3330 RASER DR
MISSOULA, MT 59808 MISSOULA

Contact: Frances Nunn, (406) 255-5714

Sys Fac ID: 32-03320
Last Inspected On: 3/8/2016
Operating Permit Renewal Date: 6/9/2019

Owners/Operators:

Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal, Owner	(406)-255-5714	2626 LILLIAN AVENUE BILLINGS MT 59101
Phillips 66 Pipeline LLC, Operator	(406)-255-5714	2626 LILLIAN AVENUE BILLINGS MT 59101

Richard Colgrove, UST Class A Operator
Mark Shellabarger, UST Class A Operator
Chris Binder, UST Class B Operator
Garrett Burgin, UST Class B Operator
Richard Colgrove, UST Class B Operator
Randy Dayley, UST Class B Operator
Kyle Jackson, UST Class B Operator
Matthew LaPierre, UST Class B Operator
Michael Mcarthur, UST Class B Operator
Dusty Nagel, UST Class B Operator
Orlando Rodriguez, UST Class B Operator
Dustin Rogers, UST Class B Operator
Brent Schreckendgust, UST Class B Operator
Mark Shellabarger, UST Class B Operator
Andrew Snyder, UST Class B Operator
Kerry Sweten, UST Class B Operator
Mark Shellabarger, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	63	1/1/1953	Cathodically Protected Steel	Steel - Terminal Piping	
739	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		6/3/2015	Deferred	MLLD Line Tightness Testing	
1,260,000		10/9/2015			

Facility Summary in MISSOULA County in the City of MISSOULA

Location: PHILLIPS 66/EXXON MOBIL JOINTLY OWNED MISSOULA TERMINAL
3330 RASER DR
MISSOULA, MT 59808 MISSOULA

Contact: Frances Nunn, (406) 255-5714

Sys Fac ID: 32-03320
Last Inspected On: 3/8/2016
Operating Permit Renewal Date: 6/9/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	63	1/1/1953	Cathodically Protected Steel	Steel - Terminal Piping	
741	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		6/3/2015	Deferred	MLLD Line Tightness Testing	
840,000		10/9/2015			
5	63	1/1/1953	Cathodically Protected Steel	Steel - Terminal Piping	
743	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Mixture		6/3/2015	Deferred	MLLD Line Tightness Testing	
840,000		10/9/2015			
7	63	1/1/1953	Cathodically Protected Steel	Steel - Terminal Piping	
745	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasohol/Ethanol		6/3/2015	Deferred	MLLD Line Tightness Testing	
840,000		10/9/2015			
9	44	1/1/1972	Cathodically Protected Steel	Steel - Terminal Piping	
747	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		6/3/2015	Deferred	MLLD Line Tightness Testing	
840,000		10/9/2015			
11	42	1/1/1974	Cathodically Protected Steel	Steel - Terminal Piping	
749	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		6/3/2015	Deferred	MLLD Line Tightness Testing	
4,200,000		10/9/2015			

Facility Summary in MISSOULA County in the City of MISSOULA

Location: PHILLIPS 66/EXXON MOBIL JOINTLY OWNED MISSOULA TERMINAL
3330 RASER DR
MISSOULA, MT 59808 MISSOULA

Contact: Frances Nunn, (406) 255-5714

Sys Fac ID: 32-03320
Last Inspected On: 3/8/2016
Operating Permit Renewal Date: 6/9/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
12	42	1/1/1974	Cathodically Protected Steel	Steel - Terminal Piping	
750	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		6/3/2015	Deferred	MLLD Line Tightness Testing	
2,646,000		10/9/2015			
20	19	11/1/1997	Cathodically Protected Steel	Steel - Terminal Piping	High Level Alarm
738			Double-Walled	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Mixture		6/3/2015	Continuous Interstitial Monitor	MLLD Line Tightness Testing	
8,000		3/8/2016	Other , Other		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: DEANOS TRAVEL PLAZA 14
5055 N RESERVE ST
MISSOULA, MT 59808 MISSOULA

Contact: Dean Clinkenbeard, (406) 728-6052

Sys Fac ID: 32-03610
Last Inspected On: 10/11/2016
Operating Permit Renewal Date: 12/21/2019

Owners/Operators: DC Petroleum Inc, Owner (406)-728-6052 PO BOX 16085 MISSOULA MT 59808-6085

Dean Clinkenbeard, UST Class A Operator
Sheri Taylor, UST Class A Operator
Sheri Taylor, UST Class B Operator
Dean Clinkenbeard, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	4/2/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
799			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/21/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	25	4/2/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
795			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		1/9/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	25	4/2/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
796			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/21/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: DEANOS TRAVEL PLAZA 14
5055 N RESERVE ST
MISSOULA, MT 59808 MISSOULA

Contact: Dean Clinkenbeard, (406) 728-6052

Sys Fac ID: 32-03610
Last Inspected On: 10/11/2016
Operating Permit Renewal Date: 12/21/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	25	4/2/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
797			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/21/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
10	25	4/2/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
798			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/21/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: NOONS 457
540 E BROADWAY ST
MISSOULA, MT 59802 MISSOULA
Contact: (406) 721-5968

Sys Fac ID: 32-03614
Last Inspected On: 8/5/2015
Operating Permit Renewal Date: 8/26/2018

Owners/Operators: Hi Noon Petroleum Missoula, Owner (406)-532-0381 PO BOX 7578
MISSOULA MT 59807-7578

Earl Allen, UST Class A Operator
Patrick Cork, UST Class A Operator
Keith Dowling, UST Class A Operator
Nicholas Holtey, UST Class A Operator
Erin Keffeler, UST Class A Operator
Randy Livingston, UST Class A Operator
Jared Sayre, UST Class A Operator
Stephanie Whiteman, UST Class A Operator
Andrew Young, UST Class A Operator
Earl Allen, UST Class B Operator
Keith Dowling, UST Class B Operator
Lisa Millspaugh, UST Class B Operator
Jared Sayre, UST Class B Operator
Willy Baker, UST Class B Global Operator
Laci Carvey, UST Class B Global Operator
Patrick Cork, UST Class B Global Operator
Cameron Fulmer, UST Class B Global Operator
Joshua Fuss, UST Class B Global Operator
Nicholas Holtey, UST Class B Global Operator
Erin Keffeler, UST Class B Global Operator
Randy Livingston, UST Class B Global Operator
Stephanie Whiteman, UST Class B Global Operator
Andrew Young, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**

Facility Summary in MISSOULA County in the City of MISSOULA

Location: NOONS 457
540 E BROADWAY ST
MISSOULA, MT 59802 MISSOULA
Contact: (406) 721-5968

Sys Fac ID: 32-03614
Last Inspected On: 8/5/2015
Operating Permit Renewal Date: 8/26/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	01	4/28/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5573		4/27/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
18,000		4/26/2015	TLS-350/Gilbarco EMC , Veeder Root	Not Listed	Yes
6	01	4/28/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5574		4/27/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000		4/26/2015	TLS-350/Gilbarco EMC , Veeder Root	Not Listed	Yes
7	01	4/28/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5575		4/27/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
4,000		4/26/2015	TLS-350/Gilbarco EMC , Veeder Root	Not Listed	Yes

Facility Summary in MISSOULA County in the City of MISSOULA

Location: ZIP TRIP 32
1540 TOOLE AVE
MISSOULA, MT 59802 MISSOULA
Contact: (406) 543-7002

Sys Fac ID: 32-03912
Last Inspected On: 8/19/2016
Operating Permit Renewal Date: 2/4/2020

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Jason Cocke, UST Class A Operator
Sean Hurley, UST Class A Operator
Jason Cocke, UST Class B Operator
Justin Mace, UST Class B Operator
Luci Tuttle, UST Class B Operator
Jason Cocke, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	3/22/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1342			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/9/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	32	3/22/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1343			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/9/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: ZIP TRIP 32
1540 TOOLE AVE
MISSOULA, MT 59802 MISSOULA
Contact: (406) 543-7002

Sys Fac ID: 32-03912
Last Inspected On: 8/19/2016
Operating Permit Renewal Date: 2/4/2020

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	32	3/22/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1344			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		10/9/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: ST PATRICKS HOSPITAL
500 W BROADWAY ST
MISSOULA, MT 59802 MISSOULA

Contact: Thomas Schussler, (406) 329-5730

Sys Fac ID: 32-04266
Last Inspected On: 1/27/2015
Operating Permit Renewal Date: 5/29/2018

Owners/Operators: Saint Patricks Hospital, Owner (406)-543-7271 500 W BROADWAY ST MISSOULA MT 59802-4096
Timothy Chopp, UST Class A Operator
Timothy Chopp, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	15	10/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4497			Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
10,000		9/24/2014	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
4	08	7/18/2008	Fiberglass Reinforced Plastic	Flexible Plastic	
5175			Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
10,000		9/24/2014	TLS-300 , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in MISSOULA County in the City of MISSOULA

Location: MISSOULA URBAN TRANSPORTATION
1221 SHAKESPEARE ST
MISSOULA, MT 59802 MISSOULA
Contact: Steve Earle, (406) 543-8386

Sys Fac ID: 32-04427
Last Inspected On: 12/11/2013
Operating Permit Renewal Date: 6/5/2017

Owners/Operators: Missoula Urban Transportation, Owner (406)-543-8386 1221 SHAKESPEARE ST MISSOULA MT 59802-2307
John Roseboom, UST Class A Operator
John Roseboom, UST Class B Operator

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
4	18	4/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1658			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					
5	18	4/30/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1659		1/27/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Not Listed	Not Applicable
Waste Oil			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
600					

Facility Summary in MISSOULA County in the City of MISSOULA

Location: UNITED PARCEL SERVICES MISSOULA
221 EXPRESSWAY LN
MISSOULA, MT 59808 MISSOULA

Contact: Dino Ostrow, (503) 978-7678

Sys Fac ID: 32-04536
Last Inspected On: 7/27/2016
Operating Permit Renewal Date: 10/11/2019

Owners/Operators:

United Parcel Service, Inc, Owner	(503)-978-7678	6707 N BASIN AVE PORTLAND OR 97217
United Parcel Service Plant Engineering Dept, Operator	(206)-621-6261	4455 7TH AVE S SEATTLE WA 98108

Robert Counts, UST Class A Operator
Treair Smith, UST Class A Operator
Russell Stott, UST Class A Operator
Paul Vandehey, UST Class A Operator
Robert Counts, UST Class B Operator
Russell Stott, UST Class B Operator
Treair Smith, UST Class B Global Operator
Paul Vandehey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	23	7/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2182			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
12,000		4/6/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: OLES COUNTRY STORE 11
1600 S RUSSELL ST
MISSOULA, MT 59801 MISSOULA
Contact: Derek Louquet, (406) 728-7618

Sys Fac ID: 32-04620
Last Inspected On: 11/3/2015
Operating Permit Renewal Date: 3/5/2019

Owners/Operators: DDJ Investments LLC, Owner (406)-728-7618 1600 S RUSSELL ST MISSOULA MT 59801

Derek Louquet, UST Class A Operator
Clark Ridgeway, UST Class A Operator
Larry Krause, UST Class B Operator
Clark Ridgeway, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	28	10/30/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1722			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/3/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		3/18/2015	Gilbarco EMC Basic , Gilbarco		
5	28	10/30/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1723			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		11/3/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		3/18/2015	Gilbarco EMC Basic , Gilbarco		
6	28	10/30/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1721			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/3/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		3/18/2015	Gilbarco EMC Basic , Gilbarco		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: OLES COUNTRY STORE INC 2
923 N ORANGE ST
MISSOULA, MT 59802 MISSOULA

Contact: Casie Schwindt, (406) 542-2224

Sys Fac ID: 32-05216
Last Inspected On: 11/29/2016
Operating Permit Renewal Date: 3/14/2017

Owners/Operators: Oles Country Stores Inc Missoula, Owner (406)-542-2224 PO BOX 3356 MISSOULA MT 59806-2927

Casie Schwindt, UST Class A Operator
Erika Nicklay, UST Class B Operator
Casie Schwindt, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	26	9/25/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2357			None	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/14/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000		8/22/2007			
5	26	9/25/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2358			None	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/14/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		8/22/2007			
6	26	9/25/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2359			None	Secondary Containment Chase	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/14/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		8/22/2007			

Facility Summary in MISSOULA County in the City of MISSOULA

Location: JAYS FOOD STORE
2738 W BROADWAY ST
MISSOULA, MT 59808 MISSOULA
Contact: Bobby Ghuman, (406) 549-1750

Sys Fac ID: 32-05760
Last Inspected On: 4/10/2014
Operating Permit Renewal Date: 8/2/2017

Owners/Operators: Jays Corporation, Owner (406)-476-6988 2738 W BROADWAY ST MISSOULA MT 59808-1622

Jagpreet Ghuman, UST Class A Operator
Jaspal Sandhu, UST Class A Operator
Jaspal Sandhu, UST Class B Operator
Jagpreet Ghuman, UST Class B Global Operator
Jaspal Sandhu, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	44	11/18/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1345		10/10/2015	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/10/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		1/11/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	40	11/18/1976	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1346		10/10/2015	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/10/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		1/9/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	44	11/18/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1347		10/10/2015	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		4/10/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		1/9/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: JAYS FOOD STORE CARDLOCK
2738 W BROADWAY ST
MISSOULA, MT 59808 MISSOULA

Sys Fac ID: 32-05761
Last Inspected On: 11/2/2016
Operating Permit Renewal Date:

Contact: Mambreet Singh, (406) 544-8853

Owners/Operators: Jays Corporation, Owner (406)-476-6988 2738 W BROADWAY ST MISSOULA MT 59808-1622

Jagpreet Ghuman, UST Class A Operator
Jagpreet Ghuman, UST Class B Global Operator
Jaspal Sandhu, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	37	11/14/1979	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3627			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Gasoline		6/23/2015	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
10,000					
2	41	11/14/1975	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3628			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Gasoline		6/23/2015	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
4,000					
3	37	11/14/1979	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3629			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Diesel		6/23/2015	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
10,000					

Facility Summary in MISSOULA County in the City of MISSOULA

Location: NOONS 426
1250 39TH ST
MISSOULA, MT 59803 MISSOULA
Contact: Monte Means, (406) 728-5104

Sys Fac ID: 32-05763
Last Inspected On: 9/15/2016
Operating Permit Renewal Date: 12/10/2019

Owners/Operators: Hi Noon Petroleum Missoula, Owner (406)-532-0381 PO BOX 7578
MISSOULA MT 59807-7578

Earl Allen, UST Class A Operator
Willy Baker, UST Class A Operator
Patrick Cork, UST Class A Operator
Keith Dowling, UST Class A Operator
Nicholas Holtey, UST Class A Operator
Erin Keffeler, UST Class A Operator
Randy Livingston, UST Class A Operator
Joseph Salisbury, UST Class A Operator
Jared Sayre, UST Class A Operator
June Schneider, UST Class A Operator
Stephanie Whiteman, UST Class A Operator
Andrew Young, UST Class A Operator
Keith Dowling, UST Class B Operator
Lisa Millspaugh, UST Class B Operator
Joseph Salisbury, UST Class B Operator
Jared Sayre, UST Class B Operator
Earl Allen, UST Class B Global Operator
Laci Carvey, UST Class B Global Operator
Patrick Cork, UST Class B Global Operator
Cameron Fulmer, UST Class B Global Operator
Joshua Fuss, UST Class B Global Operator
Nicholas Holtey, UST Class B Global Operator
Erin Keffeler, UST Class B Global Operator
Randy Livingston, UST Class B Global Operator
June Schneider, UST Class B Global Operator
Stephanie Whiteman, UST Class B Global Operator
Andrew Young, UST Class B Global Operator

Facility Summary in MISSOULA County in the City of MISSOULA

Location: NOONS 426
1250 39TH ST
MISSOULA, MT 59803 MISSOULA
Contact: Monte Means, (406) 728-5104

Sys Fac ID: 32-05763
Last Inspected On: 9/15/2016
Operating Permit Renewal Date: 12/10/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	36	1/1/1980	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1348			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/9/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		6/14/2010	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	36	1/1/1980	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1349			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		3/9/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		6/14/2010	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	36	1/1/1980	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1350			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/9/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		6/14/2010	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: SOUTH AVE MARKET 2
2401 S HIGGINS AVE
MISSOULA, MT 59801 MISSOULA
Contact: (406) 728-4899

Sys Fac ID: 32-05764
Last Inspected On: 11/2/2016
Operating Permit Renewal Date: 2/19/2020

Owners/Operators: Steven H Schmidt, Owner (406)-549-0540 DBA PS MINI MART
506 EDDY AVE
MISSOULA MT 59801-2803

Scott Denning, UST Class A Operator
Steven H Schmidt, UST Class A Operator
Josh McCourt, UST Class B Global Operator
Rico Pagauini, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	35	4/26/1981	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4668			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/2/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	35	4/26/1981	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3849			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/2/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	35	4/26/1981	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3850			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/2/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: TABISH BROTHERS DISTRIBUTORS INC
501 TAYLOR ST
MISSOULA, MT 59802 MISSOULA

Contact: Frank Tabish, (406) 543-7621

Sys Fac ID: 32-06523
Last Inspected On: 8/21/2014
Operating Permit Renewal Date: 12/17/2017

Owners/Operators: Tabish Brothers Distributors Inc, Owner (406)-543-7621 GW PETROLEUM
PO BOX 8448
MISSOULA MT 59807-8448

Franklin X Tabish, UST Class A Operator
Heather M Stiles, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	35	4/16/1981	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
2081		8/21/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Waste Oil			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
7,600			TLS-350/Gilbarco EMC , Veeder Root		
4	35	4/16/1981	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2080			None	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Heating Oil			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
7,600			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: KWIK STOP SINCLAIR
505 HIGHTON ST
MISSOULA, MT 59802 MISSOULA

Contact: Vibhutiben Patel, (406) 549-3286

Sys Fac ID: 32-06680
Last Inspected On: 5/19/2014
Operating Permit Renewal Date: 7/31/2017

Owners/Operators: Mayur LLC, Owner/Operator (406)-549-3286 505 HIGHTON ST MISSOULA MT 59802-5424

Ashish Patel, UST Class A Operator
Jayprakash Patel, UST Class A Operator
Ashish Patel, UST Class B Operator
Jayprakash Patel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	1/10/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2300			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/7/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		10/3/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	26	1/10/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2298			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/7/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		10/3/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	26	1/10/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2299			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/7/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		10/3/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: GRAY WOLF PEAK
20750 US HIGHWAY 93 N
MISSOULA, MT 59808 MISSOULA

Sys Fac ID: 32-06789
Last Inspected On: 11/13/2001
Operating Permit Renewal Date:

Contact: Peter Fordham, (406) 726-3778

Owners/Operators: S & K Gaming LLC, Owner (406)-883-3636 49708 US HIGHWAY 93
POLSON MT 59860-2305

Jennifer Domebo, UST Class A Operator
Jennifer Domebo, UST Class B Operator
Jennifer Domebo, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	38	5/5/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3805			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000					
2	38	5/5/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3806			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000					
3	38	5/5/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3807			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000					
4	38	5/5/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3808			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000					

Facility Summary in MISSOULA County in the City of MISSOULA

Location: GRAY WOLF PEAK
20750 US HIGHWAY 93 N
MISSOULA, MT 59808 MISSOULA

Contact: Peter Fordham, (406) 726-3778

Sys Fac ID: 32-06789
Last Inspected On: 11/13/2001
Operating Permit Renewal Date:

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	15	4/1/2001	Concrete	Flexible Plastic	High Level Alarm
4509	Yes		Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Deferred	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
6,000					

Facility Summary in MISSOULA County in the City of MISSOULA

Location: ZOOTOWN SUPER STOP
2105 S HIGGINS AVE
MISSOULA, MT 59801 MISSOULA
Contact: W Sweeney, (406) 273-6675

Sys Fac ID: 32-07244
Last Inspected On: 1/8/2015
Operating Permit Renewal Date: 3/13/2018

Owners/Operators: Tabish Brothers Distributors Inc, Owner/Operator (406)-543-7621 GW PETROLEUM
PO BOX 8448
MISSOULA MT 59807-8448

Dennis Daniels, UST Class A Operator
Callie Leigh Olson, UST Class A Operator
Karly Shafer, UST Class A Operator
Leanne Johnsen, UST Class B Operator
Dennis Daniels, UST Class B Global Operator
Karly Shafer, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	12/7/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1801			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/7/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		7/13/2011	Gilbarco EMC Basic , Gilbarco		
4	25	12/7/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1799			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/7/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
8,000		7/13/2011	Gilbarco EMC Basic , Gilbarco		
5	25	12/7/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1800			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/7/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		7/13/2011	Gilbarco EMC Basic , Gilbarco		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: GREAT WESTERN PETROLEUM
1002 E BROADWAY ST
MISSOULA, MT 59802 MISSOULA

Contact: Frank Tabish, (406) 543-7621

Sys Fac ID: 32-07431
Last Inspected On: 8/4/2015
Operating Permit Renewal Date: 10/30/2018

Owners/Operators: Tabish Brothers Distributors Inc, Owner (406)-543-7621 GW PETROLEUM
PO BOX 8448
MISSOULA MT 59807-8448

Franklin X Tabish, UST Class A Operator
Franklin X Tabish, UST Class B Operator
Heather M Stiles, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	18	6/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1432		8/3/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			Gilbarco EMC Basic , Gilbarco		
11	18	6/1/1998	Cathodically Protected Steel	Flexible Plastic	
1433	Yes	8/3/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
17,000					
12	18	6/1/1998	Cathodically Protected Steel	Flexible Plastic	
1434	Yes	8/3/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
11,000					
13	18	6/1/1998	Cathodically Protected Steel	Flexible Plastic	
1435	Yes	8/3/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
14,600					

Facility Summary in MISSOULA County in the City of MISSOULA

Location: GREAT WESTERN PETROLEUM
1002 E BROADWAY ST
MISSOULA, MT 59802 MISSOULA

Contact: Frank Tabish, (406) 543-7621

Sys Fac ID: 32-07431
Last Inspected On: 8/4/2015
Operating Permit Renewal Date: 10/30/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
14	18	6/1/1998	Cathodically Protected Steel	Flexible Plastic	
1436	Yes	8/3/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
11,000					

Facility Summary in MISSOULA County in the City of MISSOULA

Location: MISSOULA AIRPORT WASHINGTON HANGER
5225 W BROADWAY ST
MISSOULA, MT 59808 MISSOULA

Contact: Tim Hunt, (406) 728-3190

Sys Fac ID: 32-07606
Last Inspected On: 8/28/2014
Operating Permit Renewal Date: 12/13/2017

Owners/Operators: Washington Corporations, Owner (406)-523-1349 PO BOX 16630
MISSOULA MT 59808-6630

Donald Hughes, UST Class A Operator
Donald Hughes, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	5/7/1984	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2242		7/2/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Jet Fuel		7/2/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-300 , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: HOLIDAY STATIONSTORE 278
403 S RUSSELL ST
MISSOULA, MT 59801 MISSOULA

Contact: Jack Krueger, (406) 860-9083

Sys Fac ID: 32-08072
Last Inspected On: 8/23/2016
Operating Permit Renewal Date: 11/21/2019

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Destry Randles, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Dean Townsend, UST Class A Operator
Ronald VanDenBroeke, UST Class A Operator
Destry Randles, UST Class B Operator
Tim Randles, UST Class B Operator
Todd White, UST Class B Operator
Julie Cordie, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator
Todd White, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	7/31/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3025			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		2/27/2007	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	21	7/31/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3026			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		2/27/2007	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: HOLIDAY STATIONSTORE 278
403 S RUSSELL ST
MISSOULA, MT 59801 MISSOULA

Contact: Jack Krueger, (406) 860-9083

Sys Fac ID: 32-08072
Last Inspected On: 8/23/2016
Operating Permit Renewal Date: 11/21/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	21	7/31/1995	Steel Clad	Flexible Plastic	Ball Float Valve
4700			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
12,000		3/5/2007	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	21	7/31/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3024			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		3/5/2007	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: THE OLDE DAIRY
2106 CLEMENTS RD
MISSOULA, MT 59804 MISSOULA
Contact: Emily Englund, (406) 239-3323

Sys Fac ID: 32-08475
Last Inspected On: 5/21/2014
Operating Permit Renewal Date: 9/3/2017

Owners/Operators:

Target Range Development LLC, Owner	(406)-721-3323	4860 SUNDOWN RD MISSOULA MT 59804
Carter Beck, Operator	(406)-721-8282	4860 SUNDOWN RD MISSOULA MT 59804
Emily Englund, Operator	(406)-239-3323	5156 EXCALIBUR WAY LOLO MT 59847
Scott Denning, UST Class A Operator		
Emily Englund, UST Class A Operator		
Emily Englund, UST Class B Operator		
Emily Englund, UST Class B Global Operator		
Bettina Gottfried, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	17	3/23/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4086			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	17	3/23/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4087			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		1/26/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	17	3/23/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4088			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: TOWN PUMP INC MISSOULA 2
318 S ORANGE ST
MISSOULA, MT 59801 MISSOULA
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 32-08715
Last Inspected On: 1/14/2016
Operating Permit Renewal Date: 5/14/2019

Owners/Operators: Orange Town Pump Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	26	5/24/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2552			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
4	26	5/29/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2553			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
5	26	5/29/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2554			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: PHILLIPS 66/EXXON MOBIL JOINTLY OWNED MISSOULA TERMINAL
3330 RASER DR
MISSOULA, MT 59808 MISSOULA

Contact: Frances Nunn, (406) 255-5714

Sys Fac ID: 32-08732
Last Inspected On: 3/8/2016
Operating Permit Renewal Date: 6/9/2019

Owners/Operators:

Phillips 66/Exxon Mobil Jointly Owned Missoula Terminal, Owner	(406)-255-5714	2626 LILLIAN AVENUE BILLINGS MT 59101
Phillips 66 Pipeline LLC, Operator	(406)-255-5714	2626 LILLIAN AVENUE BILLINGS MT 59101

Richard Colgrove, UST Class A Operator
Mark Shellabarger, UST Class A Operator
Chris Binder, UST Class B Operator
Garrett Burgin, UST Class B Operator
Richard Colgrove, UST Class B Operator
Randy Dayley, UST Class B Operator
Kyle Jackson, UST Class B Operator
Matthew LaPierre, UST Class B Operator
Michael Mcarthur, UST Class B Operator
Dusty Nagel, UST Class B Operator
Orlando Rodriguez, UST Class B Operator
Brent Schreckendgust, UST Class B Operator
Mark Shellabarger, UST Class B Operator
Andrew Snyder, UST Class B Operator
Kerry Sweten, UST Class B Operator
Mark Shellabarger, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	62	6/1/1954	Cathodically Protected Steel	Steel - Terminal Piping	
2803	Yes		None	none	Yes
Temporarily Out of Use			Not Required	Pressurized	Impressed Current
Gasoline			Deferred	MLLD Line Tightness Testing	
648,000					

Facility Summary in MISSOULA County in the City of MISSOULA

Location: PHILLIPS 66/EXXON MOBIL JOINTLY OWNED MISSOULA TERMINAL
3330 RASER DR
MISSOULA, MT 59808 MISSOULA

Contact: Frances Nunn, (406) 255-5714

Sys Fac ID: 32-08732
Last Inspected On: 3/8/2016
Operating Permit Renewal Date: 6/9/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	62	6/1/1954	Cathodically Protected Steel	Steel - Terminal Piping	
2801	Yes		None	none	Yes
Temporarily Out of Use			Not Required	Pressurized	Impressed Current
Diesel			Deferred	MLLD Line Tightness Testing	
847,000					
11	62	6/1/1954	Cathodically Protected Steel	Steel - Terminal Piping	
2802	Yes		None	none	Yes
Temporarily Out of Use			Not Required	Pressurized	Impressed Current
Gasoline			Deferred	MLLD Line Tightness Testing	
648,000					
13	62	6/1/1954	Cathodically Protected Steel	Steel - Terminal Piping	
2800	Yes		None	none	Yes
Temporarily Out of Use			Not Required	Pressurized	Impressed Current
Diesel			Deferred	MLLD Line Tightness Testing	
847,000					
14	62	6/1/1954	Cathodically Protected Steel	Steel - Terminal Piping	
2796	Yes		None	none	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		6/3/2015	Deferred	MLLD Line Tightness Testing	
1,260,000		9/23/2015			
15	62	6/1/1954	Cathodically Protected Steel	Steel - Terminal Piping	
2797	Yes		None	none	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		6/3/2015	Deferred	MLLD Line Tightness Testing	
647,892		9/23/2015			

Facility Summary in MISSOULA County in the City of MISSOULA

Location: PHILLIPS 66/EXXON MOBIL JOINTLY OWNED MISSOULA TERMINAL
3330 RASER DR
MISSOULA, MT 59808 MISSOULA

Contact: Frances Nunn, (406) 255-5714

Sys Fac ID: 32-08732
Last Inspected On: 3/8/2016
Operating Permit Renewal Date: 6/9/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
18	62	6/1/1954	Cathodically Protected Steel	Steel - Terminal Piping	
4909	Yes		None	none	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		6/3/2015	Deferred	MLLD Line Tightness Testing	
840,000		9/23/2015			
20	62	6/1/1954	Cathodically Protected Steel	Steel - Terminal Piping	
2793	Yes		None	none	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		6/3/2015	Deferred	MLLD Line Tightness Testing	
630,000		9/23/2015			
22	62	6/1/1954	Cathodically Protected Steel	Steel - Terminal Piping	
4581	Yes		None	none	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		6/3/2015	Deferred	MLLD Line Tightness Testing	
630,000		9/23/2015			

Facility Summary in MISSOULA County in the City of MISSOULA

Location: SOUTHGATE MARKET
1900 SOUTH AVE W
MISSOULA, MT 59801 MISSOULA
Contact: Steve Hintz, (406) 542-2685

Sys Fac ID: 32-08862
Last Inspected On: 12/27/2014
Operating Permit Renewal Date: 3/13/2018

Owners/Operators:

Fugli LLC, Owner	(406)-542-2685	811 COTTONWOOD ST MISSOULA MT 59801-3824
Diana Hintz, Operator	(406)-542-2685	1900 S AVENUE W MISSOULA MT 59801-6508
Steve Hintz, Operator	(406)-542-2685	811 COTTONWOOD MISSOULA MT 59801
Diana Hintz, UST Class A Operator		
Steve Hintz, UST Class A Operator		
Gary Keith, UST Class B Operator		
James Farrugia, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	30	12/23/1985	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1354			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/27/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		7/8/2011	Gilbarco EMC Basic , Gilbarco		
2	30	12/23/1985	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1355			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/27/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		8/6/2011	Gilbarco EMC Basic , Gilbarco		
3	30	12/23/1985	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1356			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/27/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		7/8/2011	Gilbarco EMC Basic , Gilbarco		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: NOONS 470
1605 S RUSSELL ST
MISSOULA, MT 59801 MISSOULA
Contact: Ellen Harne, (406) 543-7092

Sys Fac ID: 32-08863
Last Inspected On: 11/3/2015
Operating Permit Renewal Date: 2/9/2019

Owners/Operators: Hi Noon Petroleum Missoula, Owner (406)-532-0381 PO BOX 7578
MISSOULA MT 59807-7578

Earl Allen, UST Class A Operator
Patrick Cork, UST Class A Operator
Keith Dowling, UST Class A Operator
Nicholas Holtey, UST Class A Operator
Erin Keffeler, UST Class A Operator
Randy Livingston, UST Class A Operator
Jared Sayre, UST Class A Operator
Stephanie Whiteman, UST Class A Operator
Andrew Young, UST Class A Operator
Earl Allen, UST Class B Operator
Keith Dowling, UST Class B Operator
Erin Keffeler, UST Class B Operator
Lisa Millspaugh, UST Class B Operator
Jared Sayre, UST Class B Operator
Willy Baker, UST Class B Global Operator
Laci Carvey, UST Class B Global Operator
Patrick Cork, UST Class B Global Operator
Cameron Fulmer, UST Class B Global Operator
Joshua Fuss, UST Class B Global Operator
Nicholas Holtey, UST Class B Global Operator
Randy Livingston, UST Class B Global Operator
Stephanie Whiteman, UST Class B Global Operator
Andrew Young, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**

Facility Summary in MISSOULA County in the City of MISSOULA

Location: NOONS 470
1605 S RUSSELL ST
MISSOULA, MT 59801 MISSOULA
Contact: Ellen Harne, (406) 543-7092

Sys Fac ID: 32-08863
Last Inspected On: 11/3/2015
Operating Permit Renewal Date: 2/9/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	6/23/1985	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
1357			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
2	31	6/23/1985	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
1358			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
3	31	6/23/1985	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
1359			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: MDOT 11 3211 MISSOULA W BROADWAY
2100 W BROADWAY ST PO BOX 7039
MISSOULA, MT 59808 MISSOULA

Contact: Joe Radonich, (406) 444-9204

Sys Fac ID: 32-09304
Last Inspected On: 6/23/2015
Operating Permit Renewal Date: 10/1/2018

Owners/Operators:

MDOT Helena, Owner	(406)-444-6200	KIM JANZEN PO BOX 201001 HELENA MT 59620-1001
Joseph J Radonich, Operator	(406)-444-9204	MDT DEADHEAD HELENA MT 59620-0901

Jeff Gleason, UST Class A Operator
Walt Kerttula, UST Class A Operator
Mike Murolo, UST Class A Operator
Joe Radonich, UST Class A Operator
Richard Bick, UST Class B Operator
John Maricelli, UST Class B Operator
Justin Marin, UST Class B Operator
Chad Pearson, UST Class B Operator
Joe Radonich, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	5/1/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2917			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
10,000			Gilbarco EMC Basic , Gilbarco		
6	29	4/1/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2918			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		6/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
10,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: JAYS MART INC
2480 39TH ST
MISSOULA, MT 59803 MISSOULA
Contact: (406) 239-4547

Sys Fac ID: 32-09690
Last Inspected On: 4/10/2014
Operating Permit Renewal Date: 8/2/2017

Owners/Operators:

Hi Star Corporation, Owner	(509)-994-6549	2480 39TH ST MISSOULA MT 59803-1123
JAYS MART INC, Operator	(406)-239-4547	2480 39TH ST MISSOULA MT 59803-1123
Harbhupinder Singh, Operator	(406)-442-3259	3919 S SUNDOWN DR SPOKANE VALLEY WA 99206-9554
Jagpreet Ghuman, UST Class A Operator		
Manpreet Singh, UST Class A Operator		
Manpreet Singh, UST Class B Operator		
Jagpreet Ghuman, UST Class B Global Operator		
Jaspal Sandhu, UST Class B Global Operator		
Manpreet Singh, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	34	11/3/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1360			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/10/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
12,000		2/2/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	34	11/3/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1361			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/10/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		2/2/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: JAYS MART INC
2480 39TH ST
MISSOULA, MT 59803 MISSOULA
Contact: (406) 239-4547

Sys Fac ID: 32-09690
Last Inspected On: 4/10/2014
Operating Permit Renewal Date: 8/2/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	34	11/3/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1362			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/10/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		1/23/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: HOLIDAY STATIONSTORE 283
2325 S RESERVE ST
MISSOULA, MT 59801 MISSOULA

Contact: Jack Krueger, (406) 860-9083

Sys Fac ID: 32-09694
Last Inspected On: 9/25/2014
Operating Permit Renewal Date: 2/13/2018

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Stephen Reckinger, UST Class A Operator
Destry Randles, UST Class B Operator
Tim Randles, UST Class B Operator
Brian Wardner, UST Class B Operator
Travis Struckman, UST Class B Global Operator
Todd White, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	8/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
3706			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/9/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
12,000		4/25/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	
2	29	8/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
3707			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/9/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
10,000		4/17/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	
3	29	8/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
3708			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/9/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
10,000		4/17/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: HOLIDAY STATIONSTORE 283
2325 S RESERVE ST
MISSOULA, MT 59801 MISSOULA

Contact: Jack Krueger, (406) 860-9083

Sys Fac ID: 32-09694
Last Inspected On: 9/25/2014
Operating Permit Renewal Date: 2/13/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	29	8/1/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3709			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		1/9/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		4/15/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: ZIP TRIP 31
3325 BROOKS ST
MISSOULA, MT 59801 MISSOULA
Contact: (406) 542-7741

Sys Fac ID: 32-09730
Last Inspected On: 7/7/2016
Operating Permit Renewal Date: 11/5/2019

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Jason Cocke, UST Class A Operator
Sean Hurley, UST Class A Operator
Jason Cocke, UST Class B Operator
Justin Mace, UST Class B Operator
Luci Tuttle, UST Class B Operator
Jason Cocke, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	28	3/18/1988	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1363			None	Double-Walled	Yes
Currently in Use		3/18/1998	Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		8/4/2010	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		11/5/2015	TLS-350/Gilbarco EMC , Veeder Root		
2	28	3/18/1988	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1364			None	Double-Walled	Yes
Currently in Use		3/18/1998	Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/4/2010	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		11/5/2015	TLS-350/Gilbarco EMC , Veeder Root		
3	28	3/18/1988	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1365			None	Double-Walled	Yes
Currently in Use		3/18/1998	Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/4/2010	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		11/5/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: HOLIDAY STATIONSTORE 282
605 S HIGGINS AVE
MISSOULA, MT 59801 MISSOULA

Contact: Jack Krueger, (406) 860-9083

Sys Fac ID: 32-09733
Last Inspected On: 6/11/2014
Operating Permit Renewal Date: 8/17/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Destry Randles, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Mary Gray, UST Class B Operator
Destry Randles, UST Class B Operator
Tim Randles, UST Class B Operator
Greg Voorhees, UST Class B Operator
Mathew McConaughey, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator
Todd White, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	28	8/1/1988	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
3029			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/9/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
12,000		8/4/2011	TLS-350/Gilbarco EMC , Veeder Root		
2	28	8/1/1988	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
3030			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/9/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
12,000		4/9/2011	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: HOLIDAY STATIONSTORE 282
605 S HIGGINS AVE
MISSOULA, MT 59801 MISSOULA

Contact: Jack Krueger, (406) 860-9083

Sys Fac ID: 32-09733
Last Inspected On: 6/11/2014
Operating Permit Renewal Date: 8/17/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	28	8/1/1988	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
3028			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/9/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
12,000		5/21/2011	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: ALLIED WASTE SERVICES OF NORTH AMERICA LLC
1501 RODGERS ST
MISSOULA, MT 59802 MISSOULA

Contact: David Seeberger, (406) 532-5115

Sys Fac ID: 32-09872
Last Inspected On: 6/18/2014
Operating Permit Renewal Date: 8/30/2017

Owners/Operators: Allied Waste Services of North America LLC, Owner (406)-543-3157 PO BOX 8449
MISSOULA MT 59807-8449

Jake Paetsch, UST Class A Operator
David Seeberger, UST Class A Operator
David Seeberger, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	26	1/24/1990	Cathodically Protected Steel	Flexible Plastic	High Level Alarm, Auto Shutoff
500			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		4/21/2014	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	26	1/24/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
501			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Waste Oil		4/21/2014	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Deferred	
2,000		11/13/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: RANGITSCH BROTHERS 2001 WEST BROADWAY
2001 W BROADWAY ST
MISSOULA, MT 59808 MISSOULA

Contact: James Rangitsch, (406) 728-4040

Sys Fac ID: 32-09919
Last Inspected On: 7/1/2014
Operating Permit Renewal Date: 10/29/2017

Owners/Operators: Rangitsch Brothers, Owner (406)-728-4040 PO BOX 16127
MISSOULA MT 59808-6127

Joel Jasperson, UST Class A Operator
Russ Dickey, UST Class B Operator
Joel Jasperson, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	17	1/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3917			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
12,000			EECO 1500 , EMCO Electronics		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: GARYS CONOCO SERVICE
2125 S HIGGINS AVE
MISSOULA, MT 59801 MISSOULA

Contact: Gary Little, (406) 542-0121

Sys Fac ID: 32-10053
Last Inspected On: 11/20/2014
Operating Permit Renewal Date: 1/22/2018

Owners/Operators: Gary D Little, Owner (406)-542-0121 2125 S HIGGINS AVE MISSOULA MT 59801-6760
Gary D Little, UST Class A Operator
Gary D Little, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	26	9/30/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2139			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000		11/19/2014			
9	26	9/30/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2140			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		11/19/2014			
10	26	9/30/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2141			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
3,000		11/19/2014			

Facility Summary in MISSOULA County in the City of MISSOULA

Location: FINEST OIL EASTGATE
940 E BROADWAY ST
MISSOULA, MT 59802 MISSOULA
Contact: Steve Hanson, (406) 543-6969

Sys Fac ID: 32-10284
Last Inspected On: 3/24/2016
Operating Permit Renewal Date: 9/17/2019

Owners/Operators: Finest Oil Co, Owner (406)-543-6969 PO BOX 17077
MISSOULA MT 59808-7077

James Brady, UST Class A Operator
James DeWaters, UST Class A Operator
Christopher Glasser, UST Class A Operator
Stephen Hanson, UST Class A Operator
David Peyton, UST Class A Operator
Stephen Hanson, UST Class B Operator
David Peyton, UST Class B Global Operator
John Stordahl, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	19	10/27/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1074			None	Double-Walled	Yes
Currently in Use		10/27/2007	Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
8	19	10/27/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1075			None	Double-Walled	Yes
Currently in Use		10/27/2007	Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
9	19	10/27/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1076			None	Double-Walled	Yes
Currently in Use		10/27/2007	Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: DEMAROIS, INC
3115 W BROADWAY ST
MISSOULA, MT 59808 MISSOULA
Contact: Jack DeMarois, (406) 721-4000

Sys Fac ID: 32-10552
Last Inspected On: 12/22/2015
Operating Permit Renewal Date: 1/8/2019

Owners/Operators: DeMarois Inc, Owner (406)-721-4000 PO BOX 8539
MISSOULA MT 59807-8539
Jack DeMarois, UST Class A Operator
Jack DeMarois, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	18	11/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
2188			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
4,000			TS-2000 , Incon		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: MONTANA RAIL LINK INC RAILYARD MISSOULA
101 INTERNATIONAL DR
MISSOULA, MT 59808 MISSOULA

Contact: Richard Shelley, (406) 523-1415

Sys Fac ID: 32-11226
Last Inspected On: 12/12/2014
Operating Permit Renewal Date: 3/27/2018

Owners/Operators: Montana Rail Link, Owner (406)-523-1415 PO BOX 16930 MISSOULA MT 59808-6930
Richard Shelley, UST Class A Operator
Richard Shelley, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	11/1/1990	Unknown	Steel	
3872	Yes		None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		9/23/2014	Not Listed	MLLD Line Tightness Testing	
30,000		9/24/2014			

Facility Summary in MISSOULA County in the City of MISSOULA

Location: COMMUNITY MEDICAL CENTER
2827 FORT MISSOULA RD
MISSOULA, MT 59804 MISSOULA

Contact: Kris Schallock, (406) 544-2106

Sys Fac ID: 32-11740
Last Inspected On: 12/22/2014
Operating Permit Renewal Date: 3/8/2018

Owners/Operators:

RCHP Billings - Missoula LLC, Owner	(615)-844-9800	103 CONTINENTAL PLACE SUITE 200 BRENTWOOD TN 37027
Chris Colten, Operator	(406)-207-3639	2827 FORT MISSOULA RD MISSOULA MT 59804
Steve Martin, Operator		108 NEW MEADOWS DR MISSOULA MT 59808
Kris Schallock, UST Class A Operator		
Michael Wilson, UST Class A Operator		
Brian Gunderson, UST Class B Operator		
Steve Martin, UST Class B Operator		
Jeff Nixon, UST Class B Operator		
Richard Odan, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	22	7/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2353		5/29/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Diesel		12/14/2014	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000		5/29/2015	ILS-250 , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: BEACH TRANSPORTATION CO
825 MOUNT AVE
MISSOULA, MT 59801 MISSOULA

Contact: Scott Beach, (406) 549-6121

Sys Fac ID: 32-11904
Last Inspected On: 10/11/2016
Operating Permit Renewal Date: 12/21/2019

Owners/Operators: Beach Transportation, Owner (406)-549-6121 825 MOUNT AVE MISSOULA MT 59801-5687

Scott R Beach, UST Class A Operator
Carlin Cavill, UST Class A Operator
Carlin Cavill, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	19	9/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2361		10/11/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: TOWN PUMP INC MISSOULA 3
2210 N RESERVE ST
MISSOULA, MT 59808 MISSOULA
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 32-13172
Last Inspected On: 1/14/2016
Operating Permit Renewal Date: 5/14/2019

Owners/Operators: Town Pump of Northwest Missoula Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000
Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2559			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		9/22/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2560			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		9/22/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2561			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		9/30/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: TOWN PUMP INC MISSOULA 3
2210 N RESERVE ST
MISSOULA, MT 59808 MISSOULA

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 32-13172
Last Inspected On: 1/14/2016
Operating Permit Renewal Date: 5/14/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2562			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		9/30/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2563			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		9/30/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: TOWN PUMP INC MISSOULA 1
5310 GRANT CREEK RD
MISSOULA, MT 59808 MISSOULA
Contact: Doug Dodge, (406) 497-6700

Sys Fac ID: 32-13336
Last Inspected On: 6/20/2016
Operating Permit Renewal Date: 8/2/2019

Owners/Operators: Missoula Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	12/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2342			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/16/2013	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	22	12/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2343			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/16/2013	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	22	12/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2344			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/16/2013	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: TOWN PUMP INC MISSOULA 1
5310 GRANT CREEK RD
MISSOULA, MT 59808 MISSOULA
Contact: Doug Dodge, (406) 497-6700

Sys Fac ID: 32-13336
Last Inspected On: 6/20/2016
Operating Permit Renewal Date: 8/2/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	22	12/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2345			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/16/2013	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	07	1/25/2009	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5196			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/11/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
6	07	1/25/2009	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5197			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/11/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in MISSOULA County in the City of MISSOULA

Location: PROVIDENCE CENTER
900 N ORANGE ST
MISSOULA, MT 59802 MISSOULA
Contact: Tim Chopp, (406) 329-5731

Sys Fac ID: 32-13405
Last Inspected On: 1/27/2015
Operating Permit Renewal Date: 4/3/2018

Owners/Operators: Saint Patricks Hospital, Owner (406)-543-7271 500 W BROADWAY ST MISSOULA MT 59802-4096

Timothy Chopp, UST Class A Operator
Timothy Chopp, UST Class B Operator
Harry McGuire, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	8/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
1960			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
2,500		9/24/2014	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: SORENSEN TRANSPORT
6575 US HIGHWAY 10 W
MISSOULA, MT 59808 MISSOULA

Contact: Lane Sorensen, (406) 721-5404

Sys Fac ID: 32-13428
Last Inspected On: 9/4/2015
Operating Permit Renewal Date: 10/15/2018

Owners/Operators: Sorensen Transport, Owner (406)-721-5404 6575 HWY 10 W MISSOULA MT 59808
Lane Sorensen, UST Class A Operator
Lane Sorensen, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	01	6/4/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5576		5/19/2015	Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
20,000		6/3/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing, Not Listed	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: PS MINI MART
930 N RUSSELL ST
MISSOULA, MT 59801 MISSOULA

Contact: Scott Denning, (406) 880-7272

Sys Fac ID: 32-13472
Last Inspected On: 8/6/2014
Operating Permit Renewal Date: 1/6/2018

Owners/Operators:

Christine Denning, Owner	(406)-880-7272	930 N RUSSELL ST MISSOULA MT 59808
Richard Denning, Owner	(406)-880-7272	930 N RUSSELL ST MISSOULA MT 59808
CR CO LLC dba PS Mini Mart, Operator	(406)-880-0100	930 N RUSSELL ST MISSOULA MT 59808
Scott Denning, UST Class A Operator		
Steven H Schmidt, UST Class A Operator		
Richard Denning, UST Class B Global Operator		
Rico Pagauini, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	6/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1451			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/4/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		8/6/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	22	6/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1452			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/4/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		8/6/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	22	6/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1450			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/4/2011	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		8/6/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: WESTFIELD MISSOULA
8448 US HIGHWAY 10 W
MISSOULA, MT 59808 MISSOULA
Contact: Steve L Hanson, (406) 543-6969

Sys Fac ID: 32-13674
Last Inspected On: 7/17/2014
Operating Permit Renewal Date: 7/22/2017

Owners/Operators: Finest Oil Co, Owner (406)-543-6969 PO BOX 17077
MISSOULA MT 59808-7077

James Brady, UST Class A Operator
James DeWaters, UST Class A Operator
Christopher Glasser, UST Class A Operator
Stephen Hanson, UST Class A Operator
David Peyton, UST Class A Operator
Stephen Hanson, UST Class B Operator
David Peyton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	12/1/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1077			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/18/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	20	12/1/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1078			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/18/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	20	12/1/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1079			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/18/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: WESTFIELD MISSOULA
8448 US HIGHWAY 10 W
MISSOULA, MT 59808 MISSOULA
Contact: Steve L Hanson, (406) 543-6969

Sys Fac ID: 32-13674
Last Inspected On: 7/17/2014
Operating Permit Renewal Date: 7/22/2017

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
4	20	12/1/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1080			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/18/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	20	12/1/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1081			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/18/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	20	12/1/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1082			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/18/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: SILVER SLIPPER
4055 HWY 93 SOUTH 4055 BROOKS ST
MISSOULA, MT 59804 MISSOULA

Contact: Noah Castle, (406) 251-5402

Sys Fac ID: 32-13711
Last Inspected On: 6/4/2015
Operating Permit Renewal Date:

Owners/Operators: Noah Castle, Owner (406)-251-7266 4055 BROOKS ST MISSOULA MT 59804

PRESLYN LLC, Owner (406)-251-5402 3615 JACK DR MISSOULA MT 59803

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	3/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3251			Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
15,000					
2	20	3/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3252			Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
15,000					
3	20	3/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3253			Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
5,000					

Facility Summary in MISSOULA County in the City of MISSOULA

Location: TOWN PUMP INC MISSOULA 8
3420 MULLAN RD STE A
MISSOULA, MT 59808 MISSOULA
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-13823
Last Inspected On: 6/22/2015
Operating Permit Renewal Date: 10/1/2018

Owners/Operators: Montana Town Pump Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000
Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	8/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1444		5/4/2016	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		5/5/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	19	8/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1445		5/4/2016	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		5/18/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	19	8/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1446		5/4/2016	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		5/17/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: TOWN PUMP INC MISSOULA 8
3420 MULLAN RD STE A
MISSOULA, MT 59808 MISSOULA

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-13823
Last Inspected On: 6/22/2015
Operating Permit Renewal Date: 10/1/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	00	5/24/2016	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5629		5/4/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000		5/18/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in MISSOULA County in the City of MISSOULA

Location: FAST TRIP CONOCO
2730 S RESERVE ST
MISSOULA, MT 59801 MISSOULA
Contact: Rollie Worster, (406) 829-9000

Sys Fac ID: 56-13914
Last Inspected On: 1/8/2016
Operating Permit Renewal Date: 7/2/2019

Owners/Operators: Scott Worster, Owner
2730 S RESERVE ST
MISSOULA MT 59801-7641

Deb Privett, UST Class A Operator
Debbie Macy, UST Class B Operator
Deb Privett, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	17	8/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4913			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		10/13/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	17	8/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4914			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		10/13/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	17	8/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4915			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		10/8/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: MISSOULA COUNTY DETENTION CENTER
2340 MULLAN RD
MISSOULA, MT 59808 MISSOULA

Contact: Robert Schieder, (406) 829-4000

Sys Fac ID: 56-13921
Last Inspected On: 10/5/2016
Operating Permit Renewal Date: 12/12/2019

Owners/Operators: Missoula County Detention Center, Owner (406)-829-4000 WES TANNER
2340 MULLAN RD
MISSOULA MT 59808-1830

John Carlson, UST Class A Operator
Raymond Anthony, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	17	6/1/1999	Unknown	Copper	High Level Alarm
3774	Yes	10/5/2016	Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor, Not Listed	
3,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in MISSOULA County in the City of MISSOULA

Location: COSTCO WHOLESALE FUELING FACILITY
3220 N RESERVE ST
MISSOULA, MT 59808 MISSOULA

Contact: David Rogers, (425) 313-8100

Sys Fac ID: 56-13977
Last Inspected On: 12/21/2015
Operating Permit Renewal Date: 2/15/2019

Owners/Operators:

Costco Wholesale, Owner	(425)-313-8100	ATTN: LICENSING PO BOX 35005 SEATTLE WA 98124-8990
David Rogers, Operator	(425)-313-8100	999 LAKE DRIVE ISSAQUAH WA 98027

Roy Allen, UST Class A Operator
Dennis Bock, UST Class A Operator
Jason Cocke, UST Class A Operator
Dan Martinez, UST Class A Operator
Wayne Rhoades, UST Class A Operator
Michael Schaeffer, UST Class A Operator
Rodney Svilar, UST Class A Operator
Shawn Willis, UST Class A Operator
Jason Cocke, UST Class B Operator
Brett G Smith, UST Class B Operator
Shawn Willis, UST Class B Operator
Dennis Bock, UST Class B Global Operator
Jason Cocke, UST Class B Global Operator
Michael Schaeffer, UST Class B Global Operator
Shawn Willis, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	16	5/15/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4189			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		11/16/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: COSTCO WHOLESALE FUELING FACILITY
3220 N RESERVE ST
MISSOULA, MT 59808 MISSOULA

Contact: David Rogers, (425) 313-8100

Sys Fac ID: 56-13977
Last Inspected On: 12/21/2015
Operating Permit Renewal Date: 2/15/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	16	5/15/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4190			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		11/16/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	16	5/15/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4191			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		11/16/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	05	8/1/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
5283			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Hazardous Substance			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
1,500		11/16/2015	TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in MISSOULA County in the City of MISSOULA

Location: LITHIA AUTO CENTER
EXPRESSWAY LN & AIRWAY BLVD
MISSOULA, MT 59808 MISSOULA

Contact: Chad Chandler, (406) 721-5000

Sys Fac ID: 56-14004
Last Inspected On: 8/1/2016
Operating Permit Renewal Date:

Owners/Operators: Lithia Chrysler Dodge of Missoula, Owner (406)-721-5000 5001 GRIZZLY CT MISSOULA MT 59808-8672
Betty Johnson, UST Class A Operator
Betty Johnson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4359			None	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000					
2	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4360			None	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000					

Facility Summary in MISSOULA County in the City of MISSOULA

Location: SPRINT MISSOULA POP
2515 RAILROAD ST W
MISSOULA, MT 59808 MISSOULA

Contact: Sara Cullen-Crafton, (913) 315-8624

Sys Fac ID: 56-14010
Last Inspected On: 2/18/2014
Operating Permit Renewal Date: 8/12/2017

Owners/Operators: Sprint Communications Co LLP, Owner (913)-762-5957 PO BOX 7994
SHAWNEE MISSION KS 66251-6106

Brian Wiedower, UST Class A Operator
Scott Hallesy, UST Class B Operator
Nikki Lattin, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4321			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,500		2/18/2014			

Facility Summary in MISSOULA County in the City of MISSOULA

Location: MISSOULA FRESH MARKET #3416
3801 S RESERVE ST
MISSOULA, MT 59801 MISSOULA

Contact: Ron Ramshacher, (406) 251-3072

Sys Fac ID: 56-14025
Last Inspected On: 7/27/2016
Operating Permit Renewal Date: 1/4/2020

Owners/Operators: Missoula Fresh Market LLC, Owner/Operator (406)-251-7170 2520 39TH ST MISSOULA MT 59803

Shari Goodmanson, UST Class A Operator
Aaron Nelson, UST Class A Operator
Lynn Pehrson, UST Class A Operator
Betty Heidrick, UST Class B Operator
Shari Goodmanson, UST Class B Global Operator
Allen Trimp, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	15	9/1/2001	Steel Clad	Flexible Plastic	High Level Alarm, Ball Float Valve
4416			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	15	9/1/2001	Steel Clad	Flexible Plastic	High Level Alarm, Ball Float Valve
4417			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	15	9/1/2001	Steel Clad	Flexible Plastic	High Level Alarm, Ball Float Valve
4418			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: KARL TYLER CHEVROLET INC N RESERVE
3663 N RESERVE ST
MISSOULA, MT 59808 MISSOULA
Contact: Todd Rust, (406) 721-2438

Sys Fac ID: 56-14056
Last Inspected On: 4/29/2014
Operating Permit Renewal Date: 9/10/2017

Owners/Operators: Karl Tyler Chevrolet Inc, Owner (406)-721-2438 PO BOX 16025
MISSOULA MT 59808-6025
Terry Hedrick, UST Class A Operator
Terry Hedrick, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	14	7/30/2002	Concrete	Flexible Plastic	High Level Alarm
4699	Yes	10/21/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Waste Oil			Deferred	Continuous Interstitial Monitor	
10,000					
2	14	7/22/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4695		10/21/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000					
3	14	7/22/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4696		10/21/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000					

Facility Summary in MISSOULA County in the City of MISSOULA

Location: AIRWAY FLEET FUEL
5355 W HARRIER
MISSOULA, MT 59808 MISSOULA
Contact: Steve Hanson, (406) 543-6969

Sys Fac ID: 56-14133
Last Inspected On: 9/1/2016
Operating Permit Renewal Date: 2/18/2020

Owners/Operators: Finest Oil Co, Owner (406)-543-6969 PO BOX 17077
MISSOULA MT 59808-7077

James Brady, UST Class A Operator
James DeWaters, UST Class A Operator
Christopher Glasser, UST Class A Operator
Stephen Hanson, UST Class A Operator
David Peyton, UST Class A Operator
John Stordahl, UST Class A Operator
Stephen Hanson, UST Class B Operator
David Peyton, UST Class B Global Operator
John Stordahl, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	11	4/5/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4904			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		6/12/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	11	4/5/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4905			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		6/12/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	11	4/5/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4906			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		6/12/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: AIRWAY FLEET FUEL
5355 W HARRIER
MISSOULA, MT 59808 MISSOULA

Contact: Steve Hanson, (406) 543-6969

Sys Fac ID: 56-14133
Last Inspected On: 9/1/2016
Operating Permit Renewal Date: 2/18/2020

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	11	4/5/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4907			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
25,000		6/12/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	11	4/5/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5038			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		6/12/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: DEANOS TRAVEL PLAZA II
5318 W HARRIER
MISSOULA, MT 59801 MISSOULA

Contact: Dean Clinkenbeard, (406) 728-6052

Sys Fac ID: 60-15010
Last Inspected On: 2/12/2015
Operating Permit Renewal Date: 4/27/2018

Owners/Operators: DC Petroleum Inc, Owner (406)-728-6052 PO BOX 16085
MISSOULA MT 59808-6085

Dean Clinkenbeard, UST Class A Operator
Sheri Taylor, UST Class A Operator
Sheri Taylor, UST Class B Operator
Dean Clinkenbeard, UST Class B Global Operator
Robert Taylor, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	10	1/17/2006	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5027			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	10	1/17/2006	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5028			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	10	1/17/2006	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5029			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of MISSOULA

Location: MISSOULA FRESH MARKET #3417
800 W BROADWAY
MISSOULA, MT 59802 MISSOULA

Contact: Ron Ramshucher, (406) 239-4846

Sys Fac ID: 60-15098
Last Inspected On: 4/10/2015
Operating Permit Renewal Date: 6/11/2018

Owners/Operators:

Aaron Nelson, Operator	(425)-201-6301	1121 124TH AVE NE BELLEVUE WA 98005-2101
Missoula Fresh Market LLC, Owner/Operator	(406)-251-7170	2520 39TH ST MISSOULA MT 59803

Shari Goodmanson, UST Class A Operator
Aaron Nelson, UST Class A Operator
Lynn Pehrson, UST Class A Operator
Shari Goodmanson, UST Class B Global Operator
Cathie Hinds, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	08	8/8/2008	Steel Clad	Flexible Plastic	High Level Alarm
5167			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
2	08	8/1/2008	Steel Clad	Flexible Plastic	High Level Alarm
5168			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
3	08	8/1/2008	Steel Clad	Flexible Plastic	High Level Alarm
5169			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in MISSOULA County in the City of MISSOULA

Location: TOWN PUMP MISSOULA #7
8745 HWY 93 N
MISSOULA, MT 59801 MISSOULA

Contact: Biggers Trent, (406) 497-6900

Sys Fac ID: 60-15158
Last Inspected On: 11/2/2015
Operating Permit Renewal Date: 2/21/2019

Owners/Operators:

Polson-Ronan Casino Inc, Owner	(406)-497-6900	PO BOX 6000 BUTTE MT 59702
Town Pump Inc, Owner	(406)-497-6700	PO BOX 6000 BUTTE MT 59702-2534

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	06	9/1/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5256			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
2	06	9/1/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5257			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
3	06	9/1/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5258			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
25,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in MISSOULA County in the City of MISSOULA

Location: TOWN PUMP MISSOULA #7
8745 HWY 93 N
MISSOULA, MT 59801 MISSOULA

Contact: Biggers Trent, (406) 497-6900

Sys Fac ID: 60-15158
Last Inspected On: 11/2/2015
Operating Permit Renewal Date: 2/21/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
4	06	9/1/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5259			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
5	06	9/1/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5260			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
8,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
6	06	9/1/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5261			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
15,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
7	06	9/1/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5262			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in MISSOULA County in the City of MISSOULA

Location: TOWN PUMP MISSOULA #7
8745 HWY 93 N
MISSOULA, MT 59801 MISSOULA
Contact: Biggers Trent, (406) 497-6900

Sys Fac ID: 60-15158
Last Inspected On: 11/2/2015
Operating Permit Renewal Date: 2/21/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	06	9/1/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5331			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
6,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in MISSOULA County in the City of MISSOULA

Location: DECKER TRUCK LINE INC
8350 OLD HWY 10
MISSOULA, MT 59808 MISSOULA

Sys Fac ID: 60-15231
Last Inspected On: 7/17/2014
Operating Permit Renewal Date: 9/1/2017

Contact:

Owners/Operators: Decker Truck Line Inc, Owner (515)-576-4141 4000 5TH AVE S
FORT DODGE IA 50501

Liam Lederer, UST Class A Operator
Cory Jelletich, UST Class B Global Operator
Liam Lederer, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	02	3/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5438		4/4/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in MISSOULA County in the City of SEELEY LAKE

Location: LINDEYS LANDING WEST SPB
MT HIGHWAY 83
SEELEY LAKE, MT 59868 MISSOULA

Contact: Mike Lindemer, (406) 677-9229

Sys Fac ID: 32-05837
Last Inspected On: 8/28/2014
Operating Permit Renewal Date: 10/17/2017

Owners/Operators: Lindeys Inc, Owner (406)-677-9229 PO BOX 791
SEELEY LAKE MT 59868-0791

Michael Lindemer, UST Class A Operator
Michael Lindemer, UST Class B Operator
Tanner Stevenson, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	17	5/1/1999	Concrete	Flexible Plastic	High Level Alarm
4104	Yes	8/28/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
1,500			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MISSOULA County in the City of SEELEY LAKE

Location: SEELEY LAKE CONVENIENCE STORE
MT HIGHWAY 83
SEELEY LAKE, MT 59868 MISSOULA

Contact: Norman Baier, (406) 677-2004

Sys Fac ID: 32-09288
Last Inspected On: 12/17/2014
Operating Permit Renewal Date: 3/13/2018

Owners/Operators: Norman W & M Rose Baier, Owner (406)-677-2004 PO BOX 87
SEELEY LAKE MT 59868-0087

Norman Baier, UST Class A Operator
Rose Baier, UST Class A Operator
Norman Baier, UST Class B Operator
Rose Baier, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	4/22/1987	Concrete	Fiberglass Reinforced Plastic	Ball Float Valve
418	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
8,000		12/15/2014			
2	29	4/22/1987	Concrete	Fiberglass Reinforced Plastic	Ball Float Valve
417	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
8,000		12/15/2014			
3	29	4/22/1987	Concrete	Fiberglass Reinforced Plastic	Ball Float Valve
416	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
8,000		12/15/2014			

Facility Summary in MISSOULA County in the City of SEELEY LAKE

Location: ROVEROS
3182 HWY 83
SEELEY LAKE, MT 59868 MISSOULA
Contact: Scafer Karly, (406) 396-2206

Sys Fac ID: 60-15146
Last Inspected On: 12/10/2013
Operating Permit Renewal Date: 1/28/2017

Owners/Operators: Tabish Brothers Distributors Inc, Owner (406)-543-7621 GW PETROLEUM
PO BOX 8448
MISSOULA MT 59807-8448

Pat Mitchell, UST Class A Operator
Kyle Marx, UST Class B Global Operator
Pat Mitchell, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	4/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3340			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000					
2	21	4/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3341			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000					
3	21	4/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3342			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Kerosene			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000					
4	21	4/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3343			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Kerosene			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
2,000					

Facility Summary in MISSOULA County in the City of SEELEY LAKE

Location: ROVEROS
3182 HWY 83
SEELEY LAKE, MT 59868 MISSOULA

Contact: Scafer Karly, (406) 396-2206

Sys Fac ID: 60-15146
Last Inspected On: 12/10/2013
Operating Permit Renewal Date: 1/28/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	21	4/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3337			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
7,000					
12	21	4/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3338			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000					
13	21	4/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3339			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000					

Facility Summary in MISSOULA County in the City of WYE

Location: MISSOULA TRAVEL CENTER
8018 US HIGHWAY 93 N
WYE, MT 59808 MISSOULA

Contact: Kelly Gelske, (440) 808-7406

Sys Fac ID: 32-02822
Last Inspected On: 7/15/2014
Operating Permit Renewal Date: 10/31/2017

Owners/Operators: TA Operating LLC, Owner/Operator (440)-808-7406 24601 CENTER RIDGE RD
WESTLAKE OH 44145

Krista Andrews, UST Class A Operator
David R Campbell, UST Class A Operator
Richard Fargher, UST Class A Operator
Kelly Gelske, UST Class A Operator
Greg Goodwin, UST Class A Operator
William Homsley, UST Class A Operator
Alex Hoskinson, UST Class A Operator
Chris Johnson, UST Class A Operator
Kimberly S Komar, UST Class A Operator
Joshua Matlock, UST Class A Operator
Scott Serfling, UST Class A Operator
Justin Spicer, UST Class A Operator
Krista Andrews, UST Class B Operator
Keith Dowling, UST Class B Operator
Alex Hoskinson, UST Class B Operator
Chris Johnson, UST Class B Operator
Joshua Matlock, UST Class B Operator
Michael Mueller, UST Class B Operator
Callie Leigh Olson, UST Class B Operator
Richard Fargher, UST Class B Global Operator
Kelly Gelske, UST Class B Global Operator
Greg Goodwin, UST Class B Global Operator
William Homsley, UST Class B Global Operator
Kimberly S Komar, UST Class B Global Operator
Scott Serfling, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**

Facility Summary in MISSOULA County in the City of WYE

Location: MISSOULA TRAVEL CENTER
8018 US HIGHWAY 93 N
WYE, MT 59808 MISSOULA
Contact: Kelly Gelske, (440) 808-7406

Sys Fac ID: 32-02822
Last Inspected On: 7/15/2014
Operating Permit Renewal Date: 10/31/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	11/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
789		8/18/2014	None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/24/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		8/4/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	23	11/1/1993	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
790		8/18/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/24/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		9/14/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	23	11/1/1993	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
791		8/18/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/24/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		9/14/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	38	2/17/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
786		8/18/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		9/24/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		8/4/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	38	2/17/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
787		8/18/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		9/24/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		9/14/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in MISSOULA County in the City of WYE

Location: MISSOULA TRAVEL CENTER
8018 US HIGHWAY 93 N
WYE, MT 59808 MISSOULA
Contact: Kelly Gelske, (440) 808-7406

Sys Fac ID: 32-02822
Last Inspected On: 7/15/2014
Operating Permit Renewal Date: 10/31/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	38	2/17/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
785		8/18/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		9/24/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		9/14/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	23	11/1/1993	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
788		8/18/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/24/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		9/14/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
14	01	2/24/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Auto Limiter
5550		10/16/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Oil Substance			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
8,000		3/12/2015	TLS-300 , Veeder Root	Continuous Interstitial Monitor, Not Listed	
15	01	2/24/2015	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5551		10/16/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Oil Substance			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
4,000		3/12/2015	TLS-300 , Veeder Root	Continuous Interstitial Monitor, Not Listed	

Facility Summary in MUSSELSHELL County in the City of MELSTONE

Location: JAKES GARAGE
221 US HIGHWAY 12
MELSTONE, MT 59054 MUSSELSHELL

Contact: Larry Zaharko, (406) 358-2389

Sys Fac ID: 33-01481
Last Inspected On: 12/22/2015
Operating Permit Renewal Date: 3/30/2019

Owners/Operators: Jakes Garage Inc, Owner (406)-358-2389 221 US HIGHWAY 12 MELSTONE MT 59054

Tim DeJaegher, UST Class A Operator
Larry Zaharko, UST Class A Operator
Tim DeJaegher, UST Class B Operator
Larry Zaharko, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	17	12/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3770			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		1/4/2013	Manual Interstitial Monitor	Deferred	
3,750					
9	17	12/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3771			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		1/4/2013	Manual Interstitial Monitor	Deferred	
2,250					

Facility Summary in MUSSELSHELL County in the City of ROUNDUP

Location: WELLS FARGO BANK ROUNDUP
12 MAIN ST
ROUNDUP, MT 59072 MUSSELSHELL

Contact: Joe Eckhardt, (406) 323-2000

Sys Fac ID: 33-02079
Last Inspected On: 10/28/2016
Operating Permit Renewal Date: 12/28/2019

Owners/Operators: Wells Fargo Bank Roundup, Owner (406)-323-2000 12 MAIN ST ROUNDUP MT 59072-2828
Chris Anderson, UST Class A Operator
Chris Anderson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	10/6/1993	Cathodically Protected Steel	Copper	Flapper Valve (Auto Shutoff)
3495		10/28/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil		10/28/2016	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,000			TLS-300 , Veeder Root		

Facility Summary in MUSSELSHELL County in the City of ROUNDUP

Location: CONOCO CONVENIENCE CENTER
806 MAIN ST
ROUNDUP, MT 59072 MUSSELSHELL

Contact: Terry Watkins, (406) 323-1108

Sys Fac ID: 33-05030
Last Inspected On: 9/9/2016
Operating Permit Renewal Date: 12/14/2019

Owners/Operators: McCleary Distributing Inc, Owner (406)-323-1108 PO BOX 406
ROUNDUP MT 59072-0406

Terry Watkins, UST Class A Operator
Terry Watkins, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	10/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1594		8/26/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		8/22/2014	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000		11/9/2011	TLS-350/Gilbarco EMC , Veeder Root		
2	27	8/30/1989	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1592			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		8/22/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		9/9/2016	TLS-350/Gilbarco EMC , Veeder Root		
3	24	9/1/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1593			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		8/22/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		9/9/2016	TLS-350/Gilbarco EMC , Veeder Root		
4	27	8/30/1989	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1591			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		8/22/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		9/9/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MUSSELSHELL County in the City of ROUNDUP

Location: CONOCO CONVENIENCE CENTER
806 MAIN ST
ROUNDUP, MT 59072 MUSSELSHELL
Contact: Terry Watkins, (406) 323-1108

Sys Fac ID: 33-05030
Last Inspected On: 9/9/2016
Operating Permit Renewal Date: 12/14/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	20	10/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1595		8/26/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		8/22/2014	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,000		9/7/2010	TLS-350/Gilbarco EMC , Veeder Root		
11	20	10/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1596		8/26/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		8/22/2014	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000		9/7/2010	TLS-350/Gilbarco EMC , Veeder Root		
12	20	10/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1597		8/26/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		8/22/2014	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,000		9/7/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MUSSELSHELL County in the City of ROUNDUP

Location: EXPRESS CENTER CONVENIENCE STORE
701 1ST AVE W
ROUNDUP, MT 59072 MUSSELSHELL
Contact: Rachel McCord, (406) 323-3443

Sys Fac ID: 33-06612
Last Inspected On: 7/5/2016
Operating Permit Renewal Date: 9/10/2019

Owners/Operators: Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756 BILLINGS MT 59103-1756
Mykel Stockton, UST Class A Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Mykel Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	3/26/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3757			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/17/2014	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		8/29/2011	TLS-350/Gilbarco EMC , Veeder Root		
2	31	3/26/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3758			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/17/2014	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
3	31	3/26/1985	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3759			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Not Applicable
Gasoline		12/17/2014	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		7/15/2011	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in MUSSELSHELL County in the City of ROUNDUP

Location: EXPRESS CENTER CONVENIENCE STORE
701 1ST AVE W
ROUNDUP, MT 59072 MUSSELSHELL

Contact: Rachel McCord, (406) 323-3443

Sys Fac ID: 33-06612
Last Inspected On: 7/5/2016
Operating Permit Renewal Date: 9/10/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	10/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1985			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Diesel		12/12/2011	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco		
5	18	10/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1986			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Diesel		12/12/2011	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
5,000			TLS-350/Gilbarco EMC , Veeder Root		
6	18	10/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1987			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Diesel		12/12/2011	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in PARK County in the City of CLYDE PARK

Location: DALES FUEL INC
301 1ST AVE
CLYDE PARK, MT 59018 PARK

Contact: Dale Jones, (406) 686-4681

Sys Fac ID: 34-07600
Last Inspected On: 2/26/2016
Operating Permit Renewal Date: 6/15/2019

Owners/Operators:

Dales Fuel Inc, Owner	(406)-686-4681	PO BOX 90 CLYDE PARK MT 59018
Dale Jones, Operator	(406)-686-4681	PO BOX 90 CLYDE PARK MT 59018-0090

Dale Jones, UST Class A Operator
Dennis A Franks, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	17	4/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3991			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Manual Interstitial Monitor	Deferred	
6,000					
6	17	4/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3992			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Manual Interstitial Monitor	Deferred	
2,500					
7	17	4/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3993			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Interstitial Monitor	Deferred	
1,900					
8	17	4/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3994			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Interstitial Monitor	Deferred	
1,900					

Facility Summary in PARK County in the City of CLYDE PARK

Location: SHIELDS VALLEY HIGH SCHOOL
401 1ST ST E
CLYDE PARK, MT 59018 PARK

Contact: Bill Sarrazin, (406) 686-4621

Sys Fac ID: 34-12515
Last Inspected On: 2/16/2016
Operating Permit Renewal Date: 3/1/2019

Owners/Operators: School Dist Shields Valley, Owner (406)-578-2176 PO BOX 131
WILSALL MT 59086-0131

Dennis Kuhl, UST Class A Operator
Randy Russell, UST Class A Operator
William Sarrazin, UST Class A Operator
Darcy Street, UST Class A Operator
Dennis Kuhl, UST Class B Operator
Randy Russell, UST Class B Operator
Darcy Street, UST Class B Operator
Tom Johnson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	51	7/1/1965	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
2725			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		2/16/2016	Automatic Tank Gauging 0.2	Deferred	
8,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in PARK County in the City of COOKE CITY

Location: COOKE CITY EXXON
US HIGHWAY 212
COOKE CITY, MT 59020 PARK
Contact: Rick D Sommers, (406) 838-2244

Sys Fac ID: 34-01584
Last Inspected On: 6/8/2016
Operating Permit Renewal Date: 9/17/2019

Owners/Operators: Rick D Sommers, Owner (406)-838-2244 PO BOX 1128
COOKE CITY MT 59020-1128

Lucas Jack, UST Class A Operator
Marlo Pmarlof, UST Class A Operator
Rick D Sommers, UST Class A Operator
Lucas Jack, UST Class B Global Operator
Rick D Sommers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	25	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
757			None	None	Yes
Currently in Use		10/1/2001	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/8/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
8	25	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
758			None	None	Yes
Currently in Use		10/1/2001	Not Required	Safe Suction	Galvanic
Gasoline		6/8/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
9	19	10/1/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
759			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		6/8/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in PARK County in the City of COOKE CITY

Location: COOKE CITY EXXON
US HIGHWAY 212
COOKE CITY, MT 59020 PARK

Contact: Rick D Sommers, (406) 838-2244

Sys Fac ID: 34-01584
Last Inspected On: 6/8/2016
Operating Permit Renewal Date: 9/17/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	19	10/1/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
760			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/8/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in PARK County in the City of COOKE CITY

Location: NORTHEAST ENTRANCE GAS PUMPS

COOKE CITY, MT 59020 PARK

Contact: Tim Hudson, (307) 344-7381

Sys Fac ID: 34-08869
Last Inspected On: 6/2/2016
Operating Permit Renewal Date: 9/26/2019

Owners/Operators: National Park Service, Owner (307)-344-2333 PO BOX 168
YELLOWSTONE NATIONAL PARK WY 82190-0168

Harry Laney, UST Class A Operator
Claude W Long, UST Class A Operator
Harry Laney, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	8/1/1992	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1741			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		5/15/2016	Continuous Interstitial Monitor	Deferred	
2,000			EECO 1000 , EMCO Electronics		
2	24	8/1/1992	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1742			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		5/15/2016	Continuous Interstitial Monitor	Deferred	
2,000			EECO 1000 , EMCO Electronics		

Facility Summary in PARK County in the City of COOKE CITY

Location: COOKE CITY SINCLAIR AND CABINS
115 MAIN ST
COOKE CITY, MT 59020 PARK

Contact: Lucas Jack, (406) 838-2000

Sys Fac ID: 34-10046
Last Inspected On: 6/8/2016
Operating Permit Renewal Date: 9/17/2019

Owners/Operators: Rick D Sommers, Owner (406)-838-2244 PO BOX 1128
COOKE CITY MT 59020-1128

Lucas Jack, UST Class A Operator
Rick D Sommers, UST Class A Operator
Lucas Jack, UST Class B Global Operator
Rick D Sommers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	18	10/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3670			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Manual Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			ILS-350 , Veeder Root	Continuous Interstitial Monitor	
7	18	10/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3671			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Manual Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			ILS-350 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in PARK County in the City of EMIGRANT

Location: EMIGRANT GENERAL STORE
3 MURPHY LN
EMIGRANT, MT 59027 PARK
Contact: Bert Otis, (406) 333-4434

Sys Fac ID: 34-06713
Last Inspected On: 5/13/2016
Operating Permit Renewal Date: 7/8/2019

Owners/Operators: Bert Otis, Owner (406)-333-4434 EMIGRANT GENERAL STORE
PO BOX 60
EMIGRANT MT 59027-0060

Bert Otis, UST Class A Operator
Bert Otis, UST Class B Operator
Jason Otis, UST Class B Operator
Josh Otis, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	27	9/1/1989	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4351			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/13/2016	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing	
6,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
5	19	1/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4352			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/13/2016	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing	
10,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
6	27	9/1/1989	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4353			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/13/2016	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing	
6,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in PARK County in the City of EMIGRANT

Location: COMMUNITY CONTINUITY INC
18 POLARIS WAY PARCEL 70 S GLASTONBURY
EMIGRANT, MT 59027 PARK

Contact: Walter Wunsch, (406) 333-4727

Sys Fac ID: 34-10930
Last Inspected On: 9/25/2014
Operating Permit Renewal Date: 10/2/2017

Owners/Operators: Community Continuity Inc, Owner (406)-333-4727 PO BOX 135
EMIGRANT MT 59027-0135

Daniel Kehoe Jr, UST Class A Operator
Daniel Kehoe Jr, UST Class B Operator
Dennis A Franks, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	2/1/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4821		9/25/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Galvanic
Diesel		9/25/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
20,000			TLS-300 , Veeder Root		

Facility Summary in PARK County in the City of EMIGRANT

Location: COMMUNITY RESTORATION INC
HERCULES ROAD & POLARIS WAY
EMIGRANT, MT 59027 PARK

Contact: Daniel Kehoe Jr, (800) 631-8885

Sys Fac ID: 34-10931
Last Inspected On: 9/25/2014
Operating Permit Renewal Date: 10/2/2017

Owners/Operators: Community Restoration Inc, Owner (800)-631-8885 PO BOX 414
EMIGRANT MT 59027-0414

Daniel Kehoe Jr, UST Class A Operator
Daniel Kehoe Jr, UST Class B Operator
Dennis A Franks, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	2/20/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
701		9/25/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Diesel		9/25/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
20,000			TLS-300 , Veeder Root		

Facility Summary in PARK County in the City of EMIGRANT

Location: SHELTER INVINCIBLE INC
25 GEMINI RD
EMIGRANT, MT 59027 PARK

Contact: Eleanor Schieffelin, (406) 333-4485

Sys Fac ID: 34-10933
Last Inspected On: 5/5/2014
Operating Permit Renewal Date: 8/24/2017

Owners/Operators: Shelter Invincible Inc, Owner (406)-333-4485 PO BOX 111
EMIGRANT MT 59027-0039

David Tonkin, UST Class A Operator
David Tonkin, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	4/17/1990	Cathodically Protected Steel	Copper	Flapper Valve (Auto Shutoff)
1882			None	Secondary Containment Chase	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		5/5/2014	Automatic Tank Gauging 0.2	Deferred	
2,000				Manual Interstitial Monitor	

Facility Summary in PARK County in the City of EMIGRANT

Location: COMMUNITY CONSERVATION ASSOCIATION
2 B TAURUS RD
EMIGRANT, MT 59027 PARK

Contact: Ed Dratz, (406) 579-3399

Sys Fac ID: 34-10934
Last Inspected On: 10/5/2016
Operating Permit Renewal Date: 12/11/2019

Owners/Operators: Edward Dratz, UST Class A Operator
Edward Dratz, UST Class B Operator
Edward Dratz, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	4/18/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4684			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/5/2016	Automatic Tank Gauging 0.2	Deferred	
12,000			TLS-300 , Veeder Root		

Facility Summary in PARK County in the City of EMIGRANT

Location: B BUNK INC
PARCEL 38 N GLASTONBURY PO BOX 519
EMIGRANT, MT 59027 PARK
Contact: Brad Tisdale, (406) 333-4512

Sys Fac ID: 34-10959
Last Inspected On: 1/6/2012
Operating Permit Renewal Date: 3/26/2018

Owners/Operators: B Bunk Inc, Owner (757)-498-6060 3333 REGENT PARK WALK VIRGINIA BEACH VA 23452-6257
Bradford Tisdale, UST Class A Operator
Dennis A Franks, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	4/18/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
415			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000			TLS-300 , Veeder Root		

Facility Summary in PARK County in the City of EMIGRANT

Location: MARKS ARK INC
PARCEL #7 NORTH GLASTONBURY
EMIGRANT, MT 59027 PARK

Contact: Philip Hoag, (406) 333-4707

Sys Fac ID: 34-10960
Last Inspected On: 11/24/2014
Operating Permit Renewal Date: 1/6/2018

Owners/Operators: Marks Ark Inc, Owner (406)-333-4707 PO BOX 11
EMIGRANT MT 59027-1626

Phillip Hoag, UST Class A Operator
Phillip Hoag, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	4/11/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1579			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		11/24/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
10,000					

Facility Summary in PARK County in the City of EMIGRANT

Location: LIFESAVERS INC
LOT 28 NORTH GLASTONBURY PO BOX 56
EMIGRANT, MT 59027 PARK

Contact: Robert Smith, (406) 333-4387

Sys Fac ID: 34-10965
Last Inspected On: 2/12/2016
Operating Permit Renewal Date:

Owners/Operators: Lifesavers Inc, Owner (406)-333-4213 PO BOX 211
EMIGRANT MT 59027-0211

Patricia Jones, UST Class A Operator
Robert Smith, UST Class A Operator
Patricia Jones, UST Class B Operator
Robert Smith, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	4/1/1990	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
4499			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	Galvanic
Diesel		8/11/2014	Vapor Monitoring	Vapor Monitoring, Continuous Interstitial Monitor	
12,000					

Facility Summary in PARK County in the City of EMIGRANT

Location: EARTH HOME PROPERTIES LLC
EVENING STAR DR
EMIGRANT, MT 59027 PARK

Contact: Craig Newhouse, (978) 857-0002

Sys Fac ID: 34-10978
Last Inspected On: 6/14/2016
Operating Permit Renewal Date:

Owners/Operators:

Earth Home Properties LLC, Owner	(978)-658-7658	5 EMMA WAY WILMINGTON MA 01887
Craig Newhouse, Operator	(978)-857-0002	EARTH HOME PROPERTIES LLC 5 EMMA WAY WILMINGTON MA 01887-2745
Craig Newhouse, UST Class A Operator		
Craig Newhouse, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	4/23/1990	Cathodically Protected Steel	No Piping	Flapper Valve (Auto Shutoff)
4754			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		6/11/2016	Vapor Monitoring		
10,000					
2	26	4/23/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4753			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		6/11/2016	Vapor Monitoring	Deferred	
12,000					

Facility Summary in PARK County in the City of EMIGRANT

Location: CAPSTONE SHELTER
LOT 105 S GLASTONBURY
EMIGRANT, MT 59027 PARK

Contact: Enrico DArgenzio, (602) 463-9838

Sys Fac ID: 34-10989
Last Inspected On: 9/16/2016
Operating Permit Renewal Date: 7/17/2006

Owners/Operators: Capstone Project, Owner (480)-657-2564 14449 N 99TH ST
SCOTTSDALE AZ 85260-3835

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	4/13/1990	Cathodically Protected Steel	Steel	Positive Shutoff
4827			Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		9/16/2016	Vapor Monitoring, Continuous Interstitial Monitor	Vapor Monitoring	
12,000					

Facility Summary in PARK County in the City of EMIGRANT

Location: HELMET OF SALVATION SHELTER UST
65 ARCTURUS DR
EMIGRANT, MT 59027 PARK

Contact: Ken Mueller, (406) 333-4669

Sys Fac ID: 34-13180
Last Inspected On: 3/15/2014
Operating Permit Renewal Date: 6/30/2017

Owners/Operators: Helmet of Salvation Shelter Assoc, Owner (406)-333-4669 PO BOX 419
EMIGRANT MT 59027-0419

Kenneth Mueller Jr, UST Class A Operator
Kenneth Mueller Jr, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	20	12/1/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3123			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		3/15/2014	Stat. Inventory Reconcilitation	Not Listed	
10,000					

Facility Summary in PARK County in the City of EMIGRANT

Location: DENNIS CURTIN
70 RAMS HORN RD
EMIGRANT, MT 59027 PARK
Contact: (406) 333-4056

Sys Fac ID: 56-14035
Last Inspected On: 10/13/2016
Operating Permit Renewal Date: 12/31/2019

Owners/Operators: D M Curtin Family Limited Partnership, Owner (816)-459-7740 2860 NE KENDALLWOOD PKWY KANSAS CITY MO 64119-2026
Channell T Libbey III, UST Class A Operator
Todd Fredericksen, UST Class B Operator
Dennis A Franks, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	15	10/15/2001	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4435		10/13/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
8,000			ILS-350 , Veeder Root		

Facility Summary in PARK County in the City of GARDINER

Location: TOWN STATION
220 PARK ST
GARDINER, MT 59030 PARK
Contact: Wade Laubach, (406) 848-7501

Sys Fac ID: 34-02285
Last Inspected On: 10/5/2016
Operating Permit Renewal Date: 12/21/2019

Owners/Operators: Gardiner Town Club Inc, Owner (406)-848-7501 PO BOX 990
GARDINER MT 59030-0990

Wade Laubach, UST Class A Operator
Wade Laubach, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	40	4/29/1976	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3910			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/5/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		10/5/2016	TLS-350/Gilbarco EMC , Veeder Root		
2	40	4/29/1976	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3911			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/5/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		10/5/2016	TLS-350/Gilbarco EMC , Veeder Root		
3	40	4/29/1976	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3912			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/5/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		10/5/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in PARK County in the City of GARDINER

Location: TOWN STATION
220 PARK ST
GARDINER, MT 59030 PARK
Contact: Wade Laubach, (406) 848-7501

Sys Fac ID: 34-02285
Last Inspected On: 10/5/2016
Operating Permit Renewal Date: 12/21/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	15	1/1/2001	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4247			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		10/5/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		10/5/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in PARK County in the City of GARDINER

Location: RANCH OFFICE
558 OLD YELLOWSTONE TRAIL SOUTH
GARDINER, MT 59030 PARK

Contact: David Otis, (406) 848-9043

Sys Fac ID: 34-03402
Last Inspected On: 7/8/2014
Operating Permit Renewal Date: 9/3/2017

Owners/Operators: Church Universal & Triumphant Inc, Owner (406)-848-9200 63 SUMMIT WAY
GARDINER MT 59030-9314

David Otis, UST Class A Operator
David Otis, UST Class B Operator
Steven Zacharias, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	28	10/21/1988	Cathodically Protected Steel	Steel	High Level Alarm
1861			None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		7/8/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
20,000		7/8/2014	TLS-350/Gilbarco EMC , Veeder Root		
8	28	10/21/1988	Cathodically Protected Steel	Steel	High Level Alarm
1862			None	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		7/8/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
20,000		7/8/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in PARK County in the City of GARDINER

Location: KREMERS CENEX
401 SCOTT ST W PO BOX 507
GARDINER, MT 59030 PARK
Contact: Scott Kremer, (406) 848-7742

Sys Fac ID: 34-06531
Last Inspected On: 2/25/2015
Operating Permit Renewal Date: 3/3/2018

Owners/Operators: Kremer Brothers Inc, Owner (406)-848-7742 DBA KREMERS CENEX
PO BOX 507
GARDINER MT 59030-0507

Scott Kremer, UST Class A Operator
Scott Kremer, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	4/16/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3189			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/16/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		2/5/2015	TLS-300 , Veeder Root		
2	32	4/16/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3190			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/16/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		2/5/2015	TLS-300 , Veeder Root		
3	32	4/16/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3191			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		7/16/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		2/5/2015	TLS-300 , Veeder Root		

Facility Summary in PARK County in the City of GARDINER

Location: KREMERS CENEX
401 SCOTT ST W PO BOX 507
GARDINER, MT 59030 PARK

Contact: Scott Kremer, (406) 848-7742

Sys Fac ID: 34-06531
Last Inspected On: 2/25/2015
Operating Permit Renewal Date: 3/3/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	32	4/16/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3192			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/16/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		2/5/2015	TLS-300 , Veeder Root		

Facility Summary in PARK County in the City of GARDINER

Location: GARDINER SERVICE CENTER
US HIGHWAY 89 S
GARDINER, MT 59030 PARK

Contact: Dylan Hoffman, (307) 344-5204

Sys Fac ID: 34-08868
Last Inspected On: 5/17/2016
Operating Permit Renewal Date: 7/28/2019

Owners/Operators: Xanterra Parks & Resorts Inc, Owner/Operator (307)-344-5340 ATTN DYLAN HOFFMAN
PO BOX 165
YELLOWSTONE NATIONAL PARK WY 82190-0753

Dylan Hoffman, UST Class A Operator
Cameron Walker, UST Class A Operator
Dylan Hoffman, UST Class B Operator
Cameron Walker, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	20	4/1/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3492			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor, Deferred	
10,000			Gilbarco EMC Basic , Gilbarco		
7	20	4/1/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3493			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor, Deferred	
5,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in PARK County in the City of GARDINER

Location: GARDINER SCHOOL DIST 4
510 STONE ST
GARDINER, MT 59030 PARK

Contact: Lynn H Mavencamp, (406) 848-7563

Sys Fac ID: 34-09287
Last Inspected On: 11/24/2014
Operating Permit Renewal Date: 1/2/2018

Owners/Operators: School Dist 7 & 4 Gardiner Public, Owner (406)-848-7563 510 STONE ST GARDINER MT 59030-9378

Douglas F Coy, UST Class A Operator
Tom Nelson, UST Class A Operator
Douglas F Coy, UST Class B Operator
Tom Nelson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	29	4/24/1987	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4451		5/12/2015	None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Galvanic
Heating Oil		11/24/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in PARK County in the City of LIVINGSTON

Location: Old Holiday Gas Station
1019 W PARK ST
LIVINGSTON, MT 59047 PARK

Contact: David Amsk, (406) 222-3817

Sys Fac ID: 34-08071
Last Inspected On: 3/30/2015
Operating Permit Renewal Date:

Owners/Operators: BVA 2 LLC, Owner (406)-222-3817 120 N G ST
LIVINGSTON MT 59047

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	41	10/1/1975	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3031			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use		4/1/2008	Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/30/2015	Tank Tightness Testing, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
12,000					
2	41	10/1/1975	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3032			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use		4/1/2008	Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/30/2015	Tank Tightness Testing, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
12,000					

Facility Summary in PARK County in the City of LIVINGSTON

Location: TOWN PUMP INC LIVINGSTON 2
29 N H ST
LIVINGSTON, MT 59047 PARK

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 34-08713
Last Inspected On: 1/26/2016
Operating Permit Renewal Date: 4/2/2019

Owners/Operators: Park Casino, Owner (406)-497-6700 600 S MAIN ST BUTTE MT 59701

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	9/1/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2577			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	20	9/1/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2578			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
5	20	9/1/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2575			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in PARK County in the City of LIVINGSTON

Location: TOWN PUMP INC LIVINGSTON 2
29 N H ST
LIVINGSTON, MT 59047 PARK

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 34-08713
Last Inspected On: 1/26/2016
Operating Permit Renewal Date: 4/2/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	20	9/1/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2576			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in PARK County in the City of LIVINGSTON

Location: QWEST LIVINGSTON CENTRAL OFFICE
302 W CALLENDER ST
LIVINGSTON, MT 59047 PARK

Contact: Kevin Robison, (801) 237-3006

Sys Fac ID: 34-08777
Last Inspected On: 10/22/2014
Operating Permit Renewal Date: 3/20/2018

Owners/Operators:

Qwest Corporation, Owner	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111
Qwest Corporation, Operator	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111

Thomas J Pitts, UST Class A Operator
Kevin Robison, UST Class A Operator
Thomas J Pitts, UST Class B Operator
Kevin Robison, UST Class B Operator
Thomas J Pitts, UST Class B Global Operator
Kevin Robison, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	59	4/15/1957	Concrete	Flexible Plastic	High Level Alarm
4811	Yes		Double-Walled	None	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel		10/22/2014	Continuous Interstitial Monitor, Deferred	MLLD Line Tightness Testing	
275		12/8/2011			

Facility Summary in PARK County in the City of LIVINGSTON

Location: CASEYS #4
2050 SOUTH PARK
LIVINGSTON, MT 59047 PARK
Contact: Gary Scales, (406) 587-0702

Sys Fac ID: 34-09906
Last Inspected On: 2/23/2016
Operating Permit Renewal Date: 7/22/2019

Owners/Operators:

Story Distributing Company, Owner	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771
Jason Shanley, Operator	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771-1201

Gary Scales, UST Class A Operator
Jason Shanley, UST Class A Operator
Venus Banthem, UST Class B Operator
Jason Shanley, UST Class B Operator
Gary Scales, UST Class B Global Operator
Kelly Scott Shutes, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	18	5/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2033			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/23/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		2/23/2016	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
6	18	5/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2034			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/23/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		2/23/2016	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in PARK County in the City of LIVINGSTON

Location: CASEYS #4
2050 SOUTH PARK
LIVINGSTON, MT 59047 PARK
Contact: Gary Scales, (406) 587-0702

Sys Fac ID: 34-09906
Last Inspected On: 2/23/2016
Operating Permit Renewal Date: 7/22/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	18	5/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2035			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		2/23/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		2/23/2016	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in PARK County in the City of LIVINGSTON

Location: CITY COUNTY COMPLEX
414 E CALLENDER ST
LIVINGSTON, MT 59047 PARK

Contact: Dan Gutebier, (406) 222-4106

Sys Fac ID: 34-10573
Last Inspected On: 8/18/2016
Operating Permit Renewal Date: 10/1/2019

Owners/Operators: Park County Shop, Owner (406)-222-4106 ATTN MAINT SUPV BRUCE
414 E CALLENDER ST
LIVINGSTON MT 59047-2700

Kelly Johnson, UST Class A Operator
Kelly Johnson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	21	11/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1783			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
3,000		8/11/2016	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in PARK County in the City of LIVINGSTON

Location: YELLOWSTONE TRUCK STOP LIVINGSTON
1226 US HIGHWAY 10 W
LIVINGSTON, MT 59047 PARK

Contact: Carol Graybill, (406) 222-6180

Sys Fac ID: 34-11200
Last Inspected On: 12/12/2013
Operating Permit Renewal Date: 3/25/2017

Owners/Operators: Yellowstone Truck Stop Livingston, Owner (406)-222-2131 1226 US HIGHWAY 10 W LIVINGSTON MT 59047-9004

Jerry Graybill, UST Class A Operator
Donald Burkenpas, UST Class B Operator
Candace Egan, UST Class B Operator
Jerry Graybill, UST Class B Operator
Stacey Lofing, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	27	1/1/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2313			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/12/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					
2	27	1/1/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2314			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/12/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000					
3	27	1/1/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2315			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/12/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000					

Facility Summary in PARK County in the City of LIVINGSTON

Location: YELLOWSTONE TRUCK STOP LIVINGSTON
1226 US HIGHWAY 10 W
LIVINGSTON, MT 59047 PARK

Contact: Carol Graybill, (406) 222-6180

Sys Fac ID: 34-11200
Last Inspected On: 12/12/2013
Operating Permit Renewal Date: 3/25/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	27	1/1/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2316			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/12/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000					

Facility Summary in PARK County in the City of LIVINGSTON

Location: ZIP TRIP 47
101 CENTENNIAL DR
LIVINGSTON, MT 59047 PARK

Sys Fac ID: 34-11741
Last Inspected On: 2/24/2015
Operating Permit Renewal Date: 3/9/2018

Contact: Todd Peterson, (406) 222-7371

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Ian Johnstone, UST Class A Operator
Nicholas Merritt, UST Class A Operator
Nicholas Merritt, UST Class B Operator
Darcy Ziegler, UST Class B Operator
Nicholas Merritt, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	9/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
562			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic, Not Applicable
Gasoline		9/2/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		9/2/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	26	9/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
563			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic, Not Applicable
Gasoline		9/2/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		9/2/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in PARK County in the City of LIVINGSTON

Location: ZIP TRIP 47
101 CENTENNIAL DR
LIVINGSTON, MT 59047 PARK

Contact: Todd Peterson, (406) 222-7371

Sys Fac ID: 34-11741
Last Inspected On: 2/24/2015
Operating Permit Renewal Date: 3/9/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	26	9/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
564			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic, Not Applicable
Diesel		9/2/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		9/2/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in PARK County in the City of LIVINGSTON

Location: TOWN PUMP INC LIVINGSTON 3
2200 PARK ST S
LIVINGSTON, MT 59047 PARK

Contact: Kevin Kenneally, (406) 222-5527

Sys Fac ID: 34-13409
Last Inspected On: 2/22/2016
Operating Permit Renewal Date: 4/2/2019

Owners/Operators: Livingston Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Don Edmisten, UST Class A Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	5/20/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2579		2/19/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	22	5/20/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2580		2/19/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	22	5/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2581		2/19/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	22	5/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2582		2/19/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in PARK County in the City of LIVINGSTON

Location: TOWN PUMP INC LIVINGSTON 3
2200 PARK ST S
LIVINGSTON, MT 59047 PARK

Contact: Kevin Kenneally, (406) 222-5527

Sys Fac ID: 34-13409
Last Inspected On: 2/22/2016
Operating Permit Renewal Date: 4/2/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	22	5/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2583		2/19/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	15	10/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4377		2/19/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	15	10/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4378		2/19/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	15	10/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4379		2/19/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in PARK County in the City of LIVINGSTON

Location: TJS GAS N CONVENIENCE
204 W PARK ST
LIVINGSTON, MT 59047 PARK

Contact: Terry Ricci, (406) 222-9720

Sys Fac ID: 34-13736
Last Inspected On: 7/1/2014
Operating Permit Renewal Date: 9/3/2017

Owners/Operators: TJs Gas N Convenience, Owner (406)-222-9720 204 E PARK ST LIVINGSTON MT 59047-2713

Terry Ricci, UST Class A Operator
Becky Thomas, UST Class A Operator
Terry Ricci, UST Class B Operator
Becky Thomas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	5/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3371			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/1/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
2	20	5/1/1996	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3372			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/1/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in PARK County in the City of WILSALL

Location: PARK FARMERS COOP
114 S ELLIOT
WILSALL, MT 59086 PARK

Contact: Donald Scott, (406) 578-2543

Sys Fac ID: 34-06686
Last Inspected On: 2/11/2016
Operating Permit Renewal Date: 5/24/2019

Owners/Operators:

Park Farmers Coop, Owner	(406)-578-2543	PO BOX 129 WILSALL MT 59086-0129
Donald Scott, Operator	(406)-686-4489	19 ASPEN LN CLYDE PARK MT 59018
Don Scott, UST Class A Operator		
Don Scott, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
13	23	7/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1784			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		4/26/2010	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		4/17/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
14	23	7/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1785			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Diesel		4/26/2010	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		4/17/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
15	23	7/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1786			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Gasoline		4/26/2010	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		4/17/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in PARK County in the City of WILSALL

Location: PARK FARMERS COOP
114 S ELLIOT
WILSALL, MT 59086 PARK
Contact: Donald Scott, (406) 578-2543

Sys Fac ID: 34-06686
Last Inspected On: 2/11/2016
Operating Permit Renewal Date: 5/24/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
16	23	7/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1787			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Diesel		4/26/2010	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		4/17/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in PETROLEUM County in the City of WINNETT

Location: WINNETT TIRE
115 N BROADWAY
WINNETT, MT 59087 PETROLEUM
Contact: (406) 429-2961

Sys Fac ID: 35-00536
Last Inspected On: 2/22/2016
Operating Permit Renewal Date: 6/17/2019

Owners/Operators: GS Oil Inc Roy, Owner (406)-464-2221 PO BOX 149
ROY MT 59471-0149

Jolene Smith, UST Class A Operator
Jolene Smith, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	17	9/27/1999	Bare Steel	Flexible Plastic	High Level Alarm
4094	Yes	10/24/2016	Double-Walled	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
2,000			TLS-350/Gilbarco EMC , Veeder Root		
4	17	9/27/1999	Bare Steel	Flexible Plastic	High Level Alarm
4095	Yes	10/24/2016	Double-Walled	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
3,000			TLS-350/Gilbarco EMC , Veeder Root		
5	17	9/27/1999	Bare Steel	Flexible Plastic	High Level Alarm
4096	Yes	10/24/2016	Double-Walled	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
3,000			TLS-350/Gilbarco EMC , Veeder Root		
6	17	9/27/1999	Bare Steel	Flexible Plastic	High Level Alarm
4097	Yes	10/24/2016	Double-Walled	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
3,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in PETROLEUM County in the City of WINNETT

Location: B & D SERVICE HWY 244
203 N BROADWAY AVE RR 244
WINNETT, MT 59087 PETROLEUM

Contact: David Grantier, (406) 429-5291

Sys Fac ID: 56-13897
Last Inspected On: 8/19/2015
Operating Permit Renewal Date: 1/26/2019

Owners/Operators: B & D Service, Owner (406)-429-5291 PO BOX 229
WINNETT MT 59087-0229

Becky Grantier, UST Class A Operator
David Grantier, UST Class A Operator
Becky Grantier, UST Class B Operator
David Grantier, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	17	4/1/1999	Unknown	Flexible Plastic	
4001	Yes	8/19/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
12,000			ILS-350 , Veeder Root		
6	17	4/1/1999	Unknown	Flexible Plastic	
4002	Yes	8/19/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000			ILS-350 , Veeder Root		

Facility Summary in PHILLIPS County in the City of MALTA

Location: PACKYS
902 S CENTRAL AVE PO BOX 490
MALTA, MT 59538 PHILLIPS

Sys Fac ID: 36-02359
Last Inspected On: 2/4/2016
Operating Permit Renewal Date:

Contact: David Adam, (406) 581-1787

Owners/Operators: Adams Convenience Store, Owner/Operator (406)-581-1787 1627 W MAIN STE 145
BOZEMAN MT 59715-9304

Garry Adams, UST Class A Operator
Barb Nevrivy, UST Class A Operator
Barb Nevrivy, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	22	6/1/1994	Bare Steel	Flexible Plastic	
892	Yes		None	Double-Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor, Not Listed	
17,000					
3	22	6/1/1994	Bare Steel	Flexible Plastic	
893	Yes		None	Double-Walled	Yes
Temporarily Out of Use		6/1/2004	Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
17,000					

Facility Summary in PHILLIPS County in the City of MALTA

Location: MALTA CONVENIENCE STORE
3 N 1ST ST E
MALTA, MT 59538 PHILLIPS
Contact: Rolle Ron, (406) 654-1199

Sys Fac ID: 36-02371
Last Inspected On: 7/25/2016
Operating Permit Renewal Date: 10/31/2019

Owners/Operators:

Horizon Resources, Owner	(701)-572-2172	317 2ND ST W WILLISTON ND 58801
Horizon Resources, Operator	(701)-572-2172	317 2ND ST W WILLISTON ND 58801

Chris Kinkelaar, UST Class A Operator
Eric Ottinger, UST Class A Operator
Chris Kinkelaar, UST Class B Operator
Eric Ottinger, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	30	10/29/1986	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3287			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/27/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
3	30	10/29/1986	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3288			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/27/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
4	18	10/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3289			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/22/2010	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in PHILLIPS County in the City of MALTA

Location: MALTA CONVENIENCE STORE
3 N 1ST ST E
MALTA, MT 59538 PHILLIPS

Contact: Rolle Ron, (406) 654-1199

Sys Fac ID: 36-02371
Last Inspected On: 7/25/2016
Operating Permit Renewal Date: 10/31/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	18	10/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3290			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/22/2010	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in PHILLIPS County in the City of MALTA

Location: WESTSIDE SELF SERVICE INC
US HIGHWAY 2 & US HIGHWAY 191
MALTA, MT 59538 PHILLIPS
Contact: Bob Ereaux, (406) 654-7070

Sys Fac ID: 36-06668
Last Inspected On: 1/27/2016
Operating Permit Renewal Date: 7/9/2019

Owners/Operators: Robert Ereaux, Owner/Operator (406)-654-7070 PO BOX 1359 MALTA MT 59538-1359
Byron Ereaux, UST Class A Operator
Byron Ereaux, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	10	4/25/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5069			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		10/11/2006	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			Gilbarco EMC Basic , Gilbarco		
7	10	4/25/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5070			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Diesel		10/12/2006	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			Gilbarco EMC Basic , Gilbarco		
8	10	4/25/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5071			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Diesel		10/13/2006	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in PHILLIPS County in the City of MALTA

Location: WESTSIDE SELF SERVICE INC
US HIGHWAY 2 & US HIGHWAY 191
MALTA, MT 59538 PHILLIPS
Contact: Bob Ereaux, (406) 654-7070

Sys Fac ID: 36-06668
Last Inspected On: 1/27/2016
Operating Permit Renewal Date: 7/9/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	10	4/25/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5075			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Diesel		10/14/2006	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			Gilbarco EMC Basic , Gilbarco		
10	10	4/25/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5076			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Diesel		10/20/2006	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			Gilbarco EMC Basic , Gilbarco		
11	10	4/25/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5077			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Gasoline		11/27/2006	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in PHILLIPS County in the City of MALTA

Location: EQUITY COOP ASSOCIATION MALTA
428 S 1ST ST E
MALTA, MT 59538 PHILLIPS
Contact: Mark French, (406) 654-2240

Sys Fac ID: 36-10706
Last Inspected On: 8/6/2016
Operating Permit Renewal Date: 10/30/2019

Owners/Operators: Equity Coop Association Malta, Owner (406)-654-2240 PO BOX 340
MALTA MT 59538-0340

Virgil Abrahamson, UST Class A Operator
Angela Anderson, UST Class A Operator
Dale Kaasa, UST Class A Operator
Virgil Abrahamson, UST Class B Operator
Angela Anderson, UST Class B Operator
Dale Kaasa, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	21	12/9/1994	Unknown	Fiberglass Reinforced Plastic	
860	Yes	8/6/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable, Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
25,600			Gilbarco EMC Basic , Gilbarco		
4	21	12/9/1994	Unknown	Fiberglass Reinforced Plastic	
861	Yes	8/6/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable, Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
17,000			Gilbarco EMC Basic , Gilbarco		
5	21	12/9/1994	Unknown	Fiberglass Reinforced Plastic	
862	Yes	8/6/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable, Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in PHILLIPS County in the City of MALTA

Location: EQUITY COOP ASSOCIATION MALTA
428 S 1ST ST E
MALTA, MT 59538 PHILLIPS
Contact: Mark French, (406) 654-2240

Sys Fac ID: 36-10706
Last Inspected On: 8/6/2016
Operating Permit Renewal Date: 10/30/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	21	12/9/1994	Unknown	Fiberglass Reinforced Plastic	
863	Yes	8/6/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable, Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
9,900			Gilbarco EMC Basic , Gilbarco		
7	21	12/1/1994	Unknown	Fiberglass Reinforced Plastic	
5421	Yes	8/6/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
3,200			Gilbarco EMC Basic , Gilbarco	Not Listed	

Facility Summary in PHILLIPS County in the City of MALTA

Location: EZZIES WHOLESALE US 2 E
US HIGHWAY 2 E
MALTA, MT 59538 PHILLIPS

Contact: David Skiff, (406) 654-2331

Sys Fac ID: 36-11372
Last Inspected On: 3/23/2016
Operating Permit Renewal Date: 9/15/2019

Owners/Operators: EZZIES WHOLESALE INC, Owner (406)-654-2331 PO BOX 1770 MALTA MT 59538-9640

David Skiff, UST Class A Operator
Loren Johnson, UST Class B Operator
David Skiff, UST Class B Operator
David Skiff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	1/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
886			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/23/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		3/29/2007	TLS-350/Gilbarco EMC , Veeder Root		
2	26	1/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
887			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/23/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		3/29/2007	TLS-350/Gilbarco EMC , Veeder Root		
3	26	1/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
888			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/23/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		3/29/2007	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in PHILLIPS County in the City of MALTA

Location: EZZIES WHOLESALE US 2 E
US HIGHWAY 2 E
MALTA, MT 59538 PHILLIPS
Contact: David Skiff, (406) 654-2331

Sys Fac ID: 36-11372
Last Inspected On: 3/23/2016
Operating Permit Renewal Date: 9/15/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	26	1/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
889			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/23/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		3/29/2007	TLS-350/Gilbarco EMC , Veeder Root		
5	26	1/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
890			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		3/23/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		3/29/2007	TLS-350/Gilbarco EMC , Veeder Root		
6	26	1/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
891			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		3/23/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		10/6/2006	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in PHILLIPS County in the City of MALTA

Location: PHILLIPS COUNTY MEDICAL CENTER
311 SOUTH 8TH AVE E
MALTA, MT 59538 PHILLIPS

Contact: Beu Winkel, (406) 390-4452

Sys Fac ID: 56-14104
Last Inspected On: 6/21/2016
Operating Permit Renewal Date: 10/5/2019

Owners/Operators:

Phillips County Medical Center, Owner	(406)-654-1100	PO BOX 640 MALTA MT 59538-0640
Beu Winkel, Operator	(406)-654-1190	PO BOX 152 MALTA MT 59538-8728

Richard Ferrell, UST Class A Operator
Thomas Miller, UST Class A Operator
Candace Radovich, UST Class A Operator
Beu Winkel, UST Class A Operator
Richard Ferrell, UST Class B Operator
Thomas Miller, UST Class B Operator
Beu Winkel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	12	3/2/2004	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4884		6/12/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
1,000		6/21/2016	TLS-300 , Veeder Root		
2	12	3/2/2004	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4885		6/12/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
1,000		6/21/2016	TLS-300 , Veeder Root		

Facility Summary in PHILLIPS County in the City of MALTA

Location: EZZIES BULK STORAGE
47259 US HWY 2
MALTA, MT 59538 PHILLIPS
Contact: David Skiff, (406) 654-2331

Sys Fac ID: 60-15156
Last Inspected On: 2/20/2014
Operating Permit Renewal Date: 4/20/2017

Owners/Operators: EZZIES WHOLESALE INC, Owner (406)-654-2331 PO BOX 1770
MALTA MT 59538-9640

David Skiff, UST Class A Operator
Loren Johnson, UST Class B Operator
David Skiff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	06	9/27/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5246			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
30,000					Yes
2	06	9/27/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5247			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					Yes
3	06	9/27/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5248			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					Yes
4	06	9/27/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5249			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					Yes

Facility Summary in PHILLIPS County in the City of MALTA

Location: EZZIES BULK STORAGE
47259 US HWY 2
MALTA, MT 59538 PHILLIPS
Contact: David Skiff, (406) 654-2331

Sys Fac ID: 60-15156
Last Inspected On: 2/20/2014
Operating Permit Renewal Date: 4/20/2017

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
5	06	9/27/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5250			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					Yes
6	06	9/27/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5251			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000					Yes
7	06	9/27/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5252		10/6/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000					Yes
8	06	9/27/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5253			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
20,000					Yes
9	06	9/27/2010	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5254			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
30,000					Yes

Facility Summary in PHILLIPS County in the City of SACO

Location: EZZIES WHOLESALE
100 HIGHWAY 243
SACO, MT 59261 PHILLIPS

Contact: Paul Poulton,

Sys Fac ID: 60-15270
Last Inspected On: 6/21/2016
Operating Permit Renewal Date: 7/5/2019

Owners/Operators: EZZIES WHOLESALE INC, Owner (406)-654-2331 PO BOX 1770
MALTA MT 59538-9640

David Skiff, UST Class A Operator
Loren Johnson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	00	1/20/2016	Aboveground Tank	Flexible Plastic	
5626	Yes	1/15/2016	None	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	Yes
2	00	1/20/2016	Aboveground Tank	Flexible Plastic	
5627	Yes	1/15/2016	None	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
2,000			TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	Yes
3	00	1/20/2016	Aboveground Tank	Flexible Plastic	
5628	Yes	1/15/2016	None	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
2,000			TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in PHILLIPS County in the City of WHITEWATER

Location: FARMERS UNION OIL CO WHITEWATER
MAIN STREET PO BOX 7
WHITEWATER, MT 59544 PHILLIPS
Contact: Curtis Reichelt, (406) 674-5515

Sys Fac ID: 36-04082
Last Inspected On: 11/25/2014
Operating Permit Renewal Date: 2/11/2018

Owners/Operators: Farmers Union Oil Co Whitewater, Owner (406)-674-5515 PO BOX 7 WHITEWATER MT 59544
David Skiff, UST Class A Operator
Loren Johnson, UST Class B Operator
David Skiff, UST Class B Operator
David Skiff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	18	10/13/1998	Unknown	Flexible Plastic	
3599	Yes	12/19/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
10,000					
6	18	10/13/1998	Unknown	Flexible Plastic	
3600	Yes	12/19/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
15,000					
7	18	10/13/1998	Unknown	Flexible Plastic	
3601	Yes	12/19/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
9,000					
8	18	10/13/1998	Unknown	Flexible Plastic	
3602	Yes	12/19/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
9,000					

Facility Summary in PHILLIPS County in the City of ZORTMAN

Location: ZORTMAN GARAGE & MOTEL
302 MAIN ST
ZORTMAN, MT 59546 PHILLIPS

Contact: John Kalal, (406) 673-3160

Sys Fac ID: 36-11549
Last Inspected On: 9/12/2016
Operating Permit Renewal Date: 11/27/2019

Owners/Operators: Zortman Garage & Motel, Owner (406)-673-3160 PO BOX 302
ZORTMAN MT 59546-0302

Deirdre Hanners, UST Class A Operator
Candy Kalal, UST Class A Operator
Candy Kalal, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	17	6/17/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4020			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		8/18/2010	Manual Interstitial Monitor	Deferred	
1,000					
4	17	6/17/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4021			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		8/18/2010	Manual Interstitial Monitor	Deferred	
1,000					

Facility Summary in PONDERA County in the City of BRADY

Location: ULRICH
309 2ND AVE NE
BRADY, MT 59416 PONDERA

Contact: Scott Ulrich, (907) 746-5848

Sys Fac ID: 37-02704
Last Inspected On: 3/18/2014
Operating Permit Renewal Date:

Owners/Operators:

Debbie Ulrich, Owner/Operator	(907)-746-5848	33066 WEST ROCKY ISLAND CIRCLE SUTTON AK 99674
Scott Ulrich, Owner/Operator	(907)-746-5848	33066 WEST ROCKY ISLAND CIRCLE SUTTON AK 99674
Clifford Suek, UST Class A Operator		
Clifford Suek, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	19	7/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
487			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	U.S. Suction	Not Applicable
Heating Oil			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in PONDERA County in the City of BRADY

Location: MOUNTAIN VIEW COOP BRADY
102 RAILROAD ST N
BRADY, MT 59416 PONDERA

Contact: Pat Trainor, (406) 753-2258

Sys Fac ID: 37-04241
Last Inspected On: 7/15/2016
Operating Permit Renewal Date: 8/4/2019

Owners/Operators: Mountain View Coop, Owner (406)-453-2435 ATTN DAVE DOUGLAS
2200 OLD HAVRE HWY
BLACK EAGLE MT 59414-1043

David Douglas, UST Class A Operator
Lorena Rouns, UST Class B Operator
David Douglas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	19	11/1/1997	Unknown	Flexible Plastic	
2142	Yes	7/7/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
17,000					
7	19	11/1/1997	Unknown	Flexible Plastic	
2143	Yes	7/7/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
17,000					
8	19	11/1/1997	Unknown	Flexible Plastic	
2144	Yes	7/7/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000					
9	19	11/1/1997	Unknown	Flexible Plastic	
2145	Yes	7/7/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
5,000					

Facility Summary in PONDERA County in the City of CONRAD

Location: MOUNTAIN VIEW COOP CONRAD
19 S MAIN ST
CONRAD, MT 59425 PONDERA

Contact: Dave Douglas, (406) 453-2435

Sys Fac ID: 37-01649
Last Inspected On: 12/27/2013
Operating Permit Renewal Date: 3/8/2017

Owners/Operators: Mountain View Coop, Owner/Operator (406)-453-2435 ATTN DAVE DOUGLAS
2200 OLD HAVRE HWY
BLACK EAGLE MT 59414-1043

Dave Douglas, UST Class A Operator
Jody Fowler, UST Class A Operator
Jeremy Kulpas, UST Class A Operator
Jody Fowler, UST Class B Operator
Jeremy Kulpas, UST Class B Operator
Dave Douglas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	1/8/1997	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
920		8/15/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		8/2/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
7,000					
2	19	1/8/1997	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
921		8/15/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		8/2/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
7,000					
3	19	1/8/1997	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
922		8/15/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		8/2/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000					

Facility Summary in PONDERA County in the City of CONRAD

Location: MOUNTAIN VIEW COOP CONRAD
19 S MAIN ST
CONRAD, MT 59425 PONDERA

Contact: Dave Douglas, (406) 453-2435

Sys Fac ID: 37-01649
Last Inspected On: 12/27/2013
Operating Permit Renewal Date: 3/8/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	19	1/8/1997	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
919		8/15/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		8/2/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000					
5	19	1/8/1997	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
918		8/15/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		8/2/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
9,000					
11	19	1/8/1997	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
916		8/15/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/2/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
9,000					
12	19	1/8/1997	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
917		8/15/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/2/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000					

Facility Summary in PONDERA County in the City of CONRAD

Location: TOMS SUPER SERVICE
301 S MAIN ST
CONRAD, MT 59425 PONDERA
Contact: Tom Fetters, (406) 278-5213

Sys Fac ID: 37-06114
Last Inspected On: 5/14/2016
Operating Permit Renewal Date: 7/20/2019

Owners/Operators: Ben Taylor Inc, Owner (800)-824-8366 PO BOX 810
SHELBY MT 59474-0810

Tom Fetters, UST Class A Operator
Tom Fetters, UST Class B Operator
Gail Mullennax, UST Class B Operator
Gregory Taylor, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	5/12/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
425			Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
4,000		5/10/2016	ILS-250 , Veeder Root		
4	23	5/12/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
423			Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
4,000		5/10/2016	ILS-250 , Veeder Root		
5	23	5/12/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
424			Double-Walled	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
8,000		5/10/2016	ILS-250 , Veeder Root		

Facility Summary in PONDERA County in the City of CONRAD

Location: TOWN PUMP INC CONRAD
215 N MAIN ST
CONRAD, MT 59425 PONDERA

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 37-08692
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 4/1/2019

Owners/Operators: Town Pump Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-2534

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	33	8/30/1983	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2584			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/10/2015	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		7/28/2006	TLS-350/Gilbarco EMC , Veeder Root		
2	33	8/30/1983	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2585			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/10/2015	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		7/29/2006	TLS-350/Gilbarco EMC , Veeder Root		
3	33	8/30/1983	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2586			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/10/2015	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		7/30/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in PONDERA County in the City of CONRAD

Location: TOWN PUMP INC CONRAD
215 N MAIN ST
CONRAD, MT 59425 PONDERA

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 37-08692
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 4/1/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	30	8/30/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2587			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/10/2015	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		8/1/2006	TLS-350/Gilbarco EMC , Veeder Root		
5	28	7/1/1988	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2588			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/3/2009	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		10/26/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	17	9/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4151			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/3/2009	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		10/30/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	17	9/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
4152			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/3/2009	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		10/30/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in PONDERA County in the City of CONRAD

Location: TOWN PUMP INC CONRAD
215 N MAIN ST
CONRAD, MT 59425 PONDERA
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 37-08692
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 4/1/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	02	7/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5495		7/21/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	
11	02	7/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5496		7/21/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	
12	02	7/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5497		7/21/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	

Facility Summary in PONDERA County in the City of HEART BUTTE

Location: HEART BUTTE SCHOOL DIST 1
SCHOOL BUS BARN RD
HEART BUTTE, MT 59448 PONDERA

Contact: Merlin Running Crane, (406) 338-2200

Sys Fac ID: 37-09353
Last Inspected On: 11/21/2013
Operating Permit Renewal Date: 12/28/2016

Owners/Operators: School Dist 1 Heart Butte, Owner (406)-338-2200 PO BOX 259
HEART BUTTE MT 59448-0259

Merlin Running Crane, UST Class A Operator
Stewart Horn, UST Class B Operator
Merlin Running Crane, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	30	5/6/1986	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1901			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable, Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Not Listed	
2,000					
4	30	5/6/1986	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1902			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable, Not Applicable
Diesel			Automatic Tank Gauging 0.2	Not Listed	
2,000					

Facility Summary in PONDERA County in the City of VALIER

Location: ONE STOP CENEX
518 TETON
VALIER, MT 59486 PONDERA

Contact: Shawna Curry, (406) 279-3578

Sys Fac ID: 37-03112
Last Inspected On: 12/15/2014
Operating Permit Renewal Date: 12/17/2017

Owners/Operators: One Stop LLC, Owner (406)-279-3600 PO BOX 368
VALIER MT 59486-0368

Scott R Curry, UST Class A Operator
Scott R Curry, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	3/21/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1879			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		9/30/2015	Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
1,000		12/15/2014			
3	26	3/21/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1878			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/30/2015	Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
1,000		12/15/2014			
4	26	3/21/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4445			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/30/2015	Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
2,000		12/15/2014			

Facility Summary in PONDERA County in the City of VALIER

Location: CFN CARDLOCK
810 TETON
VALIER, MT 59486 PONDERA
Contact: Joe Stokes, (406) 279-3365

Sys Fac ID: 56-14043
Last Inspected On: 2/25/2015
Operating Permit Renewal Date: 3/25/2018

Owners/Operators: Ben Taylor Inc, Owner (800)-824-8366 PO BOX 810 SHELBY MT 59474-0810

Scott E Curry, UST Class A Operator
Thomas Loch, UST Class B Operator
Gail Mullennax, UST Class B Operator
Rusty Rideout, UST Class B Operator
Joel Stokes, UST Class B Operator
Rita Swanson, UST Class B Operator
Gregory Taylor, UST Class B Operator
Scott E Curry, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	14	8/19/2002	Concrete	Flexible Plastic	
4710	Yes	2/23/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
8,000			ILS-350 , Veeder Root		
2	14	8/19/2002	Concrete	Flexible Plastic	
4711	Yes	2/23/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
8,000			ILS-350 , Veeder Root		
3	14	8/19/2002	Concrete	Flexible Plastic	
4712	Yes	2/23/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
17,000			ILS-350 , Veeder Root		

Facility Summary in PONDERA County in the City of VALIER

Location: CFN CARDLOCK
810 TETON
VALIER, MT 59486 PONDERA
Contact: Joe Stokes, (406) 279-3365

Sys Fac ID: 56-14043
Last Inspected On: 2/25/2015
Operating Permit Renewal Date: 3/25/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	14	8/19/2002	Concrete	Flexible Plastic	
4713	Yes	2/23/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
17,000			ILS-350 , Veeder Root		

Facility Summary in POWDER RIVER County in the City of BIDDLE

Location: CROSS RANCH MERC
MT HIGHWAY 59
BIDDLE, MT 59314 POWDER RIVER

Contact: Nathan Rumph, (406) 427-5447

Sys Fac ID: 38-01493
Last Inspected On: 5/20/2014
Operating Permit Renewal Date: 8/10/2017

Owners/Operators: Nathan Rumph, Owner (406)-427-5447 PO BOX 396
BIDDLE MT 59314-0396

Connie Rumph, UST Class A Operator
Connie Rumph, UST Class B Operator
Connie Rumph, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	26	9/11/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
783			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		5/20/2014	Automatic Tank Gauging 0.2	Deferred	
2,000			Auto Stik II , EBW		
8	26	9/11/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
784			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		5/20/2014	Automatic Tank Gauging 0.2	Deferred	
2,000			Auto Stik II , EBW		

Facility Summary in POWDER RIVER County in the City of BROADUS

Location: THE CORNER STORE
106 W HOLT ST
BROADUS, MT 59317 POWDER RIVER
Contact: Milton Amsden, (406) 436-2666

Sys Fac ID: 38-00126
Last Inspected On: 5/20/2014
Operating Permit Renewal Date: 11/6/2017

Owners/Operators: Milton L Amsden, Owner (406)-436-2924 DBA CORNER STORE
BOX 1
BROADUS MT 59317

Milton L Amsden, UST Class A Operator
Milton L Amsden, UST Class B Operator
Milton L Amsden, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	12/4/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
933			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/20/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
2	23	12/4/1992	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
934			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/20/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
3	23	12/4/1992	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
935			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/20/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			TLS-350/Gilbarco EMC , Veeder Root		
4	23	12/4/1992	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
936			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/20/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in POWDER RIVER County in the City of BROADUS

Location: COUNTY SHOP MAINTENANCE YARD
3 COUNTY SHOP ROAD
BROADUS, MT 59317 POWDER RIVER

Contact: Mark Larue, (406) 436-2248

Sys Fac ID: 38-00548
Last Inspected On: 9/18/2014
Operating Permit Renewal Date: 11/26/2017

Owners/Operators: Powder River County, Owner (406)-436-2361 PO BOX 200
BROADUS MT 59317-0200

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	25	6/17/1991	Cathodically Protected Steel	Steel	High Level Alarm
1807			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		9/18/2014	Automatic Tank Gauging 0.2	Deferred	
5,000			TLS-300 , Veeder Root		

Facility Summary in POWDER RIVER County in the City of BROADUS

Location: ALDERMAN OIL CO
601 S PARK AVE PO BOX 120
BROADUS, MT 59317 POWDER RIVER

Contact: Gary Alderman, (406) 436-2898

Sys Fac ID: 38-03951
Last Inspected On: 9/18/2014
Operating Permit Renewal Date: 11/6/2017

Owners/Operators: Alderman Oil Co, Owner (406)-436-2898 PO BOX 120
BROADUS MT 59317-0120

Gary Alderman, UST Class A Operator
Theresa Alderman, UST Class A Operator
Gary Alderman, UST Class B Operator
Theresa Alderman, UST Class B Operator
Cheryl McDowell, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	23	5/10/1993	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
359			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		3/26/2014	Automatic Tank Gauging 0.2	Deferred	
2,000			TLS-350/Gilbarco EMC , Veeder Root		
5	23	5/10/1993	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
360			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		3/26/2014	Automatic Tank Gauging 0.2	Deferred	
2,000			TLS-350/Gilbarco EMC , Veeder Root		
6	23	5/10/1993	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
361			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		3/26/2014	Automatic Tank Gauging 0.2	Deferred	
2,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in POWDER RIVER County in the City of BROADUS

Location: ALDERMAN OIL CO
601 S PARK AVE PO BOX 120
BROADUS, MT 59317 POWDER RIVER

Contact: Gary Alderman, (406) 436-2898

Sys Fac ID: 38-03951
Last Inspected On: 9/18/2014
Operating Permit Renewal Date: 11/6/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	18	9/30/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
362			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/21/2011	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
8	18	9/30/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
363			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/21/2011	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
9	18	9/30/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
364			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/21/2011	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in POWELL County in the City of DEER LODGE

Location: I 90 AUTO TRUCK PLAZA
132 N INTERCHANGE
DEER LODGE, MT 59722 POWELL

Contact: Lawrence Fickler, (406) 846-3970

Sys Fac ID: 39-07856
Last Inspected On: 8/21/2013
Operating Permit Renewal Date: 12/26/2016

Owners/Operators: Fickler Oil Co Inc Deer Lodge, Owner (406)-846-3970 725 MAVERICK LN DEER LODGE MT 59722-2347

Bonnie Cyr, UST Class A Operator
Bonnie Cyr, UST Class B Operator
Hazel Ehry, UST Class B Operator
Percy Moore, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	17	12/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3612			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
15,000					
11	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3613		12/19/2013	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000					
12	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4436		12/19/2013	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
20,000					

Facility Summary in POWELL County in the City of DEER LODGE

Location: I 90 AUTO TRUCK PLAZA
132 N INTERCHANGE
DEER LODGE, MT 59722 POWELL

Contact: Lawrence Fickler, (406) 846-3970

Sys Fac ID: 39-07856
Last Inspected On: 8/21/2013
Operating Permit Renewal Date: 12/26/2016

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
13	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4437		12/19/2013	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					
14	13	6/26/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4847			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					
15	13	6/26/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4848			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000					

Facility Summary in POWELL County in the City of DEER LODGE

Location: TOWN PUMP INC DEER LODGE
203 N MAIN ST
DEER LODGE, MT 59722 POWELL

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 39-08694
Last Inspected On: 6/30/2015
Operating Permit Renewal Date: 10/14/2018

Owners/Operators: Town Pump Inc Butte, Owner (406)-782-9121 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	39	4/14/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2589			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/24/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	39	4/14/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2590			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/24/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
5	39	4/14/1977	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2591			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Diesel		6/24/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in POWELL County in the City of DEER LODGE

Location: TOWN PUMP INC DEER LODGE
203 N MAIN ST
DEER LODGE, MT 59722 POWELL

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 39-08694
Last Inspected On: 6/30/2015
Operating Permit Renewal Date: 10/14/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	18	7/30/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2592			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/24/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
8	16	9/15/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4282			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel		6/24/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	16	9/15/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4283			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel		6/24/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in POWELL County in the City of DEER LODGE

Location: DINO MART DEER LODGE
1007 VILLAGE LN
DEER LODGE, MT 59722 POWELL

Contact: Todd Fickler, (406) 846-3970

Sys Fac ID: 39-10909
Last Inspected On: 7/16/2014
Operating Permit Renewal Date:

Owners/Operators:

T & TF Inc, Owner	(406)-846-3819	725 MAVERICK LN DEER LODGE MT 59722
Fickler Oil Co Inc Deer Lodge, Operator	(406)-846-3970	725 MAVERICK LN DEER LODGE MT 59722-2347
Randy Livingston, UST Class A Operator		
Keith Dowling, UST Class B Operator		
Randy Livingston, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	27	4/13/1989	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
767			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		7/18/2008	TLS-350/Gilbarco EMC , Veeder Root		
4	18	11/19/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
768			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/18/2008			
5	18	11/19/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
769			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		7/18/2008			

Facility Summary in POWELL County in the City of DEER LODGE

Location: BROKEN CIRCLE RANCH CO INC
3850 EASTSIDE RD
DEER LODGE, MT 59722 POWELL

Contact: Del Nicholson, (406) 846-9614

Sys Fac ID: 39-13744
Last Inspected On: 1/27/2015
Operating Permit Renewal Date: 3/26/2018

Owners/Operators: Broken Circle Ranch Co Inc, Owner (406)-846-9318 3987 EASTSIDE RD
DEER LODGE MT 59722-9520

Jennifer Nicholson, UST Class A Operator
Jereme Nicholson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	6/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4624			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
10,000			Gilbarco EMC Basic , Gilbarco		
2	20	6/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4625			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
10,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in POWELL County in the City of ELLISTON

Location: ELLISTON STORE
104 E FRONT ST
ELLISTON, MT 59728 POWELL

Contact: Bill Thomas, (406) 492-6391

Sys Fac ID: 39-05196
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 12/27/2017

Owners/Operators: William Thomas, Owner (406)-492-6391 PO BOX 15
ELLISTON MT 59728-0015

Bill Thomas, UST Class A Operator
Melissa Thomas, UST Class A Operator
William Thomas, UST Class A Operator
Melissa Thomas, UST Class B Operator
William Thomas, UST Class B Operator
Bill Thomas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	31	5/6/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3856		4/28/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		11/3/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
4	31	5/6/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3857		4/28/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		11/3/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in POWELL County in the City of GARRISON

Location: GARRISON MERCANTILE & POST OFFICE INC
INTERSTATE 90 & US HIGHWAY 12
GARRISON, MT 59731 POWELL

Contact: Judith M Wood, (406) 846-9961

Sys Fac ID: 39-03405
Last Inspected On: 8/17/2015
Operating Permit Renewal Date:

Owners/Operators: Garrison Mercantile & Post Office Inc, Owner (406)-846-3505 PO BOX 636
GARRISON MT 59731-0636

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	35	5/5/1981	Cathodically Protected Steel	Steel	
3934			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use				Safe Suction	Impressed Current
Gasoline		8/18/2015	Automatic Tank Gauging 0.1	Deferred	
5,000					
2	35	5/5/1981	Cathodically Protected Steel	Steel	
3935			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use				Safe Suction	Impressed Current
Gasoline		8/18/2015	Automatic Tank Gauging 0.1	Deferred	
5,000					

Facility Summary in POWELL County in the City of OVANDO

Location: BLACKFOOT COMMERCIAL CO LLC
406 PINE ST W
OVANDO, MT 59854 POWELL

Contact: Fred Valiton, (406) 793-5555

Sys Fac ID: 39-02276
Last Inspected On: 11/23/2016
Operating Permit Renewal Date: 11/30/2019

Owners/Operators:

Blackfoot Valley Inn & Mercentile LLC, Owner	(406)-793-5555	PO BOX 77 OVANDO MT 59854
Dennis Sharp, Operator	(406)-793-5555	406 PINE STREET W OVANDO MT 59854
Howard G Fly, UST Class A Operator		
Howard G Fly, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	6/1/1996	Aboveground Tank	Fiberglass Reinforced Plastic	
3362	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
1,000		11/23/2016			
2	20	6/1/1996	Aboveground Tank	Fiberglass Reinforced Plastic	
3363	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
3,000		11/23/2016			
3	20	6/1/1996	Aboveground Tank	Fiberglass Reinforced Plastic	
3364	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
1,000		11/23/2016			

Facility Summary in PRAIRIE County in the City of TERRY

Location: FARMERS UNION OIL CO TERRY
101 MCDONALD AVE
TERRY, MT 59349 PRAIRIE
Contact: Jimmie Rittal, (406) 637-5479

Sys Fac ID: 40-06797
Last Inspected On: 1/3/2014
Operating Permit Renewal Date: 3/14/2017

Owners/Operators: Farmers Union Oil Co Circle, Owner (406)-485-3475 PO BOX 460
CIRCLE MT 59215-0460

Larry Keltner, UST Class A Operator
Glenn Pehl, UST Class A Operator
Jeffrey P Schaefer, UST Class A Operator
Larry Kwasney, UST Class B Operator
Glenn Pehl, UST Class B Operator
Jeffrey P Schaefer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	26	4/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
955			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		1/3/2014	Stat. Inventory Reconcilitation	Deferred	
1,000					
7	26	4/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
956			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		1/3/2014	Stat. Inventory Reconcilitation	Deferred	
1,000					
8	26	4/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
957			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		1/3/2014	Stat. Inventory Reconcilitation	Deferred	
560					

Facility Summary in PRAIRIE County in the City of TERRY

Location: 4 CORNERS
3 TEN MILE ROAD
TERRY, MT 59349 PRAIRIE

Contact: Leann Lantis, (406) 635-2198

Sys Fac ID: 40-06798
Last Inspected On: 4/8/2015
Operating Permit Renewal Date: 8/3/2018

Owners/Operators:

Leann Lantis, Owner/Operator	(406)-635-2198	PO BOX 332 TERRY MT 59349
Robert Waylon, Owner/Operator	(406)-635-5814	PO BOX 332 TERRY MT 59349

Leann Lantis, UST Class A Operator
Leann Lantis, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	02	10/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5539		10/24/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	
10	02	10/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5540		10/24/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	
11	02	10/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5541		10/24/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	

Facility Summary in PRAIRIE County in the City of TERRY

Location: MTD PETROLEUM SERVICE LLC
14 TEN MILE RD
TERRY, MT 59349 PRAIRIE

Contact: Mark Underberg, (406) 635-4124

Sys Fac ID: 56-14149
Last Inspected On: 12/29/2014
Operating Permit Renewal Date: 2/24/2018

Owners/Operators: Cross Petroleum Service, Owner (406)-377-8325 PO BOX 1388 GLENDIVE MT 59330

Gregory Cross, UST Class A Operator
Timothy Fife, UST Class A Operator
RJ Serpe, UST Class A Operator
RJ Serpe, UST Class B Global Operator
Ron Serpe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	11	5/5/2005	Concrete	Flexible Plastic	
5040	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	11	5/5/2005	Concrete	Flexible Plastic	
4960	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	11	5/5/2005	Concrete	Flexible Plastic	
4961	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
4	11	5/5/2005	Concrete	Flexible Plastic	
4962	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in PRAIRIE County in the City of TERRY

Location: MTD PETROLEUM SERVICE LLC
14 TEN MILE RD
TERRY, MT 59349 PRAIRIE

Contact: Mark Underberg, (406) 635-4124

Sys Fac ID: 56-14149
Last Inspected On: 12/29/2014
Operating Permit Renewal Date: 2/24/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	11	5/5/2005	Concrete	Flexible Plastic	
5039	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in RAVALLI County in the City of CORVALLIS

Location: THE MERC FRESH MARKET INC
1000 MAIN ST
CORVALLIS, MT 59828 RAVALLI

Contact: Jay Joyner, (406) 961-4830

Sys Fac ID: 41-02402
Last Inspected On: 12/15/2015
Operating Permit Renewal Date: 2/17/2019

Owners/Operators: The Merc Fresh Market Inc, Owner (406)-961-4830 PO BOX 1025 CORVALLIS MT 59828
Jay Joyner, UST Class A Operator
Jay Joyner, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	22	2/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
376			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		12/15/2015	TLS-300 , Veeder Root		
5	20	8/1/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
377			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		12/15/2015	TLS-300 , Veeder Root		
6	20	8/1/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
378			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		12/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		12/15/2015	TLS-300 , Veeder Root		

Facility Summary in RAVALLI County in the City of DARBY

Location: MR TS FOOD AND FUEL
101 S MAIN ST
DARBY, MT 59829 RAVALLI

Contact: Robert Flood, (406) 821-3854

Sys Fac ID: 41-00028
Last Inspected On: 1/14/2014
Operating Permit Renewal Date: 5/16/2017

Owners/Operators: Floodtide Inc, Owner (406)-821-1940 PO BOX 508
DARBY MT 59829-0508

Robert L Flood, UST Class A Operator
Robert L Flood, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	21	4/13/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3070			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000			TS-1000 , Incon		
7	21	4/13/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3071			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000			TS-1000 , Incon		
8	00	10/1/2016	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5725		11/22/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
8,000			TS-1001 , Incon	Continuous Interstitial Monitor, Not Listed	Yes
9	00	10/1/2016	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5726		11/22/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
4,000			TS-1001 , Incon	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in RAVALLI County in the City of DARBY

Location: DARBY LUMBER
3299 US HIGHWAY 93
DARBY, MT 59829 RAVALLI

Contact: Cosgrisf David, (406) 293-1011

Sys Fac ID: 41-00853
Last Inspected On: 3/22/2016
Operating Permit Renewal Date:

Owners/Operators: Darby Lumber Inc, Owner (406)-821-3261 ROBERT(BOB) P & PEGGY L RUSSELL
PO BOX 357
POLSON MT 59860-0357

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	24	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
803			None	None	Yes
Temporarily Out of Use		4/1/2002	Not Required	Safe Suction	Galvanic
Diesel		3/22/2016	Tank Tightness Testing, Inventory Reconciliation	MLLD Line Tightness Testing	
3,000					
5	24	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
804			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		3/22/2016	Manual Tank Gauging, Tank Tightness Testing	MLLD Line Tightness Testing	
1,000					

Facility Summary in RAVALLI County in the City of DARBY

Location: OLES COUNTRY STORE 6
US HIGHWAY 93 S
DARBY, MT 59829 RAVALLI

Sys Fac ID: 41-10908
Last Inspected On: 10/16/2014
Operating Permit Renewal Date:

Contact: Frank Tabish, (406) 543-7621

Owners/Operators: Tabish Brothers Distributors Inc, Owner (406)-543-7621 GW PETROLEUM
PO BOX 8448
MISSOULA MT 59807-8448

Franklin X Tabish, UST Class A Operator
Heather M Stiles, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	4/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1441			None	None	Yes
Temporarily Out of Use		4/1/2005	Not Required	Pressurized	Not Applicable
Gasoline			Tank Tightness Testing, Inventory Reconciliation, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
12,000					
2	21	4/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1442			None	None	Yes
Temporarily Out of Use		4/1/2005	Not Required	Pressurized	Not Applicable
Gasoline			Tank Tightness Testing, Inventory Reconciliation, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000					
3	21	4/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1443			None	None	Yes
Temporarily Out of Use		4/1/2005	Not Required	Pressurized	Not Applicable
Diesel			Tank Tightness Testing, Inventory Reconciliation, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
5,000					

Facility Summary in RAVALLI County in the City of DARBY

Location: PEOPLES MARKET
801 N MAIN ST
DARBY, MT 59829 RAVALLI

Contact: Greg & Jesse Bergren, (406) 821-3612

Sys Fac ID: 56-14029
Last Inspected On: 11/18/2016
Operating Permit Renewal Date: 12/26/2016

Owners/Operators:

Peoples Market, Owner	(651)-261-3851	801 N MAIN ST DARBY MT 59829-9542
Greg Bergren, Operator	(406)-821-3612	801 N MAIN DARBY MT 59829

Greg Bergren, UST Class A Operator
Jesse Bergren, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	15	8/20/2001	Unknown	Flexible Plastic	
4338	Yes	8/29/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
8,000					
2	15	8/20/2001	Unknown	Flexible Plastic	
4339	Yes	8/29/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
4,000					
3	15	8/20/2001	Unknown	Flexible Plastic	
4340	Yes	8/29/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
5,000					
4	15	8/20/2001	Unknown	Flexible Plastic	
4341	Yes	8/29/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
5,000					

Facility Summary in RAVALLI County in the City of FLORENCE

Location: DYNA MART LLP
5323 US HIGHWAY 93 N
FLORENCE, MT 59833 RAVALLI

Contact: Ivan Lattin, (406) 273-9993

Sys Fac ID: 41-11356
Last Inspected On: 8/1/2016
Operating Permit Renewal Date:

Owners/Operators: Dich LLP, Owner (406)-273-2512 PO BOX 9
LOLO MT 59847

Shannon Tomicek, UST Class A Operator
Shannon Tomicek, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	36	1/1/1980	Bare Steel	Fiberglass Reinforced Plastic	
2331	Yes		None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
10,000		10/20/2010			
2	36	1/1/1980	Bare Steel	Fiberglass Reinforced Plastic	
2332	Yes		None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
12,000		10/20/2010			
3	36	1/1/1980	Bare Steel	Fiberglass Reinforced Plastic	
2333	Yes		None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
12,000		10/20/2010			
4	36	1/1/1980	Bare Steel	Fiberglass Reinforced Plastic	
2334	Yes		None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
5,000		10/20/2010			

Facility Summary in RAVALLI County in the City of FLORENCE

Location: TOWN PUMP INC FLORENCE
5495 US HIGHWAY 93 N
FLORENCE, MT 59833 RAVALLI

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 41-12720
Last Inspected On: 2/5/2016
Operating Permit Renewal Date: 5/27/2019

Owners/Operators: Billings Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	1/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2967			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/10/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
9,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root		
2	24	1/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2968			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		7/10/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
3,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root		
3	24	1/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2969			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		7/10/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in RAVALLI County in the City of FLORENCE

Location: TOWN PUMP INC FLORENCE
5495 US HIGHWAY 93 N
FLORENCE, MT 59833 RAVALLI

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 41-12720
Last Inspected On: 2/5/2016
Operating Permit Renewal Date: 5/27/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	24	1/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2970			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/10/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root		
5	16	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4192			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/6/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	16	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4193			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/6/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	16	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4194			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/6/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in RAVALLI County in the City of FLORENCE

Location: TOWN PUMP INC FLORENCE
5495 US HIGHWAY 93 N
FLORENCE, MT 59833 RAVALLI

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 41-12720
Last Inspected On: 2/5/2016
Operating Permit Renewal Date: 5/27/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	16	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4195			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/6/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	16	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4196			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/6/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
10	16	5/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4197			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/6/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		12/27/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in RAVALLI County in the City of HAMILTON

Location: TOWN PUMP INC HAMILTON 2
932 S 1ST ST
HAMILTON, MT 59840 RAVALLI

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 41-00145
Last Inspected On: 1/18/2016
Operating Permit Renewal Date: 5/27/2019

Owners/Operators: Missoula Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	30	4/7/1986	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
2593			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/10/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		12/13/2006	TLS-350/Gilbarco EMC , Veeder Root		
2	32	4/7/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
2594			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/10/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		12/13/2006	TLS-350/Gilbarco EMC , Veeder Root		
3	32	4/7/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
2595			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/10/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000		12/14/2006	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in RAVALLI County in the City of HAMILTON

Location: TOWN PUMP INC HAMILTON 2
932 S 1ST ST
HAMILTON, MT 59840 RAVALLI

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 41-00145
Last Inspected On: 1/18/2016
Operating Permit Renewal Date: 5/27/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	32	4/7/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
2596			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		7/10/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000		12/14/2006	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in RAVALLI County in the City of HAMILTON

Location: DAVISONS EXXON SERVICE
410 S 1ST ST
HAMILTON, MT 59840 RAVALLI

Contact: Robert Davison, (406) 363-1933

Sys Fac ID: 41-04846
Last Inspected On: 6/11/2015
Operating Permit Renewal Date: 8/6/2018

Owners/Operators: Davisons Exxon Service, Owner (406)-363-1933 410 S 1ST ST HAMILTON MT 59840-2809

Jack Davison, UST Class A Operator
Jack Davison, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	23	3/3/1993	Bare Steel	Fiberglass Reinforced Plastic	
823	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		11/3/2009	Deferred	MLLD Line Tightness Testing	
20,000		6/8/2015			
6	23	3/3/1993	Bare Steel	Fiberglass Reinforced Plastic	
822	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/23/2009	Deferred	MLLD Line Tightness Testing	
5,000		6/8/2015			
8	23	3/1/1993	Bare Steel	Fiberglass Reinforced Plastic	
821	Yes		None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/3/2009	Deferred	MLLD Line Tightness Testing	
2,678		6/8/2015			
9	23	3/1/1993	Bare Steel	Fiberglass Reinforced Plastic	
820	Yes		None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/3/2009	Deferred	MLLD Line Tightness Testing	
7,050		7/21/2011			

Facility Summary in RAVALLI County in the City of HAMILTON

Location: ANGLERS ROOST LLP
815 US HIGHWAY 93 S
HAMILTON, MT 59840 RAVALLI

Sys Fac ID: 41-05798
Last Inspected On: 7/17/2015
Operating Permit Renewal Date:

Contact: John G Cawley, (406) 363-1268

Owners/Operators: Anglers Roost LLP, Owner (406)-363-1268 815 US HIGHWAY 93 S
HAMILTON MT 59840-9746

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	4/25/1984	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3470			Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/29/2015	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000					
2	31	4/4/1985	Bare Steel	Steel	Flapper Valve (Auto Shutoff)
3471			Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		5/29/2015	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000					

Facility Summary in RAVALLI County in the City of HAMILTON

Location: RAVALLI COUNTY ROAD DEPT HAMILTON
244 FAIRGROUNDS RD
HAMILTON, MT 59840 RAVALLI

Contact: Becky Hankinson, (406) 363-2733

Sys Fac ID: 41-06546
Last Inspected On: 5/4/2016
Operating Permit Renewal Date: 8/5/2019

Owners/Operators: Ravalli County Sanitarian, Owner (406)-375-6200 205 BEDFORD ST HAMILTON MT 59840-2853

Jim Bryan, UST Class A Operator
Jim Bryan, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	25	11/1/1991	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1831			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		5/4/2016	Automatic Tank Gauging 0.2	Deferred	
12,000			TS-1001 , Incon		

Facility Summary in RAVALLI County in the City of HAMILTON

Location: TOWN PUMP INC HAMILTON 1
1117 N 1ST ST
HAMILTON, MT 59840 RAVALLI

Contact: Roger Hovis, (406) 363-4643

Sys Fac ID: 41-09670
Last Inspected On: 1/19/2016
Operating Permit Renewal Date: 5/27/2019

Owners/Operators: Save O Mat Corporations, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Shawn Gelling, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Shawn Gelling, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	2/23/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2597			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/22/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		1/5/2010	TLS-350/Gilbarco EMC , Veeder Root		
2	29	2/23/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2598			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/22/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		1/5/2010	TLS-350/Gilbarco EMC , Veeder Root		
3	29	2/23/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2599			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/22/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		1/5/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in RAVALLI County in the City of HAMILTON

Location: TOWN PUMP INC HAMILTON 1
1117 N 1ST ST
HAMILTON, MT 59840 RAVALLI

Contact: Roger Hovis, (406) 363-4643

Sys Fac ID: 41-09670
Last Inspected On: 1/19/2016
Operating Permit Renewal Date: 5/27/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	29	2/23/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2600			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		7/22/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		1/5/2010	TLS-350/Gilbarco EMC , Veeder Root		
5	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4490			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/6/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		1/5/2010	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4491			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/6/2010	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		1/5/2010	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in RAVALLI County in the City of HAMILTON

Location: MARCUS DALY MEMORIAL HOSPITAL
1200 WESTWOOD DR
HAMILTON, MT 59840 RAVALLI

Contact: Gary Schultz, (406) 325-4451

Sys Fac ID: 41-12767
Last Inspected On: 1/30/2015
Operating Permit Renewal Date: 2/13/2018

Owners/Operators: Marcus Daly Memorial Hospital, Owner (406)-363-2211 1200 WESTWOOD DR HAMILTON MT 59840-2345

Eric Etter, UST Class A Operator
Michael Heller, UST Class A Operator
Gary Schulz, UST Class A Operator
Eugene Morin, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	04	8/1/2012	Concrete	Flexible Plastic	
5376	Yes	8/28/2014	None	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
2,000			TLS-300 , Veeder Root		

Facility Summary in RAVALLI County in the City of HAMILTON

Location: RIVERSIDE CONOCO
1987 N 1ST ST
HAMILTON, MT 59840 RAVALLI
Contact: (406) 363-3703

Sys Fac ID: 41-13588
Last Inspected On: 10/3/2014
Operating Permit Renewal Date: 3/25/2018

Owners/Operators: West Fork Holdings LLC, Owner (406)-375-0554 LONE PINE CONOCO
504 US HIGHWAY 93 S
HAMILTON MT 59840-8967

Brian R Hawkes, UST Class A Operator
Steven Hawkes, UST Class A Operator
Brian R Hawkes, UST Class B Operator
Steven Hawkes, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	18	6/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3262			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000		8/13/2014		Automatic Tank Gauging 0.2	
3	18	6/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3263			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000		8/13/2014		Automatic Tank Gauging 0.2	
4	18	6/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3264			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000		8/13/2014		Automatic Tank Gauging 0.2	

Facility Summary in RAVALLI County in the City of HAMILTON

Location: RIVERSIDE CONOCO
1987 N 1ST ST
HAMILTON, MT 59840 RAVALLI
Contact: (406) 363-3703

Sys Fac ID: 41-13588
Last Inspected On: 10/3/2014
Operating Permit Renewal Date: 3/25/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	10	12/7/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5061			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000		8/13/2014		Automatic Tank Gauging 0.2	

Facility Summary in RAVALLI County in the City of HAMILTON

Location: Quality Used Cars
400 N 1ST ST
HAMILTON, MT 59840 RAVALLI

Contact: Robert Bapties, (406) 363-0188

Sys Fac ID: 41-13769
Last Inspected On: 3/5/2015
Operating Permit Renewal Date:

Owners/Operators: Quality Investments, Owner (208)-756-2236 PO BOX Q
SALMON ID 83467

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	3/5/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3436			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					
2	19	3/5/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3437			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000					
3	19	3/5/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3438			None	Double-Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000					

Facility Summary in RAVALLI County in the City of HAMILTON

Location: LONE PINE INC
504 US HIGHWAY 93 S
HAMILTON, MT 59840 RAVALLI

Contact: Brian R Hawkes, (406) 375-0554

Sys Fac ID: 56-13874
Last Inspected On: 12/8/2015
Operating Permit Renewal Date: 2/17/2019

Owners/Operators: West Fork Holdings LLC, Owner (406)-375-0554 LONE PINE CONOCO
504 US HIGHWAY 93 S
HAMILTON MT 59840-8967

Brian R Hawkes, UST Class A Operator
Steven Hawkes, UST Class A Operator
Brian R Hawkes, UST Class B Operator
Steven Hawkes, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	18	7/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3513			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	18	7/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3514			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	18	7/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3515			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in RAVALLI County in the City of STEVENSVILLE

Location: THREE MILE TRADING CO
899 THREE MILE CREEK RD
STEVENSVILLE, MT 59870 RAVALLI

Sys Fac ID: 41-00170
Last Inspected On: 12/22/2015
Operating Permit Renewal Date: 2/9/2019

Contact: Three Mile Trd Company, (406) 777-3365

Owners/Operators:

Gayla M Cleveland, Owner	(406)-777-5153	1407 WHEELBARROW CR RD STEVENSVILLE MT 59870
Russell A Cleveland, Owner	(406)-777-5153	1407 WHEELBARROW CR RD STEVENSVILLE MT 59870

Russell A Cleveland, UST Class A Operator
Russell A Cleveland, UST Class B Operator
Russell A Cleveland, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	3/1/1993	Cathodically Protected Steel	Steel	Positive Shutoff, High Level Alarm
2117			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
2,000			Gilbarco EMC Basic , Gilbarco		
2	23	3/1/1993	Cathodically Protected Steel	Steel	Positive Shutoff, High Level Alarm
2116			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		12/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
5,000			Gilbarco EMC Basic , Gilbarco		
4	23	3/1/1993	Cathodically Protected Steel	Steel	Positive Shutoff, High Level Alarm
2115			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/15/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
5,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in RAVALLI County in the City of STEVENSVILLE

Location: EASTSIDE COUNTRY STORE & DELI
2693 EASTSIDE HWY
STEVENSVILLE, MT 59870 RAVALLI
Contact: (406) 777-5672

Sys Fac ID: 41-10286
Last Inspected On: 4/29/2014
Operating Permit Renewal Date: 9/25/2017

Owners/Operators: Eastside Country Store Inc, Owner (406)-777-5672 2693 EASTSIDE HWY STEVENSVILLE MT 59870

Julia Cooke, UST Class A Operator
Clarence Nancy Rainforth, UST Class A Operator
Julia Cooke, UST Class B Operator
Clarence Nancy Rainforth, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	17	12/1/1998	Unknown	Flexible Plastic	High Level Alarm
3614	Yes	9/5/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
4	17	12/1/1998	Unknown	Flexible Plastic	High Level Alarm
3615	Yes	9/5/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
3,000			TLS-350/Gilbarco EMC , Veeder Root		
5	17	12/1/1998	Unknown	Flexible Plastic	High Level Alarm
3809	Yes	9/5/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
3,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in RAVALLI County in the City of STEVENSVILLE

Location: MOUNTAIN WEST CO OP STEVENSVILLE
115 MAIN ST
STEVENSVILLE, MT 59870 RAVALLI

Contact: Kyle Stensrud, (406) 777-5441

Sys Fac ID: 41-10330
Last Inspected On: 6/17/2014
Operating Permit Renewal Date: 6/20/2017

Owners/Operators: Mountain West Coop - Missoula, Owner (406)-543-8383 4570 N RESERVE ST
MISSOULA MT 59808-1411

Will Dukart, UST Class A Operator
Dusty Smith, UST Class A Operator
John Thompson, UST Class A Operator
Mary Fleming, UST Class B Operator
Alicia Milner, UST Class B Operator
Laura Tackes, UST Class B Operator
John Thompson, UST Class B Operator
Will Dukart, UST Class B Global Operator
Dusty Smith, UST Class B Global Operator
John Thompson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	38	2/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
911			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/30/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	38	2/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
909			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/30/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	38	2/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
910			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/30/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in RAVALLI County in the City of STEVENSVILLE

Location: MOUNTAIN WEST CO OP STEVENSVILLE
115 MAIN ST
STEVENSVILLE, MT 59870 RAVALLI

Contact: Kyle Stensrud, (406) 777-5441

Sys Fac ID: 41-10330
Last Inspected On: 6/17/2014
Operating Permit Renewal Date: 6/20/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	38	2/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
907			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/30/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	38	2/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
908			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/30/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	38	2/14/1978	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
906			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/30/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	18	12/29/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
912			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/30/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in RAVALLI County in the City of STEVENSVILLE

Location: CJ'S DEN
324 MAIN ST
STEVENSVILLE, MT 59870 RAVALLI
Contact: Cody Omlid, (406) 777-2337

Sys Fac ID: 41-11429
Last Inspected On: 10/20/2015
Operating Permit Renewal Date:

Owners/Operators: Cody Omlid, Owner (406)-777-2337 324 MAIN STREET STEVENSVILLE MT 59870

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	10/28/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	
2346			None	None	Yes
Temporarily Out of Use				U.S. Suction	
Gasoline		10/20/2015	Automatic Tank Gauging 0.1, Vapor Monitoring	MLLD Line Tightness Testing	
6,000					
2	26	10/28/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	
2347			None	None	Yes
Temporarily Out of Use				U.S. Suction	
Gasoline		10/20/2015	Automatic Tank Gauging 0.1, Vapor Monitoring	MLLD Line Tightness Testing	
6,000					
3	26	10/28/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	
2348			None	None	Yes
Temporarily Out of Use				U.S. Suction	
Gasoline		10/20/2015	Automatic Tank Gauging 0.1, Vapor Monitoring	Vapor Monitoring, MLLD Line Tightness Testing	
2,000					

Facility Summary in RAVALLI County in the City of STEVENSVILLE

Location: OLES COUNTRY STORE 15
3912 US HIGHWAY 93 N
STEVENSVILLE, MT 59870 RAVALLI

Contact: Vic Ralls, (406) 777-1179

Sys Fac ID: 41-13686
Last Inspected On: 2/17/2014
Operating Permit Renewal Date: 4/8/2017

Owners/Operators: Ralls Inc, Owner (406)-777-1179 3912 US HIGHWAY 93 N STEVENSVILLE MT 59870-6425

ROB RALLS, UST Class A Operator
ROB RALLS, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	5/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3316			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
12,000		4/7/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	20	5/17/1996	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3317			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
8,000		4/7/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	20	5/17/1996	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3318			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
3,000		4/7/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in RAVALLI County in the City of SULA

Location: SULA COUNTRY STORE LLC
7060 US HIGHWAY 93 S
SULA, MT 59871 RAVALLI

Contact: John Kingsbury, (406) 821-1041

Sys Fac ID: 41-10411
Last Inspected On: 8/23/2016
Operating Permit Renewal Date: 10/29/2019

Owners/Operators:

Thomcorp LLC, Owner	(406)-821-1041	KURT & DEBORAH THOMAS PO BOX 30 SULA MT 59871-0030
Sula Store LLC, Operator	(406)-821-1041	PO BOX 30 SULA MT 59871-0030

John Kingsbury, UST Class A Operator
Nancy Kingsbury, UST Class A Operator
John Kingsbury, UST Class B Global Operator
Nancy Kingsbury, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	18	3/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3485		8/15/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		
4	18	3/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3486		8/15/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			Gilbarco EMC Basic , Gilbarco		
5	18	3/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3487		8/15/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in RAVALLI County in the City of SULA

Location: LOST TRAIL POWDER MOUNTAIN
7674 US HIGHWAY 93 S
SULA, MT 59871 RAVALLI
Contact: (406) 821-3508

Sys Fac ID: 41-11692
Last Inspected On: 9/4/2014
Operating Permit Renewal Date: 10/3/2017

Owners/Operators: Lost Trail Ski Area Inc, Owner (406)-821-3211 PO BOX 311
CONNER MT 59827-0311

Judy Grasser, UST Class A Operator
Scott Grasser, UST Class A Operator
Judy Grasser, UST Class B Operator
Scott Grasser, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	1/1/1990	Cathodically Protected Steel	No Piping	Flapper Valve (Auto Shutoff)
2351			None	None	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Diesel		9/11/2014	Automatic Tank Gauging 0.2		
8,000			TLS-350/Gilbarco EMC , Veeder Root		
2	24	10/1/1992	Steel Clad	No Piping	Flapper Valve (Auto Shutoff)
2352			None	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2		
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in RAVALLI County in the City of VICTOR

Location: VICTOR SINCLAIR
2381 US HWY 93 N PO BOX 820
VICTOR, MT 59875 RAVALLI

Contact: Troy Clark, (406) 369-2772

Sys Fac ID: 41-13288
Last Inspected On: 1/27/2014
Operating Permit Renewal Date: 5/6/2017

Owners/Operators:

GEQ Inc, Owner	(406)-369-2772	PO BOX 820 VICTOR MT 59875
Teresa Clark, Operator	(406)-369-2772	PO BOX 820 VICTOR MT 59875
Troy Clark, Operator	(406)-369-2772	PO BOX 820 VICTOR MT 59875

Teresa Clark, UST Class A Operator
Troy Clark, UST Class A Operator
Shean Merwin, UST Class A Operator
Charles Robinson, UST Class A Operator
Teresa Clark, UST Class B Operator
Troy Clark, UST Class B Operator
Kevin Howe, UST Class B Operator
Charles Robinson, UST Class B Operator
Barbara Oliver, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	11/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3174			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		11/8/2013	Gilbarco EMC Basic , Gilbarco		
2	23	11/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3175			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		11/8/2013	Gilbarco EMC Basic , Gilbarco		

Facility Summary in RAVALLI County in the City of VICTOR

Location: VICTOR SINCLAIR
2381 US HWY 93 N PO BOX 820
VICTOR, MT 59875 RAVALLI
Contact: Troy Clark, (406) 369-2772

Sys Fac ID: 41-13288
Last Inspected On: 1/27/2014
Operating Permit Renewal Date: 5/6/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	23	11/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3176			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		11/8/2013	Gilbarco EMC Basic , Gilbarco		
4	23	11/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
3177			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		11/8/2013	Gilbarco EMC Basic , Gilbarco		

Facility Summary in RAVALLI County in the City of VICTOR

Location: TOWN PUMP OF WOODSIDE
#6 WOODSIDE CUTOFF RD
VICTOR, MT 59875 RAVALLI

Contact: Doug Dodge, (406) 497-6700

Sys Fac ID: 60-15155
Last Inspected On: 11/2/2015
Operating Permit Renewal Date: 1/31/2019

Owners/Operators: Manhattan Holdings LLC, Owner (406)-497-6946 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	06	9/9/2010	Fiberglass Reinforced Plastic	Fiberglass	Ball Float Valve
5241			Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable, Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000		9/16/2010	TLS-350/Gilbarco EMC , Veeder Root		
2	06	9/9/2010	Fiberglass Reinforced Plastic	Fiberglass	Ball Float Valve
5242			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable, Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		9/16/2010	TLS-350/Gilbarco EMC , Veeder Root		
3	06	9/9/2010	Fiberglass Reinforced Plastic	Fiberglass	Ball Float Valve
5243			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable, Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		9/16/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in RAVALLI County in the City of VICTOR

Location: TOWN PUMP OF WOODSIDE
#6 WOODSIDE CUTOFF RD
VICTOR, MT 59875 RAVALLI

Contact: Doug Dodge, (406) 497-6700

Sys Fac ID: 60-15155
Last Inspected On: 11/2/2015
Operating Permit Renewal Date: 1/31/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	06	9/9/2010	Fiberglass Reinforced Plastic	Fiberglass	Ball Float Valve
5244			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable, Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		9/16/2010	TLS-350/Gilbarco EMC , Veeder Root		
5	06	9/9/2010	Fiberglass Reinforced Plastic	Fiberglass	Ball Float Valve
5245			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable, Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		9/16/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in RICHLAND County in the City of FAIRVIEW

Location: HORIZON RESOURCES FAIRVIEW STORE
605 S ELLERY AVE
FAIRVIEW, MT 59221 RICHLAND
Contact: Darcy Yabon, (406) 742-5273

Sys Fac ID: 42-03363
Last Inspected On: 3/28/2014
Operating Permit Renewal Date: 7/24/2017

Owners/Operators: Horizon Resources, Owner (701)-572-2172 317 2ND ST W
WILLISTON ND 58011

Ronald Rolle, UST Class A Operator
Darcie Yadon, UST Class A Operator
Ronald Rolle, UST Class B Operator
Darcie Yadon, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	17	12/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3722			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/31/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
7,800		8/5/2009	TLS-450 , Veeder Root	Continuous Interstitial Monitor	
8	17	12/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3723			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/31/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,200		8/5/2009	TLS-450 , Veeder Root	Continuous Interstitial Monitor	
9	17	12/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3724			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		1/31/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,500		8/5/2009	TLS-450 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in RICHLAND County in the City of FAIRVIEW

Location: HORIZON RESOURCES FAIRVIEW STORE
605 S ELLERY AVE
FAIRVIEW, MT 59221 RICHLAND

Contact: Darcy Yabon, (406) 742-5273

Sys Fac ID: 42-03363
Last Inspected On: 3/28/2014
Operating Permit Renewal Date: 7/24/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	17	12/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3725			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		1/31/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,500		8/5/2009	TLS-450 , Veeder Root	Continuous Interstitial Monitor	
15	05	1/2/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5274			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
16	05	1/2/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5275			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in RICHLAND County in the City of FAIRVIEW

Location: LOAF & JUG 714
516 S ELLERY AVE
FAIRVIEW, MT 59221 RICHLAND

Contact: Billie Martin, (406) 747-5024

Sys Fac ID: 42-03914
Last Inspected On: 8/24/2016
Operating Permit Renewal Date: 10/4/2019

Owners/Operators: Mini Mart Inc dba Loaf 'N Jug, Owner (719)-948-3071 442 KEELER PKWY
PUEBLO CO 81001-4813

Randal Liebnow, UST Class A Operator
John Sumowski, UST Class A Operator
Derrick Trimble, UST Class A Operator
Richie Lesser, UST Class B Operator
Billie Martin, UST Class B Operator
Timothy Osterman, UST Class B Operator
Stevie Ulstad, UST Class B Operator
CARL WATKINS, UST Class B Operator
Norma Carlson, UST Class B Global Operator
Casey Jambretz, UST Class B Global Operator
Randal Liebnow, UST Class B Global Operator
Anthony Mosmiller, UST Class B Global Operator
Toni Mullen, UST Class B Global Operator
Hiede Richardson, UST Class B Global Operator
Derrick Trimble, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	03	3/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5410			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
7	03	3/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5411			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in RICHLAND County in the City of FAIRVIEW

Location: LOAF & JUG 714
516 S ELLERY AVE
FAIRVIEW, MT 59221 RICHLAND

Contact: Billie Martin, (406) 747-5024

Sys Fac ID: 42-03914
Last Inspected On: 8/24/2016
Operating Permit Renewal Date: 10/4/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	03	3/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5412			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in RICHLAND County in the City of LAMBERT

Location: NORTANA GRAIN CO
100 1ST AVE SW
LAMBERT, MT 59243 RICHLAND
Contact: Sheldon Heringer, (406) 774-3331

Sys Fac ID: 42-00317
Last Inspected On: 10/27/2015
Operating Permit Renewal Date: 3/4/2019

Owners/Operators: Nortana Grain Co, Owner (406)-774-3331 PO BOX 177
LAMBERT MT 59243-0177

Mike Arneson, UST Class A Operator
Shane Keller, UST Class A Operator
Mike Arneson, UST Class B Operator
Shane Keller, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	07	3/6/2009	Concrete	Flexible Plastic	
5201	Yes		None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
21,000		4/9/2015		Continuous Interstitial Monitor	
6	07	3/6/2009	Concrete	Flexible Plastic	
5202	Yes		None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
21,000		4/9/2015		Continuous Interstitial Monitor	
7	07	3/6/2009	Concrete	Flexible Plastic	
5203	Yes		None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
13,000		4/9/2015		Continuous Interstitial Monitor	
8	07	3/6/2009	Concrete	Flexible Plastic	
5204	Yes		None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
15,000		4/9/2015		Continuous Interstitial Monitor	

Facility Summary in RICHLAND County in the City of LAMBERT

Location: NORTANA GRAIN CO
100 1ST AVE SW
LAMBERT, MT 59243 RICHLAND

Contact: Sheldon Heringer, (406) 774-3331

Sys Fac ID: 42-00317
Last Inspected On: 10/27/2015
Operating Permit Renewal Date: 3/4/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	07	3/6/2009	Concrete	Flexible Plastic	
5205	Yes		None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
21,000		4/9/2015		Continuous Interstitial Monitor	

Facility Summary in RICHLAND County in the City of SAVAGE

Location: VALLEY FUEL SUPPLY
MT HIGHWAY 16
SAVAGE, MT 59262 RICHLAND
Contact: Myron Smith, (406) 776-2354

Sys Fac ID: 42-03815
Last Inspected On: 12/30/2014
Operating Permit Renewal Date: 3/14/2018

Owners/Operators: Gregory Cross, Owner (406)-252-5519 PO BOX 1078
BILLINGS MT 59103-1078

Gregory Cross, UST Class A Operator
Timothy Fife, UST Class A Operator
RJ Serpe, UST Class A Operator
RJ Serpe, UST Class B Global Operator
Ron Serpe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	18	8/25/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
780			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/18/2008	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		12/1/2011	TLS-350/Gilbarco EMC , Veeder Root		
4	18	8/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
781			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/18/2008	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		11/13/2011	TLS-350/Gilbarco EMC , Veeder Root		
5	18	8/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
782			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/18/2008	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
3,000		8/9/2011	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in RICHLAND County in the City of SIDNEY

Location: LOWER YELLOWSTONE RURAL ELECTRIC ASSOCIATION INC
MT HIGHWAY 16 NW
SIDNEY, MT 59270 RICHLAND

Contact: Roger Marker, (406) 488-1602

Sys Fac ID: 42-00001
Last Inspected On: 4/29/2015
Operating Permit Renewal Date: 9/29/2018

Owners/Operators: Lower Yellowstone Rural Electric Association Inc, Owner (406)-482-1602 PO BOX 1047 SIDNEY MT 59270-1047

Bodrey Kindopp, UST Class A Operator
Justin King, UST Class A Operator
Mike Eberling, UST Class B Global Operator
Justin King, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	23	10/1/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1558			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Manual Interstitial Monitor	Not Listed	
8,000					
6	23	10/1/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1559			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Interstitial Monitor	Not Listed	
4,000					

Facility Summary in RICHLAND County in the City of SIDNEY

Location: SWELEY OIL INC BULK PLANT
1123 10TH AVE SE
SIDNEY, MT 59270 RICHLAND
Contact: Mike Arneson, (406) 433-2508

Sys Fac ID: 42-00183
Last Inspected On: 1/5/2016
Operating Permit Renewal Date: 2/18/2019

Owners/Operators: Nortana Grain Co, Owner (406)-774-3331 PO BOX 177
LAMBERT MT 59243-0177

Mike Arneson, UST Class A Operator
John Sweley, UST Class A Operator
Mike Arneson, UST Class B Operator
John Sweley, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	6/16/1998	Bare Steel	Flexible Plastic	
2076	Yes	4/14/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
17,000			ILS-350 , Veeder Root		
5	18	6/16/1998	Bare Steel	Flexible Plastic	
2077	Yes	4/14/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
17,000			ILS-350 , Veeder Root		

Facility Summary in RICHLAND County in the City of SIDNEY

Location: SIDNEY CARDTROL
901 3RD ST NE
SIDNEY, MT 59270 RICHLAND
Contact: James Steffen, (406) 482-4376

Sys Fac ID: 42-02184
Last Inspected On: 1/3/2014
Operating Permit Renewal Date: 4/30/2017

Owners/Operators: Gregory Cross, Owner (406)-252-5519 PO BOX 1078
BILLINGS MT 59103-1078

Gregory Cross, UST Class A Operator
Timothy Fife, UST Class A Operator
Larry Garman, UST Class A Operator
RJ Serpe, UST Class A Operator
Larry Garman, UST Class B Global Operator
RJ Serpe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	34	4/17/1982	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
776			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		1/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					
2	34	4/17/1982	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
777			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		1/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					
3	34	4/17/1982	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
778			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					

Facility Summary in RICHLAND County in the City of SIDNEY

Location: SIDNEY CARDTROL
901 3RD ST NE
SIDNEY, MT 59270 RICHLAND
Contact: James Steffen, (406) 482-4376

Sys Fac ID: 42-02184
Last Inspected On: 1/3/2014
Operating Permit Renewal Date: 4/30/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	34	4/17/1982	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
779			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					

Facility Summary in RICHLAND County in the City of SIDNEY

Location: METZ FUEL & SERVICE
625 S CENTRAL AVE
SIDNEY, MT 59270 RICHLAND
Contact: Jim Metz, (406) 433-2402

Sys Fac ID: 42-03224
Last Inspected On: 5/15/2015
Operating Permit Renewal Date: 9/29/2018

Owners/Operators:

Metz Fuel Service Inc, Owner	(406)-433-2402	625 S CENTRAL SIDNEY MT 59270
Jim Metz, Operator	(406)-433-2402	625 S CENTRAL AVE SIDNEY MT 59270

Jim Metz, UST Class A Operator
Timothy Thogersen, UST Class A Operator
Timothy Thogersen, UST Class B Operator
Jim Metz, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	25	7/11/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2112		10/11/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Manual Interstitial Monitor	Continuous Interstitial Monitor	
8,000					
11	25	7/11/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2113		10/11/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Manual Interstitial Monitor	Continuous Interstitial Monitor	
8,000					
12	25	7/11/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2111			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Interstitial Monitor	Deferred	
8,000					

Facility Summary in RICHLAND County in the City of SIDNEY

Location: METZ FUEL & SERVICE
625 S CENTRAL AVE
SIDNEY, MT 59270 RICHLAND
Contact: Jim Metz, (406) 433-2402

Sys Fac ID: 42-03224
Last Inspected On: 5/15/2015
Operating Permit Renewal Date: 9/29/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
13	25	7/11/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2110			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Interstitial Monitor	Deferred	
4,000					

Facility Summary in RICHLAND County in the City of SIDNEY

Location: CENEX HARVEST STATES
1281 S CENTRAL AVE
SIDNEY, MT 59270 RICHLAND
Contact: Sean Dobbs, (406) 433-1401

Sys Fac ID: 42-03364
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 2/11/2019

Owners/Operators: Cenex Harvest States, Owner (406)-433-1401 PO BOX 1440 MILES CITY MT 59301
David Corbin, UST Class A Operator
David Corbin, UST Class B Operator
Sean Dodds, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	35	6/25/1981	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
605			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/4/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
2	35	6/25/1981	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4046			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/4/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
4	35	6/25/1981	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
602			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
>E15		9/4/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in RICHLAND County in the City of SIDNEY

Location: CENEX HARVEST STATES
1281 S CENTRAL AVE
SIDNEY, MT 59270 RICHLAND
Contact: Sean Dobbs, (406) 433-1401

Sys Fac ID: 42-03364
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 2/11/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	35	6/25/1981	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
603			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/4/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
6	35	6/25/1981	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
604			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/4/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in RICHLAND County in the City of SIDNEY

Location: SIDNEY AIRPORT SERVICE
355 AIRPORT RD PO BOX 355
SIDNEY, MT 59270 RICHLAND

Contact: Barry Holzworth, (406) 480-2024

Sys Fac ID: 42-04444
Last Inspected On: 12/17/2015
Operating Permit Renewal Date: 2/12/2019

Owners/Operators: Sidney Airport Service, Owner (406)-488-4031 PO BOX 355
SIDNEY MT 59270-0355

Barry K Holzworth, UST Class A Operator
TJ Schwartz, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	17	4/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3969			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Other			Manual Interstitial Monitor	Deferred	
12,000					

Facility Summary in RICHLAND County in the City of SIDNEY

Location: LOAF 'N JUG #712
706 S CENTRAL AVE
SIDNEY, MT 59270 RICHLAND
Contact: Shirley Treece, (719) 948-5976

Sys Fac ID: 42-05084
Last Inspected On: 8/25/2016
Operating Permit Renewal Date: 10/4/2019

Owners/Operators: Mini Mart Inc dba Loaf 'N Jug, Owner (719)-948-3071 442 KEELER PKWY PUEBLO CO 81001-4813

Randal Liebnow, UST Class A Operator
Dalinda Rasmussen, UST Class A Operator
John Sumowski, UST Class A Operator
Derrick Trimble, UST Class A Operator
LAWRENCE WOOLARD, UST Class A Operator
Eileen Campbell, UST Class B Operator
Richie Lesser, UST Class B Operator
Mary Norgard, UST Class B Operator
Timothy Osterman, UST Class B Operator
Stevie Ulstad, UST Class B Operator
CARL WATKINS, UST Class B Operator
LAWRENCE WOOLARD, UST Class B Operator
Casey Jambretz, UST Class B Global Operator
Randal Liebnow, UST Class B Global Operator
Anthony Mosmiller, UST Class B Global Operator
Toni Mullen, UST Class B Global Operator
Dalinda Rasmussen, UST Class B Global Operator
Hiede Richardson, UST Class B Global Operator
Derrick Trimble, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	40	4/24/1976	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4586			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasohol/Ethanol		10/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in RICHLAND County in the City of SIDNEY

Location: LOAF 'N JUG #712
706 S CENTRAL AVE
SIDNEY, MT 59270 RICHLAND
Contact: Shirley Treece, (719) 948-5976

Sys Fac ID: 42-05084
Last Inspected On: 8/25/2016
Operating Permit Renewal Date: 10/4/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
2	40	4/24/1976	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4587			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasohol/Ethanol		10/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	40	4/24/1976	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4588			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		10/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in RICHLAND County in the City of SIDNEY

Location: SIDNEY HEALTH CENTER
216 14TH AVE SW
SIDNEY, MT 59270 RICHLAND

Contact: Dan Schneider, (406) 482-2120

Sys Fac ID: 42-06159
Last Inspected On: 5/9/2015
Operating Permit Renewal Date: 9/14/2018

Owners/Operators: Sidney Health Center Inc, Owner (406)-482-2120 216 14TH AVE SW SIDNEY MT 59270-3519

Mark Delaney, UST Class A Operator
Mark Delaney, UST Class B Operator
Robert Jes, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	19	9/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
700		8/13/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel		4/19/2012	Manual Interstitial Monitor	Continuous Interstitial Monitor	
4,000		3/18/2009	ILS-350 , Veeder Root		

Facility Summary in RICHLAND County in the City of SIDNEY

Location: SUPERPUMPER #23 SIDNEY
902 S CENTRAL AVE
SIDNEY, MT 59270 RICHLAND
Contact: Kris Wolla, (701) 721-1000

Sys Fac ID: 42-09718
Last Inspected On: 5/24/2016
Operating Permit Renewal Date: 6/3/2019

Owners/Operators: Superpumper Inc, Owner (701)-852-0061 PO BOX 1847
MINOT ND 58702-1847

Shane Farstad, UST Class A Operator
Kristopher J Wolla, UST Class A Operator
Al Erickson, UST Class B Operator
Susan Hurley, UST Class B Operator
Lory Polensky, UST Class B Operator
Jessica Shaffer, UST Class B Operator
Shane Farstad, UST Class B Global Operator
Greg Schimetz, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	01	11/16/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5595		10/22/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	Yes
7	01	11/16/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5596		10/22/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TS-550 EVO , Incon	Continuous Interstitial Monitor	Yes
8	01	11/16/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5597		10/22/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TS-550 EVO , Incon	Continuous Interstitial Monitor	Yes

Facility Summary in RICHLAND County in the City of SIDNEY

Location: MILLERS CORNER
2201 W HOLLY ST
SIDNEY, MT 59270 RICHLAND
Contact: Nitin Patel, (765) 748-9726

Sys Fac ID: 56-14071
Last Inspected On: 3/19/2014
Operating Permit Renewal Date: 4/14/2017

Owners/Operators: Millers Corner LLC, Owner (406)-433-4041 324 23RD AVE NW SIDNEY MT 59270-3579

Gregory Miller, UST Class A Operator
Nitin Patel, UST Class A Operator
Nitin Patel, UST Class B Operator
Gregory Miller, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	13	2/6/2003	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4797			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		3/19/2014		Continuous Interstitial Monitor	
2	13	2/6/2003	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4798			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		3/19/2014		Continuous Interstitial Monitor	
3	13	2/6/2003	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4799			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		3/19/2014		Continuous Interstitial Monitor	

Facility Summary in RICHLAND County in the City of SIDNEY

Location: MILLERS CORNER
2201 W HOLLY ST
SIDNEY, MT 59270 RICHLAND
Contact: Nitin Patel, (765) 748-9726

Sys Fac ID: 56-14071
Last Inspected On: 3/19/2014
Operating Permit Renewal Date: 4/14/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	04	8/1/2012	Cathodically Protected Steel	Flexible Plastic	High Level Alarm, Flapper Valve (Auto Shutoff)
5387			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/19/2014	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		3/19/2014		Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in RICHLAND County in the City of SIDNEY

Location: TOWN PUMP OF SIDNEY #3
12280 HWY 200 UNIT 1
SIDNEY, MT 59270 RICHLAND
Contact: Charlie Anderson, (406) 497-6700

Sys Fac ID: 60-15241
Last Inspected On: 12/30/2014
Operating Permit Renewal Date: 1/14/2018

Owners/Operators: Western Catering Services Inc, Owner/Operator (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000
Charles A Armstrong, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	02	3/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5471		7/14/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
30,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Not Listed	
2	02	3/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5472		7/14/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
30,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Not Listed	
3	02	3/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5473		7/14/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
30,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Not Listed	

Facility Summary in RICHLAND County in the City of SIDNEY

Location: TOWN PUMP OF SIDNEY #3
12280 HWY 200 UNIT 1
SIDNEY, MT 59270 RICHLAND
Contact: Charlie Anderson, (406) 497-6700

Sys Fac ID: 60-15241
Last Inspected On: 12/30/2014
Operating Permit Renewal Date: 1/14/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	02	3/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5474		7/14/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
30,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Not Listed	
5	02	3/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5475		7/14/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Not Listed	
6	02	3/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5476		7/14/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Not Listed	
7	02	3/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5477		7/14/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Not Listed	

Facility Summary in ROOSEVELT County in the City of BAINVILLE

Location: THE WELCOME STOP
209 N CLINTON ST HWY 2 PO BOX 32
BAINVILLE, MT 59212 ROOSEVELT

Contact: Kathi and John Gilligan, (406) 769-2000

Sys Fac ID: 43-13761
Last Inspected On: 2/4/2016
Operating Permit Renewal Date: 7/27/2019

Owners/Operators: Welcome Stop Retail LLC, Owner (480)-717-1776 PO BOX 171 BAINVILLE MT 59212

Melissa Bonebrake, UST Class A Operator
John Gilligan, UST Class A Operator
Wendy Warren, UST Class A Operator
Melissa Bonebrake, UST Class B Operator
Rachelle Ryder, UST Class B Operator
John Gilligan, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	18	12/1/1997	Unknown	Fiberglass Reinforced Plastic	
3387	Yes	7/12/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
10,000					
4	18	12/1/1997	Unknown	Fiberglass Reinforced Plastic	
3388	Yes	7/12/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
10,000					

Facility Summary in ROOSEVELT County in the City of BROCKTON

Location: B & S QUICK STOP
US HIGHWAY 2 & 7TH ST PO BOX 248
BROCKTON, MT 59213 ROOSEVELT
Contact: (406) 786-3237

Sys Fac ID: 43-02099
Last Inspected On: 1/5/2015
Operating Permit Renewal Date: 3/13/2018

Owners/Operators: Robert Nygard, Owner (406)-786-3229 PO BOX 248
BROCKTON MT 59213-0248

Robert Nygard, UST Class A Operator
Martin Dillon, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	6/12/1995	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1828			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Continuous Interstitial Monitor	Not Listed	
7,000					
2	21	6/12/1995	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1829			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Continuous Interstitial Monitor	Not Listed	
5,000					

Facility Summary in ROOSEVELT County in the City of BROCKTON

Location: CENEX HARVEST STATES BROCKTON ELEVATOR
600 S TRACKS RD
BROCKTON, MT 59213 ROOSEVELT

Contact: David Corbin, (406) 951-0997

Sys Fac ID: 43-13651
Last Inspected On: 8/20/2015
Operating Permit Renewal Date: 10/2/2018

Owners/Operators: CHS, Owner/Operator (406)-786-3221 PO BOX 86
BROCKTON MT 59213-0086

Shari Cameron, UST Class A Operator
David Corbin, UST Class A Operator
Ron Shanks, UST Class A Operator
Shari Cameron, UST Class B Operator
David Corbin, UST Class B Operator
Ron Shanks, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	33	1/1/1983	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4317		10/9/2012	None	Double-Walled	Yes
Currently in Use		1/1/1993	Not Required	Not Listed	Galvanic
Diesel		8/20/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
2	33	1/1/1983	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4318		10/9/2012	None	Double-Walled	Yes
Currently in Use		1/1/1993	Not Required	Not Listed	Galvanic
Gasoline		8/20/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
3	17	8/1/1999	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
4319		10/9/2012	None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		8/20/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
20,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in ROOSEVELT County in the City of BROCKTON

Location: CENEX HARVEST STATES BROCKTON ELEVATOR
600 S TRACKS RD
BROCKTON, MT 59213 ROOSEVELT

Contact: David Corbin, (406) 951-0997

Sys Fac ID: 43-13651
Last Inspected On: 8/20/2015
Operating Permit Renewal Date: 10/2/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	17	8/1/1999	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
4320		10/9/2012	None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		8/20/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in ROOSEVELT County in the City of CULBERTSON

Location: OELKERS SERVICE CENTER
4 6TH ST E
CULBERTSON, MT 59218 ROOSEVELT

Contact: Ronald K & Gordon O Oelkers, (406) 787-5315

Sys Fac ID: 43-00030
Last Inspected On: 8/28/2014
Operating Permit Renewal Date: 10/18/2017

Owners/Operators: Oelkers Inc, Owner (406)-787-5315 PO BOX 272
CULBERTSON MT 59218-0272

Ronald K Oelkers, UST Class A Operator
Gordon Oelkers, UST Class B Operator
Ronald K Oelkers, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	63	1/10/1953	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1774			Impressed Current	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		8/28/2014	Automatic Tank Gauging 0.2	Deferred	
3,000			TLS-350/Gilbarco EMC , Veeder Root		
2	63	1/10/1953	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1775			Impressed Current	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		8/28/2014	Automatic Tank Gauging 0.2	Deferred	
3,000			TLS-350/Gilbarco EMC , Veeder Root		
3	63	1/10/1953	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1776			Impressed Current	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		8/28/2014	Automatic Tank Gauging 0.2	Deferred	
3,000			TLS-350/Gilbarco EMC , Veeder Root		
4	63	1/10/1953	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1777			Impressed Current	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Other		8/28/2014	Automatic Tank Gauging 0.2	Deferred	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in ROOSEVELT County in the City of CULBERTSON

Location: VAL AM STOP & GO LLC
110 6TH ST W
CULBERTSON, MT 59218 ROOSEVELT

Contact: Shanonne Oelkers, (702) 802-1289

Sys Fac ID: 43-01991
Last Inspected On: 12/31/2014
Operating Permit Renewal Date: 2/11/2018

Owners/Operators:

Val Am Stop & Go LLC, Owner	(702)-802-1289	PO BOX 345 CULBERTSON MT 59218-0345
Shanonne Oelkers, Operator	(702)-802-1289	9014 PALAZZI STREET LAS VEGAS NV 89113
Shanonne Oelkers, UST Class A Operator		
Shanonne Oelkers, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	26	7/1/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3517			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Manual Interstitial Monitor	Not Listed	
6,000					
6	26	7/1/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3518			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Interstitial Monitor	Not Listed	
6,000					

Facility Summary in ROOSEVELT County in the City of CULBERTSON

Location: MISSOURI RIVER LOGISTICS
515 6TH ST E
CULBERTSON, MT 59218 ROOSEVELT
Contact: Dalton Dosch, (605) 360-3149

Sys Fac ID: 43-03015
Last Inspected On: 1/2/2014
Operating Permit Renewal Date:

Owners/Operators: Missouri River Logistics, Owner (605)-274-8630 39231 108TH ST FREDERICK SD 57441
Kendall Craig, Operator (406)-787-5751 2303 W 50TH ST SIOUX FALLS SD 57105

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	38	5/5/1978	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3732			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Gasoline		9/26/2012	Not Listed	Deferred	
6,000					
2	38	5/5/1978	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3733			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Gasoline		9/26/2012	Not Listed	Deferred	
6,000					
3	38	5/5/1978	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3734			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Diesel		9/26/2012	Not Listed	Deferred	
6,000					
4	38	5/5/1978	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3735			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Diesel		9/26/2012	Not Listed	Deferred	
6,000					

Facility Summary in ROOSEVELT County in the City of CULBERTSON

Location: TRIPLE M SINCLAIR
3RD W & 6TH ST
CULBERTSON, MT 59218 ROOSEVELT
Contact: Gordon Miller, (406) 787-6271

Sys Fac ID: 43-07758
Last Inspected On: 2/2/2016
Operating Permit Renewal Date: 5/12/2019

Owners/Operators: Miller Oil Co Inc Culbertson, Owner (406)-787-5230 PO BOX 408 CULBERTSON MT 59218-0408

Kevin Miller, UST Class A Operator
Matthew Miller, UST Class A Operator
Kevin Miller, UST Class B Operator
Matthew Miller, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	7/1/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3635		3/31/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/2/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TS-1001 , Incon	Continuous Interstitial Monitor	
2	31	7/1/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3636		3/31/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		2/2/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TS-1001 , Incon	Continuous Interstitial Monitor	
4	31	7/1/1985	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3637		3/31/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/2/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TS-1001 , Incon	Continuous Interstitial Monitor	

Facility Summary in ROOSEVELT County in the City of CULBERTSON

Location: MILLER OIL
2006 US HIGHWAY 2
CULBERTSON, MT 59218 ROOSEVELT
Contact: Gordon Miller, (406) 787-6271

Sys Fac ID: 60-15191
Last Inspected On: 4/21/2015
Operating Permit Renewal Date: 7/18/2018

Owners/Operators: Gordon Miller, Owner (406)-787-6271 120 EAST 1ST AVE CULBERTSON MT 59218
Kevin Miller, UST Class A Operator
Matthew Miller, UST Class A Operator
Kevin Miller, UST Class B Operator
Matthew Miller, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	05	9/1/2011	Unknown	Fiberglass	
5345	Yes	9/27/2011	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
15,000		9/17/2015	TLS-350/Gilbarco EMC , Veeder Root		Yes
2	05	9/1/2011	Unknown	Fiberglass	
5346	Yes	9/27/2011	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable, Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
15,000		9/17/2015	TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in ROOSEVELT County in the City of FROID

Location: FARMERS UNION OIL CO FROID
105 2ND AVE N
FROID, MT 59226 ROOSEVELT

Contact: Breuer Jeremy, (406) 963-7242

Sys Fac ID: 43-04415
Last Inspected On: 8/18/2015
Operating Permit Renewal Date: 10/21/2018

Owners/Operators: Farmers Union Oil Co Froid, Owner (406)-766-2339 PO BOX 68
FROID MT 59226-0068

Jeremy Breuer, UST Class A Operator
Monica Turnburke, UST Class A Operator
Jeremy Breuer, UST Class B Operator
Dan Kjelshus, UST Class B Operator
Steven Long, UST Class B Operator
Danny Mogen, UST Class B Operator
Michael Pallvoda, UST Class B Operator
Allen Richard, UST Class B Operator
Bruce Unger, UST Class B Operator
Allen Richard, UST Class B Global Operator
Weston Smith, UST Class B Global Operator
Monica Turnburke, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	26	10/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
958			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/17/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
7	26	10/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
959			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/17/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in ROOSEVELT County in the City of FROID

Location: FARMERS UNION OIL CO FROID
105 2ND AVE N
FROID, MT 59226 ROOSEVELT

Contact: Breuer Jeremy, (406) 963-7242

Sys Fac ID: 43-04415
Last Inspected On: 8/18/2015
Operating Permit Renewal Date: 10/21/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	26	10/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
960			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/17/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
9	26	10/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
961			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/17/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in ROOSEVELT County in the City of POPLAR

Location: TJS QUICK STOP
302 F ST
POPLAR, MT 59255 ROOSEVELT

Contact: Robert Atkinson, (406) 768-5225

Sys Fac ID: 43-02100
Last Inspected On: 6/16/1999
Operating Permit Renewal Date:

Owners/Operators: Tom Atkinson, Owner (406)-768-3371 PO BOX 6
POPLAR MT 59255-0006

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	20	8/1/1996	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
7,000					
4	20	8/1/1996	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
5,000					

Facility Summary in ROOSEVELT County in the City of POPLAR

Location: FARMERS UNION OIL CO POPLAR
US HIGHWAY 2 E
POPLAR, MT 59255 ROOSEVELT
Contact: (406) 768-3251

Sys Fac ID: 43-10278
Last Inspected On: 11/23/2015
Operating Permit Renewal Date: 3/3/2019

Owners/Operators: Farmers Union Oil Co Wolf Point, Owner (406)-653-1510 DBA AGLAND COOP
60 US HIGHWAY 2 E
WOLF POINT MT 59201-1942

Steven Long, UST Class A Operator
David Parsley, UST Class A Operator
Gary Sadler, UST Class A Operator
Monica Turnburke, UST Class A Operator
Steven Long, UST Class B Operator
Michael Pallvoda, UST Class B Operator
David Parsley, UST Class B Operator
Allen Richard, UST Class B Operator
Gary Sadler, UST Class B Operator
Bruce Unger, UST Class B Operator
Allen Richard, UST Class B Global Operator
Weston Smith, UST Class B Global Operator
Monica Turnburke, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	6/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
997			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		8/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		3/21/2007	TLS-350/Gilbarco EMC , Veeder Root		
2	22	6/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
998			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		8/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		3/21/2007	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in ROOSEVELT County in the City of POPLAR

Location: FARMERS UNION OIL CO POPLAR
US HIGHWAY 2 E
POPLAR, MT 59255 ROOSEVELT
Contact: (406) 768-3251

Sys Fac ID: 43-10278
Last Inspected On: 11/23/2015
Operating Permit Renewal Date: 3/3/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	32	10/27/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
993			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		8/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		3/21/2007	TLS-350/Gilbarco EMC , Veeder Root		
4	22	6/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
996			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		3/21/2007	TLS-350/Gilbarco EMC , Veeder Root		
5	32	10/27/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
994			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		8/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		3/21/2007	TLS-350/Gilbarco EMC , Veeder Root		
6	32	10/27/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
995			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		3/21/2007	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in ROOSEVELT County in the City of POPLAR

Location: TRIBAL EXPRESS
US HIGHWAY 2 E
POPLAR, MT 59255 ROOSEVELT

Sys Fac ID: 43-13620
Last Inspected On: 6/16/1999
Operating Permit Renewal Date:

Contact: Lynette Adams, (406) 768-5450

Owners/Operators: Fort Peck Assiniboine & Sioux Tribes, Owner (406)-768-5155 501 MEDICINE BEAR ROAD POPLAR MT 59255-1027

Anita Trice, UST Class A Operator
Anita Trice, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	10/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
			Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	Galvanic
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
10,000					
2	24	10/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
			Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Not Required	Pressurized	Galvanic
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
6,000					
3	24	10/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Pressurized	Galvanic
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
6,000					

Facility Summary in ROOSEVELT County in the City of POPLAR

Location: FORT PECK DETENTION CENTER
6256 BUFFALO DRIVE
POPLAR, MT 59255 ROOSEVELT

Contact: David Lezard, (406) 768-8389

Sys Fac ID: 60-15207
Last Inspected On: 9/29/2014
Operating Permit Renewal Date: 11/30/2017

Owners/Operators: Assiniboine & Sioux Tribes, Owner (406)-768-2389 501 MEDICINE BEAR RD POPLAR MT 59255

Anita Trice, UST Class A Operator
Anita Trice, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	03	9/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
5419		9/15/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
3,000			TLS-300 , Veeder Root	Not Listed	Yes

Facility Summary in ROOSEVELT County in the City of WOLF POINT

Location: L M CLAYTON AIRPORT
MT HIGHWAY 13
WOLF POINT, MT 59201 ROOSEVELT

Sys Fac ID: 43-00843
Last Inspected On: 4/28/2016
Operating Permit Renewal Date: 7/12/2019

Contact: T Scott Olsen,

Owners/Operators: City of Wolf Point, Owner (406)-653-1852 201 4TH AVE S
WOLF POINT MT 59201-1514

Richard L Isle, UST Class A Operator
Tom Romo, UST Class A Operator
Tom Romo, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	24	11/1/1992	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
648			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Aviation Gas		2/20/2013	Manual Interstitial Monitor	Deferred	
8,000					
6	24	11/1/1992	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
649			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Jet Fuel		2/20/2013	Manual Interstitial Monitor	Deferred	
4,000					

Facility Summary in ROOSEVELT County in the City of WOLF POINT

Location: FARMERS UNION OIL CO WESTSIDE STATION
60 US HIGHWAY 2 E
WOLF POINT, MT 59201 ROOSEVELT

Contact: Tom Dahl, (406) 653-1510

Sys Fac ID: 43-06866
Last Inspected On: 11/24/2015
Operating Permit Renewal Date: 3/4/2019

Owners/Operators: Farmers Union Oil Co Wolf Point, Owner (406)-653-1510 DBA AGLAND COOP
60 US HIGHWAY 2 E
WOLF POINT MT 59201-1942

Nancy Sietsema, UST Class A Operator
Monica Turnburke, UST Class A Operator
Steven Long, UST Class B Operator
Michael Pallvoda, UST Class B Operator
Allen Richard, UST Class B Operator
Nancy Sietsema, UST Class B Operator
Bruce Unger, UST Class B Operator
Allen Richard, UST Class B Global Operator
Weston Smith, UST Class B Global Operator
Monica Turnburke, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	22	6/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
4327			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-450 , Veeder Root		
8	22	6/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
988			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-450 , Veeder Root		

Facility Summary in ROOSEVELT County in the City of WOLF POINT

Location: FARMERS UNION OIL CO WESTSIDE STATION
60 US HIGHWAY 2 E
WOLF POINT, MT 59201 ROOSEVELT

Contact: Tom Dahl, (406) 653-1510

Sys Fac ID: 43-06866
Last Inspected On: 11/24/2015
Operating Permit Renewal Date: 3/4/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	22	6/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
4328			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-450 , Veeder Root		
10	22	6/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
990			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-450 , Veeder Root		
11	22	6/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
4329			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-450 , Veeder Root		
12	22	6/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
992			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-450 , Veeder Root		

Facility Summary in ROOSEVELT County in the City of WOLF POINT

Location: TOWN PUMP INC WOLF POINT
401 CASCADE ST
WOLF POINT, MT 59201 ROOSEVELT

Contact: Kevin Kenneally, (406) 653-3206

Sys Fac ID: 43-08725
Last Inspected On: 3/22/2016
Operating Permit Renewal Date: 4/27/2019

Owners/Operators:

E-Z Supply Inc, Owner	(406)-497-6700	PO BOX 6000 BUTTE MT 59702-6000
E-Z Supply Inc, Operator	(406)-497-6700	PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	4/14/1985	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4774			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/24/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		11/13/2009	Gilbarco EMC Basic , Gilbarco		
2	31	4/14/1985	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4775			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/24/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		11/13/2009	Gilbarco EMC Basic , Gilbarco		
3	31	4/14/1985	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4776			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/24/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		11/13/2009	Gilbarco EMC Basic , Gilbarco		

Facility Summary in ROOSEVELT County in the City of WOLF POINT

Location: TOWN PUMP INC WOLF POINT
401 CASCADE ST
WOLF POINT, MT 59201 ROOSEVELT

Contact: Kevin Kenneally, (406) 653-3206

Sys Fac ID: 43-08725
Last Inspected On: 3/22/2016
Operating Permit Renewal Date: 4/27/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	30	4/14/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4777			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/24/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000		10/11/2006	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
5	30	4/14/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4778			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/24/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		12/20/2006	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
6	14	6/28/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4779			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/24/2016	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		12/21/2006	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in ROOSEVELT County in the City of WOLF POINT

Location: FARMERS UNION OIL CO WOLF POINT
300 US HWY 2
WOLF POINT, MT 59201 ROOSEVELT
Contact: Dennis Vinger, (406) 653-1510

Sys Fac ID: 43-10279
Last Inspected On: 11/24/2015
Operating Permit Renewal Date: 3/30/2019

Owners/Operators: Farmers Union Oil Co Wolf Point, Owner (406)-653-1510 DBA AGLAND COOP
60 US HIGHWAY 2 E
WOLF POINT MT 59201-1942

David Parsley, UST Class A Operator
Nancy Sietsema, UST Class A Operator
Monica Turnburke, UST Class A Operator
Steven Long, UST Class B Operator
Michael Pallvoda, UST Class B Operator
David Parsley, UST Class B Operator
Allen Richard, UST Class B Operator
Nancy Sietsema, UST Class B Operator
Bruce Unger, UST Class B Operator
Allen Richard, UST Class B Global Operator
Weston Smith, UST Class B Global Operator
Monica Turnburke, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	20	8/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
999			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
30,000		9/1/2009	TLS-450 , Veeder Root		
10	20	8/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1000			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
30,000		9/1/2009	TLS-450 , Veeder Root		

Facility Summary in ROOSEVELT County in the City of WOLF POINT

Location: FARMERS UNION OIL CO WOLF POINT
300 US HWY 2
WOLF POINT, MT 59201 ROOSEVELT

Contact: Dennis Vinger, (406) 653-1510

Sys Fac ID: 43-10279
Last Inspected On: 11/24/2015
Operating Permit Renewal Date: 3/30/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	20	8/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1001			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		9/1/2009	TLS-450 , Veeder Root		
12	20	8/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1002			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		9/1/2009	TLS-450 , Veeder Root		
13	20	8/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1003			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
14,000		9/1/2009	TLS-450 , Veeder Root		
14	20	8/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1004			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		9/1/2009	TLS-450 , Veeder Root		

Facility Summary in ROOSEVELT County in the City of WOLF POINT

Location: FARMERS UNION OIL CO WOLF POINT
300 US HWY 2
WOLF POINT, MT 59201 ROOSEVELT

Contact: Dennis Vinger, (406) 653-1510

Sys Fac ID: 43-10279
Last Inspected On: 11/24/2015
Operating Permit Renewal Date: 3/30/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
15	20	8/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1005			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		9/1/2009	TLS-450 , Veeder Root		

Facility Summary in ROSEBUD County in the City of ASHLAND

Location: ST LABRE INDIAN SCHOOL UST
1000 TONGUE RIVER RD
ASHLAND, MT 59003 ROSEBUD

Contact: Leney Mcnac, (406) 666-2215

Sys Fac ID: 44-00701
Last Inspected On: 9/3/2013
Operating Permit Renewal Date: 12/28/2016

Owners/Operators: St Labre Indian School, Owner (406)-666-2215 1000 TONGUE RIVER RD ASHLAND MT 59003

Dana Davis, UST Class A Operator
Leney Mcnac, UST Class A Operator
Ronald Messman, UST Class A Operator
Dana Davis, UST Class B Operator
Dana Davis, UST Class B Global Operator
Leney Mcnac, UST Class B Global Operator
Ronald Messman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	22	12/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1957			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		9/3/2013	Automatic Tank Gauging 0.2	Deferred	
15,000					

Facility Summary in ROSEBUD County in the City of ASHLAND

Location: WESTERN PUMP
US HIGHWAY 212
ASHLAND, MT 59003 ROSEBUD
Contact: (406) 784-2500

Sys Fac ID: 44-01892
Last Inspected On: 11/18/2014
Operating Permit Renewal Date: 12/31/2017

Owners/Operators: Cleatus Stevenson, Owner (406)-784-2400 PO BOX 436
ASHLAND MT 59003-0436
James Stevenson, UST Class A Operator
James Stevenson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	2/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3098			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/18/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, Deferred	
2,000					
2	23	2/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3099			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/18/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, Deferred	
8,000					
3	19	10/29/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3100			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		11/18/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, Deferred	
4,000					

Facility Summary in ROSEBUD County in the City of ASHLAND

Location: CHEYENNE DEPOT 2
US HIGHWAY 212 & MISSION RD
ASHLAND, MT 59003 ROSEBUD
Contact: Cecilia Parker, (406) 784-2522

Sys Fac ID: 44-13200
Last Inspected On: 3/6/2015
Operating Permit Renewal Date:

Owners/Operators: Northern Cheyenne Tribe, Owner (406)-477-6794 ECONOMIC DEVELOPMENT COMMITTEE
PO BOX 10
LAME DEER MT 59043-0010

Christie Avery, UST Class A Operator
Ruthie Biglefthand, UST Class A Operator
Carrie Braine, UST Class A Operator
Stoney Elkshoulder, UST Class A Operator
Raymond Holmes, UST Class A Operator
Jonathan Limpy Jr, UST Class A Operator
Chris Risingsun, UST Class A Operator
Chahoristah Rowland, UST Class A Operator
Sharee Seminole, UST Class A Operator
Zhona Tang, UST Class A Operator
Carrie Braine, UST Class B Operator
Stoney Elkshoulder, UST Class B Operator
Raymond Holmes, UST Class B Operator
Jonathan Limpy Jr, UST Class B Operator
Sharee Seminole, UST Class B Operator
Christie Avery, UST Class B Global Operator
Ruthie Biglefthand, UST Class B Global Operator
Carrie Braine, UST Class B Global Operator
Raymond Holmes, UST Class B Global Operator
Jonathan Limpy Jr, UST Class B Global Operator
Chris Risingsun, UST Class B Global Operator
Chahoristah Rowland, UST Class B Global Operator
Zhona Tang, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**

Facility Summary in ROSEBUD County in the City of ASHLAND

Location: CHEYENNE DEPOT 2
US HIGHWAY 212 & MISSION RD
ASHLAND, MT 59003 ROSEBUD
Contact: Cecilia Parker, (406) 784-2522

Sys Fac ID: 44-13200
Last Inspected On: 3/6/2015
Operating Permit Renewal Date:

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	7/30/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4420			None	None	Yes
Temporarily Out of Use			Not Required	Pressurized	Galvanic
Gasoline		3/6/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		11/26/2005			
2	23	7/30/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4421			None	None	Yes
Temporarily Out of Use			Not Required	Pressurized	Galvanic
Gasoline		3/6/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		11/26/2005			
3	23	7/30/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4422			None	None	Yes
Temporarily Out of Use			Not Required	Pressurized	Galvanic
Diesel		3/6/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		11/26/2005			

Facility Summary in ROSEBUD County in the City of COLSTRIP

Location: COLSTRIP 500 KV SUBSTATION
COLSTRIP 500 KV SUBSTATION
COLSTRIP, MT 59323 ROSEBUD

Contact: Beth Stimatz, (406) 497-2687

Sys Fac ID: 44-01432
Last Inspected On: 5/10/2016
Operating Permit Renewal Date: 7/12/2019

Owners/Operators: Northwestern Energy, Owner (406)-655-2521 405 S 20TH ST W BILLINGS MT 59102

John Habeger, UST Class A Operator
Darren Brockel, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	34	4/30/1982	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3998		5/10/2016	None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Manual Interstitial Monitor	
2,500			OPW 1500 , OPW		

Facility Summary in ROSEBUD County in the City of COLSTRIP

Location: COLSTRIP STEAM ELECTRIC STATION UNITS 3 & 4
601 WILLOW AVE
COLSTRIP, MT 59323 ROSEBUD

Sys Fac ID: 44-06584
Last Inspected On: 3/31/2015
Operating Permit Renewal Date:

Contact: Mike Holzwarth, (406) 748-5046

Owners/Operators:

Talen Montana LLC, Owner	(406)-237-6900	303 N 28TH ST STE 400 BILLINGS MT 59101
Michael Holzwarth, Operator	(406)-748-5046	PO BOX 38 COLSTRIP MT 59323-0038

Stephen Christian, UST Class A Operator
Cody Cole, UST Class A Operator
Michael Holzwarth, UST Class A Operator
David Millegan, UST Class B Operator
William Neumiller, UST Class B Operator
Stephen Christian, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	37	5/1/1979	Unknown	Steel	
3703	Yes		None	None	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		3/31/2015	Deferred	MLLD Line Tightness Testing	
500,000					
5	37	5/1/1979	Unknown	Steel	
2863	Yes		None	None	Yes
Temporarily Out of Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		3/31/2015	Deferred	MLLD Line Tightness Testing	
40,000					

Facility Summary in ROSEBUD County in the City of COLSTRIP

Location: TOWN PUMP INC COLSTRIP
112 WILLOW AVE
COLSTRIP, MT 59323 ROSEBUD

Contact: Kevin Kenneally, (406) 748-3533

Sys Fac ID: 44-08689
Last Inspected On: 3/18/2016
Operating Permit Renewal Date: 4/27/2019

Owners/Operators: Town Pump of Hardin Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	41	4/12/1975	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4787			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		11/20/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000		6/2/2006	TLS-350/Gilbarco EMC , Veeder Root		
2	41	4/12/1975	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4788			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/20/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		7/2/2006	TLS-350/Gilbarco EMC , Veeder Root		
3	41	4/12/1975	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4789			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/20/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		7/2/2006	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in ROSEBUD County in the City of COLSTRIP

Location: TOWN PUMP INC COLSTRIP
112 WILLOW AVE
COLSTRIP, MT 59323 ROSEBUD

Contact: Kevin Kenneally, (406) 748-3533

Sys Fac ID: 44-08689
Last Inspected On: 3/18/2016
Operating Permit Renewal Date: 4/27/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	41	4/12/1975	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4790			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/20/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		10/14/2006	TLS-350/Gilbarco EMC , Veeder Root		
5	41	4/12/1975	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4791			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/20/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000		10/14/2006	TLS-350/Gilbarco EMC , Veeder Root		
6	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4792			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		10/25/2006	TLS-350/Gilbarco EMC , Veeder Root		
7	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4793			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000		10/25/2006	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in ROSEBUD County in the City of COLSTRIP

Location: COLSTRIP STEAM ELECTRIC STATION WILLOW AVE
601 WILLOW AVE
COLSTRIP, MT 59323 ROSEBUD

Sys Fac ID: 44-08921
Last Inspected On: 5/9/2014
Operating Permit Renewal Date: 8/22/2017

Contact: Michael Holzwarth, (406) 748-5046

Owners/Operators:

Talen Montana LLC, Owner	(406)-237-6900	303 N 28TH ST STE 400 BILLINGS MT 59101
Michael Holzwarth, Operator	(406)-748-5046	PO BOX 38 COLSTRIP MT 59323-0038

Stephen Christian, UST Class A Operator
Cody Cole, UST Class A Operator
Michael Holzwarth, UST Class A Operator
David Millegan, UST Class B Operator
William Neumiller, UST Class B Operator
Stephen Christian, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2864			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline		3/30/2011	Manual Interstitial Monitor	Deferred	
10,000					
2	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2865			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel		3/30/2011	Manual Interstitial Monitor	Deferred	
10,000					

Facility Summary in ROSEBUD County in the City of FORSYTH

Location: FORSYTH WATERING HOLE
1017 FRONT ST
FORSYTH, MT 59327 ROSEBUD

Contact: Jones DeAnne, (406) 346-2885

Sys Fac ID: 44-01244
Last Inspected On: 9/4/2015
Operating Permit Renewal Date: 12/13/2018

Owners/Operators: RRR Properties LLC, Owner/Operator (308)-280-0330 PO BOX 606 OGALLALA NE 69153

Cory Boyd, UST Class A Operator
DeAnne Jonas, UST Class A Operator
Mike Simpson, UST Class A Operator
Cory Boyd, UST Class B Operator
DeAnne Jonas, UST Class B Global Operator
Mike Simpson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	24	2/24/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1393			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/4/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		10/28/2016	TLS-350/Gilbarco EMC , Veeder Root		
5	24	2/24/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1394			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/4/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		10/28/2016	TLS-350/Gilbarco EMC , Veeder Root		
6	24	2/24/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1395			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/4/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		10/28/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in ROSEBUD County in the City of FORSYTH

Location: ROSEBUD COUNTY ROAD DEPT
US HIGHWAY 10
FORSYTH, MT 59327 ROSEBUD

Contact: Virgil Farris, (406) 356-2261

Sys Fac ID: 44-01288
Last Inspected On: 10/29/2014
Operating Permit Renewal Date: 1/14/2018

Owners/Operators: Rosebud County Road Dept, Owner (406)-346-2261 PO BOX 1117
FORSYTH MT 59327-1117

Dawne Buck, UST Class A Operator
Wayne Buck, UST Class A Operator
Dawne Buck, UST Class B Operator
Wayne Buck, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	4/1/1991	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1859			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/29/2014	Continuous Interstitial Monitor	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
2	25	4/1/1991	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1860			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/29/2014	Continuous Interstitial Monitor	Deferred	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
4	25	4/1/1991	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1858			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/29/2014	Continuous Interstitial Monitor	Deferred	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in ROSEBUD County in the City of FORSYTH

Location: ROSEBUD HEALTH CARE CENTER
383 N 17TH AVE
FORSYTH, MT 59327 ROSEBUD

Contact: Robert Gregory, (406) 346-2161

Sys Fac ID: 44-05262
Last Inspected On: 3/3/2016
Operating Permit Renewal Date: 4/20/2019

Owners/Operators: Rosebud Health Care Center, Owner (406)-356-2161 383 17TH AVE N FORSYTH MT 59327

Tim Davis, UST Class A Operator
Michael P Jerhoff, UST Class A Operator
Tim Davis, UST Class B Global Operator
Michael P Jerhoff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	9/1/1991	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
4343			Double-Walled	none	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Diesel		3/3/2016	Manual Interstitial Monitor	MLLD Line Tightness Testing	
500		3/3/2016			

Facility Summary in ROSEBUD County in the City of FORSYTH

Location: PRINCE INC FORSYTH
W FRONTAGE RD
FORSYTH, MT 59327 ROSEBUD
Contact: BC Prince, (406) 356-2137

Sys Fac ID: 44-06209
Last Inspected On: 11/18/2014
Operating Permit Renewal Date: 2/12/2018

Owners/Operators: Prince Inc, Owner (406)-356-2137 PO BOX 440
FORSYTH MT 59327-0440

Charlee Prince, UST Class A Operator
Charlee Prince, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	18	10/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4532			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		11/18/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Not Listed	
10,000		11/21/2011			
6	18	10/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4533			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/18/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
5,000		11/21/2011			

Facility Summary in ROSEBUD County in the City of FORSYTH

Location: TOWN PUMP INC FORSYTH
974 FRONT ST
FORSYTH, MT 59327 ROSEBUD

Contact: Kevin Kenneally, (406) 356-7952

Sys Fac ID: 44-09356
Last Inspected On: 3/31/2016
Operating Permit Renewal Date: 4/27/2019

Owners/Operators: Major Brands Distributing Imports Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	14	10/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4736			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		12/3/2009	TLS-350/Gilbarco EMC , Veeder Root		
12	14	10/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4737			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		12/3/2009	TLS-350/Gilbarco EMC , Veeder Root		
13	14	11/20/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4755			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		12/3/2009	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in ROSEBUD County in the City of FORSYTH

Location: TOWN PUMP INC FORSYTH
974 FRONT ST
FORSYTH, MT 59327 ROSEBUD

Contact: Kevin Kenneally, (406) 356-7952

Sys Fac ID: 44-09356
Last Inspected On: 3/31/2016
Operating Permit Renewal Date: 4/27/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
14	14	10/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4738			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		12/3/2009	TLS-350/Gilbarco EMC , Veeder Root		
15	14	11/20/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4756			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		12/3/2009	TLS-350/Gilbarco EMC , Veeder Root		
16	14	11/20/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4757			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		12/3/2009	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SANDERS County in the City of HERON

Location: THE HERON STORE AND CAFÉ
150 RAILROAD AVE
HERON, MT 59844 SANDERS

Contact: Lisa Camara, (406) 847-3663

Sys Fac ID: 45-10136
Last Inspected On: 1/28/2016
Operating Permit Renewal Date:

Owners/Operators: Lisa Camara, Owner (406)-847-3663 PO BOX 150
HERON MT 59844-9596

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	21	6/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3291			Double-Walled	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Diesel			Not Listed	Deferred	
1,080					
4	21	6/1/1995	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3292			Double-Walled	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Gasoline			Not Listed	Deferred	
1,080					

Facility Summary in SANDERS County in the City of HOT SPRINGS

Location: SPRING STREET EXXON
104 SPRING ST N
HOT SPRINGS, MT 59845 SANDERS

Contact: Randal A Woods, (406) 741-2325

Sys Fac ID: 45-04109
Last Inspected On: 7/27/2015
Operating Permit Renewal Date:

Owners/Operators: Randal A Woods, Owner (406)-741-2325 PO BOX 808
HOT SPRINGS MT 59845-0808

Randal A Woods, UST Class A Operator
Randal A Woods, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
15	20	5/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2301			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		5/30/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
4,000		3/21/2003	Auto Stik JR , EBW		
16	20	5/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2302			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		5/30/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
4,000			Auto Stik JR , EBW		

Facility Summary in SANDERS County in the City of HOT SPRINGS

Location: CORNERSTONE CONVENIENCE LLC
1893 MT HIGHWAY 28
HOT SPRINGS, MT 59845 SANDERS

Contact: Jeffery Jung, (406) 741-3200

Sys Fac ID: 45-12871
Last Inspected On: 6/16/2014
Operating Permit Renewal Date: 8/13/2017

Owners/Operators: Cornerstone Convenience LLC, Owner/Operator (406)-741-3200 PO BOX 39
HOT SPRINGS MT 59845

Sandra Brown, UST Class A Operator
Carmen Carr, UST Class A Operator
Danielle Chesley, UST Class A Operator
Pandora Fasciana, UST Class A Operator
Jan Montgomery, UST Class A Operator
Manford Tempero, UST Class A Operator
Jetta Aldridge, UST Class B Operator
Sandra Brown, UST Class B Operator
Carmen Carr, UST Class B Operator
Jan Montgomery, UST Class B Operator
Manford Tempero, UST Class B Operator
Danielle Chesley, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	20	5/1/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2984			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		5/4/2016	TS-1000 , Incon		
4	20	5/1/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2985			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		5/4/2016	TS-1000 , Incon		

Facility Summary in SANDERS County in the City of HOT SPRINGS

Location: CORNERSTONE CONVENIENCE LLC
1893 MT HIGHWAY 28
HOT SPRINGS, MT 59845 SANDERS

Contact: Jeffery Jung, (406) 741-3200

Sys Fac ID: 45-12871
Last Inspected On: 6/16/2014
Operating Permit Renewal Date: 8/13/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	20	5/1/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2986			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		5/4/2016	TS-1000 , Incon		
6	20	6/1/1996	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2987			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		5/4/2016	TS-1000 , Incon		

Facility Summary in SANDERS County in the City of LONEPINE

Location: LONEPINE COUNTRY STORE
2435 MT HIGHWAY 28 PO BOX 1013
LONEPINE, MT 59848 SANDERS

Contact: Manford Tempero, (406) 741-3210

Sys Fac ID: 45-12786
Last Inspected On: 5/5/2016
Operating Permit Renewal Date: 8/7/2019

Owners/Operators:

M & MT Enterprise Inc, Owner	(406)-741-3210	PO BOX 295 HOT SPRINGS MT 59845-0295
Manford Tempero, Operator	(406)-741-3210	PO BOX 295 HOT SPRINGS MT 59845-0295

Manford Tempero, UST Class A Operator
Jetta Aldridge, UST Class B Operator
Manford Tempero, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	6/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3536			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		4/23/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/15/2016	TS-2000 , Incon		
2	24	6/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3537			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		4/23/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		4/15/2016	TS-2000 , Incon		
3	24	6/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3538			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		4/23/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/15/2016	TS-2000 , Incon		

Facility Summary in SANDERS County in the City of NOXON

Location: AITKENS QUIK STOP INC NOXON
1402 MT HIGHWAY 200 W
NOXON, MT 59853 SANDERS

Contact: Jeff Aitken, (406) 847-2191

Sys Fac ID: 56-13810
Last Inspected On: 3/18/2014
Operating Permit Renewal Date: 4/11/2017

Owners/Operators: Aitkens Quik Stop Inc, Owner (406)-847-4080 ATTN JEFF AITKEN
1402 MT HIGHWAY 200
NOXON MT 59853-9750

Jeffrey Aitken, UST Class A Operator
Jeffrey Aitken, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	10/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4484			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/9/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		3/1/2011	TLS-350/Gilbarco EMC , Veeder Root		
2	19	10/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4485			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/9/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000		3/1/2011	TLS-350/Gilbarco EMC , Veeder Root		
3	19	10/1/1997	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4486			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/9/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000		3/1/2011	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SANDERS County in the City of PARADISE

Location: PARADISE SCHOOL DIST 8
20 SCHOOL HOUSE HILL RD
PARADISE, MT 59856 SANDERS
Contact: (406) 826-3344

Sys Fac ID: 45-08864
Last Inspected On: 6/11/2014
Operating Permit Renewal Date: 10/17/2017

Owners/Operators: Paradise Grade School, Owner (406)-826-3344 PO BOX 126
PARADISE MT 59856-0126

Teresa Kendall, UST Class A Operator
Dan Kelly, UST Class B Operator
Teresa Kendall, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	18	7/30/1998	Unknown	Copper	
1782	Yes	8/7/2014	None	PVC	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
1,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SANDERS County in the City of PLAINS

Location: PLAINS SCHOOL DIST 1
412 RITTENOUR ST
PLAINS, MT 59859 SANDERS

Contact: Bill Hayden, (406) 826-3666

Sys Fac ID: 45-01093
Last Inspected On: 7/21/2015
Operating Permit Renewal Date: 9/3/2018

Owners/Operators: Plains High School, Owner (406)-826-3666 BILL HAYEN
PO BOX 549
PLAINS MT 59859-0549

William Hayen, UST Class A Operator
Paul Pickering, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	22	8/1/1994	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1891		6/30/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Heating Oil		7/20/2015	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
10,000			ILS-250 , Veeder Root		

Facility Summary in SANDERS County in the City of PLAINS

Location: COLYER OIL CO E RAILROAD
100 E RAILROAD AVE
PLAINS, MT 59859 SANDERS

Contact: David F Colyer, (406) 826-3961

Sys Fac ID: 45-01147
Last Inspected On: 4/29/2016
Operating Permit Renewal Date: 6/30/2019

Owners/Operators: Colyer Oil Co, Owner (406)-826-3961 PO BOX 785
PLAINS MT 59859-0785

David F Colyer, UST Class A Operator
David F Colyer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3594			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
8	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3595			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
9	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3596			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Heating Oil			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
10	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3597			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in SANDERS County in the City of PLAINS

Location: COLYER OIL CO E RAILROAD
100 E RAILROAD AVE
PLAINS, MT 59859 SANDERS

Contact: David F Colyer, (406) 826-3961

Sys Fac ID: 45-01147
Last Inspected On: 4/29/2016
Operating Permit Renewal Date: 6/30/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	17	12/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3598			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in SANDERS County in the City of PLAINS

Location: PLAINS SERVICE CENTER INC
325 E RAILROAD ST
PLAINS, MT 59859 SANDERS
Contact: (406) 826-5969

Sys Fac ID: 45-03803
Last Inspected On: 12/14/2014
Operating Permit Renewal Date: 3/21/2018

Owners/Operators: Plains Service Center Inc, Owner (406)-826-5969 PO BOX 1056
PLAINS MT 59859-1056

Meg Feist, UST Class A Operator
Debbi Kirschbaum, UST Class A Operator
Meg Feist, UST Class B Operator
Debbi Kirschbaum, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	17	2/1/1999	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4510		12/18/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		12/12/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			EECO 1500 , EMCO Electronics		
8	17	2/1/1999	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4511		12/18/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		12/12/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			EECO 1500 , EMCO Electronics		
9	17	2/1/1999	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4512		12/18/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		12/12/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000			EECO 1500 , EMCO Electronics		

Facility Summary in SANDERS County in the City of PLAINS

Location: TOWN PUMP INC PLAINS
335 RAILROAD AVE
PLAINS, MT 59859 SANDERS
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 45-08716
Last Inspected On: 4/29/2016
Operating Permit Renewal Date: 8/24/2019

Owners/Operators: Plains Town Pump Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000
Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	50	4/14/1966	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2610			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Impressed Current
Gasoline		4/27/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		1/25/2006	TLS-350/Gilbarco EMC , Veeder Root		
2	50	4/14/1966	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2611			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Impressed Current
Gasoline		4/27/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000		1/25/2006	TLS-350/Gilbarco EMC , Veeder Root		
3	40	4/14/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2612			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Impressed Current
Diesel		4/27/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		1/26/2006	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SANDERS County in the City of PLAINS

Location: TOWN PUMP INC PLAINS
335 RAILROAD AVE
PLAINS, MT 59859 SANDERS

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 45-08716
Last Inspected On: 4/29/2016
Operating Permit Renewal Date: 8/24/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	30	4/14/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2613			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Impressed Current
Diesel		4/27/2016	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000		1/26/2006	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SANDERS County in the City of THOMPSON FALLS

Location: THOMPSON FALLS FEED AND FUEL LLC
1201 MAIN ST PO BOX 26
THOMPSON FALLS, MT 59873 SANDERS
Contact: Ron Mosher, (406) 827-4325

Sys Fac ID: 45-02633
Last Inspected On: 11/12/2014
Operating Permit Renewal Date: 12/2/2017

Owners/Operators: Thompson Falls Feed and Fuel LLC, Owner (406)-827-4325 PO BOX 26
THOMPSON FALLS MT 59873-0026

Kayla Hoar, UST Class A Operator
Anna Wood, UST Class A Operator
Kayla Hoar, UST Class B Operator
Anna Wood, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	28	4/1/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3203			Lined Interior	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/8/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		7/30/2014			
2	28	4/1/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3204			Lined Interior	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/8/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		7/30/2014			
3	28	4/1/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3205			Lined Interior	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/8/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		7/30/2014			

Facility Summary in SANDERS County in the City of THOMPSON FALLS

Location: THOMPSON FALLS FEED AND FUEL LLC
1201 MAIN ST PO BOX 26
THOMPSON FALLS, MT 59873 SANDERS
Contact: Ron Mosher, (406) 827-4325

Sys Fac ID: 45-02633
Last Inspected On: 11/12/2014
Operating Permit Renewal Date: 12/2/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	28	4/1/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3206			Lined Interior	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		1/8/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		7/30/2014			

Facility Summary in SANDERS County in the City of THOMPSON FALLS

Location: ELEMENTARY SCHOOL
HALEY AVE
THOMPSON FALLS, MT 59873 SANDERS

Contact: Lynn Stagg, (406) 827-3323

Sys Fac ID: 45-08537
Last Inspected On: 9/19/2014
Operating Permit Renewal Date: 1/21/2018

Owners/Operators: School Dist 2 Thompson Falls, Owner (406)-827-3323 PO BOX 129
THOMPSON FALLS MT 59873-0129

Mike Bates, UST Class A Operator
Mike Bates, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	8/1/1992	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1887			Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil		10/2/2014	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SANDERS County in the City of THOMPSON FALLS

Location: TOWN PUMP INC THOMPSON FALLS
1301 MAIN ST
THOMPSON FALLS, MT 59873 SANDERS
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 45-08720
Last Inspected On: 12/13/2015
Operating Permit Renewal Date: 4/1/2019

Owners/Operators: Town Pump of Thompson Falls Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000
Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	36	4/14/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2614			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/13/2015	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	26	4/27/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2615			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/1/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	26	4/27/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2616			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/1/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SANDERS County in the City of THOMPSON FALLS

Location: TOWN PUMP INC THOMPSON FALLS
1301 MAIN ST
THOMPSON FALLS, MT 59873 SANDERS
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 45-08720
Last Inspected On: 12/13/2015
Operating Permit Renewal Date: 4/1/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
7	26	4/27/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2617			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/1/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
8	17	10/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4115			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/1/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	17	10/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4116			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/1/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
10	12	8/18/2004	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4932			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/1/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SANDERS County in the City of THOMPSON FALLS

Location: RONS EXPRESS PAY
5236 MT HIGHWAY 200
THOMPSON FALLS, MT 59873 SANDERS
Contact: Ron Turk, (406) 827-4653

Sys Fac ID: 45-13460
Last Inspected On: 6/10/2014
Operating Permit Renewal Date: 10/17/2017

Owners/Operators: Turk Inc, Owner (406)-827-4653 PO BOX 88
THOMPSON FALLS MT 59873-0088

Ronald R Turk, UST Class A Operator
Ronald R Turk, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	5/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2150			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Deferred	
10,000			TS-1000 , Incon		
2	22	5/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2151			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
10,000			TS-1000 , Incon		
3	22	5/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2152			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
4,000			TS-1000 , Incon		
4	22	5/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2153			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Deferred	
4,000			TS-1000 , Incon		

Facility Summary in SANDERS County in the City of THOMPSON FALLS

Location: THOMPSON FALLS UNLOADING TERMINAL
5315 MT HIGHWAY 200
THOMPSON FALLS, MT 59873 SANDERS
Contact: Dale Waltrip, (406) 827-3318

Sys Fac ID: 45-13726
Last Inspected On: 6/20/2001
Operating Permit Renewal Date:

Owners/Operators: Conoco Inc Billings, Owner (406)-255-2672 PO BOX 30198
BILLINGS MT 59107-0198

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	20	1/1/1996	Unknown	Steel	
	Yes		None	None	Yes
Currently in Use			Not Required	Gravity Feed	Not Applicable
Mixture			Deferred	MLLD Line Tightness Testing, Deferred	
2,000					

Facility Summary in SANDERS County in the City of THOMPSON FALLS

Location: MOODYS MARKET HARVEST FOODS
5254 MT HIGHWAY 200 PO BOX 880
THOMPSON FALLS, MT 59873 SANDERS
Contact: (406) 827-4321

Sys Fac ID: 56-14114
Last Inspected On: 1/22/2016
Operating Permit Renewal Date: 3/2/2019

Owners/Operators: Gregory Hurtz, Owner (406)-827-4321 PO BOX 880
THOMPSON FALLS MT 59873-0880

Fred Boon, UST Class A Operator
Fred Boon, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	13	11/4/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4868		6/29/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-300 , Veeder Root		
2	13	11/4/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4869		6/29/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			TLS-300 , Veeder Root		
3	13	11/4/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4870		6/29/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			TLS-300 , Veeder Root		

Facility Summary in SANDERS County in the City of TROUT CREEK

Location: TROUT CREEK SCHOOL DIST 6
4 SCHOOL LN
TROUT CREEK, MT 59874 SANDERS

Contact: Dave Anderson, (406) 827-3629

Sys Fac ID: 45-07647
Last Inspected On: 12/2/2013
Operating Permit Renewal Date: 4/8/2017

Owners/Operators: School Dist 6 Trout Creek, Owner (406)-827-3629 4 SCHOOL LN
TROUT CREEK MT 59874-9671

Mary Smith, UST Class A Operator
Richard Sorenson, UST Class A Operator
Richard Sorenson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	8/1/1993	Cathodically Protected Steel	Copper	Flapper Valve (Auto Shutoff)
2146		12/2/2013	Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Heating Oil		11/20/2013	Continuous Interstitial Monitor	Not Listed	
1,000					

Facility Summary in SANDERS County in the City of TROUT CREEK

Location: TROUT CREEK LOCAL STORE INC
2954 MT HIGHWAY 200
TROUT CREEK, MT 59874 SANDERS

Contact: Travis Tammaro, (406) 827-4507

Sys Fac ID: 45-10228
Last Inspected On: 6/10/2014
Operating Permit Renewal Date: 8/7/2017

Owners/Operators:

Trout Creek Local Store Inc, Owner	(406)-827-4507	PO BOX 169 HERON MT 59844-0169
Michele Tammaro, Operator	(406)-827-4507	2954 HWY 200 TROUT CREEK MT 59874
Michele Tammaro, UST Class A Operator		
Michele Tammaro, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	12/4/1989	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1607			Double-Walled	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		3/17/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
3,000		6/25/2016	TLS-350/Gilbarco EMC , Veeder Root		
3	17	12/1/1998	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1608			Double-Walled	none	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		3/17/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
3,000		6/25/2016	TLS-350/Gilbarco EMC , Veeder Root		
5	26	12/1/1989	Not Listed	Steel	
5682	Yes		None	None	No
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		3/17/2015	Deferred	MLLD Line Tightness Testing	
3,000		6/25/2016	TLS-350/Gilbarco EMC , Veeder Root	Not Listed	

Facility Summary in SANDERS County in the City of TROUT CREEK

Location: HENRYS HIDEAWAY
4091 MT HIGHWAY 200
TROUT CREEK, MT 59874 SANDERS

Contact: Mary Kendziorski, (406) 827-0175

Sys Fac ID: 45-13738
Last Inspected On: 2/5/2014
Operating Permit Renewal Date:

Owners/Operators: Mary Kendziorski, Owner (406)-827-0175 4091 MT HIGHWAY 200 TROUT CREEK MT 59874-9505

Henry M Getz, Operator (406)-542-0460 5840 LA VOIE LN MISSOULA MT 59808-8906

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	8/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4568			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		2/5/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		12/19/2007	Gilbarco EMC Basic , Gilbarco		
2	20	8/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4569			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/5/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		12/19/2007	Gilbarco EMC Basic , Gilbarco		
3	20	8/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4570			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		2/5/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		12/19/2007	Gilbarco EMC Basic , Gilbarco		

Facility Summary in SANDERS County in the City of TROUT CREEK

Location: HENRYS HIDEAWAY
4091 MT HIGHWAY 200
TROUT CREEK, MT 59874 SANDERS

Contact: Mary Kendziorski, (406) 827-0175

Sys Fac ID: 45-13738
Last Inspected On: 2/5/2014
Operating Permit Renewal Date:

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	20	8/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4571			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/5/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		12/19/2007	Gilbarco EMC Basic , Gilbarco		

Facility Summary in SANDERS County in the City of TROUT CREEK

Location: AITKENS QUIK STOP INC TROUT CREEK
2950 MT HIGHWAY 200
TROUT CREEK, MT 59874 SANDERS

Contact: Aitken Jeff, (406) 847-4080

Sys Fac ID: 56-14146
Last Inspected On: 2/26/2014
Operating Permit Renewal Date: 4/28/2017

Owners/Operators: Aitkens Quik Stop Inc, Owner (406)-847-4080 ATTN JEFF AITKEN
1402 MT HIGHWAY 200
NOXON MT 59853-9750

Jeffrey Aitken, UST Class A Operator
Tiffany Yee, UST Class A Operator
Jeffrey Aitken, UST Class B Operator
Tiffany Yee, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	11	4/21/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4946			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000			Gilbarco EMC Basic , Gilbarco		
2	11	4/21/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4947			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
4,000			Gilbarco EMC Basic , Gilbarco		
3	11	4/21/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4948			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
4,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in SANDERS County in the City of TROUT CREEK

Location: AITKENS QUIK STOP INC TROUT CREEK
2950 MT HIGHWAY 200
TROUT CREEK, MT 59874 SANDERS

Contact: Aitken Jeff, (406) 847-4080

Sys Fac ID: 56-14146
Last Inspected On: 2/26/2014
Operating Permit Renewal Date: 4/28/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	11	4/21/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4949			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
4,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in SHERIDAN County in the City of MEDICINE LAKE

Location: MEDICINE LAKE SCHOOL DIST 7
1 YOUNG ST
MEDICINE LAKE, MT 59247 SHERIDAN
Contact: (406) 789-2211

Sys Fac ID: 46-01122
Last Inspected On: 11/16/2016
Operating Permit Renewal Date: 1/21/2020

Owners/Operators: School Dist 7 Medicine Lake, Owner (406)-789-2211 PO BOX 265
MEDICINE LAKE MT 59247-0265

Mike Olson, UST Class A Operator
James Simoneau, UST Class A Operator
Mike Olson, UST Class B Operator
James Simoneau, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	8/1/1991	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1603		3/1/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Heating Oil		1/16/2014	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
10,066			OPW 1500 , OPW		

Facility Summary in SHERIDAN County in the City of MEDICINE LAKE

Location: LAKE PIT STOP
MT HIGHWAY 16 & MAIN ST
MEDICINE LAKE, MT 59247 SHERIDAN

Contact: Donald Johnson, (406) 963-2286

Sys Fac ID: 46-01127
Last Inspected On: 1/5/2016
Operating Permit Renewal Date: 3/30/2019

Owners/Operators:

Lake Pit Stop LLC, Owner	(406)-789-2242	PO BOX 173 MEDICINE LAKE MT 59247
Lake Pit Stop, Operator	(406)-789-2242	HWY 16 & MAIN MEDICINE LAKE MT 59247

James BoBo, UST Class A Operator
Robert Herman, UST Class A Operator
Chanel Johnson, UST Class A Operator
James BoBo, UST Class B Operator
Chanel Johnson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	19	10/1/1997	Unknown	Flexible Plastic	
2323	Yes	10/15/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
15,000		4/24/2015	Other , Other		
7	19	10/1/1997	Unknown	Flexible Plastic	
2324	Yes	10/15/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000		4/24/2015	Other , Other		
8	19	10/1/1997	Unknown	Flexible Plastic	
2325	Yes	10/15/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000		4/24/2015	Other , Other		
9	19	10/1/1997	Unknown	Flexible Plastic	
2326	Yes	10/15/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
8,000		4/24/2015	Other , Other		

Facility Summary in SHERIDAN County in the City of PLENTYWOOD

Location: SHERIDAN MEMORIAL HOSPITAL
440 W LAUREL AVE
PLENTYWOOD, MT 59254 SHERIDAN
Contact: Paul Beck, (406) 765-1420

Sys Fac ID: 46-00795
Last Inspected On: 1/16/2014
Operating Permit Renewal Date: 6/3/2017

Owners/Operators: Sheridan Memorial Hospital, Owner (406)-765-1420 440 W LAUREL AVE PLENTYWOOD MT 59254-1596

Murvin Anderson, UST Class A Operator
Mark A Brensdal, UST Class A Operator
Michael Cox, UST Class A Operator
Athena Gardenier, UST Class B Operator
Michael Cox, UST Class B Global Operator
Athena Gardenier, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	18	10/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1918		3/19/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Heating Oil			Manual Interstitial Monitor	Continuous Interstitial Monitor	
8,000					

Facility Summary in SHERIDAN County in the City of PLENTYWOOD

Location: AUTO TECH SERVICES
327 W 1ST AVE
PLENTYWOOD, MT 59254 SHERIDAN

Contact: James Kibbe, (406) 765-1180

Sys Fac ID: 46-01524
Last Inspected On: 12/18/2015
Operating Permit Renewal Date: 6/8/2019

Owners/Operators: Farmers Union Oil Co Plentywood, Owner (406)-765-1171 301 W 1ST AVE
PLENTYWOOD MT 59254-1802

James Kibbe, UST Class A Operator
L James Kibbe, UST Class A Operator
James Kibbe, UST Class B Global Operator
L James Kibbe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	26	12/10/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1114			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		12/18/2015	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-450 , Veeder Root		
9	26	12/10/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1115			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/18/2015	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-450 , Veeder Root		
10	26	12/10/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1116			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/18/2015	Automatic Tank Gauging 0.2	Deferred	
10,000			TLS-450 , Veeder Root		

Facility Summary in SHERIDAN County in the City of PLENTYWOOD

Location: KUM AND GO STORE 808
211 W 1ST AVE
PLENTYWOOD, MT 59254 SHERIDAN
Contact: Gary D Reynolds, (406) 765-2847

Sys Fac ID: 46-05200
Last Inspected On: 8/28/2014
Operating Permit Renewal Date: 9/10/2017

Owners/Operators: Krause Gentle Corp, Owner (515)-226-0128 MARC HYLAND
6400 WESTOWN PKWY
WEST DES MOINES IA 50266-7709

Christopher Bergman, UST Class A Operator
Wayne Lundquist, UST Class A Operator
Amanda Schumacher, UST Class A Operator
Mike Simpson, UST Class A Operator
Christopher Bergman, UST Class B Global Operator
Wayne Lundquist, UST Class B Global Operator
Amanda Schumacher, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	33	12/1/1982	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1498			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		8/28/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		8/28/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	28	1/1/1988	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4358			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/28/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
12,000		8/28/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SHERIDAN County in the City of PLENTYWOOD

Location: KUM AND GO STORE 808
211 W 1ST AVE
PLENTYWOOD, MT 59254 SHERIDAN

Contact: Gary D Reynolds, (406) 765-2847

Sys Fac ID: 46-05200
Last Inspected On: 8/28/2014
Operating Permit Renewal Date: 9/10/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	28	1/1/1988	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1500			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/28/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
12,000		8/28/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SHERIDAN County in the City of PLENTYWOOD

Location: SHERIDAN COUNTY
100 W LAUREL AVE
PLENTYWOOD, MT 59254 SHERIDAN
Contact: Gary Bartnes, (406) 765-2310

Sys Fac ID: 46-06278
Last Inspected On: 1/2/2014
Operating Permit Renewal Date: 6/18/2017

Owners/Operators: Sheridan County Sanitarian, Owner (406)-765-2310 100 W LAUREL AVE PLENTYWOOD MT 59254-1647

Gary Bartnes, UST Class A Operator
Jerry Hendrickson, UST Class A Operator
Gary Bartnes, UST Class B Global Operator
Jerry Hendrickson, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	21	9/1/1995	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1911		3/25/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Gravity Feed	Galvanic
Heating Oil		1/5/2011	Continuous Interstitial Monitor	MLLD Line Tightness Testing	
10,000		4/30/2014			

Facility Summary in SHERIDAN County in the City of PLENTYWOOD

Location: SHERIDAN COUNTY SHOP
MT HIGHWAY 16 E
PLENTYWOOD, MT 59254 SHERIDAN
Contact: Walt Heppner, (406) 765-1221

Sys Fac ID: 46-06279
Last Inspected On: 11/16/2016
Operating Permit Renewal Date: 2/19/2020

Owners/Operators: Sheridan County Sanitarian, Owner (406)-765-2310 100 W LAUREL AVE
PLENTYWOOD MT 59254-1647

DELLAS CHRISTENSEN, UST Class A Operator
DELLAS CHRISTENSEN, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	26	1/1/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1912			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		1/5/2011	Manual Interstitial Monitor	Deferred	
10,000					
6	26	1/1/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1913			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		1/5/2011	Manual Interstitial Monitor	Deferred	
10,150					
7	26	1/1/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1914			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		1/5/2011	Manual Interstitial Monitor	Deferred	
10,150					
8	26	1/1/1990	Steel Clad	Fiberglass Reinforced Plastic	Positive Shutoff
1915			Double-Walled	None	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Waste Oil		1/5/2011	Manual Interstitial Monitor	MLLD Line Tightness Testing	
1,002		11/16/2016			

Facility Summary in SHERIDAN County in the City of PLENTYWOOD

Location: FARMERS UNION OIL CO PLENTYWOOD
301 W 1ST AVE
PLENTYWOOD, MT 59254 SHERIDAN
Contact: Jim Kibbe, (406) 765-1171

Sys Fac ID: 46-06801
Last Inspected On: 7/8/2015
Operating Permit Renewal Date: 8/23/2018

Owners/Operators: Farmers Union Oil Co Plentywood, Owner (406)-765-1171 301 W 1ST AVE PLENTYWOOD MT 59254-1802
L James Kibbe, UST Class A Operator
L James Kibbe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	20	6/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
1038		6/13/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/3/2015	Automatic Tank Gauging 0.2	ELLD Line Tightness Testing	
20,000		7/28/2016	TLS-450 , Veeder Root	Continuous Interstitial Monitor	
9	20	6/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
1039		6/13/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		6/3/2015	Automatic Tank Gauging 0.2	ELLD Line Tightness Testing	
20,000		7/28/2016	TLS-450 , Veeder Root	Continuous Interstitial Monitor	
10	20	6/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
1040		6/13/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/3/2015	Automatic Tank Gauging 0.2	ELLD Line Tightness Testing	
12,000		7/28/2016	TLS-450 , Veeder Root	Continuous Interstitial Monitor	
11	20	6/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
1041		6/13/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		6/3/2015	Automatic Tank Gauging 0.2	ELLD Line Tightness Testing	
12,000		3/24/2016	TLS-450 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SHERIDAN County in the City of PLENTYWOOD

Location: FARMERS UNION OIL CO PLENTYWOOD
301 W 1ST AVE
PLENTYWOOD, MT 59254 SHERIDAN

Contact: Jim Kibbe, (406) 765-1171

Sys Fac ID: 46-06801
Last Inspected On: 7/8/2015
Operating Permit Renewal Date: 8/23/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
12	20	6/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
1042		6/13/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		6/3/2015	Automatic Tank Gauging 0.2	ELLD Line Tightness Testing	
12,000		7/28/2016	TLS-450 , Veeder Root	Continuous Interstitial Monitor	
13	20	6/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
1043		6/13/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		6/3/2015	Automatic Tank Gauging 0.2	ELLD Line Tightness Testing	
8,000		3/24/2016	TLS-450 , Veeder Root	Continuous Interstitial Monitor	
14	20	6/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff
1044		6/13/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		6/3/2015	Automatic Tank Gauging 0.2	ELLD Line Tightness Testing	
8,000		3/24/2016	TLS-450 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SHERIDAN County in the City of PLENTYWOOD

Location: MILLER OIL CO INC E RAILROAD AVE
416 WEST RAILROAD AVE
PLENTYWOOD, MT 59254 SHERIDAN
Contact: Matt Miller, (406) 765-2852

Sys Fac ID: 46-08609
Last Inspected On: 10/27/2015
Operating Permit Renewal Date: 3/4/2019

Owners/Operators: Miller Oil Co Inc Culbertson, Owner (406)-787-5230 PO BOX 408 CULBERTSON MT 59218-0408
Kevin Miller, UST Class A Operator
Matthew Miller, UST Class A Operator
Kevin Miller, UST Class B Operator
Matthew Miller, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	49	4/8/1967	Bare Steel	Fiberglass Reinforced Plastic	
1617	Yes	6/18/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,048		8/5/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	55	4/7/1961	Bare Steel	Fiberglass Reinforced Plastic	
1618	Yes	6/18/2015	None	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/8/2006	Deferred	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,327		8/5/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	49	4/8/1967	Bare Steel	Fiberglass Reinforced Plastic	
1619	Yes	6/18/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/8/2006	Deferred	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
14,848		8/5/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SHERIDAN County in the City of PLENTYWOOD

Location: MILLER OIL CO INC E RAILROAD AVE
416 WEST RAILROAD AVE
PLENTYWOOD, MT 59254 SHERIDAN

Contact: Matt Miller, (406) 765-2852

Sys Fac ID: 46-08609
Last Inspected On: 10/27/2015
Operating Permit Renewal Date: 3/4/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	48	4/7/1968	Bare Steel	Fiberglass Reinforced Plastic	
1620	Yes	6/18/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		8/8/2006	Deferred	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
14,773		8/5/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SHERIDAN County in the City of PLENTYWOOD

Location: MONTANA PIONEER MANOR INC
605 SHERIDAN ST
PLENTYWOOD, MT 59254 SHERIDAN

Contact: Ervin Steitzer, (406) 765-1400

Sys Fac ID: 46-10679
Last Inspected On: 4/27/2016
Operating Permit Renewal Date: 6/4/2019

Owners/Operators: Montana Pioneer Manor Inc, Owner (406)-765-1362 605 SHERIDAN ST PLENTYWOOD MT 59254-1715

Charles Archer, UST Class A Operator
Diane Archer, UST Class A Operator
Ervin Steltzer, UST Class A Operator
Charles Archer, UST Class B Operator
Diane Archer, UST Class B Operator
Ervin Steltzer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	5/1/1996	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1673		7/25/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Heating Oil			Manual Interstitial Monitor	Manual Interstitial Monitor	
10,000					

Facility Summary in SHERIDAN County in the City of PLENTYWOOD

Location: MNLC INC CAN AM STORES
203 RAYMOND RD
PLENTYWOOD, MT 59254 SHERIDAN

Contact: Lance Chandler, (406) 765-2983

Sys Fac ID: 46-12667
Last Inspected On: 8/20/2015
Operating Permit Renewal Date: 11/13/2018

Owners/Operators: MNLC Inc Can Am Stores, Owner (406)-765-2121 203 RAYMOND RD PLENTYWOOD MT 59254-1545
Lance Chandler, UST Class A Operator
Lance Chandler, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	7/1/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2954			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Manual Interstitial Monitor	Not Listed	
10,000					
2	25	7/1/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2955			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Interstitial Monitor	Not Listed	
10,000					

Facility Summary in SHERIDAN County in the City of RESERVE

Location: JACKS SERVICE
101 MAIN ST
RESERVE, MT 59258 SHERIDAN

Contact: Jack Schmidt, (406) 286-5465

Sys Fac ID: 46-02103
Last Inspected On: 7/21/2016
Operating Permit Renewal Date: 8/10/2019

Owners/Operators: Jacks Service Reserve, Owner (406)-286-5276 PO BOX 165
RESERVE MT 59258-0165

Jack Schmidt, UST Class A Operator
Jack Schmidt, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	25	5/21/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4733			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Manual Interstitial Monitor	Deferred	
2,000					
5	16	7/27/2000	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4213			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Interstitial Monitor	Deferred	
2,000					

Facility Summary in SILVER BOW County in the City of ANACONDA

Location: FAIRMONT RV PARK AND CAMPGROUND LLC
1700 FAIRMONT RD
ANACONDA, MT 59711 SILVER BOW

Contact: Nancy or Kevin Johnson, (406) 797-3505

Sys Fac ID: 56-13976
Last Inspected On: 9/7/2016
Operating Permit Renewal Date: 11/1/2019

Owners/Operators: Fairmont RV Park & Campground LLC, Owner (406)-209-1794 1700 FAIRMONT RD ANACONDA MT 59711-9419

Kevin Johnson, UST Class A Operator
Nancy Johnson, UST Class A Operator
Jeana Johnson, UST Class B Operator
Kevin Johnson, UST Class B Operator
Nancy Johnson, UST Class B Operator
Shelia Johnson, UST Class B Operator
Caroline Thomer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	16	4/1/2000	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4187			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Manual Interstitial Monitor	Deferred	
3,000					
3	16	4/1/2000	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4188			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Interstitial Monitor	Deferred	
3,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: CENEX ZIP TRIP #73
848 W PARK ST
BUTTE, MT 59701 SILVER BOW
Contact: Rick Bates, (509) 535-7701

Sys Fac ID: 47-00386
Last Inspected On: 7/7/2016
Operating Permit Renewal Date: 11/13/2019

Owners/Operators: CHS Inc - Spokane Valley, Owner/Operator (509)-535-7701 16124 E MARIETTA LANE SPOKANE WA 99213

Sean Hurley, UST Class A Operator
Roy Morris, UST Class A Operator
Isaac Durnford, UST Class B Operator
Mitchell Kilmer, UST Class B Operator
Terri Stringer, UST Class B Operator
Luci Tuttle, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	18	9/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4425			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	18	9/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4426			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	18	9/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4427			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: ACADIA MONTANA
55 BASIN CREEK RD
BUTTE, MT 59701 SILVER BOW

Contact: Roger Stabey, (406) 496-6329

Sys Fac ID: 47-00458
Last Inspected On: 4/7/2016
Operating Permit Renewal Date: 9/21/2019

Owners/Operators:

Kids Behavioral Health, Owner	(406)-494-4183	55 BASIN CREEK RD BUTTE MT 59701
Leon Huizinga, Operator	(406)-496-6329	55 BASIN CREEK RD BUTTE MT 59701-9704

Leon Huizinga, UST Class A Operator
Todd Skartved, UST Class A Operator
Leon Huizinga, UST Class B Operator
Bill English, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	6/22/1987	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3974		4/2/2016	None	Secondary Containment Chase	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, Not Listed	
2,000		5/26/2016	TLS-300 , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: THRIFTWAY SUPER STOP 5
901 E FRONT ST
BUTTE, MT 59701 SILVER BOW
Contact: David Sutey, (406) 494-2305

Sys Fac ID: 47-00942
Last Inspected On: 6/3/2016
Operating Permit Renewal Date: 6/12/2019

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE BUTTE MT 59701-3553

Jack Hook, UST Class A Operator
Linda Otonicar, UST Class A Operator
Louie Sutey, UST Class A Operator
Allen Beagley, UST Class B Operator
Jack Hook, UST Class B Operator
Linda Otonicar, UST Class B Operator
Allen Beagley, UST Class B Global Operator
Jack Hook, UST Class B Global Operator
Louie Sutey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	8/1/1994	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2059			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	22	8/1/1994	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2060			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	22	8/1/1994	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2061			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: MDOT BUTTE DISTRICT HEADQUARTERS
3751 WYNNE AVE
BUTTE, MT 59701 SILVER BOW

Contact: Joe Radonich, (406) 444-9204

Sys Fac ID: 47-01062
Last Inspected On: 3/7/2016
Operating Permit Renewal Date: 7/14/2019

Owners/Operators:

MDOT Helena, Owner	(406)-444-6200	KIM JANZEN PO BOX 201001 HELENA MT 59620-1001
Joseph J Radonich, Operator	(406)-444-9204	MDT DEADHEAD HELENA MT 59620-0901

Jeff Gleason, UST Class A Operator
Walt Kerttula, UST Class A Operator
Mike Murolo, UST Class A Operator
Joe Radonich, UST Class A Operator
Roy Beckman, UST Class B Operator
Donald Serich, UST Class B Operator
Charles Stratford, UST Class B Operator
Joe Radonich, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	22	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2937			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
10,000			Gilbarco EMC Basic , Gilbarco		
9	22	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2938			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Deferred	
10,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: MOUNT MORIAH CEMETERY ASSOCIATION
2415 S MONTANA ST
BUTTE, MT 59701 SILVER BOW

Contact: Edwin J Zimpel III, (406) 782-1778

Sys Fac ID: 47-01705
Last Inspected On: 5/5/2016
Operating Permit Renewal Date: 10/9/2019

Owners/Operators: Mount Moriah Cemetery Association, Owner (406)-782-1778 2415 S MONTANA ST BUTTE MT 59701-3047
Carolyn Goody, UST Class A Operator
Carolyn Goody, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	20	7/1/1996	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1720			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		5/5/2016	Manual Tank Gauging	Deferred	
300					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: SHEAS AUTO REPAIR
910 S MONTANA ST
BUTTE, MT 59701 SILVER BOW

Contact: Jamey Shea, (406) 723-7306

Sys Fac ID: 47-01835
Last Inspected On: 2/10/2014
Operating Permit Renewal Date: 4/20/2017

Owners/Operators: Bigheads Inc, Owner (406)-723-7306 624 N HENRY AVE
BUTTE MT 59701-2838

Catherine Shea, UST Class A Operator
Paul Shea, UST Class A Operator
Jake Perusich, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	17	2/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3959			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
4,000			Gilbarco EMC Basic , Gilbarco		
8	17	2/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3960			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
4,000			Gilbarco EMC Basic , Gilbarco		
9	17	2/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3961			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: BUTTE SCHOOL DIST 1 BUS BARN
1220 E FRONT ST
BUTTE, MT 59701 SILVER BOW

Contact: Mel Rauch, (406) 496-2185

Sys Fac ID: 47-01980
Last Inspected On: 8/29/2016
Operating Permit Renewal Date: 1/31/2020

Owners/Operators: School Dist 1 Butte, Owner (406)-496-2185 1220 E FRONT ST BUTTE MT 59701-2936

Leonard Diaz, UST Class A Operator
Jed Johnson, UST Class A Operator
Leonard Diaz, UST Class B Operator
Jed Johnson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1892			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Deferred	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: CENEX ZIP TRIP #72
2801 HARRISON AVE
BUTTE, MT 59701 SILVER BOW
Contact: Rick Bates, (509) 535-7701

Sys Fac ID: 47-05148
Last Inspected On: 11/5/2014
Operating Permit Renewal Date: 12/26/2017

Owners/Operators: CHS Inc - Spokane Valley, Owner/Operator (509)-535-7701 16124 E MARIETTA LANE SPOKANE WA 99213

Sean Hurley, UST Class A Operator
Deb Morris, UST Class A Operator
Roy Morris, UST Class A Operator
Isaac Durnford, UST Class B Operator
Mitchell Kilmer, UST Class B Operator
Deb Morris, UST Class B Operator
Karina Serrano, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	3/19/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1709			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000					
2	26	3/19/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1710			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000					
3	26	3/19/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1711			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
6,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: CENEX ZIP TRIP #72
2801 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Contact: Rick Bates, (509) 535-7701

Sys Fac ID: 47-05148
Last Inspected On: 11/5/2014
Operating Permit Renewal Date: 12/26/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	26	3/19/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1707			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
12,000					
9	26	3/19/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1708			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
12,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: LISACS SOUTHSIDE EXXON
2544 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Contact: Edward Lisac, (406) 494-7056

Sys Fac ID: 47-05202
Last Inspected On: 5/12/2014
Operating Permit Renewal Date: 8/19/2017

Owners/Operators: Edward Lisac, Owner (406)-494-7056 2544 HARRISON AVE
BUTTE MT 59701-6055

Nadene Lisac, UST Class A Operator
Nadene Lisac, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	3/8/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
1547			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/13/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	26	3/8/1990	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
1546			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/13/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	21	6/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1549			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		6/17/2008	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	21	6/1/1995	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
1548			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		6/17/2008	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: HOLLOW CONSTRUCTION
404 W GREENWOOD AVE
BUTTE, MT 59701 SILVER BOW
Contact: William J Hollow, (406) 782-6033

Sys Fac ID: 47-05359
Last Inspected On: 1/9/2015
Operating Permit Renewal Date:

Owners/Operators: Hollow Contracting, Owner (406)-782-6033 404 W GREENWOOD AVE BUTTE MT 59701-2898
Susan Lasher, UST Class A Operator
Susan Lasher, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4162			None	Double-Walled	Yes
Temporarily Out of Use		5/1/2009	Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
15,000					
3	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4163			None	Double-Walled	Yes
Temporarily Out of Use		5/1/2009	Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000					
4	16	1/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4164			None	Double-Walled	Yes
Temporarily Out of Use		5/1/2009	Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: SUNKEN TREASURE
2900 HARRISON AVE
BUTTE, MT 59701 SILVER BOW
Contact: Jon Dehler, (406) 494-2402

Sys Fac ID: 47-05772
Last Inspected On: 5/16/2014
Operating Permit Renewal Date: 8/2/2017

Owners/Operators: JD & JD LLC, Owner (406)-259-8857 200 REGAL ST
BILLINGS MT 59101-3133

Bobbie Goodenow, UST Class A Operator
Marco Kurilich, UST Class A Operator
Bobbie Goodenow, UST Class B Operator
Marco Kurilich, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	38	11/14/1978	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1369			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/13/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	44	11/13/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1370			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/13/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	44	11/13/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1371			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/13/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: SUNKEN TREASURE
2900 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Contact: Jon Dehler, (406) 494-2402

Sys Fac ID: 47-05772
Last Inspected On: 5/16/2014
Operating Permit Renewal Date: 8/2/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	44	11/13/1972	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1372			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/13/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: ST JAMES HEALTHCARE INC
400 S CLARK ST
BUTTE, MT 59701 SILVER BOW

Contact: Mike Wilson, (406) 723-2500

Sys Fac ID: 47-06924
Last Inspected On: 10/7/2016
Operating Permit Renewal Date: 12/5/2019

Owners/Operators: St James Healthcare Inc, Owner (406)-723-2747 400 S CLARK ST BUTTE MT 59701-2328

David Fawcett, UST Class A Operator
David Palmer, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	15	5/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4449		10/6/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
15,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: THRIFTWAY SUPER STOP 1
3501 HARRISON AVE
BUTTE, MT 59701 SILVER BOW
Contact: David Sutey, (406) 494-2305

Sys Fac ID: 47-07932
Last Inspected On: 6/2/2016
Operating Permit Renewal Date: 11/13/2019

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE BUTTE MT 59701-3553

Jack Hook, UST Class A Operator
Linda Otonicar, UST Class A Operator
Louie Sutey, UST Class A Operator
Cindy Beck, UST Class B Operator
Jack Hook, UST Class B Operator
Stacey Smith, UST Class B Operator
Carrie Taylor, UST Class B Operator
Jack Hook, UST Class B Global Operator
Louie Sutey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	4/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2062			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable
Gasoline		6/2/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
14,783		6/23/2009	TLS-350/Gilbarco EMC , Veeder Root		
8	26	4/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2065			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable
Diesel		6/2/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,929		6/23/2009	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: THRIFTWAY SUPER STOP 1
3501 HARRISON AVE
BUTTE, MT 59701 SILVER BOW
Contact: David Sutey, (406) 494-2305

Sys Fac ID: 47-07932
Last Inspected On: 6/2/2016
Operating Permit Renewal Date: 11/13/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	26	4/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2066			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable
Diesel		6/2/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,929		6/23/2009	TLS-350/Gilbarco EMC , Veeder Root		
10	26	4/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2063			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable
Gasoline		6/2/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
11,627		6/23/2009	TLS-350/Gilbarco EMC , Veeder Root		
11	26	4/10/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2064			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Not Listed	Not Applicable
Gasoline		6/2/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
11,627		6/23/2009	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: THRIFTWAY SUPER STOP 4
2610 HARRISON AVE
BUTTE, MT 59701 SILVER BOW
Contact: David Sutey, (406) 494-2305

Sys Fac ID: 47-07934
Last Inspected On: 6/2/2016
Operating Permit Renewal Date: 6/20/2019

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE BUTTE MT 59701-3553

Geoff Gifford, UST Class A Operator
Jack Hook, UST Class A Operator
Linda Otonicar, UST Class A Operator
Louie Sutey, UST Class A Operator
Geoff Gifford, UST Class B Operator
Jack Hook, UST Class B Operator
Rebecca Hook, UST Class B Operator
Michael Townsend, UST Class B Operator
Jack Hook, UST Class B Global Operator
Louie Sutey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	26	3/13/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2067			None	None	Yes
Currently in Use		3/13/2000	Mechanical Line Leak Detector	Not Listed	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
11,627		4/20/2016	TLS-300 , Veeder Root		
6	26	3/13/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2068			None	None	Yes
Currently in Use		3/13/2000	Mechanical Line Leak Detector	Not Listed	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
11,627		4/20/2016	TLS-300 , Veeder Root		
7	26	3/13/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2069			None	None	Yes
Currently in Use		3/13/2000	Mechanical Line Leak Detector	Not Listed	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
11,627		4/20/2016	TLS-300 , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: THRIFTWAY SUPER STOP 2
1900 S MONTANA ST
BUTTE, MT 59701 SILVER BOW

Contact: Dave Sutey, (406) 782-5661

Sys Fac ID: 47-07935
Last Inspected On: 6/3/2016
Operating Permit Renewal Date: 6/12/2019

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE BUTTE MT 59701-3553

Jack Hook, UST Class A Operator
Linda Otonicar, UST Class A Operator
Louie Sutey, UST Class A Operator
Jack Hook, UST Class B Operator
Patsy Lingenfelter, UST Class B Operator
Christopher Otonicar, UST Class B Operator
Sam Spetter, UST Class B Operator
Jack Hook, UST Class B Global Operator
Louie Sutey, UST Class B Global Operator
Marianne Taylor, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	27	5/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2070			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
11,627		4/21/2016	TLS-350/Gilbarco EMC , Veeder Root		
5	27	5/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2071			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
11,627		4/21/2016	TLS-350/Gilbarco EMC , Veeder Root		
6	27	5/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2072			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
11,627		4/21/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: THRIFTWAY SUPER STOP 6
2401 CONTINENTAL DR
BUTTE, MT 59701 SILVER BOW
Contact: David Sutey, (406) 494-2305

Sys Fac ID: 47-07936
Last Inspected On: 6/22/2016
Operating Permit Renewal Date: 11/13/2019

Owners/Operators: Sutey Oil Co Inc, Owner (406)-494-2305 2000 HOLMES AVE BUTTE MT 59701-3553

Ken Beck, UST Class A Operator
Jack Hook, UST Class A Operator
Linda Otonicar, UST Class A Operator
Louie Sutey, UST Class A Operator
Ken Beck, UST Class B Operator
Jack Hook, UST Class B Operator
Marianne Taylor, UST Class B Operator
Jack Hook, UST Class B Global Operator
Louie Sutey, UST Class B Global Operator
Jessica Willis, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	48	5/7/1968	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2073		7/23/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/6/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		6/3/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	48	5/7/1968	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2074		7/23/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/6/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		6/5/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: THRIFTWAY SUPER STOP 6
2401 CONTINENTAL DR
BUTTE, MT 59701 SILVER BOW

Contact: David Sutey, (406) 494-2305

Sys Fac ID: 47-07936
Last Inspected On: 6/22/2016
Operating Permit Renewal Date: 11/13/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	43	5/7/1973	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2075		7/23/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/6/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		6/18/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: BUTTE SILVER BOW MAINTENANCE CENTER
1700 CIVIC CENTER RD
BUTTE, MT 59701 SILVER BOW

Contact: John Stajcar, (406) 497-6569

Sys Fac ID: 47-08477
Last Inspected On: 4/7/2016
Operating Permit Renewal Date: 6/9/2019

Owners/Operators: Butte Silver Bow County, Owner (406)-497-6569 1700 CIVIC CENTER RD BUTTE MT 59701-4857

Jed Johnson, UST Class A Operator
Todd Skartved, UST Class A Operator
John Stajcar, UST Class A Operator
Jed Johnson, UST Class B Global Operator
Todd Skartved, UST Class B Global Operator
John Stajcar, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	19	1/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
511		4/7/2016	None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
15,000		5/4/2016	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
7	19	1/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
512		4/7/2016	None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
15,000		5/4/2016	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 1
1370 HARRISON AVE
BUTTE, MT 59701 SILVER BOW
Contact: Roger Hovis, (406) 782-4442

Sys Fac ID: 47-08679
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 5/31/2018

Owners/Operators: Town Pump Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-2534

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	7/28/1991	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2621			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	28	4/11/1988	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2620			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	30	4/11/1986	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2619			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 1
1370 HARRISON AVE
BUTTE, MT 59701 SILVER BOW
Contact: Roger Hovis, (406) 782-4442

Sys Fac ID: 47-08679
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 5/31/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	28	4/11/1988	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2618			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 2
531 S MONTANA ST
BUTTE, MT 59701 SILVER BOW
Contact: Kevin Kenneally, (406) 497-6700

Sys Fac ID: 47-08680
Last Inspected On: 2/4/2015
Operating Permit Renewal Date: 2/9/2018

Owners/Operators: Major Enterprises of Butte Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000
Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	9/1/1985	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2622			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		5/7/2006	TLS-350/Gilbarco EMC , Veeder Root		
2	31	9/1/1985	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2623			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		5/7/2006	TLS-350/Gilbarco EMC , Veeder Root		
3	28	9/1/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2624			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		5/7/2006	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 3
2328 S MONTANA ST
BUTTE, MT 59701 SILVER BOW

Contact: Kevin Kenneally, (406) 782-6758

Sys Fac ID: 47-08682
Last Inspected On: 2/4/2015
Operating Permit Renewal Date: 2/9/2018

Owners/Operators: Montana Town Pump Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	26	10/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2626			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/5/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
4	26	10/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2627			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/5/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
5	26	10/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2628			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/5/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 3
2328 S MONTANA ST
BUTTE, MT 59701 SILVER BOW

Contact: Kevin Kenneally, (406) 782-6758

Sys Fac ID: 47-08682
Last Inspected On: 2/4/2015
Operating Permit Renewal Date: 2/9/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	35	4/11/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2625			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		1/7/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 8
2001 DEWEY BLVD
BUTTE, MT 59701 SILVER BOW

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 47-08686
Last Inspected On: 2/4/2015
Operating Permit Renewal Date: 2/9/2018

Owners/Operators: U Pump Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Scot Gramm, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Scot Gramm, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	35	10/1/1981	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2629			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-350/Gilbarco EMC , Veeder Root		
2	35	10/1/1981	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
4265			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-350/Gilbarco EMC , Veeder Root		
3	39	1/1/1977	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2631			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 8
2001 DEWEY BLVD
BUTTE, MT 59701 SILVER BOW

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 47-08686
Last Inspected On: 2/4/2015
Operating Permit Renewal Date: 2/9/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	35	10/1/1981	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2632			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 10
901 N EXCELSIOR AVE
BUTTE, MT 59701 SILVER BOW

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 47-08687
Last Inspected On: 2/4/2015
Operating Permit Renewal Date: 2/9/2018

Owners/Operators: Excel Town Pump Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Brad Nelsen, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	45	4/12/1971	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2633			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	45	4/12/1971	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2634			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/2/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: ROCKER FLYING J
1122000 N BROWNS GULCH RD
BUTTE, MT 59701 SILVER BOW
Contact: Gary Dietz, (406) 723-4325

Sys Fac ID: 47-09893
Last Inspected On: 2/4/2015
Operating Permit Renewal Date: 2/9/2018

Owners/Operators: Montana Innovations LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Trent Biggers, UST Class A Operator
Don Edmisten, UST Class A Operator
Trent Biggers, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
16			Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5302			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000		9/6/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
17			Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5303			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000		9/6/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
18			Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5304			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000		9/6/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: ROCKER FLYING J
1122000 N BROWNS GULCH RD
BUTTE, MT 59701 SILVER BOW
Contact: Gary Dietz, (406) 723-4325

Sys Fac ID: 47-09893
Last Inspected On: 2/4/2015
Operating Permit Renewal Date: 2/9/2018

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
19			Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5305			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
30,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
20			Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5306			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
21			Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5307			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
22			Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5308			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: THRIFTWAY #16
4701 HARRISON AVE
BUTTE, MT 59701 SILVER BOW
Contact: Linda Sutey, (406) 494-2305

Sys Fac ID: 47-10657
Last Inspected On: 7/7/2016
Operating Permit Renewal Date: 7/10/2019

Owners/Operators: Sutey Oil Co Inc, Owner/Operator (406)-494-2305 2000 HOLMES AVE BUTTE MT 59701-3553

Joe Benski, UST Class A Operator
Jack Hook, UST Class A Operator
Linda Otonicar, UST Class A Operator
Adriana Rigney, UST Class A Operator
Joe Benski, UST Class B Operator
Mark Hodges, UST Class B Operator
Jack Hook, UST Class B Operator
Adriana Rigney, UST Class B Operator
Jack Hook, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	11/1/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1921			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		6/3/2016	TLS-350/Gilbarco EMC , Veeder Root		
2	29	11/1/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1922			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		6/3/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: THRIFTWAY #16
4701 HARRISON AVE
BUTTE, MT 59701 SILVER BOW
Contact: Linda Sutey, (406) 494-2305

Sys Fac ID: 47-10657
Last Inspected On: 7/7/2016
Operating Permit Renewal Date: 7/10/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	29	11/1/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1923			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		6/8/2016	TLS-350/Gilbarco EMC , Veeder Root		
4	29	11/1/1987	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1924			None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		7/18/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		6/8/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: SILVER BOW COUNTY PUBLIC WORKS
BROWNS GULCH
BUTTE, MT 59701 SILVER BOW

Contact: John Stajcar, (406) 497-6569

Sys Fac ID: 47-13157
Last Inspected On: 4/7/2016
Operating Permit Renewal Date: 6/9/2019

Owners/Operators: Silver Bow County Browns Gulch Landfill, Owner (406)-497-6521 RICK GELLING
126 W GRANITE ST
BUTTE MT 59701-9216

Todd Skartved, UST Class A Operator
John Stajcar, UST Class A Operator
Todd Skartved, UST Class B Global Operator
John Stajcar, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4465			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Deferred	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC ROCKER
1000 GRIZZLY TRL
BUTTE, MT 59701 SILVER BOW
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 47-13173
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 5/31/2018

Owners/Operators: Town Pump of Rocker Inc, Owner (406)-497-6700 600 S MAIN BUTTE MT 59701-6000
Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2644			None	None	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2645			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
3	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2635			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC ROCKER
1000 GRIZZLY TRL
BUTTE, MT 59701 SILVER BOW

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 47-13173
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 5/31/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2641			None	None	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
5	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2642			None	None	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
6	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2643			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
7	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2639			None	None	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
8	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2640			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC ROCKER
1000 GRIZZLY TRL
BUTTE, MT 59701 SILVER BOW

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 47-13173
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 5/31/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2638			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
10	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2637			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
11	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2636			None	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
12	17	6/1/1999	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4103			Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: RD'S QUICK FUEL
16 E DEWEY BLVD
BUTTE, MT 59701 SILVER BOW
Contact: Jay Brookie, (406) 294-0865

Sys Fac ID: 47-13531
Last Inspected On: 11/9/2016
Operating Permit Renewal Date: 12/5/2019

Owners/Operators:

Morris Marketing Co Inc, Owner	(406)-782-4255	PO BOX 3839 BUTTE MT 59702-3839
City Service Valcon LLC, Operator	(406)-294-0865	640 W MONTANA ST KALISPELL MT 59904

Jay Brookie, UST Class A Operator
Roy Morris, UST Class A Operator
Mitchell Kilmer, UST Class B Operator
Jay Brookie, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1712			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		8/20/2013	TLS-350/Gilbarco EMC , Veeder Root		
2	22	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1713			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		8/20/2013	TLS-350/Gilbarco EMC , Veeder Root		
3	22	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1714			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		8/20/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: RD'S QUICK FUEL
16 E DEWEY BLVD
BUTTE, MT 59701 SILVER BOW

Contact: Jay Brookie, (406) 294-0865

Sys Fac ID: 47-13531
Last Inspected On: 11/9/2016
Operating Permit Renewal Date: 12/5/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	22	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1715			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		8/20/2013	TLS-350/Gilbarco EMC , Veeder Root		
5	22	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1716			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		8/20/2013	TLS-350/Gilbarco EMC , Veeder Root		
6	22	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1717			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		8/20/2013	TLS-350/Gilbarco EMC , Veeder Root		
7	22	8/1/1994	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
1718			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		8/20/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: MONTANA RESOURCES INC
600 SHIELDS AVE
BUTTE, MT 59701 SILVER BOW

Contact: Robert Solari, (406) 723-4081

Sys Fac ID: 47-13549
Last Inspected On: 11/11/2014
Operating Permit Renewal Date: 3/5/2018

Owners/Operators: Montana Resources, Owner (406)-723-4081 600 SHIELDS AVE BUTTE MT 59701-2799

Thomas Dale, UST Class A Operator
Thomas Dale, UST Class B Operator
Daniel Lorengo, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	19	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1687		8/20/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Waste Oil			Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
6,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: BUTTE AVIATION INC
4602 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Contact: Dr Gene Hughes, (406) 494-6694

Sys Fac ID: 47-13713
Last Inspected On: 11/26/2001
Operating Permit Renewal Date:

Owners/Operators: Butte Aviation Inc, Owner (406)-494-6694 4602 HARRISON AVE
BUTTE MT 59701-6965

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	12/1/1995	Cathodically Protected Steel	Steel	
4663			None	None	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Aviation Gas			Manual Tank Gauging	Deferred	
100					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 4
3700 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-13911
Last Inspected On: 7/1/2015
Operating Permit Renewal Date: 10/14/2018

Owners/Operators: Bonner Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	17	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4022		8/13/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	17	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4023		8/13/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	17	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4024		8/13/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP INC BUTTE 4
3700 HARRISON AVE
BUTTE, MT 59701 SILVER BOW

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-13911
Last Inspected On: 7/1/2015
Operating Permit Renewal Date: 10/14/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	17	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4025		8/13/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	17	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4026		8/13/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	17	4/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4294		8/13/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: NORTHWEST PETROLEUM FACILITY
28 DEWEY BLVD
BUTTE, MT 59701 SILVER BOW

Contact: Kevin Kenneally, (406) 496-6062

Sys Fac ID: 56-14033
Last Inspected On: 7/1/2015
Operating Permit Renewal Date: 10/14/2018

Owners/Operators: Northwest Petroleum Co, Owner/Operator (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	14	4/17/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4639			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
25,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	14	4/17/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4640			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
25,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	14	4/17/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4641			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
25,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	14	4/17/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4642			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
25,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: NORTHWEST PETROLEUM FACILITY
28 DEWEY BLVD
BUTTE, MT 59701 SILVER BOW

Contact: Kevin Kenneally, (406) 496-6062

Sys Fac ID: 56-14033
Last Inspected On: 7/1/2015
Operating Permit Renewal Date: 10/14/2018

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
5	14	4/17/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4643			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
25,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	14	4/17/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4644			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
25,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	14	4/17/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4645			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
25,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	14	4/17/2002	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4646			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
25,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: QWEST BUTTE MAIN CENTRAL OFFICE
200 W BROADWAY ST
BUTTE, MT 59701 SILVER BOW

Contact: Kevin Robison, (801) 237-3006

Sys Fac ID: 56-14034
Last Inspected On: 11/16/2016
Operating Permit Renewal Date: 4/18/2020

Owners/Operators:

Qwest Corporation, Owner	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111
Qwest Corporation, Operator	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111
Kevin Robison, UST Class A Operator		
Kevin Robison, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	14	10/2/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4732		10/14/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,500			TLS-300 , Veeder Root		

Facility Summary in SILVER BOW County in the City of BUTTE

Location: DETENTION CENTER
155 W QUARTZ ST
BUTTE, MT 59701 SILVER BOW
Contact: Gary Lean, (406) 497-6401

Sys Fac ID: 56-14119
Last Inspected On: 3/18/2014
Operating Permit Renewal Date: 5/27/2017

Owners/Operators: Butte Silver Bow County, Owner (406)-497-6569 1700 CIVIC CENTER RD
BUTTE MT 59701-4857

Jerome McCarthy, Operator BUTTE DETENTION CENTER
155 W QUARTZ ST
BUTTE MT 59701-9200

Jed Johnson, UST Class A Operator
John Stajcar, UST Class A Operator
Jed Johnson, UST Class B Global Operator
John Stajcar, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	11	1/31/2005	Steel Clad	Flexible Plastic	High Level Alarm
5006		3/12/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
1,000					

Facility Summary in SILVER BOW County in the City of BUTTE

Location: Three Bears Alaska
45 THREE BEARS DR
BUTTE, MT 59701 SILVER BOW
Contact: David Weisz, (406) 494-7547

Sys Fac ID: 60-15058
Last Inspected On: 8/2/2016
Operating Permit Renewal Date: 1/9/2020

Owners/Operators: THREE BEARS ALASKA, Owner (907)-883-4324 PO BOX 189
TOK AK 99780-0189

Carla Caudy, UST Class A Operator
Matt Dunne, UST Class A Operator
Dave Goody, UST Class A Operator
Lindsay Myers, UST Class A Operator
Wendy Whelchel, UST Class A Operator
Carla Caudy, UST Class B Operator
Dave Goody, UST Class B Operator
Lindsay Myers, UST Class B Operator
Wendy Whelchel, UST Class B Operator
Matt Dunne, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	09	4/24/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5103			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
17,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	09	4/24/2007	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5104			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SILVER BOW County in the City of BUTTE

Location: FED EX DISTRIBUTION
119771 RICK JONES WAY
BUTTE, MT 59750 SILVER BOW

Contact: Greg Peters, (406) 782-4176

Sys Fac ID: 60-15178
Last Inspected On: 2/6/2015
Operating Permit Renewal Date: 4/12/2018

Owners/Operators:

Arc Febttmt 001 LLC, Owner	(215)-449-3600	200 DRYDEN ROAD SUITE 1100 DRESHER PA 19025
Greg Peters, Operator	(406)-782-4176	119771 RICK JONES WAY BUTTE MT 59750
Chong Lee, UST Class A Operator		
Greg Peters, UST Class A Operator		
Greg Peters, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	05	3/1/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5286			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		8/12/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in SILVER BOW County in the City of BUTTE

Location: TOWN PUMP BUTTE #5
2305 CONTINENTAL DIVIDE
BUTTE, MT 59701 SILVER BOW

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15187
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 6/11/2018

Owners/Operators:

Town Pump of Northwest Missoula Inc, Owner	(406)-497-6700	PO BOX 6000 BUTTE MT 59702-6000
Town Pump Inc, Operator	(406)-497-6700	PO BOX 6000 BUTTE MT 59702-2534

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	05	11/1/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5310			Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
20,000			TLS-350/Gilbarco EMC , Veeder Root		Yes
2	05	11/1/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5311			Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		Yes
3	05	11/1/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, Auto Shutoff
5312			Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
12,000			TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in SILVER BOW County in the City of MELROSE

Location: MELROSE BAR SERVICE STATION POST OFFICE
110 MAIN ST
MELROSE, MT 59743 SILVER BOW

Contact: Burr Lively, (406) 835-2711

Sys Fac ID: 47-07486
Last Inspected On: 1/6/2015
Operating Permit Renewal Date: 3/3/2018

Owners/Operators: Lively Inc, Owner (406)-835-2721 PO BOX 96
MELROSE MT 59743-0096

Lee Lively, UST Class A Operator
Lee Lively, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	33	5/8/1983	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4054			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/6/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	33	5/8/1983	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4055			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		1/6/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in STILLWATER County in the City of COLUMBUS

Location: FARMERS UNION TRADING CO
101 S PRATTEN ST PO BOX 509
COLUMBUS, MT 59019 STILLWATER

Contact: Ralph Lewis, (406) 322-5214

Sys Fac ID: 48-03409
Last Inspected On: 9/8/2016
Operating Permit Renewal Date: 10/31/2019

Owners/Operators: Farmers Union Trading Co Columbus, Owner (406)-322-5618 PO BOX 509 COLUMBUS MT 59019-0509

Jennifer Calovis, UST Class A Operator
Clarence McCade, UST Class B Operator
Jennifer Calovis, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	10/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1033			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/29/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,500		6/22/2007	Gilbarco EMC Basic , Gilbarco		
2	24	10/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1034			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		7/29/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
2,500		5/24/2007	Gilbarco EMC Basic , Gilbarco		
3	24	10/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1035			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		7/29/2016	Automatic Tank Gauging 0.2	Deferred	
2,500			Gilbarco EMC Basic , Gilbarco		
13	18	7/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4731			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		7/29/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		7/1/2007	Gilbarco EMC Basic , Gilbarco		

Facility Summary in STILLWATER County in the City of COLUMBUS

Location: FARMERS UNION TRADING CO
101 S PRATTEN ST PO BOX 509
COLUMBUS, MT 59019 STILLWATER

Contact: Ralph Lewis, (406) 322-5214

Sys Fac ID: 48-03409
Last Inspected On: 9/8/2016
Operating Permit Renewal Date: 10/31/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
14	18	7/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1037			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		7/29/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		6/17/2007	Gilbarco EMC Basic , Gilbarco		

Facility Summary in STILLWATER County in the City of COLUMBUS

Location: GITS CONOCO
740 E PIKE AVE
COLUMBUS, MT 59019 STILLWATER

Contact: Gary Woltermann, (406) 322-4111

Sys Fac ID: 48-07859
Last Inspected On: 7/8/2016
Operating Permit Renewal Date: 10/26/2019

Owners/Operators: Gits Inc, Owner (406)-322-4111 PO BOX 336
COLUMBUS MT 59019-0336

Tracy A Gernant, UST Class A Operator
Gary G Woltermann, UST Class A Operator
Tracy A Gernant, UST Class B Global Operator
Gary G Woltermann, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	37	5/8/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3209			Lined Interior/Impressed Current	None	Yes
Currently in Use		3/1/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/8/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		7/15/2010	TLS-350/Gilbarco EMC , Veeder Root		
2	37	5/8/1979	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3210			Lined Interior/Impressed Current	None	Yes
Currently in Use		3/1/2007	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/8/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		7/15/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in STILLWATER County in the City of COLUMBUS

Location: TOWN PUMP INC COLUMBUS UST
602 E 8TH AVE N
COLUMBUS, MT 59019 STILLWATER

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 48-08691
Last Inspected On: 7/31/2015
Operating Permit Renewal Date: 11/18/2018

Owners/Operators: Town and Country Supply and Management, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	32	5/1/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2646			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		11/17/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
6	32	9/1/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2647			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/17/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
7	27	12/29/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2648			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/17/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in STILLWATER County in the City of COLUMBUS

Location: TOWN PUMP INC COLUMBUS UST
602 E 8TH AVE N
COLUMBUS, MT 59019 STILLWATER

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 48-08691
Last Inspected On: 7/31/2015
Operating Permit Renewal Date: 11/18/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	28	11/1/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2649			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/17/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
9	28	11/1/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2650			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/17/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
10	28	11/1/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2651			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/17/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
11	17	6/25/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4064			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/17/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in STILLWATER County in the City of COLUMBUS

Location: TOWN PUMP INC COLUMBUS UST
602 E 8TH AVE N
COLUMBUS, MT 59019 STILLWATER

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 48-08691
Last Inspected On: 7/31/2015
Operating Permit Renewal Date: 11/18/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
12	17	6/25/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4065			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/17/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
13	17	6/25/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4066			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/17/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
14	11	12/30/2004	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4933			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/17/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in STILLWATER County in the City of FISHTAIL

Location: MDOT ROW FISHTAIL GENERAL STORE FHWA
35 W MAIN ST PO BOX 40
FISHTAIL, MT 59028 STILLWATER

Contact: Bill & Katy Martin, (406) 328-4260

Sys Fac ID: 48-03599
Last Inspected On: 9/25/2015
Operating Permit Renewal Date: 3/7/2019

Owners/Operators:

Katy Martin, Owner	(406)-328-4260	PO BOX 130 FISHTAIL MT 59028-0130
William Martin, Owner	(406)-328-4260	PO BOX 130 FISHTAIL MT 59028-0130

katy martin, UST Class A Operator
katy martin, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	5/1/1993	Steel Clad	Flexible Plastic	High Level Alarm
1086			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		9/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	23	5/1/1993	Steel Clad	Flexible Plastic	High Level Alarm
1087			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		9/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,002			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in STILLWATER County in the City of FISHTAIL

Location: NYE TRADING POST
1997 NYE ROAD
FISHTAIL, MT 59028 STILLWATER

Contact: Tandi Lindley, (406) 860-4968

Sys Fac ID: 48-09647
Last Inspected On: 9/25/2015
Operating Permit Renewal Date: 3/5/2019

Owners/Operators:

Chance Kukowski & Tandi Lindley, Owner	(406)-860-4968	1997 NYE ROAD FISHTAIL MT 59028-8049
Chance Kukowski, Operator	(406)-328-6262	1997 NYE ROAD FISHTAIL MT 59028
Tandi Lindley, Operator	(406)-860-4968	1997 NYE RD FISHTAIL MT 59028

WILLIAM HENDERSON, UST Class A Operator
Tandi Lindley, UST Class A Operator
William Henderson, UST Class B Operator
Tandi Lindley, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	23	10/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1296			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		9/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000			TLS-300 , Veeder Root		
4	23	10/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1297			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		9/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000			TLS-300 , Veeder Root		

Facility Summary in STILLWATER County in the City of FISHTAIL

Location: FISHTAIL BASIN RANCH
633 FIDDLER CREEK RD
FISHTAIL, MT 59028 STILLWATER

Contact: Francis Abbott Jr, (406) 328-6957

Sys Fac ID: 56-13917
Last Inspected On: 12/11/2014
Operating Permit Renewal Date: 1/28/2018

Owners/Operators: Francis H Abbott Jr, Owner (610)-353-9700 633 FIDDLER CREEK RD FISHTAIL MT 59028-8021
Francis H Abbott Jr, UST Class A Operator
Francis H Abbott Jr, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	17	3/1/1999	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4400	Yes	12/11/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Heating Oil		12/13/2011	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000					

Facility Summary in STILLWATER County in the City of FISHTAIL

Location: ROCKIN J
2993 MT HIGHWAY 78
FISHTAIL, MT 59028 STILLWATER

Sys Fac ID: 56-13932
Last Inspected On: 6/16/2014
Operating Permit Renewal Date: 7/15/2017

Contact: Joel Lindgren, (406) 328-6248

Owners/Operators: Rockin J Inc, Owner (406)-328-6248 JULIE & JOEL LINDGREN
PO BOX 216
RED LODGE MT 59068-0216

Joel Lindgren, UST Class A Operator
Julie Lindgren, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	17	5/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4038			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		6/24/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
2,000		6/16/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	17	5/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4039			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		6/24/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000		6/16/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	17	5/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4040			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		6/24/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		6/16/2014	TLS-350/Gilbarco EMC , Veeder Root		
4	17	5/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4041			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/24/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000		6/16/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in STILLWATER County in the City of FISHTAIL

Location: ROCKIN J
2993 MT HIGHWAY 78
FISHTAIL, MT 59028 STILLWATER

Contact: Joel Lindgren, (406) 328-6248

Sys Fac ID: 56-13932
Last Inspected On: 6/16/2014
Operating Permit Renewal Date: 7/15/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	17	5/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4042			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/24/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		6/16/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in STILLWATER County in the City of PARK CITY

Location: KWIK STOP INC
1 N CLARK ST
PARK CITY, MT 59063 STILLWATER

Contact: Margaret Keating, (406) 633-2730

Sys Fac ID: 48-06610
Last Inspected On: 1/14/2016
Operating Permit Renewal Date: 3/17/2019

Owners/Operators: Margaret Keating, Owner (406)-633-2730 PO BOX 128
PARK CITY MT 59063-0128

Margaret Keating, UST Class A Operator
Margaret Keating, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	19	5/5/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1507			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		5/20/2015	Automatic Tank Gauging 0.2	Deferred	
8,000			TLS-300 , Veeder Root		
4	19	5/5/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1508			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		5/20/2015	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-300 , Veeder Root		

Facility Summary in STILLWATER County in the City of PARK CITY

Location: ZIP TRIP 50
EXIT 426 & INTERSTATE 90 PO BOX 68
PARK CITY, MT 59063 STILLWATER

Sys Fac ID: 48-08910
Last Inspected On: 10/24/2016
Operating Permit Renewal Date: 10/25/2019

Contact: Luke Harnish, (406) 633-2359

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Pete Nussbaum, UST Class A Operator
ROBERT HAYS, UST Class B Operator
Darcy Ziegler, UST Class B Operator
Pete Nussbaum, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	24	5/1/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
568		5/7/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		5/19/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	24	5/1/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
569		5/7/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		5/19/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in STILLWATER County in the City of PARK CITY

Location: ZIP TRIP 50
EXIT 426 & INTERSTATE 90 PO BOX 68
PARK CITY, MT 59063 STILLWATER
Contact: Luke Harnish, (406) 633-2359

Sys Fac ID: 48-08910
Last Inspected On: 10/24/2016
Operating Permit Renewal Date: 10/25/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
10	24	5/1/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
570		5/7/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		8/17/2005	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
11	24	5/1/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
571		5/7/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		8/17/2005	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
12	24	5/1/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
572		5/7/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		8/17/2005	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
13	24	5/1/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
573		5/7/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		8/17/2005	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in STILLWATER County in the City of PARK CITY

Location: ZIP TRIP 50
EXIT 426 & INTERSTATE 90 PO BOX 68
PARK CITY, MT 59063 STILLWATER

Contact: Luke Harnish, (406) 633-2359

Sys Fac ID: 48-08910
Last Inspected On: 10/24/2016
Operating Permit Renewal Date: 10/25/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
14	18	8/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff, High Level Alarm
574		5/7/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		8/17/2005	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
15	18	8/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff, High Level Alarm
575		5/7/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		8/17/2005	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
16	18	8/1/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Positive Shutoff, High Level Alarm
576		5/7/2015	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/14/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		8/17/2005	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in STILLWATER County in the City of REED POINT

Location: REED POINT C-STORE
4 DIVISION ST
REED POINT, MT 59069 STILLWATER

Contact: Ralph Lewis, (406) 326-2484

Sys Fac ID: 48-01521
Last Inspected On: 6/10/2014
Operating Permit Renewal Date: 9/4/2017

Owners/Operators:

C Store Properties LLC, Owner	(406)-651-5101	PO BOX 80391 BILLINGS MT 59108
Valley Farmers Supply, Operator	(406)-967-3100	PO BOX 309 WORDEN MT 59088

Scott Black, UST Class A Operator
Elisha Lewis, UST Class A Operator
Ralph Lewis, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Roger Schmechel, UST Class B Operator
Stephanie Zierke, UST Class B Operator
Scott Black, UST Class B Global Operator
Elisha Lewis, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	12/10/1986	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3303			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/10/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		9/26/2013	TLS-350/Gilbarco EMC , Veeder Root		
2	29	12/10/1986	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3304			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/10/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		9/26/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in STILLWATER County in the City of REED POINT

Location: REED POINT C-STORE
4 DIVISION ST
REED POINT, MT 59069 STILLWATER

Contact: Ralph Lewis, (406) 326-2484

Sys Fac ID: 48-01521
Last Inspected On: 6/10/2014
Operating Permit Renewal Date: 9/4/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	29	12/10/1986	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3305			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/10/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000		9/26/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SWEET GRASS County in the City of BIG TIMBER

Location: THE FORT
228 BIG TIMBER LOOP
BIG TIMBER, MT 59011 SWEET GRASS
Contact: Jeff Cowell, (406) 932-5992

Sys Fac ID: 49-02680
Last Inspected On: 12/16/2014
Operating Permit Renewal Date: 3/19/2018

Owners/Operators: J Diamond L Inc, Owner (406)-932-5992 PO BOX 1343
BIG TIMBER MT 59011-1343

Donald Vancil, UST Class A Operator
Eon Day, UST Class B Operator
Harold Rains, UST Class B Operator
Colt Schieffert, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	20	8/1/1996	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
3229			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/16/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		1/17/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
5	20	8/1/1996	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
3230			None	Double-Walled	Yes
Currently in Use		8/1/2006	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/16/2014	Inventory Reconciliation, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
4,000		1/17/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	20	8/1/1996	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
3231			None	Double-Walled	Yes
Currently in Use		8/1/2006	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/16/2014	Inventory Reconciliation, Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		1/17/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SWEET GRASS County in the City of BIG TIMBER

Location: THE FORT
228 BIG TIMBER LOOP
BIG TIMBER, MT 59011 SWEET GRASS
Contact: Jeff Cowell, (406) 932-5992

Sys Fac ID: 49-02680
Last Inspected On: 12/16/2014
Operating Permit Renewal Date: 3/19/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	11	10/31/2005	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
5052			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/16/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		1/17/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in SWEET GRASS County in the City of BIG TIMBER

Location: SWEET GRASS CENEX
202 E 1ST AVE
BIG TIMBER, MT 59011 SWEET GRASS

Contact: Dennis Whitmore, (406) 932-5183

Sys Fac ID: 49-06069
Last Inspected On: 12/4/2014
Operating Permit Renewal Date: 3/19/2018

Owners/Operators: GM Petroleum Dist, Owner (406)-661-1112 PO BOX 80391 BILLINGS MT 59108

Laura Geffre, UST Class A Operator
Kyle Ginnaty, UST Class A Operator
Bill Grunstead, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Laura Geffre, UST Class B Operator
Roger Schmechel, UST Class B Operator
Stephanie Zierke, UST Class B Operator
Kyle Ginnaty, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	12/10/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3469			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		8/14/2014	Gilbarco EMC Basic , Gilbarco		
9	25	12/10/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3467			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		8/14/2014	Gilbarco EMC Basic , Gilbarco		
10	25	12/10/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3468			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		8/14/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in SWEET GRASS County in the City of BIG TIMBER

Location: SWEET GRASS CENEX
202 E 1ST AVE
BIG TIMBER, MT 59011 SWEET GRASS

Contact: Dennis Whitmore, (406) 932-5183

Sys Fac ID: 49-06069
Last Inspected On: 12/4/2014
Operating Permit Renewal Date: 3/19/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	10	2/10/2006	Concrete	Flexible Plastic	
5050	Yes		None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		12/4/2014	Deferred	MLLD Line Tightness Testing	
12,000		8/14/2014			
12	10	2/10/2006	Concrete	Flexible Plastic	
5051	Yes		None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		12/4/2014	Deferred	MLLD Line Tightness Testing	
12,000		8/14/2014			

Facility Summary in SWEET GRASS County in the City of BIG TIMBER

Location: BIG TIMBER TOWN PUMP AND CASINO
INTERSTATE 90 & US HIGHWAY 10 W
BIG TIMBER, MT 59011 SWEET GRASS
Contact: (406) 932-4419

Sys Fac ID: 49-09311
Last Inspected On: 7/31/2015
Operating Permit Renewal Date: 11/8/2018

Owners/Operators: Big Timber Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000
Don Edmisten, UST Class A Operator
Don Edmisten, UST Class B Global Operator

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
5	13	4/30/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4828			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
6	13	4/30/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4829			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
7	13	4/30/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4830			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in SWEET GRASS County in the City of BIG TIMBER

Location: BIG TIMBER TOWN PUMP AND CASINO
INTERSTATE 90 & US HIGHWAY 10 W
BIG TIMBER, MT 59011 SWEET GRASS
Contact: (406) 932-4419

Sys Fac ID: 49-09311
Last Inspected On: 7/31/2015
Operating Permit Renewal Date: 11/8/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	13	4/30/2003	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4831			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Stat. Inventory Reconcilitation, ELLD Line Tightness Testing, Approved Remote Monitoring	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in SWEET GRASS County in the City of BIG TIMBER

Location: TOWN PUMP INC BIG TIMBER 1ST AVE
510 W 1ST AVE
BIG TIMBER, MT 59011 SWEET GRASS

Contact: Roger Hovis, (406) 932-5349

Sys Fac ID: 49-13756
Last Inspected On: 10/7/2015
Operating Permit Renewal Date: 12/5/2018

Owners/Operators: Town Pump of Big Timber Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	8/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2652			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		9/1/2015	TLS-350/Gilbarco EMC , Veeder Root		
2	20	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2653			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		9/1/2015	TLS-350/Gilbarco EMC , Veeder Root		
3	20	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2654			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		9/1/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in SWEET GRASS County in the City of BIG TIMBER

Location: TOWN PUMP INC BIG TIMBER 1ST AVE
510 W 1ST AVE
BIG TIMBER, MT 59011 SWEET GRASS

Contact: Roger Hovis, (406) 932-5349

Sys Fac ID: 49-13756
Last Inspected On: 10/7/2015
Operating Permit Renewal Date: 12/5/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	20	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2655			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
5	20	10/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2656			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring, Deferred	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
6	14	5/1/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4649			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000		9/1/2015	TLS-350/Gilbarco EMC , Veeder Root		
7	14	5/1/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4650			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000		9/1/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in TETON County in the City of CHOTEAU

Location: KELLYS SERVICE
215 MAIN AVE S
CHOTEAU, MT 59422 TETON

Contact: Tim Kelly, (406) 466-2583

Sys Fac ID: 50-03593
Last Inspected On: 8/19/2016
Operating Permit Renewal Date: 10/19/2019

Owners/Operators: Kellys Service, Owner (406)-466-2583 PO BOX 427
CHOTEAU MT 59422-0427

Timothy Kelly, UST Class A Operator
Timothy Kelly, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	20	5/15/1996	Bare Steel	Fiberglass Reinforced Plastic	
1469	Yes	10/16/2013	None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
4,000		8/19/2016	ILS-350 , Veeder Root		
5	20	8/15/1996	Bare Steel	Fiberglass Reinforced Plastic	
1470	Yes	10/16/2013	None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
10,000		8/19/2016	ILS-350 , Veeder Root		
6	13	11/26/2003	Concrete	Flexible Plastic	
4929	Yes	10/16/2013	None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
10,000		8/19/2016	ILS-350 , Veeder Root		
7	13	11/26/2003	Concrete	Flexible Plastic	
4930	Yes	10/16/2013	None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
4,000		8/19/2016	ILS-350 , Veeder Root		

Facility Summary in TETON County in the City of CHOTEAU

Location: DESHS TIRE AND AUTO LLC
401 MAIN AVE S
CHOTEAU, MT 59422 TETON

Contact: Roy Deshner, (406) 466-2066

Sys Fac ID: 50-07565
Last Inspected On: 8/21/2015
Operating Permit Renewal Date:

Owners/Operators: Roy and Pandora Deshner, Owner (406)-466-2066 PO BOX 397
CHOTEAU MT 59422-0397

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	24	4/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1487			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
6,000			Gilbarco EMC Basic , Gilbarco		
6	24	4/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1488			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
4,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in TETON County in the City of CHOTEAU

Location: MALMSTROM AFB F 2
US HIGHWAY 89
CHOTEAU, MT 59422 TETON

Contact: Jim Hodges,

Sys Fac ID: 50-09031
Last Inspected On: 9/18/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
304		6/12/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in TETON County in the City of CHOTEAU

Location: MALMSTROM AFB F 3
US HIGHWAY 287
CHOTEAU, MT 59422 TETON

Contact: Jim Hodges,

Sys Fac ID: 50-09032
Last Inspected On: 9/18/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
305		6/12/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in TETON County in the City of CHOTEAU

Location: MALMSTROM AFB F 9
US HIGHWAY 89
CHOTEAU, MT 59422 TETON

Contact: Jim Hodges,

Sys Fac ID: 50-09038
Last Inspected On: 9/18/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
308		6/13/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in TETON County in the City of CHOTEAU

Location: MALMSTROM AFB F 10
US HIGHWAY 89
CHOTEAU, MT 59422 TETON

Contact: Jim Hodges,

Sys Fac ID: 50-09039
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	6/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Auto Shutoff
309		6/10/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in TETON County in the City of CHOTEAU

Location: MALMSTROM AFB F 11
US HIGHWAY 89
CHOTEAU, MT 59422 TETON

Contact: Jim Hodges,

Sys Fac ID: 50-09040
Last Inspected On: 9/18/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	6/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
310		9/11/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in TETON County in the City of CHOTEAU

Location: MALMSTROM AFB H 10
US HIGHWAY 89
CHOTEAU, MT 59422 TETON

Contact: Jim Hodges,

Sys Fac ID: 50-09061
Last Inspected On: 9/14/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	9/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
315		6/9/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in TETON County in the City of CHOTEAU

Location: MALMSTROM AFB H 11
ROAD 221
CHOTEAU, MT 59422 TETON

Contact: Jim Hodges,

Sys Fac ID: 50-09062
Last Inspected On: 9/14/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	9/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
316		6/9/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in TETON County in the City of CHOTEAU

Location: MAIN STREET EXPRESS LLP
222 N MAIN AVE
CHOTEAU, MT 59422 TETON

Contact: Jerry Breen, (406) 466-5863

Sys Fac ID: 56-13816
Last Inspected On: 9/14/2016
Operating Permit Renewal Date: 11/21/2019

Owners/Operators: Main Street Express LLP, Owner (406)-466-5863 PO BOX 10
CHOTEAU MT 59422-0010

Jerold Breen, UST Class A Operator
Jerold Breen, UST Class B Operator
Rhonda Brewster, UST Class B Operator
John Noyd, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	19	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
488			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	19	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
489			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	19	10/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
490			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in TETON County in the City of CHOTEAU

Location: BREEN OIL CARD LOCK S
505 S MAIN ST
CHOTEAU, MT 59422 TETON
Contact: (406) 466-2575

Sys Fac ID: 56-14147
Last Inspected On: 3/13/2014
Operating Permit Renewal Date: 4/27/2017

Owners/Operators: K B Leasing, Owner (406)-466-2575 PO BOX 253
CHOTEAU MT 59422-0253

Jerold Breen, UST Class A Operator
Jerold Breen, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	11	1/14/2005	Concrete	Flexible Plastic	High Level Alarm
4950	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Deferred	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
2	11	1/14/2005	Concrete	Flexible Plastic	High Level Alarm
4951	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Deferred	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
3,000			TLS-350/Gilbarco EMC , Veeder Root		
3	11	1/14/2005	Concrete	Flexible Plastic	High Level Alarm
4952	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Deferred	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
3,000			TLS-350/Gilbarco EMC , Veeder Root		
4	11	1/14/2005	Concrete	Flexible Plastic	High Level Alarm
4953	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Deferred	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
5,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in TETON County in the City of CHOTEAU

Location: BREEN OIL CARD LOCK S
505 S MAIN ST
CHOTEAU, MT 59422 TETON
Contact: (406) 466-2575

Sys Fac ID: 56-14147
Last Inspected On: 3/13/2014
Operating Permit Renewal Date: 4/27/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	11	1/14/2005	Concrete	Flexible Plastic	High Level Alarm
4954	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Deferred	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
6	11	1/14/2005	Concrete	Flexible Plastic	High Level Alarm
4955	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Deferred	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
3,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in TETON County in the City of DUTTON

Location: DUTTON SCHOOL DIST 28
101 2ND ST NE
DUTTON, MT 59433 TETON

Contact: Ward Fifield, (406) 476-3424

Sys Fac ID: 50-03600
Last Inspected On: 3/18/2014
Operating Permit Renewal Date: 8/27/2017

Owners/Operators: School Dist 28C Dutton Brady, Owner (406)-476-3201 101 2ND ST NE DUTTON MT 59433-9670

Clifford Suek, UST Class A Operator
Clifford Suek, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	27	8/21/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
842			None	None	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Heating Oil			Automatic Tank Gauging 0.2	Deferred	
10,000		3/18/2014	EECO 1500 , EMCO Electronics		

Facility Summary in TETON County in the City of DUTTON

Location: MOUNTAIN VIEW COOP DUTTON
110 MAIN ST W
DUTTON, MT 59433 TETON
Contact: Tom Demars, (406) 476-3411

Sys Fac ID: 50-03701
Last Inspected On: 7/6/2016
Operating Permit Renewal Date: 9/5/2019

Owners/Operators: Mountain View Coop, Owner (406)-453-2435 ATTN DAVE DOUGLAS
2200 OLD HAVRE HWY
BLACK EAGLE MT 59414-1043

David Douglas, UST Class A Operator
Thomas Demars, UST Class B Operator
David Douglas, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	26	4/16/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4688		7/28/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		7/12/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
2,000			TLS-350/Gilbarco EMC , Veeder Root		
5	26	4/16/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4689		7/28/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		7/12/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
2,000			TLS-350/Gilbarco EMC , Veeder Root		
6	26	4/16/1990	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4690		7/28/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		7/12/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
2,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in TETON County in the City of DUTTON

Location: MOUNTAIN VIEW COOP DUTTON
110 MAIN ST W
DUTTON, MT 59433 TETON
Contact: Tom Demars, (406) 476-3411

Sys Fac ID: 50-03701
Last Inspected On: 7/6/2016
Operating Permit Renewal Date: 9/5/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	17	8/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4108		7/28/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline		7/12/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in TETON County in the City of DUTTON

Location: MALMSTROM AFB H 02
ROAD 221
DUTTON, MT 59433 TETON

Contact: Jim Hodges,

Sys Fac ID: 50-09053
Last Inspected On: 9/18/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	27	5/21/1989	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
312		6/15/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in TETON County in the City of DUTTON

Location: MALMSTROM AFB J 1
INTERSTATE 15
DUTTON, MT 59433 TETON

Contact: Jim Hodges,

Sys Fac ID: 50-09074
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Ricardo Andrillon, UST Class B Operator
Glen Beck, UST Class B Operator
Allen Brooks, UST Class B Operator
Jonathan Buesch, UST Class B Operator
John Corbett, UST Class B Operator
David Cosner, UST Class B Operator
Ryan Cox, UST Class B Operator
Brian Day, UST Class B Operator
David Degolier, UST Class B Operator
Patrick Ellis, UST Class B Operator
Hudson English, UST Class B Operator
Paul Floyd, UST Class B Operator
Dustin Hemingway, UST Class B Operator
Aaron Hill, UST Class B Operator
William Hoffmeister, UST Class B Operator
Shane Hofstad, UST Class B Operator
Bethany Kent, UST Class B Operator
James Knudsen, UST Class B Operator
Ryan Kofoed, UST Class B Operator
Jeff Laird, UST Class B Operator
Damon McCarty, UST Class B Operator
Kieth McIlwain, UST Class B Operator
Brian McVay, UST Class B Operator
Ronald Miller, UST Class B Operator
Michael Murieen, UST Class B Operator
Jeff Nelson, UST Class B Operator
Patrick Noppenberg, UST Class B Operator
Shawn O'Grady, UST Class B Operator
Chris Ploof, UST Class B Operator
Issac Price, UST Class B Operator
Brian Rayner, UST Class B Operator

Facility Summary in TETON County in the City of DUTTON

Location: MALMSTROM AFB J 1
INTERSTATE 15
DUTTON, MT 59433 TETON

Sys Fac ID: 50-09074
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Cameron Smith, UST Class B Operator
Jimmy Sonefelt, UST Class B Operator
Michael Stokes, UST Class B Operator
Kyle Topp, UST Class B Operator
Jason Vike, UST Class B Operator
James Wooderchak, UST Class B Operator
Paul Ziemba, UST Class B Operator
Paul Floyd, UST Class B Global Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	54	6/2/1962	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
317		9/14/2015	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Impressed Current
Diesel		7/31/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in TETON County in the City of DUTTON

Location: MALMSTROM AFB J 2
ROAD 379
DUTTON, MT 59433 TETON

Contact: Jim Hodges,

Sys Fac ID: 50-09075
Last Inspected On: 3/23/2016
Operating Permit Renewal Date: 6/27/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	8/1/1991	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
318		3/22/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in TETON County in the City of DUTTON

Location: MALMSTROM AFB J 11
INTERSTATE 15
DUTTON, MT 59433 TETON

Contact: Jim Hodges,

Sys Fac ID: 50-09084
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
320		6/22/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in TETON County in the City of DUTTON

Location: Mountain View Co Op
210 N GRAIN AVE
DUTTON, MT 59433 TETON
Contact: Frank Schumacher, (406) 476-3018

Sys Fac ID: 60-15071
Last Inspected On: 1/30/2014
Operating Permit Renewal Date: 5/7/2017

Owners/Operators: Mountain View Coop, Owner (406)-453-2435 ATTN DAVE DOUGLAS
2200 OLD HAVRE HWY
BLACK EAGLE MT 59414-1043

Pat Trainor, UST Class A Operator
Pat Trainor, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	09	11/7/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5111		5/22/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
20,000			TLS-250 , Veeder Root		Yes
2	09	11/7/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5112		5/22/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
20,000			TLS-250 , Veeder Root		Yes
3	09	11/7/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5113		5/22/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
20,000			TLS-250 , Veeder Root		Yes
4	09	11/7/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5114		5/22/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
30,000			TLS-250 , Veeder Root		Yes

Facility Summary in TETON County in the City of DUTTON

Location: Mountain View Co Op
210 N GRAIN AVE
DUTTON, MT 59433 TETON
Contact: Frank Schumacher, (406) 476-3018

Sys Fac ID: 60-15071
Last Inspected On: 1/30/2014
Operating Permit Renewal Date: 5/7/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	09	11/7/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5115		5/22/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
30,000			TLS-250 , Veeder Root		Yes
6	09	11/7/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5116		5/22/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
30,000			TLS-250 , Veeder Root		Yes
7	09	11/7/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5117		5/22/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
40,000			TLS-250 , Veeder Root		Yes
8	09	11/7/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5118		5/22/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
40,000			TLS-250 , Veeder Root		Yes
9	09	11/7/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5119		5/22/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
40,000			TLS-250 , Veeder Root		Yes

Facility Summary in TETON County in the City of DUTTON

Location: Mountain View Co Op
210 N GRAIN AVE
DUTTON, MT 59433 TETON
Contact: Frank Schumacher, (406) 476-3018

Sys Fac ID: 60-15071
Last Inspected On: 1/30/2014
Operating Permit Renewal Date: 5/7/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	09	11/7/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5120		5/22/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
40,000			TLS-250 , Veeder Root		Yes
11	09	11/7/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5121		5/22/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Gravity Feed	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
40,000			TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in TETON County in the City of FAIRFIELD

Location: MOUNTAIN VIEW COOP FAIRFIELD
US HIGHWAY 89 & CENTRAL AVE
FAIRFIELD, MT 59436 TETON

Contact: Pat Trainor, (406) 467-2516

Sys Fac ID: 50-03596
Last Inspected On: 7/14/2016
Operating Permit Renewal Date: 9/27/2019

Owners/Operators: Mountain View Coop, Owner (406)-453-2435 ATTN DAVE DOUGLAS
2200 OLD HAVRE HWY
BLACK EAGLE MT 59414-1043

Dave Douglas, UST Class A Operator
Denna Lekan, UST Class A Operator
Charla Merja, UST Class A Operator
Denna Lekan, UST Class B Operator
Charla Merja, UST Class B Operator
Nathan Pitcher, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	12/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1236			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
2	23	12/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1235			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000					
12	23	12/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1237			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000					
13	18	8/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1238			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000					

Facility Summary in TETON County in the City of FAIRFIELD

Location: MOUNTAIN VIEW COOP FAIRFIELD
US HIGHWAY 89 & CENTRAL AVE
FAIRFIELD, MT 59436 TETON

Contact: Pat Trainor, (406) 467-2516

Sys Fac ID: 50-03596
Last Inspected On: 7/14/2016
Operating Permit Renewal Date: 9/27/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
14	18	8/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1239			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000					
15	18	8/1/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1240			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000					

Facility Summary in TETON County in the City of FAIRFIELD

Location: GREENFIELDS IRRIGATION DISTRICT UST
105 CENTRAL AVE W
FAIRFIELD, MT 59436 TETON

Contact: Ed Everaert, (406) 467-2533

Sys Fac ID: 50-07428
Last Inspected On: 2/13/2014
Operating Permit Renewal Date: 8/5/2017

Owners/Operators: Greenfields Irrigation District, Owner (406)-467-2533 PO BOX 157
FAIRFIELD MT 59436-0157

Russel Barrett, UST Class A Operator
Russel Barrett, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	10/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1242			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Not Listed	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	24	10/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1241			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Not Listed	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in TETON County in the City of FAIRFIELD

Location: MALMSTROM AFB F 4
ROAD 408
FAIRFIELD, MT 59436 TETON

Contact: Jim Hodges,

Sys Fac ID: 50-09033
Last Inspected On: 9/18/2015
Operating Permit Renewal Date: 9/22/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	7/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
306		6/11/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in TETON County in the City of FAIRFIELD

Location: MALMSTROM AFB H 1
US HIGHWAY 89
FAIRFIELD, MT 59436 TETON

Sys Fac ID: 50-09052
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Ricardo Andrillon, UST Class B Operator
Glen Beck, UST Class B Operator
Allen Brooks, UST Class B Operator
Jonathan Buesch, UST Class B Operator
John Corbett, UST Class B Operator
David Cosner, UST Class B Operator
Ryan Cox, UST Class B Operator
Brian Day, UST Class B Operator
David Degolier, UST Class B Operator
Patrick Ellis, UST Class B Operator
Hudson English, UST Class B Operator
Paul Floyd, UST Class B Operator
Dustin Hemingway, UST Class B Operator
Aaron Hill, UST Class B Operator
William Hoffmeister, UST Class B Operator
Shane Hofstad, UST Class B Operator
Bethany Kent, UST Class B Operator
James Knudsen, UST Class B Operator
Ryan Kofoed, UST Class B Operator
Jeff Laird, UST Class B Operator
Damon McCarty, UST Class B Operator
Kieth McIlwain, UST Class B Operator
Brian McVay, UST Class B Operator
Ronald Miller, UST Class B Operator
Michael Murieen, UST Class B Operator
Jeff Nelson, UST Class B Operator
Patrick Noppenberg, UST Class B Operator
Shawn O'Grady, UST Class B Operator
Chris Ploof, UST Class B Operator
Issac Price, UST Class B Operator

Facility Summary in TETON County in the City of FAIRFIELD

Location: MALMSTROM AFB H 1
US HIGHWAY 89
FAIRFIELD, MT 59436 TETON

Sys Fac ID: 50-09052
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Brian Rayner, UST Class B Operator
Cameron Smith, UST Class B Operator
Jimmy Sonefelt, UST Class B Operator
Michael Stokes, UST Class B Operator
Kyle Topp, UST Class B Operator
Jason Vike, UST Class B Operator
James Wooderchak, UST Class B Operator
Paul Ziemba, UST Class B Operator
Paul Floyd, UST Class B Global Operator
Lana Hedlund, UST Class B Global Operator
James Hodges, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	10	9/28/2006	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
5086		9/14/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel		7/31/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in TETON County in the City of FAIRFIELD

Location: MALMSTROM AFB H 9
ROAD 408
FAIRFIELD, MT 59436 TETON

Contact: Jim Hodges,

Sys Fac ID: 50-09060
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/30/2018

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	9/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
314		6/9/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in TETON County in the City of FAIRFIELD

Location: MOUNTAIN VIEW COOP THE STORE
305 CENTRAL AVE
FAIRFIELD, MT 59436 TETON

Contact: Gwen Fassett, (406) 467-3232

Sys Fac ID: 50-11700
Last Inspected On: 12/26/2014
Operating Permit Renewal Date: 3/13/2018

Owners/Operators: Mountain View Coop, Owner (406)-453-2435 ATTN DAVE DOUGLAS
2200 OLD HAVRE HWY
BLACK EAGLE MT 59414-1043

David Douglas, UST Class A Operator
Denna Lekan, UST Class A Operator
Charla Merja, UST Class A Operator
Denna Lekan, UST Class B Operator
Charla Merja, UST Class B Operator
David Douglas, UST Class B Global Operator
Nathan Pitcher, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	7/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2354			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	26	7/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2355			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in TETON County in the City of FAIRFIELD

Location: MOUNTAIN VIEW COOP THE STORE
305 CENTRAL AVE
FAIRFIELD, MT 59436 TETON

Contact: Gwen Fassett, (406) 467-3232

Sys Fac ID: 50-11700
Last Inspected On: 12/26/2014
Operating Permit Renewal Date: 3/13/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	26	7/1/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2356			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in TETON County in the City of RURAL LOCATION

Location: MALMSTROM AFB F 8
US HIGHWAY 287
RURAL LOCATION, MT TETON

Sys Fac ID: 50-09037
Last Inspected On: 9/17/2015
Operating Permit Renewal Date: 9/22/2018

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	24	6/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
307		6/12/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			Soil Sentry Liquid 330 , Arizona Instrument		

Facility Summary in TOOLE County in the City of GALATA

Location: FRASER OIL INC GALATA
US HIGHWAY 2 N
GALATA, MT 59444 TOOLE

Contact: James Fraser, (406) 432-2321

Sys Fac ID: 51-02311
Last Inspected On: 12/11/2014
Operating Permit Renewal Date: 3/17/2018

Owners/Operators: Fraser Oil Inc, Owner (406)-292-3833 PO BOX 770
INVERNESS MT 59530-0770

Cory Fraser, UST Class A Operator
Cory Fraser, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	24	10/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1126			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/11/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
1,000		12/11/2008	TLS-350/Gilbarco EMC , Veeder Root		
4	24	10/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1127			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		12/11/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
1,000		12/11/2008	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in TOOLE County in the City of SHELBY

Location: NOON'S 573
602 W ROOSEVELT HWY
SHELBY, MT 59474 TOOLE

Contact: Frank Kruse, (406) 452-1041

Sys Fac ID: 51-00104
Last Inspected On: 5/4/2016
Operating Permit Renewal Date: 9/29/2019

Owners/Operators:

Singh Inc, Owner	(406)-868-2062	ATTN HARINDER SINGH PO BOX 7208 GREAT FALLS MT 59406-7208
S K Gasmart, Operator	(406)-434-5882	602 ROOSEVELT W. HWY SHELBY MT 59474

Harinder Singh, UST Class A Operator
Rajinder Singh, UST Class A Operator
Joe Ackerman, UST Class B Operator
Frank Kruse, UST Class B Operator
Frank Kruse, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	44	2/18/1972	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4382			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/9/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		7/30/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	44	2/18/1972	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3557			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/9/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		7/30/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	44	2/18/1972	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4383			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/9/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		7/30/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in TOOLE County in the City of SHELBY

Location: MAIN STREET EXXON
101 E MAIN ST
SHELBY, MT 59474 TOOLE

Contact: Karen Robertson, (406) 434-5076

Sys Fac ID: 51-06113
Last Inspected On: 8/20/2014
Operating Permit Renewal Date: 1/8/2018

Owners/Operators: Ben Taylor Inc, Owner (800)-824-8366 PO BOX 810
SHELBY MT 59474-0810

Gregory Taylor, UST Class A Operator
Thomas Loch, UST Class B Operator
Gail Mullennax, UST Class B Operator
Gregory Taylor, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	27	8/16/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
426			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/10/2015	Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
8,000			Other , Other		
7	27	8/16/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
427			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/10/2015	Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
4,000			Other , Other		
8	27	8/16/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
428			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/10/2015	Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
4,000			Other , Other		
9	27	8/16/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
429			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/10/2015	Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
4,000			Other , Other		

Facility Summary in TOOLE County in the City of SHELBY

Location: SIMONS PETROLEUM INC 5108629
530 W ROOSEVELT HWY
SHELBY, MT 59474 TOOLE
Contact: (406) 434-2461

Sys Fac ID: 51-08629
Last Inspected On: 9/29/2014
Operating Permit Renewal Date: 11/27/2017

Owners/Operators: Simons Petroleum Inc, Owner (406)-434-2431 PO BOX 644
SHELBY MT 59474-0644

Pat Simons, UST Class A Operator
Joseph Pehan, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	11	5/27/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5014			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	11	5/27/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5013			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	11	5/27/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5012			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
10	11	5/27/2005	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5015			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in TOOLE County in the City of SHELBY

Location: TOWN PUMP INC SHELBY
1350 W ROOSEVELT HWY
SHELBY, MT 59474 TOOLE

Contact: Trent Biggers, (460) 497-6700

Sys Fac ID: 51-09749
Last Inspected On: 12/15/2015
Operating Permit Renewal Date: 4/1/2019

Owners/Operators: Travel Plazas of Montana Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	28	9/7/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
2657			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		5/6/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	28	9/7/1988	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2658			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/6/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	28	9/7/1988	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
2659			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		5/6/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in TOOLE County in the City of SHELBY

Location: TOWN PUMP INC SHELBY
1350 W ROOSEVELT HWY
SHELBY, MT 59474 TOOLE

Contact: Trent Biggers, (460) 497-6700

Sys Fac ID: 51-09749
Last Inspected On: 12/15/2015
Operating Permit Renewal Date: 4/1/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	28	9/7/1988	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4291			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Safe Suction	Not Applicable
Diesel		5/6/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	28	9/7/1988	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
4292			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		11/27/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	24	8/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4293			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Safe Suction	Not Applicable
Diesel		11/27/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	24	8/1/1992	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2663			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		11/27/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	17	7/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4248			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		11/27/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in TOOLE County in the City of SHELBY

Location: TOWN PUMP INC SHELBY
1350 W ROOSEVELT HWY
SHELBY, MT 59474 TOOLE
Contact: Trent Biggers, (460) 497-6700

Sys Fac ID: 51-09749
Last Inspected On: 12/15/2015
Operating Permit Renewal Date: 4/1/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	15	10/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4413			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Not Listed	Not Applicable
Diesel		11/27/2012	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in TOOLE County in the City of SUNBURST

Location: TAYLORS BULK PLANT
55 RAILROAD AVE
SUNBURST, MT 59482 TOOLE

Contact: Greg Taylor, (406) 937-2161

Sys Fac ID: 51-02025
Last Inspected On: 4/25/2016
Operating Permit Renewal Date: 6/22/2019

Owners/Operators: Ben Taylor Inc, Owner (800)-824-8366 PO BOX 810
SHELBY MT 59474-0810

DaRae Fauque, UST Class A Operator
DaRae Fauque, UST Class B Operator
Gregory Taylor, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	17	8/31/1999	Unknown	Flexible Plastic	
4137	Yes	4/20/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		
7	17	8/31/1999	Unknown	Flexible Plastic	
4138	Yes	4/20/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
20,000			Gilbarco EMC Basic , Gilbarco		
8	17	8/31/1999	Unknown	Flexible Plastic	
4139	Yes	4/20/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
20,000			Gilbarco EMC Basic , Gilbarco		
9	17	8/31/1999	Unknown	Flexible Plastic	
4140	Yes	4/20/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
20,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in TOOLE County in the City of SUNBURST

Location: TAYLORS BULK PLANT
55 RAILROAD AVE
SUNBURST, MT 59482 TOOLE

Contact: Greg Taylor, (406) 937-2161

Sys Fac ID: 51-02025
Last Inspected On: 4/25/2016
Operating Permit Renewal Date: 6/22/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	17	8/31/1999	Unknown	Flexible Plastic	
4161	Yes	4/20/2016	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
1,500			Gilbarco EMC Basic , Gilbarco		

Facility Summary in TOOLE County in the City of SWEET GRASS

Location: Duty Free America's
60 3RD AVE
SWEET GRASS, MT 59484 TOOLE

Contact: Lori Schoendaller, (406) 335-2800

Sys Fac ID: 51-01377
Last Inspected On: 2/5/2015
Operating Permit Renewal Date: 3/28/2018

Owners/Operators:

Duty Free America's, Owner	(406)-335-2800	PO BOX 249 SWEET GRASS MT 59484
Duty Free America's, Owner	(954)-986-7700	TAX DEPT 6100 HOLLYWOOD BLVD FL 7 HOLLYWOOD FL 33024-7983
Lori Schoendaller, Operator		PO BOX 249 SWEET GRASS MT 59484

Lori Schoendaller, UST Class A Operator
Jeff Nanini, UST Class B Operator
Peggy Rossmiller, UST Class B Operator
Lori Schoendaller, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	1/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
871			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/20/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root		
3	26	1/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
872			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/20/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in TOOLE County in the City of SWEET GRASS

Location: MARS GAS & GROCERY
510 2ND ST
SWEET GRASS, MT 59484 TOOLE
Contact: William Cooper, (406) 424-8006

Sys Fac ID: 51-12405
Last Inspected On: 2/5/2015
Operating Permit Renewal Date: 3/27/2018

Owners/Operators: Paper Dollar Bar Inc, Owner (406)-335-2905 PO BOX 110
SWEET GRASS MT 59484-0110
Cody Young, UST Class A Operator
Cody Young, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	6/25/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2718			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		2/5/2015	TLS-350/Gilbarco EMC , Veeder Root		
2	25	6/25/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2719			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		2/5/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in TREASURE County in the City of HYSHAM

Location: FARMERS UNION OIL CO HYSHAM
121 ELLIOT AVE
HYSHAM, MT 59038 TREASURE
Contact: Bill Haggerty, (406) 342-5221

Sys Fac ID: 52-01905
Last Inspected On: 12/2/2014
Operating Permit Renewal Date: 2/27/2018

Owners/Operators: Farmers Union Oil Co, Owner (406)-967-3100 PO BOX 309
WORDEN MT 59088-0309

Scott Black, UST Class A Operator
Shawn Hedges, UST Class B Operator
Sheryl Warren, UST Class B Operator
Scott Black, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	26	7/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3144			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/2/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000					
4	26	7/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3145			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		12/2/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000					

Facility Summary in TREASURE County in the City of HYSHAM

Location: FRIENDLY CORNER
718 ELLIOT AVE
HYSHAM, MT 59038 TREASURE

Contact: Shelly Thorwer, (406) 342-5888

Sys Fac ID: 52-06316
Last Inspected On: 6/25/2015
Operating Permit Renewal Date: 9/29/2018

Owners/Operators: Cross Petroleum Services Billings, Owner (406)-252-5519 PO BOX 1078 BILLINGS MT 59103-1078

Gregory Cross, UST Class A Operator
Timothy Fife, UST Class A Operator
RJ Serpe, UST Class A Operator
RJ Serpe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	37	8/1/1979	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1405			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		3/24/2012	TLS-350/Gilbarco EMC , Veeder Root		
2	37	8/1/1979	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1406			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		4/1/2012	TLS-350/Gilbarco EMC , Veeder Root		
3	37	8/1/1979	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1407			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
3,000		4/5/2012	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in VALLEY County in the City of FORT PECK

Location: US ARMY CORPS OF ENGINEERS FORT PECK
JUDITH RD
FORT PECK, MT 59223 VALLEY

Contact: Tom Hansen, (406) 526-3431

Sys Fac ID: 53-04612
Last Inspected On: 6/23/2015
Operating Permit Renewal Date: 8/28/2018

Owners/Operators: US Army Corps of Engineers Fort Peck, Owner (406)-526-3411 PO BOX 208
FORT PECK MT 59223-0208

Tom Hansen, UST Class A Operator
Seth A Reedy, UST Class A Operator
Tom Hansen, UST Class B Operator
Seth A Reedy, UST Class B Operator
Seth A Reedy, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	6/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2156			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		6/23/2015	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
2,500		6/23/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	26	6/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2154			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		6/23/2015	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
9,000		6/23/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	26	6/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2155			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		6/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
2,500		6/23/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in VALLEY County in the City of FRAZER

Location: NAKODA TRAILSTOP
MAIN ST & 2ND ST
FRAZER, MT 59225 VALLEY

Sys Fac ID: 56-13890
Last Inspected On: 6/17/1999
Operating Permit Renewal Date:

Contact: Anthony Runsthrough, (406) 768-3480

Owners/Operators: Fort Peck Assiniboine & Sioux Tribes, Owner (406)-768-5155 501 MEDICINE BEAR ROAD POPLAR MT 59255-1027

Julie Flynn, Operator PO BOX 342 FRAZER MT 59225-0342

Anita Trice, UST Class A Operator

Anita Trice, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	18	12/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Tank Tightness Testing, Automatic Tank Gauging 0.1, Manual Interstitial Monitor	Continuous Interstitial Monitor	
1,000					
2	18	12/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Tank Tightness Testing, Automatic Tank Gauging 0.1, Manual Interstitial Monitor	Continuous Interstitial Monitor	
2,000					

Facility Summary in VALLEY County in the City of GLASGOW

Location: FARMERS UNION OIL DBA AGLAND COOP
430 1ST AVE N
GLASGOW, MT 59230 VALLEY
Contact: Brent Bacon, (406) 785-7272

Sys Fac ID: 53-03160
Last Inspected On: 11/23/2015
Operating Permit Renewal Date: 1/30/2019

Owners/Operators:

Farmers Union Oil DBA Agland Coop, Owner	(406)-228-4641	430 1ST AVE NORTH GLASGOW MT 59230
Brent Bacon, Operator	(406)-785-7272	810 FRONT STREET NASHUA MT 59248

Brent Bacon, UST Class A Operator
Kory Hentges, UST Class A Operator
Tanner Trower, UST Class A Operator
Monica Turnburke, UST Class A Operator
Antonio Alvernaz, UST Class B Operator
Kent Cromwell, UST Class B Operator
Kory Hentges, UST Class B Operator
Steven Long, UST Class B Operator
Keith Meche, UST Class B Operator
Michael Pallvoda, UST Class B Operator
Allen Richard, UST Class B Operator
Tanner Trower, UST Class B Operator
Bruce Unger, UST Class B Operator
Allen Richard, UST Class B Global Operator
Weston Smith, UST Class B Global Operator
Tanner Trower, UST Class B Global Operator
Monica Turnburke, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	25	5/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
1574		10/26/2012	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in VALLEY County in the City of GLASGOW

Location: FARMERS UNION OIL DBA AGLAND COOP
430 1ST AVE N
GLASGOW, MT 59230 VALLEY
Contact: Brent Bacon, (406) 785-7272

Sys Fac ID: 53-03160
Last Inspected On: 11/23/2015
Operating Permit Renewal Date: 1/30/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
6	25	5/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
1575		10/26/2012	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	25	5/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
1577		10/26/2012	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	25	5/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
1578		10/26/2012	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Safe Suction	Galvanic
Diesel		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
2,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	25	5/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
1576		10/26/2012	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasohol/Ethanol		10/16/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in VALLEY County in the City of GLASGOW

Location: FARMERS UNION OIL DBA AGLAND COOP
430 1ST AVE N
GLASGOW, MT 59230 VALLEY

Contact: Brent Bacon, (406) 785-7272

Sys Fac ID: 53-03160
Last Inspected On: 11/23/2015
Operating Permit Renewal Date: 1/30/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	04	10/1/2012	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
5391		10/26/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		10/26/2012	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in VALLEY County in the City of GLASGOW

Location: 5083
100 AIRPORT RD
GLASGOW, MT 59230 VALLEY

Contact: Steve Stanley, (406) 228-4023

Sys Fac ID: 53-03271
Last Inspected On: 10/27/2015
Operating Permit Renewal Date:

Owners/Operators: Valley County Airport Commission, Owner (406)-228-8221 501 COURT SQ STE 14 GLASGOW MT 59230-2415

Manfreda Donovan, UST Class A Operator
Anthony Hebert, UST Class A Operator
Robert Lipscomb, UST Class A Operator
Lucas Locke, UST Class A Operator
Christopher Mortensen, UST Class A Operator
Steve Stanley, UST Class A Operator
Manfreda Donovan, UST Class B Operator
Robert Lipscomb, UST Class B Operator
Lucas Locke, UST Class B Operator
Steve Stanley, UST Class B Operator
Anthony Hebert, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	36	1/1/1980	Cathodically Protected Steel	Steel	High Level Alarm
2726			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/22/2013	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
12,000		8/9/2006			
2	36	1/1/1980	Cathodically Protected Steel	Steel	High Level Alarm
2726			Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		5/22/2013	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
12,000		8/9/2006			
3	35	4/7/1981	Cathodically Protected Steel	No Piping	High Level Alarm
2727			Lined Interior/Impressed Current	None	Yes
Currently in Use		7/1/2008	Not Required	U.S. Suction	Impressed Current
Jet Fuel		5/22/2013	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
12,000		8/9/2006			

Facility Summary in VALLEY County in the City of GLASGOW

Location: 5083
100 AIRPORT RD
GLASGOW, MT 59230 VALLEY

Contact: Steve Stanley, (406) 228-4023

Sys Fac ID: 53-03271
Last Inspected On: 10/27/2015
Operating Permit Renewal Date:

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	35	4/7/1981	Cathodically Protected Steel	No Piping	High Level Alarm
2727			Lined Interior/Impressed Current	None	Yes
Currently in Use		7/1/2008	Not Required	U.S. Suction	Impressed Current
Jet Fuel		5/22/2013	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
12,000		8/9/2006			

Facility Summary in VALLEY County in the City of GLASGOW

Location: FRANCES MAHON DEACONESS HOSPITAL
621 3RD ST S
GLASGOW, MT 59230 VALLEY

Contact: John Fontaine, (406) 228-4351

Sys Fac ID: 53-05192
Last Inspected On: 6/23/2014
Operating Permit Renewal Date: 11/6/2017

Owners/Operators: Frances Mahon Deaconess Hospital, Owner (406)-228-4351 621 3RD ST S GLASGOW MT 59230-2604

Trinity Cook, UST Class A Operator
Tim Harper, UST Class A Operator
Patrick Menge, UST Class A Operator
David Nixdorf, UST Class A Operator
Walter L Adams, UST Class B Operator
Daivd Bradley, UST Class B Operator
Jeff Damboise, UST Class B Operator
Gregory Eldridge, UST Class B Operator
Eric Gullickson, UST Class B Operator
Richard Trathen, UST Class B Operator
Patrick Menge, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	21	10/1/1995	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1118			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Diesel		5/22/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Deferred	
4,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	
3	21	10/1/1995	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
1119			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Diesel		5/22/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Deferred	
2,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in VALLEY County in the City of GLASGOW

Location: EZZIE'S MIDTOWN
204 1ST AVE N
GLASGOW, MT 59230 VALLEY

Contact: David Skiff, (406) 654-2331

Sys Fac ID: 53-05709
Last Inspected On: 1/1/2014
Operating Permit Renewal Date: 4/4/2017

Owners/Operators:

EZZIES WHOLESALE INC, Owner	(406)-654-2331	PO BOX 1770 MALTA MT 59538-9640
David Skiff, Operator	(406)-654-2331	PO BOX 467 MALTA MT 59538-0467
Jody Faul, UST Class A Operator		
Jody Faul, UST Class B Operator		
Jennifer Fischer, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	16	6/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4201			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/9/2010	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		6/14/2013			
6	16	6/1/2000	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4202			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/9/2010	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		6/14/2013			

Facility Summary in VALLEY County in the City of GLASGOW

Location: TRAILSIDE GENERAL STORE GLASGOW
54271 HWY 2 E
GLASGOW, MT 59230 VALLEY

Contact: Wayne Waarvik JR, (406) 263-1477

Sys Fac ID: 53-07787
Last Inspected On: 3/23/2015
Operating Permit Renewal Date:

Owners/Operators:

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	25	9/9/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
3873			None	None	Yes
Temporarily Out of Use		9/9/2001	Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		3/23/2015	Tank Tightness Testing, Inventory Reconciliation	MLLD Line Tightness Testing	
10,000					
4	25	9/9/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	
3874			None	None	Yes
Temporarily Out of Use		9/9/2001	Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		3/23/2015	Tank Tightness Testing, Inventory Reconciliation	MLLD Line Tightness Testing	
10,000					

Facility Summary in VALLEY County in the City of GLASGOW

Location: LAKERIDGE MOTEL & TACKLE INC
6004 MT HIGHWAY 24 S HC 71 BOX 1660
GLASGOW, MT 59230 VALLEY

Contact: Gene Moore, (406) 526-3597

Sys Fac ID: 53-08383
Last Inspected On: 2/3/2016
Operating Permit Renewal Date: 5/4/2019

Owners/Operators: Gene Moore, Owner (406)-526-3597 6004 MT HIGHWAY 24 S GLASGOW MT 59230-8822

Gene Moore, UST Class A Operator
Gene Moore, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	19	5/15/1997	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1509			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		1/21/2013	Manual Interstitial Monitor	Deferred	
4,000					
6	19	5/15/1997	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1510			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		1/21/2013	Manual Interstitial Monitor	Deferred	
2,000					

Facility Summary in VALLEY County in the City of GLASGOW

Location: HOLIDAY STATIONSTORE 281
108 1ST AVE N
GLASGOW, MT 59230 VALLEY

Contact: Bruce Anthony, (952) 830-8899

Sys Fac ID: 53-09712
Last Inspected On: 6/23/2014
Operating Permit Renewal Date: 10/1/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Stephen Reckinger, UST Class A Operator
Dean Townsend, UST Class A Operator
Ronald VanDenBroeke, UST Class A Operator
Craig Robbins, UST Class B Operator
Stephen Reckinger, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator
Dean Townsend, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	27	8/1/1989	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4431			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		4/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		4/25/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	30	3/1/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4432			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		4/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		4/27/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	28	4/15/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4433			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		4/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		4/21/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in VALLEY County in the City of GLASGOW

Location: EZZIES WHOLESALE GLASGOW
1330 US HIGHWAY 2 W
GLASGOW, MT 59230 VALLEY
Contact: Lary Poulton, (406) 228-2713

Sys Fac ID: 53-10475
Last Inspected On: 11/26/2014
Operating Permit Renewal Date: 3/24/2018

Owners/Operators: EZZIES WHOLESALE INC, Owner (406)-654-2331 PO BOX 1770 MALTA MT 59538-9640

David Skiff, UST Class A Operator
Brandon Hoerster, UST Class B Operator
Jarid Jensen, UST Class B Operator
David Skiff, UST Class B Operator
Brandon Hoerster, UST Class B Global Operator
David Skiff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	14	11/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4758			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					
8	14	11/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4759			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000					
9	14	11/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4760			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
6,000					

Facility Summary in VALLEY County in the City of GLASGOW

Location: EZZIES WHOLESALE GLASGOW
1330 US HIGHWAY 2 W
GLASGOW, MT 59230 VALLEY

Contact: Lary Poulton, (406) 228-2713

Sys Fac ID: 53-10475
Last Inspected On: 11/26/2014
Operating Permit Renewal Date: 3/24/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	14	11/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4761			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000					
11	14	11/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4762			None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Safe Suction	Not Applicable
Other			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000					
12	14	11/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4763			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000					
13	14	11/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4764			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
20,000					
14	14	11/21/2002	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4765			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
30,000					

Facility Summary in VALLEY County in the City of NASHUA

Location: FARMERS UNION OIL CO NASHUA
810 MAIN ST
NASHUA, MT 59248 VALLEY

Contact: Brent Bacon, (406) 746-3311

Sys Fac ID: 53-10461
Last Inspected On: 5/14/2015
Operating Permit Renewal Date: 8/7/2018

Owners/Operators: Farmers Union Oil Co Nashua, Owner (406)-746-3311 PO BOX 108
NASHUA MT 59248-0108

Brent Bacon, UST Class A Operator
James Merideth, UST Class A Operator
Monica Turnburke, UST Class A Operator
Steven Long, UST Class B Operator
Keith Meche, UST Class B Operator
James Merideth, UST Class B Operator
Michael Pallvoda, UST Class B Operator
Allen Richard, UST Class B Operator
Bruce Unger, UST Class B Operator
James Merideth, UST Class B Global Operator
Allen Richard, UST Class B Global Operator
Monica Turnburke, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	26	3/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
937			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		7/7/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
2,000			Gilbarco EMC Basic , Gilbarco		
6	26	3/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
938			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		7/7/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
4,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in VALLEY County in the City of NASHUA

Location: FARMERS UNION OIL CO NASHUA
810 MAIN ST
NASHUA, MT 59248 VALLEY
Contact: Brent Bacon, (406) 746-3311

Sys Fac ID: 53-10461
Last Inspected On: 5/14/2015
Operating Permit Renewal Date: 8/7/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	26	3/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
939			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		7/7/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
4,000			Gilbarco EMC Basic , Gilbarco		
8	26	3/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
940			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		7/7/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
4,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in VALLEY County in the City of OPHEIM

Location: PRO COOP OPHEIM
45 SOUTH MAIN
OPHEIM, MT 59250 VALLEY

Contact: Tim Stenglein, (406) 762-3231

Sys Fac ID: 53-07814
Last Inspected On: 11/5/2014
Operating Permit Renewal Date: 2/12/2018

Owners/Operators: Pro Coop Opheim, Owner (406)-762-3231 PO BOX 167
OPHEIM MT 59250-0167

Myron Redfield, UST Class A Operator
Timothy Stenglein, UST Class A Operator
Myron Redfield, UST Class B Operator
Timothy Stenglein, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	8/1/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1821			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasohol/Ethanol		11/5/2014	Manual Interstitial Monitor	Deferred	
3,700					
2	23	8/1/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1822			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		11/5/2014	Manual Interstitial Monitor	Deferred	
2,300					
3	23	8/1/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1820			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		11/5/2014	Manual Interstitial Monitor	Deferred	
2,300					

Facility Summary in VALLEY County in the City of OPHEIM

Location: PRO COOP OPHEIM
45 SOUTH MAIN
OPHEIM, MT 59250 VALLEY

Contact: Tim Stenglein, (406) 762-3231

Sys Fac ID: 53-07814
Last Inspected On: 11/5/2014
Operating Permit Renewal Date: 2/12/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	23	8/1/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1823			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		11/5/2014	Manual Interstitial Monitor	Deferred	
3,700					

Facility Summary in VALLEY County in the City of SAINT MARIE

Location: MT AVIATION RESEARCH BLDG CO BLDG 649A
BLDG 649A
SAINT MARIE, MT 59231 VALLEY

Contact: Darcel Wesen, (406) 524-3777

Sys Fac ID: 53-12774
Last Inspected On: 2/4/2016
Operating Permit Renewal Date: 6/8/2019

Owners/Operators: Montana Aviation Research Co, Owner (406)-524-3777 PO BOX 831
GLASGOW MT 59230-0831

Lynn Blatter, UST Class A Operator
Brian Mix, UST Class A Operator
Preston Murch, UST Class A Operator
Michael Myrick, UST Class A Operator
Michael Nieskens, UST Class A Operator
Kevin Wersal, UST Class A Operator
Darcel Wesen, UST Class A Operator
Brian Mix, UST Class B Operator
Preston Murch, UST Class B Operator
Michael Myrick, UST Class B Operator
Michael Nieskens, UST Class B Operator
Kevin Wersal, UST Class B Operator
Darcel Wesen, UST Class B Operator
Lynn Blatter, UST Class B Global Operator
Michael Nieskens, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	22	1/1/1994	Bare Steel	Fiberglass Reinforced Plastic	
2975	Yes		None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Jet Fuel			Automatic Tank Gauging 0.2, Deferred	Continuous Interstitial Monitor	
50,000			TLS-350/Gilbarco EMC , Veeder Root		
5	22	1/1/1994	Bare Steel	Fiberglass Reinforced Plastic	
2976	Yes		None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Jet Fuel			Automatic Tank Gauging 0.2, Deferred	Continuous Interstitial Monitor	
50,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of HARLOWTON

Location: ENGINEERS DEPOT
102 2ND STREET NE
HARLOWTON, MT 59036 WHEATLAND

Contact: Teresa Baumgardner, (406) 632-4630

Sys Fac ID: 54-04934
Last Inspected On: 9/8/2015
Operating Permit Renewal Date: 10/31/2018

Owners/Operators: Set Five LLC, Owner/Operator (719)-510-8778 PO BOX 827 HARLOWTON MT 59036

LeAnne Baumbach, UST Class A Operator
Teresa Baumgardner, UST Class A Operator
LeAnne Baumbach, UST Class B Global Operator
Teresa Baumgardner, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	28	11/17/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1045			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		9/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
4,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
6	28	11/17/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1046			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
7	28	11/17/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4342			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in WHEATLAND County in the City of HARLOWTON

Location: ENGINEERS DEPOT
102 2ND STREET NE
HARLOWTON, MT 59036 WHEATLAND

Contact: Teresa Baumgardner, (406) 632-4630

Sys Fac ID: 54-04934
Last Inspected On: 9/8/2015
Operating Permit Renewal Date: 10/31/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	13	7/17/2003	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4850			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in WHEATLAND County in the City of HARLOWTON

Location: MALMSTROM AFB K 1
US HIGHWAY 191
HARLOWTON, MT 59036 WHEATLAND

Sys Fac ID: 54-09085
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 8/21/2019

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Ricardo Andrillon, UST Class B Operator
Glen Beck, UST Class B Operator
Allen Brooks, UST Class B Operator
Jonathan Buesch, UST Class B Operator
John Corbett, UST Class B Operator
David Cosner, UST Class B Operator
Ryan Cox, UST Class B Operator
Brian Day, UST Class B Operator
David Degolier, UST Class B Operator
Hudson English, UST Class B Operator
Eric Haumschild, UST Class B Operator
Dustin Hemingway, UST Class B Operator
Aaron Hill, UST Class B Operator
William Hoffmeister, UST Class B Operator
Shane Hofstad, UST Class B Operator
Bethany Kent, UST Class B Operator
James Knudsen, UST Class B Operator
Ryan Kofoed, UST Class B Operator
Jeff Laird, UST Class B Operator
Damon McCarty, UST Class B Operator
Kieth McIlwain, UST Class B Operator
Brian McVay, UST Class B Operator
Ronald Miller, UST Class B Operator
Michael Murieen, UST Class B Operator
Jeff Nelson, UST Class B Operator
Shawn O'Grady, UST Class B Operator
Chris Ploof, UST Class B Operator
Issac Price, UST Class B Operator
Brian Rayner, UST Class B Operator
Cameron Smith, UST Class B Operator

Facility Summary in WHEATLAND County in the City of HARLOWTON

Location: MALMSTROM AFB K 1
US HIGHWAY 191
HARLOWTON, MT 59036 WHEATLAND

Sys Fac ID: 54-09085
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 8/21/2019

Contact: Jim Hodges,
Jimmy Sonefelt, UST Class B Operator
Michael Stokes, UST Class B Operator
Kyle Topp, UST Class B Operator
Jason Vike, UST Class B Operator
Mark Wight, UST Class B Operator
James Wooderchak, UST Class B Operator
Paul Ziemba, UST Class B Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	54	5/2/1962	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
341		4/12/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Impressed Current
Diesel		3/31/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Vapor Monitoring	

Facility Summary in WHEATLAND County in the City of HARLOWTON

Location: MALMSTROM AFB K 2
US HIGHWAY 191
HARLOWTON, MT 59036 WHEATLAND

Contact: Jim Hodges,

Sys Fac ID: 54-09086
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 8/21/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
342		4/13/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of HARLOWTON

Location: MALMSTROM AFB K 3
US HIGHWAY 191
HARLOWTON, MT 59036 WHEATLAND

Contact: Jim Hodges,

Sys Fac ID: 54-09087
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
343		4/14/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of HARLOWTON

Location: MALMSTROM AFB K 4
US HIGHWAY 12
HARLOWTON, MT 59036 WHEATLAND

Contact: Jim Hodges,

Sys Fac ID: 54-09088
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
344		4/13/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of HARLOWTON

Location: MALMSTROM AFB K 6
US HIGHWAY 12
HARLOWTON, MT 59036 WHEATLAND

Contact: Jim Hodges,

Sys Fac ID: 54-09090
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
346		4/12/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of HARLOWTON

Location: MALMSTROM AFB K 8
US HIGHWAY 191
HARLOWTON, MT 59036 WHEATLAND

Contact: Jim Hodges,

Sys Fac ID: 54-09092
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
348		4/12/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of HARLOWTON

Location: MALMSTROM AFB K 9
US HIGHWAY 12
HARLOWTON, MT 59036 WHEATLAND

Sys Fac ID: 54-09093
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/31/2019

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
349		4/11/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of HARLOWTON

Location: MALMSTROM AFB K 10
US HIGHWAY 12
HARLOWTON, MT 59036 WHEATLAND

Contact: Jim Hodges,

Sys Fac ID: 54-09094
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
350		4/11/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of HARLOWTON

Location: MALMSTROM AFB K 11
US HIGHWAY 12
HARLOWTON, MT 59036 WHEATLAND

Sys Fac ID: 54-09095
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/31/2019

Contact: Jim Hodges,

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	6/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
351		4/11/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of HARLOWTON

Location: RAYS SPORT & WESTERN WEAR
US HIGHWAY 12 E
HARLOWTON, MT 59036 WHEATLAND
Contact: Rick Hinand, (406) 632-4329

Sys Fac ID: 54-11975
Last Inspected On: 11/21/2014
Operating Permit Renewal Date: 2/24/2018

Owners/Operators: Ray & Alma Hinand Trust Rays Sports & Western, Owner (406)-632-4329 PO BOX 306
HARLOWTON MT 59036-0306

Anita Leach, UST Class A Operator
Anita Leach, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	5/1/1984	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
2362			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		8/9/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		11/20/2015	TLS-350/Gilbarco EMC , Veeder Root		
2	32	5/1/1984	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
2363			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/9/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		11/20/2015	TLS-350/Gilbarco EMC , Veeder Root		
3	32	1/1/1984	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
2364			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/9/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		11/20/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of JUDITH GAP

Location: MALMSTROM AFB L 1
US HIGHWAY 191
JUDITH GAP, MT 59453 WHEATLAND

Contact: Jim Hodges,

Sys Fac ID: 14-09096
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Ricardo Andrillon, UST Class B Operator
Glen Beck, UST Class B Operator
Allen Brooks, UST Class B Operator
Jonathan Buesch, UST Class B Operator
John Corbett, UST Class B Operator
David Cosner, UST Class B Operator
Ryan Cox, UST Class B Operator
Brian Day, UST Class B Operator
David Degolier, UST Class B Operator
Hudson English, UST Class B Operator
Eric Haumschild, UST Class B Operator
Dustin Hemingway, UST Class B Operator
Aaron Hill, UST Class B Operator
William Hoffmeister, UST Class B Operator
Shane Hofstad, UST Class B Operator
Bethany Kent, UST Class B Operator
James Knudsen, UST Class B Operator
Ryan Kofoed, UST Class B Operator
Jeff Laird, UST Class B Operator
Damon McCarty, UST Class B Operator
Kieth McIlwain, UST Class B Operator
Brian McVay, UST Class B Operator
Ronald Miller, UST Class B Operator
Michael Murieen, UST Class B Operator
Shawn O'Grady, UST Class B Operator
Chris Ploof, UST Class B Operator
Issac Price, UST Class B Operator
Brian Rayner, UST Class B Operator
Cameron Smith, UST Class B Operator
Jimmy Sonefelt, UST Class B Operator

Facility Summary in WHEATLAND County in the City of JUDITH GAP

Location: MALMSTROM AFB L 1
US HIGHWAY 191
JUDITH GAP, MT 59453 WHEATLAND

Sys Fac ID: 14-09096
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 7/31/2019

Contact: Jim Hodges,

Michael Stokes, UST Class B Operator
Kyle Topp, UST Class B Operator
Jason Vike, UST Class B Operator
Mark Wight, UST Class B Operator
James Wooderchak, UST Class B Operator
Paul Ziemba, UST Class B Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	54	5/2/1962	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
186		4/29/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Impressed Current
Diesel		4/30/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of JUDITH GAP

Location: JUDITH GAP OIL
302 HIGH ST
JUDITH GAP, MT 59453 WHEATLAND
Contact: Jeff Miller, (406) 473-2321

Sys Fac ID: 54-07616
Last Inspected On: 2/5/2016
Operating Permit Renewal Date: 5/8/2019

Owners/Operators: David Miller, Owner (406)-632-4891 PO BOX 228
JUDITH GAP MT 59453-0228

Jeffery Miller, UST Class A Operator
David Miller, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	10	10/2/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5089			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		2/15/2013	TLS-350/Gilbarco EMC , Veeder Root		
8	10	10/2/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5090			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000		2/15/2013	TLS-350/Gilbarco EMC , Veeder Root		
9	10	10/2/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5091			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		2/15/2013	TLS-350/Gilbarco EMC , Veeder Root		
10	10	10/2/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5092			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000		2/15/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of JUDITH GAP

Location: JUDITH GAP OIL
302 HIGH ST
JUDITH GAP, MT 59453 WHEATLAND
Contact: Jeff Miller, (406) 473-2321

Sys Fac ID: 54-07616
Last Inspected On: 2/5/2016
Operating Permit Renewal Date: 5/8/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	10	10/2/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5093			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		2/15/2013	TLS-350/Gilbarco EMC , Veeder Root		
12	10	10/2/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5094			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000		2/15/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of JUDITH GAP

Location: MALMSTROM AFB L 3
ROAD 297
JUDITH GAP, MT 59453 WHEATLAND
Contact: Jim Hodges,

Sys Fac ID: 54-09098
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/7/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	6/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
352		6/28/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of JUDITH GAP

Location: MALMSTROM AFB L 4
ROAD 297
JUDITH GAP, MT 59453 WHEATLAND
Contact: Jim Hodges,

Sys Fac ID: 54-09099
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/7/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	6/10/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
353		4/25/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of JUDITH GAP

Location: MALMSTROM AFB L 5
ROAD 297
JUDITH GAP, MT 59453 WHEATLAND
Contact: Jim Hodges,

Sys Fac ID: 54-09100
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/7/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
354		4/25/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of JUDITH GAP

Location: MALMSTROM AFB L 6
ROAD 297
JUDITH GAP, MT 59453 WHEATLAND
Contact: Jim Hodges,

Sys Fac ID: 54-09101
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/7/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	3/26/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
355		4/26/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of JUDITH GAP

Location: MALMSTROM AFB L 7
US HIGHWAY 191
JUDITH GAP, MT 59453 WHEATLAND
Contact: Jim Hodges,

Sys Fac ID: 54-09102
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/7/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	5/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
356		7/13/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of JUDITH GAP

Location: MALMSTROM AFB L 8
US HIGHWAY 191
JUDITH GAP, MT 59453 WHEATLAND

Contact: Jim Hodges,

Sys Fac ID: 54-09103
Last Inspected On: 5/9/2016
Operating Permit Renewal Date: 8/7/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	5/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
357		4/26/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of SHAWMUT

Location: MALMSTROM AFB K 5
US HIGHWAY 12
SHAWMUT, MT 59078 WHEATLAND

Contact: Jim Hodges,

Sys Fac ID: 54-09089
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	6/9/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
345		4/14/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WHEATLAND County in the City of SHAWMUT

Location: MALMSTROM AFB K 7
US HIGHWAY 12
SHAWMUT, MT 59078 WHEATLAND

Contact: Jim Hodges,

Sys Fac ID: 54-09091
Last Inspected On: 4/18/2016
Operating Permit Renewal Date: 7/31/2019

Owners/Operators: 341 CES CEANQ, Owner (406)-731-6188 39 78TH ST N
MALMSTROM AFB MT 59402-7536

Lana Hedlund, UST Class A Operator
James Hodges, UST Class A Operator
Lana Hedlund, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	6/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
347		4/13/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in WIBAUX County in the City of WIBAUX

Location: WIBAUX COUNTY UST
2ND AVE N PO BOX 86
WIBAUX, MT 59353 WIBAUX

Contact: Kim Bacon, (406) 796-2446

Sys Fac ID: 55-02446
Last Inspected On: 7/13/2016
Operating Permit Renewal Date: 10/15/2019

Owners/Operators: Wibaux County Shop, Owner (406)-796-2443 ATTN KIM BACON
225 2ND AVE NW
WIBAUX MT 59353-9219

Kim Bacon, UST Class A Operator
Kim Bacon, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	21	6/1/1995	Steel Clad	Steel	Flapper Valve (Auto Shutoff)
2272			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		7/13/2016	Manual Interstitial Monitor	Deferred	
4,000					
3	21	6/1/1995	Steel Clad	Steel	Flapper Valve (Auto Shutoff)
2273			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		7/13/2016	Manual Interstitial Monitor	Deferred	
4,000					
4	21	6/1/1995	Steel Clad	Steel	
2274			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Waste Oil		7/13/2016	Manual Interstitial Monitor	Deferred	
500					

Facility Summary in WIBAUX County in the City of WIBAUX

Location: WIBAUX COOP OIL CO
203 2ND AVE NW
WIBAUX, MT 59353 WIBAUX
Contact: Donald Lauf, (406) 795-2219

Sys Fac ID: 55-03348
Last Inspected On: 7/13/2016
Operating Permit Renewal Date: 10/23/2019

Owners/Operators: Wibaux Coop Oil Co, Owner (406)-795-2219 PO BOX 178
WIBAUX MT 59353-0178

Donald Lauf, UST Class A Operator
Donald Lauf, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	6/1/1995	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2270			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		6/11/2013	Manual Interstitial Monitor	Deferred	
4,000					
2	21	6/1/1995	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2271			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		6/11/2013	Manual Interstitial Monitor	Deferred	
4,000					
8	21	6/1/1995	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2267			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/11/2013	Manual Interstitial Monitor	Deferred	
5,000					
9	21	6/1/1995	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2268			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/11/2013	Manual Interstitial Monitor	Deferred	
4,000					

Facility Summary in WIBAUX County in the City of WIBAUX

Location: WIBAUX COOP OIL CO
203 2ND AVE NW
WIBAUX, MT 59353 WIBAUX
Contact: Donald Lauf, (406) 795-2219

Sys Fac ID: 55-03348
Last Inspected On: 7/13/2016
Operating Permit Renewal Date: 10/23/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
10	21	6/1/1995	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2269			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/11/2013	Manual Interstitial Monitor	Deferred	
4,000					

Facility Summary in WIBAUX County in the City of WIBAUX

Location: AMSLER C STORE
102 2ND AVE N
WIBAUX, MT 59353 WIBAUX
Contact: Ernst Amsler, (406) 796-2338

Sys Fac ID: 55-13559
Last Inspected On: 4/17/2014
Operating Permit Renewal Date: 8/22/2017

Owners/Operators: Amsler C Store, Owner (406)-796-2338 PO BOX 16
WIBAUX MT 59353-0016

Ernest Amsler, UST Class A Operator
Ernest Amsler, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	11/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3258			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/17/2014	Automatic Tank Gauging 0.2	Deferred	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
2	22	1/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3259			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		4/17/2014	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
3	22	1/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3260			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/17/2014	Automatic Tank Gauging 0.2	Deferred	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
4	22	1/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3261			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/17/2014	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BALLANTINE

Location: TIGER TOWN
2253 S 16TH RD
BALLANTINE, MT 59006 YELLOWSTONE

Contact: Carol & James Hayes, (406) 967-2895

Sys Fac ID: 56-06325
Last Inspected On: 4/4/2014
Operating Permit Renewal Date: 7/10/2017

Owners/Operators: Carol Hayes, Owner (406)-967-2753 DBA TIGER TOWN
PO BOX 26
BALLANTINE MT 59006-0026

Carol Hayes, UST Class A Operator
Patti Anderson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	24	11/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3310			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		4/1/2014	Automatic Tank Gauging 0.2	Deferred	
3,000			TS-1001 , Incon		
10	24	11/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3311			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/1/2014	Automatic Tank Gauging 0.2	Deferred	
4,000			TS-1001 , Incon		
11	24	11/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3312			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/1/2014	Automatic Tank Gauging 0.2	Deferred	
5,000			TS-1001 , Incon		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 51
1544 BROADWATER AVE
BILLINGS, MT 59102 YELLOWSTONE
Contact: (406) 651-0001

Sys Fac ID: 56-00050
Last Inspected On: 2/23/2015
Operating Permit Renewal Date: 7/14/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Ian Johnstone, UST Class A Operator
Nicholas Merritt, UST Class A Operator
Nicholas Merritt, UST Class B Operator
Darcy Ziegler, UST Class B Operator
Nicholas Merritt, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	19	10/30/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3074			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
5	19	10/30/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3075			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
6	19	10/30/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3076			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 5 CORNERS EXPRESS
5550 US HIGHWAY 312
BILLINGS, MT 59105 YELLOWSTONE

Contact: Mykel Stockton, (406) 245-6376

Sys Fac ID: 56-00062
Last Inspected On: 11/14/2016
Operating Permit Renewal Date: 11/28/2019

Owners/Operators: Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756
BILLINGS MT 59103-1756

Mykel Stockton, UST Class A Operator
Joey McConnell, UST Class B Global Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	00	6/30/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5653		6/30/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		6/29/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
5	00	6/30/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5654		6/30/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		6/29/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
6	00	6/30/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5655		6/30/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		6/29/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 5 CORNERS EXPRESS
5550 US HIGHWAY 312
BILLINGS, MT 59105 YELLOWSTONE
Contact: Mykel Stockton, (406) 245-6376

Sys Fac ID: 56-00062
Last Inspected On: 11/14/2016
Operating Permit Renewal Date: 11/28/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	00	6/30/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5656		6/30/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		6/29/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 3 GS CONVENIENCE CENTER 3
730 LAKE ELMO DR
BILLINGS, MT 59105 YELLOWSTONE
Contact: (406) 255-0688

Sys Fac ID: 56-00063
Last Inspected On: 10/3/2014
Operating Permit Renewal Date: 1/8/2018

Owners/Operators: SNG Inc 3, Owner (406)-245-0161 4410 STATE AVE
BILLINGS MT 59101-5060

KELLY GROSLACK, UST Class A Operator
Larry Groslack, UST Class A Operator
TAMI MAUCH, UST Class A Operator
KELLY GROSLACK, UST Class B Operator
Larry Groslack, UST Class B Operator
TAMI MAUCH, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	12/20/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1871			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		9/30/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
10,000		9/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	31	12/20/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1872			Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/30/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
10,000		9/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	31	12/20/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1873			Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/30/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
10,000		9/29/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: RIMROCK SUBARU INC
324 S 24TH ST W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Scott Hazlet, (406) 655-8572

Sys Fac ID: 56-00066
Last Inspected On: 4/29/2016
Operating Permit Renewal Date: 6/7/2019

Owners/Operators:

Rimrock Subaru Inc, Owner	(406)-651-5200	PO BOX 80208 BILLINGS MT 59108
Jack McCoy, Operator	(406)-651-5000	RIMROCK AUTO 324 S 24TH ST W BILLINGS MT 59102-5644
Scott Haslet, UST Class A Operator		
Scott Haslet, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	25	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1863			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		5/4/2016	Automatic Tank Gauging 0.2	Deferred	
1,000		4/7/2010	OPW 1500 , OPW		
5	25	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1864			None	None	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Waste Oil		5/4/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
1,000		5/4/2016	OPW 1500 , OPW		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ARCHIE COCHRANE MOTORS
2133 KING AVE W
BILLINGS, MT 59102 YELLOWSTONE
Contact: Garry Brayko, (406) 656-1100

Sys Fac ID: 56-00123
Last Inspected On: 10/24/2014
Operating Permit Renewal Date: 3/26/2018

Owners/Operators: Archie Cochrane Motors, Owner (406)-656-1100 PO BOX 80605
BILLINGS MT 59108-0605

LAUREN GOPP, UST Class A Operator
Don Hofer, UST Class A Operator
Don Hofer, UST Class B Operator
LAUREN GOPP, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	23	8/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
390			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/24/2014	Manual Interstitial Monitor	Deferred	
2,000					
5	23	8/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
391			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/3/2011	Manual Interstitial Monitor	Deferred	
1,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CONOMART SUPERSTORE 4
1240 S 27TH ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Dennis Whitmore, (406) 252-4661

Sys Fac ID: 56-00503
Last Inspected On: 6/14/2016
Operating Permit Renewal Date: 9/28/2019

Owners/Operators:

C Store Properties LLC, Owner	(406)-651-5101	PO BOX 80391 BILLINGS MT 59108
GM Cono Stores LLC, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107

Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Ken Jackson, UST Class A Operator
Charlie McHenry, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Laura Geffre, UST Class B Operator
Kim Hauck, UST Class B Operator
Roger Schmechel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1148			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/28/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		8/23/2010	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
5	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1149			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/28/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		8/22/2010	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CONOMART SUPERSTORE 4
1240 S 27TH ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Dennis Whitmore, (406) 252-4661

Sys Fac ID: 56-00503
Last Inspected On: 6/14/2016
Operating Permit Renewal Date: 9/28/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1150		4/1/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		5/28/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		5/3/2015	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN PUMP INC BILLINGS 1
1028 US HIGHWAY 87 E
BILLINGS, MT 59101 YELLOWSTONE

Sys Fac ID: 56-00767
Last Inspected On: 2/3/2015
Operating Permit Renewal Date: 2/6/2018

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Billings Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	20	10/2/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4583			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	20	10/2/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2665			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	20	10/2/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2666			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN PUMP INC BILLINGS 1
1028 US HIGHWAY 87 E
BILLINGS, MT 59101 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-00767
Last Inspected On: 2/3/2015
Operating Permit Renewal Date: 2/6/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	20	10/2/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2667			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
10	17	2/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3921			Double-Walled	Double-Walled	Yes
Currently in Use		1/1/2009	Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MSU FACILITY SERVICES BLDG
1500 UNIVERSITY DR
BILLINGS, MT 59101 YELLOWSTONE

Contact: Ken Billman, (406) 657-2309

Sys Fac ID: 56-00904
Last Inspected On: 4/27/2015
Operating Permit Renewal Date: 8/21/2018

Owners/Operators: Montana State University Billings, Owner (406)-657-2309 1500 UNIVERSITY DR BILLINGS MT 59101-0252

Brian Mackey, UST Class A Operator
Jason McGimpsey, UST Class A Operator
John Grimstad, UST Class B Operator
Brian Mackey, UST Class B Operator
Brian Mackey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
846			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Deferred	
1,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS LOGAN INTERNATIONAL AIRPORT UST
1901 TERMINAL CIR STE 216
BILLINGS, MT 59105 YELLOWSTONE

Contact: Donald (Kim) Annin, (406) 657-8482

Sys Fac ID: 56-00909
Last Inspected On: 6/9/2016
Operating Permit Renewal Date: 9/4/2019

Owners/Operators: Billings Logan International Airport, Owner (406)-657-8482 1901 TERMINAL CIR STE 216 BILLINGS MT 59105-1991

Donald Annin, UST Class A Operator
Shawn Gaalswyk, UST Class A Operator
Shawn Gaalswyk, UST Class B Operator
Colter Smith, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	29	1/1/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
623			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		6/6/2016	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
3	23	10/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
624			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/9/2016	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	23	10/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
625			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		6/9/2016	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS LOGAN INTERNATIONAL AIRPORT UST
1901 TERMINAL CIR STE 216
BILLINGS, MT 59105 YELLOWSTONE

Contact: Donald (Kim) Annin, (406) 657-8482

Sys Fac ID: 56-00909
Last Inspected On: 6/9/2016
Operating Permit Renewal Date: 9/4/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
17	23	10/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4826			Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Waste Oil		6/9/2016	Manual Interstitial Monitor	MLLD Line Tightness Testing	
500		6/9/2016			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: NORTHWESTERN ENERGY FACILITY
405 S 20TH ST W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Darren Brockel, (406) 655-2521

Sys Fac ID: 56-01188
Last Inspected On: 8/29/2014
Operating Permit Renewal Date: 12/9/2017

Owners/Operators: Northwestern Energy, Owner (406)-655-2521 405 S 20TH ST W BILLINGS MT 59102

John Habeger, UST Class A Operator
Darren Brockel, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	36	4/30/1980	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff), High Level Alarm
1683			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		4/4/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		11/1/2016	EECO 1500 , EMCO Electronics		
4	36	4/30/1980	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff), High Level Alarm
1684			None	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		4/4/2014	Automatic Tank Gauging 0.2	Deferred	
2,000			EECO 1500 , EMCO Electronics		
5	36	4/30/1980	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff), High Level Alarm
1685			None	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		4/4/2014	Automatic Tank Gauging 0.2	Deferred	
4,000			EECO 1500 , EMCO Electronics		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CARDLOCK #3
1004 4TH AVE N
BILLINGS, MT 59101 YELLOWSTONE

Sys Fac ID: 56-01290
Last Inspected On: 6/23/2016
Operating Permit Renewal Date: 8/16/2019

Contact: Roger Schmechel, (406) 252-4661

Owners/Operators:

W G Properties LLC, Owner	(406)-651-5101	PO BOX 80391 BILLINGS MT 59108-0391
City Service Valcon LLC DBA GM Petroleum Distributors, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107
Jay Brookie, UST Class A Operator		
Laura Geffre, UST Class A Operator		
Bill Grunstead, UST Class A Operator		
Cody P Oconnor, UST Class A Operator		
Roger Schmechel, UST Class A Operator		
Laura Geffre, UST Class B Operator		
Cody P Oconnor, UST Class B Operator		
Roger Schmechel, UST Class B Operator		
Jay Brookie, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	40	2/4/1976	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
752		6/23/2016	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/8/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
2	40	1/1/1976	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
753			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/8/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CARDLOCK #3
1004 4TH AVE N
BILLINGS, MT 59101 YELLOWSTONE
Contact: Roger Schmechel, (406) 252-4661

Sys Fac ID: 56-01290
Last Inspected On: 6/23/2016
Operating Permit Renewal Date: 8/16/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
3	40	2/4/1976	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
754		6/23/2016	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/8/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
4	40	2/4/1976	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
755		6/23/2016	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/8/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
5	40	2/4/1976	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
756			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		7/8/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: REDDAWAY
833 MULLOWNEY LN
BILLINGS, MT 59101 YELLOWSTONE

Contact: Fort Gary, (406) 252-3877

Sys Fac ID: 56-01340
Last Inspected On: 4/7/2016
Operating Permit Renewal Date: 5/30/2019

Owners/Operators: Reddaway, Owner (913)-344-3367 10990 ROE AVE MS A-650 OVERLAND PARK KS 66211

Gary Fort, UST Class A Operator
Gary Fort, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	23	8/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3154			None	None	Yes
Currently in Use		8/1/2003	Not Required	Safe Suction	Galvanic
Diesel		4/7/2016	Automatic Tank Gauging 0.2	Deferred	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 56
16 SHILOH RD
BILLINGS, MT 59106 YELLOWSTONE

Contact: Sean Hurley, (509) 535-7701

Sys Fac ID: 56-01664
Last Inspected On: 2/17/2015
Operating Permit Renewal Date: 7/9/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Ian Johnstone, UST Class A Operator
Darcy Ziegler, UST Class B Operator
Karina Serrano, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	12/31/1984	Bare Steel	Flexible Plastic	High Level Alarm
4344			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		2/17/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	31	12/31/1984	Bare Steel	Flexible Plastic	High Level Alarm
4345			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/17/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	27	11/10/1989	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4346			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/17/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 57
1046 N 27TH ST
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 252-9654

Sys Fac ID: 56-01665
Last Inspected On: 2/9/2015
Operating Permit Renewal Date: 7/11/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Ian Johnstone, UST Class A Operator
Chuck Crane, UST Class B Operator
ROBERT HAYS, UST Class B Operator
Ian Johnstone, UST Class B Global Operator
Katherine Warmus, UST Class B Global Operator

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
3	18	1/28/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
3080			Double-Walled	Double-Walled	Yes
Currently in Use		1/8/2009	Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/8/2009	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
15,000			Gilbarco EMC Basic , Gilbarco		
4	18	1/28/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
3081			Double-Walled	Double-Walled	Yes
Currently in Use		1/8/2009	Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/8/2009	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MT STATE WOMENS PRISON
701 S 27TH ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Dennis Wolfe, (406) 247-5133

Sys Fac ID: 56-01757
Last Inspected On: 3/10/2015
Operating Permit Renewal Date: 4/4/2018

Owners/Operators: Montana State Womens Prison, Owner (406)-247-5100 701 S 27TH ST BILLINGS MT 59101-4511

Ron Himmelspach, UST Class A Operator
Dennis Wolff, UST Class A Operator
Ron Himmelspach, UST Class B Operator
Dennis Wolff, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	11	10/1/2005	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
5053		2/10/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Diesel		2/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,000			TLS-300 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DEACONESS BILLINGS CLINIC 9TH AVE
2800 10TH AVE N
BILLINGS, MT 59101 YELLOWSTONE

Contact: Mitch Goplen, (406) 657-4030

Sys Fac ID: 56-02067
Last Inspected On: 6/1/2015
Operating Permit Renewal Date: 9/29/2018

Owners/Operators: Deaconess Clinic Billings, Owner (406)-657-4036 2800 10TH AVE N BILLINGS MT 59101-0703

Cody Anderson, UST Class A Operator
Lloyd Newman, UST Class A Operator
Cody Anderson, UST Class B Operator
Lloyd Newman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	2/1/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
826		9/17/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Diesel		2/27/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SAINT VINCENT HOSPITAL & HEALTH CENTER
1233 N 30TH ST
BILLINGS, MT 59101 YELLOWSTONE
Contact: Kevin Maddox, (406) 657-7000

Sys Fac ID: 56-02666
Last Inspected On: 12/23/2015
Operating Permit Renewal Date: 1/22/2019

Owners/Operators: Saint Vincent Hospital & Health Center, Owner (406)-237-3065 PO BOX 35200 BILLINGS MT 59107-5200
Kevin Maddox, UST Class A Operator
Kevin Maddox, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	17	11/8/1999	Bare Steel	Copper	
1953	Yes	11/9/2012	None	Secondary Containment Chase	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
4,000		1/13/2016	Auto Stik II , EBW		
6	17	11/8/1999	Bare Steel	Copper	
1954	Yes	11/9/2012	None	Secondary Containment Chase	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
4,000		1/13/2016	Auto Stik II , EBW		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SYSCO FOOD SERVICES OF MONTANA MONAD RD
1509 MONAD RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Greg Murray, (406) 247-1100

Sys Fac ID: 56-03530
Last Inspected On: 4/24/2014
Operating Permit Renewal Date: 6/11/2017

Owners/Operators: Sysco Food Services of Montana, Owner (406)-247-1131 PO BOX 31198
BILLINGS MT 59107-1198

Greg Murray, UST Class A Operator
Greg Murray, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	08	12/27/2007	Unknown	Flexible Plastic	
5144	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		11/23/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
5	08	12/27/2007	Unknown	Flexible Plastic	
5145	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		11/21/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: YELLOWSTONE COUNTY PUBLIC WORKS DEPT
3321 KING AVE E
BILLINGS, MT 59101 YELLOWSTONE

Contact: John Ostlund, (406) 256-6812

Sys Fac ID: 56-03658
Last Inspected On: 6/11/2015
Operating Permit Renewal Date: 9/29/2018

Owners/Operators: Yellowstone County Public Works Dept, Owner (406)-256-6812 3321 KING AVE E
BILLINGS MT 59101-5533

Kim Peterson, UST Class A Operator
Oscar Thompson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	17	6/1/1999	Cathodically Protected Steel	Flexible Plastic	
4092		6/11/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Waste Oil		6/11/2015	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: POLY CONOCO
1704 POLY DR
BILLINGS, MT 59102 YELLOWSTONE

Contact: Larry Sperry, (406) 245-6944

Sys Fac ID: 56-04414
Last Inspected On: 4/7/2016
Operating Permit Renewal Date: 7/14/2019

Owners/Operators: Poly Conoco Inc, Owner (406)-245-6944 1704 POLY DR BILLINGS MT 59102-1729

Lawrence Sperry, UST Class A Operator
Lawrence Sperry, UST Class B Operator

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
5	18	2/11/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4718			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		4/5/2016	Gilbarco EMC Basic , Gilbarco		
6	18	2/11/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4719			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
7,000		4/5/2016	Gilbarco EMC Basic , Gilbarco		
7	18	2/11/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4720			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		4/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
3,000		4/5/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MEADOW GOLD DAIRIES INC BILLINGS
109 S 28TH ST
BILLINGS, MT 59101 YELLOWSTONE
Contact: Tim Diet, (406) 252-2118

Sys Fac ID: 56-04464
Last Inspected On: 5/19/2015
Operating Permit Renewal Date: 10/1/2018

Owners/Operators: Meadow Gold Dairies Inc Billings, Owner (406)-252-2118 109 S 28TH ST BILLINGS MT 59101-4134
WADE BARMAN, UST Class A Operator
FRANK COOK, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	27	8/7/1989	Cathodically Protected Steel	Steel	High Level Alarm
4264			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		5/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
10,000			EECO 1500 , EMCO Electronics		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: FIRST STUDENT INC
425 SUGAR AVE PO BOX 31133
BILLINGS, MT 59101 YELLOWSTONE

Contact: Fernando Crosa, (406) 248-3667

Sys Fac ID: 56-04467
Last Inspected On: 6/18/2016
Operating Permit Renewal Date:

Owners/Operators: FIRST STUDENT INC, Owner (513)-241-2200 600 VINE ST STE 1400 CINCINNATI OH 45202-2426
Philip Steadman, UST Class A Operator
Philip Steadman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	19	7/25/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1869			Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Diesel		9/28/2011	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
12,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: UNITED PARCEL SERVICE BILLINGS
1830 LAMPMAN DR
BILLINGS, MT 59102 YELLOWSTONE

Contact: Scott Oleson, (406) 652-8772

Sys Fac ID: 56-04542
Last Inspected On: 2/19/2016
Operating Permit Renewal Date: 3/22/2019

Owners/Operators:

United Parcel Service, Inc, Owner	(503)-978-7678	6707 N BASIN AVE PORTLAND OR 97217
United Parcel Service Plant Engineering Dept, Operator	(206)-621-6261	4455 7TH AVE S SEATTLE WA 98108

Robert Counts, UST Class A Operator
Treair Smith, UST Class A Operator
Russell Stott, UST Class A Operator
Paul Vandehey, UST Class A Operator
Robert Counts, UST Class B Operator
Russell Stott, UST Class B Operator
Treair Smith, UST Class B Global Operator
Paul Vandehey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	23	7/20/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2183			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
12,000		2/19/2016	TLS-350/Gilbarco EMC , Veeder Root		
6	23	7/20/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2184			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
12,000		2/19/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: STOCKTON OIL CO 4TH AVE N
1607 4TH AVE N
BILLINGS, MT 59101 YELLOWSTONE

Contact: Joey McConnell, (406) 245-6376

Sys Fac ID: 56-04839
Last Inspected On: 11/26/2013
Operating Permit Renewal Date: 12/3/2016

Owners/Operators: Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756 BILLINGS MT 59103-1756

Mykel Stockton, UST Class A Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Mykel Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	36	3/26/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1988			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/1/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000					
5	24	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1989			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/1/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000					
6	24	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1990			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/1/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					
7	24	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1991			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/1/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: STOCKTON OIL CO 4TH AVE N
1607 4TH AVE N
BILLINGS, MT 59101 YELLOWSTONE

Contact: Joey McConnell, (406) 245-6376

Sys Fac ID: 56-04839
Last Inspected On: 11/26/2013
Operating Permit Renewal Date: 12/3/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	24	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1992			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/1/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					
9	24	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1993			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/1/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					
10	22	7/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	
			None	None	Yes
Currently in Use				Not Listed	
Oil/Water Separator			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing, Deferred	
1,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 3 GS CONVENIENCE CENTER STATE AVE
4410 STATE AVE
BILLINGS, MT 59101 YELLOWSTONE

Sys Fac ID: 56-04946
Last Inspected On: 8/25/2016
Operating Permit Renewal Date: 11/5/2019

Contact: Larry or Kelly Grosulak, (406) 256-6246

Owners/Operators: SNG Inc 3, Owner (406)-245-0161 4410 STATE AVE
BILLINGS MT 59101-5060

Larry Groslack, Operator (406)-256-6246 4410 STATE AVE
BILLINGS MT 59101-5060

KELLY GROSLACK, UST Class A Operator
Larry Groslack, UST Class A Operator
TAMI MAUCH, UST Class A Operator
KELLY GROSLACK, UST Class B Operator
Larry Groslack, UST Class B Operator
TAMI MAUCH, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	03	4/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5400		5/1/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
4	03	4/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5401		5/1/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 3 GS CONVENIENCE CENTER STATE AVE
4410 STATE AVE
BILLINGS, MT 59101 YELLOWSTONE

Contact: Larry or Kelly Grosulak, (406) 256-6246

Sys Fac ID: 56-04946
Last Inspected On: 8/25/2016
Operating Permit Renewal Date: 11/5/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	03	4/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5402		5/1/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SOCO EXPRESS 10
5400 LAUREL RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Michael Stockton, (406) 245-6376

Sys Fac ID: 56-04951
Last Inspected On: 3/5/2015
Operating Permit Renewal Date:

Owners/Operators: Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756
BILLINGS MT 59103-1756

Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	25	5/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1994			None	None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/9/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		1/15/2005	TLS-350/Gilbarco EMC , Veeder Root		
6	25	5/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1995			None	None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/9/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		11/5/2008	TLS-350/Gilbarco EMC , Veeder Root		
7	25	5/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1996			None	None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/9/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		11/5/2008	TLS-350/Gilbarco EMC , Veeder Root		
8	25	5/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1997			None	None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		2/9/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		11/5/2008	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SOCO EXPRESS 10
5400 LAUREL RD
BILLINGS, MT 59101 YELLOWSTONE
Contact: Michael Stockton, (406) 245-6376

Sys Fac ID: 56-04951
Last Inspected On: 3/5/2015
Operating Permit Renewal Date:

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	25	5/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1998			None	None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		2/9/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		11/5/2008	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SOCO EXPRESS
1503 GRAND AVE
BILLINGS, MT 59102 YELLOWSTONE
Contact: (406) 256-0386

Sys Fac ID: 56-04954
Last Inspected On: 2/12/2014
Operating Permit Renewal Date:

Owners/Operators: Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756
BILLINGS MT 59103-1756

Mykel Stockton, UST Class A Operator
Joey McConnell, UST Class B Global Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Mykel Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	28	6/1/1988	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3780			None	none	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/12/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000					
4	30	3/26/1986	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3781			None	none	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/12/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000					
5	30	3/26/1986	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3782			None	none	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/12/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SOCO EXPRESS 15TH & BROADWATER
1503 BROADWATER AVE
BILLINGS, MT 59102 YELLOWSTONE
Contact: Mykel Stockton, (406) 245-6376

Sys Fac ID: 56-04956
Last Inspected On: 12/23/2014
Operating Permit Renewal Date: 2/19/2018

Owners/Operators: Stockton Oil Company, Owner/Operator (406)-245-6376 PO BOX 1756 BILLINGS MT 59103-1756

Mykel Stockton, UST Class A Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Mykel Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	39	3/26/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3751			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/22/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
8,000					
2	47	3/26/1969	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3752			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/22/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
8,000					
3	47	3/26/1969	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3753			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/22/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
8,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 3 GS CONVENIENCE CENTER E WICKS LANE
1221 WICKS LN
BILLINGS, MT 59105 YELLOWSTONE

Contact: Larry Grosulak, (406) 670-0085

Sys Fac ID: 56-04957
Last Inspected On: 3/30/2015
Operating Permit Renewal Date: 3/31/2018

Owners/Operators: SNG Inc 3, Owner (406)-245-0161 4410 STATE AVE
BILLINGS MT 59101-5060

KELLY GROSLACK, UST Class A Operator
Larry Groslack, UST Class A Operator
TAMI MAUCH, UST Class A Operator
KELLY GROSLACK, UST Class B Operator
Larry Groslack, UST Class B Operator
TAMI MAUCH, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	02	9/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5532		12/17/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		12/17/2014	TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	
4	02	9/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5533		12/17/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		12/17/2014	TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	
5	02	9/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5534		12/17/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		12/17/2014	TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: PACIFIC SUPPLY
600 DANIEL ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Dennis Yonts, (406) 254-8876

Sys Fac ID: 56-04965
Last Inspected On: 3/14/2014
Operating Permit Renewal Date: 5/14/2017

Owners/Operators:

Pacific Coast Building Products, Owner	(916)-971-2301	PO BOX 419074 RANCHO CORDOVA CA 95741-9074
Dennis Yonts, Operator	(406)-245-8876	600 DANIEL ST BILLINGS MT 59101-0637

Ryan Eklund, UST Class A Operator
Kate Renner, UST Class A Operator
Dennis Yonts, UST Class A Operator
Ryan Eklund, UST Class B Operator
Kayla Wittman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	23	11/1/1993	Fiberglass Reinforced Plastic	Steel	Flapper Valve (Auto Shutoff)
4350			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Deferred	
10,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DONS EXPRESS CENTER
2344 CENTRAL AVE
BILLINGS, MT 59102 YELLOWSTONE

Contact: Michael Stockton, (406) 245-6376

Sys Fac ID: 56-05072
Last Inspected On: 7/17/2014
Operating Permit Renewal Date: 9/25/2017

Owners/Operators: Automatic Car Wash Inc, Owner (406)-248-2558 PO BOX 1278
BILLINGS MT 59103-1278

Mykel Stockton, UST Class A Operator
Christopher Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	22	11/8/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2002			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
20,000		7/17/2014	TLS-350/Gilbarco EMC , Veeder Root		
6	22	11/8/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2003			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		7/17/2014	TLS-350/Gilbarco EMC , Veeder Root		
7	22	11/8/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2004			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		7/17/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: LOCKWOOD INTERSTATE EXXON
1031 US HIGHWAY 87 E
BILLINGS, MT 59101 YELLOWSTONE

Contact: Michael Stockton, (406) 245-6376

Sys Fac ID: 56-05074
Last Inspected On: 1/30/2015
Operating Permit Renewal Date: 2/7/2018

Owners/Operators: Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756 BILLINGS MT 59103-1756

Mykel Stockton, UST Class A Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Mykel Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	11/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2006			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		12/12/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		6/25/2014	Gilbarco EMC Basic , Gilbarco		
2	23	11/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2005			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		12/12/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		6/25/2014	Gilbarco EMC Basic , Gilbarco		
7	28	11/30/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3677			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/12/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		6/25/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: LOCKWOOD INTERSTATE EXXON
1031 US HIGHWAY 87 E
BILLINGS, MT 59101 YELLOWSTONE

Contact: Michael Stockton, (406) 245-6376

Sys Fac ID: 56-05074
Last Inspected On: 1/30/2015
Operating Permit Renewal Date: 2/7/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	28	11/30/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3676			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/12/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		6/25/2014	Gilbarco EMC Basic , Gilbarco		
10	28	11/30/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3675			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/12/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		6/25/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MERIDIAN AUTOMOTIVE SERVICE INC
1240 AVENUE C
BILLINGS, MT 59102 YELLOWSTONE

Sys Fac ID: 56-05077
Last Inspected On: 7/10/2015
Operating Permit Renewal Date:

Contact: Richard Skewis, (406) 259-6922

Owners/Operators: Meridian Automotive Service LLC, Owner (406)-259-6922 1240 AVENUE C
BILLINGS MT 59102-3238

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	22	1/11/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3182			None	none	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		7/2/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
2,000			Gilbarco EMC Basic , Gilbarco		
6	22	1/11/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3183			None	none	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		7/2/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
4,000			Gilbarco EMC Basic , Gilbarco		
7	22	1/11/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3184			None	none	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		7/2/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CASEY'S CORNER #10
3443 CENTRAL AVE
BILLINGS, MT 59102 YELLOWSTONE

Sys Fac ID: 56-05085
Last Inspected On: 4/1/2016
Operating Permit Renewal Date: 6/14/2019

Contact: Jason Shanley, (406) 587-0702

Owners/Operators:

Story Distributing Co, Owner	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771-1201
Jason Shanley, Operator	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771-1201

Jeffrey Fletcher, UST Class A Operator
Gary Scales, UST Class A Operator
Ethan Granzow, UST Class B Operator
Gary Scales, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	21	5/1/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2009		6/30/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		2/16/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		1/7/2016	TLS-450 , Veeder Root		
6	21	5/1/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2007		6/30/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/16/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		1/7/2016	TLS-450 , Veeder Root		
7	21	5/1/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4473		6/30/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/16/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		1/7/2016	TLS-450 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 3 G'S CONVENIENCE STORE
1425 US HIGHWAY 87 E
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 252-9763

Sys Fac ID: 56-05086
Last Inspected On: 11/16/2013
Operating Permit Renewal Date: 12/31/2016

Owners/Operators: VESTA VENTURES LLP, Owner (406)-656-8402 5629 BILLY CASPER DR
BILLINGS MT 59106-1053

KELLY GROSLACK, UST Class A Operator
Larry Groslack, UST Class A Operator
JERRY KLEIN, UST Class A Operator
TAMI MAUCH, UST Class A Operator
KELLY GROSLACK, UST Class B Operator
Larry Groslack, UST Class B Operator
TAMI MAUCH, UST Class B Operator
JERRY KLEIN, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	41	4/25/1975	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1151			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		9/11/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		9/11/2013			
2	41	4/25/1975	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1152			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/11/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		9/11/2013			
3	41	4/25/1975	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1153			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/11/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		9/11/2013			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CONO MART SUPER STORE 10
11 W WICKS LN
BILLINGS, MT 59105 YELLOWSTONE

Contact: Dennis Whitmore, (406) 252-4661

Sys Fac ID: 56-05088
Last Inspected On: 11/21/2014
Operating Permit Renewal Date: 3/3/2018

Owners/Operators:

B & A Holding LLC, Owner	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107
GM Cono Stores LLC, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107

Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Ken Jackson, UST Class A Operator
Charlie McHenry, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Laura Geffre, UST Class B Operator
Roger Schmechel, UST Class B Operator
Mark Zinnecker, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm, Ball Float Valve
1156			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/21/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000		9/18/2011			
2	26	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm, Ball Float Valve
1154			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/21/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000		9/18/2011			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CONO MART SUPER STORE 10
11 W WICKS LN
BILLINGS, MT 59105 YELLOWSTONE

Contact: Dennis Whitmore, (406) 252-4661

Sys Fac ID: 56-05088
Last Inspected On: 11/21/2014
Operating Permit Renewal Date: 3/3/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	26	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm, Ball Float Valve
1155			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/21/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000		9/18/2011			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MCFINYS #2
3306 RIMROCK RD
BILLINGS, MT 59102 YELLOWSTONE
Contact: Ken McCullough, (406) 861-3952

Sys Fac ID: 56-05090
Last Inspected On: 1/27/2016
Operating Permit Renewal Date: 6/14/2019

Owners/Operators: VESTA VENTURES LLP, Owner (406)-656-8402 5629 BILLY CASPER DR
BILLINGS MT 59106-1053

MCFINNY'S, Operator 2108 BROADWATER AVE STE 102
BILLINGS MT 59102

Joe McCullough, UST Class A Operator
Ken McCullough, UST Class A Operator
Joe McCullough, UST Class B Operator
Ken McCullough, UST Class B Operator
Ken McCullough, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	28	11/30/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3681			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/26/2016	Gilbarco EMC Basic , Gilbarco		
2	28	11/30/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3682			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/26/2016	Gilbarco EMC Basic , Gilbarco		
3	28	11/30/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3683			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		1/26/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DONS CAR WASH GRAND AVE
1125 GRAND AVE
BILLINGS, MT 59102 YELLOWSTONE

Contact: Gary Carlson, (406) 259-4955

Sys Fac ID: 56-05491
Last Inspected On: 11/4/2014
Operating Permit Renewal Date: 2/10/2018

Owners/Operators: Automatic Car Wash Inc, Owner (406)-248-2558 PO BOX 1278 BILLINGS MT 59103-1278

Gene Carlson, UST Class A Operator
Gene Carlson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	28	5/4/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
406			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000		12/3/2011			
3	28	5/4/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
407			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000		12/4/2011			
4	28	5/4/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
408			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
6,000		5/15/2011			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DONS CAR WASH CENTRAL AVE
2343 CENTRAL AVE
BILLINGS, MT 59102 YELLOWSTONE

Sys Fac ID: 56-05492
Last Inspected On: 10/23/2014
Operating Permit Renewal Date: 2/10/2018

Contact: Gene Carlson, (406) 656-7051

Owners/Operators: Automatic Car Wash Inc, Owner (406)-248-2558 PO BOX 1278
BILLINGS MT 59103-1278

Gene Carlson, UST Class A Operator
Gene Carlson, UST Class B Operator
Jamie Gehring, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	26	5/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
409			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/23/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		10/12/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	
5	26	5/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4467			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/23/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		7/3/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	
6	26	5/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
411			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		10/23/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		7/3/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 3 Gs CONVENIENCE STORE
4106 STATE AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 259-0995

Sys Fac ID: 56-05748
Last Inspected On: 12/3/2014
Operating Permit Renewal Date: 1/6/2018

Owners/Operators: VESTA VENTURES LLP, Owner (406)-656-8402 5629 BILLY CASPER DR BILLINGS MT 59106-1053

KELLY GROSLACK, UST Class A Operator
Larry Groslack, UST Class A Operator
TAMI MAUCH, UST Class A Operator
KELLY GROSLACK, UST Class B Operator
Larry Groslack, UST Class B Operator
TAMI MAUCH, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	14	8/23/2002	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4714		5/3/2016	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/3/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
9,000		5/13/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	14	8/23/2002	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4715		5/3/2016	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/3/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
3,000		5/13/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MCFINY'S 3
446 GRAND AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 259-0466

Sys Fac ID: 56-05749
Last Inspected On: 10/16/2014
Operating Permit Renewal Date: 1/6/2018

Owners/Operators: Kwik Way Inc, Owner (406)-656-6310 THERESA J JENKINS
PO BOX 20799
BILLINGS MT 59104-0799

Ken McCullough, UST Class A Operator
Ken McCullough, UST Class B Operator
Ken McCullough, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	19	11/1/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3456			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/16/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		10/11/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	
6	19	11/1/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3457			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/16/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		10/11/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 24TH STREET CENEX
1031 24TH ST W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Teresa Bidleman, (406) 652-1529

Sys Fac ID: 56-05750
Last Inspected On: 10/5/2015
Operating Permit Renewal Date: 2/5/2019

Owners/Operators: Quast Inc, Owner (406)-652-1529 1031 24TH ST W
BILLINGS MT 59102-3807

Teresa Bidleman, UST Class A Operator
Jeff Bidleman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	9/1/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3720			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/20/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		5/2/2015	Gilbarco EMC Basic , Gilbarco	ELLD Line Tightness Testing	
2	32	9/1/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3721			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/20/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		8/17/2015	Gilbarco EMC Basic , Gilbarco	ELLD Line Tightness Testing	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DONS CAR WASH
1433 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE

Contact: Bob Carlson, (406) 256-1941

Sys Fac ID: 56-05755
Last Inspected On: 3/30/2015
Operating Permit Renewal Date: 5/14/2018

Owners/Operators: Automatic Car Wash Inc, Owner (406)-248-2558 PO BOX 1278 BILLINGS MT 59103-1278

Gene Carlson, UST Class A Operator
Gene Carlson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	11	11/10/2005	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
5030			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/30/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		7/4/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	11	11/10/2005	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
5031			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/30/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		7/4/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	11	11/10/2005	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
5032			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/30/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		7/8/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: AT & T COMMUNICATIONS BILLINGS
3011 2ND AVE N
BILLINGS, MT 59101 YELLOWSTONE

Contact: Gary Donnovan, (406) 256-6607

Sys Fac ID: 56-05758
Last Inspected On: 11/23/2015
Operating Permit Renewal Date: 3/9/2019

Owners/Operators: AT & T Communications Inc, Owner (214)-464-1469 ENVIRONMENTAL MANAGER
308 S AKARD ST RM 1700
DALLAS TX 75202-5315

Philip Bunker, UST Class A Operator
Gerald Eshbaugh, UST Class A Operator
Richard Powell, UST Class A Operator
Gary Vantress, UST Class A Operator
Gary Vantress, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	22	9/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
399			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Diesel		11/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SUPER VALU INC BILLINGS
1629 KING AVE W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Scott Armstrong, (406) 247-1513

Sys Fac ID: 56-06097
Last Inspected On: 6/3/2016
Operating Permit Renewal Date: 8/28/2019

Owners/Operators: Super Valu Inc Billings Distribution Center, Owner (406)-761-8444 1629 KING AVE W BILLINGS MT 59102-6448

John Beadle, UST Class A Operator
Scott Combs, UST Class A Operator
Mike Frost, UST Class A Operator
Jeffrey Lindell, UST Class A Operator
John Beadle, UST Class B Operator
Steve Schilling, UST Class B Operator
Scott Combs, UST Class B Global Operator
Mike Frost, UST Class B Global Operator
Jeffrey Lindell, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	9/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1867			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		4/18/2016	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	18	9/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1868			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		4/18/2016	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: FOOD SERVICES OF AMERICA BILLINGS
802 PARKWAY LN
BILLINGS, MT 59101 YELLOWSTONE

Contact: Kevin Malley, (406) 238-7800

Sys Fac ID: 56-06132
Last Inspected On: 9/9/2016
Operating Permit Renewal Date: 12/14/2019

Owners/Operators: Food Services Of America Inc, Owner (406)-238-7800 PO BOX 25119
SCOTTSDALE AZ 85255-0178

Jeff Brent, UST Class A Operator
Rick Hansen, UST Class A Operator
Rod Ostman, UST Class A Operator
Jeff Brent, UST Class B Operator
Larry Hoye, UST Class B Operator
Rodney Hunt, UST Class B Operator
Duane Young, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	11/2/1993	Cathodically Protected Steel	Steel	High Level Alarm
1781			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		9/9/2016	Automatic Tank Gauging 0.2	Deferred	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BLUE BASKET #2
2347 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE
Contact: (406) 252-7679

Sys Fac ID: 56-06593
Last Inspected On: 2/21/2014
Operating Permit Renewal Date: 4/25/2017

Owners/Operators: Blue Basket Markets Billings, Owner (406)-252-0166 PO BOX 531
BILLINGS MT 59103-0531

Brit Miller, UST Class A Operator
Steve Berg, UST Class B Operator
Randy Lowe, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	35	10/1/1981	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
459			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		1/24/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		11/6/2010	TLS-350/Gilbarco EMC , Veeder Root		
2	35	10/1/1981	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
460			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/24/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		11/6/2010	TLS-350/Gilbarco EMC , Veeder Root		
3	35	10/1/1981	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
461			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/24/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		11/6/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: Caseys #8
2816 OLD HARDIN RD
BILLINGS, MT 59101 YELLOWSTONE
Contact: Gary Scales, (406) 587-7438

Sys Fac ID: 56-06594
Last Inspected On: 1/21/2015
Operating Permit Renewal Date: 2/28/2018

Owners/Operators:

Story Distributing Company, Owner	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771
Jason Shanley, Operator	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771-1201

Jason Shanley, UST Class A Operator
Chuck Crane, UST Class B Operator
Andrew Mclellan, UST Class B Operator
Jason Shanley, UST Class B Operator
STEVE WILLDEN, UST Class B Operator
Kelly Scott Shutes, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Positive Shutoff
462			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/25/2011	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Positive Shutoff
463			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/25/2011	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
464			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/25/2011	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: Caseys #8
2816 OLD HARDIN RD
BILLINGS, MT 59101 YELLOWSTONE
Contact: Gary Scales, (406) 587-7438

Sys Fac ID: 56-06594
Last Inspected On: 1/21/2015
Operating Permit Renewal Date: 2/28/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
465			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		8/25/2011	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: Caseys #7
2007 BLUE CREEK RD
BILLINGS, MT 59101 YELLOWSTONE

Sys Fac ID: 56-06595
Last Inspected On: 9/26/2014
Operating Permit Renewal Date: 11/29/2017

Contact: Jason Shanley, (406) 587-7438

Owners/Operators:

Central Holdings LLC, Owner	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771
Jason Shanley, Operator	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771-1201

Jason Shanley, UST Class A Operator
Irene Matzen, UST Class B Operator
Jason Shanley, UST Class B Operator
Melanie Sims, UST Class B Operator
Kelly Scott Shutes, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	24	11/2/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
466			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		7/24/2014	TLS-300 , Veeder Root	ELLD Line Tightness Testing	
4	24	11/2/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
467			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		7/28/2014	TLS-300 , Veeder Root	ELLD Line Tightness Testing	
5	24	11/2/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
468			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		8/7/2014	TLS-300 , Veeder Root	ELLD Line Tightness Testing	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SHORT STOP
804 CENTRAL AVE
BILLINGS, MT 59102 YELLOWSTONE

Contact: Joe Stockton, (406) 591-7332

Sys Fac ID: 56-06609
Last Inspected On: 10/10/2016
Operating Permit Renewal Date: 10/26/2016

Owners/Operators: Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756
BILLINGS MT 59103-1756

Mykel Stockton, UST Class A Operator
Joey McConnell, UST Class B Global Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	35	3/26/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3754			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/10/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
8,000					
2	35	3/26/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3899			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/10/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
8,000					
3	35	3/26/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4920			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/10/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
8,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SHORT STOP
804 CENTRAL AVE
BILLINGS, MT 59102 YELLOWSTONE

Contact: Joe Stockton, (406) 591-7332

Sys Fac ID: 56-06609
Last Inspected On: 10/10/2016
Operating Permit Renewal Date: 10/26/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	35	3/26/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4921			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/10/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
8,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CONO MART SUPER STORE 6
1219 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE

Contact: Dennis Whitmore, (406) 252-4661

Sys Fac ID: 56-06948
Last Inspected On: 11/21/2014
Operating Permit Renewal Date: 1/28/2018

Owners/Operators:

C Store Properties LLC, Owner	(406)-651-5101	PO BOX 80391 BILLINGS MT 59108
GM Cono Stores LLC, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107

Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Ken Jackson, UST Class A Operator
Charlie McHenry, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Troy Davis, UST Class B Operator
Laura Geffre, UST Class B Operator
Roger Schmechel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	40	4/21/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3618			Lined Interior/Impressed Current	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/21/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000		10/16/2011			
2	45	4/22/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3619			Lined Interior/Impressed Current	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/21/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000		6/28/2011			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CONO MART SUPER STORE 6
1219 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE

Contact: Dennis Whitmore, (406) 252-4661

Sys Fac ID: 56-06948
Last Inspected On: 11/21/2014
Operating Permit Renewal Date: 1/28/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	45	4/22/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3620			Lined Interior/Impressed Current	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/21/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		9/28/2011			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: REDDI ELECTRIC INC
1045 1/2 CENTRAL AVE
BILLINGS, MT 59102 YELLOWSTONE

Contact: Mike Schmidt, (406) 245-3141

Sys Fac ID: 56-06953
Last Inspected On: 4/22/2015
Operating Permit Renewal Date: 9/16/2018

Owners/Operators: Reddi Electric Inc, Owner (406)-245-3141 1045 1/2 CENTRAL AVE BILLINGS MT 59102-5821

Darin Linger, UST Class A Operator
Mike Schmidt, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	1/10/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1837			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/21/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
560			TLS-300 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DONS CAR WASH 1ST AVE
1924 1ST AVE N
BILLINGS, MT 59101 YELLOWSTONE
Contact: Bob Carlson, (406) 259-3539

Sys Fac ID: 56-06956
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 2/10/2018

Owners/Operators: Automatic Car Wash Inc, Owner (406)-248-2558 PO BOX 1278 BILLINGS MT 59103-1278

Gene Carlson, UST Class A Operator
Dick Berg, UST Class B Operator
Gene Carlson, UST Class B Operator
Gene Carlson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	28	11/11/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
412			None	Double-Walled	Yes
Currently in Use		11/11/1998	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/21/2005	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	28	11/11/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
413			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/1/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	28	11/11/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
414			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/2/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HEIGHTS CONOCO 13 UST
1320 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE

Contact: Joe Borgstrom, (651) 247-6200

Sys Fac ID: 56-06960
Last Inspected On: 7/18/2013
Operating Permit Renewal Date: 12/12/2016

Owners/Operators: TAG Inc, Owner (406)-259-3700 1320 MAIN ST
BILLINGS MT 59105-1742

Joseph Borgstrom, UST Class A Operator
Joseph Borgstrom, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	40	4/21/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1164			Lined Interior/Impressed Current	None	Yes
Currently in Use		5/1/2005	Mechanical Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		7/18/2013	Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
10,000		7/18/2013			
2	40	4/21/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1165			Lined Interior/Impressed Current	None	Yes
Currently in Use		5/1/2005	Mechanical Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		7/18/2013	Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
10,000		7/18/2013			
3	40	4/21/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1166			Lined Interior/Impressed Current	None	Yes
Currently in Use		5/1/2005	Mechanical Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		7/18/2013	Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
5,000		7/18/2013			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: GM PETROLEUM DISTRIBUTORS
2100 1ST AVE S
BILLINGS, MT 59101 YELLOWSTONE

Contact: Jay Brookie, (406) 294-0865

Sys Fac ID: 56-06962
Last Inspected On: 12/15/2014
Operating Permit Renewal Date: 3/14/2018

Owners/Operators: City Service Valcon LLC DBA GM Petroleum Distributors, Owner/Operator (406)-252-4661 PO BOX 30335 BILLINGS MT 59107
Jay Brookie, UST Class A Operator
Laura Geffre, UST Class A Operator
Roger Schmechel, UST Class A Operator
Laura Geffre, UST Class B Operator
Roger Schmechel, UST Class B Operator
Jay Brookie, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	6/1/1985	Bare Steel	Steel	High Level Alarm
1167			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		6/28/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
2	31	6/1/1985	Bare Steel	Steel	High Level Alarm
1168			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		6/28/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
3	31	6/1/1985	Bare Steel	Steel	High Level Alarm
1169			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		6/28/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: GM PETROLEUM DISTRIBUTORS
2100 1ST AVE S
BILLINGS, MT 59101 YELLOWSTONE

Contact: Jay Brookie, (406) 294-0865

Sys Fac ID: 56-06962
Last Inspected On: 12/15/2014
Operating Permit Renewal Date: 3/14/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	31	6/1/1985	Bare Steel	Steel	High Level Alarm
4626			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		6/28/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
5	33	5/7/1983	Bare Steel	Steel	High Level Alarm
4627			Impressed Current	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Waste Oil		6/28/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TRADING POST CONOCO
1225 MULLOWNEY LN
BILLINGS, MT 59101 YELLOWSTONE
Contact: Jeff Sowden, (406) 256-8465

Sys Fac ID: 56-06963
Last Inspected On: 9/7/2016
Operating Permit Renewal Date: 11/30/2019

Owners/Operators: S & G Partnership, Owner (406)-252-4661 1225 MULLOWNEY LN BILLINGS MT 59101-6301
Jeffrey Sowden, UST Class A Operator
Jeffrey Sowden, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	13	5/9/2003	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4836			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		6/18/2010	Gilbarco EMC Basic , Gilbarco		
6	13	5/9/2003	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4837			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		6/18/2010	Gilbarco EMC Basic , Gilbarco		
7	13	5/9/2003	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4838			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		6/18/2010	Gilbarco EMC Basic , Gilbarco		
8	13	5/9/2003	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4839			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		9/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		6/18/2010	Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DOWNTOWN CONOCO
2701 6TH AVE N
BILLINGS, MT 59101 YELLOWSTONE

Contact: Dennis Whitmore, (406) 254-1401

Sys Fac ID: 56-06967
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 1/28/2018

Owners/Operators:

Grunstead Family Limited Partnership, Owner	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107
J & L Properties Management Inc, Operator	(406)-254-1401	2701 6TH AVE N BILLINGS MT 59101

Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Jim Murphy, UST Class A Operator
Paul Murphy, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Laura Geffre, UST Class B Operator
Jim Murphy, UST Class B Operator
Roger Schmechel, UST Class B Operator
Paul Murphy, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	48	4/22/1968	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
3621			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/26/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
8,000		12/1/2011			
2	46	4/22/1970	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
3622			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/26/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
6,000		11/7/2011			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DOWNTOWN CONOCO
2701 6TH AVE N
BILLINGS, MT 59101 YELLOWSTONE

Contact: Dennis Whitmore, (406) 254-1401

Sys Fac ID: 56-06967
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 1/28/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	42	4/22/1974	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
3623			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/26/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		11/9/2011			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: WILSON DUNHAM SERVICE INC
2511 1ST AVE S
BILLINGS, MT 59101 YELLOWSTONE

Contact: Joan Erickson, (406) 724-7335

Sys Fac ID: 56-07756
Last Inspected On: 4/10/2014
Operating Permit Renewal Date: 6/3/2017

Owners/Operators:

Wilson Dunham Petroleum Supply, Owner	(406)-252-0880	2511 1ST AVE S BILLINGS MT 59101-2320
Erick Forum, Operator	(406)-724-7335	2511 1ST AVE S BILLINGS MT 59101
William Dunham, UST Class A Operator		
Joan Erickson, UST Class A Operator		
Joan Erickson, UST Class B Operator		
William Dunham, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	26	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2277			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		4/8/2014	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
6	26	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2278			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/8/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		11/4/2013	TLS-350/Gilbarco EMC , Veeder Root		
7	26	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2279			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/8/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		11/4/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: WILSON DUNHAM SERVICE INC
2511 1ST AVE S
BILLINGS, MT 59101 YELLOWSTONE

Contact: Joan Erickson, (406) 724-7335

Sys Fac ID: 56-07756
Last Inspected On: 4/10/2014
Operating Permit Renewal Date: 6/3/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	26	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2280			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/8/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
8,000		11/4/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: LYNCH FLYING SERVICE
1691 AVIATION PL
BILLINGS, MT 59105 YELLOWSTONE

Contact: Warren Nemitz, (406) 252-0508

Sys Fac ID: 56-07797
Last Inspected On: 10/8/2015
Operating Permit Renewal Date: 12/17/2018

Owners/Operators: LYNCH FLYING SERVICE INC, Owner (406)-252-0508 DBA EDWARDS JET CENTER
1691 AVIATION PL
BILLINGS MT 59105-1981

Robert McCullough, UST Class A Operator
Warren Nemitz, UST Class A Operator
Joel Simmons, UST Class A Operator
Aaron VanLuchene, UST Class A Operator
Robert McCullough, UST Class B Operator
Joel Simmons, UST Class B Operator
Warren Nemitz, UST Class B Global Operator
Aaron VanLuchene, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	10/25/1990	Cathodically Protected Steel	No Piping	High Level Alarm
1565			Lined Interior	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Jet Fuel		10/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
2	26	10/25/1990	Cathodically Protected Steel	No Piping	High Level Alarm
1566			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Aviation Gas		10/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
3	26	10/25/1990	Cathodically Protected Steel	Steel	High Level Alarm
1567			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: LYNCH FLYING SERVICE
1691 AVIATION PL
BILLINGS, MT 59105 YELLOWSTONE

Contact: Warren Nemitz, (406) 252-0508

Sys Fac ID: 56-07797
Last Inspected On: 10/8/2015
Operating Permit Renewal Date: 12/17/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	26	10/25/1990	Cathodically Protected Steel	No Piping	High Level Alarm
1563			Lined Interior	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Jet Fuel		10/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
12	26	10/25/1990	Cathodically Protected Steel	No Piping	High Level Alarm
1564			Lined Interior	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Jet Fuel		10/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
13	18	6/26/1998	Cathodically Protected Steel	No Piping	High Level Alarm
1568			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Jet Fuel		10/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
14	18	6/26/1998	Cathodically Protected Steel	No Piping	High Level Alarm
1569			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Jet Fuel		10/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
20,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 266
745 GRAND AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 248-7038

Sys Fac ID: 56-08058
Last Inspected On: 8/1/2016
Operating Permit Renewal Date: 11/20/2019

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Jack Krueger Jr, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Courtney Sheriff, UST Class B Operator
Linda French, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	6/8/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3039			Double-Walled	Double-Walled	Yes
Currently in Use		6/8/2005	Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/29/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		3/23/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	21	6/8/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3036			Double-Walled	Double-Walled	Yes
Currently in Use		6/8/2005	Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		7/29/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
12,000		3/23/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	21	6/8/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3037			Double-Walled	Double-Walled	Yes
Currently in Use		6/8/2005	Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		7/29/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		3/23/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 266
745 GRAND AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 248-7038

Sys Fac ID: 56-08058
Last Inspected On: 8/1/2016
Operating Permit Renewal Date: 11/20/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	21	6/8/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3038			Double-Walled	Double-Walled	Yes
Currently in Use		6/8/2005	Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		7/29/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		3/23/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 274
2620 6TH AVE N
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 248-7037

Sys Fac ID: 56-08062
Last Inspected On: 7/28/2016
Operating Permit Renewal Date: 10/29/2019

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Stephen Reckinger, UST Class A Operator
Dean Townsend, UST Class A Operator
Ronald VanDenBroeke, UST Class A Operator
Michael Boileau, UST Class B Operator
Linda French, UST Class B Global Operator
Stephen Reckinger, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator
Dean Townsend, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	21	10/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3040			Double-Walled	Double-Walled	Yes
Currently in Use		10/1/2005	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/23/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		12/25/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	21	10/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
4399			Double-Walled	Double-Walled	Yes
Currently in Use		10/1/2005	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/23/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		12/25/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 274
2620 6TH AVE N
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 248-7037

Sys Fac ID: 56-08062
Last Inspected On: 7/28/2016
Operating Permit Renewal Date: 10/29/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	21	10/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3042			Double-Walled	Double-Walled	Yes
Currently in Use		10/1/1995	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/23/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
10,000		12/25/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 275
105 BROADWATER AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 259-7361

Sys Fac ID: 56-08063
Last Inspected On: 6/3/2014
Operating Permit Renewal Date: 11/6/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Lisa Pedersen, UST Class A Operator
Lisa Pedersen, UST Class B Operator
Jeff Reed, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	21	7/13/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3043			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/23/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Manual Interstitial Monitor	
6	21	7/13/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3044			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/23/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Manual Interstitial Monitor	
7	21	7/13/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3045			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/23/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Manual Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 275
105 BROADWATER AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 259-7361

Sys Fac ID: 56-08063
Last Inspected On: 6/3/2014
Operating Permit Renewal Date: 11/6/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	21	7/13/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3046			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/23/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Manual Interstitial Monitor	
9	21	7/13/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3047			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/23/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Manual Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 54
151 ROSEBUD LN
BILLINGS, MT 59101 YELLOWSTONE
Contact: Ian Johnstone, (406) 259-5426

Sys Fac ID: 56-08208
Last Inspected On: 6/24/2015
Operating Permit Renewal Date: 6/25/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Nicholas Merritt, UST Class A Operator
Pete Nussbaum, UST Class A Operator
Tom Savas, UST Class A Operator
Chuck Crane, UST Class B Operator
Nicholas Merritt, UST Class B Operator
Nicholas Merritt, UST Class B Global Operator
Karina Serrano, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	02	9/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm, Auto Limiter
5525		11/1/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Manual Interstitial Monitor	Continuous Interstitial Monitor	
17,000		2/13/2015	TLS-450 , Veeder Root	Not Listed	
8	02	9/1/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Auto Limiter
5526		11/1/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Manual Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
8,000		2/13/2015	TLS-450 , Veeder Root	Not Listed	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 54
151 ROSEBUD LN
BILLINGS, MT 59101 YELLOWSTONE
Contact: Ian Johnstone, (406) 259-5426

Sys Fac ID: 56-08208
Last Inspected On: 6/24/2015
Operating Permit Renewal Date: 6/25/2018

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
9	02	9/1/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Auto Limiter
5527		11/1/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Manual Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
17,000		2/13/2015	TLS-450 , Veeder Root	Not Listed	
10	02	9/1/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Auto Limiter
5528		11/1/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Manual Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
8,000		2/13/2015	TLS-450 , Veeder Root	Not Listed	
11	02	9/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm, Auto Limiter
5529		11/1/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Manual Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
25,000		2/13/2015	TLS-450 , Veeder Root	Not Listed	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 58
610 WICKS LN
BILLINGS, MT 59105 YELLOWSTONE
Contact: (406) 259-7054

Sys Fac ID: 56-08209
Last Inspected On: 1/19/2015
Operating Permit Renewal Date: 3/17/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Sean Hurley, UST Class A Operator
Tom Savas, UST Class A Operator
Chuck Crane, UST Class B Operator
Karina Serrano, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	17	1/1/1999	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4256			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/19/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	17	1/1/1999	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4257			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/19/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 58
610 WICKS LN
BILLINGS, MT 59105 YELLOWSTONE
Contact: (406) 259-7054

Sys Fac ID: 56-08209
Last Inspected On: 1/19/2015
Operating Permit Renewal Date: 3/17/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	17	1/1/1999	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4258			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		4/19/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MARKET BASKET STORE
8014 S FRONTAGE RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Kebi Bowers, (406) 652-1529

Sys Fac ID: 56-08286
Last Inspected On: 4/19/2016
Operating Permit Renewal Date: 7/28/2019

Owners/Operators: Market Basket Store, Owner (406)-656-3546 8014 S FRONTAGE RD BILLINGS MT 59101-6202

Teresa Bidleman, UST Class A Operator
Jeff Bidleman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	10/6/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
3314			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/19/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/1/2016	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
2	21	10/6/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
3315			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/19/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		4/1/2016	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
5	13	11/28/2003	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4945			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		2/19/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/1/2016	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: PEPSI COLA BOTTLING CO BILLINGS
344 HOWARD AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 252-9355

Sys Fac ID: 56-08323
Last Inspected On: 10/23/2015
Operating Permit Renewal Date: 12/4/2018

Owners/Operators: Pepsi Cola Bottling Co Billings, Owner (406)-252-9355 344 HOWARD AVE BILLINGS MT 59101-3039
ERNE BRESTER, UST Class A Operator
ERNE BRESTER, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	8/1/1990	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1798			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
3,000			OPW 1500 , OPW		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CARDLOCK #2
36TH & 1ST AVE S
BILLINGS, MT 59101 YELLOWSTONE

Sys Fac ID: 56-08324
Last Inspected On: 10/5/2016
Operating Permit Renewal Date: 12/24/2019

Contact: Roger Schmechel, (406) 252-4661

Owners/Operators:

GM Petroleum Dist, Owner	(406)-661-1112	PO BOX 80391 BILLINGS MT 59108
City Service Valcon LLC DBA GM Petroleum Distributors, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107
Jay Brookie, UST Class A Operator		
Laura Geffre, UST Class A Operator		
Bill Grunstead, UST Class A Operator		
Roger Schmechel, UST Class A Operator		
Laura Geffre, UST Class B Operator		
Roger Schmechel, UST Class B Operator		
Jay Brookie, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	38	5/6/1978	Cathodically Protected Steel	Steel	High Level Alarm
1179			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/1/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		10/29/2010	Gilbarco EMC Basic , Gilbarco		
2	38	5/6/1978	Cathodically Protected Steel	Steel	High Level Alarm
1180			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/1/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		10/29/2010	Gilbarco EMC Basic , Gilbarco		
3	38	5/6/1978	Cathodically Protected Steel	Steel	High Level Alarm
1181			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/1/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		10/29/2010	Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SUBZERO INC DBA BROADWATER QUICK STOP
942 BROADWATER AVE
BILLINGS, MT 59101 YELLOWSTONE

Contact: Duane Young, (406) 208-8232

Sys Fac ID: 56-08671
Last Inspected On: 9/19/2014
Operating Permit Renewal Date: 12/16/2017

Owners/Operators:

Gordon Vandiviere, Operator	(406)-348-2222	235 3RD ST N HUNTLEY MT 59037-2714
Subzero Inc, Owner/Operator	(406)-702-3569	1129 PEONY DR BILLINGS MT 59105

Gordon Vandiviere, UST Class A Operator
Duane Young, UST Class A Operator
Diane Vandiviere, UST Class B Operator
Cerena Young, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	22	12/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3170			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/9/2014	Tank Tightness Testing, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
8,000					
5	22	12/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3169			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/9/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
8,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: QWEST BILLINGS WEST CENTRAL OFFICE
3190 CENTRAL AVE
BILLINGS, MT 59102 YELLOWSTONE

Sys Fac ID: 56-08762
Last Inspected On: 6/25/2015
Operating Permit Renewal Date: 11/13/2018

Contact: Kevin Robison, (801) 237-3006

Owners/Operators:

Qwest Corporation, Owner	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111
Qwest Corporation, Operator	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111

Thomas J Pitts, UST Class A Operator
Kevin Robison, UST Class A Operator
Thomas J Pitts, UST Class B Operator
Thomas J Pitts, UST Class B Global Operator
Kevin Robison, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	22	11/1/1994	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1733			Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel		8/20/2012	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
1,000		6/25/2015	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 52
1201 CENTRAL AVE
BILLINGS, MT 59102 YELLOWSTONE
Contact: (406) 245-9670

Sys Fac ID: 56-08903
Last Inspected On: 3/13/2014
Operating Permit Renewal Date: 5/21/2017

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Sean Hurley, UST Class A Operator
Pete Nussbaum, UST Class A Operator
Darcy Ziegler, UST Class B Operator
Pete Nussbaum, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	06	11/22/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5270			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
15,000			TLS-350/Gilbarco EMC , Veeder Root		Yes
7	06	11/22/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5271			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
7,000			TLS-350/Gilbarco EMC , Veeder Root		Yes
8	06	11/22/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5272			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 55
236 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE
Contact: (406) 259-3240

Sys Fac ID: 56-08904
Last Inspected On: 2/27/2015
Operating Permit Renewal Date: 7/11/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Ian Johnstone, UST Class A Operator
Chuck Crane, UST Class B Operator
Darcy Ziegler, UST Class B Operator
Karina Serrano, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	34	10/3/1982	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
589		10/8/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/1/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		10/13/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	34	10/3/1982	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
590		10/8/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/1/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		10/13/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	34	10/3/1982	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
591		10/8/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		8/1/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		10/13/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CARDLOCK #4
275 DANIELS ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Roger Schmechel, (406) 252-4661

Sys Fac ID: 56-09271
Last Inspected On: 1/26/2016
Operating Permit Renewal Date: 4/20/2019

Owners/Operators:

Monad Daniels LLC, Owner	(406)-252-4661	PO BOX 80391 BILLINGS MT 59108
City Service Valcon LLC DBA GM Petroleum Distributors, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107

Jay Brookie, UST Class A Operator
Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Roger Schmechel, UST Class A Operator
Laura Geffre, UST Class B Operator
Roger Schmechel, UST Class B Operator
Jay Brookie, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	1/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), Ball Float Valve
4716			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		10/10/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	23	1/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), Ball Float Valve
4717			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		10/10/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MDOT BILLINGS SITE
424 MOREY ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Joe Radonich, (406) 444-9204

Sys Fac ID: 56-09501
Last Inspected On: 1/13/2014
Operating Permit Renewal Date: 4/25/2017

Owners/Operators:

MDOT Helena, Owner	(406)-444-6200	KIM JANZEN PO BOX 201001 HELENA MT 59620-1001
Joseph J Radonich, Operator	(406)-444-9204	MDT DEADHEAD HELENA MT 59620-0901

Jeff Gleason, UST Class A Operator
Walt Kerttula, UST Class A Operator
Mike Murolo, UST Class A Operator
Joe Radonich, UST Class A Operator
Charlie Eddlemon, UST Class B Operator
Ronald Joslyn, UST Class B Operator
John McCloskey, UST Class B Operator
Joe Radonich, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	9/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2948			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		1/13/2014	Automatic Tank Gauging 0.2	Deferred	
10,000					
2	23	9/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2949			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		1/13/2014	Automatic Tank Gauging 0.2	Deferred	
10,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 280
1020 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE
Contact: (406) 245-1254

Sys Fac ID: 56-09695
Last Inspected On: 6/25/2014
Operating Permit Renewal Date: 11/29/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Jack Krueger Jr, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Kimberly Robers, UST Class B Operator
Stephanie Wilz, UST Class B Operator
Linda French, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	4/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
3048		10/3/2013	None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/25/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
12,000		3/12/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	29	4/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
3049		10/3/2013	None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/25/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
12,000		11/27/2013	TLS-350/Gilbarco EMC , Veeder Root		
3	29	4/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
3050		10/3/2013	None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/25/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		6/25/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 280
1020 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE
Contact: (406) 245-1254

Sys Fac ID: 56-09695
Last Inspected On: 6/25/2014
Operating Permit Renewal Date: 11/29/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	29	4/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
3051		10/3/2013	None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/25/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		3/14/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS FIRE STATION 1
2305 8TH AVE N
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 657-8423

Sys Fac ID: 56-09739
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 2/20/2018

Owners/Operators: City of Billings Fire Dept, Owner (406)-657-8428 2305 8TH AVE N BILLINGS MT 59101-1018
Boyd Vopel, UST Class A Operator
Boyd Vopel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	12/1/1993	Cathodically Protected Steel	Copper	High Level Alarm
2729			None	Secondary Containment Chase	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/18/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
517					
2	22	12/1/1993	Cathodically Protected Steel	Copper	High Level Alarm
2728			None	Secondary Containment Chase	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Diesel		6/18/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,035					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS FIRE STATION 2
501 S 28TH ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Marvin Jochems, (406) 657-8423

Sys Fac ID: 56-09740
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 2/20/2018

Owners/Operators: City of Billings Fire Dept, Owner (406)-657-8428 2305 8TH AVE N BILLINGS MT 59101-1018

Boyd Vopel, UST Class A Operator
Boyd Vopel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	6/12/1990	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3699			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/22/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000					
4	26	6/12/1990	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3700			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/22/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS FIRE STATION 3
1928 17TH ST W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Marvin Jochems, (406) 657-8423

Sys Fac ID: 56-09741
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 2/20/2018

Owners/Operators: City of Billings Fire Dept, Owner (406)-657-8428 2305 8TH AVE N
BILLINGS MT 59101-1018

Boyd Vopel, UST Class A Operator
Boyd Vopel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	3/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4297			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		6/18/2012	Automatic Tank Gauging 0.2	Not Listed	
500			TLS-300 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS FIRE STATION 5
605 S 24TH ST W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Marvin L Jochems, (406) 657-8423

Sys Fac ID: 56-09742
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 2/20/2018

Owners/Operators: City of Billings Fire Dept, Owner (406)-657-8428 2305 8TH AVE N
BILLINGS MT 59101-1018

Boyd Vopel, UST Class A Operator
Boyd Vopel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	23	1/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2731			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/18/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
517					
5	23	1/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2732			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		6/18/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
517					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS FIRE STATION 6
1601 ST ANDREWS DR
BILLINGS, MT 59105 YELLOWSTONE

Contact: Marvin Jochems, (406) 657-8423

Sys Fac ID: 56-09743
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 2/20/2018

Owners/Operators: City of Billings Fire Dept, Owner (406)-657-8428 2305 8TH AVE N
BILLINGS MT 59101-1018

Boyd Vopel, UST Class A Operator
Boyd Vopel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	10/19/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2733			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		6/18/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
500					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS REGIONAL LANDFILL
5240 JELLISON RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Barbara Butler, (406) 657-8260

Sys Fac ID: 56-09744
Last Inspected On: 6/25/2015
Operating Permit Renewal Date: 9/4/2018

Owners/Operators: CITY OF BILLINGS SOLID WASTE DIVISION, Owner/Operator (406)-657-8240 PO BOX 1178 BILLINGS MT 59103
Clarence Kostenko, UST Class A Operator
Anthony Lehner, UST Class A Operator
Anthony Lehner, UST Class B Operator
Clarence Kostenko, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	30	10/1/1986	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
630		6/25/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		6/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
10,000			TLS-300 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: PUBLIC UTILITIES DEPT
2251 BELKNAP AVE
BILLINGS, MT 59101 YELLOWSTONE

Contact: Larry Diedrich, (406) 657-8335

Sys Fac ID: 56-09746
Last Inspected On: 6/19/2015
Operating Permit Renewal Date: 10/29/2018

Owners/Operators: City of Billings Public Works, Owner (406)-657-8335 2251 BELKNAP AVE BILLINGS MT 59101

Lawrence Diedrich, UST Class A Operator
Lawrence Diedrich, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	1/1/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
631			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
10,000			Gilbarco EMC Basic , Gilbarco		
2	26	1/1/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
632			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		6/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
10,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS METROPOLITAN TRANSIT
1705 MONAD RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: John Bishop, (406) 657-8218

Sys Fac ID: 56-09747
Last Inspected On: 8/13/2015
Operating Permit Renewal Date: 12/18/2018

Owners/Operators: City of Billings MET Transit, Owner (406)-657-8219 PO BOX 1178
BILLINGS MT 59103-1178

John Bishop, UST Class A Operator
Rusty Logan, UST Class A Operator
Rick Pirami, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	33	10/15/1983	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
635			None	None	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Waste Oil		8/13/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		8/13/2015	Gilbarco EMC Basic , Gilbarco		
4	13	9/3/2003	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4862			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		8/13/2015	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
8,000		8/13/2015	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
5	13	9/3/2003	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4863			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		8/13/2015	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
8,000		8/13/2015	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 284
3226 ROSEBUD DR
BILLINGS, MT 59102 YELLOWSTONE
Contact: Barbara Sparovic, (406) 652-4095

Sys Fac ID: 56-09752
Last Inspected On: 3/3/2014
Operating Permit Renewal Date: 5/30/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Jack Krueger Jr, UST Class A Operator
Ronald VanDenBroeke, UST Class A Operator
Garrett Lapp, UST Class B Operator
Irene Matzen, UST Class B Operator
Linda French, UST Class B Global Operator
Jack Krueger Jr, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	33	11/5/1983	Cathodically Protected Steel	Steel	Ball Float Valve
3052			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
10,000		11/24/2007	TLS-350/Gilbarco EMC , Veeder Root		
2	33	11/5/1983	Cathodically Protected Steel	Steel	Ball Float Valve
3053			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
10,000		11/24/2007	TLS-350/Gilbarco EMC , Veeder Root		
3	33	11/5/1983	Cathodically Protected Steel	Steel	Ball Float Valve
3054			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	IImpressed Current
Gasoline		3/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
6,000		11/24/2007	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 285
785 S 20TH ST W
BILLINGS, MT 59102 YELLOWSTONE
Contact: Jack Krueger, (406) 656-3430

Sys Fac ID: 56-09753
Last Inspected On: 11/19/2014
Operating Permit Renewal Date: 1/22/2018

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Jack Krueger Jr, UST Class A Operator
Russell Ericson, UST Class B Operator
Stan Sauer, UST Class B Operator
Jeff Reed, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	19	4/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
3055			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/19/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Yes
8,000					
6	19	4/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
3056			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/19/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Yes
8,000					
7	19	4/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
3057			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/19/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Yes
8,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 285
785 S 20TH ST W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Jack Krueger, (406) 656-3430

Sys Fac ID: 56-09753
Last Inspected On: 11/19/2014
Operating Permit Renewal Date: 1/22/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	19	4/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
3058			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/19/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Yes
8,000					
9	19	4/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
3059			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/19/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000		10/8/2008			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DEEDLES
3189 KING AVE W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Paul DiLorenzo, (406) 591-1921

Sys Fac ID: 56-10075
Last Inspected On: 12/31/2013
Operating Permit Renewal Date: 3/15/2017

Owners/Operators:

Stockton Oil Company, Owner	(406)-245-6376	PO BOX 1756 BILLINGS MT 59103-1756
Paul J DiLorenzo, Operator	(406)-839-2399	3189 KING AVE WEST BILLINGS MT 59102-7466

Paul J DiLorenzo, UST Class A Operator
Mykel Stockton, UST Class A Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Mykel Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	1/13/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3834			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/31/2013	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
8,000					
2	29	1/13/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3835			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/31/2013	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
6,000					
3	29	1/13/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3836			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/31/2013	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
6,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SKYVIEW HIGH SCHOOL DIST 2
1775 HIGH SIERRA BLVD
BILLINGS, MT 59105 YELLOWSTONE

Contact: Jim Miller, (406) 281-5200

Sys Fac ID: 56-10585
Last Inspected On: 2/3/2016
Operating Permit Renewal Date: 6/22/2019

Owners/Operators: Billings School District, Owner (406)-247-3777 415 N 30TH ST BILLINGS MT 59101-1298

Dennis Stellingwerf, UST Class A Operator
Jim Miller, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	3/16/1987	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
448		2/3/2016	None	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil		2/3/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			TLS-300 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 3 GS CONVENIENCE CENTER 27TH ST
702 S 27TH ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Larry Grosulak, (406) 256-6246

Sys Fac ID: 56-10797
Last Inspected On: 9/30/2014
Operating Permit Renewal Date: 1/7/2018

Owners/Operators: SNG Inc 3, Owner (406)-245-0161 4410 STATE AVE
BILLINGS MT 59101-5060

KELLY GROSLACK, UST Class A Operator
Larry Groslack, UST Class A Operator
TAMI MAUCH, UST Class A Operator
KELLY GROSLACK, UST Class B Operator
Larry Groslack, UST Class B Operator
TAMI MAUCH, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	7/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4751			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/19/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000		7/18/2008	TLS-300 , Veeder Root	Automatic Tank Gauging 0.2	
5	18	7/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4752			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/19/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000		7/18/2008	TLS-300 , Veeder Root	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: GAS N GO
800 JACKSON ST
BILLINGS, MT 59101 YELLOWSTONE

Sys Fac ID: 56-10866
Last Inspected On: 10/13/2016
Operating Permit Renewal Date: 1/4/2020

Contact: Connie Pelican, (406) 656-5882

Owners/Operators:

TLC Enterprises Inc, Owner	(406)-245-1133	122 1ST AVE S LAUREL MT 59044
Gas N Go, Operator	(406)-245-1133	800 JACKSON STREET BILLINGS MT 59101

Renee Andrews, UST Class A Operator
Connie Pelican, UST Class A Operator
Renee Andrews, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	4/10/1984	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
4551			Lined Interior/Impressed Current	None	Yes
Currently in Use		9/1/2008	Not Required	Safe Suction	Impressed Current
Gasoline		10/13/2016	Stat. Inventory Reconcilitation	Deferred	
6,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: EXXONMOBIL BILLINGS PRODUCTS TERMINAL
607 EXXONMOBIL RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Michael Bailey, (406) 657-5404

Sys Fac ID: 56-11335
Last Inspected On: 2/12/2016
Operating Permit Renewal Date: 5/12/2019

Owners/Operators: Exxon Mobil Corporation, Owner (832)-625-7781 607 EXXONMOBIL RD BILLINGS MT 59101-7363

Michael T Bailey, UST Class A Operator
Charles Herre, UST Class A Operator
Alan Mizner, UST Class A Operator
James Vokral Sup, UST Class A Operator
Christopher Scott Martin, UST Class B Operator
Alan Mizner, UST Class B Operator
Michael T Bailey, UST Class B Global Operator
Charles Herre, UST Class B Global Operator
Marc Larson, UST Class B Global Operator
James Vokral Sup, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1			Bare Steel	Steel	
			None	none	Yes
Currently in Use				Not Listed	
Oil/Water Separator		10/3/2008	Deferred	Deferred	
4,000		11/10/2009			
2	22	10/1/1994	Steel Clad	Steel	High Level Alarm
2736			Double-Walled	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Mixture		12/5/2015	Continuous Interstitial Monitor	Not Listed	
3,000		11/22/2015			
4	66	1/1/1950	Unknown	Steel - Terminal Piping	
2738	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Gasoline		12/5/2015	Deferred	MLLD Line Tightness Testing	
197,000		11/17/2015			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: EXXONMOBIL BILLINGS PRODUCTS TERMINAL
607 EXXONMOBIL RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Michael Bailey, (406) 657-5404

Sys Fac ID: 56-11335
Last Inspected On: 2/12/2016
Operating Permit Renewal Date: 5/12/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	66	1/1/1950	Unknown	Steel - Terminal Piping	
2740	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		12/5/2015	Deferred	MLLD Line Tightness Testing	
60,000		11/17/2015			
15	66	1/1/1950	Unknown	Steel - Terminal Piping	
2749	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		12/5/2015	Deferred	MLLD Line Tightness Testing	
60,000		11/22/2015			
16	66	1/1/1950	Unknown	Steel - Terminal Piping	
2750	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Gasoline		12/5/2015	Deferred	MLLD Line Tightness Testing	
60,000		11/22/2015			
36	64	1/1/1952	Unknown	Steel - Terminal Piping	
2764	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable, Impressed Current
Gasoline		12/5/2015	Deferred	MLLD Line Tightness Testing	
2,959,110		11/17/2015			
37	64	1/1/1952	Unknown	Steel - Terminal Piping	
2765	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable, Impressed Current
Diesel		12/5/2015	Deferred	MLLD Line Tightness Testing	
1,784,454		11/17/2015			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: EXXONMOBIL BILLINGS PRODUCTS TERMINAL
607 EXXONMOBIL RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Michael Bailey, (406) 657-5404

Sys Fac ID: 56-11335
Last Inspected On: 2/12/2016
Operating Permit Renewal Date: 5/12/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
38	64	1/1/1952	Unknown	Steel - Terminal Piping	
2766	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable, Impressed Current
Diesel		12/5/2015	Deferred	MLLD Line Tightness Testing	
1,749,888		11/17/2015			
39	19	5/1/1997	Unknown	Steel	
2758	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
15,000		11/10/2009			
40	19	5/1/1997	Unknown	Steel	
2759	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
15,000		11/10/2009			
41	19	5/1/1997	Unknown	Steel	
2760	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
15,000		11/10/2009			
42	19	5/1/1997	Unknown	Steel	
2761	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
15,000		11/10/2009			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: EXXONMOBIL BILLINGS PRODUCTS TERMINAL
607 EXXONMOBIL RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Michael Bailey, (406) 657-5404

Sys Fac ID: 56-11335
Last Inspected On: 2/12/2016
Operating Permit Renewal Date: 5/12/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
43	19	5/1/1997	Unknown	Steel	
2762	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
15,000		11/10/2009			
44	19	5/1/1997	Unknown	Steel	
2751	Yes		None	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	MLLD Line Tightness Testing	
15,000		11/10/2009			
45	19	5/1/1997	Unknown	Steel	
2752	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
6,000		11/10/2009			
46	19	5/1/1997	Unknown	Steel	
2753	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
6,000		11/10/2009			
47	19	5/1/1997	Unknown	Steel	
2754	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
6,000		11/10/2009			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: EXXONMOBIL BILLINGS PRODUCTS TERMINAL
607 EXXONMOBIL RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Michael Bailey, (406) 657-5404

Sys Fac ID: 56-11335
Last Inspected On: 2/12/2016
Operating Permit Renewal Date: 5/12/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
48	19	5/1/1997	Unknown	Steel	
2755	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
6,000		11/10/2009			
49	19	5/1/1997	Unknown	Steel	
2756	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
6,000		11/10/2009			
50	19	5/1/1997	Unknown	Steel	
2763	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
6,000		11/10/2009			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: FLYING J INC BILLINGS
2775 OLD HARDIN RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-12585
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 2/13/2018

Owners/Operators: Montana Innovations LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Trent Biggers, UST Class A Operator
Don Edmisten, UST Class A Operator
Trent Biggers, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1109			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/29/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000		6/26/2007	TLS-350/Gilbarco EMC , Veeder Root		
2	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1108			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/29/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000		6/26/2007	TLS-350/Gilbarco EMC , Veeder Root		
3	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1105			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/29/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		6/26/2007	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: FLYING J INC BILLINGS
2775 OLD HARDIN RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-12585
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 2/13/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4447			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/29/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		6/26/2007	TLS-350/Gilbarco EMC , Veeder Root		
5	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1110			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/29/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000		6/26/2007	TLS-350/Gilbarco EMC , Veeder Root		
6	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4448			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/29/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		6/26/2007	TLS-350/Gilbarco EMC , Veeder Root		
7	03	8/1/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5425		10/4/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: FLYING J INC BILLINGS
2775 OLD HARDIN RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-12585
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 2/13/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	03	8/1/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5427		10/4/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 53
2975 GRAND AVE
BILLINGS, MT 59102 YELLOWSTONE
Contact: (406) 655-0871

Sys Fac ID: 56-13245
Last Inspected On: 2/23/2015
Operating Permit Renewal Date: 7/14/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Ian Johnstone, UST Class A Operator
Nicholas Merritt, UST Class A Operator
Nicholas Merritt, UST Class B Operator
Darcy Ziegler, UST Class B Operator
Nicholas Merritt, UST Class B Global Operator
Karina Serrano, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	9/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
594			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		2/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco		
2	23	9/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
592			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco		
3	23	9/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
593			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 87
4041 GRAND AVE
BILLINGS, MT 59106 YELLOWSTONE
Contact: Paul Courchaine, (406) 651-9353

Sys Fac ID: 56-13723
Last Inspected On: 8/19/2016
Operating Permit Renewal Date: 11/20/2019

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

David Kujath, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Paul Courchaine, UST Class B Operator
Greg Hoffman, UST Class B Operator
Garrett Lapp, UST Class B Operator
Linda French, UST Class B Global Operator
David Kujath, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	6/1/1996	Steel Clad	Flexible Plastic	Ball Float Valve
3062			Double-Walled	Double-Walled	Yes
Currently in Use		6/1/2006	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/11/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		6/21/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	20	6/1/1996	Steel Clad	Flexible Plastic	Ball Float Valve
3063			Double-Walled	Double-Walled	Yes
Currently in Use		6/1/2006	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/11/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		6/21/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	20	6/1/1996	Steel Clad	Flexible Plastic	Ball Float Valve
3064			Double-Walled	Double-Walled	Yes
Currently in Use		6/1/2006	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/11/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		6/21/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 87
4041 GRAND AVE
BILLINGS, MT 59106 YELLOWSTONE

Contact: Paul Courchaine, (406) 651-9353

Sys Fac ID: 56-13723
Last Inspected On: 8/19/2016
Operating Permit Renewal Date: 11/20/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	20	6/1/1996	Steel Clad	Flexible Plastic	Ball Float Valve
3065			Double-Walled	Double-Walled	Yes
Currently in Use		6/1/2006	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/11/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		6/21/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	20	6/1/1996	Steel Clad	Flexible Plastic	Ball Float Valve
3066			Double-Walled	Double-Walled	Yes
Currently in Use		6/1/2006	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		7/11/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		6/21/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN AND COUNTRY HILL TOP
523 HILLTOP RD
BILLINGS, MT 59105 YELLOWSTONE

Contact: Wes Burley, (406) 256-1020

Sys Fac ID: 56-13731
Last Inspected On: 9/7/2016
Operating Permit Renewal Date: 12/12/2019

Owners/Operators: Town & Country Supply Association, Owner (406)-628-6314 PO BOX 367
LAUREL MT 59044-0367

Lucy Green, UST Class A Operator
Mark Heimbichner, UST Class A Operator
Leilani McCarthy, UST Class A Operator
Steven Shelton, UST Class A Operator
Leilani McCarthy, UST Class B Operator
Mark Heimbichner, UST Class B Global Operator
Steven Shelton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	7/1/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3419			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		12/3/2010	Gilbarco EMC Basic , Gilbarco		
2	20	7/1/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3420			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		12/3/2010	Gilbarco EMC Basic , Gilbarco		
3	02	6/30/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5509		6/30/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		7/14/2014	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor, Not Listed	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN PUMP BILLINGS #8
3969 GRAND AVE
BILLINGS, MT 59102 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-13741
Last Inspected On: 9/29/2014
Operating Permit Renewal Date: 2/7/2018

Owners/Operators:

Townhouse Inns of Conrad, Owner	(406)-497-6700	PO BOX 6000 BUTTE MT 59702
Town Pump Inc, Operator	(406)-497-6700	PO BOX 6000 BUTTE MT 59702-2534

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2013			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/22/2011	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2014			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/22/2011	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
3	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2015			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/22/2011	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN PUMP BILLINGS #8
3969 GRAND AVE
BILLINGS, MT 59102 YELLOWSTONE
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-13741
Last Inspected On: 9/29/2014
Operating Permit Renewal Date: 2/7/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2016			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/22/2011	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
5	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2017			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/22/2011	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: FIRST INTERSTATE CENTER
401 N 31ST ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Jermone Ries, (406) 255-7100

Sys Fac ID: 56-13766
Last Inspected On: 1/15/2016
Operating Permit Renewal Date: 6/1/2019

Owners/Operators: Billings 401 LLC, Owner (406)-255-7100 PO BOX 7047
BILLINGS MT 59103-7047

Jerome Ries, UST Class A Operator
Ricky Coop, UST Class B Operator
Patrick Kelly, UST Class B Operator
Leonard Meyer, UST Class B Operator
Jerome Ries, UST Class B Operator
Dennis Tallant, UST Class B Operator
Brad Zimmer, UST Class B Operator
Jim Zimmer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	18	10/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3400		1/15/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Diesel		1/16/2013	Manual Interstitial Monitor	Manual Interstitial Monitor	
560					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CONOMART SUPERSTORE 7
4903 SOUTHGATE DR
BILLINGS, MT 59101 YELLOWSTONE

Contact: Dennis Whitmore, (406) 252-4661

Sys Fac ID: 56-13808
Last Inspected On: 9/7/2016
Operating Permit Renewal Date: 12/31/2019

Owners/Operators:

C Store Properties LLC, Owner	(406)-651-5101	PO BOX 80391 BILLINGS MT 59108
GM Cono Stores LLC, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107

Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Ken Jackson, UST Class A Operator
Charlie McHenry, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Laura Geffre, UST Class B Operator
Kerry Schmelzer, UST Class B Operator
Ron Tenney, UST Class B Operator
Tammie Turner, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	18	12/5/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1182			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/29/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	18	12/5/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1183			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/29/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CONOMART SUPERSTORE 7
4903 SOUTHGATE DR
BILLINGS, MT 59101 YELLOWSTONE

Contact: Dennis Whitmore, (406) 252-4661

Sys Fac ID: 56-13808
Last Inspected On: 9/7/2016
Operating Permit Renewal Date: 12/31/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	17	12/5/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1184			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		5/29/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: THE WAVE CAR WASH
858 S 29TH ST W
BILLINGS, MT 59102 YELLOWSTONE
Contact: Steve Ott, (406) 656-2781

Sys Fac ID: 56-13884
Last Inspected On: 7/6/2016
Operating Permit Renewal Date: 9/13/2019

Owners/Operators: Ste Ott, Owner (406)-656-2781 858 S 29TH ST W BILLINGS MT 59102-7449

Stacy Ott, UST Class A Operator
Steven Ott, UST Class A Operator
Jessica Mascarena, UST Class B Operator
Stacy Ott, UST Class B Operator
Mark Roth, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	18	6/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3527			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/10/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
2	18	6/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3528			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/10/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: COSTCO WHOLESALE GASOLINE 69
2290 KING AVE W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Dennis Bock, (425) 313-8100

Sys Fac ID: 56-13953
Last Inspected On: 1/22/2016
Operating Permit Renewal Date: 4/1/2019

Owners/Operators: Costco Wholesale, Owner (425)-313-8100 ATTN: LICENSING
PO BOX 35005
SEATTLE WA 98124-8990

Dennis Bock, UST Class A Operator
Michael Clough, UST Class A Operator
Richard Colgrove, UST Class A Operator
Andrew Jurcich, UST Class A Operator
Shawn Kipp, UST Class A Operator
Kyle Knox, UST Class A Operator
Arthur Kraft, UST Class A Operator
Dan Martinez, UST Class A Operator
Joel Osborne, UST Class A Operator
Samuel Rodriguez, UST Class A Operator
Michael Schaeffer, UST Class A Operator
Andrew Jurcich, UST Class B Operator
Shawn Kipp, UST Class B Operator
Kyle Knox, UST Class B Operator
Arthur Kraft, UST Class B Operator
Joel Osborne, UST Class B Operator
Hal Ostlund, UST Class B Operator
Brett G Smith, UST Class B Operator
Dennis Bock, UST Class B Global Operator
Michael Clough, UST Class B Global Operator
Kyle Knox, UST Class B Global Operator
Samuel Rodriguez, UST Class B Global Operator
Michael Schaeffer, UST Class B Global Operator
Mark Shellabarger, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: COSTCO WHOLESALE GASOLINE 69
2290 KING AVE W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Dennis Bock, (425) 313-8100

Sys Fac ID: 56-13953
Last Inspected On: 1/22/2016
Operating Permit Renewal Date: 4/1/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	17	10/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4109			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Approved Remote Monitoring	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing, Approved Remote Monitoring	
30,000		11/19/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	17	10/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4110			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Approved Remote Monitoring	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing, Approved Remote Monitoring	
15,000		11/19/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	17	10/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4111			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Approved Remote Monitoring	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing, Approved Remote Monitoring	
15,000		11/19/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	05	4/1/2011	Concrete	Fiberglass Reinforced Plastic	High Level Alarm
5354	Yes		Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Hazardous Substance			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Deferred	MLLD Line Tightness Testing, Approved Remote Monitoring	
1,200		11/19/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: WELLS FARGO CENTER
175 N 27TH ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Robert Slayton, (406) 245-2748

Sys Fac ID: 56-13972
Last Inspected On: 3/27/2014
Operating Permit Renewal Date: 8/20/2017

Owners/Operators: S F H II LLC, Owner (406)-651-0603 PO BOX 1942
BILLINGS MT 59103-1942

John Schafnitz, UST Class A Operator
John Schafnitz, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	16	11/1/2000	Cathodically Protected Steel	Copper	Flapper Valve (Auto Shutoff)
4231			Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		3/27/2014	Continuous Interstitial Monitor	Not Listed	
400			LDE Series , Pneumercator		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: WELLS FARGO BANK OPERATIONS CENTER
2324 OVERLAND AVE
BILLINGS, MT 59102 YELLOWSTONE

Contact: Barr Stan, (406) 690-6680

Sys Fac ID: 56-13992
Last Inspected On: 5/19/2014
Operating Permit Renewal Date: 8/19/2017

Owners/Operators: Wells Fargo Bank Billings Operations Center, Owner (406)-655-7390 2324 OVERLAND AVE BILLINGS MT 59102-6401

Greg Amos, UST Class A Operator
Stan Barr Jr, UST Class A Operator
Richard Brodston, UST Class A Operator
Greg Amos, UST Class B Operator
Stan Barr Jr, UST Class B Operator
Richard Brodston, UST Class B Operator
Stan Barr Jr, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	16	9/1/2000	Steel Clad	Flexible Plastic	High Level Alarm
4279		9/10/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel		5/30/2008	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
2	16	9/1/2000	Steel Clad	Flexible Plastic	High Level Alarm
4280		9/10/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel		5/30/2008	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 108
790 S BILLINGS BLVD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Jack Krueger, (406) 860-9083

Sys Fac ID: 56-13994
Last Inspected On: 12/3/2013
Operating Permit Renewal Date: 2/4/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Jack Krueger Jr, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Linda French, UST Class B Global Operator
Jack Krueger Jr, UST Class B Global Operator
Jack Reed, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	15	5/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4285			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		6/19/2010	TLS-350/Gilbarco EMC , Veeder Root		
2	15	5/4/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4286			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
10,000		6/29/2010	TLS-350/Gilbarco EMC , Veeder Root		
3	15	5/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4287			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
10,000		7/25/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 108
790 S BILLINGS BLVD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Jack Krueger, (406) 860-9083

Sys Fac ID: 56-13994
Last Inspected On: 12/3/2013
Operating Permit Renewal Date: 2/4/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	15	5/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4288			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation	Automatic Tank Gauging 0.2	Yes
20,000		6/22/2009	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: JTL GROUP INC UST
1102 SHILOH RD
BILLINGS, MT 59106 YELLOWSTONE

Contact: Patrick Schneider, (406) 322-2012

Sys Fac ID: 56-14001
Last Inspected On: 6/6/2016
Operating Permit Renewal Date: 10/23/2019

Owners/Operators: JTL Group Inc, Owner (406)-655-2012 PO BOX 80066
BILLINGS MT 59108-0066

Brian Nickel, UST Class A Operator
Dan Ottman, UST Class A Operator
Brian Nickel, UST Class B Operator
Dan Ottman, UST Class B Operator
Brian Nickel, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	15	4/1/2001	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
4397			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
1,958			TLS-300 , Veeder Root		
2	15	4/1/2001	Steel Clad	Flexible Plastic	High Level Alarm
4398			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
13,019			TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS SENIOR HIGH SCHOOL
425 GRAND AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 247-2100

Sys Fac ID: 56-14045
Last Inspected On: 2/3/2016
Operating Permit Renewal Date:

Owners/Operators: Billings School District, Owner (406)-247-3777 415 N 30TH ST BILLINGS MT 59101-1298

Dennis Stellingwerf, UST Class A Operator
Rodney Grotbo, UST Class B Operator
Bruce Schliticing, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	14	12/17/2001	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4601		10/27/2012	Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Auto Dialer	Pressurized	Galvanic
Diesel		2/3/2016	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
3,000			ILS-350 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: LEWIS AND CLARK MIDDLE SCHOOL
1315 LEWIS AVE
BILLINGS, MT 59102 YELLOWSTONE

Contact: Richard Whitney, (406) 255-3778

Sys Fac ID: 56-14070
Last Inspected On: 10/23/2016
Operating Permit Renewal Date: 3/30/2020

Owners/Operators: Lewis and Clark Middle School, Owner (406)-255-3778 1315 LEWIS AVE BILLINGS MT 59102-4237

Dennis Stellingwerf, UST Class A Operator
Fred Gleich, UST Class B Global Operator
Timothy Schafft, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	12	11/15/2004	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4970		9/13/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil		9/13/2016	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,000			ILS-350 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MIDWEST MOTOR EXPRESS INC
214 ORCHARD LN
BILLINGS, MT 59101 YELLOWSTONE

Contact: Chris Booth, (406) 245-5938

Sys Fac ID: 56-14075
Last Inspected On: 11/17/2014
Operating Permit Renewal Date: 2/3/2018

Owners/Operators:

Midwest Motor Express, Owner	(406)-245-5938	220 ORCHARD LN BILLINGS MT 59101-4952
Christopher Booth, Operator	(406)-660-2151	305 SW BANNACK ST DILLON MT 59725

Loyd Allison, UST Class A Operator
Christopher Booth, UST Class A Operator
Loyd Allison, UST Class B Operator
Christopher Booth, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	13	1/9/2003	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4782		10/17/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
20,000			TLS-300 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS DIGITAL AIRPORT SURVEILLANCE RADAR
1901 TERMINAL CIR
BILLINGS, MT 59105 YELLOWSTONE

Sys Fac ID: 56-14077
Last Inspected On: 1/23/2015
Operating Permit Renewal Date: 3/26/2018

Contact: Charles Osborne, (406) 657-6981

Owners/Operators: Federal Aviation Admin Yellowstone SSC, Owner (406)-657-6455 FAA YELLOWSTONE SSC
1540 LAKE ELMO DR STE 6
BILLINGS MT 59105-1798

Michael Atkins, UST Class A Operator
Kim Feldt, UST Class A Operator
Paul Henley, UST Class A Operator
George Lamb, UST Class A Operator
Evan Wolfe, UST Class A Operator
Michael Atkins, UST Class B Operator
Paul Henley, UST Class B Operator
Kim Feldt, UST Class B Global Operator
Paul Henley, UST Class B Global Operator
George Lamb, UST Class B Global Operator
Evan Wolfe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	13	12/30/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
4780		7/3/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
1,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY #731
1280 GRAND AVE
BILLINGS, MT 59102 YELLOWSTONE
Contact: (952) 830-8899

Sys Fac ID: 56-14090
Last Inspected On: 5/13/2015
Operating Permit Renewal Date: 10/1/2018

Owners/Operators:

Rocky Mountain Oil Inc, Owner	(952)-830-8700	ATTN: ENVIRONMENTAL DIRECTOR 4567 AMERICAN BLVD W BLOOMINGTON MN 55437
Holiday #731, Operator	(952)-830-8747	1280 GRAND AVE BILLINGS MT 59102

Robert Deninno, UST Class A Operator
Michael Anderson, UST Class B Operator
Denny Munger, UST Class B Operator
Jason Vetsch, UST Class B Operator
Shelley Waters, UST Class B Operator
Darold Heck, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	13	6/24/2003	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Positive Shutoff
4844			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		6/22/2012	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	13	6/24/2003	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4845			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		5/9/2012	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY #731
1280 GRAND AVE
BILLINGS, MT 59102 YELLOWSTONE
Contact: (952) 830-8899

Sys Fac ID: 56-14090
Last Inspected On: 5/13/2015
Operating Permit Renewal Date: 10/1/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	13	6/24/2003	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4846			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000		5/7/2012	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: RADISSON HOTEL BILLINGS
5500 MIDLAND RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Tony Contreraz, (406) 248-7701

Sys Fac ID: 56-14103
Last Inspected On: 4/20/2016
Operating Permit Renewal Date: 6/22/2019

Owners/Operators: 5500 Midland Holdings LLC, Owner (386)-947-7741 1275 W GRANADA BLVD STE 3B ORMOND BEACH FL 32174

Jonathan Harpole, UST Class A Operator
Douglas Schmidt, UST Class A Operator
Douglas Schmidt, UST Class B Operator
Jonathan Harpole, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	12	3/12/2004	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4887		4/20/2016	None	Secondary Containment Chase	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Diesel		4/20/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
500		9/20/2004	EECO 1500 , EMCO Electronics		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS OPERATION CENTER
4848 MIDLAND RD
BILLINGS, MT 59101 YELLOWSTONE
Contact: Clifford Fillner, (406) 657-8216

Sys Fac ID: 56-14118
Last Inspected On: 10/13/2016
Operating Permit Renewal Date: 12/10/2019

Owners/Operators: City of Billings Operation Center, Owner (406)-657-8216 PO BOX 1178 BILLINGS MT 59103-1178
Larry Deschene, UST Class A Operator
Troy Namen, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	12	7/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4935			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	12	7/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4936			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	12	7/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4937			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	12	7/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4938			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: AIR TRAFFIC CONTROL TOWER
1907 TERMINAL CIR
BILLINGS, MT 59105 YELLOWSTONE

Contact: George Lamb, (406) 657-6455

Sys Fac ID: 56-14127
Last Inspected On: 2/12/2014
Operating Permit Renewal Date: 4/18/2017

Owners/Operators: Federal Aviation Administration, Owner (406)-657-6981 1613 AVIATION PL BILLINGS MT 59105

Michael Atkins, UST Class A Operator
Kim Feldt, UST Class A Operator
Craig Fitzgerald, UST Class A Operator
Paul Henley, UST Class A Operator
George Lamb, UST Class A Operator
Evan Wolfe, UST Class A Operator
Michael Atkins, UST Class B Operator
Paul Henley, UST Class B Operator
Kim Feldt, UST Class B Global Operator
Craig Fitzgerald, UST Class B Global Operator
Paul Henley, UST Class B Global Operator
George Lamb, UST Class B Global Operator
Evan Wolfe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	11	12/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4976		9/1/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN PUMP INC BILLINGS 3
3150 KING AVE W
BILLINGS, MT 59102 YELLOWSTONE
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15023
Last Inspected On: 12/21/2015
Operating Permit Renewal Date: 4/2/2019

Owners/Operators: New Inns Inc, Owner
PO BOX 6000
BUTTE MT 59702

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	10	4/14/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5062			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000		5/1/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	10	4/1/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5056			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/1/2006	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	10	4/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5057			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		5/1/2006	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN PUMP INC BILLINGS 3
3150 KING AVE W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15023
Last Inspected On: 12/21/2015
Operating Permit Renewal Date: 4/2/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	10	4/14/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5058			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	10	4/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5059			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		5/1/2006	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	10	4/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5060			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		5/1/2006	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MCDONALD LIGHTHOUSE
3212 1ST AVE S
BILLINGS, MT 59101 YELLOWSTONE
Contact: Dale Orth, (406) 670-2012

Sys Fac ID: 60-15027
Last Inspected On: 6/4/2015
Operating Permit Renewal Date: 9/6/2018

Owners/Operators:

Yellowstone Boys & Girls Ranch, Owner	(406)-651-3100	ATTN DALE ORTH 3212 1ST AVE S BILLINGS MT 59101-3824
DALE ORTH, Operator	(406)-670-2012	671 REPUBLIC AVE BILLINGS MT 59105

Gregory Leeds, UST Class A Operator
DALE ORTH, UST Class A Operator
Rick Kelum, UST Class B Operator
DALE ORTH, UST Class B Operator
Patrick Friesen, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	10	2/6/2006	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5072			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Heating Oil			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
6,000		6/4/2015	ILS-350 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 385
3630 GABEL ROAD
BILLINGS, MT 59102 YELLOWSTONE
Contact: Jack Krueger, (406) 651-9872

Sys Fac ID: 60-15065
Last Inspected On: 2/21/2014
Operating Permit Renewal Date: 5/20/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Jack Krueger Jr, UST Class A Operator
Ronald VanDenBroeke, UST Class A Operator
Carrie Cook, UST Class B Operator
Terry Youngblood, UST Class B Operator
Linda French, UST Class B Global Operator
Jack Krueger Jr, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	08	12/11/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5139			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Manual Interstitial Monitor	Yes
20,000		12/24/2010	TLS-350/Gilbarco EMC , Veeder Root		Yes
2	08	12/11/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5140			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Manual Interstitial Monitor	Yes
12,000		12/22/2010	TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 385
3630 GABEL ROAD
BILLINGS, MT 59102 YELLOWSTONE

Contact: Jack Krueger, (406) 651-9872

Sys Fac ID: 60-15065
Last Inspected On: 2/21/2014
Operating Permit Renewal Date: 5/20/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	08	12/11/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5141			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Manual Interstitial Monitor	Yes
8,000		12/16/2010	TLS-350/Gilbarco EMC , Veeder Root		Yes
4	08	12/11/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5142			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Manual Interstitial Monitor	
12,000		12/24/2010	TLS-350/Gilbarco EMC , Veeder Root		Yes
5	08	12/11/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5143			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Manual Interstitial Monitor	
8,000		12/24/2010	TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DONS EXPRESS CENTER
2324 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE
Contact: Gary Carlson, (406) 248-2558

Sys Fac ID: 60-15096
Last Inspected On: 10/17/2014
Operating Permit Renewal Date: 1/10/2018

Owners/Operators: Automatic Car Wash Inc, Owner (406)-248-2558 PO BOX 1278 BILLINGS MT 59103-1278
Gene Carlson, UST Class A Operator
Gene Carlson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	08	6/29/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5160			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
12,000		7/21/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	Yes
2	08	6/29/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5161			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
5,000		7/21/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	Yes
3	08	6/29/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5162			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
5,000		7/20/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DONS EXPRESS CENTER
2324 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE

Contact: Gary Carlson, (406) 248-2558

Sys Fac ID: 60-15096
Last Inspected On: 10/17/2014
Operating Permit Renewal Date: 1/10/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	08	6/29/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5163			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
5,000		7/23/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: Lynch Flying Service Inc
1482 AVIATION PLACE
BILLINGS, MT 59105 YELLOWSTONE
Contact: (406) 252-0508

Sys Fac ID: 60-15100
Last Inspected On: 8/8/2014
Operating Permit Renewal Date: 10/15/2017

Owners/Operators:

Edwards Jet Center, Owner	(406)-252-0508	1691 AVIATION PL BILLINGS MT 59105-1994
LYNCH FLYING SERVICE INC, Operator	(406)-252-0508	DBA EDWARDS JET CENTER 1691 AVIATION PL BILLINGS MT 59105-1981

Warren Nemitz, UST Class A Operator
Joel Simmons, UST Class A Operator
Aaron VanLuchene, UST Class A Operator
Joel Simmons, UST Class B Operator
Warren Nemitz, UST Class B Global Operator
Aaron VanLuchene, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	08	2/25/2008	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
5172		7/28/2014	Double-Walled	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Not Listed	Not Applicable
Jet Fuel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
20,000			TLS-350/Gilbarco EMC , Veeder Root		Yes
2	08	2/25/2008	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
5173		7/28/2014	Double-Walled	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Not Listed	Not Applicable
Jet Fuel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
20,000			TLS-350/Gilbarco EMC , Veeder Root		Yes
3	08	2/25/2008	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
5174		7/28/2014	Double-Walled	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Not Listed	Not Applicable
Aviation Gas			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
12,000			TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN PUMP INC BILLINGS 4
2711 N FRONTAGE RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15104
Last Inspected On: 2/1/2016
Operating Permit Renewal Date: 4/2/2019

Owners/Operators:

Town Pump Inc, Owner	(406)-497-6700	PO BOX 6000 BUTTE MT 59702-2534
Park Street Holdings LLC, Operator	(406)-467-6700	PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	07	12/15/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5180			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
2	07	12/15/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5181			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
3	07	12/15/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5182			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN PUMP INC BILLINGS 4
2711 N FRONTAGE RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15104
Last Inspected On: 2/1/2016
Operating Permit Renewal Date: 4/2/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	07	12/15/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5183			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
24,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
5	07	12/18/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5184			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
6	07	12/18/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5185			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
24,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
7	07	12/15/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5186			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SAM'S CLUB
4420 KING AVE E
BILLINGS, MT 59101 YELLOWSTONE
Contact: John May, (479) 277-9639

Sys Fac ID: 60-15138
Last Inspected On: 4/6/2016
Operating Permit Renewal Date: 6/17/2019

Owners/Operators: WALMART STORES INC, Owner (479)-273-4000 ATTN JOHN MAY
702 SW 8TH ST
BENTONVILLE AR 72716-6209

Kevin E Allen, UST Class A Operator
Taryn Bailey, UST Class A Operator
Dustin Branson, UST Class A Operator
Donald Elderbaum, UST Class A Operator
Sandy Goff, UST Class A Operator
Steven Hodge, UST Class A Operator
Scott Murray, UST Class A Operator
Dustin Branson, UST Class B Operator
Joseph Khan, UST Class B Operator
Kevin E Allen, UST Class B Global Operator
Taryn Bailey, UST Class B Global Operator
Donald Elderbaum, UST Class B Global Operator
Sandy Goff, UST Class B Global Operator
Steven Hodge, UST Class B Global Operator
Scott Murray, UST Class B Global Operator
James Ray, UST Class B Global Operator
Rick Weaver, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	07	9/8/2009	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5210			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
20,000		4/6/2016	OPW 1500 , OPW	Continuous Interstitial Monitor	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SAM'S CLUB
4420 KING AVE E
BILLINGS, MT 59101 YELLOWSTONE
Contact: John May, (479) 277-9639

Sys Fac ID: 60-15138
Last Inspected On: 4/6/2016
Operating Permit Renewal Date: 6/17/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
2	07	9/8/2009	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5211			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
20,000		4/6/2016	OPW 1500 , OPW	Continuous Interstitial Monitor	Yes
3	07	9/8/2009	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5212			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
12,000		4/6/2016	OPW 1500 , OPW	Continuous Interstitial Monitor	Yes
4	07	9/8/2009	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5213			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
8,000		4/6/2016	OPW 1500 , OPW	Continuous Interstitial Monitor	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: Rental Car Wash
3301 OVERLOOK DR
BILLINGS, MT 59105 YELLOWSTONE

Contact: DONALD KIM ANNIN, (406) 657-8482

Sys Fac ID: 60-15179
Last Inspected On: 12/23/2014
Operating Permit Renewal Date: 3/24/2018

Owners/Operators:

Billings Logan International Airport, Owner	(406)-657-8482	1901 TERMINAL CIR STE 216 BILLINGS MT 59105-1991
Donald Kim Annin, Operator	(406)-657-8495	BILLINGS LOGAN INTERNATIONAL AIRPORT 1901 TERMINAL CIR STE 216 BILLINGS MT 59105-1991

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	05	4/11/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5288			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
20,000		12/23/2014			Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: Fed Ex Freight
7107 COMMERCIAL AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: Chong Lee, (408) 654-3112

Sys Fac ID: 60-15181
Last Inspected On: 1/16/2015
Operating Permit Renewal Date: 3/17/2018

Owners/Operators: K W Billings, LLC, Owner (619)-435-1614 941 ORANGE AVE STE 512 CORONADO CA 92118

Adren Hillenburg, UST Class A Operator
Chong Lee, UST Class A Operator
Nick Haynes, UST Class B Operator
Kevin Roberts, UST Class B Operator
Adren Hillenburg, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	05	5/23/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5293			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		7/16/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: FEDEX GROUND BILLINGS
3815 HESPER ROAD
BILLINGS, MT 59106 YELLOWSTONE

Contact: Nancy Beaumont, (412) 262-7347

Sys Fac ID: 60-15209
Last Inspected On: 12/15/2014
Operating Permit Renewal Date: 12/30/2017

Owners/Operators: FedEx Ground, Owner (412)-262-7347 1000 FEDEX DRIVE
MOON TOWNSHIP PA 15108

Lorraine Nogrady, UST Class A Operator
Lorraine Nogrady, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	03	10/1/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, High Level Alarm
5447		11/6/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
30,000		8/13/2014	TLS-450 , Veeder Root	MLLD Line Tightness Testing, Not Listed	
2	03	10/1/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, High Level Alarm
5448		11/9/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
30,000		8/13/2014	TLS-450 , Veeder Root	MLLD Line Tightness Testing, Not Listed	
3	03	10/1/2013	Fiberglass Reinforced Plastic	Other	Ball Float Valve, High Level Alarm
5449		11/9/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
>B20			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
12,000			TLS-450 , Veeder Root	Not Listed	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: OLD DOMINION FREIGHT LINES
1030 INTERMOUNTAIN STREET
BILLINGS, MT 59101 YELLOWSTONE

Sys Fac ID: 60-15216
Last Inspected On: 7/25/2016
Operating Permit Renewal Date: 8/25/2019

Contact: Robert Alexander, (336) 822-5571

Owners/Operators:

Old Dominion Freight Line, Owner	(336)-889-5000	ATTN: CONTROL MAINTENANCE 500 OLD DOMINION WAY THOMASVILLE NC 27360
Robert Alexander, Operator	(406)-256-6506	1030 INTERMOUNTAIN BILLINGS MT 59101
Richard A McGuire, UST Class A Operator		
Lorrin Wallace, UST Class A Operator		
Ben Figg, UST Class B Global Operator		
Lorrin Wallace, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	04	10/1/2012	Unknown	Fiberglass Reinforced Plastic	
5393	Yes		Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		7/25/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in YELLOWSTONE County in the City of BROADVIEW

Location: BROADVIEW 500 KV SUBSTATION
MT HIGHWAY 3
BROADVIEW, MT 59015 YELLOWSTONE

Contact: Beth Stimatz, (406) 497-2687

Sys Fac ID: 56-01431
Last Inspected On: 9/1/2016
Operating Permit Renewal Date: 11/7/2019

Owners/Operators: Northwestern Energy, Owner (406)-655-2521 405 S 20TH ST W BILLINGS MT 59102

John Habeger, UST Class A Operator
Darren Brockel, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	34	4/30/1982	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1686		7/18/2016	None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
2,500			OPW 1500 , OPW		

Facility Summary in YELLOWSTONE County in the City of BROADVIEW

Location: BROADVIEW SERVICE STATION LLC
16437 IOWA AVE
BROADVIEW, MT 59015 YELLOWSTONE

Contact: Elisha Lewis, (406) 322-5214

Sys Fac ID: 56-02373
Last Inspected On: 12/23/2014
Operating Permit Renewal Date: 2/24/2018

Owners/Operators:

Broadview Service Station LLC, Owner	(406)-667-2253	16437 IOWA AVE BROADVIEW MT 59015-9751
Farmers Union Trading Co Columbus, Operator	(406)-322-5618	PO BOX 509 COLUMBUS MT 59019-0509

Jennifer Calovis, UST Class A Operator
Sonia Hollingsworth, UST Class A Operator
Jarred Mosdal, UST Class A Operator
Nathanial Williams, UST Class A Operator
Scott Hollingsworth, UST Class B Operator
Sonia Hollingsworth, UST Class B Operator
Susan Wood, UST Class B Operator
Jennifer Calovis, UST Class B Global Operator
Sonia Hollingsworth, UST Class B Global Operator
Elisha Lewis, UST Class B Global Operator
Nathanial Williams, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	20	5/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3410			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/23/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		7/28/2014	TLS-350/Gilbarco EMC , Veeder Root		
7	20	5/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3411			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/23/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		7/28/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BROADVIEW

Location: BROADVIEW SERVICE STATION LLC
16437 IOWA AVE
BROADVIEW, MT 59015 YELLOWSTONE
Contact: Elisha Lewis, (406) 322-5214

Sys Fac ID: 56-02373
Last Inspected On: 12/23/2014
Operating Permit Renewal Date: 2/24/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	20	5/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3412			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		12/23/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		7/28/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of CUSTER

Location: CUSTER STATION
523 2ND ST
CUSTER, MT 59024 YELLOWSTONE
Contact: Kirk Marzolf, (406) 967-3100

Sys Fac ID: 56-05291
Last Inspected On: 2/6/2016
Operating Permit Renewal Date: 4/30/2019

Owners/Operators: Farmers Union Oil Co, Owner (406)-967-3100 PO BOX 309
WORDEN MT 59088-0309

Scott Black, UST Class A Operator
Kirk Marzolf, UST Class A Operator
Tammy Onstine, UST Class B Operator
Marion Perrin, UST Class B Operator
Lenore Rogers, UST Class B Operator
Sherry Ward, UST Class B Operator
Trina Wilson, UST Class B Operator
Scott Black, UST Class B Global Operator
Lacey Cox, UST Class B Global Operator
Marion Perrin, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	17	7/1/1999	Unknown	Flexible Plastic	
4079	Yes	6/21/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
5,000			Gilbarco EMC Basic , Gilbarco		
6	17	7/1/1999	Unknown	Flexible Plastic	
4080	Yes	6/21/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		
7	17	7/1/1999	Unknown	Flexible Plastic	
4081	Yes	6/21/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of CUSTER

Location: CUSTER STATION
523 2ND ST
CUSTER, MT 59024 YELLOWSTONE

Contact: Kirk Marzolf, (406) 967-3100

Sys Fac ID: 56-05291
Last Inspected On: 2/6/2016
Operating Permit Renewal Date: 4/30/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	17	7/1/1999	Unknown	Flexible Plastic	
4082	Yes	6/21/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
10,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of HUNTLEY

Location: HUNTLEY EXPRESSWAY
135 NORTHERN AVE
HUNTLEY, MT 59037 YELLOWSTONE

Contact: Jim Woods, (406) 640-2860

Sys Fac ID: 56-00627
Last Inspected On: 9/30/2014
Operating Permit Renewal Date: 12/16/2017

Owners/Operators: Set Five LLC, Owner (406)-348-9209 PO BOX 161730 BIG SKY MT 59716

Bernie Greenfield, Operator 1126 YORKTOWN ST BILLINGS MT 59105

Bernie Greenfield, UST Class A Operator
Cheryl Greenfield, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	18	11/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3660			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	18	11/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3661			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	18	11/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3662			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: LAUREL TRAVEL CENTER
11360 S FRONTAGE RD
LAUREL, MT 59044 YELLOWSTONE
Contact: Kelly Gelski, (440) 808-7406

Sys Fac ID: 56-00626
Last Inspected On: 11/11/2016
Operating Permit Renewal Date: 12/31/2019

Owners/Operators: TA Operating LLC, Owner/Operator (440)-808-7406 24601 CENTER RIDGE RD WESTLAKE OH 44145

Renee Andrews, UST Class A Operator
Mike Rathbone, UST Class A Operator
Renee Andrews, UST Class B Operator
Mike Rathbone, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	45	5/3/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1795		8/18/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		8/1/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000		8/17/2016	TLS-350/Gilbarco EMC , Veeder Root	MLLD Line Tightness Testing	
2	48	5/2/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1796		8/18/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		8/1/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000		8/17/2016	TLS-350/Gilbarco EMC , Veeder Root	MLLD Line Tightness Testing	
3	48	5/2/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1794		8/18/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		8/1/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000		8/17/2016	TLS-350/Gilbarco EMC , Veeder Root	MLLD Line Tightness Testing	
4	48	5/2/1968	Cathodically Protected Steel	Steel	High Level Alarm
1792		8/18/2016	Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/1/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000		10/27/2016	TLS-350/Gilbarco EMC , Veeder Root	MLLD Line Tightness Testing	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: LAUREL TRAVEL CENTER
11360 S FRONTAGE RD
LAUREL, MT 59044 YELLOWSTONE
Contact: Kelly Gelski, (440) 808-7406

Sys Fac ID: 56-00626
Last Inspected On: 11/11/2016
Operating Permit Renewal Date: 12/31/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	48	5/2/1968	Cathodically Protected Steel	Steel	High Level Alarm
1793		8/18/2016	Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		8/1/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000		10/27/2016	TLS-350/Gilbarco EMC , Veeder Root	MLLD Line Tightness Testing	
6	48	5/2/1968	Cathodically Protected Steel	Steel	High Level Alarm
1791		8/18/2016	Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/1/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
6,000		10/27/2016	TLS-350/Gilbarco EMC , Veeder Root	MLLD Line Tightness Testing	
7	48	5/2/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1797		8/18/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		8/1/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000		8/17/2016	TLS-350/Gilbarco EMC , Veeder Root	MLLD Line Tightness Testing	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: LAUREL SERVICE CENTER INC UST
201 W MAIN ST
LAUREL, MT 59044 YELLOWSTONE

Contact: David Powers, (406) 628-4216

Sys Fac ID: 56-01069
Last Inspected On: 7/8/2014
Operating Permit Renewal Date: 8/20/2017

Owners/Operators:

John Munro, Owner	(406)-628-4216	201 W MAIN ST LAUREL MT 59044-3108
Laurel Service Center Inc, Operator	(406)-628-4216	201 W MAIN ST LAUREL MT 59044-3108
John Munro, UST Class A Operator		
John Munro, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	30	4/29/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1808			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		6/20/2014	Automatic Tank Gauging 0.2	Deferred	
10,000		8/8/2007	TLS-350/Gilbarco EMC , Veeder Root		
2	28	4/28/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1809			Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/20/2014	Not Listed	Not Listed	
10,000		8/8/2007	TLS-350/Gilbarco EMC , Veeder Root		
10	29	4/29/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1810			None	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		6/20/2014	Automatic Tank Gauging 0.2	Deferred	
10,000		8/8/2006	TLS-350/Gilbarco EMC , Veeder Root		
11	28	4/28/1988	Cathodically Protected Steel	No Piping	Flapper Valve (Auto Shutoff)
1811			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Safe Suction	Impressed Current
Diesel		6/20/2014	Not Listed	Not Listed	
10,000		8/8/2007	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: LAUREL SERVICE CENTER INC UST
201 W MAIN ST
LAUREL, MT 59044 YELLOWSTONE

Contact: David Powers, (406) 628-4216

Sys Fac ID: 56-01069
Last Inspected On: 7/8/2014
Operating Permit Renewal Date: 8/20/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
12	28	4/28/1988	Cathodically Protected Steel	No Piping	Flapper Valve (Auto Shutoff)
1812			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Diesel		6/20/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
8,000		8/8/2007	TLS-350/Gilbarco EMC , Veeder Root		
13	28	4/28/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1813			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Diesel		6/20/2014	Not Listed	Not Listed	
4,000		8/8/2007	TLS-350/Gilbarco EMC , Veeder Root		
14	28	4/28/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1814			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/20/2014	Not Listed	Not Listed	
4,000		8/8/2007	TLS-350/Gilbarco EMC , Veeder Root		
15	18	11/15/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1815			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/20/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		8/8/2007	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: TOWN & COUNTRY SUPPLY LAUREL ASSN
800 E MAIN ST
LAUREL, MT 59044 YELLOWSTONE

Contact: Wes Burley, (406) 628-6314

Sys Fac ID: 56-04497
Last Inspected On: 9/6/2016
Operating Permit Renewal Date: 12/14/2019

Owners/Operators: Town & Country Supply Association, Owner (406)-628-6314 PO BOX 367
LAUREL MT 59044-0367

Wesley Burley, UST Class A Operator
Karissa DeRudder, UST Class A Operator
Vincent Farr, UST Class A Operator
Ronni Nace, UST Class A Operator
Steven Shelton, UST Class A Operator
Karissa DeRudder, UST Class B Operator
Vincent Farr, UST Class B Operator
Ronni Nace, UST Class B Operator
Jennifer Reinhardt, UST Class B Operator
Steven Shelton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	2/12/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
4470			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/6/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		8/3/2016	TLS-350/Gilbarco EMC , Veeder Root		
2	26	2/12/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1520			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/6/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		8/3/2016	TLS-350/Gilbarco EMC , Veeder Root		
3	26	2/12/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
4471			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		9/6/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		8/3/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: TOWN & COUNTRY SUPPLY LAUREL ASSN
800 E MAIN ST
LAUREL, MT 59044 YELLOWSTONE

Contact: Wes Burley, (406) 628-6314

Sys Fac ID: 56-04497
Last Inspected On: 9/6/2016
Operating Permit Renewal Date: 12/14/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	26	2/12/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1518			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasohol/Ethanol		9/6/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		8/3/2016	TLS-350/Gilbarco EMC , Veeder Root		
12	26	2/12/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
4472			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		9/6/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		8/3/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: FASTLANE C STORES
815 E MAIN ST
LAUREL, MT 59044 YELLOWSTONE
Contact: (406) 628-6204

Sys Fac ID: 56-05083
Last Inspected On: 7/28/2014
Operating Permit Renewal Date: 9/25/2017

Owners/Operators:

East Main Development LLC, Owner	(406)-628-6204	1415 RIDGE DR LAUREL MT 59044
Fastlane C Stores, Operator	(406)-628-6204	1415 RIDGE DR LAUREL MT 59044
Dan Foos, UST Class A Operator		
Dan Foos, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	41	10/1/1975	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3831			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/28/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		5/27/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	41	10/1/1975	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3832			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		7/28/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,200		5/25/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	41	10/1/1975	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3833			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/28/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		6/14/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: CONOMART SUPERSTORE 3
519 W MAIN ST
LAUREL, MT 59044 YELLOWSTONE

Contact: Dennis Whitmore, (406) 628-2034

Sys Fac ID: 56-06965
Last Inspected On: 1/25/2016
Operating Permit Renewal Date: 6/2/2019

Owners/Operators:

C Store Properties LLC, Owner	(406)-651-5101	PO BOX 80391 BILLINGS MT 59108
GM Cono Stores LLC, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107

Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Ken Jackson, UST Class A Operator
Charlie McHenry, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Jewell Borchardt, UST Class B Operator
Laura Geffre, UST Class B Operator
Roger Schmechel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	10/17/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1173			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/29/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		11/9/2009	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	21	10/17/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1174			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		1/29/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		11/9/2009	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: CONOMART SUPERSTORE 3
519 W MAIN ST
LAUREL, MT 59044 YELLOWSTONE

Contact: Dennis Whitmore, (406) 628-2034

Sys Fac ID: 56-06965
Last Inspected On: 1/25/2016
Operating Permit Renewal Date: 6/2/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	21	10/17/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1172			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/29/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		11/9/2009	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: CONOMART SUPERSTORE 2
411 E 1ST ST
LAUREL, MT 59044 YELLOWSTONE

Contact: Whitmore Dennis, (406) 252-4661

Sys Fac ID: 56-06966
Last Inspected On: 9/22/2015
Operating Permit Renewal Date: 3/17/2019

Owners/Operators:

C Store Properties LLC, Owner	(406)-651-5101	PO BOX 80391 BILLINGS MT 59108
GM Cono Stores LLC, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107

Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Ken Jackson, UST Class A Operator
Charlie McHenry, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Linda Degele, UST Class B Operator
Laura Geffre, UST Class B Operator
Roger Schmechel, UST Class B Operator
Janice Wade, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	39	4/22/1977	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1177			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/22/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		5/22/2015	TLS-350/Gilbarco EMC , Veeder Root		
2	39	4/22/1977	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1176			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/22/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		5/22/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: CONOMART SUPERSTORE 2
411 E 1ST ST
LAUREL, MT 59044 YELLOWSTONE

Contact: Whitmore Dennis, (406) 252-4661

Sys Fac ID: 56-06966
Last Inspected On: 9/22/2015
Operating Permit Renewal Date: 3/17/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	39	4/22/1977	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1175			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		9/22/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		5/16/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: LAUREL CENEX C STORE
315 S 1ST AVE
LAUREL, MT 59044 YELLOWSTONE

Contact: Wayne M Reese, (406) 628-8660

Sys Fac ID: 56-08161
Last Inspected On: 9/8/2016
Operating Permit Renewal Date: 12/27/2019

Owners/Operators: Town & Country Supply Association, Owner (406)-628-6314 PO BOX 367
LAUREL MT 59044-0367

Wesley Burley, UST Class A Operator
Steven Shelton, UST Class A Operator
Cathy Culp, UST Class B Global Operator
Steven Shelton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	21	5/22/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1523			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasohol/Ethanol		9/8/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	21	5/22/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1524			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/8/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	21	5/22/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1525			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/8/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: LAUREL CENEX C STORE
315 S 1ST AVE
LAUREL, MT 59044 YELLOWSTONE

Contact: Wayne M Reese, (406) 628-8660

Sys Fac ID: 56-08161
Last Inspected On: 9/8/2016
Operating Permit Renewal Date: 12/27/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	21	5/22/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1526			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/8/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	21	5/22/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1527			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/8/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: TOWN PUMP INC LAUREL
312 FIRST AVE S
LAUREL, MT 59044 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-08710
Last Inspected On: 2/29/2016
Operating Permit Renewal Date: 4/29/2019

Owners/Operators: Major Brands Distributing Imports Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	42	4/14/1974	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2668			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Diesel		11/18/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
2	42	4/14/1974	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2669			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		11/18/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
3	42	4/14/1974	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2670			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		11/18/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: TOWN PUMP INC LAUREL
312 FIRST AVE S
LAUREL, MT 59044 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-08710
Last Inspected On: 2/29/2016
Operating Permit Renewal Date: 4/29/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	36	4/14/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), Ball Float Valve
4589			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Diesel		11/18/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	
5	36	4/14/1980	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2672			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		11/18/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	
6	29	4/1/1987	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), Ball Float Valve
4603			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Diesel		11/18/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: TOWN PUMP INC LAUREL
312 FIRST AVE S
LAUREL, MT 59044 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-08710
Last Inspected On: 2/29/2016
Operating Permit Renewal Date: 4/29/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4590			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/18/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	
8	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4591			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/18/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	
9	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4592			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/18/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	
10	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4593			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/18/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: TOWN PUMP INC LAUREL
312 FIRST AVE S
LAUREL, MT 59044 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-08710
Last Inspected On: 2/29/2016
Operating Permit Renewal Date: 4/29/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	15	8/25/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4594			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/18/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: NORTHERN SKIES AVIATION
3900 FOX ROAD
LAUREL, MT 59044 YELLOWSTONE

Contact: Brent Larson, (406) 628-2219

Sys Fac ID: 56-13474
Last Inspected On: 11/16/2015
Operating Permit Renewal Date: 1/27/2019

Owners/Operators: Kent Potter, Owner (406)-628-2219 NORTHERN SKIES AVIATION
PO BOX 936
LAUREL MT 59044-0936

Brent Larson, UST Class A Operator
Brent Larson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	6/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4295			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/16/2015	Manual Interstitial Monitor	MLLD Line Tightness Testing	
7,000		11/16/2015			
2	22	6/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4296			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/16/2015	Manual Interstitial Monitor	Deferred	
3,000					

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: RICCIS EXPRESS
704 1ST AVE
LAUREL, MT 59044 YELLOWSTONE

Contact: Vince Ricci, (406) 628-7221

Sys Fac ID: 60-15061
Last Inspected On: 7/6/2016
Operating Permit Renewal Date: 11/2/2019

Owners/Operators: Ricci of Laurel Inc, Owner/Operator (406)-628-7221 VINCE RICCI
704 1ST AVE
LAUREL MT 59044-2100

Vince Ricci, UST Class A Operator
Wes Salveson, UST Class A Operator
Sandi Frank, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	09	3/28/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5105			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
6,000		5/7/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	09	3/28/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5106			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
6,000		5/11/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	09	3/28/2007	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5107			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
12,000		5/13/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of WORDEN

Location: VALLEY FARMERS SUPPLY
1545 HIGHWAY 312
WORDEN, MT 59088 YELLOWSTONE
Contact: Ronald Broker, (406) 967-3100

Sys Fac ID: 56-02326
Last Inspected On: 12/2/2014
Operating Permit Renewal Date: 2/27/2018

Owners/Operators: Farmers Union Oil Co, Owner (406)-967-3100 PO BOX 309
WORDEN MT 59088-0309

Scott Black, UST Class A Operator
Kirk Marzolf, UST Class A Operator
Deborah Dvorak, UST Class B Operator
Scott Black, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	11/1/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1006			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/16/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		6/6/2011	TLS-350/Gilbarco EMC , Veeder Root		
2	25	11/1/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1007			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/16/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		6/6/2011	TLS-350/Gilbarco EMC , Veeder Root		
3	25	11/1/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1008			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/16/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
3,000		6/6/2011	TLS-350/Gilbarco EMC , Veeder Root		