

Facility Summary in Beaverhead County in the City of Dell

Location: DELL AIRPORT CANYON RANCH  
Dell Airport  
Dell, MT 59724 Beaverhead

System Facility ID:01-09843

Facility Code: 17682  
Last Inspected On: 12/21/2023  
Operating Permit Renewal Date: 12/26/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana Dept of Transportation (406) 444-7632 jradonich@mt.gov

Operator Contact: Joe Radonich (406) 444-9204 jradonich@mt.gov

Owner/Operator: Montana Dept of Transportation (406) 444-7632 jradonich@mt.gov

Joe Radonich, UST Class A Operator jradonich@mt.gov  
Joe Radonich, UST Class B Global Operator jradonich@mt.gov

Tank Code	01	Tank Age	36	Tank Installed Date	06/13/1989	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	516	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type		CP Met Types	Galvanic
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	12/21/2023	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Beaverhead County in the City of Dell

Location: DELL MERC  
24 Main St  
Dell, MT 59724 Beaverhead

System Facility ID:01-01523

Facility Code: 17476  
Last Inspected On: 07/14/2023  
Operating Permit Renewal Date: 08/20/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bear Paw Inc (307) 871-5947 cjshopper2017@outlook.com

Operator Contact: Chad Mussard (307) 871-5947

Owner/Operator: Bear Paw Inc (307) 871-5947 cjshopper2017@outlook.com

Chad Mussard, UST Class A Operator  
Chad Mussard, UST Class B Operator

Tank Code	04	Tank Age	20	Tank Installed Date	10/06/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5045	Spill Test Date	09/09/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/10/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	01/10/2024	Line Tightness Test Date	12/28/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	20	Tank Installed Date	10/06/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5046	Spill Test Date	09/09/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/10/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	01/10/2024	Line Tightness Test Date	12/28/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	01/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	20	Tank Installed Date	10/06/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5047	Spill Test Date	12/01/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/10/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	01/10/2024	Line Tightness Test Date	12/28/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	20	Tank Installed Date	10/06/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5048	Spill Test Date	09/09/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/10/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/10/2024	Line Tightness Test Date	12/28/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Beaverhead County in the City of Dillon

Location: COUNTY COURTHOUSE  
2 S Pacific St  
Dillon, MT 59725-4000 Beaverhead

System Facility ID:01-05668

Facility Code: 17574  
Last Inspected On: 06/07/2023  
Operating Permit Renewal Date: 05/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Beaverhead County Clerk (406) 683-5245 croffice@beaverheadcountymt.gov

Operator Contact: Shonna Graham;Beaverhead County (406) 596-1740 sgraham@beaverheadcountymt.gov

Owner/Operator: Beaverhead County Clerk (406) 683-5245 croffice@beaverheadcountymt.gov

Shonna Graham, UST Class A Operator

sgraham@beaverheadcountymt.gov

Shonna Graham, UST Class B Operator

sgraham@beaverheadcountymt.gov

Tank Code	02	Tank Age	32	Tank Installed Date	02/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	421	Spill Test Date	03/01/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	03/01/2022	Line Tightness Test Date	03/01/2008	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-250				

Facility Summary in Beaverhead County in the City of Dillon

Location: DIETRICH'S COLLEGE EXXON UST  
636 S Atlantic St  
Dillon, MT 59725-2725 Beaverhead

System Facility ID:01-05401

Facility Code: 17564  
Last Inspected On: 09/10/2025  
Operating Permit Renewal Date: 12/20/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: TJ and Megan Dietrich (406) 683-0070 dietrichcollegeautorepair@gmail.com

Operator Contact: Timothy Dietrich (404) 925-1600 tdietrich55@gmail.com

Owner/Operator: TJ and Megan Dietrich (406) 683-0070 dietrichcollegeautorepair@gmail.com

Timothy Dietrich, UST Class A Operator

tdietrich55@gmail.com

Timothy Dietrich, UST Class B Global Operator

tdietrich55@gmail.com

Tank Code	04	Tank Age	31	Tank Installed Date	07/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3226	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/20/2022	Primary Tank Leak Detection	Inventory Reconciliation;Tank Tightness Testing	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	05	Tank Age	31	Tank Installed Date	07/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3227	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/20/2022	Primary Tank Leak Detection	Inventory Reconciliation;Tank Tightness Testing	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Beaverhead County in the City of Dillon

Location: DILLON AIRPORT  
2400 Airport Rd  
Dillon, MT 59725-9500 Beaverhead

System Facility ID:56-13894

Facility Code: 30568  
Last Inspected On: 01/24/2024  
Operating Permit Renewal Date: 03/04/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Beaverhead County Clerk	(406) 683-5245	croffice@beaverheadcountymt.gov
Operator Contact:	Shonna Graham;Beaverhead County	(406) 596-1740	sgraham@beaverheadcountymt.gov

Owner/Operator:	Beaverhead County Clerk	(406) 683-5245	croffice@beaverheadcountymt.gov
	Shonna Graham, UST Class A Operator		sgraham@beaverheadcountymt.gov
	Shonna Graham, UST Class B Operator		sgraham@beaverheadcountymt.gov

Tank Code	01	Tank Age	43	Tank Installed Date	04/01/1982	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3995	Spill Test Date	01/24/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/24/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	01/24/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	01/24/2024	Line Tightness Test Date	01/24/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/24/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	43	Tank Installed Date	04/01/1982	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3996	Spill Test Date	01/24/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/24/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date	01/24/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	01/24/2024	Line Tightness Test Date	01/24/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/24/2024			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Beaverhead County in the City of Dillon

Location: ROCKY MOUNTAIN SUPPLY INC DILLON  
700 N Montana St  
Dillon, MT 59725-3357 Beaverhead

System Facility ID:01-10034

Facility Code: 17685  
Last Inspected On: 05/11/2023  
Operating Permit Renewal Date: 09/06/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Supply Inc (406) 388-4009 billballiet@rmsi.coop

Operator Contact: Jason Rorabaugh (406) 388-6116 jasonrorabaugh@rmsi.coop

Owner/Operator: Rocky Mountain Supply Inc (406) 388-4009 billballiet@rmsi.coop  
Jason Rorabaugh, UST Class A Operator jasonrorabaugh@rmsi.coop  
Perry Shank, UST Class B Operator billballiet@rmsi.coop  
Tari Eaves, UST Class B Operator rockymtnsupply@hotmail.com

Tank Code	01	Tank Age	44	Tank Installed Date	01/12/1981	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3900	Spill Test Date	05/10/2023	Piping Installed Date	03/01/2017	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/10/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	10/13/2022	Tank/Piping CP Test Date	10/07/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/13/2022	Line Tightness Test Date	06/07/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/13/2022			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	44	Tank Installed Date	01/12/1981	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3901	Spill Test Date	05/07/2020	Piping Installed Date	03/01/2017	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	10/09/2019	Tank/Piping CP Test Date	10/03/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	06/08/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	05/07/2020			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	44	Tank Installed Date	01/12/1981	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3902	Spill Test Date	05/07/2020	Piping Installed Date	03/01/2017	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	10/09/2019	Tank/Piping CP Test Date	10/03/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	06/08/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/07/2020			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	44	Tank Installed Date	01/12/1981	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3903	Spill Test Date	05/07/2020	Piping Installed Date	03/01/2017	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	10/09/2019	Tank/Piping CP Test Date	10/03/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	06/07/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/07/2020			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	44	Tank Installed Date	01/12/1981	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3904	Spill Test Date	05/07/2020	Piping Installed Date	03/01/2017	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	10/09/2019	Tank/Piping CP Test Date	10/03/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	06/07/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/07/2020			ATG Type	Veeder Root/TLS-450PLUS				

Tank Code	09	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3905	Spill Test Date	05/07/2020	Piping Installed Date	04/26/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/09/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	04/18/2017	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/07/2020			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				
Tank Code	10	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3906	Spill Test Date	05/07/2020	Piping Installed Date	03/01/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/09/2019	Tank/Piping CP Test Date	08/22/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4100	ATG Test Date		Line Tightness Test Date	04/18/2017	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/07/2020			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				
Tank Code	11	Tank Age	27	Tank Installed Date	12/01/1998	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3907	Spill Test Date	05/07/2020	Piping Installed Date	03/01/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/09/2019	Tank/Piping CP Test Date	08/22/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7900	ATG Test Date		Line Tightness Test Date	04/18/2017	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	05/07/2020			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				
Tank Code	12	Tank Age	8	Tank Installed Date	04/18/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5738	Spill Test Date	05/07/2020	Piping Installed Date	03/01/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/09/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	06/08/2017	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/07/2020			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				
Tank Code	13	Tank Age	8	Tank Installed Date	04/18/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5739	Spill Test Date	05/07/2020	Piping Installed Date	04/26/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/09/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	04/19/2017	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/07/2020			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				
Tank Code	14	Tank Age	8	Tank Installed Date	04/18/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	5740	Spill Test Date		Piping Installed Date	03/01/2017	Tank Construction		Piping Construction		AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Not Listed	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Beaverhead County in the City of Dillon

Location: SAFEWAY 1581 DILLON  
760 Vine St.  
Dillon, MT 59725-3315 Beaverhead

System Facility ID:56-13989

Facility Code: 30650  
Last Inspected On: 05/19/2025  
Operating Permit Renewal Date: 11/05/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Safeway Stores Inc (425) 201-6301

Operator Contact: Jesse Wees;Rachel Jones (208) 395-3269 jesse.wees@albertsons.com;rachel.jones@albertsons.com

Owner/Operator: Safeway Stores Inc (425) 201-6301

Jesse Wees, UST Class A Operator  
Page Rost, UST Class B Global Operator  
Rachel Jones , UST Class A Operator  
Rachel Jones , UST Class B Global Operator  
Shanna Sunderlin, UST Class B Global Operator

jesse.wees@albertsons.com  
page.rost@albertsons.com  
rachel.jones@albertsons.com  
rachel.jones@albertsons.com

Tank Code	01	Tank Age	25	Tank Installed Date	10/09/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4222	Spill Test Date	07/16/2024	Piping Installed Date	04/22/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/19/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/19/2025			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	25	Tank Installed Date	10/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4223	Spill Test Date	07/16/2024	Piping Installed Date	04/22/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/16/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	10000	ATG Test Date	05/19/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/19/2025			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	03	Tank Age	25	Tank Installed Date	10/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4224	Spill Test Date	07/16/2024	Piping Installed Date	04/22/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/16/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/19/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/19/2025			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Beaverhead County in the City of Dillon

Location: SPEEDY SINGHS INC  
4055 Rebich Ln  
Dillon, MT 59725 Beaverhead

System Facility ID:01-13101

Facility Code: 17715  
Last Inspected On: 02/02/2024  
Operating Permit Renewal Date: 03/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: SPEEDY SINGHS INC (406) 683-6404 GATEWAYTRUCKSTOP@GMAIL.COM

Operator Contact: Sharanjit Multani;SPEEDY SINGHS INC (801) 928-3419;(406) 683-6404 sharan\_jit@icloud.com;GATEWAYTRUCKSTOP@GMAIL.COM

Owner/Operator: SPEEDY SINGHS INC (406) 683-6404 GATEWAYTRUCKSTOP@GMAIL.COM

Sharanjit Multani, UST Class A Operator

GATEWAYTRUCKSTOP@GMAIL.COM

Sharanjit Multani, UST Class B Operator

GATEWAYTRUCKSTOP@GMAIL.COM

Tank Code	01	Tank Age	32	Tank Installed Date	07/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4634	Spill Test Date	02/02/2024	Piping Installed Date	03/12/2009	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/05/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/13/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/05/2023	Line Tightness Test Date	10/05/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	32	Tank Installed Date	07/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4635	Spill Test Date	04/03/2024	Piping Installed Date	03/12/2009	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/05/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/13/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/05/2023	Line Tightness Test Date	10/05/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	03	Tank Age	32	Tank Installed Date	07/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4636	Spill Test Date	04/03/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/05/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/13/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/05/2023	Line Tightness Test Date	10/05/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	32	Tank Installed Date	07/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4637	Spill Test Date	02/02/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/05/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/13/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/05/2023	Line Tightness Test Date	04/18/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	32	Tank Installed Date	07/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4638	Spill Test Date	04/03/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/05/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/13/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/05/2023	Line Tightness Test Date	10/05/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Beaverhead County in the City of Dillon

Location: THE MINI INC  
410 N Montana St  
Dillon, MT 59725 Beaverhead

System Facility ID:01-01215

Facility Code: 17471  
Last Inspected On: 09/10/2024  
Operating Permit Renewal Date: 10/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jeff Dubose;The Mini Inc (406) 683-6168 theminiinc@hotmail.com

Operator Contact: Lori DuBose (406) 638-6168 theminiinc@hotmail.com

Owner/Operator: Jeff Dubose (406) 683-6168  
Owner/Operator: The Mini Inc (406) 683-6168  
Lori DuBose, UST Class A Operator theminiinc@hotmail.com  
Lori DuBose, UST Class B Operator theminiinc@hotmail.com

Tank Code	04	Tank Age	27	Tank Installed Date	05/06/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3088	Spill Test Date	11/04/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/21/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	09/10/2024	Line Tightness Test Date	05/05/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Tank Code	05	Tank Age	27	Tank Installed Date	05/06/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3089	Spill Test Date	09/11/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/21/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	09/10/2024	Line Tightness Test Date	04/28/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	06	Tank Age	27	Tank Installed Date	05/06/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3090	Spill Test Date	09/10/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/21/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	09/10/2024	Line Tightness Test Date	04/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Beaverhead County in the City of Dillon

Location: TOWN PUMP INC DILLON 1  
101 E Helena St  
Dillon, MT 59725 Beaverhead

System Facility ID:01-08695

Facility Code: 17673  
Last Inspected On: 05/20/2025  
Operating Permit Renewal Date: 09/22/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Dillon 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
Operator Contact:	Trent Biggers		Trentb@townpump.com

Owner/Operator:	Dillon 1 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Code	01	Tank Age	64	Tank Installed Date	04/14/1961	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4794	Spill Test Date	11/09/2024	Piping Installed Date	10/19/2002	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	05/20/2025	Tank/Piping CP Test Date	07/26/2024	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/20/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/09/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	39	Tank Installed Date	01/01/1986	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4795	Spill Test Date	11/09/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/20/2025	Tank/Piping CP Test Date	07/26/2024	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	10000	ATG Test Date	05/20/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/09/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	39	Tank Installed Date	01/01/1986	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4796	Spill Test Date	11/09/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/20/2025	Tank/Piping CP Test Date	07/26/2024	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/20/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/09/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Beaverhead County in the City of Dillon

Location: TOWN PUMP OF DILLON 2  
635 N Montana St  
Dillon, MT 59725 Beaverhead

System Facility ID:01-08696

Facility Code: 17674  
Last Inspected On: 06/16/2025  
Operating Permit Renewal Date: 09/19/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Dillon 2 Town Pump LLC	(406) 497-6700	environmental@townpump.com
Operator Contact:	Trent Biggers		Trentb@townpump.com

Owner/Operator:	Dillon 2 Town Pump LLC	(406) 497-6700	environmental@townpump.com
	Trent Biggers, UST Class A Operator		Trentb@townpump.com
	Trent Biggers, UST Class B Global Operator		Trentb@townpump.com

Tank Code	07	Tank Age	35	Tank Installed Date	09/10/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2372	Spill Test Date	11/15/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/20/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/20/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	08	Tank Age	35	Tank Installed Date	09/10/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2373	Spill Test Date	11/15/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/20/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/20/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	09	Tank Age	35	Tank Installed Date	09/10/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	2374	Spill Test Date	11/15/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/20/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/20/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	10	Tank Age	35	Tank Installed Date	09/10/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2375	Spill Test Date	11/15/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/20/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/20/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/11/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	11	Tank Age	35	Tank Installed Date	09/10/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2376	Spill Test Date	11/15/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/20/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/20/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/15/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	14	Tank Age	24	Tank Installed Date	08/20/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4356	Spill Test Date	07/26/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/20/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	10000	ATG Test Date	05/20/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	15	Tank Age	24	Tank Installed Date	08/20/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4357	Spill Test Date	07/26/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	05/20/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/20/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/26/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	13	Tank Age	26	Tank Installed Date	05/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4541	Spill Test Date	11/15/2024	Piping Installed Date	11/14/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/20/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/20/2025	Line Tightness Test Date	11/16/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/15/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Beaverhead County in the City of Jackson

Location: CIRCLE S RANCH  
30300 MT Hwy 278  
Jackson, MT 59736-9700 Beaverhead

System Facility ID:01-07024

Facility Code: 17626  
Last Inspected On: 10/01/2025  
Operating Permit Renewal Date: 12/15/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: David Schuett (406) 660-4281 d.schuett@frontlineag.com

Operator Contact: David Schuett (406) 660-4281 d.schuett@frontlineag.com

Owner/Operator: David Schuett (406) 660-4281 d.schuett@frontlineag.com

David Schuett, UST Class A Operator d.schuett@frontlineag.com

Tank Code	S1	Tank Age	45	Tank Installed Date	02/12/1980	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	
Tag Number		Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Deregulated under SB386	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Not Listed	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	05	Tank Age	28	Tank Installed Date	07/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4228	Spill Test Date	10/01/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	10/01/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/01/2025			ATG Type	Other/Other				
Tank Code	06	Tank Age	28	Tank Installed Date	07/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4229	Spill Test Date	10/01/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	10/01/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/01/2025			ATG Type	Other/Other				

Facility Summary in Beaverhead County in the City of Lima

Location: LIMA SCHOOL DIST 12 INC  
1 N Harrison St  
Lima, MT 59739 Beaverhead

System Facility ID:01-07158

Facility Code: 17665  
Last Inspected On: 12/21/2023  
Operating Permit Renewal Date: 01/17/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 12 Lima (406) 276-3571 rkluesner@limaschoolmt.org

Operator Contact:

Owner/Operator: School Dist 12 Lima (406) 276-3571 rkluesner@limaschoolmt.org

Tank Code	03	Tank Age	33	Tank Installed Date	06/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1535	Spill Test Date	12/21/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/27/2020	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	12/21/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/21/2023			ATG Type	Gilbarco-Veeder Root/ILS-250				

Facility Summary in Beaverhead County in the City of Lima

Location: RALPHS EXXON  
114 S Harrison St  
Lima, MT 59739 Beaverhead

System Facility ID:01-00671

Facility Code: 17463  
Last Inspected On: 04/23/2025  
Operating Permit Renewal Date: 09/21/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Ralphs C-Store Inc	(406) 925-1081	jdt.ralphs@gmail.com
Operator Contact:	Branden Thornton;Justin Thornton		branden.t@mail.com;jdt1986@comcast.net

Owner/Operator:	Ralphs C-Store Inc	(406) 925-1081	jdt.ralphs@gmail.com
	Branden Thornton, UST Class A Operator		branden.t@mail.com
	Branden Thornton, UST Class B Global Operator		branden.t@mail.com
	Justin Thornton, UST Class A Operator		jdt1986@comcast.net
	Justin Thornton, UST Class B Global Operator		jdt1986@comcast.net

Tank Code	07	Tank Age	27	Tank Installed Date	09/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2078	Spill Test Date	12/11/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/10/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/23/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/10/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/14/2021			ATG Type	Gilbarco/TLS-350				
Tank Code	08	Tank Age	27	Tank Installed Date	09/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2079	Spill Test Date	12/11/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/10/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/23/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/10/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/10/2025			ATG Type	Gilbarco/TLS-350				

Tank Code	S9	Tank Age	8	Tank Installed Date	11/14/2017	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5783	Spill Test Date		Piping Installed Date	09/01/2017	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/10/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	04/10/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/23/2025	Line Tightness Test Date	11/14/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Beaverhead County in the City of Wisdom

Location: PINTLER STATION  
318 MT Hwy 43  
Wisdom, MT 59761-0175 Beaverhead

System Facility ID:01-02173

Facility Code: 17490  
Last Inspected On: 06/08/2023  
Operating Permit Renewal Date: 07/30/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Chancy Campbell (406) 689-3239 ccfordman74@gmail.com

Operator Contact: Sheila Campbell scrappinann7874@gmail.com

Owner/Operator: Chancy Campbell (406) 689-3239 ccfordman74@gmail.com

Sheila Campbell, UST Class A Operator  
Sheila Campbell, UST Class B Operator  
scrappinann7874@gmail.com  
scrappinann7874@gmail.com

Tank Code	01	Tank Age	40	Tank Installed Date	03/10/1985	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3323	Spill Test Date	07/20/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/08/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	05/03/2005	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/20/2023			ATG Type					
Tank Code	02	Tank Age	40	Tank Installed Date	03/10/1985	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3324	Spill Test Date	06/08/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/08/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date	05/03/2005	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/20/2023			ATG Type					

Facility Summary in Beaverhead County in the City of Wise River

Location: WISE RIVER MERCANTILE  
65221 Hwy 43  
Wise River, MT 59762 Beaverhead

System Facility ID:01-02080

Facility Code: 17487  
Last Inspected On: 04/24/2025  
Operating Permit Renewal Date: 10/13/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: JimCon Inc (406) 832-3271

Operator Contact: Connie Holland (406) 832-3271 Connieholland49@gmail.com

Owner/Operator: JimCon Inc (406) 832-3271

Connie Holland, UST Class A Operator  
Connie Holland, UST Class B Operator  
Laura Delaney, UST Class B Global Operator  
Connieholland49@gmail.com  
Connieholland49@gmail.com

Tank Code	03	Tank Age	27	Tank Installed Date	06/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1224	Spill Test Date	05/21/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	04/24/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/09/2021			ATG Type	Gilbarco/EMC Basic				