

## Facility Summary in Carter County in the City of Alzada

**Location:** B AND J CONVENIENCE STORE  
US Hwy 212 & Hwy 326  
Alzada, MT 59311 Carter

System Facility ID: 56-13910

Facility Code: 30580  
Last Inspected On: 09/16/2024  
Operating Permit Renewal Date: 09/17/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** B AND JS CONVENIENCE STORE LLC

(406) 853-4312

tlhendrickson.tt@gmail.com

**Operator Contact:** Traci Tarno; William Walker

(406) 828-4400

pook5451@yahoo.com; tlhendrickson.tt@gmail.com

**Owner/Operator:** B AND JS CONVENIENCE STORE LLC

(406) 853-4312

tlhendrickson.tt@gmail.com

Janet Walker, UST Class B Global Operator

pook5451@yahoo.com

Traci Tarno, UST Class A Operator

tlhendrickson.tt@gmail.com

Traci Tarno, UST Class B Operator

tlhendrickson.tt@gmail.com

William Walker, UST Class A Operator

pook5451@yahoo.com

<b>Tank Code</b>	01	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	12/01/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3564	<b>Spill Test Date</b>	10/12/2022	<b>Piping Installed Date</b>	10/06/2022	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	12/01/2022	<b>Line Tightness Test Date</b>	12/01/2022	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/12/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	02	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	12/01/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3565	<b>Spill Test Date</b>	10/12/2022	<b>Piping Installed Date</b>	10/06/2022	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	4000	<b>ATG Test Date</b>	12/01/2022	<b>Line Tightness Test Date</b>	12/01/2022	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	10/12/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS			
<b>Tank Code</b>	03	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	09/15/2022	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>
<b>Tag Number</b>	6114	<b>Spill Test Date</b>	10/12/2022	<b>Piping Installed Date</b>	10/06/2022	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>
<b>Capacity</b>	10000	<b>ATG Test Date</b>	12/01/2022	<b>Line Tightness Test Date</b>	12/01/2022	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>
		<b>Overfill Test Date</b>	12/12/2022			<b>ATG Type</b>				

## Facility Summary in Carter County in the City of Ekalaka

**Location:** FRUIT SERVICE AND REPAIR INC SR 323  
31 MT Hwy 323  
Ekalaka, MT 59324 Carter

System Facility ID:06-03234

Facility Code: 18280  
Last Inspected On: 03/04/2024  
Operating Permit Renewal Date: 08/17/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Fruit Service and Repair Inc

(406) 775-6541

**Operator Contact:** Troy Fruit

fruit@midrivers.com

**Owner/Operator:** Fruit Service and Repair Inc

(406) 775-6541

Mikel Fruit, UST Class B Operator

Troy Fruit, UST Class A Operator

mjfruit@midrivers.com

fruit@midrivers.com

<b>Tank Code</b>	07	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	04/01/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1135	<b>Spill Test Date</b>	03/04/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	4590	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/04/2024			<b>ATG Type</b>					
<b>Tank Code</b>	08	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	04/01/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1136	<b>Spill Test Date</b>	03/04/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2365	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/04/2024			<b>ATG Type</b>					
<b>Tank Code</b>	09	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	04/01/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1137	<b>Spill Test Date</b>	03/04/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLL D Test Date		Tank/Piping CP Test Date	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	9627	ATG Test Date		Line Tightness Test Date	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/04/2024		ATG Type					
Tank Code	06	Tank Age	28	Tank Installed Date	04/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types
Tag Number	3617	Spill Test Date	03/04/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLL D Test Date		Tank/Piping CP Test Date	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	5565	ATG Test Date		Line Tightness Test Date	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/04/2024		ATG Type					

## Facility Summary in Carter County in the City of Ekalaka

**Location:** T AND M STANDARD LLC  
40 Main St  
Ekalaka, MT 59324 Carter

System Facility ID:06-01681

Facility Code: 18270  
Last Inspected On: 03/04/2024  
Operating Permit Renewal Date: 08/17/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** T & M STANDARD LLC;Troy Fruit

(406) 775-6541

fruit@midrivers.com

**Operator Contact:** Troy Fruit

fruit@midrivers.com

**Owner/Operator:** T & M STANDARD LLC

(406) 775-6541

fruit@midrivers.com

**Owner/Operator:** Troy Fruit

(406) 775-6541

fruit@midrivers.com

Mikel Fruit, UST Class B Operator

Troy Fruit, UST Class A Operator

mjfruit@midrivers.com

fruit@midrivers.com

<b>Tank Code</b>	03	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	04/26/1990	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1132	<b>Spill Test Date</b>	03/04/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/04/2024			<b>ATG Type</b>					
<b>Tank Code</b>	04	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	04/26/1990	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1133	<b>Spill Test Date</b>	03/04/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/04/2024			<b>ATG Type</b>					
<b>Tank Code</b>	05	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	04/26/1990	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve

Tag Number	1134	Spill Test Date	03/04/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/04/2024			ATG Type					