

Facility Summary in Cascade County in the City of Belt

Location: BELT PUBLIC SCHOOLS DIST 29 UST
 1 Church St
 Belt, MT 59412 Cascade

System Facility ID:07-04613

Facility Code: 18537
Last Inspected On: 05/05/2023
Operating Permit Renewal Date: 08/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 29 Belt (406) 277-3351

Operator Contact: Joe Gaylord

Owner/Operator: School Dist 29 Belt (406) 277-3351

April Wells, UST Class B Operator
 Joe Gaylord, UST Class A Operator

awells@beltschool.com

Tank Code	S3	Tank Age	37	Tank Installed Date	10/01/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	422	Spill Test Date	04/21/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/27/2023	Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	05/05/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/21/2022			ATG Type	Incon/TS-1000				

Facility Summary in Cascade County in the City of Belt

Location: BELT VALLEY GROCERY
65 Castner St
Belt, MT 59412 Cascade

System Facility ID:07-13653

Facility Code: 19054
Last Inspected On: 08/26/2022
Operating Permit Renewal Date: 11/29/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Harry L Throckmorton

(406) 277-3523

Operator Contact: Reed Throckmorton

rthrock77@gmail.com

Owner/Operator: Harry L Throckmorton

(406) 277-3523

Reed Throckmorton, UST Class A Operator

rthrock77@gmail.com

Reed Throckmorton, UST Class B Operator

rthrock77@gmail.com

Tank Code	01	Tank Age	30	Tank Installed Date	10/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4468	Spill Test Date	10/04/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/26/2022	Sump Tightness Test Date	10/14/2019	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/26/2022	Line Tightness Test Date	08/26/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/04/2022			ATG Type	OPW/EECO 1500				
Tank Code	02	Tank Age	30	Tank Installed Date	10/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4469	Spill Test Date	10/04/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/26/2022	Sump Tightness Test Date	10/14/2019	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/26/2022	Line Tightness Test Date	08/26/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/04/2022			ATG Type	OPW/EECO 1500				

Facility Summary in Cascade County in the City of Belt

Location: MALMSTROM AFB A 10
US Hwy 87/89
Belt, MT 59412 Cascade

System Facility ID:07-08984

Facility Code: 18745
Last Inspected On: 06/13/2024
Operating Permit Renewal Date: 10/07/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	05/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	115	Spill Test Date	05/08/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/08/2023	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/08/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/08/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Belt

Location: MALMSTROM AFB A 11
 US Hwy 87/89
 Belt, MT 59412 Cascade

System Facility ID:07-08985

Facility Code: 18746
Last Inspected On: 06/13/2024
Operating Permit Renewal Date: 09/25/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	05/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	116	Spill Test Date	07/17/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/19/2020	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/03/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/03/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Belt

Location: MALMSTROM AFB A 2
 US Hwy 87/89
 Belt, MT 59412 Cascade

System Facility ID:07-08976

Facility Code: 18739
Last Inspected On: 06/13/2024
Operating Permit Renewal Date: 10/07/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;James Leigland;William Smith (406) 731-6239;(406) 731-7128;(406) 899-3635 candace.ellsworth@us.af.mil;jim@leigland.com;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

- Candace Ellsworth, UST Class A Operator candace.ellsworth@us.af.mil
- Candace Ellsworth, UST Class B Global Operator candace.ellsworth@us.af.mil
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- James Leigland, UST Class A Operator jim@leigland.com
- James Leigland, UST Class B Operator jim@leigland.com
- Mark Johnson, UST Class B Global Operator
- William Smith, UST Class A Operator william.smith@us.af.mil
- William Smith, UST Class B Global Operator william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	06/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	109	Spill Test Date	07/17/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/19/2020	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/05/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/05/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Black Eagle

Location: BLACK EAGLE SERVICE CENTER
1501 N River Rd
Black Eagle, MT 59414 Cascade

System Facility ID:07-01190

Facility Code: 18380
Last Inspected On: 08/17/2022
Operating Permit Renewal Date: 01/28/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Northwestern Energy Butte

(406) 655-2521

beth.stimatz@northwestern.com

Operator Contact: Brian Ranf

brian.ranf@northwestern.com

Owner/Operator: Northwestern Energy Butte

(406) 655-2521

beth.stimatz@northwestern.com

Brian Ranf, UST Class A Operator
Colton Coffing, UST Class B Operator
Colton Coffing, UST Class B Operator

brian.ranf@northwestern.com
colton.coffing@northwestern.com
colton.coffing@northwestern.com

Tank Code	04	Tank Age	34	Tank Installed Date	12/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1676	Spill Test Date	08/19/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2086	ATG Test Date	05/16/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/29/2021			ATG Type	Veeder Root/TLS-300				
Tank Code	05	Tank Age	34	Tank Installed Date	12/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1677	Spill Test Date	08/19/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2086	ATG Test Date	05/16/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/29/2021			ATG Type	Veeder Root/TLS-300				

Facility Summary in Cascade County in the City of Black Eagle

Location: MOUNTAIN VIEW CO-OP
1105 Smelter Ave NE
Black Eagle, MT 59414 Cascade

System Facility ID:60-15312

Facility Code: 31011
Last Inspected On: 03/17/2025
Operating Permit Renewal Date: 03/19/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

Operator Contact: David Douglas ddouglas@mountainviewcoop.com

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

David Douglas, UST Class A Operator ddouglas@mountainviewcoop.com
David Douglas, UST Class B Global Operator ddouglas@mountainviewcoop.com
Foster Sensibaugh, UST Class B Global Operator fsensibaugh@mountainviewcoop.com

Tank Code	01	Tank Age	8	Tank Installed Date	10/10/2017	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5773	Spill Test Date	03/13/2025	Piping Installed Date	09/17/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	03/13/2025	Line Tightness Test Date	06/01/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/13/2025			ATG Type	Incon/TS-5000 EVO				
Tank Code	02	Tank Age	8	Tank Installed Date	10/10/2017	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5774	Spill Test Date	03/13/2025	Piping Installed Date	09/17/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	03/13/2025	Line Tightness Test Date	06/01/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

		Overfill Test Date	03/13/2025			ATG Type	Incon/TS-5000 EVO				
Tank Code	03	Tank Age	8	Tank Installed Date	10/10/2017	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5775	Spill Test Date	03/13/2025	Piping Installed Date	09/17/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/13/2025	Line Tightness Test Date	06/01/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/13/2025			ATG Type	Incon/TS-5000 EVO				
Tank Code	04	Tank Age	8	Tank Installed Date	10/10/2017	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	5776	Spill Test Date		Piping Installed Date	09/17/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date	12/05/2017	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD Line Tightness Testing;Not Listed	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring;Not Listed	Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-550 EVO				
Tank Code	05	Tank Age	8	Tank Installed Date	10/10/2017	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5777	Spill Test Date	03/13/2025	Piping Installed Date	09/17/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/13/2025	Line Tightness Test Date	06/01/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/13/2025			ATG Type	Incon/TS-5000 EVO				

Tank Code	06	Tank Age	8	Tank Installed Date	10/10/2017	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5778	Spill Test Date	03/13/2025	Piping Installed Date	09/17/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/13/2025	Line Tightness Test Date	06/01/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/13/2025			ATG Type	Incon/TS-5000 EVO				
Tank Code	07	Tank Age	8	Tank Installed Date	10/10/2017	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5779	Spill Test Date	03/13/2025	Piping Installed Date	09/17/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/13/2025	Line Tightness Test Date	06/01/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/13/2025			ATG Type	Incon/TS-5000 EVO				

Facility Summary in Cascade County in the City of Black Eagle

Location: MOUNTAIN VIEW COOP BLACK EAGLE
2200 Old Havre Hwy
Black Eagle, MT 59414-1043 Cascade

System Facility ID:07-04232

Facility Code: 18509
Last Inspected On: 06/22/2022
Operating Permit Renewal Date: 08/04/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

Operator Contact: William (Ralph) Floyd;Mountain View Coop Great Falls (406) 401-6025 rfloyd@mvc.ag

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com
William (Ralph) Floyd, UST Class A Operator rfloyd@mvc.ag
William (Ralph) Floyd, UST Class B Operator rfloyd@mvc.ag

Tank Code	07	Tank Age	28	Tank Installed Date	12/02/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	1015	Spill Test Date	03/08/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type		CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	Yes
Capacity	12000	ATG Test Date	01/09/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/09/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	28	Tank Installed Date	12/02/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	1016	Spill Test Date	03/08/2023	Piping Installed Date	09/19/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type		CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	01/09/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/09/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	28	Tank Installed Date	12/02/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	High Level Alarm

Tag Number	1017	Spill Test Date	03/08/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type		CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	Yes
Capacity	4000	ATG Test Date	01/07/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/07/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	28	Tank Installed Date	12/02/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	1018	Spill Test Date	03/08/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type		CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	01/07/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/07/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	11	Tank Age	28	Tank Installed Date	12/02/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	1019	Spill Test Date	03/08/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	01/07/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/07/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	12	Tank Age	28	Tank Installed Date	12/02/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	1020	Spill Test Date	03/08/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	01/07/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	01/07/2025			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
--	--	---------------------------	------------	--	--	-----------------	--	--	--	--	--

Facility Summary in Cascade County in the City of Black Eagle

Location: MOUNTAIN VIEW COOP GREAT FALLS
1000 Smelter Ave NE
Black Eagle, MT 59414-1018 Cascade

System Facility ID:07-00004

Facility Code: 18320
Last Inspected On: 05/06/2019
Operating Permit Renewal Date: 08/04/2022

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

Operator Contact: David Douglas;Kila Moore (406) 453-5900 ddouglas@mountainviewcoop.com;safety@mountainviewcoop.com

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

David Douglas, UST Class A Operator ddouglas@mountainviewcoop.com
 David Douglas, UST Class B Global Operator ddouglas@mountainviewcoop.com
 Gary Boysun, UST Class B Operator ddouglas@mountainviewcoop.com
 Gary Boysun, UST Class B Operator
 Jasmin Nguyen, UST Class B Global Operator jasmin_nguyen5@hotmail.com
 Jasmin Nguyen, UST Class B Global Operator jasmin_nguyen5@hotmail.com
 Jasmin Nguyen, UST Class B Operator jasmin_nguyen5@hotmail.com
 Jasmin Nguyen, UST Class B Operator jasmin_nguyen5@hotmail.com
 John Malley, UST Class B Operator jmalley@mountainviewcoop.com
 John Malley, UST Class B Operator jmalley@mountainviewcoop.com
 Kila Moore, UST Class A Operator safety@mountainviewcoop.com
 Kila Moore, UST Class A Operator safety@mountainviewcoop.com

Tank Code	07	Tank Age	30	Tank Installed Date	11/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1009	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	24000	ATG Test Date		Line Tightness Test Date	04/28/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	30	Tank Installed Date	11/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	1010	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	24000	ATG Test Date		Line Tightness Test Date	04/30/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	30	Tank Installed Date	11/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1011	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	24000	ATG Test Date		Line Tightness Test Date	04/29/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	30	Tank Installed Date	11/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1012	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	24000	ATG Test Date		Line Tightness Test Date	05/03/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	11	Tank Age	30	Tank Installed Date	11/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1013	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	24000	ATG Test Date		Line Tightness Test Date	04/29/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	12	Tank Age	30	Tank Installed Date	11/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1014	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing	Vapor Recovery	No
Capacity	24000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	14	Tank Age	3	Tank Installed Date	07/23/2022	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6115	Spill Test Date	08/10/2022	Piping Installed Date	07/23/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	02/23/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	08/07/2022			ATG Type					
Tank Code	15	Tank Age	3	Tank Installed Date	07/23/2022	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6116	Spill Test Date	08/10/2022	Piping Installed Date	07/23/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	02/23/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/07/2022			ATG Type					
Tank Code	16	Tank Age	3	Tank Installed Date	07/23/2022	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6117	Spill Test Date	08/10/2022	Piping Installed Date	07/23/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	02/23/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/07/2022			ATG Type					
Tank Code	17	Tank Age	3	Tank Installed Date	07/23/2022	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6118	Spill Test Date	08/10/2022	Piping Installed Date	07/23/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	02/23/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/07/2022			ATG Type					
Tank Code	18	Tank Age	3	Tank Installed Date	07/23/2022	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6119	Spill Test Date	08/10/2022	Piping Installed Date	07/23/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	02/23/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/07/2022			ATG Type					
Tank Code	19	Tank Age	3	Tank Installed Date	07/23/2022	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6120	Spill Test Date	08/10/2022	Piping Installed Date	07/23/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	02/23/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/07/2022			ATG Type					

Facility Summary in Cascade County in the City of Cascade

Location: 468 MARKET
130 1st St N
Cascade, MT 59421-8353 Cascade

System Facility ID:07-04148

Facility Code: 18505
Last Inspected On: 07/13/2022
Operating Permit Renewal Date: 09/20/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: DTK Foods Inc

tomsmarket2252@yahoo.com

Operator Contact: Irene Strandell;Wesley Seabolt

(406) 468-2252;(406) 781-2060

strandellhouse@prodigy.net;wes492@yahoo.com

Owner/Operator: DTK Foods Inc

tomsmarket2252@yahoo.com

Irene Strandell, UST Class A Operator
Irene Strandell, UST Class B Operator
Wesley Seabolt, UST Class A Operator
Wesley Seabolt, UST Class B Global Operator

strandellhouse@prodigy.net
strandellhouse@prodigy.net
wes492@yahoo.com
wes492@yahoo.com

Tank Code	04	Tank Age	28	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1490	Spill Test Date	01/12/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/11/2022	Sump Tightness Test Date	08/08/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	01/13/2022	Line Tightness Test Date	01/11/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/12/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	28	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1491	Spill Test Date	01/12/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/11/2022	Sump Tightness Test Date	08/08/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	01/13/2022	Line Tightness Test Date	01/11/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/12/2022			ATG Type	Gilbarco/EMC Basic				

Tank Code	06	Tank Age	28	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1492	Spill Test Date	01/12/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/11/2022	Sump Tightness Test Date	08/08/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	01/13/2022	Line Tightness Test Date	01/11/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/12/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	07	Tank Age	28	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1493	Spill Test Date	01/12/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/11/2022	Sump Tightness Test Date	08/08/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	01/13/2022	Line Tightness Test Date	01/11/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/12/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	08	Tank Age	28	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1494	Spill Test Date	01/12/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/11/2022	Sump Tightness Test Date	08/08/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	01/13/2022	Line Tightness Test Date	01/11/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/12/2022			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB G 3
I-15
Cascade, MT 59421 Cascade

System Facility ID:07-09043

Facility Code: 18748
Last Inspected On: 04/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	36	Tank Installed Date	06/21/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	118	Spill Test Date	04/18/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/18/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/18/2024	Line Tightness Test Date	06/25/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/18/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB G 4
I-15
Cascade, MT 59421 Cascade

System Facility ID:07-09044

Facility Code: 18749
Last Inspected On: 04/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	05/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	119	Spill Test Date	04/18/2024	Piping Installed Date	11/16/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/18/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/18/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/18/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB G 5
I-15
Cascade, MT 59421 Cascade

System Facility ID:07-09045

Facility Code: 18750
Last Inspected On: 04/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	05/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	120	Spill Test Date	04/18/2024	Piping Installed Date	05/17/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/18/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/18/2024	Line Tightness Test Date	05/17/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/18/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB I 1
Hwy 330
Cascade, MT 59421 Cascade

System Facility ID:07-09063

Facility Code: 18755
Last Inspected On: 05/16/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	01	Tank Age	63	Tank Installed Date	06/02/1962	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	125	Spill Test Date	05/16/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/16/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/13/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/24/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB I 3
Road 330
Cascade, MT 59421 Cascade

System Facility ID:07-09065

Facility Code: 18757
Last Inspected On: 04/19/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	34	Tank Installed Date	10/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	127	Spill Test Date	04/19/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/19/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/19/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/19/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB I 4
Road 330
Cascade, MT 59421 Cascade

System Facility ID:07-09066

Facility Code: 18758
Last Inspected On: 04/19/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	34	Tank Installed Date	10/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	128	Spill Test Date	04/19/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/19/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/19/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/19/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB I 5
Road 330
Cascade, MT 59421 Cascade

System Facility ID:07-09067

Facility Code: 18759
Last Inspected On: 04/19/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	34	Tank Installed Date	10/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	129	Spill Test Date	04/19/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/19/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/19/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/19/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Cascade

Location: MALMSTROM AFB I 6
I-15
Cascade, MT 59421 Cascade

System Facility ID:07-09068

Facility Code: 18760
Last Inspected On: 04/19/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	05/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	130	Spill Test Date	04/19/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/19/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/19/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/19/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Cascade

Location: OLSON FARM
430 Klock Rd
Cascade, MT 59421-8014 Cascade

System Facility ID:07-04520

Facility Code: 18528
Last Inspected On: 01/09/2024
Operating Permit Renewal Date: 03/07/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cory Olson;Orin Olson (406) 468-2457 cory_olson@hotmail.com

Operator Contact: Cory Olson cory_olson@hotmail.com

Owner/Operator: Cory Olson cory_olson@hotmail.com
Owner/Operator: Orin Olson cory_olson@hotmail.com
 Cory Olson, UST Class A Operator cory_olson@hotmail.com
 Cory Olson, UST Class B Operator cory_olson@hotmail.com

Tank Code	02	Tank Age	26	Tank Installed Date	04/01/1999	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4053	Spill Test Date	05/10/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/09/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/09/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	01/09/2024	Line Tightness Test Date	01/09/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Fort Shaw

Location: MALMSTROM AFB H 6
MT Hwy 21
Fort Shaw, MT 59443 Cascade

System Facility ID:07-09057

Facility Code: 18753
Last Inspected On: 04/04/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	34	Tank Installed Date	09/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	123	Spill Test Date	04/04/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/04/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/04/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/04/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Fort Shaw

Location: MALMSTROM AFB I 8
 MT Hwy 21
 Fort Shaw, MT 59443 Cascade

System Facility ID:07-10840

Facility Code: 18856
Last Inspected On: 04/22/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Kyle Topp, UST Class B Operator	kyle.topp@us.af.mil
William Hoffmeister, UST Class B Operator	william.hoffmeister@malmstrom.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	01	Tank Age	36	Tank Installed Date	09/26/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	152	Spill Test Date	04/22/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/22/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/22/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Fort Shaw

Location: MALMSTROM AFB I 9
MT Hwy 21
Fort Shaw, MT 59443 Cascade

System Facility ID:07-09071

Facility Code: 18763
Last Inspected On: 04/22/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	34	Tank Installed Date	10/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	132	Spill Test Date	04/22/2024	Piping Installed Date	11/16/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/22/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/22/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Great Falls

Location: 15TH STREET SERVICE
1501 10th Ave S
Great Falls, MT 59405-2625 Cascade

System Facility ID:07-07573

Facility Code: 18672
Last Inspected On: 12/04/2023
Operating Permit Renewal Date: 03/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Gary Maki (406) 453-2070 dgmaki@msn.com

Operator Contact: Gary Maki (406) 453-2070 dgmaki@msn.com

Owner/Operator: Gary Maki (406) 453-2070 dgmaki@msn.com

Gary Maki, UST Class A Operator dgmaki@msn.com
Gary Maki, UST Class B Operator dgmaki@msn.com

Tank Code	05	Tank Age	36	Tank Installed Date	01/16/1989	Tank Material	Steel Clad	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3824	Spill Test Date	12/04/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/04/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	12/04/2023	Line Tightness Test Date	12/13/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/04/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	36	Tank Installed Date	01/16/1989	Tank Material	Steel Clad	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3825	Spill Test Date	12/04/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/04/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	12/04/2023	Line Tightness Test Date	12/13/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/04/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	07	Tank Age	36	Tank Installed Date	01/16/1989	Tank Material	Steel Clad	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3826	Spill Test Date	12/04/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/04/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	12/04/2023	Line Tightness Test Date	12/13/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/04/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	36	Tank Installed Date	01/16/1989	Tank Material	Steel Clad	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3827	Spill Test Date	12/04/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/04/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	12/04/2023	Line Tightness Test Date	12/13/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/04/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: BENEFIS HEALTH CARE EAST CAMPUS UST
1101 26th St S
Great Falls, MT 59405-5161 Cascade

System Facility ID:07-06552

Facility Code: 18631
Last Inspected On: 09/06/2023
Operating Permit Renewal Date: 09/08/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Benefis Healthcare (406) 455-5135

Operator Contact: Scott Kincaid;Todd Boucher;Benefis Healthcare (406) 590-0869;(406) 455-5135;(406) 868-9675 scottkincaid@benefis.org;toddboucher@benefis.org

Owner/Operator: Benefis Healthcare (406) 455-5135

Ben Konesky, UST Class B Operator
Scott Kincaid, UST Class A Operator
Scott Kincaid, UST Class B Operator
Todd Boucher, UST Class A Operator

benkonesky@benefis.org
scottkincaid@benefis.org
scottkincaid@benefis.org
toddboucher@benefis.org

Tank Code	S3	Tank Age	24	Tank Installed Date	03/30/2001	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4584	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/15/2023	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/12/2005	Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	04	Tank Age	17	Tank Installed Date	08/22/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5190	Spill Test Date	11/15/2023	Piping Installed Date	06/17/2008	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2500	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Cascade County in the City of Great Falls

Location: BENEFIS HEALTH CARE WEST CAMPUS
500 15th Ave S
Great Falls, MT 59405-4304 Cascade

System Facility ID:07-03298

Facility Code: 18480
Last Inspected On: 10/02/2023
Operating Permit Renewal Date: 09/08/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Benefis Healthcare (406) 455-5135

Operator Contact: Scott Kincaid;Todd Boucher;Benefis Healthcare (406) 590-0869;(406) 455-5135;(406) 868-9675 scottkincaid@benefis.org;toddboucher@benefis.org

Owner/Operator: Benefis Healthcare (406) 455-5135

Ben Konesky, UST Class B Operator
Scott Kincaid, UST Class A Operator
Scott Kincaid, UST Class B Operator
Todd Boucher, UST Class A Operator

benkonesky@benefis.org
scottkincaid@benefis.org
scottkincaid@benefis.org
toddboucher@benefis.org

Tank Code	05	Tank Age	29	Tank Installed Date	07/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3401	Spill Test Date	09/05/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/08/2023	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	09/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/05/2023			ATG Type	EMCO Electronics/EECO 1500				
Tank Code	06	Tank Age	26	Tank Installed Date	05/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4003	Spill Test Date	09/05/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/08/2023	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	09/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	09/05/2023			ATG Type	EMCO Electronics/EECO 1500				
--	--	---------------------------	------------	--	--	-----------------	----------------------------------	--	--	--	--

Facility Summary in Cascade County in the City of Great Falls

Location: BEST OIL DISTRIBUTING INC
5401 River Dr N
Great Falls, MT 59405-1081 Cascade

System Facility ID:07-05852

Facility Code: 18596
Last Inspected On: 03/19/2024
Operating Permit Renewal Date: 04/11/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Best Oil Distributing Inc (406) 453-0971

Operator Contact: Seth Schimerowski (406) 564-8856 Schimer66@hotmail.com

Owner/Operator: Best Oil Distributing Inc (406) 453-0971

Seth Schimerowski, UST Class A Operator
Seth Schimerowski, UST Class B Operator

Schimer66@hotmail.com
Schimer66@hotmail.com

Tank Code	01	Tank Age	44	Tank Installed Date	05/01/1981	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1254	Spill Test Date	10/16/2023	Piping Installed Date	07/27/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/22/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	02/22/2024	Line Tightness Test Date	06/04/2003	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	44	Tank Installed Date	05/01/1981	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1255	Spill Test Date	10/09/2023	Piping Installed Date	07/27/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/22/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	02/22/2024	Line Tightness Test Date	05/03/2002	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	44	Tank Installed Date	05/01/1981	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	1256	Spill Test Date	10/09/2023	Piping Installed Date	07/27/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/22/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	02/22/2024	Line Tightness Test Date	07/01/2001	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	44	Tank Installed Date	05/01/1981	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1257	Spill Test Date	10/09/2023	Piping Installed Date	07/27/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/22/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	02/22/2024	Line Tightness Test Date	05/29/2003	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	27	Tank Installed Date	04/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1258	Spill Test Date	10/16/2023	Piping Installed Date	07/27/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/22/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	02/22/2024	Line Tightness Test Date	07/20/2001	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	27	Tank Installed Date	04/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1259	Spill Test Date	10/09/2023	Piping Installed Date	07/27/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/22/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	02/22/2024	Line Tightness Test Date	09/24/2004	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	02/22/2024			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
--	--	---------------------------	------------	--	--	-----------------	--	--	--	--	--

Facility Summary in Cascade County in the City of Great Falls

Location: BIG O TIRES
1101 7th St S
Great Falls, MT 59405 Cascade

System Facility ID:60-15329

Facility Code: 31025
Last Inspected On:
Operating Permit Renewal Date: 05/07/2019

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Gus & Jacks Tire

(406) 799-5650

bigotires26702@bresnan.net

Operator Contact:

Tank Code	01	Tank Age	0	Tank Installed Date		Tank Material	Bare Steel	Piping Material	No Piping	Overfill Types	
Tag Number	5895	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Not Listed	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Not Listed	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Cascade County in the City of Great Falls

Location: BISON FORD
500 10th Ave S
Great Falls, MT 59405-4047 Cascade

System Facility ID:07-00077

Facility Code: 18324
Last Inspected On: 06/26/2024
Operating Permit Renewal Date: 11/05/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bison Motors (406) 727-2552

Operator Contact: Ryan Christensen

rchristensen@bisonford.com

Owner/Operator: Bison Motors

(406) 727-2552

Ryan Christensen, UST Class A Operator
Ryan Christensen, UST Class A Operator
Ryan Christensen, UST Class B Operator
Ryan Christensen, UST Class B Operator

rchristensen@bisonford.com
rchristensen@bisonford.com
rchristensen@bisonford.com
rchristensen@bisonford.com

Tank Code	07	Tank Age	37	Tank Installed Date	08/05/1988	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	3908	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/10/2013	Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	3000	ATG Test Date	06/26/2024	Line Tightness Test Date	06/26/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	OPW/Other				
Tank Code	08	Tank Age	37	Tank Installed Date	08/05/1988	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4303	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/10/2013	Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	1000	ATG Test Date	06/26/2024	Line Tightness Test Date	06/26/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Cascade County in the City of Great Falls

Location: BRAKE TIME 253722
1225 Central Ave W
Great Falls, MT 59404-3968 Cascade

System Facility ID:07-05777

Facility Code: 18586
Last Inspected On: 01/07/2025
Operating Permit Renewal Date: 03/08/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Central Ave Great falls LLC	(832) 539-8190	licensing@btcmstores.com
Operator Contact: Chelsey Partridge;Holly Seymour;John Sumowski;Randal Liebnow;Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo	(267) 799-8664;(406) 750-8563;(513) 964-1568	eglegaldept@eg-america.com;hseymour86@hotmail.com;randy.liebnow@loafnjug.com
Owner/Operator: Central Ave Great falls LLC	(832) 539-8190	licensing@btcmstores.com

- Chelsey Partridge, UST Class A Operator
- Chelsey Partridge, UST Class A Operator
- Chelsey Partridge, UST Class B Operator
- Chelsey Partridge, UST Class B Operator
- Hiede Richardson, UST Class B Global Operator
- Holly Seymour, UST Class A Operator
- Holly Seymour, UST Class A Operator
- Holly Seymour, UST Class B Global Operator
- Holly Seymour, UST Class B Global Operator
- John Sumowski, UST Class A Operator
- John Sumowski, UST Class A Operator
- Randal Liebnow, UST Class A Operator
- Randal Liebnow, UST Class B Global Operator
- Scott Huether, UST Class B Global Operator
- Stevie Ulstad, UST Class B Operator
- Theodore Bezel, UST Class A Operator
- Theodore Bezel, UST Class A Operator
- Theodore Bezel, UST Class B Global Operator
- Theodore Bezel, UST Class B Global Operator
- Theodore Bezel, UST Class B Operator
- Theodore Bezel, UST Class B Operator
- Toni Mullen, UST Class B Global Operator

- hiede.richardson@yahoo.com
- hseymour86@hotmail.com
- hseymour86@hotmail.com
- hseymour86@hotmail.com
- hseymour86@hotmail.com
- randy.liebnow@loafnjug.com
- randy.liebnow@loafnjug.com
- mtscorpion1963@msn.com
- crazyfroggie2003@yahoo.com
- eglegaldept@eg-america.com
- eglegaldept@eg-america.com

Tank Code	01	Tank Age	53	Tank Installed Date	04/26/1972	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1630	Spill Test Date	08/28/2024	Piping Installed Date	10/19/2016	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/28/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	08/28/2024	Tank/Piping CP Test Date	04/21/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/28/2024	Line Tightness Test Date	01/07/2011	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/21/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	53	Tank Installed Date	04/26/1972	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1631	Spill Test Date	08/28/2024	Piping Installed Date	10/19/2016	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/28/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/28/2024	Tank/Piping CP Test Date	04/21/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/28/2024	Line Tightness Test Date	01/07/2011	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/21/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	53	Tank Installed Date	04/26/1972	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1632	Spill Test Date	08/28/2024	Piping Installed Date	10/19/2016	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/28/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/28/2024	Tank/Piping CP Test Date	04/21/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/28/2024	Line Tightness Test Date	01/07/2011	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/21/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: BRAKE TIME 253719
3726 2nd Ave N
Great Falls, MT 59401-3010 Cascade

System Facility ID:07-03920

Facility Code: 18493
Last Inspected On: 01/07/2025
Operating Permit Renewal Date: 03/06/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 2ND AVE GREAT FALLS MT LLC;Muhammad Akhtar (406) 727-7917;(832) 539-8190 akhatarmuhammad65@gmail.com

Operator Contact: Muhammad Akhtar;Nicole Younger-Taylor;Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo (307) 871-7831;(513) 964-1568;(832) 539-8190 akhatarmuhammad65@gmail.com;eglegaldept@eg-america.com;nicole.younger-taylor@loafnjug.com

Owner/Operator: 2ND AVE GREAT FALLS MT LLC (406) 727-7917 akhatarmuhammad65@gmail.com

Owner/Operator: Muhammad Akhtar (406) 727-7917 akhatarmuhammad65@gmail.com

- Muhammad Akhtar, UST Class A Operator akhatarmuhammad65@gmail.com
- Nicole Younger-Taylor, UST Class A Operator nicole.younger-taylor@loafnjug.com
- Nicole Younger-Taylor, UST Class A Operator nicole.younger-taylor@loafnjug.com
- Theodore Bezel, UST Class A Operator eglegaldept@eg-america.com
- Theodore Bezel, UST Class A Operator eglegaldept@eg-america.com
- Theodore Bezel, UST Class B Global Operator
- Theodore Bezel, UST Class B Global Operator
- Theodore Bezel, UST Class B Operator
- Theodore Bezel, UST Class B Operator
- Timothy Osterman, UST Class B Global Operator bigoproductions@msn.com
- Timothy Osterman, UST Class B Operator bigoproductions@msn.com

Tank Code	01	Tank Age	41	Tank Installed Date	03/24/1984	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1624	Spill Test Date	12/19/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/05/2024	Tank/Piping CP Test Date	03/19/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/25/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/19/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	41	Tank Installed Date	03/24/1984	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	1625	Spill Test Date	12/19/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	08/05/2024	Tank/Piping CP Test Date	03/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/25/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/19/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	41	Tank Installed Date	03/24/1984	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1626	Spill Test Date	12/19/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/05/2024	Tank/Piping CP Test Date	03/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/25/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/19/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: BRAKE TIME 253720
900 1st Ave N
Great Falls, MT 59401 Cascade

System Facility ID:07-05775

Facility Code: 18584
Last Inspected On: 02/10/2025
Operating Permit Renewal Date: 03/06/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 1ST AVE GREAT FALLS MT LLC (832) 539-8190

Operator Contact: John Sumowski;Nicole Younger-Taylor;Omair Bashir;Randal Liebnow;Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo (307) 871-7831;(513) 964-1568;(832) 539-8190

eglegaldept@eg-america.com;licensing@btcmstores.com;nicole.younger-taylor@loafnjug.com;randy.liebnow@loafnjug.com

Owner/Operator: 1ST AVE GREAT FALLS MT LLC (832) 539-8190

- John Sumowski, UST Class A Operator
- John Sumowski, UST Class A Operator
- Natalee Crumley, UST Class B Operator
- Natalee Crumley, UST Class B Operator
- Nicole Younger-Taylor, UST Class A Operator
- Nicole Younger-Taylor, UST Class A Operator
- Omair Bashir, UST Class A Operator
- Randal Liebnow, UST Class A Operator
- Scott Huether, UST Class B Global Operator
- Stevie Ulstad, UST Class B Global Operator
- Stevie Ulstad, UST Class B Operator
- Theodore Bezel, UST Class A Operator
- Theodore Bezel, UST Class A Operator
- Theodore Bezel, UST Class B Global Operator
- Theodore Bezel, UST Class B Global Operator
- Theodore Bezel, UST Class B Operator
- Theodore Bezel, UST Class B Operator
- Timothy Osterman, UST Class B Global Operator

- nicole.younger-taylor@loafnjug.com
- nicole.younger-taylor@loafnjug.com
- licensing@btcmstores.com
- randy.liebnow@loafnjug.com
- mtscorpion1963@msn.com
- crazyfroggie2003@yahoo.com
- crazyfroggie2003@yahoo.com
- eglegaldept@eg-america.com
- eglegaldept@eg-america.com
- bigoproductions@msn.com

Tank Code	01	Tank Age	42	Tank Installed Date	04/27/1983	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1627	Spill Test Date	09/29/2024	Piping Installed Date	10/23/1998	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	08/05/2024	Tank/Piping CP Test Date	01/27/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	8000	ATG Test Date	09/29/2024	Line Tightness Test Date	08/01/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/29/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	42	Tank Installed Date	04/27/1983	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1628	Spill Test Date	09/29/2024	Piping Installed Date	10/23/1998	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/05/2024	Tank/Piping CP Test Date	01/27/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/27/2025	Line Tightness Test Date	08/01/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Manual Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/27/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	42	Tank Installed Date	04/27/1983	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1629	Spill Test Date	01/27/2025	Piping Installed Date	10/23/1998	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/05/2024	Tank/Piping CP Test Date	01/27/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/27/2024	Line Tightness Test Date	08/01/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.1	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/29/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: BRAKE TIME 253721
601 Smelter Ave NW
Great Falls, MT 59404 Cascade

System Facility ID:07-05776

Facility Code: 18585
Last Inspected On: 02/10/2025
Operating Permit Renewal Date: 03/06/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: SMELTER AVE GREAT FALL MT LLC (406) 727-8578 usmanbashir1254@gmail.com

Operator Contact: Nicole Younger-Taylor;Randal Liebnow;Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo (307) 871-7831;(513) 964-1568 elegaldept@eg-america.com;nicole.younger-taylor@loafnjug.com;randy.liebnow@loafnjug.com

Owner/Operator: SMELTER AVE GREAT FALL MT LLC (406) 727-8578 usmanbashir1254@gmail.com

Hiede Richardson, UST Class B Global Operator	hiede.richardson@yahoo.com
Hiede Richardson, UST Class B Global Operator	hiede.richardson@yahoo.com
Jennifer Coleman, UST Class B Global Operator	
Jennifer Coleman, UST Class B Global Operator	
Nicole Younger-Taylor, UST Class A Operator	nicole.younger-taylor@loafnjug.com
Nicole Younger-Taylor, UST Class A Operator	nicole.younger-taylor@loafnjug.com
Nicole Younger-Taylor, UST Class A Operator	nicole.younger-taylor@loafnjug.com
Randal Liebnow, UST Class A Operator	randy.liebnow@loafnjug.com
Randal Liebnow, UST Class A Operator	randy.liebnow@loafnjug.com
Randal Liebnow, UST Class B Global Operator	randy.liebnow@loafnjug.com
Randal Liebnow, UST Class B Global Operator	randy.liebnow@loafnjug.com
Scott Huether, UST Class B Global Operator	mtscorpion1963@msn.com
Scott Huether, UST Class B Global Operator	mtscorpion1963@msn.com
Stevie Ulstad, UST Class B Operator	crazyfroggie2003@yahoo.com
Stevie Ulstad, UST Class B Operator	crazyfroggie2003@yahoo.com
Theodore Bezel, UST Class A Operator	elegaldept@eg-america.com
Theodore Bezel, UST Class A Operator	elegaldept@eg-america.com
Theodore Bezel, UST Class A Operator	elegaldept@eg-america.com
Theodore Bezel, UST Class B Global Operator	
Theodore Bezel, UST Class B Global Operator	
Theodore Bezel, UST Class B Global Operator	
Theodore Bezel, UST Class B Operator	
Theodore Bezel, UST Class B Operator	
Theodore Bezel, UST Class B Operator	
Timothy Osterman, UST Class B Global Operator	bigoproductions@msn.com
Timothy Osterman, UST Class B Global Operator	bigoproductions@msn.com

Timothy Osterman, UST Class B Operator
 Timothy Osterman, UST Class B Operator
 Toni Mullen, UST Class B Global Operator
 Toni Mullen, UST Class B Global Operator

bigoproductions@msn.com
 bigoproductions@msn.com

Tank Code	01	Tank Age	42	Tank Installed Date	04/27/1983	Tank Material	STI - P3	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3638	Spill Test Date	09/29/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/29/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	08/05/2024	Tank/Piping CP Test Date	01/25/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring; ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/05/2024	Line Tightness Test Date	11/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/27/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	42	Tank Installed Date	04/27/1983	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3639	Spill Test Date	01/27/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/05/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	09/29/2024	Tank/Piping CP Test Date	01/25/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring; ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/05/2024	Line Tightness Test Date	11/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/27/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	42	Tank Installed Date	04/27/1983	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3640	Spill Test Date	09/29/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/05/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/05/2024	Tank/Piping CP Test Date	01/25/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring; ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	01/18/2023	Line Tightness Test Date	11/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	01/27/2025			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
--	--	---------------------------	------------	--	--	-----------------	--	--	--	--	--

Facility Summary in Cascade County in the City of Great Falls

Location: CARLS AUTOCARE INC
2300 10th Ave S
Great Falls, MT 59405-2968 Cascade

System Facility ID:07-00621

Facility Code: 18355
Last Inspected On: 12/05/2023
Operating Permit Renewal Date: 03/18/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Carl Halcro (406) 761-1342 carlsautocare@yahoo.com

Operator Contact: Carl Halcro (406) 761-1342 carlsautocare@yahoo.com

Owner/Operator: Carl Halcro (406) 761-1342 carlsautocare@yahoo.com

Carl Halcro, UST Class A Operator
Paul Halcro, UST Class B Operator

carlsautocare@yahoo.com
phalcro1@yahoo.com

Tank Code	05	Tank Age	39	Tank Installed Date	01/27/1986	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1264	Spill Test Date	12/05/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/28/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/04/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/12/2024	Line Tightness Test Date	03/03/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/04/2023			ATG Type	Veeder Root/TLS-4I, B, C				
Tank Code	06	Tank Age	39	Tank Installed Date	01/27/1986	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1265	Spill Test Date	12/05/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/28/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/04/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/12/2024	Line Tightness Test Date	03/03/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/04/2023			ATG Type	Veeder Root/TLS-4I, B, C				
Tank Code	07	Tank Age	39	Tank Installed Date	01/27/1986	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1266	Spill Test Date	12/05/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date	03/28/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/04/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/12/2024	Line Tightness Test Date	03/03/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/04/2023			ATG Type	Veeder Root/TLS-4I, B, C				

Facility Summary in Cascade County in the City of Great Falls

Location: CASCADE COUNTY SHERIFFS OFFICE
3800 Ulm N Frontage Rd
Great Falls, MT 59404-5574 Cascade

System Facility ID:07-13772

Facility Code: 19066
Last Inspected On: 08/31/2020
Operating Permit Renewal Date: 09/12/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:

Operator Contact:

Tank Code	02	Tank Age	28	Tank Installed Date	05/06/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4489	Spill Test Date	08/04/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	08/05/2021	Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date	11/10/2020	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	1200	ATG Test Date	08/04/2021	Line Tightness Test Date	11/20/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S1	Tank Age	28	Tank Installed Date	05/06/1997	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	537	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	09/02/2014	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Cascade County in the City of Great Falls

Location: CIRCLE K STORE 2746010
1601 Fox Farm Rd
Great Falls, MT 59404-3338 Cascade

System Facility ID:07-09914

Facility Code: 18792
Last Inspected On: 08/11/2023
Operating Permit Renewal Date: 12/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC

(602) 728-8000

NT-ESS@Circlek.com

Operator Contact: Veronica Rivera

ESS-WestCoast@circlek.com

Owner/Operator: Rocky Mountain Oil LLC

(602) 728-8000

NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator
Brad Lee, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Veronica Rivera, UST Class A Operator
Veronica Rivera, UST Class A Operator

brad.lee@holidaycompanies.com
brad.lee@holidaycompanies.com
jeff.reed@holidaycompanies.com
jeff.reed@holidaycompanies.com
ESS-WestCoast@circlek.com
ESS-WestCoast@circlek.com

Tank Code	06	Tank Age	27	Tank Installed Date	06/16/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	1697	Spill Test Date	06/26/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/26/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	06/26/2023	Line Tightness Test Date	04/11/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/26/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	27	Tank Installed Date	06/16/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	1698	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/30/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes

Capacity	8000	ATG Test Date		Line Tightness Test Date	03/10/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	27	Tank Installed Date	06/16/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	1699	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/30/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	08/15/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: CIRCLE K STORE 2746059
601 Northwest Bypass
Great Falls, MT 59404-2480 Cascade

System Facility ID:07-13729

Facility Code: 19059
Last Inspected On: 06/26/2023
Operating Permit Renewal Date: 12/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC

(602) 728-8000

NT-ESS@Circlek.com

Operator Contact: Veronica Rivera

ESS-WestCoast@circlek.com

Owner/Operator: Rocky Mountain Oil LLC

(602) 728-8000

NT-ESS@Circlek.com

Brad Lee, UST Class B Operator
Brad Lee, UST Class B Operator
Brad Lee, UST Class B Operator
Jeff Reed, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Veronica Rivera, UST Class A Operator
Veronica Rivera, UST Class A Operator
Veronica Rivera, UST Class A Operator

brad.lee@holidaycompanies.com
brad.lee@holidaycompanies.com
brad.lee@holidaycompanies.com
jeff.reed@holidaycompanies.com
jeff.reed@holidaycompanies.com
jeff.reed@holidaycompanies.com
ESS-WestCoast@circlek.com
ESS-WestCoast@circlek.com
ESS-WestCoast@circlek.com

Tank Code	01	Tank Age	29	Tank Installed Date	07/17/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3359	Spill Test Date	06/26/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/14/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/26/2023	Tank/Piping CP Test Date	11/06/2012	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	06/26/2023	Line Tightness Test Date	05/25/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/26/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	29	Tank Installed Date	07/17/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3360	Spill Test Date	06/26/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/14/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/26/2023	Tank/Piping CP Test Date	11/06/2012	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	06/26/2023	Line Tightness Test Date	05/21/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/26/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	29	Tank Installed Date	07/17/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3361	Spill Test Date	06/26/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/14/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/26/2023	Tank/Piping CP Test Date	11/06/2012	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/26/2023	Line Tightness Test Date	05/17/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/26/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: CIRCLE K STORE 2746273
1020 15th St. N
Great Falls, MT 59401-1238 Cascade

System Facility ID:07-08069

Facility Code: 18687
Last Inspected On: 08/11/2023
Operating Permit Renewal Date: 12/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC

(602) 728-8000

NT-ESS@Circlek.com

Operator Contact: Veronica Rivera

ESS-WestCoast@circlek.com

Owner/Operator: Rocky Mountain Oil LLC

(602) 728-8000

NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator
Brad Lee, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Veronica Rivera, UST Class A Operator
Veronica Rivera, UST Class A Operator

brad.lee@holidaycompanies.com
brad.lee@holidaycompanies.com
jeff.reed@holidaycompanies.com
jeff.reed@holidaycompanies.com
ESS-WestCoast@circlek.com
ESS-WestCoast@circlek.com

Tank Code	04	Tank Age	27	Tank Installed Date	05/15/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2995	Spill Test Date	07/21/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/30/2020	Tank/Piping CP Test Date	09/16/2009	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	03/08/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/21/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	27	Tank Installed Date	05/15/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2996	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/30/2020	Tank/Piping CP Test Date	09/16/2009	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	8000	ATG Test Date		Line Tightness Test Date	03/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	27	Tank Installed Date	05/15/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2997	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/30/2020	Tank/Piping CP Test Date	09/16/2009	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	03/06/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: CIRCLE K STORE 2746724
2260 10th Ave S
Great Falls, MT 59405 Cascade

System Facility ID:56-13975

Facility Code: 30637
Last Inspected On: 11/06/2024
Operating Permit Renewal Date: 03/30/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Operator Contact: Veronica Rivera ESS-WestCoast@circlek.com

Owner/Operator: Rocky Mountain Oil LLC (602) 728-8000 NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Veronica Rivera, UST Class A Operator

brad.lee@holidaycompanies.com
jeff.reed@holidaycompanies.com
ESS-WestCoast@circlek.com

Tank Code	01	Tank Age	25	Tank Installed Date	10/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4219	Spill Test Date	11/06/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/25/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	06/25/2024	Line Tightness Test Date	07/20/2018	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/25/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	25	Tank Installed Date	10/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4220	Spill Test Date	11/06/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/25/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/25/2024	Line Tightness Test Date	07/20/2018	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	06/25/2024			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
--	--	---------------------------	------------	--	--	-----------------	--	--	--	--	--

Facility Summary in Cascade County in the City of Great Falls

Location: CIRCLE K STORE 2746730
1428 3rd St NW
Great Falls, MT 59404-1928 Cascade

System Facility ID:56-13970

Facility Code: 30632
Last Inspected On: 11/06/2024
Operating Permit Renewal Date: 03/30/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC

(602) 728-8000

NT-ESS@Circlek.com

Operator Contact: Veronica Rivera

ESS-WestCoast@circlek.com

Owner/Operator: Rocky Mountain Oil LLC

(602) 728-8000

NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator
Brad Lee, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Veronica Rivera, UST Class A Operator
Veronica Rivera, UST Class A Operator

brad.lee@holidaycompanies.com
brad.lee@holidaycompanies.com
jeff.reed@holidaycompanies.com
jeff.reed@holidaycompanies.com
ESS-WestCoast@circlek.com
ESS-WestCoast@circlek.com

Tank Code	01	Tank Age	25	Tank Installed Date	07/07/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4203	Spill Test Date	11/06/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/25/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	06/25/2024	Line Tightness Test Date	10/29/2018	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/25/2024			ATG Type	Veeder Root/TLS-450				
Tank Code	02	Tank Age	25	Tank Installed Date	07/07/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4204	Spill Test Date	11/06/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/25/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	10000	ATG Test Date	06/25/2024	Line Tightness Test Date	06/14/2018	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/25/2024			ATG Type	Veeder Root/TLS-450				

Facility Summary in Cascade County in the City of Great Falls

Location: CITY MOTOR CO INC
3900 10th Ave S
Great Falls, MT 59405-3648 Cascade

System Facility ID:07-05853

Facility Code: 18597
Last Inspected On: 03/27/2023
Operating Permit Renewal Date: 07/01/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City Motors (406) 761-4900 johnk@citymotor.com

Operator Contact: Kelly Qunell kellyq@citymotor.com

Owner/Operator: City Motors (406) 761-4900 johnk@citymotor.com

Kelly Qunell, UST Class A Operator
Kelly Qunell, UST Class B Operator

kellyq@citymotor.com
kellyq@citymotor.com

Tank Code	06	Tank Age	36	Tank Installed Date	09/01/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2365	Spill Test Date	03/27/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/04/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	3000	ATG Test Date	03/27/2023	Line Tightness Test Date	02/04/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/27/2023			ATG Type	EMCO Electronics/EECO 1500				
Tank Code	07	Tank Age	36	Tank Installed Date	09/01/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2366	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	3000	ATG Test Date	03/27/2023	Line Tightness Test Date	03/27/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	EMCO Electronics/EECO 1500				

Facility Summary in Cascade County in the City of Great Falls

Location: CITY SHOP COMPLEX
1025 25th Ave NE
Great Falls, MT 59404-1602 Cascade

System Facility ID:07-05558

Facility Code: 18570
Last Inspected On: 01/02/2019
Operating Permit Renewal Date: 01/10/2022

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City of Great Falls (406) 771-1258

Operator Contact: Dale Calvert;Doug Alm (406) 771-1401 dalm@greatfallsmt.net;dcalvert@greatfallsmt.net

Dale Calvert, UST Class A Operator
Dale Calvert, UST Class B Global Operator
Doug Alm, UST Class A Operator
Doug Alm, UST Class B Global Operator
Doug Alm, UST Class B Operator

dcalvert@greatfallsmt.net
dcalvert@greatfallsmt.net
dalm@greatfallsmt.net
dalm@greatfallsmt.net
dalm@greatfallsmt.net

Tank Code	06	Tank Age	35	Tank Installed Date	02/23/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	640	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	12/17/2018	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/16/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	12/17/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-450				
Tank Code	07	Tank Age	35	Tank Installed Date	02/23/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	641	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	12/17/2018	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/16/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	12/17/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-450				

Tank Code	08	Tank Age	35	Tank Installed Date	02/23/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	642	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/16/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	03/18/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-450				

Facility Summary in Cascade County in the City of Great Falls

Location: FEDERAL AVIATION ADMIN AIRWAY TERMINAL
2830 Airport Ave A
Great Falls, MT 59404-5544 Cascade

System Facility ID:07-02558

Facility Code: 18445
Last Inspected On: 03/11/2021
Operating Permit Renewal Date: 03/26/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Federal Aviation Admin Great Falls (406) 788-8041 joe.konesky@faa.gov

Operator Contact: Joe Konesky joe.konesky@faa.gov

Joe Konesky, UST Class A Operator

joe.konesky@faa.gov

Joe Konesky, UST Class B Global Operator

joe.konesky@faa.gov

Tank Code	S2	Tank Age	28	Tank Installed Date	07/31/1997	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	1048	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	05/07/2012	Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	1500	ATG Test Date		Line Tightness Test Date	03/11/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Cascade County in the City of Great Falls

Location: FEDERAL AVIATION ADMIN ARSR 4
 Bootlegger Rdg
 Great Falls, MT 59401 Cascade

System Facility ID:07-13710

Facility Code: 19056
Last Inspected On: 02/06/2024
Operating Permit Renewal Date: 06/15/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Federal Aviation Admin Great Falls (406) 788-8041 joe.konesky@faa.gov

Operator Contact: Joe Konesky joe.konesky@faa.gov

Owner/Operator: Federal Aviation Admin Great Falls (406) 788-8041 joe.konesky@faa.gov

Joe Konesky, UST Class A Operator joe.konesky@faa.gov
 Joe Konesky, UST Class B Global Operator joe.konesky@faa.gov

Tank Code	S1	Tank Age	29	Tank Installed Date	04/01/1996	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4564	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/24/2021	Catastrophic L.D Type 3.0	Auto Dialer;Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Cascade County in the City of Great Falls

Location: GAS N SHOP
101 Smelter Ave NE
Great Falls, MT 59404 Cascade

System Facility ID:07-05851

Facility Code: 18595
Last Inspected On: 12/04/2023
Operating Permit Renewal Date: 03/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Muhar LLC;Sandeep Muhar (406) 624-6912;(406) 750-0708 gasnshop133@gmail.com

Operator Contact: Gurinderbir Muhar;Harinder Singh (406) 868-2062;(408) 660-9884 gasnshop133@gmail.com;inder4030@yahoo.com

Owner/Operator: Muhar LLC (406) 624-6912

Owner/Operator: Sandeep Muhar (406) 624-6912

Frank Kruse, UST Class B Operator	wfkruse79@yahoo.com
Gurinderbir Muhar, UST Class A Operator	gasnshop133@gmail.com
Gurinderbir Muhar, UST Class B Global Operator	gasnshop133@gmail.com
Harinder Singh, UST Class A Operator	inder4030@yahoo.com
Sandeep Muhar, UST Class B Global Operator	gasnshop133@gmail.com

Tank Code	06	Tank Age	37	Tank Installed Date	07/21/1988	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1251	Spill Test Date	11/15/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/15/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	11/15/2023	Line Tightness Test Date	02/28/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/15/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	37	Tank Installed Date	07/21/1988	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1252	Spill Test Date	11/15/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	11/15/2023	Line Tightness Test Date	09/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	11/15/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	37	Tank Installed Date	07/21/1988	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1253	Spill Test Date	11/15/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/15/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	11/15/2023	Line Tightness Test Date	09/28/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/15/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: GAS N SHOP 2
101 Truman Ave
Great Falls, MT 59404-6210 Cascade

System Facility ID:07-00097

Facility Code: 18333
Last Inspected On: 12/04/2023
Operating Permit Renewal Date: 03/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sandeep Muhar (406) 750-0708 gasnshop133@gmail.com

Operator Contact: Gurinderbir Muhar;Perry Joyce (408) 660-9884 gasnshop133@gmail.com

Owner/Operator: Sandeep Muhar (406) 750-0708 gasnshop133@gmail.com

- | | |
|--|--------------------------|
| Gurinderbir Muhar, UST Class A Operator | gasnshop133@gmail.com |
| Gurinderbir Muhar, UST Class B Global Operator | gasnshop133@gmail.com |
| Kevin Joyce, UST Class B Global Operator | kjshamrock13@gmail.com |
| Kevin Joyce, UST Class B Global Operator | kjshamrock13@gmail.com |
| Maureen Pettis, UST Class B Operator | joycostroes.sp@gmail.com |
| Maureen Pettis, UST Class B Operator | joycostroes.sp@gmail.com |
| Perry Joyce, UST Class A Operator | |
| Perry Joyce, UST Class A Operator | |
| Sandeep Muhar, UST Class B Global Operator | gasnshop133@gmail.com |

Tank Code	04	Tank Age	35	Tank Installed Date	03/04/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3545	Spill Test Date	11/15/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/15/2023	Tank/Piping CP Test Date	02/14/2005	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/15/2023	Line Tightness Test Date	12/09/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/15/2023			ATG Type	Veeder Root/TLS-450				
Tank Code	05	Tank Age	35	Tank Installed Date	03/04/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3546	Spill Test Date	11/15/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel	PLLD Test Date	11/15/2023	Tank/Piping CP Test Date	02/14/2005	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/15/2023	Line Tightness Test Date	12/09/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/15/2023			ATG Type	Veeder Root/TLS-450				
Tank Code	06	Tank Age	35	Tank Installed Date	03/04/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3547	Spill Test Date	11/15/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/15/2023	Tank/Piping CP Test Date	02/14/2005	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/15/2023	Line Tightness Test Date	12/09/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/15/2023			ATG Type	Veeder Root/TLS-450				

Facility Summary in Cascade County in the City of Great Falls

Location: GENERAL DISTRIBUTING CO INC
430 17th Ave NE
Great Falls, MT 59404-1936 Cascade

System Facility ID:07-00081

Facility Code: 18325
Last Inspected On: 04/07/2023
Operating Permit Renewal Date: 04/05/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: General Distributing Co Inc (406) 454-1351

Operator Contact: Sean Kelley (406) 454-1351 skelley@gendco.com

Owner/Operator: General Distributing Co Inc (406) 454-1351

Sean Kelley, UST Class A Operator

skelley@gendco.com

Sean Kelley, UST Class B Global Operator

skelley@gendco.com

Tank Code	01	Tank Age	47	Tank Installed Date	02/14/1978	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1206	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	47	Tank Installed Date	02/14/1978	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1207	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	03	Tank Age	47	Tank Installed Date	02/14/1978	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	1208	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Cascade County in the City of Great Falls

Location: GREAT FALLS FIRE STATION 1 GREAT FALLS
105 9th St S
Great Falls, MT 59401-3715 Cascade

System Facility ID:07-00680

Facility Code: 18359
Last Inspected On: 01/02/2019
Operating Permit Renewal Date: 01/10/2022

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City of Great Falls (406) 771-1258

Operator Contact: Dale Calvert;Doug Alm (406) 771-1401 dalm@greatfallsmt.net;dcalvert@greatfallsmt.net

Dale Calvert, UST Class A Operator	dcalvert@greatfallsmt.net
Dale Calvert, UST Class A Operator	dcalvert@greatfallsmt.net
Doug Alm, UST Class A Operator	dalm@greatfallsmt.net
Doug Alm, UST Class A Operator	dalm@greatfallsmt.net
Doug Alm, UST Class B Global Operator	dalm@greatfallsmt.net
Doug Alm, UST Class B Global Operator	dalm@greatfallsmt.net
Doug Alm, UST Class B Operator	dalm@greatfallsmt.net
Doug Alm, UST Class B Operator	dalm@greatfallsmt.net

Tank Code	03	Tank Age	34	Tank Installed Date	04/22/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	636	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	12/26/2018	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/16/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4172	ATG Test Date		Line Tightness Test Date	12/26/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-450				
Tank Code	04	Tank Age	34	Tank Installed Date	04/22/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	637	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	12/26/2018	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/16/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No

Capacity	4172	ATG Test Date		Line Tightness Test Date	12/26/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-450				
Tank Code	05	Tank Age	34	Tank Installed Date	04/22/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	638	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	12/26/2018	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/16/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	12/26/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-450				

Facility Summary in Cascade County in the City of Great Falls

Location: GREAT FALLS INTERNATIONAL AIRPORT FUEL FARM 1
1931 Airport Ct
Great Falls, MT 59404-5599 Cascade

System Facility ID:07-10676

Facility Code: 18828
Last Inspected On: 09/01/2022
Operating Permit Renewal Date: 10/11/2019

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Great Falls International Airport

Operator Contact: Mike Cunningham;Rod Hall

(406) 727-3404;(406) 781-7242

mikefra1@msn.com;rod@flygtf.com

Owner/Operator: Great Falls International Airport

Mike Cunningham, UST Class A Operator
Mike Cunningham, UST Class B Operator
Rod Hall, UST Class A Operator
Rod Hall, UST Class A Operator
Rod Hall, UST Class B Operator
Rod Hall, UST Class B Operator

mikefra1@msn.com
mikefra1@msn.com
rod@flygtf.com
rod@flygtf.com
rod@flygtf.com
rod@flygtf.com

Tank Code	01	Tank Age	51	Tank Installed Date	04/03/1974	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	3740	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/04/2014	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	30550	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	51	Tank Installed Date	04/03/1974	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	3741	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Impressed Current
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date	09/04/2014	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Deferred	Vapor Recovery	No

Capacity	30550	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	51	Tank Installed Date	04/03/1974	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	3742	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/04/2014	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	30550	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	51	Tank Installed Date	04/03/1974	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	3743	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	09/04/2014	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	30550	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	51	Tank Installed Date	04/03/1974	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	3744	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	09/04/2014	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	30550	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	51	Tank Installed Date	04/03/1974	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	3745	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	09/04/2014	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	51	Tank Installed Date	04/03/1974	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	3746	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	09/04/2014	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	38000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	51	Tank Installed Date	04/03/1974	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	3747	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	09/04/2014	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	50000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	09	Tank Age	51	Tank Installed Date	04/03/1974	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	3748	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	09/04/2014	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	50000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	30	Tank Installed Date	11/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	3749	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	08/31/2006	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	20000	ATG Test Date	09/01/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	11	Tank Age	30	Tank Installed Date	11/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	3750	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Non-corrodible
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date	08/31/2006	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	20000	ATG Test Date	09/01/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: GREAT FALLS SINCLAIR
620 57th St S
Great Falls, MT 59405-3940 Cascade

System Facility ID:07-02087

Facility Code: 18422
Last Inspected On: 03/31/2021
Operating Permit Renewal Date: 03/31/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Set Five LLC Harlowtown (406) 632-4630 jwoodsoil@aol.com

Operator Contact: Derek Richardson;Greg Haines;William Raaen (406) 231-9465;(406) 590-2667;(406) 750-0090 setfive@hotmail.com;setfive01@outlook.com;wtraaen@gmail.com

Derek Richardson, UST Class A Operator	setfive@hotmail.com
Derek Richardson, UST Class A Operator	setfive@hotmail.com
Derek Richardson, UST Class B Global Operator	setfive@hotmail.com
Derek Richardson, UST Class B Global Operator	setfive@hotmail.com
Greg Haines, UST Class A Operator	setfive01@outlook.com
Greg Haines, UST Class A Operator	setfive01@outlook.com
Greg Haines, UST Class B Operator	setfive01@outlook.com
Greg Haines, UST Class B Operator	setfive01@outlook.com
Mitzi McIntosh, UST Class B Operator	jstbnmitzi@yahoo.com
Mitzi McIntosh, UST Class B Operator	jstbnmitzi@yahoo.com
NayOmie Bean, UST Class B Global Operator	
NayOmie Bean, UST Class B Global Operator	
Norm Jensen, UST Class B Operator	maui2@bresnan.net
Norm Jensen, UST Class B Operator	maui2@bresnan.net
Roberta Gresham, UST Class B Operator	
Roberta Gresham, UST Class B Operator	
Thomas Ohagan, UST Class B Global Operator	ohagan@rock.com
Thomas Ohagan, UST Class B Global Operator	ohagan@rock.com
William Raaen, UST Class A Operator	wtraaen@gmail.com
William Raaen, UST Class A Operator	wtraaen@gmail.com
William Raaen, UST Class B Operator	wtraaen@gmail.com
William Raaen, UST Class B Operator	wtraaen@gmail.com

Tank Code	01	Tank Age	47	Tank Installed Date	04/04/1978	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1933	Spill Test Date	09/09/2020	Piping Installed Date	04/29/1998	Tank Construction		Piping Construction	None	AST	No

Tank Status	Permanently Out of Use	MLLD Test Date	09/09/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/09/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	16000	ATG Test Date		Line Tightness Test Date	09/09/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/09/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	47	Tank Installed Date	04/04/1978	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1934	Spill Test Date	09/09/2020	Piping Installed Date	04/29/1998	Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	09/09/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/09/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	16000	ATG Test Date		Line Tightness Test Date	09/09/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/09/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	47	Tank Installed Date	04/04/1978	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1935	Spill Test Date	09/09/2020	Piping Installed Date	04/29/1998	Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	09/09/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/09/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	24000	ATG Test Date		Line Tightness Test Date	09/09/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/09/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: GREAT FALLS TRANSIT DISTRICT
3905 N Star Blvd
Great Falls, MT 59405-1036 Cascade

System Facility ID:07-05346

Facility Code: 18560
Last Inspected On: 02/26/2025
Operating Permit Renewal Date: 06/02/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Great Falls Transit District

Operator Contact: Nadine Hanning

(406) 727-0382

nhanning@gftransit.com

Owner/Operator: Great Falls Transit District

Chad Peterson, UST Class B Global Operator
Chad Peterson, UST Class B Global Operator
Nadine Hanning, UST Class A Operator

cpeterson@gftransit.com
cpeterson@gftransit.com
nhanning@gftransit.com

Tank Code	01	Tank Age	40	Tank Installed Date	05/06/1985	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1233	Spill Test Date	02/09/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12380	ATG Test Date	02/09/2022	Line Tightness Test Date	02/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	40	Tank Installed Date	05/06/1985	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	1234	Spill Test Date	02/09/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	1000	ATG Test Date	02/09/2022	Line Tightness Test Date	02/09/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: H AND R #1
3200 10th Ave S
Great Falls, MT 59405 Cascade

System Facility ID:07-00092

Facility Code: 18331
Last Inspected On: 09/19/2022
Operating Permit Renewal Date: 11/20/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Singh Inc (406) 868-2062 inder4030@yahoo.com

Operator Contact: Harinder Singh;Rajinder Singh (406) 761-4791;(406) 868-2062 hrkinc101@gmail.com;inder4030@yahoo.com

Owner/Operator: Singh Inc (406) 868-2062 inder4030@yahoo.com

Frank Kruse, UST Class B Global Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Global Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Operator	wfkruse79@yahoo.com
Harinder Singh, UST Class A Operator	inder4030@yahoo.com
Rajinder Singh, UST Class A Operator	hrkinc101@gmail.com

Tank Code	01	Tank Age	55	Tank Installed Date	12/31/1970	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3839	Spill Test Date	08/17/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/02/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/13/2023	Tank/Piping CP Test Date	09/07/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.1	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/03/2023	Line Tightness Test Date	11/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/19/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	55	Tank Installed Date	12/31/1970	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3840	Spill Test Date	08/17/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/02/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	09/06/2018	Tank/Piping CP Test Date	09/07/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.1	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	10000	ATG Test Date	03/03/2023	Line Tightness Test Date	11/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/19/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	55	Tank Installed Date	12/31/1970	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4440	Spill Test Date	08/17/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/02/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	03/13/2023	Tank/Piping CP Test Date	09/07/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.1	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/03/2023	Line Tightness Test Date	11/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/19/2022			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Cascade County in the City of Great Falls

Location: H AND R #2
1300 12th Ave S
Great Falls, MT 59405 Cascade

System Facility ID:07-00082

Facility Code: 18326
Last Inspected On: 02/21/2024
Operating Permit Renewal Date: 05/29/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Singh Inc (406) 868-2062 nder4030@yahoo.com

Operator Contact: Harinder Singh;Rajinder Singh (406) 761-4791;(406) 868-2062 hrkinc101@gmail.com;inder4030@yahoo.com

Owner/Operator: Singh Inc (406) 868-2062 nder4030@yahoo.com

Frank Kruse, UST Class B Global Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Global Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Operator	wfkruse79@yahoo.com
Frank Kruse, UST Class B Operator	wfkruse79@yahoo.com
Harinder Singh, UST Class A Operator	inder4030@yahoo.com
Rajinder Singh, UST Class A Operator	hrkinc101@gmail.com

Tank Code	03	Tank Age	14	Tank Installed Date	11/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5339	Spill Test Date	04/13/2024	Piping Installed Date	10/11/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/21/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/06/2023	Tank/Piping CP Test Date	09/13/2010	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/06/2023	Line Tightness Test Date	12/07/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	06/14/2024			ATG Type	Gilbarco/TLS-350;Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	14	Tank Installed Date	11/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5340	Spill Test Date	02/21/2024	Piping Installed Date	10/11/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/21/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/06/2023	Tank/Piping CP Test Date	09/13/2010	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	10000	ATG Test Date	09/06/2023	Line Tightness Test Date	12/05/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	06/14/2024			ATG Type	Gilbarco/TLS-350;Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Great Falls

Location: H AND R #4
5600 3rd Ave S
Great Falls, MT 59405-1726 Cascade

System Facility ID:07-00090

Facility Code: 18330
Last Inspected On: 02/28/2025
Operating Permit Renewal Date: 03/14/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: H and R Inc

inder4030@yahoo.com

Operator Contact: Harinder Singh;Rajinder Singh

(406) 761-4791;(406) 868-2062

hrkinc101@gmail.com;inder4030@yahoo.com

Owner/Operator: H and R Inc

inder4030@yahoo.com

Frank Kruse, UST Class B Global Operator
Frank Kruse, UST Class B Global Operator
Frank Kruse, UST Class B Operator
Frank Kruse, UST Class B Operator
Harinder Singh, UST Class A Operator
Rajinder Singh, UST Class A Operator

wfkruse79@yahoo.com
wfkruse79@yahoo.com
wfkruse79@yahoo.com
wfkruse79@yahoo.com
inder4030@yahoo.com
hrkinc101@gmail.com

Tank Code	03	Tank Age	55	Tank Installed Date	12/31/1970	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3838	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/04/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	01	Tank Age	55	Tank Installed Date	12/31/1970	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4439	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/04/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	4	Tank Installed Date	08/03/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6074	Spill Test Date	02/25/2025	Piping Installed Date	08/03/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/25/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date	11/16/2021	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	02/25/2025	Line Tightness Test Date	11/24/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	02/25/2025			ATG Type					
Tank Code	05	Tank Age	4	Tank Installed Date	08/03/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6075	Spill Test Date	02/25/2025	Piping Installed Date	08/03/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/25/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date	11/16/2021	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	02/25/2025	Line Tightness Test Date	11/24/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	02/25/2025			ATG Type					
Tank Code	06	Tank Age	4	Tank Installed Date	08/03/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6076	Spill Test Date	02/25/2025	Piping Installed Date	08/03/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/25/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date	11/16/2021	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	5000	ATG Test Date	02/25/2025	Line Tightness Test Date	11/24/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	02/25/2025			ATG Type					

Facility Summary in Cascade County in the City of Great Falls

Location: H AND R 3 ON YOUR WAY
1608 Fox Farm Rd
Great Falls, MT 59404-3339 Cascade

System Facility ID:07-04945

Facility Code: 18550
Last Inspected On: 05/24/2023
Operating Permit Renewal Date: 09/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: H and R Inc

inder4030@yahoo.com

Operator Contact:

Owner/Operator: H and R Inc

inder4030@yahoo.com

Tank Code	02	Tank Age	57	Tank Installed Date	01/01/1968	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1972	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	07/17/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	57	Tank Installed Date	01/01/1968	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1973	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	07/17/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	28	Tank Installed Date	11/03/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	1974	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	07/17/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	28	Tank Installed Date	11/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1975	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	02/21/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: HALL TRANSIT CO
2620 Upper River Rd
Great Falls, MT 59405-7231 Cascade

System Facility ID:07-06402

Facility Code: 18626
Last Inspected On: 09/01/2023
Operating Permit Renewal Date: 08/06/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hall Transit Co;Lynn Hall;Hall Transit Co (406) 945-1363 lynn.l.hall66@gmail.com

Operator Contact: Lynn Hall;Hall Transit Co (406) 945-1363 lynn.l.hall66@gmail.com

Owner/Operator: Hall Transit Co

Owner/Operator: Lynn Hall,Hall Transit Co

Lynn Hall, UST Class A Operator
Lynn Hall, UST Class B Operator

lynn.l.hall66@gmail.com
lynn.l.hall66@gmail.com

Tank Code	02	Tank Age	34	Tank Installed Date	11/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1268	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	07/14/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/14/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	07/14/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: KEITHS COUNTRY STORE
1621 10th Ave S
Great Falls, MT 59405 Cascade

System Facility ID:07-01418

Facility Code: 18394
Last Inspected On: 09/25/2023
Operating Permit Renewal Date: 12/02/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Keiths Country Store (406) 727-7114

Operator Contact: David Keith (406) 862-2578 terionline@123mail.org

Owner/Operator: Keiths Country Store (406) 727-7114

Anna Dion, UST Class B Operator
Anna Dion, UST Class B Operator
David Keith, UST Class A Operator
David Keith, UST Class A Operator
David Keith, UST Class B Operator
David Keith, UST Class B Operator

amvd86@hotmail.com
amvd86@hotmail.com
terionline@123mail.org
terionline@123mail.org
terionline@123mail.org
terionline@123mail.org

Tank Code	03	Tank Age	26	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3988	Spill Test Date	06/07/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/07/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.1;ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/07/2021	Line Tightness Test Date	05/05/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/07/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	26	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3989	Spill Test Date	06/07/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/07/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.1;ELLD 0.2	Vapor Recovery	No

Capacity	8000	ATG Test Date	06/07/2021	Line Tightness Test Date	04/27/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/07/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	26	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3990	Spill Test Date	06/07/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/07/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.1;ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/07/2021	Line Tightness Test Date	05/21/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/07/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: KERNAGHANS SERVICE 8TH AVE N
1507 8th Ave N
Great Falls, MT 59401-1749 Cascade

System Facility ID:07-04508

Facility Code: 18524
Last Inspected On: 09/06/2022
Operating Permit Renewal Date: 10/26/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: James Kernaghan

(406) 452-9505

Operator Contact: Jeff Rearden

Owner/Operator: James Kernaghan

(406) 452-9505

Callie Rearden, UST Class B Operator
Jeff Rearden, UST Class A Operator

piknpump@gmail.com

Tank Code	03	Tank Age	36	Tank Installed Date	07/28/1989	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1473	Spill Test Date	11/01/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/29/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	7500	ATG Test Date	01/29/2024	Line Tightness Test Date	04/17/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/29/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	36	Tank Installed Date	07/28/1989	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1474	Spill Test Date	11/01/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/29/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	01/29/2024	Line Tightness Test Date	09/20/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/29/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	36	Tank Installed Date	07/28/1989	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	1475	Spill Test Date	12/07/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/29/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	7500	ATG Test Date	01/29/2024	Line Tightness Test Date	07/15/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/29/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	36	Tank Installed Date	07/28/1989	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1476	Spill Test Date	11/01/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/29/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/29/2024	Line Tightness Test Date	04/12/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/29/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	36	Tank Installed Date	07/28/1989	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1477	Spill Test Date	11/01/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	01/29/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	01/29/2024	Line Tightness Test Date	05/14/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/29/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	36	Tank Installed Date	07/28/1989	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1478	Spill Test Date	11/01/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	01/29/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/29/2024	Line Tightness Test Date	04/17/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	01/29/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	43	Tank Installed Date	07/29/1982	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1479	Spill Test Date	11/01/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	01/29/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	2500	ATG Test Date	01/29/2024	Line Tightness Test Date	04/17/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/29/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: KERNAGHANS SERVICE 9TH AVE N
1504 9th Ave N
Great Falls, MT 59401-1301 Cascade

System Facility ID:07-04509

Facility Code: 18525
Last Inspected On: 09/01/2023
Operating Permit Renewal Date: 09/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: James Kernaghan

(406) 452-9505

Operator Contact: Jeff Rearden

Owner/Operator: James Kernaghan

(406) 452-9505

Callie Rearden, UST Class B Operator
Jeff Rearden, UST Class A Operator

piknpump@gmail.com

Tank Code	05	Tank Age	27	Tank Installed Date	05/23/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1480	Spill Test Date	10/18/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	10/18/2022	Tank/Piping CP Test Date	08/05/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	2000	ATG Test Date	10/18/2022	Line Tightness Test Date	11/09/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/18/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	27	Tank Installed Date	05/23/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1481	Spill Test Date	12/06/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	10/18/2022	Tank/Piping CP Test Date	08/05/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	1000	ATG Test Date	10/18/2022	Line Tightness Test Date	11/09/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/18/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	27	Tank Installed Date	05/23/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm

Tag Number	1482	Spill Test Date	10/18/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	10/18/2022	Tank/Piping CP Test Date	08/05/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	2000	ATG Test Date	10/18/2022	Line Tightness Test Date	11/09/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/18/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	27	Tank Installed Date	05/23/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1483	Spill Test Date	12/06/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	10/18/2022	Tank/Piping CP Test Date	08/05/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	3500	ATG Test Date	10/18/2022	Line Tightness Test Date	11/12/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/18/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	27	Tank Installed Date	05/23/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1484	Spill Test Date	12/06/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	10/18/2022	Tank/Piping CP Test Date	08/05/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	1500	ATG Test Date	10/18/2022	Line Tightness Test Date	11/13/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/18/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: LITHIA BUICK GMC
26 9th St S
Great Falls, MT 59401-3757 Cascade

System Facility ID:07-10262

Facility Code: 18808
Last Inspected On: 03/31/2020
Operating Permit Renewal Date: 03/31/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lithia Real Estate Inc Great Falls

toberhoulser@lithia.com

Operator Contact: Mark McCarthy

Dan Noland, UST Class B Operator
Dan Noland, UST Class B Operator
Mark McCarthy, UST Class A Operator
Mark McCarthy, UST Class B Global Operator

Tank Code	01	Tank Age	49	Tank Installed Date	01/27/1976	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	430	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	3996	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Cascade County in the City of Great Falls

Location: LOVES TRAVEL STOP GREAT FALLS #789
3219 Airport Drive
Great Falls, MT 59404 Cascade

System Facility ID:60-15349

Facility Code: 32433
Last Inspected On: 03/28/2025
Operating Permit Renewal Date: 06/06/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Loves Travel Stops and Country Stores Inc

environmental@loves.com

Operator Contact: Eric Bennett;Loves Travel Stops and Country Stores Inc;Ted Lowery (405) 779-3768

environmental@loves.com;environmental@loves.com;environmental@loves.com

Owner/Operator: Loves Travel Stops and Country Stores Inc

environmental@loves.com

Eric Bennett, UST Class A Operator
Eric Bennett, UST Class B Operator
Ted Lowery, UST Class A Operator
Victor Valdez, UST Class B Operator

environmental@loves.com
environmental@loves.com
environmental@loves.com
Victor.Valdez@loves.com

Tank Code	1	Tank Age	4	Tank Installed Date	11/18/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6003	Spill Test Date	11/02/2021	Piping Installed Date	11/18/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	11/21/2021	Line Tightness Test Date	11/22/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	11/30/2021			ATG Type					
Tank Code	2	Tank Age	4	Tank Installed Date	11/18/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6004	Spill Test Date	11/02/2021	Piping Installed Date	11/18/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	11/21/2021	Line Tightness Test Date	11/22/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	11/30/2021			ATG Type					

Tank Code	3	Tank Age	4	Tank Installed Date	11/18/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6005	Spill Test Date	11/02/2021	Piping Installed Date	11/18/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	11/21/2021	Line Tightness Test Date	11/29/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	11/30/2021			ATG Type					
Tank Code	4	Tank Age	4	Tank Installed Date	11/18/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6006	Spill Test Date	11/02/2021	Piping Installed Date	11/18/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	11/21/2021	Line Tightness Test Date	11/22/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	11/30/2021			ATG Type					
Tank Code	5	Tank Age	4	Tank Installed Date	11/18/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6007	Spill Test Date	11/02/2021	Piping Installed Date	11/18/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	11/21/2021	Line Tightness Test Date	11/22/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	11/30/2021			ATG Type					
Tank Code	6	Tank Age	4	Tank Installed Date	11/18/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6008	Spill Test Date		Piping Installed Date	11/18/2021	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type		CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

	Overfill Test Date		ATG Type		
--	--------------------	--	----------	--	--

Facility Summary in Cascade County in the City of Great Falls

Location: MCLAUGHLIN RESEARCH INSTITUTE
1520 23rd St S
Great Falls, MT 59405-4900 Cascade

System Facility ID:07-12790

Facility Code: 19013
Last Inspected On: 03/19/2025
Operating Permit Renewal Date: 07/16/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: McLaughlin Research Institute (406) 452-6208

Operator Contact: Leroy Bishop (406) 899-1600 Irbishop@mclaughlinresearch.org

Owner/Operator: McLaughlin Research Institute (406) 452-6208

Leroy Bishop, UST Class A Operator

Irbishop@mclaughlinresearch.org

Leroy Bishop, UST Class B Global Operator

Irbishop@mclaughlinresearch.org

Tank Code	01	Tank Age	32	Tank Installed Date	05/23/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2977	Spill Test Date	06/20/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	1000	ATG Test Date	06/20/2022	Line Tightness Test Date	06/20/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/20/2022			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Cascade County in the City of Great Falls

Location: MDOT GREAT FALLS
200 Smelter Ave NE
Great Falls, MT 59404-1900 Cascade

System Facility ID:07-04047

Facility Code: 18498
Last Inspected On: 12/04/2023
Operating Permit Renewal Date: 03/25/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: MDOT Helena (406) 444-6163 mmurolo@mt.gov

Operator Contact: Joe Radonich;Montana Dept of Transportation;Mike Murolo;Montana Dept of Transportation;Tracy Deeds;MDOT Helena;Walt Kerttula;Montana Dept of Transportation (406) 444-6151;(406) 444-7632;(406) 444-6163;(406) 444-7632;(406) 444-9204;(406) 444-7632;(406) 461-0769;(406) 444-6163 jradonich@mt.gov;jradonich@mt.gov;mmurolo@mt.gov;jradonich@mt.gov;tdeeds@mt.gov;mmurolo@mt.gov;wkerttula@mt.gov;jradonich@mt.gov

Owner/Operator: MDOT Helena (406) 444-6163 mmurolo@mt.gov

Joe Radonich, UST Class A Operator jradonich@mt.gov
 Joe Radonich, UST Class B Global Operator jradonich@mt.gov
 Kelly Holbrook, UST Class B Global Operator kholbrook@mt.gov
 Mike Murolo, UST Class A Operator jradonich@mt.gov
 Steven Rupnow, UST Class B Operator vrupnow@mt.gov
 Tracy Deeds, UST Class A Operator mmurolo@mt.gov
 Walt Kerttula, UST Class A Operator jradonich@mt.gov

Tank Code	05	Tank Age	35	Tank Installed Date	11/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3704	Spill Test Date	12/04/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/04/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	12/04/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/04/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	33	Tank Installed Date	04/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3705	Spill Test Date	12/04/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/04/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	12/04/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

	Overfill Test Date	12/04/2023						
--	---------------------------	------------	--	--	--	--	--	--

			ATG Type	Gilbarco/EMC Basic				
--	--	--	-----------------	-----------------------	--	--	--	--

				Gilbarco/EMC Basic				
--	--	--	--	-----------------------	--	--	--	--

Facility Summary in Cascade County in the City of Great Falls

Location: MEADOWLARK COUNTRY CLUB
300 Country Club Blvd
Great Falls, MT 59404-3355 Cascade

System Facility ID:07-11234

Facility Code: 18876
Last Inspected On: 10/31/2024
Operating Permit Renewal Date: 03/01/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Meadowlark Country Club (406) 453-6531

Operator Contact: Tim Furan (406) 899-6846 timfuran@hotmail.com

Owner/Operator: Meadowlark Country Club (406) 453-6531

Tim Furan, UST Class A Operator
Tim Furan, UST Class B Operator

timfuran@hotmail.com
timfuran@hotmail.com

Tank Code	02	Tank Age	34	Tank Installed Date	05/23/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2317	Spill Test Date	10/31/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/31/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	10/31/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/31/2024			ATG Type	OPW/EECO 1500				
Tank Code	03	Tank Age	34	Tank Installed Date	05/23/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2318	Spill Test Date	10/31/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/31/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	10/31/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/31/2024			ATG Type	OPW/EECO 1500				

Facility Summary in Cascade County in the City of Great Falls

Location: MONTANA AIR NATIONAL GUARD UST
2800 Airport Ave B
Great Falls, MT 59404-5570 Cascade

System Facility ID:07-02294

Facility Code: 18433
Last Inspected On: 11/30/2022
Operating Permit Renewal Date: 03/11/2020

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana Air National Guard (406) 791-0316

Operator Contact: Clint Tyler;Joe Kerkes;Joseph Leggett;Mark Payton (406) 231-0600 joseph.leggett@us.af.mil

Owner/Operator: Montana Air National Guard (406) 791-0316

Clint Tyler, UST Class A Operator
Clint Tyler, UST Class B Operator
Joe Kerkes, UST Class A Operator
Joe Kerkes, UST Class A Operator
Joseph Leggett, UST Class A Operator
Mark Payton, UST Class A Operator
Mark Payton, UST Class A Operator

joseph.leggett@us.af.mil

Tank Code	26	Tank Age	31	Tank Installed Date	10/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	
Tag Number		Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Gravity Feed	CP Met Types	
Product	Oil/Water Separator	PLLD Test Date		Tank/Piping CP Test Date	09/19/2007	Primary Tank Leak Detection	Continuous Interstitial Monitoring;Deferred	Primary Pipe Detection		Vapor Recovery	No
Capacity	2110	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	3A	Tank Age	70	Tank Installed Date	01/01/1955	Tank Material	Bare Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	1662	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Impressed Current

Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	03/13/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	25000	ATG Test Date	11/30/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	3B	Tank Age	70	Tank Installed Date	01/01/1955	Tank Material	Bare Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	1663	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	03/13/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	25000	ATG Test Date	11/30/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	3C	Tank Age	70	Tank Installed Date	01/01/1955	Tank Material	Bare Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	1664	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	03/13/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	25000	ATG Test Date	11/30/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	3D	Tank Age	70	Tank Installed Date	01/01/1955	Tank Material	Bare Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	1665	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	03/13/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	25000	ATG Test Date	11/30/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	11/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	3F	Tank Age	70	Tank Installed Date	01/01/1955	Tank Material	Bare Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	1667	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	03/13/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	25000	ATG Test Date	11/30/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	3E	Tank Age	70	Tank Installed Date	01/01/1955	Tank Material	Bare Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	4783	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	03/13/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	25000	ATG Test Date	11/30/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Great Falls

Location: ON YOUR WAY
3601 10th Ave S
Great Falls, MT 59405 Cascade

System Facility ID:07-03973

Facility Code: 18494
Last Inspected On: 12/05/2023
Operating Permit Renewal Date: 03/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: H and R Inc 5 (406) 727-9830 nder4030@yahoo.com

Operator Contact: Harinder Singh;Rajinder Singh (406) 761-4791;(406) 868-2062 hrkinc101@gmail.com;inder4030@yahoo.com

Owner/Operator: H and R Inc 5 (406) 727-9830 nder4030@yahoo.com

Frank Kruse, UST Class B Global Operator wfkruise79@yahoo.com
 Frank Kruse, UST Class B Global Operator wfkruise79@yahoo.com
 Frank Kruse, UST Class B Operator wfkruise79@yahoo.com
 Frank Kruse, UST Class B Operator wfkruise79@yahoo.com
 Harinder Singh, UST Class A Operator nder4030@yahoo.com
 Rajinder Singh, UST Class A Operator hrkinc101@gmail.com

Tank Code	06	Tank Age	34	Tank Installed Date	06/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1248	Spill Test Date	12/05/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	12/05/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	12/05/2023	Line Tightness Test Date	07/12/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	34	Tank Installed Date	06/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1249	Spill Test Date	12/05/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	12/05/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	12/05/2023	Line Tightness Test Date	08/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	12/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	34	Tank Installed Date	06/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1250	Spill Test Date	12/18/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	12/05/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	12/05/2023	Line Tightness Test Date	10/06/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: PHILLIPS 66 GREAT FALLS TERMINAL
1401 52nd St N
Great Falls, MT 59405-1073 Cascade

System Facility ID:07-01845

Facility Code: 18413
Last Inspected On: 01/21/2025
Operating Permit Renewal Date: 06/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Phillips 66 Great Falls Terminal

(406) 255-5714

Operator Contact: Brian Buckley;Russel Fox;Scott Cleveland

russel.fox@p66.com;scleveland@pplweb.com

Owner/Operator: Phillips 66 Great Falls Terminal

(406) 255-5714

Brian Buckley, UST Class A Operator
 Brian Buckley, UST Class A Operator
 Brian Buckley, UST Class A Operator
 Brian Buckley, UST Class A Operator
 Brian Buckley, UST Class B Operator
 Brian Buckley, UST Class B Operator
 Brian Buckley, UST Class B Operator
 Brian Buckley, UST Class B Operator
 Russel Fox, UST Class A Operator
 Russel Fox, UST Class A Operator
 Russel Fox, UST Class B Operator
 Russel Fox, UST Class B Operator
 Scott Cleveland, UST Class A Operator
 Scott Cleveland, UST Class A Operator
 Scott Cleveland, UST Class A Operator
 Scott Cleveland, UST Class A Operator
 Scott Parker, UST Class B Operator
 Scott Parker, UST Class B Operator
 Scott Parker, UST Class B Operator
 Scott Parker, UST Class B Operator

russel.fox@p66.com
 russel.fox@p66.com
 russel.fox@p66.com
 russel.fox@p66.com
 scleveland@pplweb.com
 scleveland@pplweb.com
 scleveland@pplweb.com
 scleveland@pplweb.com
 Scott.G.Parker@p66.com
 Scott.G.Parker@p66.com
 Scott.G.Parker@p66.com
 Scott.G.Parker@p66.com

Tank Code	22	Tank Age	31	Tank Installed Date	02/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	4910	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Regulated by DOT	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	

Product	Mixture	PLLD Test Date		Tank/Piping CP Test Date	07/24/2009	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	11/03/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S5	Tank Age	65	Tank Installed Date	01/01/1960	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	704	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/29/2024	Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/29/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	2520000	ATG Test Date		Line Tightness Test Date	09/01/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S9	Tank Age	65	Tank Installed Date	01/01/1960	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	707	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/29/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	1512000	ATG Test Date		Line Tightness Test Date	10/30/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S11	Tank Age	65	Tank Installed Date	01/01/1960	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	709	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Kerosene	PLLD Test Date		Tank/Piping CP Test Date	05/29/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	1512000	ATG Test Date		Line Tightness Test Date	09/17/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S13	Tank Age	65	Tank Installed Date	01/01/1960	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	711	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	

Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/29/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	1050000	ATG Test Date		Line Tightness Test Date	09/17/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S15	Tank Age	65	Tank Installed Date	01/01/1960	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	713	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Kerosene	PLLD Test Date		Tank/Piping CP Test Date	05/29/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	21000	ATG Test Date		Line Tightness Test Date	11/03/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S16	Tank Age	65	Tank Installed Date	01/01/1960	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	714	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/29/2024	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	1512000	ATG Test Date		Line Tightness Test Date	10/30/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Cascade County in the City of Great Falls

Location: RAINBOW SHOP
6700 Rainbow Dam Rd
Great Falls, MT 59404-6000 Cascade

System Facility ID:07-01189

Facility Code: 18379
Last Inspected On: 05/16/2022
Operating Permit Renewal Date: 09/30/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Northwestern Energy Butte (406) 655-2521 beth.stimatz@northwestern.com

Operator Contact: Brian Ranf brian.ranf@northwestern.com

Owner/Operator: Northwestern Energy Butte (406) 655-2521 beth.stimatz@northwestern.com

Brian Ranf, UST Class A Operator brian.ranf@northwestern.com
Matthew Lynn, UST Class B Operator matthew.lynn@northwestern.com

Tank Code	01	Tank Age	33	Tank Installed Date	08/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1674	Spill Test Date	09/21/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/16/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	550	ATG Test Date	05/16/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	02	Tank Age	33	Tank Installed Date	08/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1675	Spill Test Date	09/21/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/16/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	05/16/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Cascade County in the City of Great Falls

Location: RENTAL CAR SERVICE BUILDING
2700 Airport Dr
Great Falls, MT 59404 Cascade

System Facility ID:07-12300

Facility Code: 18994
Last Inspected On: 05/11/2022
Operating Permit Renewal Date: 07/20/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Great Falls International Airport

Operator Contact: Chris Houghton;Christopher Upchurch;Kent Funyak;Michael Novak;Rod Hall

(406) 727-3404;(406) 759-5538;(406) 799-3189

bb.hof.collector@gmail.com;chris@flygtf.com;rod@flygtf.com

Owner/Operator: Great Falls International Airport

Chris Houghton, UST Class A Operator

Chris Houghton, UST Class B Operator

Christopher Upchurch, UST Class A Operator

Christopher Upchurch, UST Class B Operator

Kent Funyak, UST Class A Operator

Kent Funyak, UST Class B Operator

Michael Novak, UST Class A Operator

Michael Novak, UST Class B Global Operator

Rod Hall, UST Class A Operator

Rod Hall, UST Class B Operator

Tory Ewing, UST Class B Operator

chris@flygtf.com

chris@flygtf.com

bb.hof.collector@gmail.com

bb.hof.collector@gmail.com

rod@flygtf.com

rod@flygtf.com

Tank Code	01	Tank Age	35	Tank Installed Date	11/27/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2704	Spill Test Date	05/11/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	05/11/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/11/2022			ATG Type	Veeder Root/TLS-300				

Facility Summary in Cascade County in the City of Great Falls

Location: SAMS CLUB 6379
401 Northwest Byp
Great Falls, MT 59404-4124 Cascade

System Facility ID:56-14065

Facility Code: 30718
Last Inspected On: 03/20/2023
Operating Permit Renewal Date: 04/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sams West Inc	(785) 550-8812	marie.brouhard@aptim.com
Operator Contact: Cheryl Shie;Dylan Oakden;Shaiyna Chinery	(406) 217-2265;(760) 669-2468	clshie.s06379.us@samsclub.com;fatalangelshai@gmail.com;rdoakde.s06379.us@samsclub.com

Owner/Operator: Sams West Inc (785) 550-8812 marie.brouhard@aptim.com

- Cheryl Shie, UST Class A Operator
- Cheryl Shie, UST Class B Operator
- Dylan Oakden, UST Class A Operator
- Dylan Oakden, UST Class B Operator
- Johney Miller, UST Class B Global Operator
- Shaiyna Chinery, UST Class A Operator
- Shaiyna Chinery, UST Class B Global Operator

- clshie.s06379.us@samsclub.com
- clshie.s06379.us@samsclub.com
- rdoakde.s06379.us@samsclub.com
- rdoakde.s06379.us@samsclub.com
- john.miller@7g-enviro.com
- fatalangelshai@gmail.com
- fatalangelshai@gmail.com

Tank Code	01	Tank Age	23	Tank Installed Date	08/05/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4702	Spill Test Date	02/15/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/15/2023	Sump Tightness Test Date	04/26/2023	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	02/15/2023	Line Tightness Test Date	02/15/2023	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/26/2023			ATG Type	Veeder Root/TLS-450				
Tank Code	02	Tank Age	23	Tank Installed Date	08/05/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4703	Spill Test Date	02/15/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/15/2023	Sump Tightness Test Date	04/26/2023	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No

Capacity	20000	ATG Test Date	02/15/2023	Line Tightness Test Date	02/15/2023	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/26/2023			ATG Type	Veeder Root/TLS-450				
Tank Code	03	Tank Age	23	Tank Installed Date	08/05/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4704	Spill Test Date	02/15/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/15/2023	Sump Tightness Test Date	04/26/2023	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	02/15/2023	Line Tightness Test Date	02/15/2023	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/26/2023			ATG Type	Veeder Root/TLS-450				

Facility Summary in Cascade County in the City of Great Falls

Location: SCHULTES 38TH STREET STORE
3800 3rd Ave S
Great Falls, MT 59405 Cascade

System Facility ID:07-08480

Facility Code: 18691
Last Inspected On: 01/29/2024
Operating Permit Renewal Date: 03/24/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Great Falls Convenience Store (406) 453-3450 schultes38@bresnan.net

Operator Contact: Rory Schulte (406) 453-3450 schultes38@bresnan.net

Owner/Operator: Great Falls Convenience Store (406) 453-3450 schultes38@bresnan.net
Rory Schulte, UST Class A Operator schultes38@bresnan.net
Rory Schulte, UST Class B Global Operator schultes38@bresnan.net

Tank Code	01	Tank Age	40	Tank Installed Date	12/07/1985	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1906	Spill Test Date	01/22/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/11/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/11/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/10/2023	Line Tightness Test Date	10/11/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/22/2024			ATG Type	Veeder Root/TLS-350				
Tank Code	02	Tank Age	40	Tank Installed Date	12/07/1985	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1907	Spill Test Date	01/22/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/11/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/11/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/10/2023	Line Tightness Test Date	10/11/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/22/2024			ATG Type	Veeder Root/TLS-350				
Tank Code	03	Tank Age	36	Tank Installed Date	12/07/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1908	Spill Test Date	01/22/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date	10/11/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	02/22/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	10/10/2023	Line Tightness Test Date	10/11/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/22/2024			ATG Type	Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Great Falls

Location: SMITHS 166 FUEL CENTER
1601 Market Place Dr
Great Falls, MT 59401 Cascade

System Facility ID:60-15217

Facility Code: 30936
Last Inspected On: 01/07/2025
Operating Permit Renewal Date: 04/16/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Smiths Food and Drug (801) 974-1400 roger.gough@sfdc.com

Operator Contact: Braxton Hill;James Dye (801) 560-0471 braxton.hill@sfdc.com;jim.dye@sfdc.com

Owner/Operator: Smiths Food and Drug (801) 974-1400 roger.gough@sfdc.com

Braxton Hill, UST Class A Operator	braxton.hill@sfdc.com
Braxton Hill, UST Class B Operator	braxton.hill@sfdc.com
James Dye, UST Class A Operator	jim.dye@sfdc.com
James Dye, UST Class B Global Operator	jim.dye@sfdc.com
Todd Dotseth, UST Class B Operator	petrocompliance@gmail.com

Tank Code	01	Tank Age	13	Tank Installed Date	12/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5395	Spill Test Date	09/03/2024	Piping Installed Date	10/17/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/05/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/03/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	09/03/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/23/2024			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	02	Tank Age	13	Tank Installed Date	12/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5396	Spill Test Date	09/03/2024	Piping Installed Date	10/17/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/05/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel	PLLD Test Date	09/03/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/03/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	03	Tank Age	13	Tank Installed Date	12/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5397	Spill Test Date	09/03/2024	Piping Installed Date	10/17/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/05/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/03/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	09/03/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				

Facility Summary in Cascade County in the City of Great Falls

Location: SUCH GROUP INTERNATIONAL INC
2224 Vaughn Rd
Great Falls, MT 59404-2196 Cascade

System Facility ID:07-13632

Facility Code: 19051
Last Inspected On: 02/06/2024
Operating Permit Renewal Date: 02/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Such Group International Inc (406) 727-4144 todds@wwpgf.com

Operator Contact: Todd Such (406) 727-4114 todds@sgigf.com

Owner/Operator: Such Group International Inc (406) 727-4144 todds@wwpgf.com
Todd Such, UST Class A Operator todds@sgigf.com
Todd Such, UST Class B Operator todds@sgigf.com

Tank Code	01	Tank Age	30	Tank Installed Date	08/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4389	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	30	Tank Installed Date	08/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4390	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Cascade County in the City of Great Falls

Location: TOLAN DISTRIBUTING INC
2201 Vaughn Rd
Great Falls, MT 59404-2197 Cascade

System Facility ID:07-04511

Facility Code: 18527
Last Inspected On: 08/11/2023
Operating Permit Renewal Date: 09/15/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Tolan Distributing Inc

tdimt@gmx.com

Operator Contact:

Owner/Operator: Tolan Distributing Inc

tdimt@gmx.com

Tank Code	06	Tank Age	26	Tank Installed Date	09/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4098	Spill Test Date	06/07/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/07/2023	Sump Tightness Test Date	09/26/2020	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/07/2023	Line Tightness Test Date	06/07/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/07/2023			ATG Type	EMCO Electronics/EECO 1500				
Tank Code	07	Tank Age	26	Tank Installed Date	01/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4099	Spill Test Date	06/07/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/07/2023	Sump Tightness Test Date	09/26/2018	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/07/2023	Line Tightness Test Date	06/07/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/07/2023			ATG Type	EMCO Electronics/EECO 1500				

Tank Code	08	Tank Age	26	Tank Installed Date	09/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4100	Spill Test Date	06/07/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/07/2023	Sump Tightness Test Date	09/26/2018	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/07/2023	Line Tightness Test Date	06/07/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/07/2023			ATG Type	EMCO Electronics/EECO 1500				
Tank Code	09	Tank Age	26	Tank Installed Date	09/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4101	Spill Test Date	06/07/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/07/2023	Sump Tightness Test Date	09/26/2018	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/07/2023	Line Tightness Test Date	06/07/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/07/2023			ATG Type	EMCO Electronics/EECO 1500				

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP GREAT FALLS 6
3715 31st St SW
Great Falls, MT 59404-4700 Cascade

System Facility ID:56-14148

Facility Code: 30784
Last Inspected On: 03/26/2024
Operating Permit Renewal Date: 08/06/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Great Falls 6 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Great Falls 6 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	01	Tank Age	20	Tank Installed Date	02/25/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4956	Spill Test Date	01/12/2024	Piping Installed Date	02/25/2005	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date	03/26/2024	Line Tightness Test Date	02/29/2016	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/13/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	20	Tank Installed Date	02/25/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4957	Spill Test Date	09/13/2023	Piping Installed Date	02/25/2005	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date	03/26/2024	Line Tightness Test Date	02/24/2016	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	09/13/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	20	Tank Installed Date	02/25/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4958	Spill Test Date	09/13/2023	Piping Installed Date	02/25/2005	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/13/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date	03/26/2024	Line Tightness Test Date	02/24/2016	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/13/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	20	Tank Installed Date	02/25/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4959	Spill Test Date	09/13/2023	Piping Installed Date	02/25/2005	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/26/2024	Line Tightness Test Date	02/23/2016	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/13/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	12	Tank Installed Date	05/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5420	Spill Test Date		Piping Installed Date	05/05/2013	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Deferred;Not Listed	Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP GREAT FALLS 7
1411 10th Ave S
Great Falls, MT 59405 Cascade

System Facility ID:60-15283

Facility Code: 30990
Last Inspected On: 03/26/2024
Operating Permit Renewal Date: 08/06/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Great Falls 7 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers;Town Pump

Trentb@townpump.com;environmental@townpump.com

Owner/Operator: Great Falls 7 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

environmental@townpump.com

Trent Biggers, UST Class B Global Operator

environmental@townpump.com

Tank Code	01	Tank Age	8	Tank Installed Date	01/25/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	High Density Polyethylene	Overfill Types	Flapper Valve
Tag Number	5665	Spill Test Date	09/12/2023	Piping Installed Date	07/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/12/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/26/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	01/15/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	8	Tank Installed Date	01/25/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	High Density Polyethylene	Overfill Types	Flapper Valve
Tag Number	5666	Spill Test Date	01/15/2024	Piping Installed Date	07/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/12/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	15000	ATG Test Date	03/26/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Energy Act	Yes

		Overfill Test Date	09/12/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	03	Tank Age	8	Tank Installed Date	01/25/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	High Density Polyethylene	Overfill Types	Flapper Valve
Tag Number	5667	Spill Test Date	09/12/2023	Piping Installed Date	07/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/12/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/26/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	01/15/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	04	Tank Age	8	Tank Installed Date	01/25/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	High Density Polyethylene	Overfill Types	Flapper Valve
Tag Number	5668	Spill Test Date	09/12/2023	Piping Installed Date	07/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/12/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	25000	ATG Test Date	03/26/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	01/15/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	05	Tank Age	8	Tank Installed Date	01/25/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	High Density Polyethylene	Overfill Types	Flapper Valve
Tag Number	5669	Spill Test Date	09/12/2023	Piping Installed Date	07/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/12/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	03/26/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	01/15/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	06	Tank Age	8	Tank Installed Date	01/25/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	High Density Polyethylene	Overfill Types	Flapper Valve

Tag Number	5670	Spill Test Date	01/15/2024	Piping Installed Date	07/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/12/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/26/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/26/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	01/15/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP INC GREAT FALLS 1
401 10th Ave S
Great Falls, MT 59405-4044 Cascade

System Facility ID:07-08700

Facility Code: 18695
Last Inspected On: 03/21/2024
Operating Permit Renewal Date: 08/06/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Great Falls 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Great Falls 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator
Trent Biggers, UST Class B Global Operator

Trentb@townpump.com
Trentb@townpump.com
Trentb@townpump.com
Trentb@townpump.com

Tank Code	01	Tank Age	39	Tank Installed Date	01/01/1986	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2391	Spill Test Date	08/30/2023	Piping Installed Date	07/12/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/30/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date	08/30/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/21/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	08/30/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	39	Tank Installed Date	01/01/1986	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2392	Spill Test Date	08/30/2023	Piping Installed Date	07/12/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/30/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date	03/21/2024	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/21/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No

		Overfill Test Date	08/30/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	37	Tank Installed Date	08/18/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2393	Spill Test Date	08/30/2023	Piping Installed Date	07/12/2013	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/30/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date	03/21/2024	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/21/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	08/30/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	27	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2394	Spill Test Date	09/14/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/30/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date	03/16/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/21/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/30/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	27	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2395	Spill Test Date	08/30/2023	Piping Installed Date	07/12/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/30/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/21/2024	Tank/Piping CP Test Date	03/16/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/21/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	08/30/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP INC GREAT FALLS 2
1400 10th Ave S
Great Falls, MT 59405-2624 Cascade

System Facility ID:07-08701

Facility Code: 18696
Last Inspected On: 02/28/2024
Operating Permit Renewal Date: 06/24/2022

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Great Falls 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Great Falls 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Code	04	Tank Age	35	Tank Installed Date	01/04/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2396	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Approved Remote Monitoring;Statistical Inventory Reconciliation	Primary Pipe Detection	Approved Remote Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	05	Tank Age	35	Tank Installed Date	01/04/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2397	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Approved Remote Monitoring;Statistical Inventory Reconciliation	Primary Pipe Detection	Approved Remote Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	24000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	06	Tank Age	35	Tank Installed Date	01/04/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	2398	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Approved Remote Monitoring;Statistical Inventory Reconciliation	Primary Pipe Detection	Approved Remote Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	24000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	07	Tank Age	35	Tank Installed Date	01/04/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2399	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Approved Remote Monitoring;Statistical Inventory Reconciliation	Primary Pipe Detection	Approved Remote Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	16000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	08	Tank Age	35	Tank Installed Date	01/04/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2400	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Approved Remote Monitoring;Statistical Inventory Reconciliation	Primary Pipe Detection	Approved Remote Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	11	Tank Age	5	Tank Installed Date	01/10/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5944	Spill Test Date	09/14/2023	Piping Installed Date	01/10/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/14/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/28/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes

Capacity	15000	ATG Test Date	02/28/2024	Line Tightness Test Date	09/14/2023	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/14/2023			ATG Type					
Tank Code	12	Tank Age	5	Tank Installed Date	01/10/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5945	Spill Test Date	01/12/2024	Piping Installed Date	01/10/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/14/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/28/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	02/28/2024	Line Tightness Test Date	09/14/2023	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/14/2023			ATG Type					
Tank Code	13	Tank Age	5	Tank Installed Date	01/10/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5946	Spill Test Date	09/14/2023	Piping Installed Date	01/10/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/14/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/28/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	02/28/2024	Line Tightness Test Date	09/14/2023	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/14/2023			ATG Type					

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP INC GREAT FALLS 3
505 Northwest Byp
Great Falls, MT 59404-4102 Cascade

System Facility ID:56-14016

Facility Code: 30676
Last Inspected On: 03/25/2024
Operating Permit Renewal Date: 08/06/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Great Falls 3 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Great Falls 3 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Tank Code	01	Tank Age	24	Tank Installed Date	10/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4453	Spill Test Date	09/13/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/25/2024	Tank/Piping CP Test Date	11/30/2005	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	15000	ATG Test Date	03/25/2024	Line Tightness Test Date	10/12/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/13/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	24	Tank Installed Date	10/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4454	Spill Test Date	09/13/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/25/2024	Tank/Piping CP Test Date	11/30/2005	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/25/2024	Line Tightness Test Date	10/12/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/13/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	24	Tank Installed Date	10/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4455	Spill Test Date	09/13/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/25/2024	Tank/Piping CP Test Date	11/30/2005	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	03/25/2024	Line Tightness Test Date	10/12/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/13/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	24	Tank Installed Date	10/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4456	Spill Test Date	09/13/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/25/2024	Tank/Piping CP Test Date	11/30/2005	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/25/2024	Line Tightness Test Date	10/12/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/13/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	24	Tank Installed Date	10/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4457	Spill Test Date	09/13/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/25/2024	Tank/Piping CP Test Date	11/30/2005	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	03/25/2024	Line Tightness Test Date	10/12/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/13/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP INC GREAT FALLS 4
700 10th Ave S
Great Falls, MT 59405-4051 Cascade

System Facility ID:07-03217

Facility Code: 18470
Last Inspected On: 03/27/2024
Operating Permit Renewal Date: 08/06/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Great Falls 4 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Great Falls 4 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator
Trent Biggers, UST Class B Global Operator

Trentb@townpump.com
Trentb@townpump.com
Trentb@townpump.com
Trentb@townpump.com

Tank Code	08	Tank Age	23	Tank Installed Date	08/18/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4708	Spill Test Date	01/09/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/27/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/27/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/14/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	09	Tank Age	23	Tank Installed Date	08/18/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4709	Spill Test Date	09/14/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	03/27/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	03/27/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	09/14/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	30	Tank Installed Date	08/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4804	Spill Test Date	12/15/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/27/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	2000	ATG Test Date	03/27/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/14/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	30	Tank Installed Date	08/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4805	Spill Test Date	09/14/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/27/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/27/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/14/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	30	Tank Installed Date	08/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4806	Spill Test Date	12/15/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/27/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/27/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/14/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Great Falls

Location: TOWN PUMP INC GREAT FALLS 5
3700 31st St SW Ste 1
Great Falls, MT 59404-4734 Cascade

System Facility ID:07-03463

Facility Code: 18483
Last Inspected On: 03/27/2024
Operating Permit Renewal Date: 08/06/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Great Falls 5 Town Pump Inc (406) 497-6000 environmental@townpump.com

Operator Contact: Trent Biggers Trentb@townpump.com

Owner/Operator: Great Falls 5 Town Pump Inc (406) 497-6000 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class A Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

Tank Code	04	Tank Age	36	Tank Installed Date	01/15/1989	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2223	Spill Test Date	12/15/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date	03/27/2024	Tank/Piping CP Test Date	09/21/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/27/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	36	Tank Installed Date	01/15/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2224	Spill Test Date	01/12/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/02/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/27/2024	Tank/Piping CP Test Date	12/12/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	14000	ATG Test Date	03/27/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	08/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	08	Tank Age	32	Tank Installed Date	04/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2225	Spill Test Date	08/31/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/27/2024	Tank/Piping CP Test Date	09/21/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	03/27/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	09	Tank Age	32	Tank Installed Date	04/01/1993	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2226	Spill Test Date	12/15/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	03/27/2024	Tank/Piping CP Test Date	12/12/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/27/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	10	Tank Age	32	Tank Installed Date	04/01/1993	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2227	Spill Test Date	08/31/2023	Piping Installed Date	10/20/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/03/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	03/27/2024	Tank/Piping CP Test Date	09/21/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/27/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	08/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	11	Tank Age	19	Tank Installed Date	04/25/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve

Tag Number	5080	Spill Test Date	08/31/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/27/2024	Tank/Piping CP Test Date	03/12/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	30000	ATG Test Date	03/27/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	12	Tank Age	19	Tank Installed Date	04/26/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5081	Spill Test Date	08/31/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/27/2024	Tank/Piping CP Test Date	03/12/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	30000	ATG Test Date	03/27/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	13	Tank Age	19	Tank Installed Date	04/25/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5082	Spill Test Date	08/31/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/27/2024	Tank/Piping CP Test Date	03/12/2010	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	30000	ATG Test Date	03/27/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	14	Tank Age	0	Tank Installed Date		Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass	Overfill Types	High Level Alarm
Tag Number	5362	Spill Test Date		Piping Installed Date	04/12/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Not Listed	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1	Primary Pipe Detection	Continuous Interstitial Monitoring;Not Listed	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Great Falls

Location: WALMART SUPERCENTER #7199
5400 10th Ave S
Great Falls, MT 59405 Cascade

System Facility ID:60-15280

Facility Code: 30988
Last Inspected On: 03/21/2023
Operating Permit Renewal Date: 09/10/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Walmart Inc (877) 829-5505 walmartepmsupport@aptim.com

Operator Contact: Treavor Harpine (406) 770-6083 treavor12321@gmail.com

Owner/Operator: Walmart Inc (877) 829-5505 walmartepmsupport@aptim.com

Treavor Harpine, UST Class A Operator treavor12321@gmail.com
Treavor Harpine, UST Class B Global Operator treavor12321@gmail.com

Tank Code	01	Tank Age	8	Tank Installed Date	03/01/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5646	Spill Test Date	02/05/2020	Piping Installed Date	03/01/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/05/2020	Sump Tightness Test Date	10/17/2019	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date		Line Tightness Test Date	02/05/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	Yes
		Overfill Test Date	02/05/2020			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	8	Tank Installed Date	03/01/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5647	Spill Test Date	02/05/2020	Piping Installed Date	03/01/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/05/2020	Sump Tightness Test Date	10/17/2019	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date		Line Tightness Test Date	02/05/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	Yes
		Overfill Test Date	02/05/2020			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	03	Tank Age	8	Tank Installed Date	03/01/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	5648	Spill Test Date	02/05/2020	Piping Installed Date	03/01/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/05/2020	Sump Tightness Test Date	10/17/2019	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	02/05/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	Yes
		Overfill Test Date	02/05/2020			ATG Type	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Cascade County in the City of Great Falls

Location: ZIP TRIP 45
625 1st Ave N
Great Falls, MT 59401-2510 Cascade

System Facility ID:07-01057

Facility Code: 18375
Last Inspected On: 03/18/2025
Operating Permit Renewal Date: 03/30/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Operator Contact: Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

- | | |
|------------------------------------|------------------------------|
| Jim Alford, UST Class A Operator | jim.alford@chsinc.com |
| Jim Alford, UST Class A Operator | jim.alford@chsinc.com |
| Jim Alford, UST Class B Operator | jim.alford@chsinc.com |
| Jim Alford, UST Class B Operator | jim.alford@chsinc.com |
| Luci Tuttle, UST Class B Operator | Lucinda.Tuttle@chsinc.com |
| Luci Tuttle, UST Class B Operator | Lucinda.Tuttle@chsinc.com |
| Sean Hurley, UST Class A Operator | sean.hurley@chsinc.com |
| Sean Hurley, UST Class A Operator | sean.hurley@chsinc.com |
| Travis Weber, UST Class B Operator | Donald.Widdicombe@chsinc.com |
| Travis Weber, UST Class B Operator | Donald.Widdicombe@chsinc.com |

Tank Code	01	Tank Age	43	Tank Installed Date	04/27/1982	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1610	Spill Test Date	06/29/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	08/08/2024	Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	08/08/2024	Line Tightness Test Date	09/20/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/08/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	43	Tank Installed Date	04/27/1982	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1611	Spill Test Date	06/29/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/08/2024	Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	08/08/2024	Line Tightness Test Date	06/21/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/08/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	43	Tank Installed Date	04/27/1982	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1612	Spill Test Date	06/29/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/08/2024	Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	08/08/2024	Line Tightness Test Date	06/16/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/08/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Malmstrom A F B

Location: MALMSTROM AFB BLDG 1480 1482
6705 Flightline Dr
Malmstrom A F B, MT 59402-7524 Cascade

System Facility ID:07-10733

Facility Code: 18844
Last Inspected On: 05/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Rodney Borger, UST Class B Global Operator	rodney.borger.ctr@malmstrom.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	04	Tank Age	29	Tank Installed Date	08/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4325	Spill Test Date	05/18/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/31/2021	Sump Tightness Test Date	03/31/2021	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Jet Fuel, JP8	PLLD Test Date		Tank/Piping CP Test Date	03/31/2021	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/02/2024	Line Tightness Test Date	11/26/2012	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/02/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Malmstrom A F B

Location: MALMSTROM AFB BLDG 500
21 77th St N
Malmstrom A F B, MT 59402-7538 Cascade

System Facility ID:07-08954

Facility Code: 18720
Last Inspected On: 05/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
David Degolier, UST Class B Operator	david.degolier@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	07	Tank Age	25	Tank Installed Date	11/22/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4227	Spill Test Date	05/18/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/31/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/04/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/04/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Cascade County in the City of Malmstrom A F B

Location: MILITARY VEHICLE REFUELING SITE BLDG 448
7832 Flightline Dr
Malmstrom A F B, MT 59402-7525 Cascade

System Facility ID:56-14116

Facility Code: 30757
Last Inspected On: 05/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Malmstrom A F B (406) 731-6167

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: Malmstrom A F B (406) 731-6167

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	S1	Tank Age	20	Tank Installed Date	06/15/2005	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4971	Spill Test Date		Piping Installed Date	07/29/2020	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/18/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Biodiesel, <=B20	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	60000	ATG Test Date		Line Tightness Test Date	07/29/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S2	Tank Age	20	Tank Installed Date	08/05/2005	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4972	Spill Test Date		Piping Installed Date	07/29/2020	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/18/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	07/29/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date				ATG Type					
Tank Code	S3	Tank Age	20	Tank Installed Date	08/05/2005	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5037	Spill Test Date		Piping Installed Date	07/29/2020	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/18/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Gasoline, E85	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	07/29/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Cascade County in the City of Malmstrom AFB

Location: AAFES SHOPPING CENTER BLDG 1340
7200 Perimeter Rd
Malmstrom AFB, MT 59402 Cascade

System Facility ID:60-15199

Facility Code: 30920
Last Inspected On: 05/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Malmstrom A F B (406) 731-6167

Operator Contact: Ashley Collins;Candace Ellsworth;Famh Kosoff;Fatima Quintanilla;James Nau;Malmstrom A F B;Sonya Coker (406) 454-1301;(406) 731-6167;(406) 731-7128;(406) 761-8004 ashley.collins@7g-enviro.com;candace.ellsworth@us.af.mil;cokers@aafes.com;naujm@aafes.com;quintanillafm@aafes.com

Owner/Operator: Malmstrom A F B (406) 731-6167

Ashley Collins, UST Class A Operator	ashley.collins@7g-enviro.com
Ashley Collins, UST Class B Global Operator	ashley.collins@7g-enviro.com
Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Famh Kosoff, UST Class A Operator	
Fatima Quintanilla, UST Class A Operator	quintanillafm@aafes.com
Fatima Quintanilla, UST Class B Operator	quintanillafm@aafes.com
James Nau, UST Class A Operator	naujm@aafes.com
James Nau, UST Class B Operator	naujm@aafes.com
Ken Chorpenning, UST Class B Global Operator	chorpenningk@aafes.com
Sonya Coker, UST Class A Operator	cokers@aafes.com
Sonya Coker, UST Class B Global Operator	cokers@aafes.com
Sonya Coker, UST Class B Operator	cokers@aafes.com

Tank Code	01	Tank Age	14	Tank Installed Date	09/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5329	Spill Test Date	05/18/2024	Piping Installed Date	08/31/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/14/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/28/2024	Tank/Piping CP Test Date	06/11/2012	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	05/28/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

		Overfill Test Date	05/28/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	14	Tank Installed Date	09/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5330	Spill Test Date	05/18/2024	Piping Installed Date	08/31/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/14/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/28/2024	Tank/Piping CP Test Date	06/11/2012	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/28/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/28/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				

Facility Summary in Cascade County in the City of Monarch

Location: COUGAR CANYON LODGE and ESCAPE
5012 US Hwy 89 S
Monarch, MT 59463 Cascade

System Facility ID:07-01874

Facility Code: 18415
Last Inspected On: 09/29/2022
Operating Permit Renewal Date: 09/29/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mark Properties LLC (406) 236-5922 heatmechanical@gmail.com

Operator Contact: Richard Hatanpaa (406) 236-5922 cougarcanyonlodge@gmail.com

Owner/Operator: Mark Properties LLC (406) 236-5922 heatmechanical@gmail.com
Richard Hatanpaa, UST Class A Operator cougarcanyonlodge@gmail.com
Richard Hatanpaa, UST Class B Operator cougarcanyonlodge@gmail.com

Tank Code	01	Tank Age	33	Tank Installed Date	09/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2979	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date	05/16/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	05/16/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Cascade County in the City of Monarch

Location: MALMSTROM AFB A 5
US Hwy 89
Monarch, MT 59463 Cascade

System Facility ID:07-08979

Facility Code: 18740
Last Inspected On: 06/14/2024
Operating Permit Renewal Date: 09/25/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	06/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	110	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/17/2020	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/03/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/03/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Monarch

Location: MALMSTROM AFB A 6
US Hwy 89
Monarch, MT 59463 Cascade

System Facility ID:07-08980

Facility Code: 18741
Last Inspected On: 06/14/2024
Operating Permit Renewal Date: 09/25/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	06/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	111	Spill Test Date	07/17/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/18/2020	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/03/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/03/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Monarch

Location: MALMSTROM AFB A 7
US Hwy 89
Monarch, MT 59463 Cascade

System Facility ID:07-08981

Facility Code: 18742
Last Inspected On: 06/14/2024
Operating Permit Renewal Date: 10/07/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	06/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	112	Spill Test Date	05/05/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/05/2023	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Monarch

Location: MALMSTROM AFB A 8
US Hwy 89
Monarch, MT 59463 Cascade

System Facility ID:07-08982

Facility Code: 18743
Last Inspected On: 06/14/2024
Operating Permit Renewal Date: 09/25/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	06/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	113	Spill Test Date	07/17/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/18/2020	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/03/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/03/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Neihart

Location: BOBS BAR UST
107 Main St
Neihart, MT 59465-0037 Cascade

System Facility ID:07-09274

Facility Code: 18768
Last Inspected On: 04/15/2021
Operating Permit Renewal Date: 05/16/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Smith Bagheri LLC (406) 236-5955 jsmithbagheri@gmail.com

Operator Contact: Janice Smith-Bagheri (406) 236-5955 jsmithbagheri@gmail.com

Janice Smith-Bagheri, UST Class A Operator
Janice Smith-Bagheri, UST Class A Operator
Janice Smith-Bagheri, UST Class B Operator
Janice Smith-Bagheri, UST Class B Operator

jsmithbagheri@gmail.com
jsmithbagheri@gmail.com
jsmithbagheri@gmail.com
jsmithbagheri@gmail.com

Tank Code	01	Tank Age	38	Tank Installed Date	02/16/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1455	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/31/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/				
Tank Code	02	Tank Age	38	Tank Installed Date	02/16/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1456	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/31/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/				

Facility Summary in Cascade County in the City of Sand Coulee

Location: CENTERVILLE ELEMENTARY SCHOOL
693 Stockett Rd
Sand Coulee, MT 59472-9757 Cascade

System Facility ID:07-11037

Facility Code: 18866
Last Inspected On: 02/17/2017
Operating Permit Renewal Date: 01/16/2019

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Centerville School

(406) 736-5123

Operator Contact: Steve Beaumont

(406) 736-5123

steveb@centerville.k12.mt.us

Steve Beaumont, UST Class A Operator
Steve Beaumont, UST Class B Operator

steveb@centerville.k12.mt.us
steveb@centerville.k12.mt.us

Tank Code	S1	Tank Age	39	Tank Installed Date	04/30/1986	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	606	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	03/28/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Cascade County in the City of Simms

Location: CURTISS SERVICE CENTER
12742 MT Hwy 200
Simms, MT 59477 Cascade

System Facility ID:07-01612

Facility Code: 18399
Last Inspected On: 05/16/2023
Operating Permit Renewal Date: 07/30/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Robert Curtiss;Robert D Curtiss (406) 264-5640 bobnsheree@live.com

Operator Contact: Robert D Curtiss (406) 264-5640 bobnsheree@live.com

Owner/Operator: Robert D Curtiss

Robert D Curtiss, UST Class A Operator
Robert D Curtiss, UST Class A Operator
Robert D Curtiss, UST Class B Operator
Robert D Curtiss, UST Class B Operator

bobnsheree@live.com
bobnsheree@live.com
bobnsheree@live.com
bobnsheree@live.com

Tank Code	06	Tank Age	26	Tank Installed Date	11/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4124	Spill Test Date	08/31/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/16/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/16/2023	Line Tightness Test Date	05/16/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/31/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	26	Tank Installed Date	11/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4125	Spill Test Date	08/31/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/16/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/16/2023	Line Tightness Test Date	05/16/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/31/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	08	Tank Age	26	Tank Installed Date	11/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4126	Spill Test Date	08/31/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/16/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/16/2023	Line Tightness Test Date	05/16/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/31/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	26	Tank Installed Date	11/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4127	Spill Test Date	08/31/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/16/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/16/2023	Line Tightness Test Date	05/16/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/31/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 1
MT Hwy 200
Simms, MT 59477 Cascade

System Facility ID:25-09041

Facility Code: 23811
Last Inspected On: 05/16/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Aaron Hill, UST Class B Operator	aaron.hill@malmstrom.af.mil
Allen Brooks, UST Class B Operator	allen.brooks@malmstrom.af.mil
Bethany Kent, UST Class B Operator	bethany.kent@malmstrom.af.mil
Brian Day, UST Class B Operator	brian.day@malmstrom.af.mil
Brian McVay, UST Class B Operator	
Brian Rayner, UST Class B Operator	brian.rayner@malmstrom.af.mil
Cameron Smith, UST Class B Operator	cameron.smith@malmstrom.af.mil
Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Chris Ploof, UST Class B Operator	chris.ploof@malmstrom.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Damon McCarty, UST Class B Operator	damon.mccarty@malmstrom.af.mil
David Cosner, UST Class B Operator	david.cosner@malmstrom.af.mil
David Degolier, UST Class B Operator	david.degolier@us.af.mil
Dustin Hemingway, UST Class B Operator	dustin.hemingway@malmstrom.af.mil
Glen Beck, UST Class B Operator	glen.beck@malmstrom.af.mil
Hudson English, UST Class B Operator	hudson.english@malmstrom.af.mil
Issac Price, UST Class B Operator	Issac.Price@malmstrom.af.mil
James Knudsen, UST Class B Operator	james.knudsen@malmstrom.af.mil
James Wooderchak, UST Class B Operator	jwooderchak@yahoo.com
Jason Vike, UST Class B Operator	jason.vike@malmstrom.af.mil
Jeff Laird, UST Class B Operator	jeffrey.laird@malmstrom.af.mil
Jeff Nelson, UST Class B Operator	jeffrey.nelson@malmstrom.af.mil
Jimmy Sonfelt, UST Class B Operator	jimmy.sonfelt@malmstrom.af.mil
John Corbett, UST Class B Operator	john.corbett.2@us.af.mil

Jonathan Buesch, UST Class B Operator
 Kieth McIlwain, UST Class B Operator
 Kyle Topp, UST Class B Operator
 Michael Murieen, UST Class B Operator
 Michael Stokes, UST Class B Operator
 Patrick Ellis, UST Class B Operator
 Patrick Noppenberg, UST Class B Operator
 Paul Floyd, UST Class B Global Operator
 Paul Floyd, UST Class B Operator
 Paul Ziemba, UST Class B Operator
 Ricardo Andrillon, UST Class B Operator
 Ronald Miller, UST Class B Operator
 Ryan Cox, UST Class B Operator
 Ryan Kofoed, UST Class B Operator
 Shane Hofstad, UST Class B Operator
 Shawn Ogrady, UST Class B Operator
 William Hoffmeister, UST Class B Operator
 William Smith, UST Class A Operator
 William Smith, UST Class B Global Operator

jonathan.buesch@malmstrom.af.mil
 keith.mcilwain@malmstrom.af.mil
 kyle.topp@us.af.mil
 michael.murieen@malmstrom.af.mil
 michael.stokes@malmstrom.af.mil
 patrick.ellis@malmstrom.af.mil
 patrick.noppenberg@malmstrom.af.mil
 paul.floyd@malmstrom.af.mil
 paul.floyd@malmstrom.af.mil
 paul.ziemba@malmstrom.af.mil
 ricardo.andrillon@malmstrom.af.mil
 ronald.miller@malmstrom.af.mil
 ryan.cox@malmstrom.af.mil
 ryan.kofoed@malmstrom.af.mil
 shane.hofstad@malmstrom.af.mil
 shawn.ograde@malmstrom.af.mil
 william.hoffmeister@malmstrom.af.mil
 william.smith@us.af.mil
 william.smith@us.af.mil

Tank Code	01	Tank Age	63	Tank Installed Date	06/02/1962	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	250	Spill Test Date	05/16/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/16/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/11/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	12/10/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 11
 MT Hwy 200
 Simms, MT 59477 Cascade

System Facility ID:25-09051

Facility Code: 23817
Last Inspected On: 04/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	36	Tank Installed Date	05/21/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	256	Spill Test Date	04/04/2024	Piping Installed Date	08/18/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/04/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/04/2024	Line Tightness Test Date	08/20/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/04/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 2
 MT Hwy 200
 Simms, MT 59477 Cascade

System Facility ID:07-09042

Facility Code: 18747
Last Inspected On: 04/18/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	06/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	117	Spill Test Date	04/18/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/18/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/18/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/18/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 6
Road 287
Simms, MT 59477 Cascade

System Facility ID:25-09046

Facility Code: 23812
Last Inspected On: 04/17/2024
Operating Permit Renewal Date: 09/23/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	05/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	251	Spill Test Date	04/17/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/17/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/17/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/17/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 7
 MT Hwy 200
 Simms, MT 59477 Cascade

System Facility ID:25-09047

Facility Code: 23813
Last Inspected On: 04/17/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	05/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4271	Spill Test Date	05/24/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/24/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/24/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/24/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB G 8
 MT Hwy 200
 Simms, MT 59477 Cascade

System Facility ID:25-09048

Facility Code: 23814
Last Inspected On: 04/17/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	05/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	253	Spill Test Date	04/17/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/17/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/17/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/17/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB H 7
 MT Hwy 200
 Simms, MT 59477 Cascade

System Facility ID:07-09058

Facility Code: 18754
Last Inspected On: 04/04/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	34	Tank Installed Date	09/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	124	Spill Test Date	04/04/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/04/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/04/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/04/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Simms

Location: MALMSTROM AFB H 8
 MT Hwy 21
 Simms, MT 59477 Cascade

System Facility ID:25-09059

Facility Code: 23818
Last Inspected On: 04/04/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	34	Tank Installed Date	09/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	257	Spill Test Date	04/04/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/04/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/04/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/04/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Stockett

Location: MALMSTROM AFB A 9
Road 227
Stockett, MT 59480 Cascade

System Facility ID:07-08983

Facility Code: 18744
Last Inspected On: 06/13/2024
Operating Permit Renewal Date: 09/25/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	05/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	114	Spill Test Date	07/17/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/19/2020	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/04/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/04/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Stockett

Location: MALMSTROM AFB I 2
Road 226
Stockett, MT 59480 Cascade

System Facility ID:07-09064

Facility Code: 18756
Last Inspected On: 04/22/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	34	Tank Installed Date	10/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	126	Spill Test Date	04/22/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/22/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/22/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Sun River

Location: MALMSTROM AFB H 4
 US Hwy 89
 Sun River, MT 59483 Cascade

System Facility ID:07-09055

Facility Code: 18751
Last Inspected On: 04/03/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	34	Tank Installed Date	09/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	121	Spill Test Date	04/03/2024	Piping Installed Date	04/20/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/03/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/03/2024	Line Tightness Test Date	04/17/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Sun River

Location: MALMSTROM AFB H 5
US Hwy 89
Sun River, MT 59483 Cascade

System Facility ID:07-09056

Facility Code: 18752
Last Inspected On: 04/04/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	34	Tank Installed Date	09/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	122	Spill Test Date	04/04/2024	Piping Installed Date	05/18/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/04/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/04/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/04/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Ulm

Location: MALMSTROM AFB I 11
I-15
Ulm, MT 59485 Cascade

System Facility ID:07-09073

Facility Code: 18765
Last Inspected On: 04/22/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	34	Tank Installed Date	10/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	134	Spill Test Date	04/19/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/19/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/19/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/19/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Ulm

Location: MALMSTROM AFB I 7
I-15
Ulm, MT 59485 Cascade

System Facility ID:07-09069

Facility Code: 18761
Last Inspected On: 04/19/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	33	Tank Installed Date	05/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	131	Spill Test Date	04/19/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/19/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/19/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/19/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Ulm

Location: MOUNTAIN VIEW CO OP
2 Millegan Rd
Ulm, MT 59485 Cascade

System Facility ID:56-13797

Facility Code: 30484
Last Inspected On: 10/09/2023
Operating Permit Renewal Date: 11/14/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

Operator Contact: Charles Niswanger;David Douglas;Robin Niswanger (406) 866-2030 ddouglas@mountainviewcoop.com

Owner/Operator: Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

- | | |
|--|--------------------------------|
| Charles Niswanger, UST Class A Operator | |
| Charles Niswanger, UST Class B Operator | |
| David Douglas, UST Class A Operator | ddouglas@mountainviewcoop.com |
| Jasmin Nguyen, UST Class B Global Operator | jasmin_nguyen5@hotmail.com |
| Jasmin Nguyen, UST Class B Operator | jasmin_nguyen5@hotmail.com |
| John Malley, UST Class B Operator | jmalley@mountainviewcoop.com |
| Paul Obrien, UST Class B Operator | pobrien@moutainviewcoop.com |
| Robin Niswanger, UST Class A Operator | |
| Scott Bartlett, UST Class B Operator | sbartlett@mountianveiwcoop.com |

Tank Code	01	Tank Age	28	Tank Installed Date	10/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4428	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/27/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/26/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	02/27/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	28	Tank Installed Date	10/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4429	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/27/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel	PLLD Test Date	04/26/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	02/27/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	28	Tank Installed Date	10/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4430	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/27/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/26/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	02/27/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Cascade County in the City of Vaughn

Location: GAS N SHOP 3
133 US Highway 89
Vaughn, MT 59487 Cascade

System Facility ID:07-05008

Facility Code: 18552
Last Inspected On: 01/15/2024
Operating Permit Renewal Date: 06/30/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Gas N Shop Inc (406) 660-9884 gasnshop133@gmail.com

Operator Contact: Gurinderbir Muhar (408) 660-9884 gasnshop133@gmail.com

Owner/Operator: Gas N Shop Inc (406) 660-9884 gasnshop133@gmail.com

Gurinderbir Muhar, UST Class A Operator gasnshop133@gmail.com
Gurinderbir Muhar, UST Class B Global Operator gasnshop133@gmail.com
Sandeep Muhar, UST Class B Operator gasnshop133@gmail.com

Tank Code	05	Tank Age	28	Tank Installed Date	04/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2208	Spill Test Date	08/29/2023	Piping Installed Date	08/22/2023	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/22/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/05/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/05/2024	Line Tightness Test Date	04/23/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/05/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	28	Tank Installed Date	04/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2209	Spill Test Date	08/29/2023	Piping Installed Date	08/22/2023	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/22/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/05/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	4000	ATG Test Date	11/05/2024	Line Tightness Test Date	04/23/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	11/05/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	28	Tank Installed Date	04/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2210	Spill Test Date	08/29/2023	Piping Installed Date	08/22/2023	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/22/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	03/01/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	11/05/2024	Line Tightness Test Date	04/22/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/05/2024			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	08	Tank Age	2	Tank Installed Date	08/22/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6169	Spill Test Date	08/29/2023	Piping Installed Date	08/22/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/22/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/05/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	11/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/05/2024			ATG Type					
Tank Code	09	Tank Age	2	Tank Installed Date	08/22/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6170	Spill Test Date	08/29/2023	Piping Installed Date	08/22/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/22/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	11/05/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	11/05/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/05/2024			ATG Type					

Facility Summary in Cascade County in the City of Vaughn

Location: GLACIER GATEWAY
99 US Hwy 89
Vaughn, MT 59487 Cascade

System Facility ID:56-13783

Facility Code: 30471
Last Inspected On: 11/20/2023
Operating Permit Renewal Date: 04/09/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: NCI Tech Company LLC Vaughn;William Dean (406) 965-9014 bill@scheerswholesale.com

Operator Contact: Eric Bucher;Jake Neil;Kay Neil;Kevin Enochs;Kevin Francis (406) 799-6499;(406) 836-2087 jaken@nciengineering.com;jnkneil@gmail.com;woahmandude@hotmail.com

Owner/Operator: NCI Tech Company LLC Vaughn (406) 965-9014

Owner/Operator: William Dean (406) 965-9014

Aaron McConnell, UST Class B Operator	
Allicia Wick, UST Class B Operator	a.r.zagar@live.com
Amy Evans, UST Class B Operator	fireyember@yahoo.com
Andrea Bowie, UST Class B Operator	
Barbara Matthews, UST Class B Operator	
Brenda Pischke, UST Class B Global Operator	
Bridget Bowen, UST Class B Operator	b_breezy34@yahoo.com
Christine Igel, UST Class B Operator	
Debbie Pengilly, UST Class B Operator	
Eric Bucher, UST Class A Operator	
Helen Taylor, UST Class B Global Operator	hannmadetattoo@yahoo.com
Jake Neil, UST Class A Operator	jaken@nciengineering.com
Jake Neil, UST Class B Operator	jaken@nciengineering.com
Janet Jensen, UST Class B Operator	b_breezy34@yahoo.com
Jenifer Colden, UST Class B Operator	
Jenna Blair, UST Class B Operator	
Josh Wick, UST Class B Operator	
Justin Vallier, UST Class B Operator	
Kay Neil, UST Class A Operator	jnkneil@gmail.com
Kay Neil, UST Class B Operator	jnkneil@gmail.com
Kevin Enochs, UST Class A Operator	
Kevin Francis, UST Class A Operator	woahmandude@hotmail.com
Leigh Wilson, UST Class B Operator	agfjk_1@msn.com
Marilyn Hutton, UST Class B Global Operator	
Matthew Schnittgen, UST Class B Operator	schnittgenm@hotmail.com

Roy Powell, UST Class B Operator
 Shalina Abrams, UST Class B Operator
 Vicki Ferda, UST Class B Operator
 Vicki Kriedeman, UST Class B Operator

roypowell.d@gmail.com
 shalina.johnson@yahoo.com
 iluvdavidday@yahoo.com
 vickikriedeman@yahoo.com

Tank Code	01	Tank Age	28	Tank Installed Date	06/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3444	Spill Test Date	11/17/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	11/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/16/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	02	Tank Age	28	Tank Installed Date	06/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3445	Spill Test Date	02/01/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	11/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/16/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	03	Tank Age	28	Tank Installed Date	06/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3446	Spill Test Date	11/17/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/17/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	04	Tank Age	28	Tank Installed Date	06/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3447	Spill Test Date	11/17/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/17/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/16/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Cascade County in the City of Vaughn

Location: MALMSTROM AFB H 3
I-15
Vaughn, MT 59487 Cascade

System Facility ID:50-09054

Facility Code: 28887
Last Inspected On: 04/03/2024
Operating Permit Renewal Date: 09/23/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	34	Tank Installed Date	09/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	313	Spill Test Date	04/03/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/03/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/03/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/03/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Vaughn

Location: MALMSTROM AFB I 10
I-15
Vaughn, MT 59487 Cascade

System Facility ID:07-09072

Facility Code: 18764
Last Inspected On: 04/22/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	34	Tank Installed Date	08/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	133	Spill Test Date	04/22/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/22/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/22/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/22/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Vaughn

Location: MALMSTROM AFB J 10
I-15
Vaughn, MT 59487 Cascade

System Facility ID:50-09083

Facility Code: 28893
Last Inspected On: 04/16/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	34	Tank Installed Date	08/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	319	Spill Test Date	04/16/2024	Piping Installed Date	06/02/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/16/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/16/2024	Line Tightness Test Date	05/29/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Vaughn

Location: MALMSTROM AFB J 8
I-15
Vaughn, MT 59487 Cascade

System Facility ID:07-09081

Facility Code: 18766
Last Inspected On: 04/15/2024
Operating Permit Renewal Date: 09/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	34	Tank Installed Date	08/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	135	Spill Test Date	04/15/2024	Piping Installed Date	08/11/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/15/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/15/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/15/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Cascade County in the City of Vaughn

Location: MALMSTROM AFB J 9
I-15
Vaughn, MT 59487 Cascade

System Facility ID:07-09082

Facility Code: 18767
Last Inspected On: 04/15/2024
Operating Permit Renewal Date: 06/23/2020

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: 341 CES CEANQ (406) 731-6188

Operator Contact: Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

Owner/Operator: 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

Tank Code	02	Tank Age	34	Tank Installed Date	08/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	136	Spill Test Date		Piping Installed Date	08/28/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	08/28/2018	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	5	Tank Installed Date	05/20/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5925	Spill Test Date	04/15/2024	Piping Installed Date	08/28/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/15/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible

Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	04/15/2024	Line Tightness Test Date	06/04/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	04/15/2024			ATG Type					