

**Facility Summary in Fallon County in the City of Baker**

**Location:** BAKER FARMERS UNION OIL  
303 W Montana Ave  
Baker, MT 59313 Fallon

System Facility ID:13-09960

**Facility Code:** 20017  
**Last Inspected On:** 01/17/2024  
**Operating Permit Renewal Date:** 05/16/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Farmers Union Oil Co Baker (406) 778-2519

**Operator Contact:** Tonya England (541) 643-4540 cenexoffice@midrivers.com

**Owner/Operator:** Farmers Union Oil Co Baker (406) 778-2519

Kelly Brookes, UST Class B Operator	
Kelly Brookes, UST Class B Operator	
Tonya England, UST Class A Operator	cenexoffice@midrivers.com
Tonya England, UST Class A Operator	cenexoffice@midrivers.com
Tonya England, UST Class B Global Operator	cenexoffice@midrivers.com
Tonya England, UST Class B Global Operator	cenexoffice@midrivers.com
Tonya England, UST Class B Operator	cenexoffice@midrivers.com
Tonya England, UST Class B Operator	cenexoffice@midrivers.com

<b>Tank Code</b>	12	<b>Tank Age</b>	8	<b>Tank Installed Date</b>	08/01/2017	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5693	<b>Spill Test Date</b>	09/08/2022	<b>Piping Installed Date</b>	08/01/2017	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	20000	<b>ATG Test Date</b>	04/15/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/08/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
<b>Tank Code</b>	13	<b>Tank Age</b>	8	<b>Tank Installed Date</b>	08/01/2017	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5694	<b>Spill Test Date</b>	09/08/2022	<b>Piping Installed Date</b>	08/01/2017	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible

<b>Product</b>	Diesel	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	14000	<b>ATG Test Date</b>	04/15/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/08/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
<b>Tank Code</b>	14	<b>Tank Age</b>	8	<b>Tank Installed Date</b>	08/01/2017	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5695	<b>Spill Test Date</b>	09/08/2022	<b>Piping Installed Date</b>	08/01/2017	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	10/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/08/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
<b>Tank Code</b>	15	<b>Tank Age</b>	8	<b>Tank Installed Date</b>	08/01/2017	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5696	<b>Spill Test Date</b>	09/08/2022	<b>Piping Installed Date</b>	08/01/2017	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	8000	<b>ATG Test Date</b>	04/15/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/08/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
<b>Tank Code</b>	16	<b>Tank Age</b>	8	<b>Tank Installed Date</b>	08/01/2017	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5697	<b>Spill Test Date</b>	09/08/2022	<b>Piping Installed Date</b>	08/01/2017	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No

<b>Capacity</b>	6000	<b>ATG Test Date</b>	10/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/08/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
<b>Tank Code</b>	17	<b>Tank Age</b>	8	<b>Tank Installed Date</b>	08/01/2017	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Positive Shutoff
<b>Tag Number</b>	5702	<b>Spill Test Date</b>	09/08/2022	<b>Piping Installed Date</b>	08/01/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Other	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/21/2017	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	DEF (Not Regulated)	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	ELLD 0.2;ELLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring;Not Listed	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/08/2022			<b>ATG Type</b>	Veeder Root/TLS-450				
<b>Tank Code</b>	06	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	11/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	973	<b>Spill Test Date</b>	10/24/2023	<b>Piping Installed Date</b>	05/30/2012	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>	08/28/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	10/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/15/2024			<b>ATG Type</b>	Veeder Root/TLS-450				
<b>Tank Code</b>	07	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	11/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	974	<b>Spill Test Date</b>	10/06/2022	<b>Piping Installed Date</b>	05/30/2012	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>	08/28/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	10/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	04/15/2024			<b>ATG Type</b>	Veeder Root/TLS-450				
<b>Tank Code</b>	08	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	11/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	975	<b>Spill Test Date</b>	04/15/2024	<b>Piping Installed Date</b>	05/30/2012	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>	08/28/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	10/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/15/2024			<b>ATG Type</b>	Veeder Root/TLS-450				
<b>Tank Code</b>	09	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	11/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	976	<b>Spill Test Date</b>	10/06/2022	<b>Piping Installed Date</b>	05/30/2012	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>	08/28/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	10/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/15/2024			<b>ATG Type</b>	Veeder Root/TLS-450				
<b>Tank Code</b>	10	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	11/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	977	<b>Spill Test Date</b>	10/06/2022	<b>Piping Installed Date</b>	05/30/2012	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>	08/28/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	10/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/15/2024			<b>ATG Type</b>	Veeder Root/TLS-450				
<b>Tank Code</b>	11	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	11/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	978	<b>Spill Test Date</b>	10/06/2022	<b>Piping Installed Date</b>	05/30/2012	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No

<b>Tank Status</b>	<b>Currently in Use</b>	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	10/24/2023	<b>Tank/Piping CP Test Date</b>	08/28/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	04/15/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/15/2024			<b>ATG Type</b>	Veeder Root/TLS-450				

**Facility Summary in Fallon County in the City of Baker**

**Location:** FALLON COUNTY AIRPORT  
Fallon County Airport  
Baker, MT 59313 Fallon

System Facility ID:13-10696

**Facility Code:** 20018  
**Last Inspected On:** 05/27/2021  
**Operating Permit Renewal Date:** 06/21/2024

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Fallon County (406) 778-3508

**Operator Contact:** Roger Meggers (406) 778-3508 bakerair@midrivers.com

Roger Meggers, UST Class A Operator  
Roger Meggers, UST Class B Operator

bakerair@midrivers.com  
bakerair@midrivers.com

<b>Tank Code</b>	01	<b>Tank Age</b>	37	<b>Tank Installed Date</b>	01/01/1988	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	894	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Jet Fuel (Jet-A, Jet-A1, JP5)	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/13/2012	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.1	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	05/27/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	OPW/EECO 1500				
<b>Tank Code</b>	02	<b>Tank Age</b>	37	<b>Tank Installed Date</b>	01/01/1988	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	895	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Aviation Gas	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/13/2012	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.1	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	05/27/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	OPW/EECO 1500				

**Facility Summary in Fallon County in the City of Baker**

**Location:** FALLON COUNTY MEDICAL COMPLEX  
225 S 3rd St W  
Baker, MT 59313 Fallon

System Facility ID:60-15072

**Facility Code:** 30843  
**Last Inspected On:** 06/06/2023  
**Operating Permit Renewal Date:** 07/13/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Fallon Medical Complex Inc (406) 778-3331

**Operator Contact:** Brad Kings;Tonna Hartman;Fallon Medical Complex Inc (406) 778-5419;(406) 778-3331;(406) 978-5220 bekings@fallonmedical.org;fmcmaintenance@fallonmedical.org

**Owner/Operator:** Fallon Medical Complex Inc (406) 778-3331

Brad Kings, UST Class A Operator  
John Zook, UST Class B Global Operator  
John Zook, UST Class B Operator  
Tonna Hartman, UST Class A Operator  
Tonna Hartman, UST Class B Global Operator

bekings@fallonmedical.org  
jzook894@yahoo.com  
jzook894@yahoo.com  
fmcmaintenance@fallonmedical.org  
fmcmaintenance@fallonmedical.org

<b>Tank Code</b>	01	<b>Tank Age</b>	19	<b>Tank Installed Date</b>	01/02/2006	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5125	<b>Spill Test Date</b>	08/22/2023	<b>Piping Installed Date</b>	04/25/2007	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/22/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2500	<b>ATG Test Date</b>	06/06/2023	<b>Line Tightness Test Date</b>	06/24/2014	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/22/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Fallon County in the City of Baker**

**Location:** FALLON COUNTY RD DEPT  
122 E Center Ave  
Baker, MT 59313 Fallon

System Facility ID:13-01687

**Facility Code:** 19967  
**Last Inspected On:** 04/01/2024  
**Operating Permit Renewal Date:** 08/03/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Fallon County Road Dept (406) 778-2019

**Operator Contact:** Alba Higgins;Bobby Wiedmer (406) 978-2015 falcord@midrivers.com

**Owner/Operator:** Fallon County Road Dept (406) 778-2019

- |                                     |                          |
|-------------------------------------|--------------------------|
| Alba Higgins, UST Class A Operator  | falcord@midrivers.com    |
| Alba Higgins, UST Class A Operator  | falcord@midrivers.com    |
| Alba Higgins, UST Class B Operator  | falcord@midrivers.com    |
| Alba Higgins, UST Class B Operator  | falcord@midrivers.com    |
| Bobby Wiedmer, UST Class A Operator | falcord@midrivers.com    |
| Bobby Wiedmer, UST Class A Operator | falcord@midrivers.com    |
| Bobby Wiedmer, UST Class B Operator | falcord@midrivers.com    |
| Bobby Wiedmer, UST Class B Operator | falcord@midrivers.com    |
| Carl Overland, UST Class B Operator | blackycarlata1@gmail.com |
| Carl Overland, UST Class B Operator | blackycarlata1@gmail.com |
| Mitch Overn, UST Class B Operator   | falcord@midrivers.com    |
| Mitch Overn, UST Class B Operator   | falcord@midrivers.com    |

<b>Tank Code</b>	05	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	06/09/1993	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	896	<b>Spill Test Date</b>	03/05/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/13/2012	<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/05/2024			<b>ATG Type</b>					
<b>Tank Code</b>	06	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	06/01/1993	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	897	<b>Spill Test Date</b>	03/05/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No



<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/13/2012	<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/05/2024			<b>ATG Type</b>					
<b>Tank Code</b>	07	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	06/01/1993	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	898	<b>Spill Test Date</b>	03/05/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/13/2012	<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	3000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/05/2024			<b>ATG Type</b>					

**Facility Summary in Fallon County in the City of Baker**

**Location:** GENERATIONAL PROPERTIES RENTAL  
908 E Montana Ave  
Baker, MT 59313-0000 Fallon

System Facility ID:13-08221

**Facility Code:** 20008  
**Last Inspected On:** 07/01/2024  
**Operating Permit Renewal Date:** 07/01/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** GENERATIONAL PROPERTIES LLC (406) 891-0979 generationalpropertiesmt@gmail.com

**Operator Contact:** Michael Miller;Promise Miller (406) 772-5828 flatlineincmg@gmail.com;promisemiller@hotmail.com

**Owner/Operator:** GENERATIONAL PROPERTIES LLC (406) 891-0979 generationalpropertiesmt@gmail.com  
 Michael Miller, UST Class A Operator flatlineincmg@gmail.com  
 Michael Miller, UST Class B Operator flatlineincmg@gmail.com  
 Promise Miller, UST Class A Operator promisemiller@hotmail.com  
 Promise Miller, UST Class B Operator promisemiller@hotmail.com

<b>Tank Code</b>	04	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	08/01/1999	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4083	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/15/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	05	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	08/01/1999	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4084	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/15/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco/EMC Basic				

<b>Tank Code</b>	S6	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	08/01/1999	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	4085	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	06/13/2018	<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/12/2018	<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5500	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Fallon County in the City of Baker**

**Location:** J and A MINI STORE  
116 W Montana Ave  
Baker, MT 59313 Fallon

System Facility ID:13-00685

**Facility Code:** 19958  
**Last Inspected On:** 12/12/2023  
**Operating Permit Renewal Date:** 12/16/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** ARMH Group LLC;Rose Heiser (406) 778-2411;(406) 891-0229 jandaministore@gmail.com;rosemorast98@hotmail.com

**Operator Contact:** Rose Heiser (406) 891-0229 rosemorast98@hotmail.com

**Owner/Operator:** ARMH Group LLC (406) 778-2411 jandaministore@gmail.com

**Owner/Operator:** Rose Heiser (406) 778-2411 jandaministore@gmail.com

Rose Heiser, UST Class A Operator rosemorast98@hotmail.com

Rose Heiser, UST Class B Global Operator rosemorast98@hotmail.com

<b>Tank Code</b>	05	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	05/24/1989	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1447	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	12/12/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	4042	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	06	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	05/24/1989	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1448	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	12/12/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	9954	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

<b>Tank Code</b>	07	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	05/24/1989	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1449	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	12/12/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	10003	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Fallon County in the City of Baker**

**Location:** MUFFYS  
19 E Montana Ave  
Baker, MT 59313 Fallon

System Facility ID:13-00227

**Facility Code:** 19954  
**Last Inspected On:** 11/01/2024  
**Operating Permit Renewal Date:** 11/13/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Monica Stark (406) 978-2643 muffysirish@gmail.com

**Operator Contact:** Monica Stark (406) 978-2643 muffysirish@gmail.com

**Owner/Operator:** Monica Stark (406) 978-2643 muffysirish@gmail.com

Monica Stark, UST Class A Operator muffysirish@gmail.com  
 Monica Stark, UST Class B Operator muffysirish@gmail.com  
 Stacey Sterns, UST Class B Operator sternsstacey03@gmail.com  
 Stacey Sterns, UST Class B Operator sternsstacey03@gmail.com

<b>Tank Code</b>	05	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	04/13/1989	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	3519	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>	12/03/2018	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/01/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	12/03/2018	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	06	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	3520	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>	12/03/2018	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/01/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	12/03/2018	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco/EMC Basic				

**Facility Summary in Fallon County in the City of Baker**

**Location:** PRAIRIE FUELS  
176 E Milwaukee Ave  
Baker, MT 59313 Fallon

System Facility ID:13-07740

**Facility Code:** 20000  
**Last Inspected On:** 07/01/2024  
**Operating Permit Renewal Date:** 10/01/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Prairie Fuels (406) 778-3245

**Operator Contact:** Sharon Tronstad merwininc@midrivers.com

**Owner/Operator:** Prairie Fuels (406) 778-3245

Sharon Tronstad, UST Class A Operator  
Sharon Tronstad, UST Class B Operator

merwininc@midrivers.com  
merwininc@midrivers.com

<b>Tank Code</b>	S05	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass	<b>Overfill Types</b>	
<b>Tag Number</b>	3197	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	12/12/2014	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/01/2024	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	17000	<b>ATG Test Date</b>	07/01/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S06	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass	<b>Overfill Types</b>	
<b>Tag Number</b>	3198	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	07/20/2015	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/01/2024	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8500	<b>ATG Test Date</b>	07/01/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S07	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass	<b>Overfill Types</b>	

Tag Number	3199	Spill Test Date		Piping Installed Date	12/12/2014	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/31/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S08	Tank Age	29	Tank Installed Date	09/01/1996	Tank Material	Bare Steel	Piping Material	Fiberglass	Overfill Types	
Tag Number	3200	Spill Test Date		Piping Installed Date	12/12/2014	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/31/2024	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S09	Tank Age	29	Tank Installed Date	09/01/1996	Tank Material	Bare Steel	Piping Material	Fiberglass	Overfill Types	
Tag Number	3201	Spill Test Date		Piping Installed Date	12/12/2014	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	11/18/2020	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S10	Tank Age	29	Tank Installed Date	09/01/1996	Tank Material	Bare Steel	Piping Material	Fiberglass	Overfill Types	
Tag Number	3202	Spill Test Date		Piping Installed Date	12/12/2014	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	11/18/2020	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					