

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** BIGFORK OUTDOOR RENTALS INC  
110 Swan River Rd  
Bigfork, MT 59911-6329 Flathead

System Facility ID:15-07361

**Facility Code:** 20728  
**Last Inspected On:** 01/04/2024  
**Operating Permit Renewal Date:** 01/03/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Bigfork Outdoor Rentals Inc;Dalen Whalen (406) 396-8185 dwhalen9@gmail.com

**Operator Contact:** Dale Whalen (406) 396-8185 dalewhalen@gmail.com

**Owner/Operator:** Bigfork Outdoor Rentals Inc (406) 396-8185 dwhalen9@gmail.com

**Owner/Operator:** Dalen Whalen (406) 396-8185 dwhalen9@gmail.com

- Dale Whalen, UST Class A Operator dalewhalen@gmail.com
- Dale Whalen, UST Class A Operator dalewhalen@gmail.com
- Dale Whalen, UST Class B Global Operator dalewhalen@gmail.com
- Dale Whalen, UST Class B Global Operator dalewhalen@gmail.com
- Dale Whalen, UST Class B Operator dalewhalen@gmail.com
- Dale Whalen, UST Class B Operator dalewhalen@gmail.com

<b>Tank Code</b>	06	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	11/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	3498	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	01/03/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	EMCO Electronics/EECO 1500				
<b>Tank Code</b>	07	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	11/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	3499	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic

<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	01/03/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.1; Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	3000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	EMCO Electronics/EECO 1500				
<b>Tank Code</b>	08	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	11/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	3500	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	01/03/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.1; Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	3000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	EMCO Electronics/EECO 1500				

### Facility Summary in Flathead County in the City of Bigfork

**Location:** BIGFORK STAGE STOP INC  
8263 MT Hwy 35  
Bigfork, MT 59911-3518 Flathead

System Facility ID:56-13885

**Facility Code:** 30560  
**Last Inspected On:** 10/05/2022  
**Operating Permit Renewal Date:** 12/02/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Bigfork Stage Stop Inc (406) 837-5858

**Operator Contact:** Vicky Miller;Bigfork Stage Stop Inc (406) 837-1551;(406) 837-5858 vicky@stage-stop.com

**Owner/Operator:** Bigfork Stage Stop Inc (406) 837-5858

Vicky Miller, UST Class A Operator

vicky@stage-stop.com

Vicky Miller, UST Class B Global Operator

vicky@stage-stop.com

<b>Tank Code</b>	01	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3531	<b>Spill Test Date</b>	04/07/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	10/05/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/07/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	02	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3532	<b>Spill Test Date</b>	04/07/2022	<b>Piping Installed Date</b>	11/24/2008	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	10/05/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/07/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	03	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve

<b>Tag Number</b>	3533	<b>Spill Test Date</b>	04/07/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	10/05/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/07/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** CALUMET CARDLOCK  
8111 MT Hwy 35  
Bigfork, MT 59911-3588 Flathead

System Facility ID:15-09801

**Facility Code:** 20806  
**Last Inspected On:** 01/27/2025  
**Operating Permit Renewal Date:** 03/18/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Bigfork Properties LLC (406) 837-4550

**Operator Contact:** Marcus Balgos;Bigfork Properties LLC (406) 837-5010;(406) 837-4550 bhf\_marcus@centurytel.net

**Owner/Operator:** Bigfork Properties LLC (406) 837-4550

Marcus Balgos, UST Class A Operator  
Marcus Balgos, UST Class B Operator

bhf\_marcus@centurytel.net  
bhf\_marcus@centurytel.net

<b>Tank Code</b>	01	<b>Tank Age</b>	44	<b>Tank Installed Date</b>	05/01/1981	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	481	<b>Spill Test Date</b>	10/08/2024	<b>Piping Installed Date</b>	02/02/2022	<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/08/2024	<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/08/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	10/08/2024	<b>Line Tightness Test Date</b>	02/02/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/08/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	44	<b>Tank Installed Date</b>	05/01/1981	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	482	<b>Spill Test Date</b>	11/14/2024	<b>Piping Installed Date</b>	02/02/2022	<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	02/02/2022	<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/08/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	10/08/2024	<b>Line Tightness Test Date</b>	02/02/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/08/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

<b>Tank Code</b>	03	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	07/01/1993	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	483	<b>Spill Test Date</b>	10/08/2024	<b>Piping Installed Date</b>	02/02/2022	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	02/02/2022	<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/08/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	10/08/2024	<b>Line Tightness Test Date</b>	02/02/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/08/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	04	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	04/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	484	<b>Spill Test Date</b>	11/14/2024	<b>Piping Installed Date</b>	02/02/2022	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/08/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	10/08/2024	<b>Line Tightness Test Date</b>	02/02/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/14/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	05	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	04/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	485	<b>Spill Test Date</b>	10/08/2024	<b>Piping Installed Date</b>	02/02/2022	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	02/02/2022	<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/08/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	10/08/2024	<b>Line Tightness Test Date</b>	02/02/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/08/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** EAGLE BEND YACHT HARBOR  
371 Eagle Bend Dr  
Bigfork, MT 59911-6210 Flathead

System Facility ID:15-13152

**Facility Code:** 21034  
**Last Inspected On:** 05/26/2022  
**Operating Permit Renewal Date:** 06/01/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Eagle Bend Yacht Harbor Boat Slip Owners Association

**Operator Contact:** Dave Roberts

**(406) 253-2840**

**droberts@westernmountains.com**

**Owner/Operator:** Eagle Bend Yacht Harbor Boat Slip Owners Association

Dave Roberts, UST Class A Operator

droberts@westernmountains.com

Dave Roberts, UST Class B Operator

droberts@westernmountains.com

<b>Tank Code</b>	01	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	07/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4013	<b>Spill Test Date</b>	06/02/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	05/26/2022	<b>Line Tightness Test Date</b>	08/02/2010	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/31/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-250				
<b>Tank Code</b>	02	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	07/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4014	<b>Spill Test Date</b>	05/26/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>	05/26/2022	<b>Line Tightness Test Date</b>	08/02/2010	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/31/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-250				

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** FERNDALE MARKET  
1845 MT Hwy 209  
Bigfork, MT 59911-6540 Flathead

System Facility ID:15-07199

**Facility Code:** 20719  
**Last Inspected On:** 04/27/2023  
**Operating Permit Renewal Date:** 08/08/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Griggs Ferndale LLC (406) 837-5597 invoices@ferndalemarket.net

**Operator Contact:** Brian Truckey;Griggs Ferndale LLC;Robert Dileo;Ferndale Market (406) 407-0743;(406) 837-5597;(406) 837-5597 btruckey@gmail.com;invoices@ferndalemarket.net;dileorobert@gmail.com

**Owner/Operator:** Griggs Ferndale LLC (406) 837-5597 invoices@ferndalemarket.net  
 Brian Truckey, UST Class A Operator invoices@ferndalemarket.net  
 Brian Truckey, UST Class B Operator invoices@ferndalemarket.net  
 Robert Dileo, UST Class A Operator dileorobert@gmail.com  
 Robert Dileo, UST Class B Operator dileorobert@gmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	49	<b>Tank Installed Date</b>	04/28/1976	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3254	<b>Spill Test Date</b>	04/27/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	04/27/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	04/27/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/27/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	48	<b>Tank Installed Date</b>	04/28/1977	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3255	<b>Spill Test Date</b>	04/27/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	04/27/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	04/27/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No



		<b>Overfill Test Date</b>	04/27/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	03	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	06/01/1993	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3256	<b>Spill Test Date</b>	09/12/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	04/27/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	04/27/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/27/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	04	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	06/01/1993	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3257	<b>Spill Test Date</b>	09/12/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	04/27/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	04/27/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/27/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** FLATHEAD LAKE LODGE  
150 Flathead Lodge Rd  
Bigfork, MT 59911-7419 Flathead

System Facility ID:15-04551

**Facility Code:** 20643  
**Last Inspected On:** 02/05/2021  
**Operating Permit Renewal Date:** 02/02/2024

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Flathead Lake Lodge

**Operator Contact:** Douglas Averill

**(406) 837-4391**

**info@flatheadlakelodge.com**

Douglas Averill, UST Class A Operator  
Douglas Averill, UST Class B Operator

info@flatheadlakelodge.com  
info@flatheadlakelodge.com

<b>Tank Code</b>	04	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	05/14/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1826	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	01/10/2013	<b>Primary Tank Leak Detection</b>	Manual Tank Gauging; Tank Tightness Testing	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	05	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	06/01/1994	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1827	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	01/10/2013	<b>Primary Tank Leak Detection</b>	Manual Tank Gauging; Tank Tightness Testing	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	1200	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** MARINA CAY RESORT  
180 Vista Lane  
Bigfork, MT 59911-6162 Flathead

System Facility ID:15-03002

**Facility Code:** 20591  
**Last Inspected On:** 09/12/2024  
**Operating Permit Renewal Date:** 10/14/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Ken Wheeler;Marina Cay Resort

**(406) 837-5861**

**k.wheeler@frontlineag.com&gt;**

**Operator Contact:**

**Owner/Operator:** Ken Wheeler,Marina Cay Resort

**(406) 837-5861**

**k.wheeler@frontlineag.com>**

<b>Tank Code</b>	02	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	05/05/1999	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4067	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	03	<b>Tank Age</b>	18	<b>Tank Installed Date</b>	07/25/2007	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	5110	<b>Spill Test Date</b>	09/12/2024	<b>Piping Installed Date</b>	02/05/2006	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/08/2015	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	10/21/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.1	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	09/12/2024	<b>Line Tightness Test Date</b>	10/21/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/12/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** MEADOWLARK ENTERPRISES LLC  
20221 MT Hwy 35  
Bigfork, MT 59911-7254 Flathead

System Facility ID:56-14137

**Facility Code:** 30773  
**Last Inspected On:** 04/19/2023  
**Operating Permit Renewal Date:** 07/02/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** Meadowlark Enterprises LLC (415) 225-2249 michael@baumer.us

---

**Operator Contact:** Michael Baumer;Stephen Baumer;Meadowlark Enterprises LLC (415) 225-2249 michael@baumer.us;stephen@baumer.us;michael@baumer.us

---

**Owner/Operator:** Meadowlark Enterprises LLC (415) 225-2249 michael@baumer.us

Michael Baumer, UST Class A Operator michael@baumer.us  
 Michael Baumer, UST Class B Operator michael@baumer.us  
 Stephen Baumer, UST Class A Operator michael@baumer.us  
 Stephen Baumer, UST Class B Operator michael@baumer.us

<b>Tank Code</b>	01	<b>Tank Age</b>	20	<b>Tank Installed Date</b>	03/21/2005	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5024	<b>Spill Test Date</b>	09/15/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/12/2012	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/11/2011	<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>	04/19/2023	<b>Line Tightness Test Date</b>	06/30/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/19/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** MONTANA RANCH LLC  
1463 Hwy 83  
Bigfork, MT 59911 Flathead

System Facility ID:60-15198

**Facility Code:** 30919  
**Last Inspected On:** 02/05/2024  
**Operating Permit Renewal Date:** 03/23/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Montana Ranch LLC Bigfork (406) 755-0264 mattc@sabey.com

**Operator Contact:** Matt Cottle (406) 253-8403 mattc@sabey.com

**Owner/Operator:** Montana Ranch LLC Bigfork (406) 755-0264 mattc@sabey.com

Matt Cottle, UST Class A Operator

mattc@sabey.com

Matt Cottle, UST Class B Operator

mattc@sabey.com

<b>Tank Code</b>	01	<b>Tank Age</b>	14	<b>Tank Installed Date</b>	08/29/2011	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5327	<b>Spill Test Date</b>	02/05/2024	<b>Piping Installed Date</b>	08/29/2011	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2500	<b>ATG Test Date</b>	02/05/2024	<b>Line Tightness Test Date</b>	10/06/2011	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	02/05/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/EMC Basic				
<b>Tank Code</b>	02	<b>Tank Age</b>	14	<b>Tank Installed Date</b>	08/29/2011	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5328	<b>Spill Test Date</b>	02/05/2024	<b>Piping Installed Date</b>	08/29/2011	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2500	<b>ATG Test Date</b>	02/05/2024	<b>Line Tightness Test Date</b>	10/06/2011	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	02/05/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/EMC Basic				

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** O'CONNELLS QWICK STOP  
21385 MT Hwy 83  
Bigfork, MT 59911-7811 Flathead

System Facility ID:24-05644

**Facility Code:** 22977  
**Last Inspected On:** 10/08/2023  
**Operating Permit Renewal Date:** 11/26/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** PH and J Enterprises LLC;Preston O'Connell (406) 886-2300 froggitha@gmail.com

**Operator Contact:** Keith Broere (406) 360-4417 kbroere@aetmt.com

**Owner/Operator:** PH and J Enterprises LLC (406) 886-2300 froggitha@gmail.com  
**Owner/Operator:** Preston O'Connell (406) 886-2300 froggitha@gmail.com  
 Keith Broere, UST Class A Operator kbroere@aetmt.com  
 Keith Broere, UST Class B Operator kbroere@aetmt.com

<b>Tank Code</b>	04	<b>Tank Age</b>	39	<b>Tank Installed Date</b>	05/07/1986	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3325	<b>Spill Test Date</b>	10/06/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	10/06/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/06/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	10/06/2023	<b>Line Tightness Test Date</b>	10/06/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/06/2023			<b>ATG Type</b>	Incon/TS-1000				
<b>Tank Code</b>	05	<b>Tank Age</b>	39	<b>Tank Installed Date</b>	05/07/1986	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3326	<b>Spill Test Date</b>	10/06/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	10/06/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/06/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	10/06/2023	<b>Line Tightness Test Date</b>	10/06/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/06/2023			<b>ATG Type</b>	Incon/TS-1000				
<b>Tank Code</b>	06	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	07/01/1996	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve

<b>Tag Number</b>	3327	<b>Spill Test Date</b>	10/06/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	10/06/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/06/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	10/06/2023	<b>Line Tightness Test Date</b>	10/06/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/06/2023			<b>ATG Type</b>	Incon/TS-1000				
<b>Tank Code</b>	07	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	07/01/1996	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3328	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/06/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	03/08/2011	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Incon/TS-1000				

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** PAPAS MARKET  
14535 MT Hwy 35  
Bigfork, MT 59911 Flathead

System Facility ID:24-06085

**Facility Code:** 22990  
**Last Inspected On:** 09/06/2023  
**Operating Permit Renewal Date:** 03/28/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** GEMBALA CORP (406) 837-4884

**Operator Contact:** Shawn Gembala (406) 837-4884 papasmarket.gembala@gmail.com

**Owner/Operator:** GEMBALA CORP (406) 837-4884

Shawn Gembala, UST Class A Operator

Shawn Gembala, UST Class B Operator

Shawn Kneeland, UST Class B Global Operator

papasmarket.gembala@gmail.com

papasmarket.gembala@gmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	41	<b>Tank Installed Date</b>	01/30/1984	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1279	<b>Spill Test Date</b>	09/06/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	09/06/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/06/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	11/30/2023	<b>Line Tightness Test Date</b>	09/06/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/06/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-300				
<b>Tank Code</b>	02	<b>Tank Age</b>	41	<b>Tank Installed Date</b>	01/30/1984	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1280	<b>Spill Test Date</b>	09/06/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	09/06/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/06/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	11/30/2023	<b>Line Tightness Test Date</b>	09/06/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/06/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-300				
<b>Tank Code</b>	03	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	05/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve



<b>Tag Number</b>	1281	<b>Spill Test Date</b>	09/06/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	09/06/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/06/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	11/30/2023	<b>Line Tightness Test Date</b>	05/13/2016	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/06/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-300				

**Facility Summary in Flathead County in the City of Bigfork**

**Location:** YOUR TURN CONVENIENCE STOP  
7505 MT Hwy 35  
Bigfork, MT 59911-6215 Flathead

System Facility ID:15-02482

**Facility Code:** 20582  
**Last Inspected On:** 05/03/2023  
**Operating Permit Renewal Date:** 08/08/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** White Enterprises (406) 837-6170 yourturnmercantile@hotmail.com

**Operator Contact:** Charity Neal;Your Turn Convenience Stop (406) 837-6170 ytm1993@yahoo.com

**Owner/Operator:** White Enterprises (406) 837-6170 yourturnmercantile@hotmail.com

Charity Neal, UST Class A Operator ytm1993@yahoo.com  
Charity Neal, UST Class B Operator ytm1993@yahoo.com

<b>Tank Code</b>	06	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	01/10/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3185	<b>Spill Test Date</b>	12/21/2021	<b>Piping Installed Date</b>	07/25/2013	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/23/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/02/2023	<b>Line Tightness Test Date</b>	02/03/2011	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/05/2022			<b>ATG Type</b>	Incon/TS-550 EVO				
<b>Tank Code</b>	07	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	01/10/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3186	<b>Spill Test Date</b>	05/03/2023	<b>Piping Installed Date</b>	07/25/2013	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/23/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/02/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	02/03/2011	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/03/2023			<b>ATG Type</b>	Incon/TS-550 EVO				
<b>Tank Code</b>	08	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	01/10/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve

<b>Tag Number</b>	3187	<b>Spill Test Date</b>	05/03/2023	<b>Piping Installed Date</b>	07/25/2013	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/23/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/03/2023	<b>Line Tightness Test Date</b>	02/03/2011	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/03/2023			<b>ATG Type</b>	Incon/TS-550 EVO				
<b>Tank Code</b>	09	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	11/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3188	<b>Spill Test Date</b>	12/22/2021	<b>Piping Installed Date</b>	07/25/2013	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/23/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	05/02/2023	<b>Line Tightness Test Date</b>	02/03/2011	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/05/2022			<b>ATG Type</b>	Incon/TS-550 EVO				

**Facility Summary in Flathead County in the City of Columbia Falls**

**Location:** CSV CARDLOCK NORTH  
195 Truck Route Rd  
Columbia Falls, MT 59912 Flathead

System Facility ID:15-12972

**Facility Code:** 21018  
**Last Inspected On:** 08/22/2023  
**Operating Permit Renewal Date:** 10/02/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** City Service Valcon LLC

**tamara.noble@cityservicevalcon.com**

**Operator Contact:** Kary Tonjum

**(406) 755-4321**

**Owner/Operator:** City Service Valcon LLC

**tamara.noble@cityservicevalcon.com**

Kary Tonjum, UST Class A Operator

Kary Tonjum, UST Class B Global Operator

<b>Tank Code</b>	01	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	12/15/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4404	<b>Spill Test Date</b>	05/03/2023	<b>Piping Installed Date</b>	10/02/2014	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/03/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/03/2023	<b>Tank/Piping CP Test Date</b>	05/03/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	05/03/2023	<b>Line Tightness Test Date</b>	09/29/2014	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/03/2023			<b>ATG Type</b>	Veeder Root/TLS-450				
<b>Tank Code</b>	04	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	11/15/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4405	<b>Spill Test Date</b>	11/11/2021	<b>Piping Installed Date</b>	10/02/2014	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	04/07/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	04/19/2017	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	09/29/2014	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/29/2021			<b>ATG Type</b>	Veeder Root/TLS-450				
<b>Tank Code</b>	05	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	11/15/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve

<b>Tag Number</b>	4406	<b>Spill Test Date</b>	04/07/2021	<b>Piping Installed Date</b>	10/02/2014	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	04/07/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/28/2020	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	09/29/2014	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Veeder Root/TLS-450				
<b>Tank Code</b>	03	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	11/15/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4407	<b>Spill Test Date</b>	04/07/2021	<b>Piping Installed Date</b>	10/02/2014	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	04/07/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/28/2020	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	09/29/2014	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Veeder Root/TLS-450				
<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	11/15/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4408	<b>Spill Test Date</b>	05/03/2023	<b>Piping Installed Date</b>	10/02/2014	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/03/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/03/2023	<b>Tank/Piping CP Test Date</b>	05/03/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	05/03/2023	<b>Line Tightness Test Date</b>	09/29/2014	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/03/2023			<b>ATG Type</b>	Veeder Root/TLS-450				

**Facility Summary in Flathead County in the City of Columbia Falls**

**Location:** HI-STAR PROPERTIES LLC  
7356 US Hwy 2 E  
Columbia Falls, MT 59912-9107 Flathead

System Facility ID:15-11333

**Facility Code:** 20934  
**Last Inspected On:** 07/28/2022  
**Operating Permit Renewal Date:** 08/02/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Hi-Star Properties LLC

histarms3@yahoo.com

**Operator Contact:** Wade Lindsay

(406) 890-0968

wade.w.lindsay@gmail.com

**Owner/Operator:** Hi-Star Properties LLC

histarms3@yahoo.com

Wade Lindsay, UST Class A Operator

wade.w.lindsay@gmail.com

Wade Lindsay, UST Class B Global Operator

wade.w.lindsay@gmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	01/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;High Level Alarm
<b>Tag Number</b>	686	<b>Spill Test Date</b>	03/21/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	07/27/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	04/26/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	07/27/2022	<b>Line Tightness Test Date</b>	07/27/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/22/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	01/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;High Level Alarm
<b>Tag Number</b>	687	<b>Spill Test Date</b>	03/21/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	07/27/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	07/27/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	07/27/2022	<b>Line Tightness Test Date</b>	07/27/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/22/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

<b>Tank Code</b>	03	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	01/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;High Level Alarm
<b>Tag Number</b>	688	<b>Spill Test Date</b>	03/21/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	07/27/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	07/27/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	07/27/2022	<b>Line Tightness Test Date</b>	07/27/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/22/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	04	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	01/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;High Level Alarm
<b>Tag Number</b>	689	<b>Spill Test Date</b>	03/21/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	07/27/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	07/27/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	07/27/2022	<b>Line Tightness Test Date</b>	07/27/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/22/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Flathead County in the City of Columbia Falls**

**Location:** JUNCTION GAS  
7322 US Hwy 2 E  
Columbia Falls, MT 59912-9107 Flathead

System Facility ID:15-02820

**Facility Code:** 20587  
**Last Inspected On:** 10/10/2022  
**Operating Permit Renewal Date:** 12/24/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Kalispell Properties LLC (509) 994-6599 pamelpkp@yahoo.com

**Operator Contact:** David Brotnov;Ramdeep Kaur (406) 892-2004;(803) 522-5352 ramdeeprokha@yahoo.com

**Owner/Operator:** Kalispell Properties LLC (509) 994-6599 pamelpkp@yahoo.com

David M Brotnov, UST Class A Operator  
Marlene Sevesind, UST Class B Global Operator  
Ramdeep Kaur, UST Class A Operator ramdeeprokha@yahoo.com  
Ramdeep Kaur, UST Class B Global Operator ramdeeprokha@yahoo.com  
Ramdeep Kaur, UST Class B Operator ramdeeprokha@yahoo.com

<b>Tank Code</b>	01	<b>Tank Age</b>	48	<b>Tank Installed Date</b>	07/01/1977	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	496	<b>Spill Test Date</b>	09/22/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	12/06/2016	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/22/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	09/22/2022	<b>Line Tightness Test Date</b>	06/29/2010	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/22/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	02	<b>Tank Age</b>	48	<b>Tank Installed Date</b>	07/01/1977	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	497	<b>Spill Test Date</b>	09/22/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/22/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No



<b>Capacity</b>	10000	<b>ATG Test Date</b>	09/22/2022	<b>Line Tightness Test Date</b>	12/06/2016	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/22/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	03	<b>Tank Age</b>	48	<b>Tank Installed Date</b>	07/01/1977	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	498	<b>Spill Test Date</b>	09/22/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	12/06/2016	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/22/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	09/22/2022	<b>Line Tightness Test Date</b>	06/29/2010	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/22/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	04	<b>Tank Age</b>	37	<b>Tank Installed Date</b>	11/17/1988	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	499	<b>Spill Test Date</b>	10/06/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/22/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	09/22/2022	<b>Line Tightness Test Date</b>	12/06/2016	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/22/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				

**Facility Summary in Flathead County in the City of Columbia Falls**

**Location:** MIKES OF COLUMBIA FALLS  
1645 9th St W  
Columbia Falls, MT 59912 Flathead

System Facility ID:15-06839

**Facility Code:** 20716  
**Last Inspected On:** 06/30/2023  
**Operating Permit Renewal Date:** 07/31/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Dan Elder;KMR LLC;KMR LLC (253) 985-5039;(406) 892-2078;(406) 892-2078 dane@mikesconoco.com;dane@mikesconoco.com;dane@mikesconoco.com

**Operator Contact:** Ronda Heil;Shawn Damphier (406) 892-2078 schopper12345@gmail.com

**Owner/Operator:** Dan Elder,KMR LLC (253) 985-5039 dane@mikesconoco.com

**Owner/Operator:** KMR LLC (253) 985-5039 dane@mikesconoco.com

Ronda Heil, UST Class A Operator

Ronda Heil, UST Class A Operator

Shawn Damphier, UST Class A Operator

Shawn Damphier, UST Class B Operator

schopper12345@gmail.com

schopper12345@gmail.com

<b>Tank Code</b>	06	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	07/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3366	<b>Spill Test Date</b>	11/30/2024	<b>Piping Installed Date</b>	03/30/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Secondary Containment Chase	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/30/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	01/22/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	01/22/2025	<b>Line Tightness Test Date</b>	02/25/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/29/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	07	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	07/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3367	<b>Spill Test Date</b>	11/30/2024	<b>Piping Installed Date</b>	03/30/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/30/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	01/22/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No

<b>Capacity</b>	12000	<b>ATG Test Date</b>	01/22/2025	<b>Line Tightness Test Date</b>	02/26/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/29/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	08	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	07/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3368	<b>Spill Test Date</b>	06/29/2023	<b>Piping Installed Date</b>	03/30/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/30/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	01/22/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	01/22/2025	<b>Line Tightness Test Date</b>	02/26/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/29/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	09	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	07/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3369	<b>Spill Test Date</b>	06/29/2023	<b>Piping Installed Date</b>	03/30/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/30/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	01/22/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	01/22/2025	<b>Line Tightness Test Date</b>	02/25/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/29/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	05	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	07/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4466	<b>Spill Test Date</b>	06/28/2023	<b>Piping Installed Date</b>	03/30/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Secondary Containment Chase	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	06/28/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	01/22/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	01/22/2025	<b>Line Tightness Test Date</b>	02/25/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/29/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Flathead County in the City of Columbia Falls**

**Location:** SMITHS #168 FUEL CENTER  
150 Halfmoon Rd  
Columbia Falls, MT 59912 Flathead

System Facility ID:60-15336

**Facility Code:** 32381  
**Last Inspected On:** 05/17/2023  
**Operating Permit Renewal Date:** 07/29/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Smiths Food and Drug (801) 974-1400 roger.gough@sfdc.com

**Operator Contact:** Braxton Hill;Kerry Busey (801) 977-1048 braxton.hill@sfdc.com;kerry.busey@sfdc.com

**Owner/Operator:** Smiths Food and Drug (801) 974-1400 roger.gough@sfdc.com

Braxton Hill, UST Class A Operator braxton.hill@sfdc.com  
 Braxton Hill, UST Class B Operator braxton.hill@sfdc.com  
 Kerry Busey, UST Class A Operator kerry.busey@sfdc.com  
 Kerry Busey, UST Class B Global Operator kerry.busey@sfdc.com

<b>Tank Code</b>	01	<b>Tank Age</b>	5	<b>Tank Installed Date</b>	01/27/2020	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5926	<b>Spill Test Date</b>	09/22/2022	<b>Piping Installed Date</b>	01/27/2020	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/22/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	20000	<b>ATG Test Date</b>	09/24/2024	<b>Line Tightness Test Date</b>	02/20/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	11/20/2024			<b>ATG Type</b>					
<b>Tank Code</b>	02	<b>Tank Age</b>	5	<b>Tank Installed Date</b>	01/27/2020	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5927	<b>Spill Test Date</b>	09/22/2022	<b>Piping Installed Date</b>	01/27/2020	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/22/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	09/24/2024	<b>Line Tightness Test Date</b>	02/20/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	11/20/2024			<b>ATG Type</b>					

<b>Tank Code</b>	03	<b>Tank Age</b>	5	<b>Tank Installed Date</b>	01/27/2020	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve; High Level Alarm
<b>Tag Number</b>	5928	<b>Spill Test Date</b>	12/28/2022	<b>Piping Installed Date</b>	01/27/2020	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/22/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	8000	<b>ATG Test Date</b>	09/24/2024	<b>Line Tightness Test Date</b>	02/20/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	11/20/2024			<b>ATG Type</b>					

**Facility Summary in Flathead County in the City of Columbia Falls**

**Location:** TOWN PUMP INC COLUMBIA FALLS 1  
502 9th St W  
Columbia Falls, MT 59912-3808 Flathead

System Facility ID:15-08690

**Facility Code:** 20763  
**Last Inspected On:** 03/10/2023  
**Operating Permit Renewal Date:** 08/28/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Columbia Falls 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

**Operator Contact:** Trent Biggers Trentb@townpump.com

**Owner/Operator:** Columbia Falls 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com  
Trent Biggers, UST Class A Operator Trentb@townpump.com  
Trent Biggers, UST Class B Global Operator Trentb@townpump.com  
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

<b>Tank Code</b>	02	<b>Tank Age</b>	44	<b>Tank Installed Date</b>	07/14/1981	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2420	<b>Spill Test Date</b>	03/12/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/12/2025	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	02/07/2022	<b>Tank/Piping CP Test Date</b>	09/19/2022	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	12000	<b>ATG Test Date</b>	03/12/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/19/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	07	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	07/14/1989	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2423	<b>Spill Test Date</b>	03/12/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/12/2025	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	02/07/2022	<b>Tank/Piping CP Test Date</b>	02/07/2022	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	12000	<b>ATG Test Date</b>	03/12/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	09/19/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	05	<b>Tank Age</b>	40	<b>Tank Installed Date</b>	10/01/1985	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4380	<b>Spill Test Date</b>	03/12/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/12/2025	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	02/07/2022	<b>Tank/Piping CP Test Date</b>	09/19/2022	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	03/12/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/19/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	06	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	07/14/1989	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4381	<b>Spill Test Date</b>	03/12/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/12/2025	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	02/07/2022	<b>Tank/Piping CP Test Date</b>	02/07/2022	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	12000	<b>ATG Test Date</b>	03/12/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/19/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				

**Facility Summary in Flathead County in the City of Columbia Falls**

**Location:** TOWN PUMP INC COLUMBIA FALLS 2  
6102 US Hwy 2 W  
Columbia Falls, MT 59912-8927 Flathead

System Facility ID:56-13825

**Facility Code:** 30511  
**Last Inspected On:** 03/10/2023  
**Operating Permit Renewal Date:** 08/29/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Columbia Falls 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

**Operator Contact:** Trent Biggers Trentb@townpump.com

**Owner/Operator:** Columbia Falls 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator	Trentb@townpump.com
Trent Biggers, UST Class A Operator	Trentb@townpump.com
Trent Biggers, UST Class B Global Operator	Trentb@townpump.com
Trent Biggers, UST Class B Global Operator	Trentb@townpump.com

<b>Tank Code</b>	01	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	10/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	2674	<b>Spill Test Date</b>	09/21/2022	<b>Piping Installed Date</b>	10/08/2013	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/21/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/11/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	12000	<b>ATG Test Date</b>	03/09/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/21/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	03	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	10/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	2676	<b>Spill Test Date</b>	09/21/2022	<b>Piping Installed Date</b>	10/08/2013	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/21/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/11/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes



<b>Capacity</b>	10000	<b>ATG Test Date</b>	03/09/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/17/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	04	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	10/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2677	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Approved Remote Monitoring;MLLD Line Tightness Testing;Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	11/12/2015	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	05	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	10/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2678	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Approved Remote Monitoring;MLLD Line Tightness Testing;Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	11/12/2015	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	06	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	10/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2679	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	09/18/2014	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/07/2014	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	

<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Approved Remote Monitoring;MLLD Line Tightness Testing;Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	11/12/2015	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	07	<b>Tank Age</b>	25	<b>Tank Installed Date</b>	10/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4249	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	06/20/2012	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Approved Remote Monitoring;Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	30000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	08	<b>Tank Age</b>	25	<b>Tank Installed Date</b>	10/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4250	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	06/20/2012	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Approved Remote Monitoring;Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	30000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	02	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	10/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	4670	<b>Spill Test Date</b>	09/21/2022	<b>Piping Installed Date</b>	10/08/2013	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No

<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/21/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/11/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	03/09/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/17/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	09	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	10/02/2015	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5600	<b>Spill Test Date</b>	09/21/2022	<b>Piping Installed Date</b>	10/07/2015	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/21/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/11/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	15000	<b>ATG Test Date</b>	03/09/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/21/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	10	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	10/02/2015	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5601	<b>Spill Test Date</b>	09/21/2022	<b>Piping Installed Date</b>	10/07/2015	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/21/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/11/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	6000	<b>ATG Test Date</b>	03/09/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/21/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	11	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	01/18/2021	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5995	<b>Spill Test Date</b>	09/21/2022	<b>Piping Installed Date</b>	01/18/2021	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/21/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/11/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes

<b>Capacity</b>	6000	<b>ATG Test Date</b>	03/09/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/21/2022			<b>ATG Type</b>					
<b>Tank Code</b>	12	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	01/18/2021	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5996	<b>Spill Test Date</b>	09/21/2022	<b>Piping Installed Date</b>	01/18/2021	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/21/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/11/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	8000	<b>ATG Test Date</b>	03/09/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/21/2022			<b>ATG Type</b>					
<b>Tank Code</b>	13	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	01/18/2021	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5997	<b>Spill Test Date</b>	09/21/2022	<b>Piping Installed Date</b>	01/18/2021	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/21/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/11/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	6000	<b>ATG Test Date</b>	03/09/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/21/2022			<b>ATG Type</b>					
<b>Tank Code</b>	14	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	01/18/2021	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	5998	<b>Spill Test Date</b>	09/29/2020	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>		<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/29/2020	<b>Catastrophic L.D Type 3.0</b>		<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	DEF (Not Regulated)	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/29/2020			<b>ATG Type</b>					
<b>Tank Code</b>	15	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	01/18/2021	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm

<b>Tag Number</b>	6009	<b>Spill Test Date</b>	09/21/2022	<b>Piping Installed Date</b>	01/18/2021	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/21/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/11/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	30000	<b>ATG Test Date</b>	03/09/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/21/2022			<b>ATG Type</b>					
<b>Tank Code</b>	16	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	01/18/2021	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	6010	<b>Spill Test Date</b>	09/21/2022	<b>Piping Installed Date</b>	01/18/2021	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/21/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/11/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	03/09/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/21/2022			<b>ATG Type</b>					
<b>Tank Code</b>	17	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	01/18/2021	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	6011	<b>Spill Test Date</b>	09/21/2022	<b>Piping Installed Date</b>	01/18/2021	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/21/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	05/11/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	03/09/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/21/2022			<b>ATG Type</b>					

**Facility Summary in Flathead County in the City of Coram**

**Location:** GLACIER CENTER  
10049 US Hwy 2 E  
Coram, MT 59913 Flathead

System Facility ID:15-10895

**Facility Code:** 20898  
**Last Inspected On:** 05/03/2023  
**Operating Permit Renewal Date:** 06/03/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Kalispell Properties LLC (509) 994-6599 pamelpkp@yahoo.com

**Operator Contact:** Rhonda Andverson;Wade Lindsay;Kalispell Properties LLC (406) 38-75090;(406) 890-0968;(509) 994-6599 glaciercentergas@gmail.com;wade.w.lindsay@gmail.com;pamelpkp@yahoo.com

**Owner/Operator:** Kalispell Properties LLC (509) 994-6599 pamelpkp@yahoo.com  
 Rhonda Andverson, UST Class A Operator glaciercentergas@gmail.com  
 Wade Lindsay, UST Class A Operator pamelpkp@yahoo.com  
 Wade Lindsay, UST Class A Operator pamelpkp@yahoo.com  
 Wade Lindsay, UST Class B Operator pamelpkp@yahoo.com  
 Wade Lindsay, UST Class B Operator pamelpkp@yahoo.com

<b>Tank Code</b>	04	<b>Tank Age</b>	37	<b>Tank Installed Date</b>	04/17/1988	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	1883	<b>Spill Test Date</b>	05/03/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	05/03/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/03/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	05/03/2023	<b>Line Tightness Test Date</b>	05/03/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/03/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	05	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	05/01/1995	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	1884	<b>Spill Test Date</b>	05/03/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	05/03/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/28/2014	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/03/2023	<b>Line Tightness Test Date</b>	05/03/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	05/03/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	06	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	05/01/1995	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	1885	<b>Spill Test Date</b>	05/03/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	05/03/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/28/2014	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/03/2023	<b>Line Tightness Test Date</b>	05/03/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/03/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	07	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	05/01/1995	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	1886	<b>Spill Test Date</b>	05/03/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	05/03/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/28/2014	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	05/03/2023	<b>Line Tightness Test Date</b>	05/03/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/03/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Flathead County in the City of Hungry Horse**

**Location:** BOBS SINCLAIR HUNGRY HORSE  
8930 US Hwy 2 E  
Hungry Horse, MT 59919 Flathead

System Facility ID:15-07506

**Facility Code:** 20733  
**Last Inspected On:** 01/24/2024  
**Operating Permit Renewal Date:** 03/24/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** SCR Investment LLC (406) 206-3676 snowman190202@gmail.com

**Operator Contact:** Jeff Johnson (406) 260-3676 snowman190202@gmail.com

**Owner/Operator:** SCR Investment LLC (406) 206-3676 snowman190202@gmail.com

Jeff Johnson, UST Class A Operator snowman190202@gmail.com  
 Jeff Johnson, UST Class A Operator snowman190202@gmail.com  
 Jeff Johnson, UST Class B Operator snowman190202@gmail.com  
 Jeff Johnson, UST Class B Operator snowman190202@gmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	45	<b>Tank Installed Date</b>	09/01/1980	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	4180	<b>Spill Test Date</b>	04/15/2021	<b>Piping Installed Date</b>	04/15/2021	<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	03/17/2021	<b>Sump Tightness Test Date</b>	04/15/2021	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	04/28/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	04/28/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/15/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	02	<b>Tank Age</b>	45	<b>Tank Installed Date</b>	09/01/1980	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	4181	<b>Spill Test Date</b>	04/15/2021	<b>Piping Installed Date</b>	04/15/2021	<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	04/15/2021	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	04/28/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No



<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	04/28/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/15/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	03	<b>Tank Age</b>	45	<b>Tank Installed Date</b>	09/01/1980	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve; Flapper Valve
<b>Tag Number</b>	4182	<b>Spill Test Date</b>	04/15/2021	<b>Piping Installed Date</b>	04/15/2021	<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	03/17/2021	<b>Sump Tightness Test Date</b>	04/15/2021	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	04/28/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	04/28/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/15/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	04	<b>Tank Age</b>	45	<b>Tank Installed Date</b>	09/01/1980	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve; Flapper Valve
<b>Tag Number</b>	4183	<b>Spill Test Date</b>	04/15/2021	<b>Piping Installed Date</b>	04/15/2021	<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	03/17/2021	<b>Sump Tightness Test Date</b>	04/15/2021	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	04/28/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	04/28/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/15/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Flathead County in the City of Hungry Horse**

**Location:** CENEX ZIP TRIP 71  
8840 US Hwy 2 E  
Hungry Horse, MT 59919 Flathead

System Facility ID:15-09708

**Facility Code:** 20804  
**Last Inspected On:** 11/07/2024  
**Operating Permit Renewal Date:** 04/29/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

**Operator Contact:** Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

**Owner/Operator:** CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jason Brenner, UST Class B Operator  
Jim Alford, UST Class A Operator  
Jim Alford, UST Class A Operator  
Jim Alford, UST Class B Operator  
Jim Alford, UST Class B Operator  
Luci Tuttle, UST Class B Operator  
Sean Hurley, UST Class A Operator  
Sean Hurley, UST Class A Operator

jason.brenner@chsinc.com  
jim.alford@chsinc.com  
jim.alford@chsinc.com  
jim.alford@chsinc.com  
jim.alford@chsinc.com  
Lucinda.Tuttle@chsinc.com  
sean.hurley@chsinc.com  
sean.hurley@chsinc.com

<b>Tank Code</b>	05	<b>Tank Age</b>	7	<b>Tank Installed Date</b>	10/23/2018	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5855	<b>Spill Test Date</b>	11/07/2024	<b>Piping Installed Date</b>	10/23/2018	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/07/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/07/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	08/07/2024	<b>Line Tightness Test Date</b>	10/18/2018	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	03/10/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
<b>Tank Code</b>	06	<b>Tank Age</b>	7	<b>Tank Installed Date</b>	10/23/2018	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5856	<b>Spill Test Date</b>	11/07/2024	<b>Piping Installed Date</b>	10/23/2018	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No

<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/07/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/07/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/07/2024	<b>Line Tightness Test Date</b>	10/18/2018	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	03/10/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
<b>Tank Code</b>	07	<b>Tank Age</b>	7	<b>Tank Installed Date</b>	10/23/2018	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5857	<b>Spill Test Date</b>	11/07/2024	<b>Piping Installed Date</b>	10/23/2018	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/07/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	08/07/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/07/2024	<b>Line Tightness Test Date</b>	10/18/2018	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	03/10/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
<b>Tank Code</b>	08	<b>Tank Age</b>	7	<b>Tank Installed Date</b>	10/23/2018	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5858	<b>Spill Test Date</b>	11/07/2024	<b>Piping Installed Date</b>	10/23/2018	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/07/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	08/07/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/07/2024	<b>Line Tightness Test Date</b>	10/18/2018	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	03/10/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
<b>Tank Code</b>	09	<b>Tank Age</b>	7	<b>Tank Installed Date</b>	10/23/2018	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5859	<b>Spill Test Date</b>	11/07/2024	<b>Piping Installed Date</b>	10/23/2018	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No

<b>Tank Status</b>	<b>Currently in Use</b>	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/07/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	08/07/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/07/2024	<b>Line Tightness Test Date</b>	10/18/2018	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	03/10/2025			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** APPLEWAY CONOCO  
100 N Meridian Rd  
Kalispell, MT 59901-3848 Flathead

System Facility ID:15-00113

**Facility Code:** 20517  
**Last Inspected On:** 10/12/2023  
**Operating Permit Renewal Date:** 01/12/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Appleway Conoco

**Operator Contact:** Linda Bertoli

**(509) 315-9959**

**lindabertoli@gmail.com**

**Owner/Operator:** Appleway Conoco

Linda Bertoli, UST Class A Operator  
Linda Bertoli, UST Class B Operator

lindabertoli@gmail.com  
lindabertoli@gmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	46	<b>Tank Installed Date</b>	12/31/1979	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3141	<b>Spill Test Date</b>	03/10/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	08/31/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	08/31/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/31/2023	<b>Line Tightness Test Date</b>	08/31/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/10/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	02	<b>Tank Age</b>	46	<b>Tank Installed Date</b>	12/31/1979	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3142	<b>Spill Test Date</b>	03/10/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	08/31/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	08/31/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/31/2023	<b>Line Tightness Test Date</b>	08/31/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/10/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	03	<b>Tank Age</b>	46	<b>Tank Installed Date</b>	12/31/1979	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve

<b>Tag Number</b>	3143	<b>Spill Test Date</b>	03/10/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	08/31/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	08/31/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/31/2023	<b>Line Tightness Test Date</b>	08/31/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/10/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** BRAR FOOD STORE  
1090 N Meridian Rd  
Kalispell, MT 59901-3564 Flathead

System Facility ID:15-00110

**Facility Code:** 20514  
**Last Inspected On:** 12/24/2024  
**Operating Permit Renewal Date:** 03/23/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** BRAR FOOD STORE INC (341) 345-8514 BFS.U.S.A@YAHOO.COM

**Operator Contact:** Navneet Brar;BRAR FOOD STORE INC;Paramjit Singh;BRAR FOOD STORE INC (341) 345-8514 bfs.usa@xyz.com;BFS.U.S.A@YAHOO.COM;brarnaman0@gmail.com;BFS.U.S.A@YAHOO.COM

**Owner/Operator:** BRAR FOOD STORE INC (341) 345-8514 BFS.U.S.A@YAHOO.COM

Muskan Sohi, UST Class B Operator	4.sohi062@gmail.com
Navneet Brar, UST Class A Operator	BFS.U.S.A@YAHOO.COM
Navneet Brar, UST Class B Operator	BFS.U.S.A@YAHOO.COM
Paramjit Singh, UST Class A Operator	BFS.U.S.A@YAHOO.COM
Paramjit Singh, UST Class B Operator	BFS.U.S.A@YAHOO.COM

<b>Tank Code</b>	04	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	11/01/1997	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3171	<b>Spill Test Date</b>	01/15/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	12/09/2021	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/20/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	12/09/2021	<b>Line Tightness Test Date</b>	12/09/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/15/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	05	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	11/01/1997	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3172	<b>Spill Test Date</b>	11/23/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	12/09/2021	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/20/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	12/09/2021	<b>Line Tightness Test Date</b>	12/09/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/15/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				

<b>Tank Code</b>	06	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	11/01/1997	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3173	<b>Spill Test Date</b>	01/15/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	12/09/2021	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/20/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	12/09/2021	<b>Line Tightness Test Date</b>	12/09/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/15/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				



**Facility Summary in Flathead County in the City of Kalispell**

**Location:** BRIANS C STORE  
2075 US Hwy 2 E  
Kalispell, MT 59901-2944 Flathead

System Facility ID:15-13730

**Facility Code:** 21091  
**Last Inspected On:** 01/03/2024  
**Operating Permit Renewal Date:** 01/14/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** DJL LLC (406) 751-4623

**Operator Contact:** Brian Kahler (406) 360-6484 muddsin1@yahoo.com

**Owner/Operator:** DJL LLC (406) 751-4623

Brian Kahler, UST Class A Operator

muddsin1@yahoo.com

Brian Kahler, UST Class B Global Operator

muddsin1@yahoo.com

<b>Tank Code</b>	01	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	06/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3352	<b>Spill Test Date</b>	03/21/2024	<b>Piping Installed Date</b>	11/28/2023	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/20/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	11/16/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	11/16/2023	<b>Line Tightness Test Date</b>	05/25/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/21/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	06/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3353	<b>Spill Test Date</b>	03/21/2024	<b>Piping Installed Date</b>	11/28/2023	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/20/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	11/16/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	11/16/2023	<b>Line Tightness Test Date</b>	08/07/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/21/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

<b>Tank Code</b>	03	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	06/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3354	<b>Spill Test Date</b>	11/16/2023	<b>Piping Installed Date</b>	11/28/2023	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/20/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	11/16/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	11/16/2023	<b>Line Tightness Test Date</b>	10/04/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/21/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	04	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	06/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3355	<b>Spill Test Date</b>	11/16/2023	<b>Piping Installed Date</b>	11/28/2023	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/20/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	11/16/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	11/16/2023	<b>Line Tightness Test Date</b>	10/04/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/16/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	05	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	06/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3356	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	05/28/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	06	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	06/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3357	<b>Spill Test Date</b>	03/21/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No

<b>Tank Status</b>	<b>Currently in Use</b>	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	04/28/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/21/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** BRIANS INC  
1319 US Hwy 93 S  
Kalispell, MT 59901-5765 Flathead

System Facility ID:15-09820

**Facility Code:** 20807  
**Last Inspected On:** 05/18/2023  
**Operating Permit Renewal Date:** 06/28/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Darryl Bjork;DJL LLC (406) 751-4623;(406) 752-7339

**Operator Contact:** Brian Kahler (406) 360-6484 muddsin1@yahoo.com

**Owner/Operator:** Darryl Bjork (406) 752-7339

**Owner/Operator:** DJL LLC (406) 752-7339

Brian Kahler, UST Class A Operator

muddsin1@yahoo.com

Brian Kahler, UST Class A Operator

muddsin1@yahoo.com

Brian Kahler, UST Class B Global Operator

muddsin1@yahoo.com

Brian Kahler, UST Class B Global Operator

muddsin1@yahoo.com

<b>Tank Code</b>	05	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	09/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	1847	<b>Spill Test Date</b>	05/17/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	05/17/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/18/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	05/17/2023	<b>Line Tightness Test Date</b>	05/17/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/28/2023			<b>ATG Type</b>	Incon/TS-1000				
<b>Tank Code</b>	06	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	09/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	1848	<b>Spill Test Date</b>	05/17/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	05/17/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/18/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	05/17/2023	<b>Line Tightness Test Date</b>	05/17/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/17/2023			<b>ATG Type</b>	Incon/TS-1000				

<b>Tank Code</b>	07	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	09/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve; Flapper Valve
<b>Tag Number</b>	1849	<b>Spill Test Date</b>	06/27/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	05/17/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/18/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	7500	<b>ATG Test Date</b>	05/17/2023	<b>Line Tightness Test Date</b>	05/17/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/28/2023			<b>ATG Type</b>	Incon/TS-1000				
<b>Tank Code</b>	08	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	09/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	1850	<b>Spill Test Date</b>	05/17/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	05/17/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/18/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	7500	<b>ATG Test Date</b>	05/17/2023	<b>Line Tightness Test Date</b>	05/17/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/17/2023			<b>ATG Type</b>	Incon/TS-1000				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** CHS - CENTRAL  
55 4th Ave E N  
Kalispell, MT 59901-4157 Flathead

System Facility ID:15-09705

**Facility Code:** 20802  
**Last Inspected On:** 06/16/2020  
**Operating Permit Renewal Date:** 06/16/2023

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Flathead County Economic Development Authority

**Operator Contact:** Bob Westin;Christy Dawson;Victor Hannam

**victor.hannam@chsinc.com**

Bob Westin, UST Class A Operator  
Bob Westin, UST Class B Global Operator  
Christy Dawson, UST Class A Operator  
Christy Dawson, UST Class A Operator  
Christy Dawson, UST Class A Operator  
Christy Dawson, UST Class B Operator  
Christy Dawson, UST Class B Operator  
Christy Dawson, UST Class B Operator  
Christy Dawson, UST Class B Operator  
Victor Hannam, UST Class A Operator  
Victor Hannam, UST Class A Operator  
Victor Hannam, UST Class A Operator  
Victor Hannam, UST Class A Operator  
Victor Hannam, UST Class B Global Operator  
Victor Hannam, UST Class B Global Operator  
Victor Hannam, UST Class B Global Operator  
Victor Hannam, UST Class B Global Operator

victor.hannam@chsinc.com  
victor.hannam@chsinc.com  
victor.hannam@chsinc.com  
victor.hannam@chsinc.com  
victor.hannam@chsinc.com  
victor.hannam@chsinc.com  
victor.hannam@chsinc.com  
victor.hannam@chsinc.com  
victor.hannam@chsinc.com

<b>Tank Code</b>	01	<b>Tank Age</b>	44	<b>Tank Installed Date</b>	03/26/1981	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3786	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/28/2017	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	40000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	07/06/2017	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD Line Tightness Testing	<b>Energy Act</b>	No

		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	44	<b>Tank Installed Date</b>	03/26/1981	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3787	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/28/2017	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	40000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	06/28/2017	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD Line Tightness Testing	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	03	<b>Tank Age</b>	44	<b>Tank Installed Date</b>	03/26/1981	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3788	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/28/2017	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	40000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	06/28/2017	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD Line Tightness Testing	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	08	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	03/01/1999	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4075	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	16000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	06/28/2017	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD Line Tightness Testing	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	09	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	03/01/1999	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4076	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No

<b>Tank Status</b>	<b>Permanently Out of Use</b>	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	08/04/2017	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				



**Facility Summary in Flathead County in the City of Kalispell**

**Location:** CHS - WEST  
120 W Idaho St  
Kalispell, MT 59901 Flathead

System Facility ID:15-05069

**Facility Code:** 20654  
**Last Inspected On:** 06/27/2017  
**Operating Permit Renewal Date:** 06/30/2020

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** DOCO LLC

**Operator Contact:** Bob Westin

Bob Westin, UST Class A Operator  
Bob Westin, UST Class B Global Operator

<b>Tank Code</b>	11	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	03/01/1996	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	866	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/28/2017	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	03/16/2017	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring;ELLD Line Tightness Testing	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	12	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	03/01/1996	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	867	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/28/2017	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	03/16/2017	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring;ELLD Line Tightness Testing	<b>Energy Act</b>	No

		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	13	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	03/01/1996	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	868	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/28/2017	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	30000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	03/16/2017	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring;ELLD Line Tightness Testing	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** CIRCLE K STORE 2746722  
840 W Idaho St  
Kalispell, MT 59901-3844 Flathead

System Facility ID:56-13985

**Facility Code:** 30646  
**Last Inspected On:** 10/28/2021  
**Operating Permit Renewal Date:** 03/30/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

<b>Owner Operator Contact:</b> Rocky Mountain Oil LLC	<b>(602) 728-8000</b>	<b>NT-ESS@Circlek.com</b>
<b>Operator Contact:</b> Chuck Nyberg;Patrick Patnaude;Robert Deninno;Stephen Reckinger;Valeria Jeffries;Veronica Rivera	<b>(952) 830-8028;(952) 830-8721;(952) 830-8722</b>	<b>ESS-WestCoast@circlek.com;patrick.patnaude@holidaycompanies.com;steve.reckinger@holidaycompanies.com;valeria.jeffries@holidaycompanies.com</b>

Brad Lee, UST Class B Global Operator	brad.lee@holidaycompanies.com
Chuck Nyberg, UST Class A Operator	
Patrick Patnaude, UST Class A Operator	patrick.patnaude@holidaycompanies.com
Robert Deninno, UST Class A Operator	
Stephen Reckinger, UST Class A Operator	steve.reckinger@holidaycompanies.com
Todd White, UST Class B Global Operator	todd.white@holidaycompanies.com
Valeria Jeffries, UST Class A Operator	valeria.jeffries@holidaycompanies.com
Veronica Rivera, UST Class A Operator	ESS-WestCoast@circlek.com
Veronica Rivera, UST Class B Global Operator	ESS-WestCoast@circlek.com

<b>Tank Code</b>	01	<b>Tank Age</b>	25	<b>Tank Installed Date</b>	10/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4239	<b>Spill Test Date</b>	10/28/2021	<b>Piping Installed Date</b>	10/20/2000	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	10/28/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	30000	<b>ATG Test Date</b>	10/28/2021	<b>Line Tightness Test Date</b>	07/24/2018	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/28/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	25	<b>Tank Installed Date</b>	10/01/2000	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4240	<b>Spill Test Date</b>	10/28/2021	<b>Piping Installed Date</b>	10/20/2000	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No

<b>Tank Status</b>	<b>Permanently Out of Use</b>	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	10/28/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	10/28/2021	<b>Line Tightness Test Date</b>	07/25/2018	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/28/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** CITY SERVICE BULK PLANT  
1841 3rd Ave E  
Kalispell, MT 59901-5758 Flathead

System Facility ID:56-13824

**Facility Code:** 30510  
**Last Inspected On:** 08/09/2022  
**Operating Permit Renewal Date:** 12/24/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** City Service Inc (406) 755-4321

**Operator Contact:** Drew Pike;Kary Tonjum;Margaret Flynn (406) 294-0863;(406) 755-4321 [drewp@cityservicevalcon.com](mailto:drewp@cityservicevalcon.com);[margaretf@cityservicevalcon.com](mailto:margaretf@cityservicevalcon.com)

**Owner/Operator:** City Service Inc (406) 755-4321

Drew Pike, UST Class A Operator  
Drew Pike, UST Class B Global Operator  
Kary Tonjum, UST Class A Operator  
Kary Tonjum, UST Class B Global Operator  
Margaret Flynn, UST Class A Operator  
Margaret Flynn, UST Class B Operator

[drewp@cityservicevalcon.com](mailto:drewp@cityservicevalcon.com)  
[drewp@cityservicevalcon.com](mailto:drewp@cityservicevalcon.com)  
  
[margaretf@cityservicevalcon.com](mailto:margaretf@cityservicevalcon.com)  
[margaretf@cityservicevalcon.com](mailto:margaretf@cityservicevalcon.com)

<b>Tank Code</b>	01	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	08/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	681	<b>Spill Test Date</b>	04/15/2021	<b>Piping Installed Date</b>	09/28/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	04/15/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/13/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	05/13/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/13/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	08/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	682	<b>Spill Test Date</b>	04/15/2021	<b>Piping Installed Date</b>	09/28/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	04/15/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/13/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No

<b>Capacity</b>	15000	<b>ATG Test Date</b>	05/13/2022	<b>Line Tightness Test Date</b>	09/22/2016	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/13/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	03	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	08/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	683	<b>Spill Test Date</b>	04/15/2021	<b>Piping Installed Date</b>	09/28/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	04/15/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/13/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	05/13/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/13/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	04	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	08/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	684	<b>Spill Test Date</b>	04/15/2021	<b>Piping Installed Date</b>	09/28/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	04/15/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	05/13/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	05/13/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/13/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	05	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	08/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	685	<b>Spill Test Date</b>	04/15/2021	<b>Piping Installed Date</b>	09/28/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	04/15/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/13/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	05/13/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/13/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** CITY SERVICE VALCON - EAGLE FUEL  
3150 US Hwy 2  
Kalispell, MT 59901 Flathead

System Facility ID:56-14014

**Facility Code:** 30674  
**Last Inspected On:** 08/11/2022  
**Operating Permit Renewal Date:** 12/31/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** City Service Valcon LLC

**tamara.noble@cityservicevalcon.com**

**Operator Contact:** Kary Tonjum

**(406) 755-4321**

**Owner/Operator:** City Service Valcon LLC

**tamara.noble@cityservicevalcon.com**

Kary Tonjum, UST Class A Operator

Kary Tonjum, UST Class B Global Operator

<b>Tank Code</b>	01	<b>Tank Age</b>	24	<b>Tank Installed Date</b>	07/01/2001	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4605	<b>Spill Test Date</b>	02/02/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	04/15/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/18/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/18/2022	<b>Line Tightness Test Date</b>	12/13/2018	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/18/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	24	<b>Tank Installed Date</b>	07/01/2001	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4606	<b>Spill Test Date</b>	02/02/2022	<b>Piping Installed Date</b>	12/20/2018	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	04/15/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	05/18/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/18/2022	<b>Line Tightness Test Date</b>	12/13/2018	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/18/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

<b>Tank Code</b>	03	<b>Tank Age</b>	24	<b>Tank Installed Date</b>	07/01/2001	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4607	<b>Spill Test Date</b>	04/15/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	04/15/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/18/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	05/18/2022	<b>Line Tightness Test Date</b>	12/13/2018	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/18/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	04	<b>Tank Age</b>	24	<b>Tank Installed Date</b>	07/01/2001	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4608	<b>Spill Test Date</b>	02/02/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	04/15/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/18/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	05/18/2022	<b>Line Tightness Test Date</b>	12/13/2018	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/18/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				



**Facility Summary in Flathead County in the City of Kalispell**

**Location:** CITY SERVICE VALCON LLC  
52 5th Ave W N  
Kalispell, MT 59901-3802 Flathead

System Facility ID:15-01680

**Facility Code:** 20552  
**Last Inspected On:** 01/27/2025  
**Operating Permit Renewal Date:** 05/01/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** City Service Valcon LLC

**tamara.noble@cityservicevalcon.com**

**Operator Contact:** Drew Pike;Jay Brookie;Kary Tonjum

**(406) 252-4661;(406) 755-4321**

**drewp@cityservicevalcon.com;jayb@cityservicevalcon.com**

**Owner/Operator:** City Service Valcon LLC

tamara.noble@cityservicevalcon.com

David Wines, UST Class B Global Operator  
Drew Pike, UST Class A Operator  
Drew Pike, UST Class B Global Operator  
Jay Brookie, UST Class A Operator  
Jay Brookie, UST Class B Global Operator  
Kary Tonjum, UST Class A Operator  
Kary Tonjum, UST Class B Operator

davidw@cityservicevalcon.com  
drewp@cityservicevalcon.com  
drewp@cityservicevalcon.com  
jayb@cityservicevalcon.com  
jayb@cityservicevalcon.com

<b>Tank Code</b>	09	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	11/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3689	<b>Spill Test Date</b>	05/01/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/01/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	25000	<b>ATG Test Date</b>	05/01/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/01/2024			<b>ATG Type</b>	Gilbarco/EMC				
<b>Tank Code</b>	10	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	11/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3690	<b>Spill Test Date</b>	05/01/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/01/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No

<b>Capacity</b>	25000	<b>ATG Test Date</b>	05/01/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/01/2024			<b>ATG Type</b>	Gilbarco/EMC				
<b>Tank Code</b>	11	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	11/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3691	<b>Spill Test Date</b>	05/01/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/01/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	05/01/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/01/2024			<b>ATG Type</b>	Gilbarco/EMC				
<b>Tank Code</b>	12	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	11/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3692	<b>Spill Test Date</b>	05/01/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/01/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	05/01/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/01/2024			<b>ATG Type</b>	Gilbarco/EMC				
<b>Tank Code</b>	13	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	12/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3693	<b>Spill Test Date</b>	05/01/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Heating Oil	<b>PLLD Test Date</b>	05/01/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	05/01/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/01/2024			<b>ATG Type</b>	Gilbarco/EMC				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** CONOCO CAR CARE CENTER  
292 3rd Ave E N  
Kalispell, MT 59901 Flathead

System Facility ID:15-01677

**Facility Code:** 20550  
**Last Inspected On:** 11/22/2024  
**Operating Permit Renewal Date:** 12/12/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Maurissa Spain (406) 609-8977 maurissaspain@gmail.com

**Operator Contact:** Dallas Herron;Maurissa Spain (406) 609-8977;(406) 751-4623 dallash@cityservicevalcon.com;maurissaspain@gmail.com

**Owner/Operator:** Maurissa Spain (406) 609-8977 maurissaspain@gmail.com  
 Dallas Herron, UST Class A Operator dallash@cityservicevalcon.com  
 Maurissa Spain, UST Class A Operator maurissaspain@gmail.com  
 Maurissa Spain, UST Class B Operator maurissaspain@gmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	54	<b>Tank Installed Date</b>	04/24/1971	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2199	<b>Spill Test Date</b>	11/30/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>	11/30/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/30/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	11/30/2023	<b>Line Tightness Test Date</b>	11/30/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/30/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	54	<b>Tank Installed Date</b>	04/24/1971	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2200	<b>Spill Test Date</b>	08/05/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>	11/30/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/30/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	11/30/2023	<b>Line Tightness Test Date</b>	11/30/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	11/30/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	03	<b>Tank Age</b>	49	<b>Tank Installed Date</b>	04/23/1976	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2201	<b>Spill Test Date</b>	08/05/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>	11/30/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/30/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	11/30/2023	<b>Line Tightness Test Date</b>	11/30/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/30/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	09	<b>Tank Age</b>	39	<b>Tank Installed Date</b>	04/23/1986	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	No Piping	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	2202	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Gravity Feed	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Oil, Waste	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	02/20/2020	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	3-Year Line Tightness Test	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	10/07/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** COSTCO WHOLESALE  
2330 US Hwy 93 N  
Kalispell, MT 59901-2547 Flathead

System Facility ID:60-15012

**Facility Code:** 30802  
**Last Inspected On:** 12/07/2022  
**Operating Permit Renewal Date:** 02/07/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Costco Wholesale (425) 251-6222 gaslicenses@costco.com

**Operator Contact:** Zane Wilson;Costco Wholesale Corporation Missoula w745gas@costco.com

**Owner/Operator:** Costco Wholesale (425) 251-6222 gaslicenses@costco.com

Zane Wilson, UST Class A Operator w745gas@costco.com  
Zane Wilson, UST Class B Operator w745gas@costco.com

<b>Tank Code</b>	01	<b>Tank Age</b>	20	<b>Tank Installed Date</b>	10/07/2005	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	5033	<b>Spill Test Date</b>	06/14/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/15/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/07/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	07/07/2022	<b>Line Tightness Test Date</b>	07/07/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/14/2020			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	02	<b>Tank Age</b>	20	<b>Tank Installed Date</b>	10/07/2005	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	5034	<b>Spill Test Date</b>	06/14/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/15/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/07/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	07/07/2022	<b>Line Tightness Test Date</b>	07/07/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/14/2020			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

<b>Tank Code</b>	03	<b>Tank Age</b>	20	<b>Tank Installed Date</b>	10/07/2005	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	5035	<b>Spill Test Date</b>	06/14/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	06/14/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/07/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	07/07/2022	<b>Line Tightness Test Date</b>	07/07/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/14/2020			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	04	<b>Tank Age</b>	14	<b>Tank Installed Date</b>	04/19/2011	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	5280	<b>Spill Test Date</b>	06/02/2022	<b>Piping Installed Date</b>	10/25/2010	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	07/07/2022	<b>Sump Tightness Test Date</b>	06/02/2022	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Hazardous Substance	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	1500	<b>ATG Test Date</b>	07/07/2022	<b>Line Tightness Test Date</b>	12/09/2019	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	07/07/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** DIAMOND AIRE LLC LEASEE  
1893 Airport Rd  
Kalispell, MT 59901-7501 Flathead

System Facility ID:15-03172

**Facility Code:** 20598  
**Last Inspected On:** 12/27/2022  
**Operating Permit Renewal Date:** 12/20/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** John Talmage;Montana Diamond Aire Inc (406) 752-5092 john@diamondaire.com;tia@flymissionmountain.com

**Operator Contact:** Tia Komberec;Montana Diamond Aire Inc (406) 250-8281 tia@flymissionmountain.com;tia@flymissionmountain.com

**Owner/Operator:** John Talmage (406) 752-5092 john@diamondaire.com  
**Owner/Operator:** Montana Diamond Aire Inc (406) 752-5092 john@diamondaire.com  
 Tia Komberec, UST Class A Operator tia@flymissionmountain.com  
 Tia Komberec, UST Class B Operator tia@flymissionmountain.com

<b>Tank Code</b>	07	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	05/24/1995	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3285	<b>Spill Test Date</b>	04/01/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	12/27/2022	<b>Sump Tightness Test Date</b>	11/29/2016	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Aviation Gas	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	12/27/2022	<b>Line Tightness Test Date</b>	12/27/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	12/27/2022			<b>ATG Type</b>	Gilbarco/TLS-350				
<b>Tank Code</b>	08	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	05/24/1995	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3286	<b>Spill Test Date</b>	12/27/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	12/27/2022	<b>Sump Tightness Test Date</b>	11/29/2016	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Jet Fuel (Jet-A, Jet-A1, JP5)	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	12/27/2022	<b>Line Tightness Test Date</b>	12/27/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	12/27/2022			<b>ATG Type</b>	Gilbarco/TLS-350				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** EVERGREEN GAS and DELI  
2100 US Hwy 2 E  
Kalispell, MT 59901-2814 Flathead

System Facility ID:15-00108

**Facility Code:** 20512  
**Last Inspected On:** 10/11/2023  
**Operating Permit Renewal Date:** 12/02/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Aries Enterprises LLC;Kristi Ruggles (406) 890-5047 ramdeeprokha@yahoo.com

**Operator Contact:** Ramdeep Kaur (803) 522-5352 ramdeeprokha@yahoo.com

**Owner/Operator:** Aries Enterprises LLC (406) 890-5047 ramdeeprokha@yahoo.com

**Owner/Operator:** Kristi Lyn Ruggles (406) 890-5047 ramdeeprokha@yahoo.com

Ramdeep Kaur, UST Class A Operator ramdeeprokha@yahoo.com  
 Ramdeep Kaur, UST Class B Global Operator ramdeeprokha@yahoo.com  
 Ramdeep Kaur, UST Class B Operator ramdeeprokha@yahoo.com

<b>Tank Code</b>	04	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	06/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3180	<b>Spill Test Date</b>	10/20/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	08/31/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/31/2023	<b>Line Tightness Test Date</b>	08/31/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/23/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	05	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	06/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3181	<b>Spill Test Date</b>	10/20/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	08/31/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	08/31/2023	<b>Line Tightness Test Date</b>	08/31/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No



		<b>Overfill Test Date</b>	09/23/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
--	--	---------------------------	------------	--	--	-----------------	--	--	--	--	--

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** FLATHEAD COUNTY JUSTICE CENTER  
920 S Main St  
Kalispell, MT 59901 Flathead

System Facility ID:15-09279

**Facility Code:** 20774  
**Last Inspected On:** 10/20/2022  
**Operating Permit Renewal Date:** 03/16/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Flathead County Commissioners (406) 758-5790

**Operator Contact:** David Covill (406) 758-5834 dcovill@flathead.mt.gov

**Owner/Operator:** Flathead County Commissioners (406) 758-5790

David Covill, UST Class A Operator  
David Covill, UST Class B Operator

dcovill@flathead.mt.gov  
dcovill@flathead.mt.gov

<b>Tank Code</b>	01	<b>Tank Age</b>	38	<b>Tank Installed Date</b>	03/11/1987	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Copper	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3810	<b>Spill Test Date</b>	10/20/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Secondary Containment Chase	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	12/06/2022	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/20/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	10/20/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/20/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** FLATHEAD COUNTY ROAD DEPT  
1249 Willow Glen Dr  
Kalispell, MT 59901-7541 Flathead

System Facility ID:15-06286

**Facility Code:** 20703  
**Last Inspected On:** 01/22/2025  
**Operating Permit Renewal Date:** 05/23/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Flathead County Commissioners (406) 758-5790

**Operator Contact:** Corey Pilsch (406) 752-4962

**Owner/Operator:** Flathead County Commissioners (406) 758-5790

Corey Pilsch, UST Class A Operator  
Corey Pilsch, UST Class A Operator  
Corey Pilsch, UST Class B Operator  
Corey Pilsch, UST Class B Operator

<b>Tank Code</b>	08	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	05/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1088	<b>Spill Test Date</b>	06/13/2024	<b>Piping Installed Date</b>	11/19/2013	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	06/13/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	06/13/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/13/2024			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	09	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	05/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1089	<b>Spill Test Date</b>	06/13/2024	<b>Piping Installed Date</b>	11/19/2013	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	06/13/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	3000	<b>ATG Test Date</b>	06/13/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/13/2024			<b>ATG Type</b>	Gilbarco/EMC Basic				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** FLATHEAD COUNTY SOLID WASTE DIST  
4098 US Hwy 93 N  
Kalispell, MT 59901-6820 Flathead

System Facility ID:56-14041

**Facility Code:** 30696  
**Last Inspected On:** 10/13/2022  
**Operating Permit Renewal Date:** 12/26/2022

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Flathead County Commissioners (406) 758-5790

**Operator Contact:** James Chilton

jchilton@flathead.mt.gov

**Owner/Operator:** Flathead County Commissioners (406) 758-5790

James Chilton, UST Class A Operator

jchilton@flathead.mt.gov

James Chilton, UST Class B Operator

jchilton@flathead.mt.gov

<b>Tank Code</b>	01	<b>Tank Age</b>	24	<b>Tank Installed Date</b>	11/26/2001	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	No Piping	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4559	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/24/2016	<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Not Listed	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Oil, Waste	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S2	<b>Tank Age</b>	22	<b>Tank Installed Date</b>	02/25/2003	<b>Tank Material</b>	Concrete	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4802	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	02/15/2022	<b>Sump Tightness Test Date</b>	01/16/2020	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	02/15/2022	<b>Line Tightness Test Date</b>	02/15/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S3	<b>Tank Age</b>	22	<b>Tank Installed Date</b>	02/25/2003	<b>Tank Material</b>	Concrete	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm

<b>Tag Number</b>	4803	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	02/15/2022	<b>Sump Tightness Test Date</b>	01/16/2020	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	3000	<b>ATG Test Date</b>	02/15/2022	<b>Line Tightness Test Date</b>	02/15/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** FLATHEAD ELECTRIC COOP KALISPELL  
2510 US Hwy 2 E  
Kalispell, MT 59901-2312 Flathead

System Facility ID:15-00044

**Facility Code:** 20508  
**Last Inspected On:** 08/08/2023  
**Operating Permit Renewal Date:** 08/08/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Flathead Electric Cooperative Inc (406) 751-4483

**Operator Contact:** Francisco Carbajal;Flathead Electric Cooperative Inc (406) 471-0554;(406) 751-4483 f.carbajal@flathead.coop

**Owner/Operator:** Flathead Electric Cooperative Inc (406) 751-4483

Francisco Carbajal, UST Class A Operator

f.carbajal@flathead.coop

Francisco Carbajal, UST Class B Operator

f.carbajal@flathead.coop

<b>Tank Code</b>	04	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	04/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1090	<b>Spill Test Date</b>	08/08/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/08/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/08/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/08/2023			<b>ATG Type</b>	Veeder Root/TLS-450				
<b>Tank Code</b>	05	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	04/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1091	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Veeder Root/TLS-450				
<b>Tank Code</b>	06	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	04/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm

<b>Tag Number</b>	1092	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Veeder Root/TLS-450				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** GLACIER GAS N GO  
1454 MT Hwy 35  
Kalispell, MT 59901-2916 Flathead

System Facility ID:15-08357

**Facility Code:** 20756  
**Last Inspected On:** 07/18/2023  
**Operating Permit Renewal Date:** 08/20/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** HARJ93, LLC (206) 834-5349 sheragroupllc@gmail.com

**Operator Contact:** Rahul Kumar;Ranch Hand Inc (406) 296-2342 tharejallc@gmail.com

**Owner/Operator:** HARJ93, LLC (206) 834-5349 sheragroupllc@gmail.com

Rahul Kumar, UST Class A Operator  
Rahul Kumar, UST Class B Operator

tharejallc@gmail.com  
tharejallc@gmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	43	<b>Tank Installed Date</b>	05/08/1982	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1420	<b>Spill Test Date</b>	05/08/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	05/08/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/08/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	05/08/2023	<b>Line Tightness Test Date</b>	05/08/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/08/2023			<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	02	<b>Tank Age</b>	43	<b>Tank Installed Date</b>	05/08/1982	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1421	<b>Spill Test Date</b>	06/26/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	05/08/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/09/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	05/08/2023	<b>Line Tightness Test Date</b>	05/08/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/08/2023			<b>ATG Type</b>	Veeder Root/TLS-300				



**Facility Summary in Flathead County in the City of Kalispell**

**Location:** KELLY RAES INC  
25 Batavia Ln  
Kalispell, MT 59901-7280 Flathead

System Facility ID:15-06101

**Facility Code:** 20691  
**Last Inspected On:** 12/07/2022  
**Operating Permit Renewal Date:** 02/03/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Kalispell Properties LLC (509) 994-6599 pamelpkp@yahoo.com

**Operator Contact:** Lisa Myers (406) 752-5880 lisaloumyers@gmail.com

**Owner/Operator:** Kalispell Properties LLC (509) 994-6599 pamelpkp@yahoo.com  
 Lisa Myers, UST Class A Operator lisaloumyers@gmail.com  
 Lisa Myers, UST Class A Operator lisaloumyers@gmail.com  
 Lisa Myers, UST Class B Operator lisaloumyers@gmail.com  
 Lisa Myers, UST Class B Operator lisaloumyers@gmail.com

<b>Tank Code</b>	03	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	02/01/1994	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4505	<b>Spill Test Date</b>	01/18/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	12/07/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	01/18/2023	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	12/07/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	12/07/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	S5	<b>Tank Age</b>	60	<b>Tank Installed Date</b>	01/01/1965	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	4506	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/03/2013	<b>Primary Tank Leak Detection</b>	Deferred	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	08/16/2016	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

<b>Tank Code</b>	S4	<b>Tank Age</b>	60	<b>Tank Installed Date</b>	01/01/1965	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	4507	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/03/2013	<b>Primary Tank Leak Detection</b>	Deferred	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	16000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	08/16/2016	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S6	<b>Tank Age</b>	6	<b>Tank Installed Date</b>	01/10/2019	<b>Tank Material</b>	Aboveground Tank	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	5891	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	01/10/2019	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	01/10/2019	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	12/07/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	12/07/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S7	<b>Tank Age</b>	6	<b>Tank Installed Date</b>	01/10/2019	<b>Tank Material</b>	Aboveground Tank	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	5892	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	01/10/2019	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	01/10/2019	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	12/07/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	12/07/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S8	<b>Tank Age</b>	6	<b>Tank Installed Date</b>	01/10/2019	<b>Tank Material</b>	Aboveground Tank	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	5893	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	01/10/2019	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	01/10/2019	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	12/07/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	12/07/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No

		<b>Overfill Test Date</b>			<b>ATG Type</b>						
<b>Tank Code</b>	S9	<b>Tank Age</b>	6	<b>Tank Installed Date</b>	01/10/2019	<b>Tank Material</b>	Aboveground Tank	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	5894	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	01/10/2019	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	01/10/2019	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	12/07/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	12/07/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** LOGAN HEALTH MEDICAL CENTER - ALERT  
325 Claremont St  
Kalispell, MT 59901-3576 Flathead

System Facility ID:15-00800

**Facility Code:** 20529  
**Last Inspected On:** 12/02/2024  
**Operating Permit Renewal Date:** 03/15/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Northwest Healthcare (406) 756-3695

**Operator Contact:** Kevin McCallum;Logan Health Whitefish;Kyle Hovey;Monti Arneson;Logan Health Whitefish (406) 212-8644;(406) 863-3533

got2fish62@gmail.com;jnewson@logan.org;khovey@krmc.org;kmccallum@logan.org;jnewson@logan.org

**Owner/Operator:** Northwest Healthcare (406) 756-3695

Kevin McCallum, UST Class A Operator  
Kevin McCallum, UST Class B Operator  
Kyle Hovey, UST Class A Operator  
Kyle Hovey, UST Class B Operator  
Monti Arneson, UST Class A Operator  
Monti Arneson, UST Class B Operator

jnewson@logan.org  
jnewson@logan.org  
khovey@krmc.org  
khovey@krmc.org  
jnewson@logan.org  
jnewson@logan.org

<b>Tank Code</b>	02	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	11/06/1990	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	1465	<b>Spill Test Date</b>	06/18/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	06/18/2024	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Jet Fuel (Jet-A, Jet-A1, JP5)	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	06/18/2024	<b>Line Tightness Test Date</b>	06/18/2024	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	12/02/2024			<b>ATG Type</b>	Gilbarco/EMC Basic				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** LOGAN HEALTH MEDICAL CENTER - LOGAN NORTH  
 320 Sunnyview Ln  
 Kalispell, MT 59901-3177 Flathead

System Facility ID:56-14072

**Facility Code:** 30724  
**Last Inspected On:** 07/06/2022  
**Operating Permit Renewal Date:** 09/29/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** Flathead Hospital Development Co (406) 752-5111 mchitwood@krmc.org

---

**Operator Contact:** Alan Wallace;Kyle Hovey (406) 212-8644;(406) 871-5890 Alanwallace@logan.org;khovey@krmc.org

---

Alan Wallace, UST Class A Operator

Alanwallace@logan.org

Alan Wallace, UST Class B Global Operator

Alanwallace@logan.org

Kyle Hovey, UST Class A Operator

khovey@krmc.org

Kyle Hovey, UST Class B Operator

khovey@krmc.org

<b>Tank Code</b>	S1	<b>Tank Age</b>	22	<b>Tank Installed Date</b>	12/16/2003	<b>Tank Material</b>	Concrete	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	4880	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/06/2022	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Deferred	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	07/06/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** MATES 101  
1645 US Hwy 93 S  
Kalispell, MT 59901-5775 Flathead

System Facility ID:15-02014

**Facility Code:** 20564  
**Last Inspected On:** 02/13/2025  
**Operating Permit Renewal Date:** 02/13/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** MATES 101 INC (929) 372-6087 101matesinc@gmail.com

**Operator Contact:** Tejas Sehgal;MATES 101 INC (929) 372-6087 101matesinc@gmail.com

**Owner/Operator:** MATES 101 INC (929) 372-6087 101matesinc@gmail.com

Michael Apoka, UST Class B Operator  
Tejas Sehgal, UST Class A Operator

101matesinc@gmail.com  
101matesinc@gmail.com

<b>Tank Code</b>	11	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	05/01/1997	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	650	<b>Spill Test Date</b>	11/22/2021	<b>Piping Installed Date</b>	11/04/2013	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/22/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	12/08/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	12/08/2021	<b>Line Tightness Test Date</b>	09/07/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/22/2021			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	12	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	05/01/1997	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	651	<b>Spill Test Date</b>	11/22/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	12/08/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	12/08/2021	<b>Line Tightness Test Date</b>	12/14/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/22/2021			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	13	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	05/01/1997	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve

<b>Tag Number</b>	652	<b>Spill Test Date</b>	11/22/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	12/08/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	12/08/2021	<b>Line Tightness Test Date</b>	08/26/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/22/2021			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	14	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	05/01/1997	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	653	<b>Spill Test Date</b>	11/22/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	12/08/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	12/08/2021	<b>Line Tightness Test Date</b>	09/30/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/22/2021			<b>ATG Type</b>	Gilbarco/EMC Basic				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** MDOT KALISPELL  
85 5th Ave E N  
Kalispell, MT 59901-4115 Flathead

System Facility ID:15-08733

**Facility Code:** 20766  
**Last Inspected On:** 07/30/2024  
**Operating Permit Renewal Date:** 11/01/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** MDOT Helena (406) 444-6163 mmurolo@mt.gov

---

**Operator Contact:** Joe Radonich;Montana Dept of Transportation;Mike Murolo;Montana Dept of Transportation;Tracy Deeds;MDOT Helena;Walt Kerttula;Montana Department of Transportation Helena (406) 444-6151;(406) 444-6163;(406) 444-7632;(406) 444-9204;(406) 444-7632;(406) 461-0769;(406) 444-6163 jraddonich@mt.gov;jraddonich@mt.gov;mmurolo@mt.gov;jraddonich@mt.gov;tdeeds@mt.gov;mmurolo@mt.gov;wkerttula@mt.gov

---

**Owner/Operator:** MDOT Helena (406) 444-6163 mmurolo@mt.gov

Joe Radonich, UST Class A Operator jraddonich@mt.gov  
 Joe Radonich, UST Class B Operator jraddonich@mt.gov  
 Mike Murolo, UST Class A Operator jraddonich@mt.gov  
 Nick Rosenbaum, UST Class B Operator nrosenbaum@mt.gov  
 Tracy Deeds, UST Class A Operator mmurolo@mt.gov  
 Walt Kerttula, UST Class A Operator wkerttula@mt.gov

<b>Tank Code</b>	04	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	12/01/1991	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2892	<b>Spill Test Date</b>	07/30/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	07/30/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/30/2024			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	05	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	12/01/1991	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2893	<b>Spill Test Date</b>	07/30/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	07/30/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No



	<b>Overfill Test Date</b> 07/30/2024						
--	--------------------------------------	--	--	--	--	--	--

		<b>ATG Type</b>					
--	--	-----------------	--	--	--	--	--

			Gilbarco/EMC Basic				
--	--	--	-----------------------	--	--	--	--

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** MICHAELS WEST FACILITY  
1011 US Hwy 2 W  
Kalispell, MT 59901-3800 Flathead

System Facility ID:15-02330

**Facility Code:** 20571  
**Last Inspected On:** 12/17/2024  
**Operating Permit Renewal Date:** 09/25/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** S AND M LLC (406) 253-2458 MAHAYES801@GMAIL.COM

**Operator Contact:** Christina Turner;Michael Hayes;Tiffany Howard (406) 755-4075 christinackt948@gmail.com;hayes6@centurytel.net;vvgirl\_1117@yahoo.com

**Owner/Operator:** S AND M LLC (406) 253-2458 MAHAYES801@GMAIL.COM

- Alice Reeves, UST Class B Operator
  - Alice Reeves, UST Class B Operator
  - Christina Turner, UST Class A Operator
  - Michael Hayes, UST Class A Operator
  - Michael Hayes, UST Class A Operator
  - Tiffany Howard, UST Class A Operator
  - Tiffany Howard, UST Class A Operator
  - Tiffany Howard, UST Class B Global Operator
  - Tiffany Howard, UST Class B Global Operator
  - Tiffany Howard, UST Class B Operator
  - Tiffany Howard, UST Class B Operator
- christinackt948@gmail.com
  - hayes6@centurytel.net
  - hayes6@centurytel.net
  - vvgirl\_1117@yahoo.com
  - vvgirl\_1117@yahoo.com
  - vvgirl\_1117@yahoo.com
  - vvgirl\_1117@yahoo.com
  - vvgirl\_1117@yahoo.com
  - vvgirl\_1117@yahoo.com

<b>Tank Code</b>	30	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	12/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	654	<b>Spill Test Date</b>	08/13/2024	<b>Piping Installed Date</b>	07/01/2024	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/13/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	12000	<b>ATG Test Date</b>	12/11/2024	<b>Line Tightness Test Date</b>	08/09/2024	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/13/2024			<b>ATG Type</b>	Franklin Fueling Systems/EVO 600				
<b>Tank Code</b>	31	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	12/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm

<b>Tag Number</b>	655	<b>Spill Test Date</b>	08/13/2024	<b>Piping Installed Date</b>	07/01/2024	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/13/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	12000	<b>ATG Test Date</b>	12/11/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/13/2024			<b>ATG Type</b>	Franklin Fueling Systems/EVO 600				
<b>Tank Code</b>	32	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	12/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	656	<b>Spill Test Date</b>	08/13/2024	<b>Piping Installed Date</b>	07/01/2024	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/13/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	12000	<b>ATG Test Date</b>	12/11/2024	<b>Line Tightness Test Date</b>	03/12/2015	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/13/2024			<b>ATG Type</b>	Franklin Fueling Systems/EVO 600				
<b>Tank Code</b>	33	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	04/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	657	<b>Spill Test Date</b>	08/13/2024	<b>Piping Installed Date</b>	07/01/2024	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/13/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	12/11/2024	<b>Line Tightness Test Date</b>	08/09/2024	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/13/2024			<b>ATG Type</b>	Franklin Fueling Systems/EVO 600				
<b>Tank Code</b>	34	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	04/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	658	<b>Spill Test Date</b>	08/13/2024	<b>Piping Installed Date</b>	07/01/2024	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/13/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible

<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	12/11/2024	<b>Line Tightness Test Date</b>	08/09/2024	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/13/2024			<b>ATG Type</b>	Franklin Fueling Systems/EVO 600				
<b>Tank Code</b>	35	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	04/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	659	<b>Spill Test Date</b>	08/13/2024	<b>Piping Installed Date</b>	07/01/2024	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/13/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	12/11/2024	<b>Line Tightness Test Date</b>	08/09/2024	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/13/2024			<b>ATG Type</b>	Franklin Fueling Systems/EVO 600				
<b>Tank Code</b>	36	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	06/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	660	<b>Spill Test Date</b>	08/13/2024	<b>Piping Installed Date</b>	07/01/2024	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/13/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	4000	<b>ATG Test Date</b>	12/11/2024	<b>Line Tightness Test Date</b>	08/09/2024	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/13/2024			<b>ATG Type</b>	Franklin Fueling Systems/EVO 600				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** MOUNTAIN WEST COOP KALISPELL  
700 Rail Park Dr  
Kalispell, MT 59901 Flathead

System Facility ID:60-15343

**Facility Code:** 32409  
**Last Inspected On:** 08/30/2023  
**Operating Permit Renewal Date:** 09/08/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Mountain West Cooperative (406) 543-8383

**Operator Contact:** Bane Simonsen;Mountain West Coop;Dusty Smith;Mountain West Coop;Michael Gourley;CHS Inc Inver Grove Heights;Vane Simonsen;Mountain West Cooperative (406) 370-3920;(651) 355-6343;(406) 543-8383;(406) 777-5441 bane.simonsen@chsinc.com;dusty.smith@chsinc.com;michael.gourley@chsinc.com;Kirsten.Tindall@chsinc.com;Vane.Simonsen@chsinc.com

**Owner/Operator:** Mountain West Cooperative (406) 543-8383

Bane Simonsen, UST Class A Operator  
Dusty Smith, UST Class A Operator  
Dusty Smith, UST Class B Operator  
Michael Gourley, UST Class A Operator  
Vane Simonsen, UST Class A Operator  
Vane Simonsen, UST Class B Operator

bane.simonsen@chsinc.com  
dusty.smith@chsinc.com  
dusty.smith@chsinc.com  
Kirsten.Tindall@chsinc.com  
Vane.Simonsen@chsinc.com  
Vane.Simonsen@chsinc.com

<b>Tank Code</b>	01	<b>Tank Age</b>	5	<b>Tank Installed Date</b>	03/09/2020	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5963	<b>Spill Test Date</b>	08/30/2023	<b>Piping Installed Date</b>	03/09/2020	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/30/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/30/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	4000	<b>ATG Test Date</b>	08/30/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/30/2023			<b>ATG Type</b>					
<b>Tank Code</b>	02	<b>Tank Age</b>	5	<b>Tank Installed Date</b>	03/09/2020	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5964	<b>Spill Test Date</b>	08/30/2023	<b>Piping Installed Date</b>	03/09/2020	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/30/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	08/30/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No

<b>Capacity</b>	8000	<b>ATG Test Date</b>	08/30/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/30/2023			<b>ATG Type</b>					
<b>Tank Code</b>	03	<b>Tank Age</b>	5	<b>Tank Installed Date</b>	03/09/2020	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5965	<b>Spill Test Date</b>	08/30/2023	<b>Piping Installed Date</b>	03/09/2020	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/30/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	08/30/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	08/30/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/30/2023			<b>ATG Type</b>					
<b>Tank Code</b>	04	<b>Tank Age</b>	5	<b>Tank Installed Date</b>	03/09/2020	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5966	<b>Spill Test Date</b>	08/30/2023	<b>Piping Installed Date</b>	03/09/2020	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/30/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/30/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	8000	<b>ATG Test Date</b>	08/30/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/30/2023			<b>ATG Type</b>					
<b>Tank Code</b>	05	<b>Tank Age</b>	5	<b>Tank Installed Date</b>	03/09/2020	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5967	<b>Spill Test Date</b>	08/30/2023	<b>Piping Installed Date</b>	03/09/2020	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/30/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	08/30/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	7000	<b>ATG Test Date</b>	08/30/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/30/2023			<b>ATG Type</b>					

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** ON YOUR WAY 103  
1278 US Hwy 2 E  
Kalispell, MT 59901-3219 Flathead

System Facility ID:15-09707

**Facility Code:** 20803  
**Last Inspected On:** 08/09/2023  
**Operating Permit Renewal Date:** 09/04/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Indian Brothers LLC (406) 759-5538 chestersupermarket@gmail.com

**Operator Contact:** Tiffany Howard vwgirl\_1117@yahoo.com

**Owner/Operator:** Indian Brothers LLC (406) 759-5538 chestersupermarket@gmail.com

- |   |                          |
|---|--------------------------|
| Sharon Trickey, UST Class B Global Operator | trickeykid@gmail.com     |
| Sharon Trickey, UST Class B Global Operator | trickeykid@gmail.com     |
| Sharon Trickey, UST Class B Operator        | trickeykid@gmail.com     |
| Sharon Trickey, UST Class B Operator        | trickeykid@gmail.com     |
| Sherry Doyle, UST Class B Global Operator   | sherryhabtech2@yahoo.com |
| Sherry Doyle, UST Class B Global Operator   | sherryhabtech2@yahoo.com |
| Tiffany Howard, UST Class A Operator        | vwgirl_1117@yahoo.com    |
| Tiffany Howard, UST Class A Operator        | vwgirl_1117@yahoo.com    |
| Tiffany Howard, UST Class B Global Operator | vwgirl_1117@yahoo.com    |
| Tiffany Howard, UST Class B Global Operator | vwgirl_1117@yahoo.com    |
| Tiffany Howard, UST Class B Operator        | vwgirl_1117@yahoo.com    |
| Tiffany Howard, UST Class B Operator        | vwgirl_1117@yahoo.com    |

<b>Tank Code</b>	01	<b>Tank Age</b>	40	<b>Tank Installed Date</b>	06/01/1985	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3005	<b>Spill Test Date</b>	09/19/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/07/2023	<b>Tank/Piping CP Test Date</b>	08/09/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	12000	<b>ATG Test Date</b>	08/09/2023	<b>Line Tightness Test Date</b>	10/08/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/09/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	40	<b>Tank Installed Date</b>	06/01/1985	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Ball Float Valve

<b>Tag Number</b>	3006	<b>Spill Test Date</b>	09/19/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/07/2023	<b>Tank/Piping CP Test Date</b>	08/09/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	12000	<b>ATG Test Date</b>	08/09/2023	<b>Line Tightness Test Date</b>	10/08/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/09/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	03	<b>Tank Age</b>	40	<b>Tank Installed Date</b>	06/01/1985	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3007	<b>Spill Test Date</b>	09/19/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/07/2023	<b>Tank/Piping CP Test Date</b>	08/09/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/09/2023	<b>Line Tightness Test Date</b>	10/08/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/09/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	04	<b>Tank Age</b>	40	<b>Tank Installed Date</b>	06/01/1985	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3008	<b>Spill Test Date</b>	08/07/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	08/07/2023	<b>Tank/Piping CP Test Date</b>	08/09/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/09/2023	<b>Line Tightness Test Date</b>	10/08/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/09/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				



**Facility Summary in Flathead County in the City of Kalispell**

**Location:** RED EAGLE AVIATION INC  
1880 US Hwy 93 S  
Kalispell, MT 59901-5729 Flathead

System Facility ID:15-11166

**Facility Code:** 20921  
**Last Inspected On:** 08/24/2023  
**Operating Permit Renewal Date:** 09/14/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Red Eagle Aviation Inc

**Operator Contact:** Paige Pitz

**paige@redeagleaviation.com**

**Owner/Operator:** Red Eagle Aviation Inc

Paige Pitz, UST Class A Operator  
Paige Pitz, UST Class B Operator

paige@redeagleaviation.com  
paige@redeagleaviation.com

<b>Tank Code</b>	03	<b>Tank Age</b>	44	<b>Tank Installed Date</b>	01/01/1981	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4144	<b>Spill Test Date</b>	09/30/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	08/24/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Aviation Gas	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	08/24/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	08/24/2023	<b>Line Tightness Test Date</b>	08/24/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/24/2023			<b>ATG Type</b>	Incon/TS-1000				
<b>Tank Code</b>	04	<b>Tank Age</b>	44	<b>Tank Installed Date</b>	01/01/1981	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4173	<b>Spill Test Date</b>	09/30/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Jet Fuel (Jet-A, Jet-A1, JP5)	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	08/24/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	08/24/2023	<b>Line Tightness Test Date</b>	11/28/2011	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/24/2023			<b>ATG Type</b>	Incon/TS-1000				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** RMC KALISPELL SHOP  
2214 US Hwy 2 E  
Kalispell, MT 59901-2816 Flathead

System Facility ID:15-04359

**Facility Code:** 20634  
**Last Inspected On:** 05/05/2023  
**Operating Permit Renewal Date:** 09/03/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Rocky Mountain Contractors Inc Kalispell (406) 752-4280

**Operator Contact:** Leona Prezeau (406) 756-6012 leona.prezeau@rmcontractors.com

**Owner/Operator:** Rocky Mountain Contractors Inc Kalispell (406) 752-4280

Leona Prezeau, UST Class A Operator  
Leona Prezeau, UST Class B Operator

leona.prezeau@rmcontractors.com  
leona.prezeau@rmcontractors.com

<b>Tank Code</b>	03	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	01/01/1994	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1284	<b>Spill Test Date</b>	03/15/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/05/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/15/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-300				
<b>Tank Code</b>	04	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	01/01/1994	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1285	<b>Spill Test Date</b>	03/15/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/05/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/15/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-300				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** SMITHS FUEL CENTER 172  
195 3rd Ave E N  
Kalispell, MT 59901-4051 Flathead

System Facility ID:56-14062

**Facility Code:** 30715  
**Last Inspected On:** 08/30/2023  
**Operating Permit Renewal Date:** 11/04/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Smiths Food and Drug (801) 974-1400 roger.gough@sfdc.com

**Operator Contact:** Braxton Hill;David Harris;Gary Dotseth;James Dye;Kerry Busey;Michael Crumley;Ronnie Houtekamer;Steven Perkins;Todd Dotseth (406) 544-6677;(406) 788-2338;(801) 560-0471;(801) 974-1206;(801) 974-1317;(801) 977-1048;(801) 977-2012 braxton.hill@sfdc.com;david.harris@sfdc.com;jim.dye@sfdc.com;kerry.busey@sfdc.com;mike.crumley@kenecopetro.com;petrocompliance@gmail.com;ronnie.houtekamer@sfdc.com;steven.perkins@sfdc.com

**Owner/Operator:** Smiths Food and Drug (801) 974-1400 roger.gough@sfdc.com

- Braxton Hill, UST Class A Operator braxton.hill@sfdc.com
- Braxton Hill, UST Class B Operator braxton.hill@sfdc.com
- David Harris, UST Class A Operator david.harris@sfdc.com
- David Harris, UST Class B Global Operator david.harris@sfdc.com
- Gary Dotseth, UST Class A Operator petrocompliance@gmail.com
- Gary Dotseth, UST Class B Global Operator petrocompliance@gmail.com
- James Dye, UST Class A Operator jim.dye@sfdc.com
- James Dye, UST Class B Global Operator jim.dye@sfdc.com
- Kerry Busey, UST Class A Operator kerry.busey@sfdc.com
- Kerry Busey, UST Class B Global Operator kerry.busey@sfdc.com
- Michael Crumley, UST Class A Operator mike.crumley@kenecopetro.com
- Michael Crumley, UST Class B Global Operator mike.crumley@kenecopetro.com
- Ronnie Houtekamer, UST Class A Operator ronnie.houtekamer@sfdc.com
- Ronnie Houtekamer, UST Class B Global Operator ronnie.houtekamer@sfdc.com
- Steven Perkins, UST Class A Operator steven.perkins@sfdc.com
- Steven Perkins, UST Class B Global Operator steven.perkins@sfdc.com
- Todd Dotseth, UST Class A Operator petrocompliance@gmail.com
- Todd Dotseth, UST Class B Operator petrocompliance@gmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	23	<b>Tank Installed Date</b>	08/23/2002	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve;High Level Alarm
<b>Tag Number</b>	4742	<b>Spill Test Date</b>	08/16/2023	<b>Piping Installed Date</b>	08/23/2002	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/24/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible

<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/24/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	20000	<b>ATG Test Date</b>	08/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/16/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	02	<b>Tank Age</b>	23	<b>Tank Installed Date</b>	08/23/2002	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve;High Level Alarm
<b>Tag Number</b>	4743	<b>Spill Test Date</b>	08/16/2023	<b>Piping Installed Date</b>	08/23/2002	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/24/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/24/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	8000	<b>ATG Test Date</b>	08/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/16/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	03	<b>Tank Age</b>	23	<b>Tank Installed Date</b>	08/23/2002	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	4744	<b>Spill Test Date</b>	08/16/2023	<b>Piping Installed Date</b>	08/23/2002	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/24/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	08/24/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	08/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/16/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** SWEET PEAKS ICE CREAM  
343 S Main St  
Kalispell, MT 59901-4847 Flathead

System Facility ID:15-04894

**Facility Code:** 20649  
**Last Inspected On:** 06/13/2019  
**Operating Permit Renewal Date:** 08/06/2022

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** Gene Towle (714) 642-5001 upstreetnews@aol.com

---

**Operator Contact:** Keith Broere;Lisa Shriver (406) 360-4417 kbroere@aetmt.com;lshr461@ecy.wa.gov

- Keith Broere, UST Class A Operator kbroere@aetmt.com
- Keith Broere, UST Class A Operator kbroere@aetmt.com
- Keith Broere, UST Class A Operator kbroere@aetmt.com
- Keith Broere, UST Class B Global Operator kbroere@aetmt.com
- Keith Broere, UST Class B Global Operator kbroere@aetmt.com
- Keith Broere, UST Class B Global Operator kbroere@aetmt.com
- Lisa Shriver, UST Class A Operator lshr461@ecy.wa.gov
- Lisa Shriver, UST Class A Operator lshr461@ecy.wa.gov
- Lisa Shriver, UST Class A Operator lshr461@ecy.wa.gov
- Lisa Shriver, UST Class A Operator lshr461@ecy.wa.gov
- Lisa Shriver, UST Class B Global Operator lshr461@ecy.wa.gov
- Lisa Shriver, UST Class B Global Operator lshr461@ecy.wa.gov
- Lisa Shriver, UST Class B Global Operator lshr461@ecy.wa.gov
- Lisa Shriver, UST Class B Global Operator lshr461@ecy.wa.gov
- Lisa Shriver, UST Class B Operator lshr461@ecy.wa.gov
- Lisa Shriver, UST Class B Operator lshr461@ecy.wa.gov
- Lisa Shriver, UST Class B Operator lshr461@ecy.wa.gov
- Lisa Shriver, UST Class B Operator lshr461@ecy.wa.gov

<b>Tank Code</b>	03	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	09/14/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	438	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/17/2019	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No

<b>Capacity</b>	24000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Incon/TS-1000				
<b>Tank Code</b>	04	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	09/14/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	439	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/17/2019	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Incon/TS-1000				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** TOWN PUMP INC KALISPELL 1  
445 W Idaho St  
Kalispell, MT 59901 Flathead

System Facility ID:15-08709

**Facility Code:** 20764  
**Last Inspected On:** 03/10/2023  
**Operating Permit Renewal Date:** 09/11/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Kalispell 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

**Operator Contact:** Trent Biggers Trentb@townpump.com

**Owner/Operator:** Kalispell 1 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com  
Trent Biggers, UST Class A Operator Trentb@townpump.com  
Trent Biggers, UST Class B Global Operator Trentb@townpump.com  
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

<b>Tank Code</b>	02	<b>Tank Age</b>	43	<b>Tank Installed Date</b>	04/14/1982	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2425	<b>Spill Test Date</b>	09/15/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/20/2021	<b>Tank/Piping CP Test Date</b>	09/15/2022	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	10/12/2023	<b>Line Tightness Test Date</b>	10/12/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/15/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	06	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	05/28/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2426	<b>Spill Test Date</b>	09/15/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/20/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	10/12/2023	<b>Line Tightness Test Date</b>	10/12/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	09/15/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	01	<b>Tank Age</b>	43	<b>Tank Installed Date</b>	04/14/1982	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4679	<b>Spill Test Date</b>	09/15/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/20/2021	<b>Tank/Piping CP Test Date</b>	09/15/2022	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	10/10/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/15/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	07	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	05/28/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4680	<b>Spill Test Date</b>	09/15/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	04/20/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	10/12/2023	<b>Line Tightness Test Date</b>	10/12/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/15/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	08	<b>Tank Age</b>	21	<b>Tank Installed Date</b>	08/18/2004	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4939	<b>Spill Test Date</b>	09/15/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/20/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	10/12/2023	<b>Line Tightness Test Date</b>	10/12/2023	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/15/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				



**Facility Summary in Flathead County in the City of Kalispell**

**Location:** TOWN PUMP INC KALISPELL 2  
1100 E Idaho St  
Kalispell, MT 59901 Flathead

System Facility ID:15-13764

**Facility Code:** 21094  
**Last Inspected On:** 05/18/2023  
**Operating Permit Renewal Date:** 09/12/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Kalispell 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

**Operator Contact:** Trent Biggers Trentb@townpump.com

**Owner/Operator:** Kalispell 2 Town Pump LLC (406) 497-6700 environmental@townpump.com

Trent Biggers, UST Class A Operator Trentb@townpump.com  
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

<b>Tank Code</b>	01	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	04/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4814	<b>Spill Test Date</b>	12/01/2022	<b>Piping Installed Date</b>	07/12/2013	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/18/2023	<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/21/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/18/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	12/01/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	02	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	04/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4815	<b>Spill Test Date</b>	12/01/2022	<b>Piping Installed Date</b>	07/12/2013	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/18/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/21/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/18/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	12/01/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

<b>Tank Code</b>	03	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	04/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4816	<b>Spill Test Date</b>	12/01/2022	<b>Piping Installed Date</b>	07/12/2013	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/18/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/21/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/18/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	12/01/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	04	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	04/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4817	<b>Spill Test Date</b>	12/01/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/18/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/21/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/18/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	12/01/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	05	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	04/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4818	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/18/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	04/21/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/18/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** TOWN PUMP INC KALISPELL 3  
2605 US Hwy 2 E  
Kalispell, MT 59901-2363 Flathead

System Facility ID:15-13732

**Facility Code:** 21092  
**Last Inspected On:** 05/16/2023  
**Operating Permit Renewal Date:** 09/13/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Kalispell 3 Town Pump (406) 497-6700 environmental@townpump.com

**Operator Contact:** Trent Biggers Trentb@townpump.com

**Owner/Operator:** Kalispell 3 Town Pump (406) 497-6700 environmental@townpump.com  
Trent Biggers, UST Class A Operator Trentb@townpump.com  
Trent Biggers, UST Class B Global Operator Trentb@townpump.com

<b>Tank Code</b>	01	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	07/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4766	<b>Spill Test Date</b>	09/13/2022	<b>Piping Installed Date</b>	12/02/2013	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/13/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	20000	<b>ATG Test Date</b>	05/16/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/13/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	02	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	07/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4767	<b>Spill Test Date</b>	09/13/2022	<b>Piping Installed Date</b>	12/02/2013	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/13/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	15000	<b>ATG Test Date</b>	05/16/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/13/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

<b>Tank Code</b>	03	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	07/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4768	<b>Spill Test Date</b>	09/13/2022	<b>Piping Installed Date</b>	12/02/2013	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/13/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	05/16/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/13/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	04	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	07/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4769	<b>Spill Test Date</b>	09/13/2022	<b>Piping Installed Date</b>	12/02/2013	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/13/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	05/16/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/13/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				
<b>Tank Code</b>	05	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	07/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4770	<b>Spill Test Date</b>	09/13/2022	<b>Piping Installed Date</b>	12/02/2013	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/13/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	05/16/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/13/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** TOWN PUMP INC KALISPELL 5  
2910 US Hwy 93 S  
Kalispell, MT 59901-7901 Flathead

System Facility ID:15-13765

**Facility Code:** 21095  
**Last Inspected On:** 05/17/2023  
**Operating Permit Renewal Date:** 09/14/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Kalispell 5 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

**Operator Contact:** Trent Biggers

**Trentb@townpump.com**

**Owner/Operator:** Kalispell 5 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

<b>Tank Code</b>	01	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3430	<b>Spill Test Date</b>	08/25/2022	<b>Piping Installed Date</b>	04/20/2011	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/25/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/17/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	05/17/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/25/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	02	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3431	<b>Spill Test Date</b>	06/01/2022	<b>Piping Installed Date</b>	04/20/2011	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/04/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				

<b>Tank Code</b>	03	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve;Positive Shutoff
<b>Tag Number</b>	3432	<b>Spill Test Date</b>	05/04/2021	<b>Piping Installed Date</b>	04/20/2011	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/04/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	20000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	04	<b>Tank Age</b>	7	<b>Tank Installed Date</b>	12/05/2018	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5793	<b>Spill Test Date</b>	05/04/2021	<b>Piping Installed Date</b>	12/05/2018	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/04/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	05	<b>Tank Age</b>	7	<b>Tank Installed Date</b>	12/05/2018	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5794	<b>Spill Test Date</b>	05/04/2021	<b>Piping Installed Date</b>	12/05/2018	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/04/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	06	<b>Tank Age</b>	7	<b>Tank Installed Date</b>	12/05/2018	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5795	<b>Spill Test Date</b>	05/04/2021	<b>Piping Installed Date</b>	12/05/2018	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No

<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/04/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	07	<b>Tank Age</b>	7	<b>Tank Installed Date</b>	12/05/2018	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5796	<b>Spill Test Date</b>	12/30/2024	<b>Piping Installed Date</b>	12/05/2018	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/04/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	08	<b>Tank Age</b>	7	<b>Tank Installed Date</b>	12/05/2018	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5797	<b>Spill Test Date</b>	05/04/2021	<b>Piping Installed Date</b>	12/05/2018	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/04/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	15000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	09	<b>Tank Age</b>	7	<b>Tank Installed Date</b>	12/05/2018	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	5798	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	12/05/2018	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	DEF (Not Regulated)	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No

<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	10	<b>Tank Age</b>	7	<b>Tank Installed Date</b>	12/05/2018	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5799	<b>Spill Test Date</b>	05/04/2021	<b>Piping Installed Date</b>	12/05/2018	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/04/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	20000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				



**Facility Summary in Flathead County in the City of Kalispell**

**Location:** TOWN PUMP KALISPELL 7  
859 W Reserve St  
Kalispell, MT 59901 Flathead

System Facility ID:60-15262

**Facility Code:** 30977  
**Last Inspected On:** 05/16/2023  
**Operating Permit Renewal Date:** 09/15/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Kalispell 7 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

**Operator Contact:** Trent Biggers

**Trentb@townpump.com**

**Owner/Operator:** Kalispell 7 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Operator

Trentb@townpump.com

<b>Tank Code</b>	01	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	11/04/2015	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5604	<b>Spill Test Date</b>	09/12/2022	<b>Piping Installed Date</b>	05/28/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/12/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/16/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	30000	<b>ATG Test Date</b>	05/16/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/12/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	02	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	11/04/2015	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5605	<b>Spill Test Date</b>	09/12/2022	<b>Piping Installed Date</b>	05/28/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/12/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/16/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	6000	<b>ATG Test Date</b>	05/16/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes

		<b>Overfill Test Date</b>	09/12/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	03	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	11/04/2015	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5606	<b>Spill Test Date</b>	09/12/2022	<b>Piping Installed Date</b>	05/28/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/12/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/16/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	15000	<b>ATG Test Date</b>	05/16/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/12/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	04	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	11/04/2015	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	5607	<b>Spill Test Date</b>	04/15/2020	<b>Piping Installed Date</b>	05/28/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Other	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	12/03/2015	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	DEF (Not Regulated)	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Approved Remote Monitoring;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Approved Remote Monitoring;Continuous Interstitial Monitoring;Not Listed	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Veeder Root/TLS-450				
<b>Tank Code</b>	05	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	11/04/2015	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5608	<b>Spill Test Date</b>	09/12/2022	<b>Piping Installed Date</b>	05/28/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/12/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/16/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No

<b>Capacity</b>	6000	<b>ATG Test Date</b>	05/16/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/12/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	06	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	11/04/2015	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5609	<b>Spill Test Date</b>	09/12/2022	<b>Piping Installed Date</b>	05/28/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/12/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/16/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	05/16/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/12/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	07	<b>Tank Age</b>	10	<b>Tank Installed Date</b>	11/04/2015	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5610	<b>Spill Test Date</b>	09/12/2023	<b>Piping Installed Date</b>	05/28/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/12/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/16/2023	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	05/16/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/12/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** UNITED PARCEL SERVICES KALISPELL  
1151 N Meridian Rd  
Kalispell, MT 59901-3003 Flathead

System Facility ID:15-04535

**Facility Code:** 20640  
**Last Inspected On:** 05/31/2019  
**Operating Permit Renewal Date:** 10/11/2022

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

<b>Owner Operator Contact:</b> United Parcel Service Inc Seattle	<b>cdd6jxd@ups.com</b>
<b>Operator Contact:</b> Dino Ostrow;Kaytee Villafrancaa;Russell Stott;Treira Smith	<b>(206) 621-6286;(206) 621-6380;(503) 329-7154;(503) 978-7678</b>
	<b>dostrow@ups.com;jstott@ups.com;kvillafranca@ups.com;treairstmith@ups.com</b>

- Dino Ostrow, UST Class A Operator dostrow@ups.com
- Dino Ostrow, UST Class A Operator dostrow@ups.com
- Dino Ostrow, UST Class B Operator dostrow@ups.com
- Dino Ostrow, UST Class B Operator dostrow@ups.com
- Kaytee Villafrancaa, UST Class A Operator kvillafranca@ups.com
- Kaytee Villafrancaa, UST Class A Operator kvillafranca@ups.com
- Kaytee Villafrancaa, UST Class B Global Operator kvillafranca@ups.com
- Kaytee Villafrancaa, UST Class B Global Operator kvillafranca@ups.com
- Russell Stott, UST Class A Operator jstott@ups.com
- Russell Stott, UST Class A Operator jstott@ups.com
- Russell Stott, UST Class B Operator jstott@ups.com
- Russell Stott, UST Class B Operator jstott@ups.com
- Treira Smith, UST Class A Operator treairsmith@ups.com
- Treira Smith, UST Class A Operator treairsmith@ups.com
- Treira Smith, UST Class B Global Operator treairsmith@ups.com
- Treira Smith, UST Class B Global Operator treairsmith@ups.com

<b>Tank Code</b>	03	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	08/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2180	<b>Spill Test Date</b>	04/05/2019	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>	04/05/2019	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	24000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	04/05/2019	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No

		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
--	--	---------------------------	--	--	--	-----------------	--	--	--	--	--

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** WARDEN HUTTERIAN BRETHREN  
295 Middle Rd  
Kalispell, MT 59901-7700 Flathead

System Facility ID:15-05344

**Facility Code:** 20661  
**Last Inspected On:** 11/04/2024  
**Operating Permit Renewal Date:** 02/12/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Warden Hutterian Brethren (406) 253-2276 pkwollman@gmail.com

**Operator Contact:** Steve Streich (406) 253-2276 spudtruck@montanasky.net

**Owner/Operator:** Warden Hutterian Brethren (406) 253-2276 pkwollman@gmail.com  
Steve Streich, UST Class A Operator spudtruck@montanasky.net  
Steve Streich, UST Class B Global Operator spudtruck@montanasky.net

<b>Tank Code</b>	S3	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	11/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	869	<b>Spill Test Date</b>	11/04/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/04/2024	<b>Primary Tank Leak Detection</b>	Manual Tank Gauging	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/23/2025			<b>ATG Type</b>					
<b>Tank Code</b>	S4	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	11/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	870	<b>Spill Test Date</b>	11/04/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/04/2024	<b>Primary Tank Leak Detection</b>	Manual Tank Gauging	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/23/2025			<b>ATG Type</b>					

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** WEST VALLEY SCHOOL DIST 1  
2290 Farm To Market Rd  
Kalispell, MT 59901-7108 Flathead

System Facility ID:15-10295

**Facility Code:** 20846  
**Last Inspected On:** 08/23/2023  
**Operating Permit Renewal Date:** 08/24/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** School Dist 1 West Valley (406) 755-7239 crisher@westvalleyschool.com

**Operator Contact:** Phillip Jackson (406) 755-7239 pjackson@westvalleyschool.com

**Owner/Operator:** School Dist 1 West Valley (406) 755-7239 crisher@westvalleyschool.com  
Phillip Jackson, UST Class A Operator pjackson@westvalleyschool.com  
Phillip Jackson, UST Class B Operator pjackson@westvalleyschool.com

<b>Tank Code</b>	S2	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	08/09/1995	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Copper	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2249	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Secondary Containment Chase	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/23/2015	<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Heating Oil	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Manual Tank Gauging	<b>Primary Pipe Detection</b>	3-Year Line Tightness Test	<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** WHITE OAK SUPER STOP  
4810 US Hwy 93 S  
Kalispell, MT 59901-7985 Flathead

System Facility ID:15-13287

**Facility Code:** 21043  
**Last Inspected On:** 09/13/2023  
**Operating Permit Renewal Date:** 10/17/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** Greg Tabish;Tabish Brothers Distributors Inc (406) 543-7621;(406) 728-2575 lss@gwpetrol.com;zootown@gwpetrol.com

---

**Operator Contact:** Amber Terrell;Karly Shafer;Kristy Stevenson (406) 396-2206;(406) 857-2344;(406) 871-8400 ambert2007@gmail.com;karly@gwpetrol.com;kristyinmontana@gmail.com

---

**Owner/Operator:** Greg Tabish (406) 728-2575 zootown@gwpetrol.com

**Owner/Operator:** Tabish Brothers Distributors Inc (406) 728-2575 zootown@gwpetrol.com

Amber Terrell, UST Class A Operator ambert2007@gmail.com  
 Amber Terrell, UST Class B Operator ambert2007@gmail.com  
 Karly Shafer, UST Class A Operator karly@gwpetrol.com  
 Karly Shafer, UST Class B Global Operator karly@gwpetrol.com  
 Kristy Stevenson, UST Class A Operator kristyinmontana@gmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	42	<b>Tank Installed Date</b>	10/01/1983	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4481	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	09/01/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2017	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/18/2017	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	10/09/2019	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/12/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	02	<b>Tank Age</b>	42	<b>Tank Installed Date</b>	11/01/1983	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4482	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	09/01/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2017	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/18/2017	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No



<b>Capacity</b>	10000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	10/09/2019	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	03	<b>Tank Age</b>	42	<b>Tank Installed Date</b>	11/01/1983	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4483	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	09/01/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2017	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/18/2017	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	10/09/2019	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Veeder Root/TLS-450				
<b>Tank Code</b>	04	<b>Tank Age</b>	8	<b>Tank Installed Date</b>	09/01/2017	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5781	<b>Spill Test Date</b>	09/12/2023	<b>Piping Installed Date</b>	09/01/2017	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/04/2017	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	10/09/2019	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** WOODLAND QUIKSTOP  
81 Woodland Park Dr  
Kalispell, MT 59901-4665 Flathead

System Facility ID:15-00115

**Facility Code:** 20518  
**Last Inspected On:** 03/11/2025  
**Operating Permit Renewal Date:** 06/11/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Kalispell Properties LLC

**(509) 994-6599**

**pamelpkp@yahoo.com**

**Operator Contact:** Semere Kentiba

**sammyimagination@gmail.com**

**Owner/Operator:** Kalispell Properties LLC

**(509) 994-6599**

**pamelpkp@yahoo.com**

Semere Kentiba, UST Class A Operator  
Semere Kentiba, UST Class B Global Operator

**sammyimagination@gmail.com**  
**sammyimagination@gmail.com**

<b>Tank Code</b>	03	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	07/23/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3524	<b>Spill Test Date</b>	02/02/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	02/02/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	02/02/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	02/02/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	04	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	07/23/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3525	<b>Spill Test Date</b>	02/02/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	02/02/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	02/02/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	02/02/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				

## Facility Summary in Flathead County in the City of Kalispell

**Location:** WOODYS COUNTRY STORE INC  
3333 MT Hwy 35  
Kalispell, MT 59901-7724 Flathead

System Facility ID:15-05801

**Facility Code:** 20677  
**Last Inspected On:** 11/06/2023  
**Operating Permit Renewal Date:** 03/17/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Woodys Country Store Inc (406) 755-5544

**Operator Contact:** Charles Weiss (406) 253-2818 charlesalanweis@gmail.com

**Owner/Operator:** Woodys Country Store Inc (406) 755-5544

Charles Weiss, UST Class A Operator  
Charles Weiss, UST Class B Operator

charlesalanweis@gmail.com  
charlesalanweis@gmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	41	<b>Tank Installed Date</b>	12/05/1984	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2243	<b>Spill Test Date</b>	10/18/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/18/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	02/10/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/18/2023			<b>ATG Type</b>	Franklin Fueling Systems/EVO 600				
<b>Tank Code</b>	02	<b>Tank Age</b>	41	<b>Tank Installed Date</b>	12/05/1984	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2244	<b>Spill Test Date</b>	10/18/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/18/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	02/10/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/18/2023			<b>ATG Type</b>	Franklin Fueling Systems/EVO 600				
<b>Tank Code</b>	03	<b>Tank Age</b>	41	<b>Tank Installed Date</b>	12/05/1984	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2245	<b>Spill Test Date</b>	10/18/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No

<b>Tank Status</b>	<b>Currently in Use</b>	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/18/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	02/10/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/18/2023			<b>ATG Type</b>	Franklin Fueling Systems/EVO 600				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** ZIP TRIP 39  
305 E Idaho St  
Kalispell, MT 59901-4134 Flathead

System Facility ID:15-03915

**Facility Code:** 20624  
**Last Inspected On:** 08/14/2024  
**Operating Permit Renewal Date:** 01/24/2024

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

**Operator Contact:** Jim Alford (509) 536-7418 jim.alford@chsinc.com

**Owner/Operator:** CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

- |  |                           |
|--|---------------------------|
| Andrew Duffie, UST Class B Operator        | duffstars@yahoo.com       |
| Andrew Duffie, UST Class B Operator        | duffstars@yahoo.com       |
| Ian Johnstone, UST Class B Global Operator | ianj@ziptrip.net          |
| Ian Johnstone, UST Class B Global Operator | ianj@ziptrip.net          |
| Jim Alford, UST Class A Operator           | jim.alford@chsinc.com     |
| Jim Alford, UST Class A Operator           | jim.alford@chsinc.com     |
| Jim Alford, UST Class B Global Operator    | jim.alford@chsinc.com     |
| Jim Alford, UST Class B Global Operator    | jim.alford@chsinc.com     |
| Justin Mace, UST Class B Operator          | minuzle@gmail.com         |
| Justin Mace, UST Class B Operator          | minuzle@gmail.com         |
| Wesley Bentley, UST Class B Operator       | wesley.bentley@chsinc.com |

<b>Tank Code</b>	04	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	1306	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	24000	<b>ATG Test Date</b>	06/30/2020	<b>Line Tightness Test Date</b>	06/30/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	05	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm

<b>Tag Number</b>	1307	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	24000	<b>ATG Test Date</b>	06/30/2020	<b>Line Tightness Test Date</b>	06/30/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	06	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	1308	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	06/30/2020	<b>Line Tightness Test Date</b>	06/30/2020	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	07	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	1309	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	06/30/2020	<b>Line Tightness Test Date</b>	06/30/2020	<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	08	<b>Tank Age</b>	2	<b>Tank Installed Date</b>	09/06/2023	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	6196	<b>Spill Test Date</b>	01/09/2024	<b>Piping Installed Date</b>	09/06/2023	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	01/09/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	

<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	14000	<b>ATG Test Date</b>	01/17/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	01/09/2024			<b>ATG Type</b>					
<b>Tank Code</b>	09	<b>Tank Age</b>	2	<b>Tank Installed Date</b>	09/06/2023	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	6197	<b>Spill Test Date</b>	01/09/2024	<b>Piping Installed Date</b>	09/06/2023	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	01/09/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	6000	<b>ATG Test Date</b>	01/17/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	01/09/2024			<b>ATG Type</b>					
<b>Tank Code</b>	10	<b>Tank Age</b>	2	<b>Tank Installed Date</b>	09/06/2023	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	6198	<b>Spill Test Date</b>	01/09/2024	<b>Piping Installed Date</b>	09/06/2023	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	01/09/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	14000	<b>ATG Test Date</b>	01/17/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	01/09/2024			<b>ATG Type</b>					
<b>Tank Code</b>	11	<b>Tank Age</b>	2	<b>Tank Installed Date</b>	09/06/2023	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	6199	<b>Spill Test Date</b>	01/09/2024	<b>Piping Installed Date</b>	09/06/2023	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	6000	<b>ATG Test Date</b>	01/17/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	01/09/2024			<b>ATG Type</b>					

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** ZIP TRIP 40  
1420 1st Ave E  
Kalispell, MT 59901 Flathead

System Facility ID:15-02331

**Facility Code:** 20572  
**Last Inspected On:** 09/15/2022  
**Operating Permit Renewal Date:** 03/14/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

**Operator Contact:** Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

**Owner/Operator:** CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jason Brenner, UST Class B Operator  
Jim Alford, UST Class A Operator  
Jim Alford, UST Class A Operator  
Jim Alford, UST Class B Operator  
Jim Alford, UST Class B Operator  
Luci Tuttle, UST Class B Operator  
Sean Hurley, UST Class A Operator  
Sean Hurley, UST Class A Operator

jason.brenner@chsinc.com  
jim.alford@chsinc.com  
jim.alford@chsinc.com  
jim.alford@chsinc.com  
jim.alford@chsinc.com  
Lucinda.Tuttle@chsinc.com  
sean.hurley@chsinc.com  
sean.hurley@chsinc.com

<b>Tank Code</b>	01	<b>Tank Age</b>	43	<b>Tank Installed Date</b>	04/30/1982	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	1303	<b>Spill Test Date</b>	09/17/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/26/2022	<b>Tank/Piping CP Test Date</b>	07/01/2020	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	07/26/2022	<b>Line Tightness Test Date</b>	07/26/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/26/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	02	<b>Tank Age</b>	43	<b>Tank Installed Date</b>	04/30/1982	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	1304	<b>Spill Test Date</b>	09/17/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current



<b>Product</b>	Diesel	<b>PLLD Test Date</b>	07/26/2022	<b>Tank/Piping CP Test Date</b>	07/01/2020	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	07/26/2022	<b>Line Tightness Test Date</b>	07/26/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/26/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	03	<b>Tank Age</b>	43	<b>Tank Installed Date</b>	04/30/1982	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve; Flapper Valve
<b>Tag Number</b>	1305	<b>Spill Test Date</b>	09/17/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/26/2022	<b>Tank/Piping CP Test Date</b>	07/01/2020	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	07/26/2022	<b>Line Tightness Test Date</b>	07/26/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/26/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				

**Facility Summary in Flathead County in the City of Kalispell**

**Location:** ZIP TRIP 41  
2490 US Hwy 93 N  
Kalispell, MT 59901-2148 Flathead

System Facility ID:15-07432

**Facility Code:** 20730  
**Last Inspected On:** 07/05/2022  
**Operating Permit Renewal Date:** 11/09/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

**Operator Contact:** Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

**Owner/Operator:** CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jason Brenner, UST Class B Operator  
Jim Alford, UST Class A Operator  
Jim Alford, UST Class B Operator  
Luci Tuttle, UST Class B Operator  
Sean Hurley, UST Class A Operator

jason.brenner@chsinc.com  
jim.alford@chsinc.com  
jim.alford@chsinc.com  
Lucinda.Tuttle@chsinc.com  
sean.hurley@chsinc.com

<b>Tank Code</b>	01	<b>Tank Age</b>	40	<b>Tank Installed Date</b>	04/23/1985	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	382	<b>Spill Test Date</b>	09/16/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	06/27/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/29/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	06/27/2022	<b>Line Tightness Test Date</b>	06/27/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/16/2021			<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	02	<b>Tank Age</b>	40	<b>Tank Installed Date</b>	04/23/1985	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	383	<b>Spill Test Date</b>	09/16/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	09/26/2018	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/29/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	06/27/2022	<b>Line Tightness Test Date</b>	09/26/2018	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	09/16/2021			<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	03	<b>Tank Age</b>	23	<b>Tank Installed Date</b>	06/21/2002	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve; Flapper Valve
<b>Tag Number</b>	4685	<b>Spill Test Date</b>	09/16/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	06/27/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/29/2015	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	06/27/2022	<b>Line Tightness Test Date</b>	06/27/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/16/2021			<b>ATG Type</b>	Veeder Root/TLS-300				

**Facility Summary in Flathead County in the City of Lakeside**

**Location:** ARIES GAS AND GROCERY  
7254 US Hwy 93  
Lakeside, MT 59922 Flathead

System Facility ID:15-13487

**Facility Code:** 21062  
**Last Inspected On:** 10/20/2022  
**Operating Permit Renewal Date:** 12/06/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** RKR LLC (406) 890-5047 ramdeeprokha@hotmail.com

**Operator Contact:** Asham Singh;Janet Heinze;Ramdeep Kaur;Rod Phillips;Steven Heinze (406) 844-0336;(406) 871-7278;(406) 890-5047;(803) 522-5352 ashamjeet\_singh@yahoo.com;backinblack\_07@hotmail.com;ramdeeprokha@yahoo.com;sjdheinze@hotmail.com

**Owner/Operator:** RKR LLC (406) 890-5047 ramdeeprokha@hotmail.com

- |                                     |                            |
|-------------------------------------|----------------------------|
| Asham Singh, UST Class A Operator   | ashamjeet_singh@yahoo.com  |
| Asham Singh, UST Class A Operator   | ashamjeet_singh@yahoo.com  |
| Asham Singh, UST Class B Operator   | ashamjeet_singh@yahoo.com  |
| Asham Singh, UST Class B Operator   | ashamjeet_singh@yahoo.com  |
| Janet Heinze, UST Class A Operator  | sjdheinze@hotmail.com      |
| Janet Heinze, UST Class A Operator  | sjdheinze@hotmail.com      |
| Janet Heinze, UST Class B Operator  | sjdheinze@hotmail.com      |
| Janet Heinze, UST Class B Operator  | sjdheinze@hotmail.com      |
| Ramdeep Kaur, UST Class A Operator  | ramdeeprokha@yahoo.com     |
| Ramdeep Kaur, UST Class A Operator  | ramdeeprokha@yahoo.com     |
| Rod Phillips, UST Class A Operator  | backinblack_07@hotmail.com |
| Rod Phillips, UST Class A Operator  | backinblack_07@hotmail.com |
| Rod Phillips, UST Class B Operator  | backinblack_07@hotmail.com |
| Rod Phillips, UST Class B Operator  | backinblack_07@hotmail.com |
| Steven Heinze, UST Class A Operator | sjdheinze@hotmail.com      |
| Steven Heinze, UST Class A Operator | sjdheinze@hotmail.com      |

<b>Tank Code</b>	01	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	08/01/1994	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;Flapper Valve
<b>Tag Number</b>	666	<b>Spill Test Date</b>	09/21/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	09/21/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	03/19/2024	<b>Line Tightness Test Date</b>	09/21/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	10/19/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	02	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	08/01/1994	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve; Flapper Valve
<b>Tag Number</b>	667	<b>Spill Test Date</b>	09/21/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	09/21/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	03/19/2024	<b>Line Tightness Test Date</b>	09/21/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/19/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	03	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	08/01/1994	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve; Flapper Valve
<b>Tag Number</b>	668	<b>Spill Test Date</b>	09/21/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	09/21/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	7000	<b>ATG Test Date</b>	03/19/2024	<b>Line Tightness Test Date</b>	09/21/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/19/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	04	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	08/01/1994	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	669	<b>Spill Test Date</b>	09/21/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	09/21/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	03/19/2024	<b>Line Tightness Test Date</b>	09/21/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/19/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				

**Facility Summary in Flathead County in the City of Lakeside**

**Location:** ARSR GATR BLDG  
 Blacktail Mountain Rd  
 Lakeside, MT 59922 Flathead

System Facility ID:15-03618

**Facility Code:** 20613  
**Last Inspected On:** 02/14/2024  
**Operating Permit Renewal Date:** 02/19/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Federal Aviation Admin Renton (206) 227-2367

**Operator Contact:** Rob Jodsaas rob.jodsaas@faa.gov

**Owner/Operator:** Federal Aviation Admin Renton (206) 227-2367

Rob Jodsaas, UST Class A Operator  
 Rob Jodsaas, UST Class B Operator

rob.jodsaas@faa.gov  
 rob.jodsaas@faa.gov

<b>Tank Code</b>	S5	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	09/25/1996	<b>Tank Material</b>	Unknown	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	4565	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	02/14/2024	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	02/14/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Flathead County in the City of Lakeside**

**Location:** JOE BLOGZ  
7170 US Hwy 93 S  
Lakeside, MT 59922-9728 Flathead

System Facility ID:15-10513

**Facility Code:** 20867  
**Last Inspected On:** 11/20/2024  
**Operating Permit Renewal Date:** 02/20/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** FH Properties LLC (509) 833-6629 JoeBlogz@gmail.com

**Operator Contact:** Atinderpal Chana;FH Properties LLC (509) 833-6629 Joeblogzcasino@gmail.com;JoeBlogz@gmail.com

**Owner/Operator:** FH Properties LLC (509) 833-6629 JoeBlogz@gmail.com  
Atinderpal Chana, UST Class A Operator JoeBlogz@gmail.com  
Atinderpal Chana, UST Class B Operator JoeBlogz@gmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	40	<b>Tank Installed Date</b>	03/07/1985	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3798	<b>Spill Test Date</b>	11/20/2024	<b>Piping Installed Date</b>	04/01/1999	<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/20/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	11/20/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/20/2024			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	02	<b>Tank Age</b>	40	<b>Tank Installed Date</b>	03/07/1985	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3799	<b>Spill Test Date</b>	11/20/2024	<b>Piping Installed Date</b>	04/01/1999	<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/20/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	11/20/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/20/2024			<b>ATG Type</b>	Gilbarco/EMC Basic				

**Facility Summary in Flathead County in the City of Lakeside**

**Location:** MOCCASIN LODGE LLC  
616 Lutheran Camp Rd  
Lakeside, MT 59922 Flathead

System Facility ID:56-14069

**Facility Code:** 30721  
**Last Inspected On:** 11/15/2023  
**Operating Permit Renewal Date:** 02/19/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Moccasin Lodge LLC (406) 844-3569 kgnelson@centurytel.net

**Operator Contact:** Kathleen Nelson (406) 253-1021 kgnelson@centurytel.net

**Owner/Operator:** Moccasin Lodge LLC (406) 844-3569 kgnelson@centurytel.net

Kathleen Nelson, UST Class A Operator  
Kathleen Nelson, UST Class B Operator

kgnelson@centurytel.net  
kgnelson@centurytel.net

<b>Tank Code</b>	S1	<b>Tank Age</b>	23	<b>Tank Installed Date</b>	12/30/2002	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4781	<b>Spill Test Date</b>	11/15/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/15/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Heating Oil	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Manual Tank Gauging	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	1600	<b>ATG Test Date</b>	11/15/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/15/2023			<b>ATG Type</b>					



**Facility Summary in Flathead County in the City of Marion**

**Location:** CABIN CREEK LANDING LLC  
166 Wright Way  
Marion, MT 59925-9874 Flathead

System Facility ID:56-14102

**Facility Code:** 30745  
**Last Inspected On:** 01/26/2023  
**Operating Permit Renewal Date:** 04/04/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Cabin Creek Landing LLC Dillon

**randy@dillonflyingservice.com**

**Operator Contact:** J. Peter Gross

**(406) 270-0910**

**petegrossbackcountryflyingservice@cabincreek.com**

**Owner/Operator:** Cabin Creek Landing LLC Dillon

randy@dillonflyingservice.com

J. Peter Gross, UST Class A Operator

petegrossbackcountryflyingservice@cabincreek.com

J. Peter Gross, UST Class B Operator

petegrossbackcountryflyingservice@cabincreek.com

<b>Tank Code</b>	01	<b>Tank Age</b>	21	<b>Tank Installed Date</b>	02/09/2004	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4883	<b>Spill Test Date</b>	09/08/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	09/08/2022	<b>Sump Tightness Test Date</b>	09/08/2022	<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring; Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Aviation Gas	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	09/08/2022	<b>Line Tightness Test Date</b>	09/08/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/08/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/EMC Basic				

**Facility Summary in Flathead County in the City of Marion**

**Location:** CANI INC  
8205 US Hwy 2 W  
Marion, MT 59925-9740 Flathead

System Facility ID:56-13803

**Facility Code:** 30490  
**Last Inspected On:** 09/08/2022  
**Operating Permit Renewal Date:** 11/06/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** CANI Inc (406) 854-2992 caniincstore@gmail.com

**Operator Contact:** Tonia Gardner tonia159@hotmail.com

**Owner/Operator:** CANI Inc (406) 854-2992 caniincstore@gmail.com

Tonia Gardner, UST Class A Operator  
Tonia Gardner, UST Class B Operator

tonia159@hotmail.com  
tonia159@hotmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	08/01/1997	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	834	<b>Spill Test Date</b>	09/06/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/07/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/07/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	09/07/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/06/2022			<b>ATG Type</b>	EMCO Electronics/EECO 1500				
<b>Tank Code</b>	02	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	08/01/1997	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	835	<b>Spill Test Date</b>	10/27/2022	<b>Piping Installed Date</b>	02/20/2015	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/07/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/07/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	09/07/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/27/2022			<b>ATG Type</b>	EMCO Electronics/EECO 1500				

<b>Tank Code</b>	03	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	08/01/1997	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	836	<b>Spill Test Date</b>	10/27/2022	<b>Piping Installed Date</b>	02/20/2015	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/07/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/07/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	09/07/2022	<b>Line Tightness Test Date</b>	02/12/2015	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/27/2022			<b>ATG Type</b>	EMCO Electronics/EECO 1500				

**Facility Summary in Flathead County in the City of Marion**

**Location:** MOOSE CROSSING INC  
8405 US Hwy 2 W  
Marion, MT 59925-9701 Flathead

System Facility ID:15-10015

**Facility Code:** 20822  
**Last Inspected On:** 09/28/2021  
**Operating Permit Renewal Date:** 10/12/2024

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Vern Taber Moose Crossing Inc;Virginia Guderjahn (406) 854-2070;(406) 854-2292

**Operator Contact:** Rebecca Taber;Vernon Taber (406) 854-2070 founds@live.com;moosecrossing406@gmail.com

Rebecca Taber, UST Class A Operator  
Rebecca Taber, UST Class B Operator  
Vernon Taber, UST Class A Operator

founds@live.com  
founds@live.com  
moosecrossing406@gmail.com

<b>Tank Code</b>	S3	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	09/25/1997	<b>Tank Material</b>	Unknown	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	1245	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/28/2021	<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	Gravity Feed	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	03/09/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S4	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	09/25/1997	<b>Tank Material</b>	Unknown	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	1246	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/28/2021	<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	03/09/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

<b>Tank Code</b>	S5	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	09/25/1997	<b>Tank Material</b>	Unknown	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	1247	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/28/2021	<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	03/09/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Flathead County in the City of Olney**

**Location:** GLACIER GOLD LLC  
255 Good Creek Rd  
Olney, MT 59927 Flathead

System Facility ID:15-02973

**Facility Code:** 20589  
**Last Inspected On:** 01/23/2024  
**Operating Permit Renewal Date:** 01/23/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Glacier Gold LLC

**(406) 881-3030**

**Operator Contact:** Joe Warner

**(406) 881-3030**

**glacieregold@centurytel.net**

**Owner/Operator:** Glacier Gold LLC

**(406) 881-3030**

Joe Warner, UST Class A Operator  
Joe Warner, UST Class B Operator

glacieregold@centurytel.net  
glacieregold@centurytel.net

<b>Tank Code</b>	03	<b>Tank Age</b>	37	<b>Tank Installed Date</b>	03/29/1988	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	No Piping	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3583	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>		<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	01/23/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	9000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.1	<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Flathead County in the City of Olney**

**Location:** OLNEY STORE  
105 Olney Loop Rd  
Olney, MT 59927 Flathead

System Facility ID:56-13849

**Facility Code:** 30531  
**Last Inspected On:** 07/28/2022  
**Operating Permit Renewal Date:** 07/28/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Jon Lemburg (406) 471-5557 lastbestplace@gmail.com

**Operator Contact:** Fred Peters;Jon Lemburg;Briggs Mercantile (406) 471-5557;(406) 881-2100;(406) 881-4010 birddog@blackfoot.net;lastbestplace@gmail.com

**Owner/Operator:** Jon Lemburg (406) 471-5557 lastbestplace@gmail.com  
Fred Peters, UST Class A Operator birddog@blackfoot.net  
Fred Peters, UST Class B Operator birddog@blackfoot.net  
Jon Lemburg, UST Class A Operator lastbestplace@gmail.com

<b>Tank Code</b>	03	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	06/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	3504	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	07/28/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	EMCO Electronics/EECO 1500				
<b>Tank Code</b>	04	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	06/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	3505	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	07/28/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	500	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	EMCO Electronics/EECO 1500				

<b>Tank Code</b>	05	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	06/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	3506	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	07/28/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	500	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	EMCO Electronics/EECO 1500				



**Facility Summary in Flathead County in the City of West Glacier**

**Location:** GLACIER HIGHLAND RESORT  
12555 US Hwy 2 E  
West Glacier, MT 59936 Flathead

System Facility ID:15-10685

**Facility Code:** 20877  
**Last Inspected On:** 09/14/2023  
**Operating Permit Renewal Date:** 09/17/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Glacier Highland Resort;Joseph Hoff (406) 888-5427 glacierhighland@gmail.com

**Operator Contact:** Joseph Hoff bubba284@icloud.com

**Owner/Operator:** Glacier Highland Resort (406) 888-5427 glacierhighland@gmail.com

**Owner/Operator:** Joseph B Hoff (406) 888-5427 glacierhighland@gmail.com

Joseph Hoff, UST Class A Operator bubba284@icloud.com  
Joseph Hoff, UST Class B Global Operator bubba284@icloud.com

<b>Tank Code</b>	03	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3214	<b>Spill Test Date</b>	09/13/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	09/13/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/14/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	09/13/2023	<b>Line Tightness Test Date</b>	09/13/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/13/2023			<b>ATG Type</b>	EMCO Electronics/EECO 1500				
<b>Tank Code</b>	04	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3215	<b>Spill Test Date</b>	09/13/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	09/13/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/14/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	09/13/2023	<b>Line Tightness Test Date</b>	09/13/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/13/2023			<b>ATG Type</b>	EMCO Electronics/EECO 1500				

**Facility Summary in Flathead County in the City of West Glacier**

**Location:** GLACIER PARK HDQTRS GAS PUMPS  
64 Grinnell Dr  
West Glacier, MT 59936-0128 Flathead

System Facility ID:15-09491

**Facility Code:** 20794  
**Last Inspected On:** 06/24/2023  
**Operating Permit Renewal Date:** 08/02/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Glacier National Park (406) 732-7718 john\_lucke@nps.gov

**Operator Contact:** Franklin Thompson;Lori King;Patrick Glynn (406) 888-7967 frank\_thompson@nps.gov;patrick\_glynn@nps.gov

**Owner/Operator:** Glacier National Park (406) 732-7718 john\_lucke@nps.gov

Franklin Thompson, UST Class A Operator frank\_thompson@nps.gov  
Franklin Thompson, UST Class B Operator frank\_thompson@nps.gov  
Lori King, UST Class A Operator  
Lori King, UST Class B Operator  
Patrick Glynn, UST Class A Operator patrick\_glynn@nps.gov  
Patrick Glynn, UST Class B Operator patrick\_glynn@nps.gov

<b>Tank Code</b>	06	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	11/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	1219	<b>Spill Test Date</b>	06/21/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	06/21/2023	<b>Sump Tightness Test Date</b>	06/21/2023	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/21/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	06/21/2023	<b>Line Tightness Test Date</b>	06/21/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/21/2023			<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	07	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	11/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	1220	<b>Spill Test Date</b>	06/21/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	06/21/2023	<b>Sump Tightness Test Date</b>	06/21/2023	<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/21/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No

<b>Capacity</b>	12000	<b>ATG Test Date</b>	06/21/2023	<b>Line Tightness Test Date</b>	07/07/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/21/2023			<b>ATG Type</b>	Veeder Root/TLS-300				

**Facility Summary in Flathead County in the City of West Glacier**

**Location:** MRC GAS STATION  
200 Going To The Sun Rd  
West Glacier, MT 59936 Flathead

System Facility ID:15-03288

**Facility Code:** 20602  
**Last Inspected On:** 08/15/2023  
**Operating Permit Renewal Date:** 12/02/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Glacier Park Inc (406) 892-6708 lwyrick@pursuitcollection.com

**Operator Contact:** Charles Krasselt (406) 270-8013 ckrasselt@glacierparkinc.com

**Owner/Operator:** Glacier Park Inc (406) 892-6708 lwyrick@pursuitcollection.com

Charles Krasselt, UST Class A Operator	ckrasselt@glacierparkinc.com
Charles Krasselt, UST Class A Operator	ckrasselt@glacierparkinc.com
Charles Krasselt, UST Class B Global Operator	ckrasselt@glacierparkinc.com
Charles Krasselt, UST Class B Global Operator	ckrasselt@glacierparkinc.com

<b>Tank Code</b>	04	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	10/23/1989	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2246	<b>Spill Test Date</b>	04/28/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	04/06/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/09/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	04/06/2023	<b>Line Tightness Test Date</b>	04/06/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/28/2022			<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	05	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	10/23/1989	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	No Piping	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2247	<b>Spill Test Date</b>	04/28/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	03/16/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/09/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	04/06/2023	<b>Line Tightness Test Date</b>	03/16/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/28/2022			<b>ATG Type</b>	Veeder Root/TLS-300				

<b>Tank Code</b>	06	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	10/23/1989	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2248	<b>Spill Test Date</b>	04/28/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	04/06/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/09/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	04/06/2023	<b>Line Tightness Test Date</b>	04/06/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/28/2022			<b>ATG Type</b>	Veeder Root/TLS-300				

**Facility Summary in Flathead County in the City of Whitefish**

**Location:** ALPINE VILLAGE MARKET  
721 Wisconsin Ave  
Whitefish, MT 59937-2131 Flathead

System Facility ID:15-10944

**Facility Code:** 20900  
**Last Inspected On:** 09/20/2023  
**Operating Permit Renewal Date:** 12/31/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Super Grocer Corp (406) 862-5025

**Operator Contact:** Alan Reisch;Brent Silcox (406) 862-5025 alpine1@aboutmontana.net

**Owner/Operator:** Super Grocer Corp (406) 862-5025

Alan Reisch, UST Class A Operator  
Alan Reisch, UST Class B Operator  
Brent Silcox, UST Class A Operator  
Brent Silcox, UST Class B Operator

alpine1@aboutmontana.net  
alpine1@aboutmontana.net  
alpine1@aboutmontana.net  
alpine1@aboutmontana.net

<b>Tank Code</b>	01	<b>Tank Age</b>	44	<b>Tank Installed Date</b>	04/21/1981	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4692	<b>Spill Test Date</b>	12/21/2023	<b>Piping Installed Date</b>	09/13/2002	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	09/19/2023	<b>Tank/Piping CP Test Date</b>	09/19/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	09/19/2023	<b>Line Tightness Test Date</b>	09/10/2014	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/19/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	44	<b>Tank Installed Date</b>	04/21/1981	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4693	<b>Spill Test Date</b>	12/21/2023	<b>Piping Installed Date</b>	09/13/2002	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	09/19/2023	<b>Tank/Piping CP Test Date</b>	09/19/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	09/19/2023	<b>Line Tightness Test Date</b>	08/15/2014	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	09/19/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	03	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	10/01/1991	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4694	<b>Spill Test Date</b>	12/21/2023	<b>Piping Installed Date</b>	09/13/2002	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	09/19/2023	<b>Tank/Piping CP Test Date</b>	09/19/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	09/19/2023	<b>Line Tightness Test Date</b>	09/09/2017	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	12/21/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Flathead County in the City of Whitefish**

**Location:** BIG MOUNTAIN SKI RESORT SHOP  
3910 Big Mountain Rd  
Whitefish, MT 59937 Flathead

System Facility ID:15-05579

**Facility Code:** 20672  
**Last Inspected On:** 09/06/2022  
**Operating Permit Renewal Date:** 10/22/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Winter Sports Inc (406) 862-2987

**Operator Contact:** Gardner Beougher (406) 862-2987 gardnerb@skiwhhitefish.com

**Owner/Operator:** Winter Sports Inc (406) 862-2987

Gardner Beougher, UST Class A Operator  
Gardner Beougher, UST Class B Operator

gardnerb@skiwhhitefish.com  
gardnerb@skiwhhitefish.com

<b>Tank Code</b>	08	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	09/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2295	<b>Spill Test Date</b>	07/13/2022	<b>Piping Installed Date</b>	07/20/2007	<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	07/14/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	07/13/2022	<b>Line Tightness Test Date</b>	07/14/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/13/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450				
<b>Tank Code</b>	09	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	07/14/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2296	<b>Spill Test Date</b>	07/13/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	07/13/2022	<b>Line Tightness Test Date</b>	11/01/2006	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/13/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/Other				
<b>Tank Code</b>	10	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	07/14/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2297	<b>Spill Test Date</b>	09/01/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No



<b>Tank Status</b>	<b>Currently in Use</b>	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	07/13/2022	<b>Line Tightness Test Date</b>	11/01/2006	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/13/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/Other				

**Facility Summary in Flathead County in the City of Whitefish**

**Location:** CENEX ZIP TRIP #69  
6585 US Hwy 93 S  
Whitefish, MT 59937 Flathead

System Facility ID:15-04903

**Facility Code:** 20650  
**Last Inspected On:** 10/28/2022  
**Operating Permit Renewal Date:** 12/27/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

**Operator Contact:** Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

**Owner/Operator:** CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

Jason Brenner, UST Class B Operator  
Jim Alford, UST Class A Operator  
Jim Alford, UST Class B Operator  
Luci Tuttle, UST Class B Operator  
Sean Hurley, UST Class A Operator

jim.alford@chsinc.com  
jim.alford@chsinc.com  
jim.alford@chsinc.com  
Lucinda.Tuttle@chsinc.com  
sean.hurley@chsinc.com

<b>Tank Code</b>	07	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	11/04/1991	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2956	<b>Spill Test Date</b>	01/21/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/02/2018	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/30/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/25/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/21/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	08	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	11/04/1991	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2957	<b>Spill Test Date</b>	01/21/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/02/2018	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/30/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/25/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	01/21/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	09	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	11/04/1991	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2958	<b>Spill Test Date</b>	01/21/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/02/2018	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/30/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/25/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/21/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	10	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	11/04/1991	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2959	<b>Spill Test Date</b>	01/21/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	11/02/2018	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/30/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	08/25/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/21/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Flathead County in the City of Whitefish**

**Location:** LOGAN HEALTH WHITEFISH  
1600 Hospital Way  
Whitefish, MT 59937-2990 Flathead

System Facility ID:60-15034

**Facility Code:** 30816  
**Last Inspected On:** 03/12/2025  
**Operating Permit Renewal Date:** 03/13/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** Logan Health Whitefish (406) 863-3533 jnewson@logan.org

---

**Operator Contact:** Kyle Hovey (406) 212-8644 khovey@krmc.org

---

**Owner/Operator:** Logan Health Whitefish (406) 863-3533 jnewson@logan.org  
 Kyle Hovey, UST Class A Operator khovey@krmc.org  
 Kyle Hovey, UST Class B Operator khovey@krmc.org

<b>Tank Code</b>	S1	<b>Tank Age</b>	18	<b>Tank Installed Date</b>	01/17/2007	<b>Tank Material</b>	Aboveground Tank	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	5123	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/12/2025	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Heating Oil	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	03/12/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

## Facility Summary in Flathead County in the City of Whitefish

**Location:** MIDWAY MINI MART  
4899 US Hwy 93 S  
Whitefish, MT 59937-8520 Flathead

System Facility ID:15-07766

**Facility Code:** 20742  
**Last Inspected On:** 05/10/2023  
**Operating Permit Renewal Date:** 08/07/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Midway MM Inc (406) 862-6365 victorsmarket@outlook.com

**Operator Contact:** Riley Workman riley.a.workman@gmail.com

**Owner/Operator:** Midway MM Inc (406) 862-6365 victorsmarket@outlook.com

Riley Workman, UST Class A Operator

riley.a.workman@gmail.com

Riley Workman, UST Class B Operator

riley.a.workman@gmail.com

<b>Tank Code</b>	04	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	04/01/1996	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3384	<b>Spill Test Date</b>	05/10/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/10/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/10/2023	<b>Line Tightness Test Date</b>	06/04/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/10/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	05	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	04/01/1996	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3385	<b>Spill Test Date</b>	05/10/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/10/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	7000	<b>ATG Test Date</b>	05/10/2023	<b>Line Tightness Test Date</b>	06/04/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/10/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	06	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	04/01/1996	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve

<b>Tag Number</b>	3386	<b>Spill Test Date</b>	05/10/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/10/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	05/10/2023	<b>Line Tightness Test Date</b>	06/04/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/10/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

### Facility Summary in Flathead County in the City of Whitefish

**Location:** SAFEWAY FUEL STATION #2106  
110 W 13th St  
Whitefish, MT 59937 Flathead

System Facility ID:60-15151

**Facility Code:** 30892  
**Last Inspected On:** 07/25/2022  
**Operating Permit Renewal Date:** 12/28/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** Safeway #2106 (623) 869-3573 liz.alwine@safeway.com

---

**Operator Contact:** Jesse Wees;Page Rost (208) 412-2233;(208) 412-7561 jesse.wees@albertsons.com;page.rost@albertsons.com

---

**Owner/Operator:** Safeway #2106 (623) 869-3573 liz.alwine@safeway.com

- A Beagle, UST Class B Global Operator
  - A Beagle, UST Class B Global Operator
  - Allen Long, UST Class B Global Operator
  - Allen Long, UST Class B Global Operator
  - Jesse Wees, UST Class A Operator
  - Jesse Wees, UST Class A Operator
  - Page Rost, UST Class A Operator
  - Page Rost, UST Class A Operator
  - Page Rost, UST Class B Global Operator
  - Page Rost, UST Class B Global Operator
- jesse.wees@albertsons.com
  - jesse.wees@albertsons.com
  - page.rost@albertsons.com
  - page.rost@albertsons.com
  - page.rost@albertsons.com
  - page.rost@albertsons.com

<b>Tank Code</b>	01	<b>Tank Age</b>	15	<b>Tank Installed Date</b>	04/28/2010	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5233	<b>Spill Test Date</b>	05/13/2020	<b>Piping Installed Date</b>	04/08/2010	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/13/2020	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/25/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	07/25/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/12/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	15	<b>Tank Installed Date</b>	04/28/2010	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm

<b>Tag Number</b>	5234	<b>Spill Test Date</b>	05/13/2020	<b>Piping Installed Date</b>	04/08/2010	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/13/2020	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	07/25/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	07/25/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/12/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	03	<b>Tank Age</b>	15	<b>Tank Installed Date</b>	04/28/2010	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5235	<b>Spill Test Date</b>	05/13/2020	<b>Piping Installed Date</b>	04/08/2010	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/13/2020	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	07/25/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	07/25/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/12/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				



### Facility Summary in Flathead County in the City of Whitefish

**Location:** TOMS SUPER SERVICE  
722 Clearwater Drive  
Whitefish, MT 59937 Flathead

System Facility ID:37-06114

**Facility Code:** 26416  
**Last Inspected On:** 04/17/2019  
**Operating Permit Renewal Date:** 07/20/2022

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Ben Taylor Inc

bti@3rivers.net

**Operator Contact:** Tom Fetters

(406) 278-5213

bti@3rivers.net

Gail Mullennax, UST Class B Operator  
Gail Mullennax, UST Class B Operator  
Gail Mullennax, UST Class B Operator  
Tom Fetters, UST Class A Operator  
Tom Fetters, UST Class A Operator  
Tom Fetters, UST Class A Operator  
Tom Fetters, UST Class B Operator  
Tom Fetters, UST Class B Operator  
Tom Fetters, UST Class B Operator

bti@3rivers.net  
bti@3rivers.net  
bti@3rivers.net  
bti@3rivers.net  
bti@3rivers.net  
bti@3rivers.net

<b>Tank Code</b>	03	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/12/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	423	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>	04/17/2019	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	04/17/2019	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/ILS-250				
<b>Tank Code</b>	04	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/12/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	424	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>	04/17/2019	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible

<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	16000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	04/17/2019	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/ILS-250				
<b>Tank Code</b>	05	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/12/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	425	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>	04/17/2019	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	04/17/2019	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Flathead County in the City of Whitefish**

**Location:** TOWN PUMP INC WHITEFISH 1  
6600 US Hwy 93 S  
Whitefish, MT 59937 Flathead

System Facility ID:15-10105

**Facility Code:** 20827  
**Last Inspected On:** 05/24/2023  
**Operating Permit Renewal Date:** 08/31/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Whitefish 1 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

**Operator Contact:** Trent Biggers

**Trentb@townpump.com**

**Owner/Operator:** Whitefish 1 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator  
Trent Biggers, UST Class B Global Operator

Trentb@townpump.com  
Trentb@townpump.com  
Trentb@townpump.com  
Trentb@townpump.com

<b>Tank Code</b>	01	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	01/17/1990	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2428	<b>Spill Test Date</b>	10/22/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/22/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	04/28/2021	<b>Tank/Piping CP Test Date</b>	11/18/2021	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/22/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	03	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	01/17/1990	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2430	<b>Spill Test Date</b>	11/16/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/28/2021	<b>Tank/Piping CP Test Date</b>	11/18/2021	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	09/22/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	04	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	01/17/1990	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2431	<b>Spill Test Date</b>	10/22/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/28/2021	<b>Tank/Piping CP Test Date</b>	11/18/2021	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/22/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	02	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	01/17/1990	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4306	<b>Spill Test Date</b>	11/16/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/28/2021	<b>Tank/Piping CP Test Date</b>	11/18/2021	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/22/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	05	<b>Tank Age</b>	21	<b>Tank Installed Date</b>	10/01/2004	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4941	<b>Spill Test Date</b>	10/22/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/28/2021	<b>Tank/Piping CP Test Date</b>	11/18/2021	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	05/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/22/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				

### Facility Summary in Flathead County in the City of Whitefish

**Location:** TOWN PUMP WHITEFISH 2  
4825 US Hwy 40  
Whitefish, MT 59937 Flathead

System Facility ID:60-15355

**Facility Code:** 32453  
**Last Inspected On:** 05/29/2023  
**Operating Permit Renewal Date:** 05/29/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Whitefish #2 Town Pump LLC

**(406) 497-6900**

**environmental@townpump.com**

**Operator Contact:** Trent Biggers;Town Pump

**Trentb@townpump.com;environmental@townpump.com**

**Owner/Operator:** Whitefish #2 Town Pump LLC

**(406) 497-6900**

**environmental@townpump.com**

Trent Biggers, UST Class A Operator

**environmental@townpump.com**

Trent Biggers, UST Class B Global Operator

**environmental@townpump.com**

<b>Tank Code</b>	01	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	11/26/2021	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6044	<b>Spill Test Date</b>	09/27/2022	<b>Piping Installed Date</b>	11/26/2021	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/24/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	30000	<b>ATG Test Date</b>	05/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/27/2022			<b>ATG Type</b>					
<b>Tank Code</b>	02	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	11/26/2021	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6045	<b>Spill Test Date</b>	09/27/2022	<b>Piping Installed Date</b>	11/26/2021	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/24/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	6000	<b>ATG Test Date</b>	05/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/27/2022			<b>ATG Type</b>					
<b>Tank Code</b>	03	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	11/26/2021	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve

<b>Tag Number</b>	6046	<b>Spill Test Date</b>	09/27/2022	<b>Piping Installed Date</b>	11/26/2021	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/24/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	15000	<b>ATG Test Date</b>	05/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/27/2022			<b>ATG Type</b>					
<b>Tank Code</b>	04	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	11/26/2021	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6047	<b>Spill Test Date</b>	09/27/2022	<b>Piping Installed Date</b>	11/26/2021	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	05/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/27/2022			<b>ATG Type</b>					
<b>Tank Code</b>	05	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	11/26/2021	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6048	<b>Spill Test Date</b>	09/27/2022	<b>Piping Installed Date</b>	11/26/2021	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/24/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	7000	<b>ATG Test Date</b>	05/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/27/2022			<b>ATG Type</b>					
<b>Tank Code</b>	06	<b>Tank Age</b>	4	<b>Tank Installed Date</b>	11/26/2021	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	6049	<b>Spill Test Date</b>	09/27/2022	<b>Piping Installed Date</b>	11/26/2021	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/24/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No

<b>Capacity</b>	20000	<b>ATG Test Date</b>	05/24/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/27/2022			<b>ATG Type</b>					

## Facility Summary in Flathead County in the City of Whitefish

**Location:** WHITEFISH LAKE LODGE  
1380 Wisconsin Ave  
Whitefish, MT 59937-3338 Flathead

System Facility ID:15-12719

**Facility Code:** 21003  
**Last Inspected On:** 08/29/2023  
**Operating Permit Renewal Date:** 04/30/2019

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Whitefish Lake Lodge

**Operator Contact:** Chris Gulick;Dave Wood;Heath Howell

**(406) 863-4000;(406) 863-4049;(615) 426-3939**

**chrisgulick@lodgeatwhitefishlake.com;marina@lodgeatwhitefishlake.com**

**Owner/Operator:** Whitefish Lake Lodge

Chris Gulick, UST Class A Operator  
Chris Gulick, UST Class B Operator  
Dave Wood, UST Class A Operator  
Dave Wood, UST Class B Operator  
Heath Howell, UST Class A Operator  
Heath Howell, UST Class B Operator

chrisgulick@lodgeatwhitefishlake.com  
chrisgulick@lodgeatwhitefishlake.com  
marina@lodgeatwhitefishlake.com  
marina@lodgeatwhitefishlake.com

<b>Tank Code</b>	01	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	04/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>		<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Other	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>		<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	04/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4898	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/22/2017	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No



<b>Capacity</b>	4000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	07/22/2014	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Flathead County in the City of Whitefish**

**Location:** WHITEFISH WESTSIDE MARKET  
145 2nd St W  
Whitefish, MT 59937 Flathead

System Facility ID:15-00112

**Facility Code:** 20516  
**Last Inspected On:** 08/22/2024  
**Operating Permit Renewal Date:** 09/06/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** West 2nd Property Group LLC (406) 862-4535 westsidemarket406@gmail.com

**Operator Contact:** Bill Kahle;Whitefish Westside Market LLC (406) 862-4535 westsidemarket406@gmail.com;westsidemarket406@gmail.com

**Owner/Operator:** West 2nd Property Group LLC (406) 862-4535 westsidemarket406@gmail.com  
Bill Kahle, UST Class A Operator westsidemarket406@gmail.com  
Bill Kahle, UST Class B Operator westsidemarket406@gmail.com

<b>Tank Code</b>	03	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	11/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3421	<b>Spill Test Date</b>	10/17/2024	<b>Piping Installed Date</b>	05/08/2018	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/22/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/22/2024	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	08/22/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/22/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-300				
<b>Tank Code</b>	04	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	11/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3422	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	05/08/2018	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/07/2018	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	02/27/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-300				