

## Facility Summary in Hill County in the City of Havre

**Location:** BN HAVRE RAIL YARD  
235 Main St  
Havre, MT 59501-3523 Hill

System Facility ID:21-09548

Facility Code: 22426  
Last Inspected On: 05/26/2023  
Operating Permit Renewal Date: 08/26/2026

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** BNSF Railway Company Fort Worth (817) 333-2000

**Operator Contact:** Robert Mantle;BNSF Railway Havre;Tavita Masau;Tim Christianson (406) 265-0483;(406) 939-4254;(773) 600-2860 bobmantle@hotmail.com;tmasau@icloud.com

**Owner/Operator:** BNSF Railway Company Fort Worth (817) 333-2000

Doran Loftus, UST Class B Global Operator	doran.loftus@aecom.com
Dwayne Whitaker, UST Class B Operator	
Ed Hill, UST Class B Operator	edward.hill@bnsf.com
Robert Mantle, UST Class A Operator	bobmantle@hotmail.com
Tavita Masau, UST Class A Operator	tmasau@icloud.com
Tavita Masau, UST Class B Global Operator	tmasau@icloud.com
Tim Christianson, UST Class A Operator	
Tom Swinney, UST Class B Operator	thomas.swinney@bnsf.com

<b>Tank Code</b>	S23	<b>Tank Age</b>	22	<b>Tank Installed Date</b>	01/22/2004	<b>Tank Material</b>	Concrete	<b>Piping Material</b>	Steel - Terminal Piping	<b>Overfill Types</b>	
<b>Tag Number</b>	4877	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/02/2023	<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Terminal Piping Annual Line Test	<b>Vapor Recovery</b>	No
<b>Capacity</b>	640000	<b>ATG Test Date</b>	05/23/2023	<b>Line Tightness Test Date</b>	08/02/2019	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
<b>Overfill Test Date</b>											
<b>Tank Code</b>	S24	<b>Tank Age</b>	22	<b>Tank Installed Date</b>	01/22/2004	<b>Tank Material</b>	Concrete	<b>Piping Material</b>	Steel - Terminal Piping	<b>Overfill Types</b>	
<b>Tag Number</b>	4878	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/02/2023	<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	Terminal Piping Annual Line Test	<b>Vapor Recovery</b>	No

Capacity	640000	ATG Test Date	05/23/2023	Line Tightness Test Date	08/02/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
<hr/>											
Tank Code	22	Tank Age	33	Tank Installed Date	06/21/1993	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	506	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Impressed Current
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date	11/02/2023	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	20000	ATG Test Date	05/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

## Facility Summary in Hill County in the City of Havre

**Location:** CIRCLE K STORE 2746272  
200 1st St W  
Havre, MT 59501 Hill

System Facility ID:21-08068

**Facility Code:** 22350  
**Last Inspected On:** 05/23/2023  
**Operating Permit Renewal Date:** 12/04/2026

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Rocky Mountain Oil LLC

(602) 728-8000

NT-ESS@Circlek.com

**Operator Contact:** Veronica Rivera

ESS-WestCoast@circlek.com

**Owner/Operator:** Rocky Mountain Oil LLC

(602) 728-8000

NT-ESS@Circlek.com

Brad Lee, UST Class B Global Operator

brad.lee@holidaycompanies.com

Jeff Reed, UST Class B Global Operator

jeff.reed@holidaycompanies.com

Veronica Rivera, UST Class A Operator

ESS-WestCoast@circlek.com

Tank Code	01	Tank Age	0	Tank Installed Date		Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3013	Spill Test Date		Piping Installed Date	11/24/2020	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/23/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	09/09/2020	Tank/Piping CP Test Date	09/06/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	05/23/2023	Line Tightness Test Date	11/12/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/07/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	41	Tank Installed Date	10/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3014	Spill Test Date		Piping Installed Date	11/24/2020	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/07/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	09/09/2020	Tank/Piping CP Test Date	09/06/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	05/23/2023	Line Tightness Test Date	11/17/2020 <th>Secondary Tank Leak Detection</th> <td></td> <th>Secondary Pipe Detection</th> <td>ELLD 0.2</td> <th>Energy Act</th> <td>No</td>	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		<b>Overfill Test Date</b>	09/08/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	03	<b>Tank Age</b>	41	<b>Tank Installed Date</b>	10/01/1985	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3015	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	11/24/2020	<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/23/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	09/09/2020	<b>Tank/Piping CP Test Date</b>	09/06/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	10000	<b>ATG Test Date</b>	05/23/2023	<b>Line Tightness Test Date</b>	11/10/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/07/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	04	<b>Tank Age</b>	41	<b>Tank Installed Date</b>	10/01/1985	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3016	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	11/24/2020	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/23/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	09/09/2020	<b>Tank/Piping CP Test Date</b>	09/06/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	05/23/2023	<b>Line Tightness Test Date</b>	11/11/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/07/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

## Facility Summary in Hill County in the City of Havre

**Location:** EMPORIUM FOOD AND FUEL  
1415 1st St  
Havre, MT 59501 Hill

System Facility ID: 21-12763

Facility Code: 22461  
Last Inspected On: 03/18/2025  
Operating Permit Renewal Date: 06/30/2028

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Duck Inn Inc

duckinninc@gmail.com

**Operator Contact:** Joseph Hopf; Marie Hawkins; Duck Inn Inc

(406) 344-2966

gpgekk1@yahoo.com; duckinninc@gmail.com; jhopf2016@gmail.com

**Owner/Operator:** Duck Inn Inc

duckinninc@gmail.com

Cindy Lee, UST Class B Operator

emporiumstationhavre@gmail.com

Dustin Rolfe, UST Class B Operator

dustinrolfe81@gmail.com

Joseph Hopf, UST Class A Operator

jhopf2016@gmail.com

Joseph Hopf, UST Class B Operator

jhopf2016@gmail.com

Marie Hawkins, UST Class A Operator

duckinninc@gmail.com

Marie Hawkins, UST Class B Operator

duckinninc@gmail.com

Tank Code	01	Tank Age	34	Tank Installed Date	08/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2971	Spill Test Date	03/15/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/12/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/07/2025	Line Tightness Test Date	01/06/2025	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/15/2024			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	02	Tank Age	34	Tank Installed Date	08/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2972	Spill Test Date	03/15/2025	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/12/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/07/2025	Line Tightness Test Date	03/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		<b>Overfill Test Date</b>	05/15/2024			<b>ATG Type</b>	Franklin Fueling Systems/EVO 600			
<b>Tank Code</b>	03	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	08/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>
<b>Tag Number</b>	2973	<b>Spill Test Date</b>	03/15/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/12/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>
<b>Capacity</b>	6000	<b>ATG Test Date</b>	05/07/2025	<b>Line Tightness Test Date</b>	01/03/2025	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>
		<b>Overfill Test Date</b>	05/15/2024			<b>ATG Type</b>	Franklin Fueling Systems/EVO 600			
<b>Tank Code</b>	04	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	08/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>
<b>Tag Number</b>	2974	<b>Spill Test Date</b>	03/15/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/12/2021	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>
<b>Capacity</b>	6000	<b>ATG Test Date</b>	05/07/2025	<b>Line Tightness Test Date</b>	01/09/2025	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>
		<b>Overfill Test Date</b>	05/15/2024			<b>ATG Type</b>	Franklin Fueling Systems/EVO 600			

## Facility Summary in Hill County in the City of Havre

**Location:** EZZIES CENEX CARDTROL  
33 1st St  
Havre, MT 59501 Hill

System Facility ID:21-07467

Facility Code: 22339  
Last Inspected On: 09/05/2023  
Operating Permit Renewal Date: 09/05/2026

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com

**Operator Contact:** Conor Moran;Ezzies Wholesale Inc (406) 654-2331 conor@ezzies.com;bill@ezzies.com

**Owner/Operator:** Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com  
Conor Moran, UST Class A Operator bill@ezzies.com  
Jimmy Kimberling, UST Class B Operator havre@ezzies.com

<b>Tank Code</b>	08	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	06/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	538	<b>Spill Test Date</b>	05/23/2023	<b>Piping Installed Date</b>	08/27/2008	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/12/2020	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/23/2023	<b>Line Tightness Test Date</b>	05/23/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/23/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	09	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	06/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	539	<b>Spill Test Date</b>	05/23/2023	<b>Piping Installed Date</b>	08/27/2008	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/12/2020	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/23/2023	<b>Line Tightness Test Date</b>	05/23/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/23/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	10	Tank Age	29	Tank Installed Date	06/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	540	Spill Test Date	05/23/2023	Piping Installed Date	08/27/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/12/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/23/2023	Line Tightness Test Date	05/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	11	Tank Age	29	Tank Installed Date	06/28/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	541	Spill Test Date	05/23/2023	Piping Installed Date	08/27/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/12/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/23/2023	Line Tightness Test Date	05/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	12	Tank Age	29	Tank Installed Date	06/28/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	542	Spill Test Date	05/23/2023	Piping Installed Date	08/27/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/12/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/23/2023	Line Tightness Test Date	05/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	13	Tank Age	29	Tank Installed Date	06/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	543	Spill Test Date	05/23/2023	Piping Installed Date	08/27/2008	Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLL D Test Date	05/12/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/23/2023	Line Tightness Test Date	05/23/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

## Facility Summary in Hill County in the City of Havre

**Location:** EZZIES WHOLESALE HAVRE  
726 1st St W  
Havre, MT 59501-3418 Hill

System Facility ID: 21-12751

Facility Code: 22460  
Last Inspected On: 03/18/2025  
Operating Permit Renewal Date: 07/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com

**Operator Contact:** Conor Moran; Ezzies Wholesale Inc (406) 654-2331 conor@ezzies.com; bill@ezzies.com

**Owner/Operator:** Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com  
Conor Moran, UST Class A Operator bill@ezzies.com  
Jimmy Kimberling, UST Class B Operator havre@ezzies.com

<b>Tank Code</b>	01	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	07/01/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	878	<b>Spill Test Date</b>	05/12/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Solvents	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/18/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/12/2021	<b>Line Tightness Test Date</b>	03/21/2013	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/12/2021			<b>ATG Type</b>	Gilbarco/EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	07/01/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	879	<b>Spill Test Date</b>	05/15/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/15/2024	<b>Tank/Piping CP Test Date</b>	03/18/2025	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/15/2024	<b>Line Tightness Test Date</b>	08/29/2007	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/15/2024			<b>ATG Type</b>	Gilbarco/EMC				
<b>Tank Code</b>	03	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	07/01/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	880	<b>Spill Test Date</b>	05/15/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Single Walled	<b>AST</b>	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLL Test Date	05/15/2024	Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/15/2024	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/15/2024			ATG Type	Gilbarco/EMC				
Tank Code	04	Tank Age	34	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	881	Spill Test Date	05/15/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLL Test Date	05/15/2024	Tank/Piping CP Test Date	07/16/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/15/2024	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/15/2024			ATG Type	Gilbarco/EMC				
Tank Code	05	Tank Age	34	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	882	Spill Test Date	05/15/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLL Test Date	05/15/2024	Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/15/2024	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/15/2024			ATG Type	Gilbarco/EMC				
Tank Code	06	Tank Age	34	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	883	Spill Test Date	05/15/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLL Test Date	05/15/2024	Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/15/2024	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/15/2024			ATG Type	Gilbarco/EMC				
Tank Code	07	Tank Age	34	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	884	Spill Test Date	05/15/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLL Test Date	05/15/2024	Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/15/2024	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/15/2024			ATG Type	Gilbarco/EMC				
Tank Code	08	Tank Age	34	Tank Installed Date	07/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	885	Spill Test Date	05/15/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLL Test Date	05/15/2024	Tank/Piping CP Test Date	03/18/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/15/2024	Line Tightness Test Date	08/29/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/15/2024			ATG Type	Gilbarco/EMC				

## Facility Summary in Hill County in the City of Havre

**Location:** HILL COUNTY JUSTICE CENTER  
1450 2nd St W  
Havre, MT 59501-3497 Hill

System Facility ID: 56-13886

Facility Code: 30561  
Last Inspected On: 09/04/2024  
Operating Permit Renewal Date: 11/05/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Hill County Commissioners (406) 265-5481

**Operator Contact:** Daryl Anez; Joseph Smith; Richard Ricci (406) 262-3467; (406) 945-1497 anezd@hillcounty.us; ricci@co.hill.mt.us

**Owner/Operator:** Hill County Commissioners (406) 265-5481

Daryl Anez, UST Class A Operator anezd@hillcounty.us

Daryl Anez, UST Class B Global Operator anezd@hillcounty.us

Daryl Anez, UST Class B Operator anezd@hillcounty.us

Joseph Smith, UST Class A Operator

mike@lodestarlandandhome.com

Joseph Smith, UST Class B Operator

ricci@co.hill.mt.us

Mike Winchell, UST Class B Global Operator

ricci@co.hill.mt.us

Richard Ricci, UST Class A Operator

Richard Ricci, UST Class B Global Operator

<b>Tank Code</b>	S1	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	07/20/1998	<b>Tank Material</b>	Concrete	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	
<b>Tag Number</b>	1377	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Secondary Containment Chase	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	3-Year Line Tightness Test	<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	09/04/2024	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

## Facility Summary in Hill County in the City of Havre

**Location:** STROMBERGS SINCLAIR  
1200 1st St  
Havre, MT 59501-3802 Hill

System Facility ID:21-02166

Facility Code: 22209  
Last Inspected On: 07/01/2025  
Operating Permit Renewal Date: 12/12/2028

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Stromberg Sinclair

toleary75@icloud.com

**Operator Contact:** Todd O'Leary

(406) 262-3441

toleary75@icloud.com

**Owner/Operator:** Stromberg Sinclair

Todd O'Leary, UST Class A Operator

toleary75@icloud.com

Todd O'Leary, UST Class B Operator

toleary75@icloud.com

<b>Tank Code</b>	08	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	03/01/1999	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3965	<b>Spill Test Date</b>	07/01/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	07/01/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/01/2025			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	09	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	03/01/1999	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	3966	<b>Spill Test Date</b>	10/17/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	10/09/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/17/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	10	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	03/01/1999	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve

Tag Number	3967	Spill Test Date	10/17/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	10/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/17/2022			ATG Type	Gilbarco/EMC Basic				

## Facility Summary in Hill County in the City of Havre

**Location:** TOWN PUMP HAVRE  
136 1st St W  
Havre, MT 59501 Hill

System Facility ID:21-08705

Facility Code: 22359  
Last Inspected On: 02/27/2024  
Operating Permit Renewal Date: 09/19/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Havre 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

**Operator Contact:** Daniel Sampson;Trent Biggers

(406) 497-6700

andrew02@directv.net;Trentb@townpump.com

**Owner/Operator:** Havre 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Daniel Sampson, UST Class A Operator

andrew02@directv.net

Daniel Sampson, UST Class B Global Operator

andrew02@directv.net

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

<b>Tank Code</b>	03	<b>Tank Age</b>	37	<b>Tank Installed Date</b>	11/15/1989	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2472	<b>Spill Test Date</b>	07/26/2023	<b>Piping Installed Date</b>	07/25/2014	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/26/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	06/19/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	06/19/2025	<b>Line Tightness Test Date</b>	01/29/2015	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/26/2023			<b>ATG Type</b>	Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	04	<b>Tank Age</b>	37	<b>Tank Installed Date</b>	11/15/1989	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2473	<b>Spill Test Date</b>	07/26/2023	<b>Piping Installed Date</b>	07/25/2014	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/26/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	06/19/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No

Capacity	12000	ATG Test Date	06/19/2025	Line Tightness Test Date	01/29/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/26/2023			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	37	Tank Installed Date	11/15/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2474	Spill Test Date	07/26/2023	Piping Installed Date	07/25/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/26/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/19/2025	Line Tightness Test Date	01/29/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/26/2023			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	37	Tank Installed Date	11/15/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2475	Spill Test Date	07/26/2023	Piping Installed Date	07/25/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/26/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/19/2025	Line Tightness Test Date	01/29/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/26/2023			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	12	Tank Installed Date	08/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5510	Spill Test Date	07/26/2023	Piping Installed Date	07/25/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/26/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/19/2025	Line Tightness Test Date	01/29/2015	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/26/2023			ATG Type	Veeder Root/TLS-450PLUS				

Tank Code	08	Tank Age	12	Tank Installed Date	08/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5514	Spill Test Date	07/26/2023	Piping Installed Date	07/25/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/26/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	06/19/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	06/19/2025	Line Tightness Test Date	01/29/2015	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/07/2023			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	09	Tank Age	12	Tank Installed Date	08/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5515	Spill Test Date		Piping Installed Date	07/25/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

## Facility Summary in Hill County in the City of Havre

**Location:** ZIP TRIP 48  
911 11th St W  
Havre, MT 59501 Hill

System Facility ID:21-00089

**Facility Code:** 22169  
**Last Inspected On:** 06/24/2024  
**Operating Permit Renewal Date:** 06/27/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** CHS Inc Spokane Valley (509) 535-7701 [jim.alford@chsinc.com](mailto:jim.alford@chsinc.com)

**Operator Contact:** Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 [jim.alford@chsinc.com;sean.hurley@chsinc.com](mailto:jim.alford@chsinc.com;sean.hurley@chsinc.com)

**Owner/Operator:** CHS Inc Spokane Valley (509) 535-7701 [jim.alford@chsinc.com](mailto:jim.alford@chsinc.com)

Jim Alford, UST Class A Operator

[jim.alford@chsinc.com](mailto:jim.alford@chsinc.com)

Jim Alford, UST Class B Operator

[jim.alford@chsinc.com](mailto:jim.alford@chsinc.com)

Luci Tuttle, UST Class B Operator

[Lucinda.Tuttle@chsinc.com](mailto:Lucinda.Tuttle@chsinc.com)

Sean Hurley, UST Class A Operator

[sean.hurley@chsinc.com](mailto:sean.hurley@chsinc.com)

Travis Weber, UST Class B Operator

[travis.weber3@chsinc.com](mailto:travis.weber3@chsinc.com)

<b>Tank Code</b>	03	<b>Tank Age</b>	15	<b>Tank Installed Date</b>	10/01/2011	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	5341	<b>Spill Test Date</b>	08/08/2024	<b>Piping Installed Date</b>	10/11/2011	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/29/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	06/24/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	06/24/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/08/2024			<b>ATG Type</b>	Gilbarco/EMC Basic; Gilbarco-Veeder Root/EMC Basic				
<b>Tank Code</b>	04	<b>Tank Age</b>	15	<b>Tank Installed Date</b>	10/01/2011	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	5342	<b>Spill Test Date</b>	06/24/2024	<b>Piping Installed Date</b>	10/11/2011	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/29/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	06/24/2025	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No

Capacity	10000	ATG Test Date	06/24/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/08/2024			ATG Type	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				
Tank Code	05	Tank Age	15	Tank Installed Date	10/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5343	Spill Test Date	06/24/2024	Piping Installed Date	10/11/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/29/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/24/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/24/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/08/2024			ATG Type	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				

## Facility Summary in Hill County in the City of Havre

**Location:** ZIP TRIP 49  
1004 1st St  
Havre, MT 59501 Hill

System Facility ID:21-00103

Facility Code: 22170  
Last Inspected On: 08/06/2025  
Operating Permit Renewal Date: 12/04/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** CHS Inc Spokane Valley

**(509) 535-7701**

jim.alford@chsinc.com

**Operator Contact:** Jim Alford;Sean Hurley

**(509) 535-7701;(509) 536-7418**

jim.alford@chsinc.com;sean.hurley@chsinc.com

**Owner/Operator:** CHS Inc Spokane Valley

(509) 535-7701

jim.alford@chsinc.com

Jim Alford, UST Class A Operator

jim.alford@chsinc.com

Jim Alford, UST Class B Operator

jim.alford@chsinc.com

Luci Tuttle, UST Class B Operator

Lucinda.Tuttle@chsinc.com

Sean Hurley, UST Class A Operator

sean.hurley@chsinc.c

Tank Code	04	Tank Age	13	Tank Installed Date	05/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5405	Spill Test Date	01/05/2023	Piping Installed Date	11/27/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/06/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/24/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/24/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	01/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-350; Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	13	Tank Installed Date	05/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5406	Spill Test Date	07/06/2020	Piping Installed Date	11/27/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/06/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/24/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	6000	ATG Test Date	06/24/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/03/2025			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	13	Tank Installed Date	05/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5407	Spill Test Date	01/05/2023	Piping Installed Date	11/27/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/06/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/24/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/24/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/06/2025			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

## Facility Summary in Hill County in the City of Inverness

**Location:** FRASER OIL INC INVERNESS  
125 Main St  
Inverness, MT 59530 Hill

System Facility ID:21-07327

Facility Code: 22337  
Last Inspected On: 11/16/2023  
Operating Permit Renewal Date: 03/27/2027

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Fraser Oil Inc

(406) 292-3833

**Operator Contact:** Cory Fraser

frasfuel@yahoo.com

**Owner/Operator:** Fraser Oil Inc

(406) 292-3833

Cory Fraser, UST Class A Operator

Cory Fraser, UST Class B Operator

frasfuel@yahoo.com

frasfuel@yahoo.com

<b>Tank Code</b>	04	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	10/15/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1120	<b>Spill Test Date</b>	11/16/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/14/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>	11/16/2023	<b>Line Tightness Test Date</b>	12/11/2008	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/16/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	05	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	10/15/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1121	<b>Spill Test Date</b>	11/16/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/14/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	1000	<b>ATG Test Date</b>	11/16/2023	<b>Line Tightness Test Date</b>	12/11/2008	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	11/16/2022			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	06	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	10/15/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1122	<b>Spill Test Date</b>	11/16/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLL D Test Date		Tank/Piping CP Test Date	11/14/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	11/16/2023	Line Tightness Test Date	12/11/2008	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overflow Test Date	11/16/2022			ATG Type	Gilbarco/EMC Basic				

## Facility Summary in Hill County in the City of Rudyard

**Location:** C & H TIRES INC  
103 Main St  
Rudyard, MT 59540 Hill

System Facility ID:21-02475

Facility Code: 22212  
Last Inspected On: 06/24/2025  
Operating Permit Renewal Date: 09/24/2028

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** C & H Tires Inc

(406) 355-4131

dunlop\_12345@yahoo.com

**Operator Contact:** Rick Pester;Robert Toner

(406) 355-4131

toners@itstriangle.com;toners@mtintouch.net

**Owner/Operator:** C & H Tires Inc

(406) 355-4131

dunlop\_12345@yahoo.com

Rick Pester, UST Class A Operator

toners@mtintouch.net

Rick Pester, UST Class B Operator

toners@mtintouch.net

Robert Toner, UST Class A Operator

toners@itstriangle.com

<b>Tank Code</b>	05	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	11/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	2108	<b>Spill Test Date</b>	06/24/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	04/14/2016	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.1	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	06/24/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/24/2025			<b>ATG Type</b>	Franklin Fueling Systems/EVO 600				
<b>Tank Code</b>	06	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	11/01/1997	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	2109	<b>Spill Test Date</b>	06/24/2025	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	04/14/2016	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.1	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	06/24/2025	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/24/2025			<b>ATG Type</b>	Franklin Fueling Systems/EVO 600				

## Facility Summary in Hill County in the City of Rudyard

**Location:** FARMERS UNION OIL CO RUDYARD  
1 Main St  
Rudyard, MT 59540 Hill

System Facility ID:21-03509

Facility Code: 22239  
Last Inspected On: 09/11/2025  
Operating Permit Renewal Date: 09/28/2028

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Farmers Union Oil Co Rudyard

(406) 355-4543

farmersunionoilrudyard@yahoo.com

**Operator Contact:** Cory Tollefson;Farmers Union Oil Co Rudyard

(406) 443-0382;(406) 355-4543

farmersunionoilrudyard@yahoo.com;farmersunionoilrudyard@yahoo.com

**Owner/Operator:** Farmers Union Oil Co Rudyard

(406) 355-4543

farmersunionoilrudyard@yahoo.com

Cory Tollefson, UST Class A Operator

farmersunionoilrudyard@yahoo.com

Cory Tollefson, UST Class B Operator

farmersunionoilrudyard@yahoo.com

Tank Code	S4	Tank Age	60	Tank Installed Date	04/23/1966	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	947	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/11/2025	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	2000	ATG Test Date	09/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date				ATG Type				
Tank Code	S5	Tank Age	60	Tank Installed Date	04/23/1966	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	948	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/11/2025	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	10000	ATG Test Date	09/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date				ATG Type				
Tank Code	S6	Tank Age	60	Tank Installed Date	04/23/1966	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types

Tag Number	949	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/11/2025	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	09/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					