

**Facility Summary in Judith Basin County in the City of Geysers**

**Location:** GEYSER SCHOOL DIST 58  
103 3rd St E  
Geysers, MT 59447-0070 Judith Basin

System Facility ID:23-03795

**Facility Code:** 22697  
**Last Inspected On:** 01/30/2024  
**Operating Permit Renewal Date:** 03/26/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** School Dist 58 Geysers (406) 735-4368 jayme.simonis@geyser.k12.mt.us

---

**Operator Contact:** Jamie Stahl jstahl@geyser.k12.mt.us

---

**Owner/Operator:** School Dist 58 Geysers (406) 735-4368 jayme.simonis@geyser.k12.mt.us

Jamie Stahl, UST Class A Operator  
Jamie Stahl, UST Class A Operator  
Kenneth Annala, UST Class B Operator

jstahl@geyser.k12.mt.us  
jstahl@geyser.k12.mt.us  
swatkins@geyser.k12.mt.us

<b>Tank Code</b>	02	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	07/19/1990	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4609	<b>Spill Test Date</b>	01/30/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2200	<b>ATG Test Date</b>	01/30/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/30/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Judith Basin County in the City of Geyser**

**Location:** MALMSTROM AFB A 3  
US Hwy 87  
Geyser, MT 59447 Judith Basin

System Facility ID:23-08977

**Facility Code:** 22771  
**Last Inspected On:** 06/13/2024  
**Operating Permit Renewal Date:** 09/25/2023

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	10/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	223	<b>Spill Test Date</b>	07/17/2020	<b>Piping Installed Date</b>	06/12/2020	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/10/2020	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/02/2022	<b>Line Tightness Test Date</b>	07/08/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/02/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Geyser**

**Location:** MALMSTROM AFB B 1  
 US Hwy 87  
 Geyser, MT 59447 Judith Basin

System Facility ID:23-08986

**Facility Code:** 22772  
**Last Inspected On:** 06/12/2024  
**Operating Permit Renewal Date:** 09/25/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	03	<b>Tank Age</b>	63	<b>Tank Installed Date</b>	05/02/1962	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	224	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/18/2020	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	07/07/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	12/11/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	12/11/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				

**Facility Summary in Judith Basin County in the City of Geyser**

**Location:** MALMSTROM AFB B 10  
US Hwy 87  
Geyser, MT 59447 Judith Basin

System Facility ID:23-08995

**Facility Code:** 22778  
**Last Inspected On:** 06/12/2024  
**Operating Permit Renewal Date:** 09/26/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	10/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	230	<b>Spill Test Date</b>	05/09/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/09/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/09/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/09/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Geyser**

**Location:** MALMSTROM AFB B 11  
 US Hwy 87  
 Geyser, MT 59447 Judith Basin

System Facility ID:23-08996

**Facility Code:** 22779  
**Last Inspected On:** 06/12/2024  
**Operating Permit Renewal Date:** 09/26/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	06/21/1989	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	231	<b>Spill Test Date</b>	05/10/2023	<b>Piping Installed Date</b>	06/17/2016	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/10/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/10/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/10/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Geyser**

**Location:** MALMSTROM AFB B 7  
US Hwy 87  
Geyser, MT 59447 Judith Basin

System Facility ID:23-08992

**Facility Code:** 22775  
**Last Inspected On:** 06/12/2024  
**Operating Permit Renewal Date:** 09/26/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	10/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	227	<b>Spill Test Date</b>	05/09/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/09/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/09/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/09/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Geyser**

**Location:** MALMSTROM AFB B 8  
US Hwy 87  
Geyser, MT 59447 Judith Basin

System Facility ID:23-08993

**Facility Code:** 22776  
**Last Inspected On:** 06/12/2024  
**Operating Permit Renewal Date:** 09/26/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	03	<b>Tank Age</b>	11	<b>Tank Installed Date</b>	01/01/2014	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5466	<b>Spill Test Date</b>	05/10/2023	<b>Piping Installed Date</b>	11/25/2013	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/10/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/10/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	05/10/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Geyser**

**Location:** MALMSTROM AFB B 9  
US Hwy 87  
Geyser, MT 59447 Judith Basin

System Facility ID:23-08994

**Facility Code:** 22777  
**Last Inspected On:** 06/12/2024  
**Operating Permit Renewal Date:** 09/26/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	10/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	229	<b>Spill Test Date</b>	05/09/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/09/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/09/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/09/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				



**Facility Summary in Judith Basin County in the City of Hobson**

**Location:** HOBSON SCHOOL DIST 25  
108 6th St S E, Hobson, MT 59452  
Hobson, MT Judith Basin

System Facility ID:23-05904

**Facility Code:** 22732  
**Last Inspected On:** 07/28/2021  
**Operating Permit Renewal Date:** 08/22/2024

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** School Dist 25 Hobson (406) 423-5483

**Operator Contact:** Amanda Barnes;Parker Campbell;Hobson School Dist 25 (406) 423-5483 mandy.barnes@hobson.k12.mt.us;parker.campbell@hobson.k12.mt.us

Amanda Barnes, UST Class A Operator  
Amanda Barnes, UST Class A Operator  
Amanda Barnes, UST Class B Operator  
Amanda Barnes, UST Class B Operator  
Parker Campbell, UST Class A Operator  
Parker Campbell, UST Class A Operator  
Parker Campbell, UST Class B Operator  
Parker Campbell, UST Class B Operator

mandy.barnes@hobson.k12.mt.us  
mandy.barnes@hobson.k12.mt.us  
mandy.barnes@hobson.k12.mt.us  
mandy.barnes@hobson.k12.mt.us  
parker.campbell@hobson.k12.mt.us  
parker.campbell@hobson.k12.mt.us  
parker.campbell@hobson.k12.mt.us  
parker.campbell@hobson.k12.mt.us

<b>Tank Code</b>	S3	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	08/18/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1388	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Secondary Containment Chase	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/28/2021	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Heating Oil	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	07/28/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Veeder Root/TLS-300				

**Facility Summary in Judith Basin County in the City of Hobson**

**Location:** MALMSTROM AFB L 9  
Road 400  
Hobson, MT 59452 Judith Basin

System Facility ID:23-09104

**Facility Code:** 22791  
**Last Inspected On:** 03/27/2025  
**Operating Permit Renewal Date:** 07/31/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	243	<b>Spill Test Date</b>	03/21/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/21/2022	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	03/21/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/21/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Hobson**

**Location:** MALMSTROM AFB M 8  
Road 400  
Hobson, MT 59452 Judith Basin

System Facility ID:23-09114

**Facility Code:** 22792  
**Last Inspected On:** 03/28/2025  
**Operating Permit Renewal Date:** 07/24/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	244	<b>Spill Test Date</b>	03/21/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/21/2022	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	03/21/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/21/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Judith Basin County in the City of Hobson**

**Location:** WOODHALL DISTRIBUTING HOBSON  
21 Sawmill Rd  
Hobson, MT 59452 Judith Basin

System Facility ID:23-06450

**Facility Code:** 22738  
**Last Inspected On:** 03/27/2023  
**Operating Permit Renewal Date:** 07/10/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** WOODHALL DISTRIBUTING LLC

**woodhalldist@itstriangle.com**

**Operator Contact:** Greg Econom

**(406) 567-2266**

**woodhalldist2@itstriangle.com**

**Owner/Operator:** WOODHALL DISTRIBUTING LLC

woodhalldist@itstriangle.com

Greg Econom, UST Class A Operator  
Greg Econom, UST Class A Operator  
Greg Econom, UST Class B Operator  
Greg Econom, UST Class B Operator

woodhalldist2@itstriangle.com  
woodhalldist2@itstriangle.com  
woodhalldist2@itstriangle.com  
woodhalldist2@itstriangle.com

<b>Tank Code</b>	05	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	04/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4745	<b>Spill Test Date</b>	03/27/2023	<b>Piping Installed Date</b>	04/01/1998	<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/27/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	03/27/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/27/2023			<b>ATG Type</b>	Gilbarco/EMC Basic				
<b>Tank Code</b>	06	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	04/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4746	<b>Spill Test Date</b>	03/27/2023	<b>Piping Installed Date</b>	04/01/1998	<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/27/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	03/27/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/27/2023			<b>ATG Type</b>	Gilbarco/EMC Basic				

**Facility Summary in Judith Basin County in the City of Moccasin**

**Location:** MALMSTROM AFB C 4  
US Hwy 87  
Moccasin, MT 59462 Judith Basin

System Facility ID:23-09000

**Facility Code:** 22783  
**Last Inspected On:** 06/07/2024  
**Operating Permit Renewal Date:** 07/08/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	09/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	235	<b>Spill Test Date</b>	03/31/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/31/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	03/31/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/31/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Moccasin**

**Location:** MALMSTROM AFB C 5  
US Hwy 87  
Moccasin, MT 59462 Judith Basin

System Facility ID:23-09001

**Facility Code:** 22784  
**Last Inspected On:** 06/07/2024  
**Operating Permit Renewal Date:** 07/08/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	09/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	236	<b>Spill Test Date</b>	03/31/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/31/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	03/31/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/31/2023			<b>ATG Type</b>					

**Facility Summary in Judith Basin County in the City of Moccasin**

**Location:** MALMSTROM AFB C 6  
Road 239  
Moccasin, MT 59462 Judith Basin

System Facility ID:23-09002

**Facility Code:** 22785  
**Last Inspected On:** 06/07/2024  
**Operating Permit Renewal Date:** 07/08/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	09/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	237	<b>Spill Test Date</b>	05/10/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/10/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/10/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/10/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Moccasin**

**Location:** MALMSTROM AFB C 7  
Road 239  
Moccasin, MT 59462 Judith Basin

System Facility ID:23-09003

**Facility Code:** 22786  
**Last Inspected On:** 06/07/2024  
**Operating Permit Renewal Date:** 07/08/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	09/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	238	<b>Spill Test Date</b>	03/30/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/30/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	03/30/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/30/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				



**Facility Summary in Judith Basin County in the City of Moccasin**

**Location:** MALMSTROM AFB M 10  
US Hwy 87  
Moccasin, MT 59462 Judith Basin

System Facility ID:23-09116

**Facility Code:** 22794  
**Last Inspected On:** 03/31/2025  
**Operating Permit Renewal Date:** 08/06/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	246	<b>Spill Test Date</b>	03/21/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/21/2022	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	03/21/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/21/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Moccasin**

**Location:** MALMSTROM AFB M 9  
US Hwy 87  
Moccasin, MT 59462 Judith Basin

System Facility ID:23-09115

**Facility Code:** 22793  
**Last Inspected On:** 03/28/2025  
**Operating Permit Renewal Date:** 07/24/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	245	<b>Spill Test Date</b>	03/21/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/21/2022	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	03/21/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/21/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Raynesford**

**Location:** KIBBEY KORNER TRUCK STOP  
US Hwy 87 & Rte 427  
Raynesford, MT 59469-0197 Judith Basin

System Facility ID:23-03301

**Facility Code:** 22691  
**Last Inspected On:** 06/22/2022  
**Operating Permit Renewal Date:** 08/04/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

**Operator Contact:** David Douglas ddouglas@mountainviewcoop.com

**Owner/Operator:** Mountain View Coop Black Eagle (406) 453-5900 ddouglas@mountainviewcoop.com

David Douglas, UST Class A Operator ddouglas@mountainviewcoop.com  
David Douglas, UST Class B Global Operator ddouglas@mountainviewcoop.com

<b>Tank Code</b>	S6	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	1026	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	02/14/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	25000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	02/14/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S7	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	1027	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	02/14/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	02/14/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S8	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	1028	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes

<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	02/14/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	02/14/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S9	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	1029	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	02/14/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	02/14/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	S10	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	
<b>Tag Number</b>	1030	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	Yes
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	02/14/2022	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>		<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	02/14/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Judith Basin County in the City of Raynesford**

**Location:** MALMSTROM AFB A 1  
US Hwy 87  
Raynesford, MT 59469 Judith Basin

System Facility ID:23-08974

**Facility Code:** 22770  
**Last Inspected On:** 06/14/2024  
**Operating Permit Renewal Date:** 09/19/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Gavin Johnson, UST Class B Global Operator	gavin_johnson@hotmail.com
Josi Brosam, UST Class B Global Operator	josibrosam@rmsi.coop
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	01	<b>Tank Age</b>	63	<b>Tank Installed Date</b>	05/02/1962	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	222	<b>Spill Test Date</b>	05/09/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/09/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	04/01/2020	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	09/30/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/30/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				

**Facility Summary in Judith Basin County in the City of Raynesford**

**Location:** MALMSTROM AFB A 4  
Road 427  
Raynesford, MT 59469 Judith Basin

System Facility ID:20-08978

**Facility Code:** 22139  
**Last Inspected On:** 06/14/2024  
**Operating Permit Renewal Date:** 09/25/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	06/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	221	<b>Spill Test Date</b>	07/17/2020	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/18/2020	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/03/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/03/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Stanford**

**Location:** MALMSTROM AFB B 2  
 MT Hwy 80  
 Stanford, MT 59479 Judith Basin

System Facility ID:23-08987

**Facility Code:** 22773  
**Last Inspected On:** 06/11/2024  
**Operating Permit Renewal Date:** 09/26/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	09/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	225	<b>Spill Test Date</b>	05/04/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/04/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/04/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/04/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Stanford**

**Location:** MALMSTROM AFB B 3  
 MT Hwy 81  
 Stanford, MT 59479 Judith Basin

System Facility ID:14-08988

**Facility Code:** 20308  
**Last Inspected On:** 06/11/2024  
**Operating Permit Renewal Date:** 09/26/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	08/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	163	<b>Spill Test Date</b>	08/14/2020	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/18/2020	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	04/20/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/20/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				



**Facility Summary in Judith Basin County in the City of Stanford**

**Location:** MALMSTROM AFB B 4  
MT Hwy 80  
Stanford, MT 59479 Judith Basin

System Facility ID:14-08989

**Facility Code:** 20309  
**Last Inspected On:** 06/11/2024  
**Operating Permit Renewal Date:** 09/15/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	09/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	164	<b>Spill Test Date</b>	05/04/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/04/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	04/20/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/04/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Stanford**

**Location:** MALMSTROM AFB B 5  
 MT Hwy 80  
 Stanford, MT 59479 Judith Basin

System Facility ID:26-08990

**Facility Code:** 24068  
**Last Inspected On:** 06/11/2024  
**Operating Permit Renewal Date:** 09/26/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	09/10/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	258	<b>Spill Test Date</b>	05/04/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/04/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/04/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/04/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/				

**Facility Summary in Judith Basin County in the City of Stanford**

**Location:** MALMSTROM AFB B 6  
US Hwy 87  
Stanford, MT 59479 Judith Basin

System Facility ID:23-08991

**Facility Code:** 22774  
**Last Inspected On:** 06/11/2024  
**Operating Permit Renewal Date:** 09/26/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	10/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	226	<b>Spill Test Date</b>	05/04/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/04/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/04/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/04/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Stanford**

**Location:** MALMSTROM AFB C 10  
US Hwy 87  
Stanford, MT 59479 Judith Basin

System Facility ID:23-09006

**Facility Code:** 22789  
**Last Inspected On:** 06/10/2024  
**Operating Permit Renewal Date:** 05/16/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	03	<b>Tank Age</b>	8	<b>Tank Installed Date</b>	04/01/2017	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve;High Level Alarm
<b>Tag Number</b>	5741	<b>Spill Test Date</b>	05/11/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/16/2020	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/11/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	05/11/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Stanford**

**Location:** MALMSTROM AFB C 11  
US Hwy 87  
Stanford, MT 59479 Judith Basin

System Facility ID:23-09007

**Facility Code:** 22790  
**Last Inspected On:** 06/10/2024  
**Operating Permit Renewal Date:** 09/26/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	10/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	242	<b>Spill Test Date</b>	03/31/2023	<b>Piping Installed Date</b>	06/11/2020	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/31/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	03/31/2023	<b>Line Tightness Test Date</b>	06/11/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/31/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Stanford**

**Location:** MALMSTROM AFB C 2  
US Hwy 87  
Stanford, MT 59479 Judith Basin

System Facility ID:23-08998

**Facility Code:** 22781  
**Last Inspected On:** 06/07/2024  
**Operating Permit Renewal Date:** 07/08/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	09/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	233	<b>Spill Test Date</b>	03/31/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/31/2023	<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	03/31/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/31/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Stanford**

**Location:** MALMSTROM AFB C 3  
US Hwy 87  
Stanford, MT 59479 Judith Basin

System Facility ID:23-08999

**Facility Code:** 22782  
**Last Inspected On:** 06/07/2024  
**Operating Permit Renewal Date:** 07/08/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	09/11/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	234	<b>Spill Test Date</b>	03/31/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/31/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	03/31/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/31/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Stanford**

**Location:** MALMSTROM AFB C 8  
US Hwy 87  
Stanford, MT 59479 Judith Basin

System Facility ID:23-09004

**Facility Code:** 22787  
**Last Inspected On:** 06/10/2024  
**Operating Permit Renewal Date:** 10/07/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	09/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	239	<b>Spill Test Date</b>	05/10/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/10/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/10/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/10/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				



**Facility Summary in Judith Basin County in the City of Stanford**

**Location:** MALMSTROM AFB C 9  
US Hwy 87  
Stanford, MT 59479 Judith Basin

System Facility ID:23-09005

**Facility Code:** 22788  
**Last Inspected On:** 06/10/2024  
**Operating Permit Renewal Date:** 10/07/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	10/01/1992	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	240	<b>Spill Test Date</b>	05/10/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/10/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	05/10/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/10/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350				

**Facility Summary in Judith Basin County in the City of Stanford**

**Location:** STANFORD SCHOOL DIST 12  
104 4th Ave S  
Stanford, MT 59479 Judith Basin

System Facility ID:23-01938

**Facility Code:** 22680  
**Last Inspected On:** 08/10/2022  
**Operating Permit Renewal Date:** 10/11/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** School Dist 12 Stanford (406) 566-2265

**Operator Contact:** Arnold Smith

asmith@stanford.k12.mt.us

**Owner/Operator:** School Dist 12 Stanford (406) 566-2265

Arnold Smith, UST Class A Operator

asmith@stanford.k12.mt.us

Arnold Smith, UST Class B Global Operator

asmith@stanford.k12.mt.us

<b>Tank Code</b>	S3	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/09/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1893	<b>Spill Test Date</b>	08/10/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Heating Oil	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>	3-Year Line Tightness Test	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	08/10/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Manual Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/10/2022			<b>ATG Type</b>					

**Facility Summary in Judith Basin County in the City of Stanford**

**Location:** WOODHALL DISTRIBUTING STANFORD  
219 Central Ave  
Stanford, MT 59479 Judith Basin

System Facility ID:23-03303

**Facility Code:** 22692  
**Last Inspected On:** 07/18/2022  
**Operating Permit Renewal Date:** 07/18/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** WOODHALL DISTRIBUTING LLC

woodhalldist@itstriangle.com

**Operator Contact:** Dylan Woodhall;Woodhall Distributing - Stanford

(406) 366-5509;(406) 566-2671

woodysfuelstop@gmail.com

**Owner/Operator:** WOODHALL DISTRIBUTING LLC

woodhalldist@itstriangle.com

Dylan Woodhall, UST Class A Operator  
Gloria Hungate, UST Class B Global Operator  
Greg Econom, UST Class B Operator

woodysfuelstop@gmail.com

woodhalldist2@itstriangle.com

<b>Tank Code</b>	04	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	07/06/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1031	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Vapor Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	05	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	07/06/1998	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1032	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Vapor Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

## Facility Summary in Judith Basin County in the City of Stanford

**Location:** WOODYS FUEL STOP  
36653 US Hwy 87  
Stanford, MT 59479 Judith Basin

System Facility ID:23-01526

**Facility Code:** 22675  
**Last Inspected On:** 05/24/2023  
**Operating Permit Renewal Date:** 10/23/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** Dylan Woodhall (406) 366-5509 woodysfuelstop@gmail.com

---

**Operator Contact:** Dylan Woodhall;Shirley Woodhall (406) 366-5509;(406) 566-2203 woodysfuelstop@gmail.com

---

**Owner/Operator:** Dylan Woodhall (406) 366-5509 woodysfuelstop@gmail.com

Dylan Woodhall, UST Class A Operator woodysfuelstop@gmail.com  
 Dylan Woodhall, UST Class A Operator woodysfuelstop@gmail.com  
 Shirley Woodhall, UST Class A Operator woodysfuelstop@gmail.com  
 Shirley Woodhall, UST Class A Operator

<b>Tank Code</b>	06	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4410	<b>Spill Test Date</b>	09/08/2020	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/08/2020	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	09/01/2011	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/08/2020			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	07	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4411	<b>Spill Test Date</b>	09/08/2020	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	09/08/2020	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/08/2020	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	09/06/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/08/2020			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

<b>Tank Code</b>	08	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	4412	<b>Spill Test Date</b>	09/08/2020	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	09/08/2020	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/08/2020	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	09/06/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/08/2020			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Judith Basin County in the City of WINDHAM**

**Location:** MALMSTROM AFB C 1  
US Hwy 87  
WINDHAM, MT 59479 Judith Basin

System Facility ID:23-08997

**Facility Code:** 22780  
**Last Inspected On:** 06/10/2024  
**Operating Permit Renewal Date:** 09/25/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** 341 CES CEANQ (406) 731-6188

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith (406) 731-6239;(406) 731-7128 candace.ellsworth@us.af.mil;william.smith@us.af.mil

**Owner/Operator:** 341 CES CEANQ (406) 731-6188

Candace Ellsworth, UST Class A Operator	candace.ellsworth@us.af.mil
Candace Ellsworth, UST Class B Global Operator	candace.ellsworth@us.af.mil
Curtis Hester, UST Class A Operator	
Curtis Hester, UST Class B Global Operator	
William Smith, UST Class A Operator	william.smith@us.af.mil
William Smith, UST Class B Global Operator	william.smith@us.af.mil

<b>Tank Code</b>	02	<b>Tank Age</b>	63	<b>Tank Installed Date</b>	05/02/1962	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	232	<b>Spill Test Date</b>	05/11/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/11/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	01/09/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	12/05/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	12/05/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				