

Facility Summary in Madison County in the City of Cameron

Location: WARREN MILLER LODGE
Seven Bears Trl
Cameron, MT 59720 Madison

System Facility ID:60-15020

Facility Code: 30806
Last Inspected On: 01/30/2024
Operating Permit Renewal Date: 04/08/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Yellowstone Club

tyler.schmidt@yellowstoneclub.com

Operator Contact: Joe Robillard

(406) 993-2422

joe.robillard@yellowstoneclub.com

Owner/Operator: Yellowstone Club

Dan Nitsche, UST Class B Global Operator

Joe Robillard, UST Class A Operator

tyler.schmidt@yellowstoneclub.com

joe.robillard@yellowstoneclub.com

Tank Code	02	Tank Age	9	Tank Installed Date	08/14/2017	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5766	Spill Test Date	11/06/2023	Piping Installed Date	08/14/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	11/06/2023	Line Tightness Test Date	09/18/2017	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	11/06/2023			ATG Type	OPW/EECO 1500				

Facility Summary in Madison County in the City of Ennis

Location: MADISON FOODS ENNIS
4939 US-287 N
Ennis, MT 59729 Madison

System Facility ID:00-32574

Facility Code: 32574
Last Inspected On: 12/18/2024
Operating Permit Renewal Date: 12/18/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Chris Gentry;JGC Land LLC

(406) 579-2535

afsfoods@3rivers.nte

Operator Contact: Chris Gentry;JGC Land LLC

(406) 579-2535

afsfoods@3rivers.nte

Owner/Operator: Chris Gentry,JGC Land LLC

(406) 579-2535

afsfoods@3rivers.nte

Chris Gentry, UST Class A Operator

afsfoods@3rivers.nte

Chris Gentry, UST Class B Operator

afsfoods@3rivers.nte

Tank Code	01	Tank Age	2	Tank Installed Date	07/01/2024	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6228	Spill Test Date	08/06/2024	Piping Installed Date	07/01/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	13000	ATG Test Date	08/14/2024	Line Tightness Test Date	08/21/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/14/2024			ATG Type					
Tank Code	02	Tank Age	2	Tank Installed Date	07/01/2024	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6229	Spill Test Date	08/06/2024	Piping Installed Date	07/01/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	7000	ATG Test Date	08/14/2024	Line Tightness Test Date	08/21/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/14/2024			ATG Type					

Tank Code	03	Tank Age	2	Tank Installed Date	07/01/2024	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6230	Spill Test Date	08/06/2024	Piping Installed Date	07/01/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/14/2024	Line Tightness Test Date	08/21/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/14/2024			ATG Type					
Tank Code	04	Tank Age	2	Tank Installed Date	07/01/2024	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6231	Spill Test Date	08/06/2024	Piping Installed Date	07/01/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	7000	ATG Test Date	08/14/2024	Line Tightness Test Date	08/21/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/14/2024			ATG Type					

Facility Summary in Madison County in the City of Ennis

Location: ROCKY MOUNTAIN SUPPLY INC ENNIS
4997 US Hwy 287 N
Ennis, MT 59729 Madison

System Facility ID: 56-13826

Facility Code: 30512
Last Inspected On: 08/13/2024
Operating Permit Renewal Date: 11/29/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Supply Inc (406) 388-4009 billballiet@rmsi.coop

Operator Contact: Jason Rorabaugh (406) 388-6116 jasonrorabaugh@rmsi.coop

Owner/Operator: Rocky Mountain Supply Inc (406) 388-4009 billballiet@rmsi.coop

Dan Lewis, UST Class B Operator
Jason Rorabaugh, UST Class A Operator danielleewis@rmsi.coop
jasonrorabaugh@rmsi.coop

Tank Code	01	Tank Age	29	Tank Installed Date	07/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1768	Spill Test Date	04/22/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/02/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/24/2024	Line Tightness Test Date	04/24/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/24/2024			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	02	Tank Age	29	Tank Installed Date	07/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	1769	Spill Test Date	04/22/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/02/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	04/24/2024	Line Tightness Test Date	04/24/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/24/2024			ATG Type	Franklin Fueling Systems/EVO 6000				

Tank Code	03	Tank Age	29	Tank Installed Date	07/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	1770	Spill Test Date	04/22/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/02/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/24/2024	Line Tightness Test Date	04/24/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/24/2024			ATG Type	Franklin Fueling Systems/EVO 6000				
Tank Code	04	Tank Age	29	Tank Installed Date	07/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	1771	Spill Test Date	04/22/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/02/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	04/24/2024	Line Tightness Test Date	04/24/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/24/2024			ATG Type	Franklin Fueling Systems/EVO 6000				
Tank Code	05	Tank Age	29	Tank Installed Date	07/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	1772	Spill Test Date	04/22/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/02/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/24/2024	Line Tightness Test Date	04/24/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/24/2024			ATG Type	Franklin Fueling Systems/EVO 6000				
Tank Code	06	Tank Age	29	Tank Installed Date	07/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm

Tag Number	1773	Spill Test Date	04/22/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/24/2024	Line Tightness Test Date	04/24/2024	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/24/2024			ATG Type	Franklin Fueling Systems/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	3	Tank Installed Date	10/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6191	Spill Test Date	04/22/2024	Piping Installed Date	04/24/2024	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	04/24/2024	Line Tightness Test Date	04/24/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	04/24/2024			ATG Type					
Tank Code	08	Tank Age	3	Tank Installed Date	10/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6192	Spill Test Date	04/22/2024	Piping Installed Date	04/24/2024	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/24/2024	Line Tightness Test Date	04/24/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	04/24/2024			ATG Type					
Tank Code	09	Tank Age	3	Tank Installed Date	10/01/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6193	Spill Test Date		Piping Installed Date	04/24/2024	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No

Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Madison County in the City of Ennis

Location: TOWN PUMP INC ENNIS
116 W Main St
Ennis, MT 59729 Madison

System Facility ID:28-08698

Facility Code: 24722
Last Inspected On: 05/21/2025
Operating Permit Renewal Date: 09/23/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ennis 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Ennis 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

Tank Code	01	Tank Age	46	Tank Installed Date	04/14/1980	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2529	Spill Test Date	10/08/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/21/2025	Tank/Piping CP Test Date	07/10/2024	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/21/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	34	Tank Installed Date	04/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2530	Spill Test Date	07/10/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/21/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/21/2025	Line Tightness Test Date	07/13/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	05	Tank Age	34	Tank Installed Date	04/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2531	Spill Test Date	07/10/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/21/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/21/2025	Line Tightness Test Date	08/28/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	34	Tank Installed Date	04/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2532	Spill Test Date	07/10/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/21/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/21/2025	Line Tightness Test Date	08/28/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	24	Tank Installed Date	10/16/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4734	Spill Test Date	07/10/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	05/21/2025	Tank/Piping CP Test Date	05/03/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/21/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	08	Tank Age	24	Tank Installed Date	10/16/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4735	Spill Test Date	07/10/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel	PLL D Test Date	05/21/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/21/2025	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Madison County in the City of Norris

Location: MCLEOD MERCANTILE SW CORNER
6533 US Hwy 287
Norris, MT 59745 Madison

System Facility ID: 56-14138

Facility Code: 30774
Last Inspected On: 10/10/2024
Operating Permit Renewal Date: 02/28/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: A M Welles Inc		(406) 842-5477		Tim@amwelles.com							
Operator Contact: Katie Burtchett; Marvena Rice; Patricia Lehman		(406) 580-3664; (406) 685-3372		dsgrl4ever@hotmail.com; katie@amwelles.com; pg_lehman@yahoo.com							
Owner/Operator: A M Welles Inc		(406) 842-5477		Tim@amwelles.com							
	Katie Burtchett, UST Class A Operator				katie@amwelles.com						
	Katie Burtchett, UST Class B Operator				katie@amwelles.com						
	Marvena Rice, UST Class A Operator				dsgrl4ever@hotmail.com						
	Patricia Lehman, UST Class A Operator				pg_lehman@yahoo.com						
Tank Code	06	Tank Age	35	Tank Installed Date	07/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2712	Spill Test Date	10/10/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	10/10/2024	Tank/Piping CP Test Date	10/10/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	2000	ATG Test Date	10/10/2024	Line Tightness Test Date	11/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	07	Tank Age	35	Tank Installed Date	07/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2713	Spill Test Date	10/10/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	10/10/2024	Tank/Piping CP Test Date	10/10/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	2000	ATG Test Date	10/10/2024	Line Tightness Test Date	11/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	08	Tank Age	35	Tank Installed Date	07/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2714	Spill Test Date	10/10/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	10/10/2024	Tank/Piping CP Test Date	10/10/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	10/10/2024	Line Tightness Test Date	11/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	09	Tank Age	35	Tank Installed Date	07/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2715	Spill Test Date	10/10/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	10/10/2024	Tank/Piping CP Test Date	10/10/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	10/10/2024	Line Tightness Test Date	11/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	10	Tank Age	35	Tank Installed Date	07/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2716	Spill Test Date	10/10/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/10/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	10/10/2024	Line Tightness Test Date	11/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	11	Tank Age	35	Tank Installed Date	07/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2717	Spill Test Date	10/10/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/10/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	10/10/2024	Line Tightness Test Date	11/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	10/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-450			
Tank Code	14	Tank Age	22	Tank Installed Date	07/02/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	4892	Spill Test Date	10/10/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date	10/10/2024	Tank/Piping CP Test Date	11/04/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery
Capacity	12000	ATG Test Date	10/10/2024	Line Tightness Test Date	11/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date	10/10/2024			ATG Type	Gilbarco-Veeder Root/TLS-450			

Facility Summary in Madison County in the City of Sheridan

Location: MCLEOD MERCANTILE 2802043
202 S Main St
Sheridan, MT 59749 Madison

System Facility ID:28-02043

Facility Code: 24575
Last Inspected On: 04/09/2024
Operating Permit Renewal Date: 06/09/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: AM Welles Inc dba McLeod Merc

(406) 685-3372

Tim@amwelles.com

Operator Contact: Sandy Flager

sandylouhou@hotmail.com

Owner/Operator: AM Welles Inc dba McLeod Merc

(406) 685-3372

Tim@amwelles.com

Sandy Flager, UST Class A Operator

sandylouhou@hotmail.com

Sandy Flager, UST Class B Operator

sandylouhou@hotmail.com

Tank Code	13	Tank Age	6	Tank Installed Date	11/19/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5999	Spill Test Date	04/09/2024	Piping Installed Date	11/19/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/09/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	04/09/2024	Line Tightness Test Date	11/27/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	04/09/2024			ATG Type					
Tank Code	14	Tank Age	6	Tank Installed Date	11/19/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6000	Spill Test Date	04/09/2024	Piping Installed Date	11/19/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/09/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/09/2024	Line Tightness Test Date	11/27/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	04/09/2024			ATG Type					

Tank Code	15	Tank Age	6	Tank Installed Date	11/19/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6001	Spill Test Date	04/09/2024	Piping Installed Date	11/19/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/09/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	04/09/2024	Line Tightness Test Date	11/27/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	04/09/2024			ATG Type					
Tank Code	16	Tank Age	6	Tank Installed Date	11/19/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6002	Spill Test Date	04/09/2024	Piping Installed Date	11/19/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/09/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/09/2024	Line Tightness Test Date	11/27/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	04/09/2024			ATG Type					

Facility Summary in Madison County in the City of Sheridan

Location: SHERIDAN SINCLAIR
95 Tuke Ln
Sheridan, MT 59749 Madison

System Facility ID: 60-15002

Facility Code: 30796
Last Inspected On: 06/24/2025
Operating Permit Renewal Date: 09/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: AM Welles Inc dba McLeod Merc

(406) 685-3372

Tim@amwelles.com

Operator Contact: Tim Nicholls

(406) 596-0068

dimes-62@hotmail.com

Owner/Operator: AM Welles Inc dba McLeod Merc

(406) 685-3372

Tim@amwelles.com

Tim Nicholls, UST Class A Operator

dimes-62@hotmail.com

Tim Nicholls, UST Class B Operator

dimes-62@hotmail.com

Tank Code	02	Tank Age	21	Tank Installed Date	09/15/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5007	Spill Test Date	06/24/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	06/24/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	06/24/2025	Line Tightness Test Date	12/09/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/24/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	21	Tank Installed Date	09/15/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5008	Spill Test Date	06/24/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	06/24/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/24/2025	Line Tightness Test Date	12/17/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	06/24/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			
Tank Code	04	Tank Age	21	Tank Installed Date	09/15/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	5009	Spill Test Date	06/24/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date	06/24/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery
Capacity	7000	ATG Test Date	06/24/2025	Line Tightness Test Date	12/17/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act
		Overfill Test Date	06/24/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			
Tank Code	05	Tank Age	21	Tank Installed Date	09/15/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	5010	Spill Test Date	06/24/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date	06/24/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery
Capacity	15000	ATG Test Date	06/24/2025	Line Tightness Test Date	12/11/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act
		Overfill Test Date	06/24/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			
Tank Code	06	Tank Age	21	Tank Installed Date	09/15/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	5011	Spill Test Date	06/24/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date	12/26/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery
Capacity	10000	ATG Test Date	06/24/2025	Line Tightness Test Date	12/23/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act
		Overfill Test Date	06/24/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			

Tank Code	01	Tank Age	21	Tank Installed Date	09/15/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5044	Spill Test Date	06/24/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/24/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	06/24/2025	Line Tightness Test Date	12/05/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/24/2025			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Madison County in the City of Twin Bridges

Location: BOS CHEVRON AND TIRE SERVICE
100 S Main St
Twin Bridges, MT 59754 Madison

System Facility ID:28-07478

Facility Code: 24698
Last Inspected On: 12/11/2025
Operating Permit Renewal Date: 11/08/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bo Mailey		(406) 684-5611		bos.service32@gmail.com							
Operator Contact: Bo Mailey		(406) 684-5611		bos.service32@gmail.com							
Owner/Operator: Bo Mailey		(406) 684-5611		bos.service32@gmail.com							
Bo Mailey, UST Class A Operator				bos.service32@gmail.com							
Bo Mailey, UST Class B Operator				bos.service32@gmail.com							
Tank Code	05	Tank Age	27	Tank Installed Date	01/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3913	Spill Test Date	12/11/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/11/2025			ATG Type					
Tank Code	06	Tank Age	27	Tank Installed Date	01/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3914	Spill Test Date	12/11/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/11/2025			ATG Type					

Facility Summary in Madison County in the City of Twin Bridges

Location: THREE RIVERS QUICK STOP
325 S Main St
Twin Bridges, MT 59754-9740 Madison

System Facility ID: 28-10708

Facility Code: 24759
Last Inspected On: 09/23/2024
Operating Permit Renewal Date: 01/19/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Heath Pardieau (559) 362-5850 trqsandti@outlook.com

Operator Contact: Heath Pardieau (559) 362-5850 trqsandti@outlook.com

Owner/Operator: Heath Pardieau (559) 362-5850 trqsandti@outlook.com

Heath Pardieau, UST Class A Operator trqsandti@outlook.com

Heath Pardieau, UST Class B Operator trqsandti@outlook.com

Tank Code	04	Tank Age	34	Tank Installed Date	10/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1816	Spill Test Date	09/23/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/10/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	3000	ATG Test Date	09/10/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/10/2024			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	34	Tank Installed Date	10/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1817	Spill Test Date	09/23/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/10/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	09/10/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/10/2024			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Madison County in the City of Virginia City

Location: VILLAGE PUMP AND INFORMATION CENTER
221 E Wallace St
Virginia City, MT 59755-0338 Madison

System Facility ID:28-05399

Facility Code: 24653
Last Inspected On: 10/01/2025
Operating Permit Renewal Date: 01/07/2029

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana Heritage Preservation and Development Commission (406) 843-5655
Virginia City

ksteeley@mt.gov

Operator Contact: Tanya Engle;Village Pump Gas Station

(406) 843-5247

tanya.engle@mt.gov

Owner/Operator: Montana Heritage Preservation and Development Commission Virginia City

(406) 843-5655

ksteeley@mt.gov

Tanya Engle, UST Class A Operator

tanya.engle@mt.gov

Tanya Engle, UST Class B Operator

tanya.engle@mt.gov

Tank Code	04	Tank Age	7	Tank Installed Date	02/05/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5860	Spill Test Date	10/01/2025	Piping Installed Date	02/05/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/01/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/10/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	10/01/2025	Line Tightness Test Date	02/11/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/01/2025			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	7	Tank Installed Date	02/05/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5861	Spill Test Date	10/01/2025	Piping Installed Date	02/05/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/01/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/10/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	10/01/2025	Line Tightness Test Date	02/11/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

	Overfill Test Date	10/01/2025		ATG Type	Gilbarco-Veeder Root/TLS- 450PLUS;Veeder Root/TLS- 450PLUS		
--	---------------------------	------------	--	-----------------	--	--	--