

Facility Summary in McCone County in the City of Circle

Location: CIRCLE CONOCO
901 B Ave
Circle, MT 59215 McCone

System Facility ID:29-03684

Facility Code: 24887
Last Inspected On: 12/14/2023
Operating Permit Renewal Date: 12/14/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Chuck Hawkinson

(307) 389-3445

chawkinson@outlook.com

Operator Contact:

Owner/Operator: Chuck Hawkinson

(307) 389-3445

chawkinson@outlook.com

Tank Code	05	Tank Age	36	Tank Installed Date	09/12/1990	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1267	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/15/2023	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in McCone County in the City of Circle

Location: CIRCLE COUNTRY MARKET LLC
105 10th St
Circle, MT 59215 McCone

System Facility ID:29-00042

Facility Code: 24842
Last Inspected On: 12/09/2024
Operating Permit Renewal Date: 12/09/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Circle Country Market LLC

circlefoods.graves@gmail.com

Operator Contact: Cody Carlsen;Julian Hoffman;Leonard Kuntz;Les Carlsen;Tammy Leeson

(406) 485-2680;(406) 485-3645;(406) 941-2131

circlefoods.graves@gmail.com;circlefoods.leeson@gmail.com;lescarlsen@hotmail.com

Owner/Operator: Circle Country Market LLC

circlefoods.graves@gmail.com

Cody Carlsen, UST Class A Operator

lescarlsen@hotmail.com

Cody Carlsen, UST Class B Global Operator

lescarlsen@hotmail.com

Cory Hirschfeld, UST Class B Global Operator

Denny Hogan, UST Class B Global Operator

Julian Hoffman, UST Class A Operator

circlefoods.graves@gmail.com

Julian Hoffman, UST Class B Global Operator

circlefoods.graves@gmail.com

Julian Hoffman, UST Class B Operator

circlefoods.graves@gmail.com

Leonard Kuntz, UST Class A Operator

Les Carlsen, UST Class A Operator

lescarlsen@hotmail.com

Les Carlsen, UST Class B Global Operator

lescarlsen@hotmail.com

Tammy Leeson, UST Class A Operator

circlefoods.leeson@gmail.com

Tammy Leeson, UST Class B Global Operator

circlefoods.leeson@gmail.com

Tammy Leeson, UST Class B Operator

circlefoods.leeson@gmail.com

Tank Code	03	Tank Age	29	Tank Installed Date	10/01/1997	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	618	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/26/2015	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	04	Tank Age	29	Tank Installed Date	10/01/1997	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	619	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No

Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLL D Test Date		Tank/Piping CP Test Date	10/26/2015	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in McCone County in the City of Circle

Location: CIRCLE PUBLIC SCHOOL DIST 1
1105 F Ave
Circle, MT 59215 McCone

System Facility ID:29-00874

Facility Code: 24849
Last Inspected On: 03/12/2025
Operating Permit Renewal Date: 06/04/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 1 Circle

rkirkegard@circleschools.k12.mt.us

Operator Contact: Tara Hubing;School Dist 1 Circle

(406) 974-2464

thubing@circleschools.k12.mt.us;rkirkegard@circleschools.k12.mt.us

Owner/Operator: School Dist 1 Circle

rkirkegard@circleschools.k12.mt.us

Tara Hubing, UST Class A Operator

rkirkegard@circleschools.k12.mt.us

Tara Hubing, UST Class B Operator

rkirkegard@circleschools.k12.mt.us

Tank Code	S2	Tank Age	29	Tank Installed Date	08/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1890	Spill Test Date	03/12/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	04/10/2013	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/12/2025	Line Tightness Test Date	03/10/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/12/2025			ATG Type					

Facility Summary in McCone County in the City of Circle

Location: CIRCLE SINCLAIR
210 A Ave
Circle, MT 59215 McCone

System Facility ID:29-00041

Facility Code: 24841
Last Inspected On: 03/20/2025
Operating Permit Renewal Date: 03/30/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Grant Herden (406) 485-2268 slimjimgrant@gmail.com

Operator Contact: Grant Herden (406) 485-2268 slimjimgrant@gmail.com

Owner/Operator: Grant Herden (406) 485-2268 slimjimgrant@gmail.com

Grant Herden, UST Class A Operator
Grant Herden, UST Class B Operator
slimjimgrant@gmail.com
slimjimgrant@gmail.com

Tank Code	08	Tank Age	29	Tank Installed Date	10/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	612	Spill Test Date	03/20/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/20/2025			ATG Type					
Tank Code	09	Tank Age	29	Tank Installed Date	10/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	613	Spill Test Date	03/20/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/20/2025			ATG Type					
Tank Code	10	Tank Age	29	Tank Installed Date	10/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	614	Spill Test Date	03/20/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/20/2025			ATG Type					
Tank Code	11	Tank Age	29	Tank Installed Date	10/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	615	Spill Test Date	03/20/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/20/2025			ATG Type					
Tank Code	12	Tank Age	29	Tank Installed Date	10/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	616	Spill Test Date	03/20/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/20/2025			ATG Type					
Tank Code	13	Tank Age	29	Tank Installed Date	10/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	617	Spill Test Date	03/20/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/20/2025			ATG Type					

Facility Summary in McCone County in the City of Circle

Location: FARMERS UNION OIL CO CIRCLE
906 A Ave
Circle, MT 59215 McCone

System Facility ID:29-06376

Facility Code: 24902
Last Inspected On: 10/21/2024
Operating Permit Renewal Date: 03/04/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Farmers Union Oil Co Circle

Operator Contact: Cory Vorderbruggen;Jeffrey Schaefer;Terry Wahl

(406) 485-3475

farmersgm@midrivers.com

Owner/Operator: Farmers Union Oil Co Circle

Cory Vorderbruggen, UST Class A Operator

farmersgm@midrivers.com

Jeffrey Schaefer, UST Class A Operator

farmersgm@midrivers.com

Jeffrey Schaefer, UST Class B Operator

farmersgm@midrivers.com

Larry Kwasney, UST Class B Operator

farmers@midrivers.com

Terry Wahl, UST Class A Operator

Terry Wahl, UST Class B Global Operator

Tank Code	S12	Tank Age	20	Tank Installed Date	10/06/2006	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types
Tag Number	5108	Spill Test Date		Piping Installed Date	<th>Tank Construction</th> <td></td> <th>Piping Construction</th> <td>Double Walled</td> <th>AST</th>	Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date	05/01/2025	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery
Capacity	5000	ATG Test Date		Line Tightness Test Date	09/03/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act
		Overfill Test Date			<th>ATG Type</th> <td></td> <td></td> <td></td> <td></td>	ATG Type				
Tank Code	S08	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Unknown	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	951	Spill Test Date		Piping Installed Date	08/16/2006	Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	<th>Catastrophic L.D Type 3.0</th> <td>Electronic Line Leak Detector</td> <th>Piping Type</th> <td>Pressurized</td> <th>CP Met Types</th>	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date	06/10/2024	Tank/Piping CP Test Date	<th>Primary Tank Leak Detection</th> <td></td> <th>Primary Pipe Detection</th> <td>ELLD 0.2</td> <th>Vapor Recovery</th>	Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery
Capacity	15000	ATG Test Date	<th>Line Tightness Test Date</th> <td>08/21/2021<th>Secondary Tank Leak Detection</th><td></td><th>Secondary Pipe Detection</th><td>Continuous Interstitial Monitoring</td><th>Energy Act</th></td>	Line Tightness Test Date	08/21/2021 <th>Secondary Tank Leak Detection</th> <td></td> <th>Secondary Pipe Detection</th> <td>Continuous Interstitial Monitoring</td> <th>Energy Act</th>	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act

	Overfill Test Date				ATG Type				
Tank Code	S09	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Unknown	Piping Material	Fiberglass Reinforced Plastic
Tag Number	952	Spill Test Date		Piping Installed Date	08/16/2006	Tank Construction		Piping Construction	Double Walled
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	CP Met Types
Product	Gasoline	PLLD Test Date	06/10/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2
Capacity	15000	ATG Test Date		Line Tightness Test Date	08/23/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring
	Overfill Test Date					ATG Type			
Tank Code	S10	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Unknown	Piping Material	Fiberglass Reinforced Plastic
Tag Number	953	Spill Test Date		Piping Installed Date	08/16/2006	Tank Construction		Piping Construction	Double Walled
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	CP Met Types
Product	Diesel	PLLD Test Date	06/10/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2
Capacity	15000	ATG Test Date		Line Tightness Test Date	09/30/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring
	Overfill Test Date					ATG Type			
Tank Code	S11	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Unknown	Piping Material	Fiberglass Reinforced Plastic
Tag Number	954	Spill Test Date		Piping Installed Date	08/16/2006	Tank Construction		Piping Construction	Double Walled
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	CP Met Types
Product	Diesel	PLLD Test Date	06/10/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2
Capacity	15000	ATG Test Date		Line Tightness Test Date	08/20/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring
	Overfill Test Date					ATG Type			

Facility Summary in McCone County in the City of Circle

Location: FARMERS UNION OIL C-STORE
200 B Ave
Circle, MT 59215 McCone

System Facility ID:60-15206

Facility Code: 30926
Last Inspected On: 01/02/2025
Operating Permit Renewal Date: 04/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Farmers Union Oil C-Store (406) 485-3333

Operator Contact: Cory Vorderbruggen;Jeffrey Schaefer;Terry Wahl (406) 485-3475 farmersgm@midrivers.com

Owner/Operator: Farmers Union Oil C-Store (406) 485-3333

Cory Vorderbruggen, UST Class A Operator	farmersgm@midrivers.com
Dharlyne Kirkegard, UST Class B Operator	farmerscstore@midrivers.com
Dorothy Johnson, UST Class B Operator	farmers@midrivers.com
Jeffrey Schaefer, UST Class A Operator	farmersgm@midrivers.com
Jeffrey Schaefer, UST Class B Operator	farmersgm@midrivers.com
Sadie Idland, UST Class B Operator	farmerscstore@midrivers.com
Terry Wahl, UST Class A Operator	
Terry Wahl, UST Class B Global Operator	

Tank Code	02	Tank Age	14	Tank Installed Date	06/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5356	Spill Test Date	10/21/2024	Piping Installed Date	10/10/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/10/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	06/10/2024	Line Tightness Test Date	10/19/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/21/2024			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	14	Tank Installed Date	06/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5357	Spill Test Date	10/21/2024	Piping Installed Date	10/10/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/10/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	14000	ATG Test Date	06/10/2024	Line Tightness Test Date	10/19/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/21/2024			ATG Type	Gilbarco-Veeder Root/TLS-350; Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	14	Tank Installed Date	06/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5358	Spill Test Date	10/21/2024	Piping Installed Date	10/10/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/10/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	14000	ATG Test Date	06/10/2024	Line Tightness Test Date	10/25/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/21/2024			ATG Type	Gilbarco-Veeder Root/TLS-350; Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	14	Tank Installed Date	06/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5359	Spill Test Date	10/21/2024	Piping Installed Date	10/10/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/10/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/10/2024	Line Tightness Test Date	05/02/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/21/2024			ATG Type	Gilbarco-Veeder Root/TLS-350; Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	14	Tank Installed Date	06/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5360	Spill Test Date	10/21/2024	Piping Installed Date	10/10/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLL D Test Date	06/10/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/10/2024	Line Tightness Test Date	10/11/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/21/2024			ATG Type	Gilbarco-Veeder Root/TLS-350; Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in McCone County in the City of Circle

Location: KWASNEY LLC
706 B Ave
Circle, MT 59215 McCone

System Facility ID:29-03433

Facility Code: 24879
Last Inspected On: 05/15/2023
Operating Permit Renewal Date: 08/11/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: KWASNEY LLC	(406) 485-3401	kwaz7@middrivers.com
--	----------------	----------------------

Operator Contact: Tamra Englund;KWASNEY LLC	(406) 485-3401	tamra.exxon2@gmail.com;kwaz7@middrivers.com
--	----------------	---

Owner/Operator: KWASNEY LLC	(406) 485-3401	kwaz7@middrivers.com
Tamra Englund, UST Class A Operator		kwaz7@middrivers.com
Tamra Englund, UST Class B Operator		kwaz7@middrivers.com

Tank Code	07	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3802	Spill Test Date	05/15/2023	Piping Installed Date	02/14/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/11/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/23/2023	Line Tightness Test Date	02/03/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/15/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3803	Spill Test Date	05/15/2023	Piping Installed Date	02/14/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/11/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	03/23/2023	Line Tightness Test Date	02/05/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/15/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	09	Tank Age	28	Tank Installed Date	11/01/1998	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3804	Spill Test Date	05/15/2023	Piping Installed Date	02/14/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/23/2023	Line Tightness Test Date	03/04/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/15/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in McCone County in the City of Vida

Location: AGLAND COOP VIDA
MT Hwy 13
Vida, MT 59274 McCone

System Facility ID: 56-14042

Facility Code: 30697
Last Inspected On: 02/26/2024
Operating Permit Renewal Date: 08/07/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Agland Coop Wolf Point (406) 653-1221 dave.williams@agland-coop.com

Operator Contact: Aaron Bradley;David Parsley;Waldo Wall (406) 653-1510;(406) 853-0492 aaron.bradley@chsinc.com;dave.parsley@agland-coop.com

Owner/Operator: Agland Coop Wolf Point (406) 653-1221 dave.williams@agland-coop.com

Aaron Bradley, UST Class A Operator
Aaron Bradley, UST Class B Operator
Allen Richard, UST Class B Global Operator
Allen Richard, UST Class B Operator
David Parsley, UST Class A Operator
Michael Pallvoda, UST Class B Operator
Waldo Wall, UST Class A Operator
Waldo Wall, UST Class B Operator
Weston Smith, UST Class B Global Operator

aaron.bradley@chsinc.com
aaron.bradley@chsinc.com
allen.richard@agland-coop.com
allen.richard@agland-coop.com
dave.parsley@agland-coop.com
fuoilwp@nemont.net

Tank Code	01	Tank Age	25	Tank Installed Date	12/01/2001	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4560	Spill Test Date	02/27/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	02/27/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	05/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/27/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	25	Tank Installed Date	12/01/2001	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4561	Spill Test Date	02/27/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic

Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	02/27/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	05/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/27/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	25	Tank Installed Date	12/01/2001	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4562	Spill Test Date	02/27/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	02/27/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	05/01/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/27/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				