

**Facility Summary in Park County in the City of Clyde Park**

**Location:** DALES FUEL INC  
301 1st Ave  
Clyde Park, MT 59018 Park

System Facility ID:34-07600

**Facility Code:** 26059  
**Last Inspected On:** 03/13/2025  
**Operating Permit Renewal Date:** 06/15/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Dales Fuel Inc (406) 686-4681

**Operator Contact:** Dale Jones

**Owner/Operator:** Dales Fuel Inc (406) 686-4681

Dale Jones, UST Class A Operator  
Dale Jones, UST Class A Operator  
Jackie Jones, UST Class B Operator  
Jackie Jones, UST Class B Operator

dalesfuel@gmail.com  
dalesfuel@gmail.com

<b>Tank Code</b>	05	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	04/01/1999	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3991	<b>Spill Test Date</b>	08/11/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/19/2024			<b>ATG Type</b>					
<b>Tank Code</b>	06	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	04/01/1999	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3992	<b>Spill Test Date</b>	08/11/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2500	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/03/2021			<b>ATG Type</b>					
<b>Tank Code</b>	07	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	04/01/1999	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve

<b>Tag Number</b>	3993	<b>Spill Test Date</b>	08/03/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	1900	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/03/2021			<b>ATG Type</b>					
<b>Tank Code</b>	08	<b>Tank Age</b>	26	<b>Tank Installed Date</b>	04/01/1999	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3994	<b>Spill Test Date</b>	08/03/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Manual Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	1900	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/03/2021			<b>ATG Type</b>					

**Facility Summary in Park County in the City of Clyde Park**

**Location:** SHIELDS VALLEY HIGH SCHOOL  
401 1st St E  
Clyde Park, MT 59018 Park

System Facility ID:34-12515

**Facility Code:** 26147  
**Last Inspected On:** 10/29/2024  
**Operating Permit Renewal Date:** 03/01/2028

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** School Dist Shields Valley (406) 578-2176

**Operator Contact:** Dan Johnston;Shields Valley School Dist djohnston@shieldsvalleyschools.org

**Owner/Operator:** School Dist Shields Valley (406) 578-2176

Dan Johnston, UST Class A Operator  
Mitchell Marx, UST Class B Operator

djohnston@shieldsvalleyschools.org  
central.montana@gmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	60	<b>Tank Installed Date</b>	07/01/1965	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	2725	<b>Spill Test Date</b>	10/29/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Lined Interior/Impressed Current	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	10/29/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	10/29/2024	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/29/2024			<b>ATG Type</b>	Gilbarco/EMC Basic				

## Facility Summary in Park County in the City of Cooke City

**Location:** COOKE CITY EXXON  
204 Main St  
Cooke City, MT 59020 Park

System Facility ID:34-01584

**Facility Code:** 25925  
**Last Inspected On:** 07/05/2022  
**Operating Permit Renewal Date:** 09/17/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** Wea Enterprises Inc. (406) 838-2244 cookecityexxon@gmail.com

---

**Operator Contact:** Joelle Passerello;Timmy Weamer (406) 855-5792 cookecityexxon@gmail.com;joellepasserello@gmail.com

---

**Owner/Operator:** Wea Enterprises Inc. (406) 838-2244 cookecityexxon@gmail.com

Joelle Passerello, UST Class A Operator joellepasserello@gmail.com  
Joelle Passerello, UST Class B Operator joellepasserello@gmail.com  
Timmy Weamer, UST Class A Operator cookecityexxon@gmail.com  
Timmy Weamer, UST Class B Global Operator cookecityexxon@gmail.com

<b>Tank Code</b>	07	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	10/01/1991	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;High Level Alarm
<b>Tag Number</b>	757	<b>Spill Test Date</b>	09/23/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/31/2022	<b>Tank/Piping CP Test Date</b>	09/23/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	05/26/2023	<b>Line Tightness Test Date</b>	05/30/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/05/2022			<b>ATG Type</b>	Franklin Fueling Systems/EVO 6000				
<b>Tank Code</b>	08	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	10/01/1991	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve;High Level Alarm
<b>Tag Number</b>	758	<b>Spill Test Date</b>	09/23/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	06/03/2019	<b>Tank/Piping CP Test Date</b>	09/23/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	05/26/2023	<b>Line Tightness Test Date</b>	06/03/2019	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	07/05/2022			<b>ATG Type</b>	Franklin Fueling Systems/EVO 6000				
<b>Tank Code</b>	09	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	10/01/1997	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	759	<b>Spill Test Date</b>	09/23/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	05/31/2022	<b>Tank/Piping CP Test Date</b>	09/23/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	05/26/2023	<b>Line Tightness Test Date</b>	05/30/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/05/2022			<b>ATG Type</b>	Franklin Fueling Systems/EVO 6000				
<b>Tank Code</b>	10	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	10/01/1997	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	760	<b>Spill Test Date</b>	09/23/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	05/31/2022	<b>Tank/Piping CP Test Date</b>	09/23/2021	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	05/26/2023	<b>Line Tightness Test Date</b>	05/31/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	07/05/2022			<b>ATG Type</b>	Franklin Fueling Systems/EVO 6000				

**Facility Summary in Park County in the City of Cooke City**

**Location:** COOKE CITY SINCLAIR AND CABINS  
115 Main St  
Cooke City, MT 59020 Park

System Facility ID:34-10046

**Facility Code:** 26103  
**Last Inspected On:** 05/31/2022  
**Operating Permit Renewal Date:** 09/17/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Cooke City Sinclair and Lodging, Inc. (406) 579-9993 benzavora@gmail.com

**Operator Contact:** Ben Zavora;Cooke City Sinclair and Lodging, Inc.;Benjamin Zavora;Cooke City Sinclair and Lodging, Inc.;Rick Sommers (406) 579-9993;(406) 838-2244 benzavora@gmail.com;benzavora@gmail.com

**Owner/Operator:** Cooke City Sinclair and Lodging, Inc. (406) 579-9993 benzavora@gmail.com

Ben Zavora, UST Class A Operator benzavora@gmail.com  
 Ben Zavora, UST Class A Operator benzavora@gmail.com  
 Ben Zavora, UST Class B Operator benzavora@gmail.com  
 Ben Zavora, UST Class B Operator benzavora@gmail.com  
 Benjamin Zavora, UST Class A Operator benzavora@gmail.com  
 Benjamin Zavora, UST Class B Operator benzavora@gmail.com  
 Rick Sommers, UST Class A Operator benzavora@gmail.com  
 Rick Sommers, UST Class A Operator benzavora@gmail.com  
 Rick Sommers, UST Class B Global Operator benzavora@gmail.com  
 Rick Sommers, UST Class B Global Operator benzavora@gmail.com

<b>Tank Code</b>	06	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	3670	<b>Spill Test Date</b>	05/31/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	05/31/2022	<b>Line Tightness Test Date</b>	06/03/2019	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/31/2022			<b>ATG Type</b>	Incon/Other				
<b>Tank Code</b>	07	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	10/01/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	3671	<b>Spill Test Date</b>	05/31/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No

<b>Tank Status</b>	<b>Currently in Use</b>	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	05/31/2022	<b>Line Tightness Test Date</b>	06/03/2019	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/31/2022			<b>ATG Type</b>	Incon/				

### Facility Summary in Park County in the City of Cooke City

**Location:** NORTHEAST ENTRANCE GAS PUMPS  
NE Entrance of Park  
Cooke City, MT 59020 Park

System Facility ID:34-08869

**Facility Code:** 26082  
**Last Inspected On:** 07/12/2022  
**Operating Permit Renewal Date:** 09/26/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** National Park Service Mammoth (307) 344-2333

**Operator Contact:** Claude Long;Harry Laney;Jason Ogle;Joel Browning;Nathan Munson (304) 344-2333;(307) 344-2333;(406) 581-9206;(406) 595-0840  
claude\_long@nps.gov;harry\_laney@nps.gov;jason\_ogle@nps.gov;joel\_browning@nps.gov;nathan\_munson@nps.gov

**Owner/Operator:** National Park Service Mammoth (307) 344-2333

Claude Long, UST Class A Operator  
Harry Laney, UST Class A Operator  
Harry Laney, UST Class B Operator  
Jason Ogle, UST Class A Operator  
Joel Browning, UST Class A Operator  
Nathan Munson, UST Class A Operator

claude\_long@nps.gov  
harry\_laney@nps.gov  
harry\_laney@nps.gov  
jason\_ogle@nps.gov  
joel\_browning@nps.gov  
nathan\_munson@nps.gov

<b>Tank Code</b>	04	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	08/01/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1741	<b>Spill Test Date</b>	08/05/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/15/2022	<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	08/25/2021	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/05/2024			<b>ATG Type</b>					
<b>Tank Code</b>	05	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	08/01/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1742	<b>Spill Test Date</b>	08/05/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/15/2022	<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	08/25/2021	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No



Overfill Test Date 08/05/2024

ATG Type

**Facility Summary in Park County in the City of Emigrant**

**Location:** B BUNK INC  
 Parcel 38 N Glastonbury  
 Emigrant, MT 59027-0519 Park

System Facility ID:34-10959

**Facility Code:** 26118  
**Last Inspected On:** 05/23/2023  
**Operating Permit Renewal Date:** 08/27/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** B Bunk Inc (757) 498-6060 padma36mtnow@protonmail.com

---

**Operator Contact:** Bradford Tisdale (757) 498-6060 padma36mtnow@protonmail.com

---

**Owner/Operator:** B Bunk Inc (757) 498-6060 padma36mtnow@protonmail.com  
 Bradford Tisdale, UST Class A Operator padma36mtnow@protonmail.com  
 Bradford Tisdale, UST Class B Operator padma36mtnow@protonmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	04/18/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	415	<b>Spill Test Date</b>	05/23/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/23/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	05/23/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/23/2023			<b>ATG Type</b>	Veeder Root/TLS-300				

**Facility Summary in Park County in the City of Emigrant**

**Location:** CAPSTONE SHELTER  
 Lot 105 S Glastonbury  
 Emigrant, MT 59027 Park

System Facility ID:34-10989

**Facility Code:** 26125  
**Last Inspected On:** 07/06/2022  
**Operating Permit Renewal Date:** 07/06/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Capstone Project (480) 657-2564

**Operator Contact:** Enrico DArgenzio (602) 463-9838 enrigo.dargenzio@cox.net

**Owner/Operator:** Capstone Project (480) 657-2564

Enrico DArgenzio, UST Class A Operator  
 Enrico DArgenzio, UST Class B Operator

enrico.dargenzio@cox.net  
 enrigo.dargenzio@cox.net

<b>Tank Code</b>	01	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	04/13/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4827	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/23/2021	<b>Primary Tank Leak Detection</b>	Vapor Monitoring	<b>Primary Pipe Detection</b>	Not Listed	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Park County in the City of Emigrant**

**Location:** COMMUNITY CONSERVATION ASSOCIATION  
2 B Taurus Rd  
Emigrant, MT 59027 Park

System Facility ID:34-10934

**Facility Code:** 26116  
**Last Inspected On:** 05/18/2022  
**Operating Permit Renewal Date:** 06/12/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Community Conservation Association Inc Emigrant (406) 579-3399

**Operator Contact:** Edward Dratz (406) 579-3399 edratz@gmail.com

**Owner/Operator:** Community Conservation Association Inc Emigrant (406) 579-3399

Edward Dratz, UST Class A Operator edratz@gmail.com  
Edward Dratz, UST Class B Global Operator edratz@gmail.com  
Edward Dratz, UST Class B Operator edratz@gmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	04/18/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4684	<b>Spill Test Date</b>	05/18/2022	<b>Piping Installed Date</b>	11/06/1998	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/18/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/18/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/18/2022			<b>ATG Type</b>	Veeder Root/TLS-300				

**Facility Summary in Park County in the City of Emigrant**

**Location:** COMMUNITY CONTINUITY INC  
18 Polaris Way Parcel 70 S Glastonbury  
Emigrant, MT 59027 Park

System Facility ID:34-10930

**Facility Code:** 26113  
**Last Inspected On:** 06/16/2023  
**Operating Permit Renewal Date:** 10/02/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Community Continuity Inc

**Operator Contact:** Daniel Kehoe

**(406) 223-2232**

**dankehoe56@gmail.com**

**Owner/Operator:** Community Continuity Inc

Daniel Kehoe, UST Class A Operator

dankehoe56@gmail.com

Daniel Kehoe, UST Class B Operator

dankehoe56@gmail.com

Dennis Franks, UST Class B Global Operator

dennis@ajminc.net

<b>Tank Code</b>	01	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	02/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4821	<b>Spill Test Date</b>	06/16/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	06/16/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	Gravity Feed	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/16/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	06/16/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/16/2023			<b>ATG Type</b>	Veeder Root/TLS-300				

**Facility Summary in Park County in the City of Emigrant**

**Location:** COMMUNITY RESTORATION INC  
Hercules Rd and Polaris Way  
Emigrant, MT 59027 Park

System Facility ID:34-10931

**Facility Code:** 26114  
**Last Inspected On:** 06/16/2023  
**Operating Permit Renewal Date:** 10/02/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Community Restoration Inc (800) 631-8885

**Operator Contact:** Daniel Kehoe (406) 223-2232 dankehoe56@gmail.com

**Owner/Operator:** Community Restoration Inc (800) 631-8885

Daniel Kehoe, UST Class A Operator

dankehoe56@gmail.com

Daniel Kehoe, UST Class B Operator

dankehoe56@gmail.com

Dennis Franks, UST Class B Global Operator

dennis@ajminc.net

<b>Tank Code</b>	01	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	02/20/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	701	<b>Spill Test Date</b>	06/16/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	06/16/2023	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/16/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	06/16/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/16/2023			<b>ATG Type</b>	Veeder Root/TLS-300				

**Facility Summary in Park County in the City of Emigrant**

**Location:** DENNIS CURTIN  
70 Ramshorn Rd  
Emigrant, MT 59027 Park

System Facility ID:56-14035

**Facility Code:** 30691  
**Last Inspected On:** 09/06/2022  
**Operating Permit Renewal Date:** 12/31/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** D M Curtin Family Limited Partnership (406) 333-4056 dcurtin@rmxreg.com

---

**Operator Contact:** Channell Libbey;Todd Fredericksen (406) 223-1459 chan.libbey@earthlink.net;fredericksentodd@gmail.com

---

**Owner/Operator:** D M Curtin Family Limited Partnership (406) 333-4056 dcurtin@rmxreg.com  
 Channell Libbey, UST Class A Operator chan.libbey@earthlink.net  
 Todd Fredericksen, UST Class A Operator fredericksentodd@gmail.com  
 Todd Fredericksen, UST Class B Operator fredericksentodd@gmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	24	<b>Tank Installed Date</b>	10/15/2001	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4435	<b>Spill Test Date</b>	09/06/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/06/2022	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/06/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/ILS-350				

**Facility Summary in Park County in the City of Emigrant**

**Location:** EARTH HOME PROPERTIES LLC  
Evening Star Dr  
Emigrant, MT 59027 Park

System Facility ID:34-10978

**Facility Code:** 26123  
**Last Inspected On:** 08/15/2024  
**Operating Permit Renewal Date:** 08/15/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** Earth Home Properties LLC (978) 658-3010 newhousebuilders@gmail.com

---

**Operator Contact:** Craig Newhouse (978) 65-87675 newhousebuilders@gmail.com

---

**Owner/Operator:** Earth Home Properties LLC (978) 658-3010 newhousebuilders@gmail.com

Craig Newhouse, UST Class A Operator

newhousebuilders@gmail.com

Craig Newhouse, UST Class B Operator

newhousebuilders@gmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	04/23/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4753	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/11/2021	<b>Primary Tank Leak Detection</b>	Vapor Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					
<b>Tank Code</b>	02	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	04/23/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	No Piping	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4754	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/11/2021	<b>Primary Tank Leak Detection</b>	Vapor Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					



**Facility Summary in Park County in the City of Emigrant**

**Location:** EMIGRANT GENERAL STORE  
3 Murphy Ln  
Emigrant, MT 59027-6100 Park

System Facility ID:34-06713

**Facility Code:** 26035  
**Last Inspected On:** 08/28/2024  
**Operating Permit Renewal Date:** 05/28/2022

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** EMGS LLC (406) 333-4434 cameron@emigrantgeneralstore.com

**Operator Contact:** Cameron Ehrlich;Emigrant General Store (406) 333-4434 cehlich112@gmail.com;otisranch@wispwest.net

**Owner/Operator:** EMGS LLC (406) 333-4434 cameron@emigrantgeneralstore.com  
Cameron Ehrlich, UST Class A Operator otisranch@wispwest.net  
Cameron Ehrlich, UST Class B Operator otisranch@wispwest.net

<b>Tank Code</b>	02	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	09/01/1989	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4351	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/07/2019	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	06	<b>Tank Age</b>	28	<b>Tank Installed Date</b>	01/01/1997	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4352	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/07/2019	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No

<b>Capacity</b>	10000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	01	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	09/01/1989	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4353	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/07/2019	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	ELLD 0.1;ELLD 0.2;ELLD Line Tightness Testing;Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	07	<b>Tank Age</b>	7	<b>Tank Installed Date</b>	11/15/2018	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5852	<b>Spill Test Date</b>	08/28/2024	<b>Piping Installed Date</b>	11/15/2018	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/28/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	12000	<b>ATG Test Date</b>	08/28/2024	<b>Line Tightness Test Date</b>	03/01/2019	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/28/2024			<b>ATG Type</b>	Incon/TS-550 EVO				
<b>Tank Code</b>	08	<b>Tank Age</b>	7	<b>Tank Installed Date</b>	11/15/2018	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5853	<b>Spill Test Date</b>	08/28/2024	<b>Piping Installed Date</b>	11/15/2018	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/28/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	8000	<b>ATG Test Date</b>	08/28/2024	<b>Line Tightness Test Date</b>	03/05/2019	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/28/2024			<b>ATG Type</b>	Incon/TS-550 EVO				

<b>Tank Code</b>	09	<b>Tank Age</b>	7	<b>Tank Installed Date</b>	11/15/2018	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	5854	<b>Spill Test Date</b>	08/28/2024	<b>Piping Installed Date</b>	11/15/2018	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/28/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	08/28/2024	<b>Line Tightness Test Date</b>	03/05/2019	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/28/2024			<b>ATG Type</b>	Incon/TS-550 EVO				

**Facility Summary in Park County in the City of Emigrant**

**Location:** LIFESAVERS INC  
 Lot 28 N Glastonbury  
 Emigrant, MT 59027-0056 Park

System Facility ID:34-10965

**Facility Code:** 26120  
**Last Inspected On:** 06/21/2021  
**Operating Permit Renewal Date:** 06/21/2024

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Lifesavers Inc

**Operator Contact:** Patricia Jones;Robert Smith

**(406) 295-5852**

**patricia\_sk@sbcglobal.net**

Patricia Jones, UST Class A Operator  
 Patricia Jones, UST Class B Operator  
 Robert Smith, UST Class A Operator  
 Robert Smith, UST Class B Operator

patricia\_sk@sbcglobal.net  
 patricia\_sk@sbcglobal.net

<b>Tank Code</b>	01	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	04/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Copper	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4499	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/21/2021	<b>Primary Tank Leak Detection</b>	Vapor Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring;Vapor Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	24000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Park County in the City of Emigrant**

**Location:** ROSKIND RANCH  
65 Arcturus Dr  
Emigrant, MT 59027 Park

System Facility ID:34-13180

**Facility Code:** 26156  
**Last Inspected On:** 01/16/2023  
**Operating Permit Renewal Date:** 01/16/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

---

**Owner Operator Contact:** Alicia Roskind (424) 610-6640 asroskind@gmail.com

---

**Operator Contact:** Alicia Roskind;Kenneth Mueller (406) 333-4669;(424) 610-6640 asroskind@gmail.com;kencmueller@gmail.com

---

**Owner/Operator:** Alicia Roskind (424) 610-6640 asroskind@gmail.com

Alicia Roskind, UST Class A Operator asroskind@gmail.com  
 Alicia Roskind, UST Class B Global Operator asroskind@gmail.com  
 Alicia Roskind, UST Class B Operator asroskind@gmail.com  
 Kenneth Mueller, UST Class A Operator kencmueller@gmail.com  
 Kenneth Mueller, UST Class B Operator kencmueller@gmail.com

<b>Tank Code</b>	02	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	12/01/1995	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3123	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	01/16/2023	<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>					

**Facility Summary in Park County in the City of Emigrant**

**Location:** SHELTER INVINCIBLE INC  
25 Gemini Rd  
Emigrant, MT 59027 Park

System Facility ID:34-10933

**Facility Code:** 26115  
**Last Inspected On:** 09/21/2020  
**Operating Permit Renewal Date:** 08/24/2023

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Shelter Invincible Inc

**(406) 333-4485**

**alane@vondir.com**

**Operator Contact:** David Tonkin

**cdavid@wispwest.net**

Charles Widaman, UST Class B Operator  
Charles Widaman, UST Class B Operator  
David Tonkin, UST Class A Operator  
David Tonkin, UST Class A Operator  
David Tonkin, UST Class B Operator  
David Tonkin, UST Class B Operator

cdavid@wispwest.net  
cdavid@wispwest.net  
cdavid@wispwest.net  
cdavid@wispwest.net

<b>Tank Code</b>	01	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	04/17/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Copper	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1882	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Secondary Containment Chase	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	09/21/2020	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Park County in the City of Gardiner**

**Location:** GARDINER SCHOOL DIST 4  
510 Stone St  
Gardiner, MT 59030-9378 Park

System Facility ID:34-09287

**Facility Code:** 26086  
**Last Inspected On:** 11/09/2017  
**Operating Permit Renewal Date:** 01/02/2021

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** School Dist 7 & 4 Gardiner Public

**(406) 848-7563**

**Operator Contact:** Douglas Coy;Tom Nelson

**tnelson@gardiner.org**

Douglas Coy, UST Class A Operator  
Douglas Coy, UST Class B Operator  
Tom Nelson, UST Class A Operator  
Tom Nelson, UST Class B Operator

tnelson@gardiner.org  
tnelson@gardiner.org

<b>Tank Code</b>	S2	<b>Tank Age</b>	38	<b>Tank Installed Date</b>	04/24/1987	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	4451	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Permanently Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/31/2018	<b>Catastrophic L.D Type 3.0</b>	Auto Dialer	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Heating Oil	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/09/2017	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	16000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Park County in the City of Gardiner**

**Location:** GARDINER SERVICE CENTER  
US Hwy 89 S  
Gardiner, MT 59030 Park

System Facility ID:34-08868

**Facility Code:** 26081  
**Last Inspected On:** 03/01/2022  
**Operating Permit Renewal Date:** 07/28/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

<b>Owner Operator Contact:</b> Xanterra Parks and Resorts Inc	(307) 344-5340	DYHOFFMAN@XANTERRA.COM
<b>Operator Contact:</b> Anthony Bevill;Xanterra Parks and Resorts Inc;Dylan Hoffman;Josiah Reese;Samuel Krasnobrod	(307) 344-5204;(307) 344-5340;(307) 344-5593;(406) 220-9348	abevill@xanterra.com;DYHOFFMAN@XANTERRA.COM;dhoffman@xanterra.com;jreese@xanterra.com;skrasnobrod@xanterra.com

<b>Owner/Operator:</b> Xanterra Parks and Resorts Inc	(307) 344-5340	DYHOFFMAN@XANTERRA.COM
Anthony Bevill, UST Class A Operator		DYHOFFMAN@XANTERRA.COM
Anthony Bevill, UST Class B Operator		DYHOFFMAN@XANTERRA.COM
Dylan Hoffman, UST Class A Operator		dhoffman@xanterra.com
Dylan Hoffman, UST Class A Operator		dhoffman@xanterra.com
Dylan Hoffman, UST Class B Operator		dhoffman@xanterra.com
Dylan Hoffman, UST Class B Operator		dhoffman@xanterra.com
Josiah Reese, UST Class A Operator		jreese@xanterra.com
Josiah Reese, UST Class A Operator		jreese@xanterra.com
Josiah Reese, UST Class B Global Operator		jreese@xanterra.com
Josiah Reese, UST Class B Global Operator		jreese@xanterra.com
Samuel Krasnobrod, UST Class A Operator		skrasnobrod@xanterra.com

<b>Tank Code</b>	06	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	04/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3492	<b>Spill Test Date</b>	05/12/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/16/2018	<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	09/17/2021	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/01/2022			<b>ATG Type</b>	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				
<b>Tank Code</b>	07	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	04/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve



<b>Tag Number</b>	3493	<b>Spill Test Date</b>	09/17/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	07/16/2018	<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	09/17/2021	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/01/2022			<b>ATG Type</b>	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				

**Facility Summary in Park County in the City of Gardiner**

**Location:** GARDINER SINCLAIR  
375 US Hwy 89 S  
Gardiner, MT 59030 Park

System Facility ID:60-15332

**Facility Code:** 32332  
**Last Inspected On:** 09/07/2022  
**Operating Permit Renewal Date:** 02/15/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** GBP Enterprises LLC (406) 223-7333 jg@ypss.com

**Operator Contact:** Jeff Guengerich;Paul Bauer (406) 223-7333;(406) 224-2620 jg@ypss.com;paul.r.bauer@gmail.com

**Owner/Operator:** GBP Enterprises LLC (406) 223-7333 jg@ypss.com  
 Jeff Guengerich, UST Class A Operator jg@ypss.com  
 Jeff Guengerich, UST Class B Global Operator jg@ypss.com  
 Paul Bauer, UST Class A Operator paul.r.bauer@gmail.com  
 Paul Bauer, UST Class B Global Operator paul.r.bauer@gmail.com

<b>Tank Code</b>	1	<b>Tank Age</b>	6	<b>Tank Installed Date</b>	08/12/2019	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5904	<b>Spill Test Date</b>	09/07/2022	<b>Piping Installed Date</b>	08/12/2019	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/07/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline, E10	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	20000	<b>ATG Test Date</b>	09/07/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/07/2022			<b>ATG Type</b>					
<b>Tank Code</b>	2	<b>Tank Age</b>	6	<b>Tank Installed Date</b>	08/12/2019	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5905	<b>Spill Test Date</b>	09/07/2022	<b>Piping Installed Date</b>	08/12/2019	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/07/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	10000	<b>ATG Test Date</b>	09/07/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/07/2022			<b>ATG Type</b>					

<b>Tank Code</b>	3	<b>Tank Age</b>	6	<b>Tank Installed Date</b>	08/12/2019	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5906	<b>Spill Test Date</b>	09/07/2022	<b>Piping Installed Date</b>	08/12/2019	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/07/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	09/07/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/07/2022			<b>ATG Type</b>					
<b>Tank Code</b>	4	<b>Tank Age</b>	6	<b>Tank Installed Date</b>	08/12/2019	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5907	<b>Spill Test Date</b>	09/07/2022	<b>Piping Installed Date</b>	08/12/2019	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/07/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	Yes
<b>Capacity</b>	10000	<b>ATG Test Date</b>	09/07/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/07/2022			<b>ATG Type</b>					
<b>Tank Code</b>	5	<b>Tank Age</b>	6	<b>Tank Installed Date</b>	08/12/2019	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	5908	<b>Spill Test Date</b>	09/07/2022	<b>Piping Installed Date</b>	08/12/2019	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	09/07/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	15000	<b>ATG Test Date</b>	09/07/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	09/07/2022			<b>ATG Type</b>					

**Facility Summary in Park County in the City of Gardiner**

**Location:** RANCH OFFICE  
558 Old Yellowstone Trl S  
Gardiner, MT 59030-9359 Park

System Facility ID:34-03402

**Facility Code:** 25977  
**Last Inspected On:** 06/05/2023  
**Operating Permit Renewal Date:** 09/03/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Church Universal and Triumphant Inc (406) 848-9200

**Operator Contact:** David Otis (406) 848-9043 daotis@tsl.org

**Owner/Operator:** Church Universal and Triumphant Inc (406) 848-9200

David Otis, UST Class A Operator  
David Otis, UST Class B Operator

daotis@tsl.org  
daotis@tsl.org

<b>Tank Code</b>	07	<b>Tank Age</b>	37	<b>Tank Installed Date</b>	10/21/1988	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1861	<b>Spill Test Date</b>	06/05/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	06/05/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/05/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	06/05/2023	<b>Line Tightness Test Date</b>	06/05/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/05/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	08	<b>Tank Age</b>	37	<b>Tank Installed Date</b>	10/21/1988	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1862	<b>Spill Test Date</b>	06/05/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	06/05/2023	<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Mechanical Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/05/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	MLLD Line Tightness Testing	<b>Vapor Recovery</b>	No
<b>Capacity</b>	20000	<b>ATG Test Date</b>	06/05/2023	<b>Line Tightness Test Date</b>	06/05/2023	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	06/05/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Park County in the City of Gardiner**

**Location:** TOWN STATION  
401 Scott St W  
Gardiner, MT 59030-0507 Park

System Facility ID:34-06531

**Facility Code:** 26030  
**Last Inspected On:** 10/10/2023  
**Operating Permit Renewal Date:** 03/03/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Gardiner Town Club Inc (406) 848-7322 townstation@outlook.com

**Operator Contact:** Wade Laubach (406) 223-0847 townstation@outlook.com

**Owner/Operator:** Gardiner Town Club Inc (406) 848-7322 townstation@outlook.com  
 Scott Kremer, UST Class B Global Operator patty@kremerbrothers.com;kremer4mt@wildblue.net  
 Scott Kremer, UST Class B Global Operator patty@kremerbrothers.com;kremer4mt@wildblue.net  
 Wade Laubach, UST Class A Operator townstation@outlook.com  
 Wade Laubach, UST Class A Operator townstation@outlook.com

<b>Tank Code</b>	01	<b>Tank Age</b>	41	<b>Tank Installed Date</b>	04/16/1984	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3189	<b>Spill Test Date</b>		<b>Piping Installed Date</b>	11/12/2019	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/10/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	01/04/2024	<b>Tank/Piping CP Test Date</b>	10/10/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	01/04/2024	<b>Line Tightness Test Date</b>	10/03/2017	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/10/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	02	<b>Tank Age</b>	41	<b>Tank Installed Date</b>	04/16/1984	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3190	<b>Spill Test Date</b>	10/10/2023	<b>Piping Installed Date</b>	11/12/2019	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/10/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	01/04/2024	<b>Tank/Piping CP Test Date</b>	10/10/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	01/04/2024	<b>Line Tightness Test Date</b>	10/03/2017	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	10/10/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	03	<b>Tank Age</b>	41	<b>Tank Installed Date</b>	04/16/1984	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3191	<b>Spill Test Date</b>	10/10/2023	<b>Piping Installed Date</b>	11/12/2019	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/10/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	01/04/2024	<b>Tank/Piping CP Test Date</b>	10/10/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	01/04/2024	<b>Line Tightness Test Date</b>	10/03/2017	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/10/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	04	<b>Tank Age</b>	41	<b>Tank Installed Date</b>	04/16/1984	<b>Tank Material</b>	Bare Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3192	<b>Spill Test Date</b>	10/10/2023	<b>Piping Installed Date</b>	11/12/2019	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	10/10/2023	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Impressed Current
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	01/04/2024	<b>Tank/Piping CP Test Date</b>	10/10/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	01/04/2024	<b>Line Tightness Test Date</b>	10/03/2017	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	10/10/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				

**Facility Summary in Park County in the City of Livingston**

**Location:** CASEYS CORNER 4  
2050 S Park  
Livingston, MT 59047-9133 Park

System Facility ID:34-09906

**Facility Code:** 26096  
**Last Inspected On:** 04/08/2025  
**Operating Permit Renewal Date:** 07/22/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Superpumper Inc (701) 852-1194

**Operator Contact:** Vern Patterson;Parkland USA Corporation (701) 720-6649;(701) 852-1194 vern.patterson@parklandusa.com;nancy.coen@parklandusa.com

**Owner/Operator:** Superpumper Inc (701) 852-1194

Scott Trullinger, UST Class B Operator  
Vern Patterson, UST Class A Operator  
Vern Patterson, UST Class B Operator

nancy.coen@parklandusa.com  
nancy.coen@parklandusa.com  
nancy.coen@parklandusa.com

<b>Tank Code</b>	05	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	05/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	2033	<b>Spill Test Date</b>	04/16/2021	<b>Piping Installed Date</b>	02/20/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/18/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/02/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	01/18/2023	<b>Line Tightness Test Date</b>	02/23/2016	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/18/2023			<b>ATG Type</b>	Franklin Fueling Systems/EVO 6000				
<b>Tank Code</b>	06	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	05/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	2034	<b>Spill Test Date</b>	04/16/2021	<b>Piping Installed Date</b>	02/20/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/18/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/02/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	01/18/2023	<b>Line Tightness Test Date</b>	02/23/2016	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	01/18/2023			<b>ATG Type</b>	Franklin Fueling Systems/EVO 6000				
<b>Tank Code</b>	07	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	05/01/1998	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	2035	<b>Spill Test Date</b>	03/18/2021	<b>Piping Installed Date</b>	02/20/2017	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	03/18/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	05/02/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	01/18/2023	<b>Line Tightness Test Date</b>	02/23/2016	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	01/18/2023			<b>ATG Type</b>	Franklin Fueling Systems/EVO 6000				



**Facility Summary in Park County in the City of Livingston**

**Location:** CITY COUNTY COMPLEX  
414 E Callender St  
Livingston, MT 59047-2700 Park

System Facility ID:34-10573

**Facility Code:** 26105  
**Last Inspected On:** 09/07/2022  
**Operating Permit Renewal Date:** 10/01/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Park County Shop - City of Livingston (406) 222-4106

**Operator Contact:** Kelly Johnson (406) 222-4141 maintenance@parkcounty.org

**Owner/Operator:** Park County Shop - City of Livingston (406) 222-4106

Kelly Johnson, UST Class A Operator	maintenance@parkcounty.org
Kelly Johnson, UST Class A Operator	maintenance@parkcounty.org
Kelly Johnson, UST Class B Global Operator	maintenance@parkcounty.org
Kelly Johnson, UST Class B Global Operator	maintenance@parkcounty.org

<b>Tank Code</b>	02	<b>Tank Age</b>	30	<b>Tank Installed Date</b>	11/01/1995	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1783	<b>Spill Test Date</b>	09/07/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Continuous Interstitial Monitoring	<b>Piping Type</b>	U.S. Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Primary Pipe Detection</b>	3-Year Line Tightness Test	<b>Vapor Recovery</b>	No
<b>Capacity</b>	3000	<b>ATG Test Date</b>	09/07/2022	<b>Line Tightness Test Date</b>	09/28/2022	<b>Secondary Tank Leak Detection</b>	Automatic Tank Gauging 0.1	<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	09/07/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

### Facility Summary in Park County in the City of Livingston

**Location:** TJS GAS N CONVENIENCE  
204 E Park St  
Livingston, MT 59047-2713 Park

System Facility ID:34-13736

**Facility Code:** 26167  
**Last Inspected On:** 05/05/2023  
**Operating Permit Renewal Date:** 09/03/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** TJs Gas N Convenience (406) 222-9720

**Operator Contact:** Becky Thomas;William Woods (406) 222-9720 becalicious@yahoo.com;wjwoods10@gmail.com

**Owner/Operator:** TJs Gas N Convenience (406) 222-9720

Becky Thomas, UST Class A Operator

becalicious@yahoo.com

Becky Thomas, UST Class B Global Operator

becalicious@yahoo.com

William Woods, UST Class A Operator

wjwoods10@gmail.com

William Woods, UST Class B Operator

wjwoods10@gmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	05/01/1996	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3371	<b>Spill Test Date</b>	05/05/2023	<b>Piping Installed Date</b>	06/24/2014	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	01/12/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	01/22/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	05/05/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/05/2023			<b>ATG Type</b>	Veeder Root/TLS-300				
<b>Tank Code</b>	02	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	05/01/1996	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	3372	<b>Spill Test Date</b>	05/05/2023	<b>Piping Installed Date</b>	06/24/2014	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	01/12/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	01/22/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	05/05/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/05/2023			<b>ATG Type</b>	Veeder Root/TLS-300				

**Facility Summary in Park County in the City of Livingston**

**Location:** TOWN PUMP INC LIVINGSTON 2  
716 E Park St  
Livingston, MT 59047 Park

System Facility ID:34-08713

**Facility Code:** 26078  
**Last Inspected On:** 03/25/2025  
**Operating Permit Renewal Date:** 08/30/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Livingston 2 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

**Operator Contact:** Trent Biggers

**Trentb@townpump.com**

**Owner/Operator:** Livingston 2 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator  
Trent Biggers, UST Class B Global Operator

Trentb@townpump.com  
Trentb@townpump.com  
Trentb@townpump.com  
Trentb@townpump.com

<b>Tank Code</b>	03	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2575	<b>Spill Test Date</b>	08/02/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	05/13/2021	<b>Sump Tightness Test Date</b>	08/15/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/15/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	08/15/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/02/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	04	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2576	<b>Spill Test Date</b>	05/13/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	05/13/2021	<b>Sump Tightness Test Date</b>	08/15/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/15/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No

<b>Capacity</b>	12000	<b>ATG Test Date</b>	08/15/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/02/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	05	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2577	<b>Spill Test Date</b>	08/02/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	05/13/2021	<b>Sump Tightness Test Date</b>	08/15/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	08/15/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	08/15/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/02/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	06	<b>Tank Age</b>	29	<b>Tank Installed Date</b>	09/01/1996	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2578	<b>Spill Test Date</b>	08/02/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>	05/13/2021	<b>Sump Tightness Test Date</b>	08/15/2022	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/15/2022	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	08/15/2022	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	Yes
		<b>Overfill Test Date</b>	08/02/2021			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				

**Facility Summary in Park County in the City of Livingston**

**Location:** TOWN PUMP INC LIVINGSTON 3  
2200 Park St S  
Livingston, MT 59047 Park

System Facility ID:34-13409

**Facility Code:** 26162  
**Last Inspected On:** 03/25/2025  
**Operating Permit Renewal Date:** 08/02/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Livingston 3 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

**Operator Contact:** Trent Biggers

**Trentb@townpump.com**

**Owner/Operator:** Livingston 3 Town Pump LLC

**(406) 497-6700**

**environmental@townpump.com**

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator  
Trent Biggers, UST Class B Global Operator

Trentb@townpump.com  
Trentb@townpump.com  
Trentb@townpump.com  
Trentb@townpump.com

<b>Tank Code</b>	01	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	05/20/1994	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2579	<b>Spill Test Date</b>	11/04/2024	<b>Piping Installed Date</b>	04/20/2011	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/12/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	12/30/2019	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/12/2021	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	02	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	05/20/1994	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2580	<b>Spill Test Date</b>	05/12/2021	<b>Piping Installed Date</b>	04/20/2011	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/12/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	12/30/2019	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No

<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/12/2021	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	03	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	05/01/1994	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2581	<b>Spill Test Date</b>	07/19/2021	<b>Piping Installed Date</b>	04/20/2011	<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/12/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	12/30/2019	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/12/2021	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	04	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	05/01/1994	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2582	<b>Spill Test Date</b>	07/19/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/12/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	12/30/2019	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/12/2021	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	05	<b>Tank Age</b>	31	<b>Tank Installed Date</b>	05/01/1994	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	2583	<b>Spill Test Date</b>	07/19/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/12/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible

<b>Product</b>	Diesel	<b>PLLD Test Date</b>	12/30/2019	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/12/2021	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	06	<b>Tank Age</b>	24	<b>Tank Installed Date</b>	10/01/2001	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4377	<b>Spill Test Date</b>	07/19/2021	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/12/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	12/30/2019	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	05/12/2021	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	07	<b>Tank Age</b>	24	<b>Tank Installed Date</b>	10/01/2001	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4378	<b>Spill Test Date</b>	11/04/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/12/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	12/30/2019	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	05/12/2021	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450;Gilbarco-Veeder Root/TLS-450PLUS				
<b>Tank Code</b>	08	<b>Tank Age</b>	24	<b>Tank Installed Date</b>	10/01/2001	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Ball Float Valve
<b>Tag Number</b>	4379	<b>Spill Test Date</b>	11/04/2024	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No

<b>Tank Status</b>	<b>Currently in Use</b>	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	05/12/2021	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	12/30/2019	<b>Tank/Piping CP Test Date</b>		<b>Primary Tank Leak Detection</b>	Statistical Inventory Reconciliation	<b>Primary Pipe Detection</b>	Statistical Inventory Reconciliation	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	05/12/2021	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>	Continuous Interstitial Monitoring	<b>Secondary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-450PLUS				



**Facility Summary in Park County in the City of Livingston**

**Location:** YELLOWSTONE TRAVEL PLAZA  
1226 US Hwy 10 W  
Livingston, MT 59047-9004 Park

System Facility ID:34-11200

**Facility Code:** 26137  
**Last Inspected On:** 11/16/2022  
**Operating Permit Renewal Date:** 03/25/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** LIVINGSTON 10W LLC

**MOTIBALYAN@GMAIL.COM**

**Operator Contact:** Moti Balyan;Yellowstone Travel Plaza

**(406) 222-6180**

**MOTIBALYAN@GMAIL.COM;gchana26@gmail.com**

**Owner/Operator:** LIVINGSTON 10W LLC

MOTIBALYAN@GMAIL.COM

Moti Balyan, UST Class A Operator

gchana26@gmail.com

Moti Balyan, UST Class B Operator

gchana26@gmail.com

<b>Tank Code</b>	01	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	01/01/1989	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2313	<b>Spill Test Date</b>	08/26/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/16/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	8000	<b>ATG Test Date</b>	07/21/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/26/2022			<b>ATG Type</b>	Incon/TS-1001				
<b>Tank Code</b>	02	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	01/01/1989	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2314	<b>Spill Test Date</b>	08/26/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/16/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	07/21/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/26/2022			<b>ATG Type</b>	Incon/TS-1001				
<b>Tank Code</b>	03	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	01/01/1989	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2315	<b>Spill Test Date</b>	08/26/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No

<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/16/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	07/21/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/26/2022			<b>ATG Type</b>	Incon/TS-1001				
<b>Tank Code</b>	04	<b>Tank Age</b>	36	<b>Tank Installed Date</b>	01/01/1989	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	2316	<b>Spill Test Date</b>	08/26/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/16/2022	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	07/21/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/26/2022			<b>ATG Type</b>	Incon/TS-1001				

**Facility Summary in Park County in the City of Livingston**

**Location:** ZIP TRIP 47  
101 Centennial Dr  
Livingston, MT 59047-9155 Park

System Facility ID:34-11741

**Facility Code:** 26145  
**Last Inspected On:** 09/03/2024  
**Operating Permit Renewal Date:** 11/08/2027

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

**Operator Contact:** Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

**Owner/Operator:** CHS Inc Spokane Valley (509) 535-7701 Donald.Widdicombe@chsinc.com

- |                                    |                           |
|------------------------------------|---------------------------|
| Jim Alford, UST Class A Operator   | jim.alford@chsinc.com     |
| Jim Alford, UST Class A Operator   | jim.alford@chsinc.com     |
| Jim Alford, UST Class B Operator   | jim.alford@chsinc.com     |
| Jim Alford, UST Class B Operator   | jim.alford@chsinc.com     |
| Luci Tuttle, UST Class B Operator  | Lucinda.Tuttle@chsinc.com |
| Sean Hurley, UST Class A Operator  | sean.hurley@chsinc.com    |
| Sean Hurley, UST Class A Operator  | sean.hurley@chsinc.com    |
| Travis Weber, UST Class B Operator | travis.weber3@chsinc.com  |

<b>Tank Code</b>	01	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	09/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	562	<b>Spill Test Date</b>	08/15/2024	<b>Piping Installed Date</b>	06/25/2018	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/15/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/06/2024	<b>Tank/Piping CP Test Date</b>	08/15/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/06/2024	<b>Line Tightness Test Date</b>	01/04/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/15/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	02	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	09/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	563	<b>Spill Test Date</b>	08/15/2024	<b>Piping Installed Date</b>	06/25/2018	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/15/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic

<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	08/06/2024	<b>Tank/Piping CP Test Date</b>	08/15/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/06/2024	<b>Line Tightness Test Date</b>	01/04/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/15/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	03	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	09/01/1990	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	564	<b>Spill Test Date</b>	08/15/2024	<b>Piping Installed Date</b>	06/25/2018	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>	08/15/2024	<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	08/06/2024	<b>Tank/Piping CP Test Date</b>	08/15/2024	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	10000	<b>ATG Test Date</b>	08/06/2024	<b>Line Tightness Test Date</b>	01/04/2021	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	08/15/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Park County in the City of Wilsall**

**Location:** PARK FARMERS COOP  
114 S Elliot  
Wilsall, MT 59086 Park

System Facility ID:34-06686

**Facility Code:** 26034  
**Last Inspected On:** 04/20/2022  
**Operating Permit Renewal Date:** 05/24/2025

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Park Farmers Coop (406) 578-2543

**Operator Contact:** Don Scott pfcoop@aol.com

**Owner/Operator:** Park Farmers Coop (406) 578-2543

Don Scott, UST Class A Operator	pfcoop@aol.com
Don Scott, UST Class A Operator	pfcoop@aol.com
Don Scott, UST Class B Operator	pfcoop@aol.com
Don Scott, UST Class B Operator	pfcoop@aol.com
Donald Scott, UST Class B Operator	pfcoop@aol.com
Donald Scott, UST Class B Operator	pfcoop@aol.com

<b>Tank Code</b>	13	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	07/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1784	<b>Spill Test Date</b>	06/16/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/20/2022	<b>Tank/Piping CP Test Date</b>	04/26/2010	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	04/20/2022	<b>Line Tightness Test Date</b>	02/05/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/20/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	14	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	07/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1785	<b>Spill Test Date</b>	06/16/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel, Dyed	<b>PLLD Test Date</b>	04/20/2022	<b>Tank/Piping CP Test Date</b>	04/26/2010	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	12000	<b>ATG Test Date</b>	04/20/2022	<b>Line Tightness Test Date</b>	02/06/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No

		<b>Overfill Test Date</b>	04/20/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	15	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	07/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1786	<b>Spill Test Date</b>	06/16/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	04/20/2022	<b>Tank/Piping CP Test Date</b>	04/26/2010	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	04/20/2022	<b>Line Tightness Test Date</b>	02/05/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/20/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	16	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	07/01/1993	<b>Tank Material</b>	Fiberglass Reinforced Plastic	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	Flapper Valve
<b>Tag Number</b>	1787	<b>Spill Test Date</b>	06/16/2022	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	04/20/2022	<b>Tank/Piping CP Test Date</b>	04/26/2010	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	04/20/2022	<b>Line Tightness Test Date</b>	02/07/2022	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	04/20/2022			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				