

Facility Summary in Phillips County in the City of Malta

Location: EQUITY COOP ASSOCIATION MALTA
428 S 1st St E
Malta, MT 59538 Phillips

System Facility ID:36-10706

Facility Code: 26305
Last Inspected On: 09/24/2025
Operating Permit Renewal Date: 10/30/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Equity Coop Association Malta (406) 654-2240

Operator Contact: Angela Anderson;Dale Kaasa;Virgil Abrahamson dareangi@yahoo.com;equityco-op@mtintouch.net

Owner/Operator: Equity Coop Association Malta (406) 654-2240

Angela Anderson, UST Class A Operator

dareangi@yahoo.com

Angela Anderson, UST Class B Operator

dareangi@yahoo.com

Dale Kaasa, UST Class A Operator

equityco-op@mtintouch.net

Dale Kaasa, UST Class B Operator

equityco-op@mtintouch.net

Virgil Abrahamson, UST Class A Operator

equityco-op@mtintouch.net

Virgil Abrahamson, UST Class B Operator

equityco-op@mtintouch.net

Tank Code	S7	Tank Age	32	Tank Installed Date	12/01/1994	Tank Material	Unknown	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	5421	Spill Test Date		Piping Installed Date	<th>Tank Construction</th> <td></td> <th>Piping Construction</th> <td>Double Walled</td> <th>AST</th>	Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2022	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	3200	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date			<th>ATG Type</th> <td></td> <td></td> <td></td> <td>No</td>	ATG Type				No
Tank Code	S3	Tank Age	32	Tank Installed Date	12/09/1994	Tank Material	Unknown	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	860	Spill Test Date		Piping Installed Date	07/20/2007	Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2022	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	<th>Primary Tank Leak Detection</th> <td></td> <th>Primary Pipe Detection</th> <td>Continuous Interstitial Monitoring</td> <th>Vapor Recovery</th>	Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery

Capacity	25600	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S4	Tank Age	32	Tank Installed Date	12/09/1994	Tank Material	Unknown	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	861	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2022	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	17000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S5	Tank Age	32	Tank Installed Date	12/09/1994	Tank Material	Unknown	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	862	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2022	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S6	Tank Age	32	Tank Installed Date	12/09/1994	Tank Material	Unknown	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	863	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/21/2022	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	9900	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Phillips County in the City of Malta

Location: EZZIES BULK STORAGE
47259 US Hwy 2 E
Malta, MT 59538 Phillips

System Facility ID: 60-15156

Facility Code: 30897
Last Inspected On: 10/13/2025
Operating Permit Renewal Date: 10/13/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com

Operator Contact: Clayton Jesson;Conor Moran;Ezzies Wholesale Inc (406) 654-2331 clay@ezzies.com;conor@ezzies.com;bill@ezzies.com

Owner/Operator: Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com

Clayton Jesson, UST Class A Operator
Conor Moran, UST Class A Operator
Derek Oshio, UST Class B Operator
clay@ezzies.com
bill@ezzies.com
loren@ezzies.com

Tank Code	01	Tank Age	16	Tank Installed Date	09/27/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5246	Spill Test Date	11/13/2019	Piping Installed Date	09/27/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	07/07/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/07/2025			ATG Type	Incon/TS-5000				
Tank Code	02	Tank Age	16	Tank Installed Date	09/27/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5247	Spill Test Date	11/13/2019	Piping Installed Date	09/27/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/07/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/07/2025			ATG Type	Incon/TS-5000				

Tank Code	03	Tank Age	16	Tank Installed Date	09/27/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5248	Spill Test Date	11/13/2019	Piping Installed Date	09/27/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/07/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/07/2025			ATG Type	Incon/TS-5000				
Tank Code	04	Tank Age	16	Tank Installed Date	09/27/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5249	Spill Test Date	11/13/2019	Piping Installed Date	09/27/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/07/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/07/2025			ATG Type	Incon/TS-5000				
Tank Code	05	Tank Age	16	Tank Installed Date	09/27/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5250	Spill Test Date	11/13/2019	Piping Installed Date	09/27/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/07/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/07/2025			ATG Type	Incon/TS-5000				
Tank Code	06	Tank Age	16	Tank Installed Date	09/27/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5251	Spill Test Date	11/13/2019	Piping Installed Date	09/27/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLL D Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/07/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/07/2025			ATG Type	Incon/TS-5000				
Tank Code	07	Tank Age	16	Tank Installed Date	09/27/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5252	Spill Test Date	01/10/2023	Piping Installed Date	09/27/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/07/2025	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Hazardous Substance	PLL D Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/07/2025	Line Tightness Test Date	09/21/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	07/07/2025			ATG Type	Incon/TS-5000				
Tank Code	08	Tank Age	16	Tank Installed Date	09/27/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5253	Spill Test Date	11/13/2019	Piping Installed Date	09/27/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLL D Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	07/07/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/07/2025			ATG Type	Incon/TS-5000				
Tank Code	09	Tank Age	16	Tank Installed Date	09/27/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5254	Spill Test Date	11/13/2019	Piping Installed Date	09/27/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLL D Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	07/07/2025	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/07/2025			ATG Type	Incon/TS-5000				

Facility Summary in Phillips County in the City of Malta

Location: EZZIES WHOLESALE US 2 E
US Hwy 2 E
Malta, MT 59538 Phillips

System Facility ID:36-11372

Facility Code: 26310
Last Inspected On: 05/05/2025
Operating Permit Renewal Date: 09/15/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com

Operator Contact: Conor Moran;Ezzies Wholesale Inc (406) 654-2331 conor@ezzies.com;bill@ezzies.com

Owner/Operator: Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com

Clayton Jesson, UST Class B Operator
Conor Moran, UST Class A Operator
bill@ezzies.com
bill@ezzies.com

Tank Code	01	Tank Age	36	Tank Installed Date	01/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	886	Spill Test Date	07/08/2024	Piping Installed Date	07/23/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/05/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date	07/08/2024	Tank/Piping CP Test Date	05/05/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/08/2024	Line Tightness Test Date	03/18/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/08/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	36	Tank Installed Date	01/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	887	Spill Test Date	07/08/2024	Piping Installed Date	07/23/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/05/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	07/08/2024	Tank/Piping CP Test Date	05/05/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/08/2024	Line Tightness Test Date	03/18/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/08/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	36	Tank Installed Date	01/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	888	Spill Test Date	07/08/2024	Piping Installed Date	07/23/2007	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/05/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	07/08/2024	Tank/Piping CP Test Date	05/05/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/08/2024	Line Tightness Test Date	03/18/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/08/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	36	Tank Installed Date	01/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	889	Spill Test Date	07/08/2024	Piping Installed Date	07/23/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/05/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date	07/08/2024	Tank/Piping CP Test Date	05/05/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/08/2024	Line Tightness Test Date	03/18/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/08/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	36	Tank Installed Date	01/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	890	Spill Test Date	07/08/2024	Piping Installed Date	07/23/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/05/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	07/08/2024	Tank/Piping CP Test Date	05/05/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/08/2024	Line Tightness Test Date	03/18/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/08/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	36	Tank Installed Date	01/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	891	Spill Test Date	07/08/2024	Piping Installed Date	07/23/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/05/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	07/08/2024	Tank/Piping CP Test Date	05/05/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	6000	ATG Test Date	07/08/2024	Line Tightness Test Date	03/18/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/08/2024			ATG Type		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC			

Facility Summary in Phillips County in the City of Malta

Location: MALTA CONVENIENCE STORE
3 N 1st St E
Malta, MT 59538 Phillips

System Facility ID:36-02371

Facility Code: 26213
Last Inspected On: 05/05/2025
Operating Permit Renewal Date: 10/31/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Horizon Resources Cooperative

(701) 572-2172

kquinnel@horizonresources.coop

Operator Contact: Novalene Nelson

NNelson@horizonresources.coop

Owner/Operator: Horizon Resources Cooperative

(701) 572-2172

kquinnel@horizonresources.coop

Novalene Nelson, UST Class A Operator

NNelson@horizonresources.coop

Novalene Nelson, UST Class B Global Operator

NNelson@horizonresources.coop

Tank Code	02	Tank Age	40	Tank Installed Date	10/29/1986	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3287	Spill Test Date	05/05/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date	05/05/2025	Tank/Piping CP Test Date	05/05/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/05/2025	Line Tightness Test Date	05/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/05/2025			ATG Type	Veeder Root/TLS-300				
Tank Code	03	Tank Age	40	Tank Installed Date	10/29/1986	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3288	Spill Test Date	05/05/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	05/05/2025	Tank/Piping CP Test Date	05/05/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/05/2025	Line Tightness Test Date	05/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/05/2025			ATG Type	Veeder Root/TLS-300				

Tank Code	04	Tank Age	28	Tank Installed Date	10/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3289	Spill Test Date	05/05/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/05/2025	Tank/Piping CP Test Date	05/05/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/05/2025	Line Tightness Test Date	05/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/05/2025			ATG Type	Veeder Root/TLS-300				
Tank Code	05	Tank Age	28	Tank Installed Date	10/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3290	Spill Test Date	05/05/2025	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/12/2022	Tank/Piping CP Test Date	05/05/2025	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/05/2025	Line Tightness Test Date	05/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/05/2025			ATG Type	Veeder Root/TLS-300				

Facility Summary in Phillips County in the City of Malta

Location: PHILLIPS COUNTY MEDICAL CENTER
311 S 8th Ave E
Malta, MT 59538 Phillips

System Facility ID: 56-14104

Facility Code: 30747
Last Inspected On: 07/07/2025
Operating Permit Renewal Date: 10/05/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Phillips County Medical Center

bwinkel@hlrc.us

Operator Contact: Beu Winkel;Richard Ferrell;Thomas Miller

(406) 654-1190;(406) 683-2175

bwinkel@hlrc.us;PCHM@pchospital.us

Owner/Operator: Phillips County Medical Center

bwinkel@hlrc.us

Beu Winkel, UST Class A Operator

bwinkel@hlrc.us

Beu Winkel, UST Class B Operator

bwinkel@hlrc.us

Richard Ferrell, UST Class A Operator

PCHM@pchospital.us

Richard Ferrell, UST Class B Operator

PCHM@pchospital.us

Thomas Miller, UST Class A Operator

PCHM@pchospital.us

Thomas Miller, UST Class B Operator

PCHM@pchospital.us

Tank Code	01	Tank Age	22	Tank Installed Date	03/02/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4884	Spill Test Date	07/12/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	1000	ATG Test Date	07/07/2025	Line Tightness Test Date	07/07/2025 <th>Secondary Tank Leak Detection</th> <td></td> <th>Secondary Pipe Detection</th> <td>Continuous Interstitial Monitoring</td> <th>Energy Act</th> <td>No</td>	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date			<th>ATG Type</th> <td>Gilbarco-Veeder Root/TLS-300</td> <td></td> <td></td> <td></td> <td></td>	ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	02	Tank Age	22	Tank Installed Date	03/02/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4885	Spill Test Date	07/07/2025	Piping Installed Date	<th>Tank Construction</th> <td>Double-Walled</td> <th>Piping Construction</th> <td>Double Walled</td> <th>AST</th> <td>No</td>	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	<th>Catastrophic L.D Type 3.0</th> <td>Continuous Interstitial Monitoring</td> <th>Piping Type</th> <td>Pressurized</td> <th>CP Met Types</th> <td>Non-corrodible</td>	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel, Dyed	PLL D Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	1000	ATG Test Date	07/07/2025	Line Tightness Test Date	07/07/2025	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/07/2025			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Phillips County in the City of Malta

Location: WESTSIDE SELF SERVICE INC
200 US Hwy 2
Malta, MT 59538 Phillips

System Facility ID:36-06668

Facility Code: 26274
Last Inspected On: 04/15/2025
Operating Permit Renewal Date: 07/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Robert Ereaux (406) 654-7070

Operator Contact: Darla Niebur;Westside Self Service Inc;Ron Welch;Westside Self Service Inc (800) 892-6874

dartomrj@mtintouch.net;wssklc@mtintouch.net;katherynwssklc@gmail.com;wssklc@mtintouch.net

Owner/Operator: Robert Ereaux (406) 654-7070

Owner/Operator: Robert N Ereaux (406) 654-7070

Darla Niebur, UST Class A Operator

wssklc@mtintouch.net

Darla Niebur, UST Class B Operator

wssklc@mtintouch.net

Ron Welch, UST Class A Operator

wssklc@mtintouch.net

Ron Welch, UST Class B Operator

wssklc@mtintouch.net

Tank Code	06	Tank Age	20	Tank Installed Date	04/25/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5069	Spill Test Date	10/04/2021	Piping Installed Date	04/25/2006	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/30/2022	Tank/Piping CP Test Date	10/11/2006	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	05/19/2023	Line Tightness Test Date	12/17/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/19/2023			ATG Type	Franklin Fueling Systems/EVO 600				
Tank Code	07	Tank Age	20	Tank Installed Date	04/25/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5070	Spill Test Date	10/04/2021	Piping Installed Date	04/25/2006	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/27/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/30/2022	Tank/Piping CP Test Date	10/12/2006	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	05/19/2023	Line Tightness Test Date	01/27/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	05/19/2023			ATG Type	Franklin Fueling Systems/EVO 600			
Tank Code	08	Tank Age	20	Tank Installed Date	04/25/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	5071	Spill Test Date	10/04/2021	Piping Installed Date	04/25/2006	Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date	03/30/2022	Tank/Piping CP Test Date	10/13/2006	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery
Capacity	15000	ATG Test Date	05/19/2023	Line Tightness Test Date	12/17/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act
		Overfill Test Date	05/19/2023			ATG Type	Franklin Fueling Systems/EVO 600			
Tank Code	09	Tank Age	20	Tank Installed Date	04/25/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	5075	Spill Test Date	11/26/2021	Piping Installed Date	04/25/2006	Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date	01/27/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date	03/30/2022	Tank/Piping CP Test Date	10/14/2006	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery
Capacity	5000	ATG Test Date	05/19/2023	Line Tightness Test Date	01/27/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act
		Overfill Test Date	05/19/2023			ATG Type	Franklin Fueling Systems/EVO 600			
Tank Code	10	Tank Age	20	Tank Installed Date	04/25/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	5076	Spill Test Date	10/04/2021	Piping Installed Date	04/25/2006	Tank Construction		Piping Construction	Double Walled	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date	03/30/2022	Tank/Piping CP Test Date	10/20/2006	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery
Capacity	5000	ATG Test Date	05/19/2023	Line Tightness Test Date	12/17/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act
		Overfill Test Date	05/19/2023			ATG Type	Franklin Fueling Systems/EVO 600			
Tank Code	11	Tank Age	20	Tank Installed Date	04/25/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types
Tag Number	5077	Spill Test Date	11/26/2021	Piping Installed Date	04/25/2006	Tank Construction		Piping Construction	Double Walled	AST

Tank Status	Currently in Use	MLLD Test Date	01/27/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/30/2022	Tank/Piping CP Test Date	11/27/2006	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/19/2023	Line Tightness Test Date	01/27/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/19/2023			ATG Type	Franklin Fueling Systems/EVO 600				

Facility Summary in Phillips County in the City of Saco

Location: EZZIES WHOLESALE
100 Hwy 243
Saco, MT 59261 Phillips

System Facility ID: 60-15270

Facility Code: 30982
Last Inspected On: 03/17/2025
Operating Permit Renewal Date: 07/05/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com

Operator Contact: Conor Moran; Ezzies Wholesale Inc (406) 654-2331 conor@ezzies.com; bill@ezzies.com

Owner/Operator: Ezzies Wholesale Inc (406) 654-2331 bill@ezzies.com

Clayton Jesson, UST Class B Operator
Conor Moran, UST Class A Operator
clay@ezzies.com
bill@ezzies.com

Tank Code	S1	Tank Age	10	Tank Installed Date	01/20/2016	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5626	Spill Test Date		Piping Installed Date	01/20/2016	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/17/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/09/2024	Line Tightness Test Date	03/27/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	S2	Tank Age	10	Tank Installed Date	01/20/2016	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5627	Spill Test Date		Piping Installed Date	01/20/2016	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/17/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	07/09/2024	Line Tightness Test Date	03/27/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	S3	Tank Age	10	Tank Installed Date	01/20/2016	Tank Material	Aboveground Tank	Piping Material	Flexible Plastic	Overfill Types	

Tag Number	5628	Spill Test Date		Piping Installed Date	01/20/2016	Tank Construction	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/17/2025	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	2000	ATG Test Date	07/09/2024	Line Tightness Test Date	03/27/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act
		Overfill Test Date				ATG Type				Yes

Facility Summary in Phillips County in the City of Whitewater

Location: EZZIES WHOLESALE INC
Main St
Whitewater, MT 59544 Phillips

System Facility ID:36-04082

Facility Code: 26227
Last Inspected On: 10/09/2023
Operating Permit Renewal Date: 10/09/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Ezzies Wholesale, Inc. (406) 654-2331 dave@ezzies.com

Operator Contact: Conor Moran;Ezzies Wholesale Inc (406) 654-2331 conor@ezzies.com;bill@ezzies.com

Owner/Operator: Ezzies Wholesale, Inc. (406) 654-2331 dave@ezzies.com

Clayton Jesson, UST Class B Operator
Conor Moran, UST Class A Operator bill@ezzies.com
bill@ezzies.com

Tank Code	S5	Tank Age	28	Tank Installed Date	10/13/1998	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	3599	Spill Test Date		Piping Installed Date	09/10/2007	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	10/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S6	Tank Age	28	Tank Installed Date	10/13/1998	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	3600	Spill Test Date		Piping Installed Date	09/10/2007	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	10/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S7	Tank Age	28	Tank Installed Date	10/13/1998	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	

Tag Number	3601	Spill Test Date		Piping Installed Date	09/10/2007	Tank Construction	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	9000	ATG Test Date	10/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date				ATG Type				No
Tank Code	S8	Tank Age	28	Tank Installed Date	10/13/1998	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types
Tag Number	3602	Spill Test Date		Piping Installed Date	09/10/2007	Tank Construction	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery
Capacity	9000	ATG Test Date	10/09/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date				ATG Type				No

Facility Summary in Phillips County in the City of Zortman

Location: ZORTMAN GARAGE AND MOTEL
302 Main St
Zortman, MT 59546-0302 Phillips

System Facility ID:36-11549

Facility Code: 26314
Last Inspected On: 09/02/2025
Operating Permit Renewal Date: 11/27/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: John Kalal;Zortman Garage and Motel

(406) 673-3160

Operator Contact: Candy Kalal;Deirdre Hanners

zortman76@mtintouch.net

Owner/Operator: John Kalal

(406) 673-3160

Owner/Operator: Zortman Garage and Motel

(406) 673-3160

Candy Kalal, UST Class A Operator

zortman76@mtintouch.net

Candy Kalal, UST Class B Operator

zortman76@mtintouch.net

Deirdre Hanners, UST Class A Operator

Tank Code	03	Tank Age	27	Tank Installed Date	06/17/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4020	Spill Test Date	09/02/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/18/2010	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/02/2025			ATG Type					
Tank Code	04	Tank Age	27	Tank Installed Date	06/17/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4021	Spill Test Date	09/02/2025	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/18/2010	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/02/2025			ATG Type					