

**Facility Summary in Powder River County in the City of Biddle**

**Location:** CROSS RANCH MERC  
222 MT Hwy 59  
Biddle, MT 59314 Powder River

System Facility ID:38-01493

**Facility Code:** 26537  
**Last Inspected On:** 03/07/2023  
**Operating Permit Renewal Date:** 08/10/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Nathan Rumph

**Operator Contact:** Connie Rumph

**(406) 427-5447**

**crossranchmerc@gmail.com**

**Owner/Operator:** Nathan Rumph

Connie Rumph, UST Class A Operator  
Connie Rumph, UST Class B Operator

crossranchmerc@gmail.com  
crossranchmerc@gmail.com

<b>Tank Code</b>	07	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	09/11/1990	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	783	<b>Spill Test Date</b>	03/07/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/07/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	03/07/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/07/2023			<b>ATG Type</b>	EBW/Auto Stik II				
<b>Tank Code</b>	08	<b>Tank Age</b>	35	<b>Tank Installed Date</b>	09/11/1990	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Fiberglass Reinforced Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	784	<b>Spill Test Date</b>	03/07/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/07/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	03/07/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/07/2023			<b>ATG Type</b>	EBW/Auto Stik II				

**Facility Summary in Powder River County in the City of Broadus**

**Location:** ALDERMAN OIL CO  
601 S Park Ave  
Broadus, MT 59317 Powder River

System Facility ID:38-03951

**Facility Code:** 26549  
**Last Inspected On:** 03/07/2023  
**Operating Permit Renewal Date:** 04/08/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Alderman Oil Co;Gary Alderman

**Operator Contact:** Gary Alderman;Theresa Alderman

**(406) 436-2898**

**galderman@rangeweb.net**

**Owner/Operator:** Alderman Oil Co

**Owner/Operator:** Gary Alderman

Gary Alderman, UST Class A Operator

galderman@rangeweb.net

Gary Alderman, UST Class A Operator

galderman@rangeweb.net

Gary Alderman, UST Class B Operator

galderman@rangeweb.net

Gary Alderman, UST Class B Operator

galderman@rangeweb.net

Raymond Rolfson, UST Class B Operator

Raymond Rolfson, UST Class B Operator

Theresa Alderman, UST Class A Operator

galderman@rangeweb.net

Theresa Alderman, UST Class A Operator

galderman@rangeweb.net

Theresa Alderman, UST Class B Operator

galderman@rangeweb.net

Theresa Alderman, UST Class B Operator

galderman@rangeweb.net

<b>Tank Code</b>	04	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/10/1993	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	359	<b>Spill Test Date</b>	03/29/2023	<b>Piping Installed Date</b>	04/15/2008	<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/07/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	03/29/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/07/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	05	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/10/1993	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve;High Level Alarm

<b>Tag Number</b>	360	<b>Spill Test Date</b>	03/29/2023	<b>Piping Installed Date</b>	04/15/2008	<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/07/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	03/29/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/07/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	06	<b>Tank Age</b>	32	<b>Tank Installed Date</b>	05/10/1993	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	361	<b>Spill Test Date</b>	03/29/2023	<b>Piping Installed Date</b>	04/15/2008	<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/07/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	2000	<b>ATG Test Date</b>	03/29/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/07/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	07	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	09/30/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	362	<b>Spill Test Date</b>	04/07/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/21/2011	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	03/29/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/07/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	08	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	09/30/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	363	<b>Spill Test Date</b>	03/07/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic

<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/21/2011	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	03/29/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/07/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	09	<b>Tank Age</b>	27	<b>Tank Installed Date</b>	09/30/1998	<b>Tank Material</b>	Steel Clad	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	364	<b>Spill Test Date</b>	04/07/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>	Double-Walled	<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Non-corrodible
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	06/21/2011	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	4000	<b>ATG Test Date</b>	03/29/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/07/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Powder River County in the City of Broadus**

**Location:** CORNER STORE  
106 W Holt St  
Broadus, MT 59317 Powder River

System Facility ID:38-00126

**Facility Code:** 26529  
**Last Inspected On:** 11/06/2023  
**Operating Permit Renewal Date:** 11/06/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Amsden, LLC (406) 580-4698 amsden@becklawyers.com

**Operator Contact:** Julie Riley (406) 853-3971 jriley@rangeweb.net

**Owner/Operator:** Amsden, LLC (406) 580-4698 amsden@becklawyers.com  
Julie Riley, UST Class A Operator jriley@rangeweb.net  
Julie Riley, UST Class B Operator jriley@rangeweb.net

<b>Tank Code</b>	06	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	12/04/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	Flapper Valve;High Level Alarm
<b>Tag Number</b>	933	<b>Spill Test Date</b>	05/30/2024	<b>Piping Installed Date</b>	03/22/2013	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	11/06/2023	<b>Tank/Piping CP Test Date</b>	11/06/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	11/06/2023	<b>Line Tightness Test Date</b>	10/10/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/30/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	07	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	12/04/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	934	<b>Spill Test Date</b>	11/06/2023	<b>Piping Installed Date</b>	04/28/2020	<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Gasoline	<b>PLLD Test Date</b>	11/06/2023	<b>Tank/Piping CP Test Date</b>	11/06/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	Continuous Interstitial Monitoring	<b>Vapor Recovery</b>	No
<b>Capacity</b>	6000	<b>ATG Test Date</b>	11/06/2023	<b>Line Tightness Test Date</b>	09/25/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>	ELLD 0.2	<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/30/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

<b>Tank Code</b>	08	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	12/04/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	935	<b>Spill Test Date</b>	11/06/2023	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>	11/06/2023	<b>Tank/Piping CP Test Date</b>	11/06/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.2	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	11/06/2023	<b>Line Tightness Test Date</b>	09/22/2020	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	05/30/2024			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
<b>Tank Code</b>	09	<b>Tank Age</b>	33	<b>Tank Installed Date</b>	12/04/1992	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Flexible Plastic	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	936	<b>Spill Test Date</b>		<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	Double Walled	<b>AST</b>	No
<b>Tank Status</b>	Temporarily Out of Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Electronic Line Leak Detector	<b>Piping Type</b>	Pressurized	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	11/06/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>	ELLD 0.1	<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>		<b>Line Tightness Test Date</b>	01/07/2017	<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>				<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

**Facility Summary in Powder River County in the City of Broadus**

**Location:** COUNTY SHOP MAINTENANCE YARD  
3 County Shop Rd  
Broadus, MT 59317 Powder River

System Facility ID:38-00548

**Facility Code:** 26532  
**Last Inspected On:** 03/07/2023  
**Operating Permit Renewal Date:** 05/23/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Powder River County (406) 436-2361

**Operator Contact:** Teel Mullanix (406) 436-2248 prcrd1@gmail.com

**Owner/Operator:** Powder River County (406) 436-2361

Teel Mullanix, UST Class A Operator  
Teel Mullanix, UST Class A Operator  
Teel Mullanix, UST Class B Operator  
Teel Mullanix, UST Class B Operator

prcrd1@gmail.com  
prcrd1@gmail.com  
prcrd1@gmail.com  
prcrd1@gmail.com

<b>Tank Code</b>	03	<b>Tank Age</b>	34	<b>Tank Installed Date</b>	06/17/1991	<b>Tank Material</b>	Cathodically Protected Steel	<b>Piping Material</b>	Steel	<b>Overfill Types</b>	High Level Alarm
<b>Tag Number</b>	1807	<b>Spill Test Date</b>	04/07/2020	<b>Piping Installed Date</b>		<b>Tank Construction</b>		<b>Piping Construction</b>	None	<b>AST</b>	No
<b>Tank Status</b>	Currently in Use	<b>MLLD Test Date</b>		<b>Sump Tightness Test Date</b>		<b>Catastrophic L.D Type 3.0</b>	Not Required	<b>Piping Type</b>	Safe Suction	<b>CP Met Types</b>	Galvanic
<b>Product</b>	Diesel	<b>PLLD Test Date</b>		<b>Tank/Piping CP Test Date</b>	03/07/2023	<b>Primary Tank Leak Detection</b>	Automatic Tank Gauging 0.2	<b>Primary Pipe Detection</b>		<b>Vapor Recovery</b>	No
<b>Capacity</b>	5000	<b>ATG Test Date</b>	03/07/2023	<b>Line Tightness Test Date</b>		<b>Secondary Tank Leak Detection</b>		<b>Secondary Pipe Detection</b>		<b>Energy Act</b>	No
		<b>Overfill Test Date</b>	03/07/2023			<b>ATG Type</b>	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				