

Facility Summary in Powder River County in the City of Biddle

Location: CROSS RANCH MERC
222 MT Hwy 59
Biddle, MT 59314 Powder River

System Facility ID:38-01493

Facility Code: 26537
Last Inspected On: 03/07/2023
Operating Permit Renewal Date: 08/10/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Nathan Rumph

Operator Contact: Connie Rumph

(406) 427-5447

crossranchmerc@gmail.com

Owner/Operator: Nathan Rumph

Connie Rumph, UST Class A Operator

Connie Rumph, UST Class B Operator

crossranchmerc@gmail.com

crossranchmerc@gmail.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|----------------------------|---------------------------------|-------------------------------|-----------------------|------------------|
| Tank Code | 07 | Tank Age | 36 | Tank Installed Date | 09/11/1990 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 783 | Spill Test Date | 03/07/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 03/07/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | 03/07/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/07/2023 | | | ATG Type | EBW/Auto Stik II | | | | |
| Tank Code | 08 | Tank Age | 36 | Tank Installed Date | 09/11/1990 | Tank Material | Steel Clad | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 784 | Spill Test Date | 03/07/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 03/07/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | 03/07/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/07/2023 | | | ATG Type | EBW/Auto Stik II | | | | |

Facility Summary in Powder River County in the City of Broadus

Location: ALDERMAN OIL CO
601 S Park Ave
Broadus, MT 59317 Powder River

System Facility ID:38-03951

Facility Code: 26549
Last Inspected On: 12/30/2025
Operating Permit Renewal Date: 04/08/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Alderman Oil Co;Gary Alderman

(406) 436-2898

Operator Contact: Gary Alderman;Theresa Alderman

galderman@rangeweb.net

Owner/Operator: Alderman Oil Co

(406) 436-2898

Owner/Operator: Gary Alderman

(406) 436-2898

Gary Alderman, UST Class A Operator

galderman@rangeweb.net

Gary Alderman, UST Class B Operator

galderman@rangeweb.net

Raymond Rolfson, UST Class B Operator

galderman@rangeweb.net

Theresa Alderman, UST Class A Operator

galderman@rangeweb.net

Theresa Alderman, UST Class B Operator

galderman@rangeweb.net

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|--------------|-----------------------|--------------------------------|
| Tank Code | 04 | Tank Age | 33 | Tank Installed Date | 05/10/1993 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 359 | Spill Test Date | 03/29/2023 | Piping Installed Date | 04/15/2008 | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 03/07/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | 03/29/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/07/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 05 | Tank Age | 33 | Tank Installed Date | 05/10/1993 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 360 | Spill Test Date | 03/29/2023 | Piping Installed Date | 04/15/2008 | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 03/07/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------|----------------|--------------------------------|
| Capacity | 2000 | ATG Test Date | 03/29/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/07/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 06 | Tank Age | 33 | Tank Installed Date | 05/10/1993 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 361 | Spill Test Date | 03/29/2023 | Piping Installed Date | 04/15/2008 | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 03/07/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | 03/29/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/07/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 07 | Tank Age | 28 | Tank Installed Date | 09/30/1998 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 362 | Spill Test Date | 04/07/2023 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 06/21/2011 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 03/29/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/07/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 08 | Tank Age | 28 | Tank Installed Date | 09/30/1998 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 363 | Spill Test Date | 03/07/2023 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 06/21/2011 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 03/29/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/07/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------|----------------|--------------------------------|
| Tank Code | 09 | Tank Age | 28 | Tank Installed Date | 09/30/1998 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 364 | Spill Test Date | 04/07/2023 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 06/21/2011 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 03/29/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/07/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Powder River County in the City of Broadus

Location: CORNER STORE
106 W Holt St
Broadus, MT 59317 Powder River

System Facility ID:38-00126

Facility Code: 26529
Last Inspected On: 11/06/2023
Operating Permit Renewal Date: 11/06/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Amsden, LLC

(406) 580-4698

amsden@becklawyers.com

Operator Contact: Julie Riley

(406) 853-3971

jriley@rangeweb.net

Owner/Operator: Amsden, LLC

(406) 580-4698

amsden@becklawyers.com

Julie Riley, UST Class A Operator

jriley@rangeweb.net

Julie Riley, UST Class B Operator

jriley@rangeweb.net

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|--------------------------------|
| Tank Code | 06 | Tank Age | 34 | Tank Installed Date | 12/04/1992 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 933 | Spill Test Date | 05/30/2024 | Piping Installed Date | 03/22/2013 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 11/06/2023 | Tank/Piping CP Test Date | 11/06/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 11/06/2023 | Line Tightness Test Date | 10/10/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 05/30/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 07 | Tank Age | 34 | Tank Installed Date | 12/04/1992 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 934 | Spill Test Date | 11/06/2023 | Piping Installed Date | 04/28/2020 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 11/06/2023 | Tank/Piping CP Test Date | 11/06/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 11/06/2023 | Line Tightness Test Date | 09/25/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 05/30/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

| | | | | | | | | | | | |
|-------------|------------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------|----------------|------------------|
| Tank Code | 08 | Tank Age | 34 | Tank Installed Date | 12/04/1992 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 935 | Spill Test Date | 11/06/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | 11/06/2023 | Tank/Piping CP Test Date | 11/06/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 11/06/2023 | Line Tightness Test Date | 09/22/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/30/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 09 | Tank Age | 34 | Tank Installed Date | 12/04/1992 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 936 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Temporarily Out of Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 11/06/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.1 | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | | Line Tightness Test Date | 01/07/2017 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Powder River County in the City of Broadus

Location: COUNTY SHOP MAINTENANCE YARD
3 County Shop Rd
Broadus, MT 59317 Powder River

System Facility ID:38-00548

Facility Code: 26532
Last Inspected On: 12/30/2025
Operating Permit Renewal Date: 05/23/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Powder River County

(406) 436-2361

Operator Contact: Teel Mullanix

(406) 436-2248

prcrd1@gmail.com

Owner/Operator: Powder River County

(406) 436-2361

Teel Mullanix, UST Class A Operator

Teel Mullanix, UST Class B Operator

prcrd1@gmail.com

prcrd1@gmail.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|--------------|-----------------------|------------------|
| Tank Code | 03 | Tank Age | 35 | Tank Installed Date | 06/17/1991 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | High Level Alarm |
| Tag Number | 1807 | Spill Test Date | 04/07/2020 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 03/07/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 03/07/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/07/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |