

Facility Summary in Rosebud County in the City of Ashland

Location: CHEYENNE DEPOT 2
2363 W US Hwy 212
Ashland, MT 59003 Rosebud

System Facility ID:44-13200

Facility Code: 27702
Last Inspected On: 06/25/2024
Operating Permit Renewal Date: 06/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Northern Cheyenne Development Corporation

ncdcmt@gmail.com

Operator Contact:

Owner/Operator: Northern Cheyenne Development Corporation

ncdcmt@gmail.com

Tank Code	01	Tank Age	33	Tank Installed Date	07/30/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4420	Spill Test Date	06/25/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/25/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/11/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/25/2024	Line Tightness Test Date	06/25/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/25/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	33	Tank Installed Date	07/30/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4421	Spill Test Date	06/25/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/25/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/11/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/25/2024	Line Tightness Test Date	06/25/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/25/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	33	Tank Installed Date	07/30/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	4424	Spill Test Date	06/25/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	06/25/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/11/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/25/2024	Line Tightness Test Date	06/25/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/25/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Rosebud County in the City of Ashland

Location: ST LABRE INDIAN SCHOOL UST
1000 Tongue River Rd
Ashland, MT 59003 Rosebud

System Facility ID:44-00701

Facility Code: 27579
Last Inspected On: 05/09/2024
Operating Permit Renewal Date: 10/09/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: St Labre Indian School

(406) 784-4994

STLMAINTINV@STLABRE.ORG

Operator Contact: Dana Davis;Leney Mcnac

ddavis@stlabre.org;lmcnac@stlabre.org

Owner/Operator: St Labre Indian School

(406) 784-4994

STLMAINTINV@STLABRE.ORG

Dana Davis, UST Class A Operator

ddavis@stlabre.org

Dana Davis, UST Class B Global Operator

ddavis@stlabre.org

Dana Davis, UST Class B Operator

ddavis@stlabre.org

Leney Mcnac, UST Class A Operator

lmcnac@stlabre.org

Leney Mcnac, UST Class B Global Operator

lmcnac@stlabre.org

Tank Code	10	Tank Age	33	Tank Installed Date	12/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1957	Spill Test Date	05/09/2024	Piping Installed Date	08/26/2011	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/09/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	15000	ATG Test Date	05/09/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/09/2024			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Rosebud County in the City of Ashland

Location: WESTERN PUMP
US Hwy 212
Ashland, MT 59003 Rosebud

System Facility ID:44-01892

Facility Code: 27599
Last Inspected On: 09/18/2023
Operating Permit Renewal Date: 12/31/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cleatus Stevenson (406) 784-2400

Operator Contact: James Stevenson (406) 784-2400 joats@rangeweb.net

Owner/Operator: Cleatus Stevenson (406) 784-2400

James Stevenson, UST Class A Operator
James Stevenson, UST Class B Operator
joats@rangeweb.net
joats@rangeweb.net

Tank Code	01	Tank Age	33	Tank Installed Date	02/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3098	Spill Test Date	09/18/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/12/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	09/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/18/2023			ATG Type	Gilbarco-Veeder Root/				
Tank Code	02	Tank Age	33	Tank Installed Date	02/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3099	Spill Test Date	09/18/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/02/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date	09/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/18/2023			ATG Type	Gilbarco-Veeder Root/				
Tank Code	03	Tank Age	29	Tank Installed Date	10/29/1997	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3100	Spill Test Date	11/02/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLL D Test Date		Tank/Piping CP Test Date	09/18/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	09/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/02/2023			ATG Type	Gilbarco-Veeder Root/				

Facility Summary in Rosebud County in the City of Colstrip

Location: COLSTRIP STEAM ELECTRIC STATION UNITS 3 AND 4
601 Willow Ave
Colstrip, MT 59323 Rosebud

System Facility ID:44-06584

Facility Code: 27651
Last Inspected On: 10/13/2023
Operating Permit Renewal Date: 10/13/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Talen Montana LLC (406) 748-5002 gordon.criswell@talenenergy.com

Operator Contact: Brian Sullivan (406) 748-5038 brian.sullivan@talenenergy.com

Owner/Operator: Talen Montana LLC (406) 748-5002 gordon.criswell@talenenergy.com

Brian Sullivan, UST Class A Operator
William Neumiller, UST Class B Operator
brian.sullivan@talenenergy.com
wlneumiller@pplweb.com

Tank Code	S10-24	Tank Age	47	Tank Installed Date	05/01/1979	Tank Material	Unknown	Piping Material	Steel	Overfill Types
Tag Number	2863	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/30/2024	Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery
Capacity	40000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date				ATG Type				
Tank Code	S10-23	Tank Age	47	Tank Installed Date	05/01/1979	Tank Material	Unknown	Piping Material	Steel	Overfill Types
Tag Number	3703	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/30/2024	Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery
Capacity	500000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date				ATG Type				

Facility Summary in Rosebud County in the City of Colstrip

Location: TOWN PUMP INC COLSTRIP
112 Willow Ave
Colstrip, MT 59323 Rosebud

System Facility ID:44-08689

Facility Code: 27667
Last Inspected On: 03/12/2024
Operating Permit Renewal Date: 07/01/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Colstrip 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Colstrip 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

Tank Code	01	Tank Age	51	Tank Installed Date	04/12/1975	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4787	Spill Test Date	07/27/2023	Piping Installed Date	04/20/2011	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	06/07/2022	Tank/Piping CP Test Date	06/08/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	12/01/2023	Line Tightness Test Date	06/02/2006	Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	08/17/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	51	Tank Installed Date	04/12/1975	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4788	Spill Test Date	08/17/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/07/2022	Tank/Piping CP Test Date	07/08/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	12/01/2023	Line Tightness Test Date	07/02/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS			
Tank Code	03	Tank Age	51	Tank Installed Date	04/12/1975	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	4789	Spill Test Date	07/27/2023	Piping Installed Date	04/20/2011	Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date	06/07/2022	Tank/Piping CP Test Date	06/08/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery
Capacity	12000	ATG Test Date	12/01/2023	Line Tightness Test Date	07/02/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS			
Tank Code	04	Tank Age	51	Tank Installed Date	04/12/1975	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	4790	Spill Test Date	08/17/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date	06/07/2022	Tank/Piping CP Test Date	06/08/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery
Capacity	12000	ATG Test Date	12/01/2023	Line Tightness Test Date	10/14/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS			
Tank Code	05	Tank Age	51	Tank Installed Date	04/12/1975	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types
Tag Number	4791	Spill Test Date	08/17/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types
Product	Gasoline	PLLD Test Date	06/07/2022	Tank/Piping CP Test Date	06/08/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery
Capacity	6000	ATG Test Date	12/01/2023	Line Tightness Test Date	10/14/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act
		Overfill Test Date	08/17/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS			

Tank Code	06	Tank Age	26	Tank Installed Date	01/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4792	Spill Test Date	07/27/2023	Piping Installed Date	04/20/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/07/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	12/01/2023	Line Tightness Test Date	10/25/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	26	Tank Installed Date	01/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4793	Spill Test Date	08/17/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/07/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	12/01/2023	Line Tightness Test Date	10/25/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Rosebud County in the City of Forsyth

Location: FORSYTH WATERING HOLE
1017 Front St
Forsyth, MT 59327 Rosebud

System Facility ID:44-01244

Facility Code: 27590
Last Inspected On: 08/16/2024
Operating Permit Renewal Date: 12/12/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: RRR Properties LLC (406) 346-2885 forsythwh@yahoo.com

Operator Contact: DeAnne Jonas (406) 346-2885 forsythwh@yahoo.com

Owner/Operator: RRR Properties LLC (406) 346-2885 forsythwh@yahoo.com

DeAnne Jonas, UST Class A Operator forsythwh@yahoo.com

DeAnne Jonas, UST Class B Global Operator forsythwh@yahoo.com

Tank Code	04	Tank Age	34	Tank Installed Date	02/24/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1393	Spill Test Date	08/16/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/16/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/15/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/16/2024	Line Tightness Test Date	08/16/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	34	Tank Installed Date	02/24/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1394	Spill Test Date	08/16/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/16/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/27/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/16/2024	Line Tightness Test Date	08/16/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	34	Tank Installed Date	02/24/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	1395	Spill Test Date	08/16/2024	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/16/2024	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/27/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/16/2024	Line Tightness Test Date	08/16/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/16/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Rosebud County in the City of Forsyth

Location: GM PETROLEUM DISTRIBUTORS
200 Main St
Forsyth, MT 59327 Rosebud

System Facility ID:44-10824

Facility Code: 27691
Last Inspected On: 09/06/2013
Operating Permit Renewal Date: 11/07/2016

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City Service Valcon LLC DBA GM Petroleum Distributors (406) 252-4661 jbrookie@gmpetroleum.com

Operator Contact: Bill Grunstead;Laura Geffre;Roger Schmechel (406) 208-3147 bgrunstead@gmpetroleum.com

Bill Grunstead, UST Class A Operator

bgrunstead@gmpetroleum.com

Laura Geffre, UST Class A Operator

Laura Geffre, UST Class B Operator

Roger Schmechel, UST Class A Operator

Roger Schmechel, UST Class B Operator

Tank Code	07	Tank Age	0	Tank Installed Date	Tank Material	Not Listed	Piping Material	Not Listed	Overfill Types
Tag Number	5582	Spill Test Date		Piping Installed Date	Tank Construction		Piping Construction		AST
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date	Catastrophic L.D Type 3.0		Piping Type	Not Listed	CP Met Types
Product	Unknown	PLLD Test Date		Tank/Piping CP Test Date	Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Not Listed	Vapor Recovery
Capacity	1000	ATG Test Date		Line Tightness Test Date	Secondary Tank Leak Detection		Secondary Pipe Detection	Not Listed	Energy Act
		Overfill Test Date			ATG Type				

Facility Summary in Rosebud County in the City of Forsyth

Location: PRINCE INC FORSYTH
W Frontage Rd
Forsyth, MT 59327 Rosebud

System Facility ID:44-06209

Facility Code: 27646
Last Inspected On: 09/26/2023
Operating Permit Renewal Date: 02/12/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Prince Inc (406) 356-2137

Operator Contact: Charlee Prince;Shelley Thompson;Steve Pulver (406) 346-2137 cprince@princeinc.us;slnpulver@live.com;sthompson@princeinc.us

Owner/Operator: Prince Inc (406) 356-2137

Charlee Prince, UST Class A Operator

cprince@princeinc.us

Charlee Prince, UST Class B Global Operator

cprince@princeinc.us

Shelley Thompson, UST Class A Operator

sthompson@princeinc.us

Shelley Thompson, UST Class B Operator

sthompson@princeinc.us

Steve Pulver, UST Class A Operator

slnpulver@live.com

Steve Pulver, UST Class B Operator

slnpulver@live.com

Tank Code	05	Tank Age	28	Tank Installed Date	10/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4532	Spill Test Date	09/26/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/26/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	09/26/2023	Line Tightness Test Date	11/21/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/26/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	28	Tank Installed Date	10/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4533	Spill Test Date	09/26/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/26/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	5000	ATG Test Date	09/26/2023	Line Tightness Test Date	11/21/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

	Overfill Test Date	09/26/2023		ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		
--	---------------------------	------------	--	-----------------	--	--	--

Facility Summary in Rosebud County in the City of Forsyth

Location: ROSEBUD COUNTY ROAD DEPT
2975 US Hwy 10
Forsyth, MT 59327 Rosebud

System Facility ID:44-01288

Facility Code: 27592
Last Inspected On: 10/11/2023
Operating Permit Renewal Date: 10/11/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rosebud County Road Dept (406) 346-2261

Operator Contact: Dawne Buck;Pat Zent;Wayne Buck (406) 698-3778 dbuck@rosebudcountymt.com;pzent@rosebudcountymt.com

Owner/Operator: Rosebud County Road Dept (406) 346-2261

Dawne Buck, UST Class A Operator dbuck@rosebudcountymt.com
Dawne Buck, UST Class B Operator dbuck@rosebudcountymt.com
Pat Zent, UST Class A Operator pzent@rosebudcountymt.com
Pat Zent, UST Class B Operator pzent@rosebudcountymt.com
Wayne Buck, UST Class A Operator dbuck@rosebudcountymt.com
Wayne Buck, UST Class B Operator dbuck@rosebudcountymt.com

Tank Code	05	Tank Age	35	Tank Installed Date	04/01/1991	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1858	Spill Test Date	09/26/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/26/2023	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date	09/26/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/26/2023			ATG Type	Gilbarco-Veeder Root/EMC Basic				
Tank Code	06	Tank Age	35	Tank Installed Date	04/01/1991	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1859	Spill Test Date	09/26/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/26/2023	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No

Capacity	4000	ATG Test Date	09/26/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/26/2023			ATG Type	Gilbarco-Veeder Root/EMC Basic				
Tank Code	07	Tank Age	35	Tank Installed Date	04/01/1991	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1860	Spill Test Date	09/26/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/26/2023	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	09/26/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/26/2023			ATG Type	Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Rosebud County in the City of Forsyth

Location: ROSEBUD HEALTH CARE CENTER
383 N 17th Ave
Forsyth, MT 59327 Rosebud

System Facility ID:44-05262

Facility Code: 27633
Last Inspected On: 03/10/2025
Operating Permit Renewal Date: 03/14/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rosebud Health Care Center (406) 356-2161

Operator Contact: Chad Potts;Michael Jerhoff;Tim Davis (406) 347-5222;(406) 351-2274;(406) 351-9095 cpotts@rosebudhealthcare.com

Owner/Operator: Rosebud Health Care Center (406) 356-2161

Chad Potts, UST Class A Operator

cpotts@rosebudhealthcare.com

Clint Boyer, UST Class B Operator

cboyer@rosebudhealthcare.com

Michael Jerhoff, UST Class A Operator

Michael Jerhoff, UST Class B Global Operator

Tim Davis, UST Class A Operator

Tim Davis, UST Class B Global Operator

Tank Code	02	Tank Age	35	Tank Installed Date	09/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4343	Spill Test Date	01/10/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/10/2025	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	500	ATG Test Date		Line Tightness Test Date	01/27/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/27/2022			ATG Type					

Facility Summary in Rosebud County in the City of Forsyth

Location: TOWN PUMP INC FORSYTH
974 Front St
Forsyth, MT 59327 Rosebud

System Facility ID:44-09356

Facility Code: 27672
Last Inspected On: 02/14/2024
Operating Permit Renewal Date: 07/01/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Forsyth 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Forsyth 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

Tank Code	11	Tank Age	24	Tank Installed Date	10/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4736	Spill Test Date	09/26/2023	Piping Installed Date	10/21/2002	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/14/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	02/14/2024	Line Tightness Test Date	12/03/2009	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/26/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	12	Tank Age	24	Tank Installed Date	10/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4737	Spill Test Date	12/20/2023	Piping Installed Date	10/21/2002	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/14/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	02/14/2024	Line Tightness Test Date	12/03/2009	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/26/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	14	Tank Age	24	Tank Installed Date	10/21/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4738	Spill Test Date	09/26/2023	Piping Installed Date	10/21/2002	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/14/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	02/14/2024	Line Tightness Test Date	12/03/2009	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/26/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	13	Tank Age	24	Tank Installed Date	11/20/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4755	Spill Test Date	09/26/2023	Piping Installed Date	11/20/2002	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/14/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	02/14/2024	Line Tightness Test Date	12/03/2009	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/26/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	15	Tank Age	24	Tank Installed Date	11/20/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4756	Spill Test Date	09/26/2023	Piping Installed Date	11/20/2002	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/14/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	02/14/2024	Line Tightness Test Date	12/03/2009	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/26/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	16	Tank Age	24	Tank Installed Date	11/20/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4757	Spill Test Date	09/26/2023	Piping Installed Date	11/20/2002	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLL D Test Date	02/14/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	02/14/2024	Line Tightness Test Date	12/03/2009	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/26/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				