

Facility Summary in Silver Bow County in the City of Butte

Location: ACADIA BUILDING
55 Basin Creek Rd
Butte, MT 59701-9704 Silver Bow

System Facility ID:47-00458

Facility Code: 28332
Last Inspected On: 03/10/2025
Operating Permit Renewal Date: 03/19/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana Dept of Corrections (406) 444-6551 JCHRISTOFFERSON@MT.GOV

Operator Contact: Bill English;Leon Huizinga;Todd Skartved (406) 496-6329;(406) 498-4550;(406) 782-2143 hbigbearmt@aol.com;leon.huizinga@acadiahealthcare.com;milehighpetro@gmail.com

Owner/Operator: Montana Dept of Corrections (406) 444-6551 JCHRISTOFFERSON@MT.GOV

Bill English, UST Class A Operator hbigbearmt@aol.com
Bill English, UST Class B Global Operator hbigbearmt@aol.com
Leon Huizinga, UST Class A Operator leon.huizinga@acadiahealthcare.com
Leon Huizinga, UST Class B Operator leon.huizinga@acadiahealthcare.com
Todd Skartved, UST Class A Operator milehighpetro@gmail.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|------------------------------------|-----------------------|----------------|
| Tank Code | 01 | Tank Age | 39 | Tank Installed Date | 06/22/1987 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Copper | Overfill Types | Flapper Valve |
| Tag Number | 3974 | Spill Test Date | 03/10/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Secondary Containment Chase | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | U.S. Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 2000 | ATG Test Date | 03/10/2025 | Line Tightness Test Date | 10/31/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | 3-Year Line Tightness Test | Energy Act | No |
| | | Overfill Test Date | 03/10/2025 | | | ATG Type | Veeder Root/TLS-300 | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: BUTTE MAIN CENTRAL OFFICE
200 W Broadway St
Butte, MT 59701-9226 Silver Bow

System Facility ID: 56-14034

Facility Code: 30690
Last Inspected On: 08/25/2025
Operating Permit Renewal Date: 10/26/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Century Link Communication

(501) 680-8141

Stephanie.miller@lumen.com

Operator Contact: Stephanie Miller

(501) 680-8141

Stephanie.miller@lumen.com

Owner/Operator: Century Link Communication

(501) 680-8141

Stephanie.miller@lumen.com

Stephanie Miller, UST Class A Operator

Stephanie.miller@lumen.com

Stephanie Miller, UST Class B Global Operator

Stephanie.miller@lumen.com

| Tank Code | 01 | Tank Age | 24 | Tank Installed Date | 10/02/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|------------------------------------|--------------------------|------------------------------------|----------------|------------------|
| Tag Number | 4732 | Spill Test Date | 08/25/2025 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | U.S. Suction | CP Met Types | |
| Product | Diesel, Dyed | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | 3-Year Line Tightness Test | Vapor Recovery | No |
| Capacity | 2500 | ATG Test Date | 08/25/2025 | Line Tightness Test Date | 08/25/2025 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/25/2025 | | | ATG Type | | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: BUTTE SCHOOL DIST 1 BUS BARN
1220 E Front St
Butte, MT 59701-2936 Silver Bow

System Facility ID:47-01980

Facility Code: 28355
Last Inspected On: 09/10/2025
Operating Permit Renewal Date: 01/31/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 1 Butte (406) 496-2185

Operator Contact: Bill English;Jed Johnson;Leonard Diaz;Todd Skartved (406) 498-4550;(406) 782-2143 hbigbearmt@aol.com;jedjohnson86@yahoo.com;leonard.diaz@rsd.k12.az.us;milehighpetro@gmail.com

Owner/Operator: School Dist 1 Butte (406) 496-2185

| | |
|--|----------------------------|
| Bill English, UST Class A Operator | hbigbearmt@aol.com |
| Bill English, UST Class B Global Operator | hbigbearmt@aol.com |
| Jed Johnson, UST Class A Operator | jedjohnson86@yahoo.com |
| Jed Johnson, UST Class B Global Operator | jedjohnson86@yahoo.com |
| Leonard Diaz, UST Class A Operator | leonard.diaz@rsd.k12.az.us |
| Leonard Diaz, UST Class B Operator | leonard.diaz@rsd.k12.az.us |
| Todd Skartved, UST Class A Operator | milehighpetro@gmail.com |
| Todd Skartved, UST Class B Global Operator | milehighpetro@gmail.com |

| Tank Code | 03 | Tank Age | 34 | Tank Installed Date | 08/01/1992 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|----------------|
| Tag Number | 1892 | Spill Test Date | 09/10/2025 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 09/10/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 09/10/2025 | | | ATG Type | Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: CENEX ZIP TRIP 72
2801 Harrison Ave
Butte, MT 59701-3715 Silver Bow

System Facility ID:47-05148

Facility Code: 28404
Last Inspected On: 06/08/2023
Operating Permit Renewal Date: 12/26/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Operator Contact: Jim Alford;Sean Hurley (509) 535-7701;(509) 536-7418 jim.alford@chsinc.com;sean.hurley@chsinc.com

Owner/Operator: CHS Inc Spokane Valley (509) 535-7701 jim.alford@chsinc.com

Jim Alford, UST Class A Operator

jim.alford@chsinc.com

Jim Alford, UST Class B Operator

jim.alford@chsinc.com

Luci Tuttle, UST Class B Operator

Lucinda.Tuttle@chsinc.com

Sean Hurley, UST Class A Operator

sean.hurley@chsinc.com

Travis Weber, UST Class B Operator

travis.weber3@chsinc.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|-------------------------------|-----------------------|----------------|
| Tank Code | 08 | Tank Age | 36 | Tank Installed Date | 03/19/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1707 | Spill Test Date | 06/27/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | 05/19/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/27/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 09 | Tank Age | 36 | Tank Installed Date | 03/19/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1708 | Spill Test Date | 06/27/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | | Line Tightness Test Date | 05/19/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |

| | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|-------------------------------|----------------|
| | | Overfill Test Date | 06/27/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | |
| Tank Code | 10 | Tank Age | 36 | Tank Installed Date | 03/19/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 1709 | Spill Test Date | 06/27/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 05/19/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act |
| | | Overfill Test Date | 06/27/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | |
| Tank Code | 11 | Tank Age | 36 | Tank Installed Date | 03/19/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 1710 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | 05/19/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act |
| | | Overfill Test Date | 06/27/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | |
| Tank Code | 12 | Tank Age | 36 | Tank Installed Date | 03/19/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 1711 | Spill Test Date | | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery |
| Capacity | 6000 | ATG Test Date | | Line Tightness Test Date | 05/19/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: CENEX ZIP TRIP 73
848 W Park St
Butte, MT 59701-9066 Silver Bow

System Facility ID:47-00386

Facility Code: 28330
Last Inspected On: 02/24/2025
Operating Permit Renewal Date: 05/16/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | |
|---|----------------|-----------------------|
| Owner Operator Contact: CHS Inc Spokane Valley | (509) 535-7701 | jim.alford@chsinc.com |
|---|----------------|-----------------------|

| | | |
|---|-------------------------------|--|
| Operator Contact: Jim Alford;Sean Hurley | (509) 535-7701;(509) 536-7418 | jim.alford@chsinc.com;sean.hurley@chsinc.com |
|---|-------------------------------|--|

| | | |
|---|----------------|-----------------------|
| Owner/Operator: CHS Inc Spokane Valley | (509) 535-7701 | jim.alford@chsinc.com |
|---|----------------|-----------------------|

Jim Alford, UST Class A Operator
Jim Alford, UST Class B Operator
Luci Tuttle, UST Class B Operator
Sean Hurley, UST Class A Operator
Travis Weber, UST Class B Operator

jim.alford@chsinc.com
jim.alford@chsinc.com
Lucinda.Tuttle@chsinc.com
sean.hurley@chsinc.com
travis.weber3@chsinc.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|----------------|
| Tank Code | 05 | Tank Age | 28 | Tank Installed Date | 09/01/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4425 | Spill Test Date | 10/05/2021 | Piping Installed Date | 05/15/2016 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/07/2020 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/22/2019 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 08/04/2022 | Line Tightness Test Date | 01/21/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 06/26/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 06 | Tank Age | 28 | Tank Installed Date | 09/01/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4426 | Spill Test Date | 10/05/2021 | Piping Installed Date | 05/15/2016 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/07/2020 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/22/2019 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 08/04/2022 | Line Tightness Test Date | 01/21/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |

| | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|
| | | Overfill Test Date | 06/26/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | |
| Tank Code | 07 | Tank Age | 28 | Tank Installed Date | 09/01/1998 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types |
| Tag Number | 4427 | Spill Test Date | 10/05/2021 | Piping Installed Date | 05/15/2016 | Tank Construction | | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/07/2020 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | 05/22/2019 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |
| Capacity | 5000 | ATG Test Date | 08/04/2022 | Line Tightness Test Date | 01/20/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act |
| | | Overfill Test Date | 06/26/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: DETENTION CENTER
155 W Quartz St
Butte, MT 59701-9200 Silver Bow

System Facility ID:56-14119

Facility Code: 30760
Last Inspected On: 10/29/2025
Operating Permit Renewal Date: 05/27/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Butte Silver Bow County

Operator Contact: Bill English;Jed Johnson;John Stajcar

(406) 497-6569;(406) 782-2143

hbigbearmt@aol.com;jedjohnson86@yahoo.com;jstajcar@bsb.mt.gov

Owner/Operator: Butte Silver Bow County

Bill English, UST Class A Operator

hbigbearmt@aol.com

Bill English, UST Class B Global Operator

hbigbearmt@aol.com

Jed Johnson, UST Class A Operator

jedjohnson86@yahoo.com

John Stajcar, UST Class A Operator

jstajcar@bsb.mt.gov

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|------------------------------------|---------------------------------|------------------------------------|-----------------------|------------------|
| Tank Code | 01 | Tank Age | 21 | Tank Installed Date | 01/31/2005 | Tank Material | Steel Clad | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 5006 | Spill Test Date | 11/08/2022 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 1000 | ATG Test Date | 02/06/2023 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 02/06/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-300 | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: FED EX DISTRIBUTION
119771 Rick Jones Way
Butte, MT 59750 Silver Bow

System Facility ID:60-15178

Facility Code: 30904
Last Inspected On: 11/27/2023
Operating Permit Renewal Date: 04/12/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Arc Febtmt 001 LLC

(215) 449-3600

Operator Contact: Brenden Rose;Arc Febtmt 001 LLC;Chong Lee;Greg Peters

(215) 449-3600;(408) 654-3112

Brenden.Rose@fedex.com;chong.lee@fedex.com;greg.peters@fedex.com

Owner/Operator: Arc Febtmt 001 LLC

(215) 449-3600

Brenden Rose, UST Class A Operator

Brenden.Rose@fedex.com

Brenden Rose, UST Class B Operator

Brenden.Rose@fedex.com

Chong Lee, UST Class A Operator

chong.lee@fedex.com

Greg Peters, UST Class A Operator

greg.peters@fedex.com

Greg Peters, UST Class B Operator

greg.peters@fedex.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--|---------------------------------|------------------------------------|-----------------------|--------------------------------|
| Tank Code | 01 | Tank Age | 15 | Tank Installed Date | 03/01/2011 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve;High Level Alarm |
| Tag Number | 5286 | Spill Test Date | 11/28/2023 | Piping Installed Date | 12/20/2010 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 11/27/2023 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 10/05/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 10/05/2023 | Line Tightness Test Date | 07/10/2020 | Secondary Tank Leak Detection | Automatic Tank Gauging 0.2 | Secondary Pipe Detection | ELLD 0.2 | Energy Act | Yes |
| | | Overfill Test Date | 11/27/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: HOLLOW CONSTRUCTION
404 W Greenwood Ave
Butte, MT 59701-2898 Silver Bow

System Facility ID:47-05359

Facility Code: 28410
Last Inspected On: 01/23/2024
Operating Permit Renewal Date: 05/22/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hollow Contracting;William Hollow

(406) 782-6033

Operator Contact: Susan Lasher

slasher@hollowcontracting.com

Owner/Operator: Hollow Contracting

(406) 782-6033

Owner/Operator: William J Hollow

(406) 782-6033

Susan Lasher, UST Class A Operator
Susan Lasher, UST Class B Operator

slasher@hollowcontracting.com
slasher@hollowcontracting.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------|---------------------------------|-----------------------------|-----------------------|--------------------------------|
| Tank Code | 02 | Tank Age | 26 | Tank Installed Date | 01/01/2000 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 4162 | Spill Test Date | 04/30/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 10/25/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 04/03/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 15000 | ATG Test Date | 04/04/2024 | Line Tightness Test Date | 04/30/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/30/2024 | | | ATG Type | Gilbarco-Veeder Root/EMC Basic | | | | |
| Tank Code | 03 | Tank Age | 26 | Tank Installed Date | 01/01/2000 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 4163 | Spill Test Date | 04/30/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 10/25/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 10/25/2023 | Line Tightness Test Date | 04/30/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/30/2024 | | | ATG Type | Gilbarco-Veeder Root/EMC Basic | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------|--------------------------|-----------------------------|----------------|--------------------------------|
| Tank Code | 04 | Tank Age | 26 | Tank Installed Date | 01/01/2000 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 4164 | Spill Test Date | 04/30/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 10/25/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | MLLD Line Tightness Testing | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 10/25/2023 | Line Tightness Test Date | 04/30/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/30/2024 | | | ATG Type | Gilbarco-Veeder Root/EMC Basic | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: JMT CORP MONTANA DBA JMT TRISTOP AND CASINO
2544 Harrison Ave
Butte, MT 59701 Silver Bow

System Facility ID:47-05202

Facility Code: 28406
Last Inspected On: 05/12/2023
Operating Permit Renewal Date: 08/19/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: JMT Corp Montana

(406) 782-9359

jmann@jmtpetro.com

Operator Contact:

Owner/Operator: JMT Corp Montana

(406) 782-9359

jmann@jmtpetro.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|------------------|
| Tank Code | 06 | Tank Age | 36 | Tank Installed Date | 03/08/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 1546 | Spill Test Date | 04/24/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 01/09/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 04/24/2023 | Line Tightness Test Date | 07/05/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/24/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 07 | Tank Age | 36 | Tank Installed Date | 03/08/1990 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 1547 | Spill Test Date | 04/24/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 01/09/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 04/24/2023 | Line Tightness Test Date | 07/05/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/24/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|------------------|
| Tank Code | 08 | Tank Age | 31 | Tank Installed Date | 06/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 1548 | Spill Test Date | 04/24/2023 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 04/24/2023 | Line Tightness Test Date | 07/07/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/27/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 09 | Tank Age | 31 | Tank Installed Date | 06/01/1995 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 1549 | Spill Test Date | 04/24/2023 | Piping Installed Date | 02/12/2021 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 04/24/2023 | Line Tightness Test Date | 07/04/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/24/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: MDOT BUTTE
3751 Wynne Ave
Butte, MT 59701-6712 Silver Bow

System Facility ID:47-01062

Facility Code: 28342
Last Inspected On: 05/01/2024
Operating Permit Renewal Date: 10/26/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | |
|--|----------------|----------------|
| Owner Operator Contact: MDOT Helena | (406) 444-6163 | mmurolo@mt.gov |
|--|----------------|----------------|

| | | |
|--|--|--|
| Operator Contact: Joe Radonich;Montana Dept of Transportation;Walt Kerttula;Montana Department of Transportation Helena | (406) 444-6151;(406) 444-9204;(406) 444-7632 | jradonich@mt.gov;jradonich@mt.gov;wkerttula@mt.gov |
|--|--|--|

| | | |
|---|----------------|-------------------|
| Owner/Operator: MDOT Helena | (406) 444-6163 | mmurolo@mt.gov |
| Charles Stratford, UST Class B Operator | | cstratford@mt.gov |
| Joe Radonich, UST Class A Operator | | jradonich@mt.gov |
| Joe Radonich, UST Class B Operator | | jradonich@mt.gov |
| Paul Jordan, UST Class B Operator | | pjordan@mt.gov |
| Walt Kerttula, UST Class A Operator | | wkerttula@mt.gov |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|-------------------------------|-----------------------|----------------|
| Tank Code | 08 | Tank Age | 32 | Tank Installed Date | 08/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2937 | Spill Test Date | 05/01/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/01/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/01/2024 | | | ATG Type | Gilbarco/EMC Basic | | | | |
| Tank Code | 09 | Tank Age | 32 | Tank Installed Date | 08/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2938 | Spill Test Date | 05/01/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Deferred | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/01/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/09/2024 | | | ATG Type | Gilbarco/EMC Basic | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: MONTANA RESOURCES INC
600 Shields Ave
Butte, MT 59701-2705 Silver Bow

System Facility ID:47-13549

Facility Code: 28507
Last Inspected On: 11/14/2023
Operating Permit Renewal Date: 03/05/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana Resources LLC

(406) 723-9542

jfleege@montanaresources.com

Operator Contact: Jeremy Fleege;Thomas Dale

(406) 498-8360

jfleege@jbrenv.com

Owner/Operator: Montana Resources LLC

(406) 723-9542

jfleege@montanaresources.com

Daniel Lorengo, UST Class B Operator

dlorenzo@montanaresources.com

Jeremy Fleege, UST Class A Operator

jfleege@jbrenv.com

Jerry Frohreich, UST Class B Operator

jfrohreich@montanaresources.com

Jody D'Arcy, UST Class B Operator

drc2251@hotmail.com

Thomas Dale, UST Class A Operator

Thomas Dale, UST Class B Operator

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|------------------------------------|---------------------------------|------------------------------------|-----------------------|------------------|
| Tank Code | 02 | Tank Age | 29 | Tank Installed Date | 10/01/1997 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | High Level Alarm |
| Tag Number | 1687 | Spill Test Date | 11/14/2023 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Continuous Interstitial Monitoring | Piping Type | Gravity Feed | CP Met Types | Non-corrodible |
| Product | Oil, Waste | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 12/18/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/ILS-350 | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: NORTHWEST PETROLEUM FACILITY
28 Dewey Blvd
Butte, MT 59701-3195 Silver Bow

System Facility ID: 56-14033

Facility Code: 30689
Last Inspected On: 03/26/2025
Operating Permit Renewal Date: 08/02/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Northwest Petroleum Co

(406) 497-6700

done@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Northwest Petroleum Co

(406) 497-6700

done@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|------------------|
| Tank Code | 01 | Tank Age | 24 | Tank Installed Date | 04/17/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4639 | Spill Test Date | | Piping Installed Date | 09/15/2006 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/14/2021 | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 25000 | ATG Test Date | 03/26/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/07/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 02 | Tank Age | 24 | Tank Installed Date | 04/17/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4640 | Spill Test Date | | Piping Installed Date | 09/15/2006 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/14/2021 | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 25000 | ATG Test Date | 03/26/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|
| | | Overfill Test Date | 08/07/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | |
| Tank Code | 03 | Tank Age | 24 | Tank Installed Date | 04/17/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 4641 | Spill Test Date | | Piping Installed Date | 09/15/2006 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/14/2021 | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery |
| Capacity | 25000 | ATG Test Date | 03/26/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act |
| | | | | | | | Gilbarco-Veeder Root/TLS-450PLUS | | | |
| | | Overfill Test Date | 08/07/2024 | | | ATG Type | | | | |
| Tank Code | 04 | Tank Age | 24 | Tank Installed Date | 04/17/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 4642 | Spill Test Date | | Piping Installed Date | 09/15/2006 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/14/2021 | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery |
| Capacity | 25000 | ATG Test Date | 03/26/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act |
| | | | | | | | Gilbarco-Veeder Root/TLS-450PLUS | | | |
| | | Overfill Test Date | 08/07/2024 | | | ATG Type | | | | |
| Tank Code | 05 | Tank Age | 24 | Tank Installed Date | 04/17/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 4643 | Spill Test Date | | Piping Installed Date | 09/15/2006 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/14/2021 | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types |
| Product | Diesel, Dyed | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery |
| Capacity | 25000 | ATG Test Date | 03/26/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act |
| | | | | | | | Gilbarco-Veeder Root/TLS-450PLUS | | | |
| | | Overfill Test Date | 08/07/2024 | | | ATG Type | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Code | 06 | Tank Age | 24 | Tank Installed Date | 04/17/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4644 | Spill Test Date | | Piping Installed Date | 09/15/2006 | Tank Construction | Double-Walled | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/14/2021 | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 25000 | ATG Test Date | 03/26/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/07/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 07 | Tank Age | 24 | Tank Installed Date | 04/17/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4645 | Spill Test Date | | Piping Installed Date | 09/15/2006 | Tank Construction | Double-Walled | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/14/2021 | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 25000 | ATG Test Date | 03/26/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/07/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 08 | Tank Age | 24 | Tank Installed Date | 04/17/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | High Level Alarm |
| Tag Number | 4646 | Spill Test Date | | Piping Installed Date | 09/15/2006 | Tank Construction | Double-Walled | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/14/2021 | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 25000 | ATG Test Date | 03/26/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 08/07/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: RD'S QUICK FUEL
16 E Dewey Blvd
Butte, MT 59701-3195 Silver Bow

System Facility ID:47-13531

Facility Code: 28506
Last Inspected On: 09/12/2025
Operating Permit Renewal Date: 12/05/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City Service Valcon LLC

(406) 294-0865

mailto:tamara.noble@cityservicevalcon.com

Operator Contact: Kary Tonjum

Owner/Operator: City Service Valcon LLC

(406) 294-0865

mailto:tamara.noble@cityservicevalcon.com

Kary Tonjum, UST Class A Operator

Kary Tonjum, UST Class B Operator

Mitchell Kilmer, UST Class B Operator

Roy Morris, UST Class B Global Operator

mkilmer@bresnan.net

roy@morris-marketing.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|-------------------------------|-----------------------|------------------|
| Tank Code | 01 | Tank Age | 32 | Tank Installed Date | 08/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 1712 | Spill Test Date | 10/28/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 04/21/2025 | Line Tightness Test Date | 08/20/2013 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 09/12/2025 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 02 | Tank Age | 32 | Tank Installed Date | 08/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 1713 | Spill Test Date | 09/12/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 04/21/2025 | Line Tightness Test Date | 08/20/2013 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 09/12/2025 | | | ATG Type | Incon/TS-550 EVO | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-------------------------------|----------------|------------------|
| Tank Code | 03 | Tank Age | 32 | Tank Installed Date | 08/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 1714 | Spill Test Date | 10/28/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 04/21/2025 | Line Tightness Test Date | 08/20/2013 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 09/12/2025 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 04 | Tank Age | 32 | Tank Installed Date | 08/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 1715 | Spill Test Date | 09/12/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 04/21/2025 | Line Tightness Test Date | 08/20/2013 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 09/12/2025 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 05 | Tank Age | 32 | Tank Installed Date | 08/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 1716 | Spill Test Date | 09/12/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 04/21/2025 | Line Tightness Test Date | 08/20/2013 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 09/12/2025 | | | ATG Type | Incon/TS-550 EVO | | | | |
| Tank Code | 06 | Tank Age | 32 | Tank Installed Date | 08/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 1717 | Spill Test Date | 09/12/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 04/21/2025 | Line Tightness Test Date | 08/20/2013 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |

| | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|-------------------------------|-----------------------|
| | | Overfill Test Date | 09/12/2025 | | | ATG Type | Incon/TS-550 EVO | | | |
| Tank Code | 07 | Tank Age | 32 | Tank Installed Date | 08/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 1718 | Spill Test Date | 09/12/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery |
| Capacity | 10000 | ATG Test Date | 04/21/2025 | Line Tightness Test Date | 08/20/2013 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act |
| | | Overfill Test Date | 09/12/2025 | | | ATG Type | Incon/TS-550 EVO | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: ROCKER FLYING J
122000 N Browns Gulch Rd
Butte, MT 59701 Silver Bow

System Facility ID:47-09893

Facility Code: 28472
Last Inspected On: 08/19/2025
Operating Permit Renewal Date: 11/11/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocker 3 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Rocker 3 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|--------------------------------|
| Tank Code | 15 | Tank Age | 14 | Tank Installed Date | 04/12/2012 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 5302 | Spill Test Date | 04/16/2024 | Piping Installed Date | 04/12/2012 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/27/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 30000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | 09/06/2014 | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 16 | Tank Age | 14 | Tank Installed Date | 04/12/2012 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 5303 | Spill Test Date | 08/01/2024 | Piping Installed Date | 08/26/2014 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/27/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 30000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | 09/06/2014 | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |

| | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | |
| Tank Code | 17 | Tank Age | 14 | Tank Installed Date | 04/12/2012 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 5304 | Spill Test Date | 04/16/2024 | Piping Installed Date | 08/26/2014 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | 03/27/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |
| Capacity | 30000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | 09/06/2014 | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act |
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | Yes |
| Tank Code | 18 | Tank Age | 14 | Tank Installed Date | 04/12/2012 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 5305 | Spill Test Date | 04/16/2024 | Piping Installed Date | 08/26/2014 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Gasoline | PLLD Test Date | 03/27/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |
| Capacity | 30000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act |
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | Yes |
| Tank Code | 19 | Tank Age | 14 | Tank Installed Date | 04/12/2012 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 5306 | Spill Test Date | 04/16/2024 | Piping Installed Date | 07/25/2011 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel, Dyed | PLLD Test Date | 03/27/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |
| Capacity | 8000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act |

| | | | | | | | | | | |
|-------------|---------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | |
| Tank Code | 20 | Tank Age | 14 | Tank Installed Date | 04/12/2012 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 5307 | Spill Test Date | 08/01/2024 | Piping Installed Date | 07/25/2011 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Gasoline | PLLD Test Date | 03/27/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |
| Capacity | 15000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act |
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | Yes |
| Tank Code | 21 | Tank Age | 14 | Tank Installed Date | 04/12/2012 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 5308 | Spill Test Date | 04/16/2024 | Piping Installed Date | 07/25/2011 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 05/12/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | 03/27/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |
| Capacity | 8000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act |
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | Yes |
| Tank Code | 23 | Tank Age | 15 | Tank Installed Date | 07/25/2011 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Unknown | Overfill Types |
| Tag Number | 5364 | Spill Test Date | | Piping Installed Date | 07/25/2011 | Tank Construction | Double-Walled | Piping Construction | None | AST |
| Tank Status | Other | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | | Piping Type | Not Listed | CP Met Types |
| Product | DEF (Not Regulated) | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Not Listed | Vapor Recovery |
| Capacity | 10000 | ATG Test Date | | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | | Energy Act |
| | | | | | | | | | | Yes |

| | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | |
| Tank Code | 24 | Tank Age | 1 | Tank Installed Date | 02/19/2025 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types |
| Tag Number | 6283 | Spill Test Date | 04/25/2025 | Piping Installed Date | 03/01/2025 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |
| Capacity | 22000 | ATG Test Date | 04/25/2025 | Line Tightness Test Date | 03/03/2025 | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act |
| | | Overfill Test Date | 04/25/2025 | | | ATG Type | | | | |
| Tank Code | 25 | Tank Age | 1 | Tank Installed Date | 02/19/2025 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types |
| Tag Number | 6284 | Spill Test Date | 04/25/2025 | Piping Installed Date | 03/01/2025 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |
| Capacity | 8000 | ATG Test Date | 04/25/2025 | Line Tightness Test Date | 03/03/2025 | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act |
| | | Overfill Test Date | 04/25/2025 | | | ATG Type | | | | |
| Tank Code | 26 | Tank Age | 1 | Tank Installed Date | 02/19/2025 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 6285 | Spill Test Date | 04/25/2025 | Piping Installed Date | 03/01/2025 | Tank Construction | | Piping Construction | | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |
| Capacity | 22000 | ATG Test Date | 04/25/2025 | Line Tightness Test Date | 03/03/2025 | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act |
| | | Overfill Test Date | 04/25/2025 | | | ATG Type | | | | |
| Tank Code | 27 | Tank Age | 1 | Tank Installed Date | 02/19/2025 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types |
| Tag Number | 6286 | Spill Test Date | 04/25/2025 | Piping Installed Date | 03/01/2025 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |

| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----------------|
| Product | Gasoline, E10 | PLL D Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 8000 | ATG Test Date | 04/25/2025 | Line Tightness Test Date | 03/03/2025 | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 04/25/2025 | | | ATG Type | | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: SILVER BOW COUNTY PUBLIC WORKS
Browns Gulch
Butte, MT 59701 Silver Bow

System Facility ID:47-13157

Facility Code: 28500
Last Inspected On: 03/10/2025
Operating Permit Renewal Date: 06/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Silver Bow County Browns Gulch Landfill (406) 497-6569

Operator Contact: Todd Skartved (406) 498-4550 milehighpetro@gmail.com

Owner/Operator: Silver Bow County Browns Gulch Landfill (406) 497-6569

Todd Skartved, UST Class A Operator milehighpetro@gmail.com
Todd Skartved, UST Class B Global Operator milehighpetro@gmail.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|-------------------------------|-----------------------|----------------|
| Tank Code | 01 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4465 | Spill Test Date | 10/29/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Not Required | Piping Type | Safe Suction | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/10/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 09/24/2024 | | | ATG Type | Gilbarco/EMC Basic | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: ST JAMES HEALTHCARE INC
400 S Clark St
Butte, MT 59701-2328 Silver Bow

System Facility ID:47-06924

Facility Code: 28426
Last Inspected On: 08/04/2025
Operating Permit Renewal Date: 12/05/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: St James Healthcare Inc

Operator Contact: Thomas McKenna

(406) 723-2747

tmckennaco@icloud.com

Owner/Operator: St James Healthcare Inc

Mark McGivern, UST Class B Operator

mark.mcgivern@sclhealth.org

Richard Giuffra, UST Class B Operator

richard.giuffra@mail2.org

Thomas McKenna, UST Class A Operator

tmckennaco@icloud.com

Thomas McKenna, UST Class B Global Operator

tmckennaco@icloud.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|----------------|
| Tank Code | 05 | Tank Age | 25 | Tank Installed Date | 05/01/2001 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4449 | Spill Test Date | 11/11/2021 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer;Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 01/17/2023 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 15000 | ATG Test Date | 08/04/2025 | Line Tightness Test Date | 08/04/2025 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 10/03/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: THREE BEARS ALASKA
45 Three Bears Dr
Butte, MT 59701-7171 Silver Bow

System Facility ID:60-15058

Facility Code: 30832
Last Inspected On: 08/04/2025
Operating Permit Renewal Date: 01/09/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | | | | | | | | |
|--|------------------|--------------------|----------------|--|------------|-------------------------------|------------------------------------|--------------------------|------------------|
| Owner Operator Contact: FIP Master Funding II, LLC | | | (602) 448-5226 | matt@fundamentalincome.com | | | | | |
| Operator Contact: Dave Goody;Lindsay Myers;Wendy Whelchel | | | (406) 494-7547 | lmyers@threebearsalaska.com;lmyers@threebearsalaska.com;store70@threebearsalaska.com | | | | | |
| Owner/Operator: FIP Master Funding II, LLC | | | (602) 448-5226 | matt@fundamentalincome.com | | | | | |
| Tank Code | 01 | Tank Age | 19 | Tank Installed Date | 04/24/2007 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic |
| Tag Number | 5103 | Spill Test Date | 10/02/2025 | Piping Installed Date | 10/25/2006 | Tank Construction | Double-Walled | Piping Construction | Double Walled |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | AST |
| Product | Gasoline | PLLD Test Date | 08/04/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Vapor Recovery |
| Capacity | 17000 | ATG Test Date | 08/04/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Energy Act |
| | | Overfill Test Date | 08/04/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | |
| Tank Code | 02 | Tank Age | 19 | Tank Installed Date | 04/24/2007 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Overfill Types |
| Tag Number | 5104 | Spill Test Date | 08/04/2025 | Piping Installed Date | 10/25/2006 | Tank Construction | Double-Walled | Piping Construction | Ball Float Valve |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | AST |
| Product | Diesel | PLLD Test Date | 08/04/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Vapor Recovery |
| Capacity | 8000 | ATG Test Date | 08/04/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Energy Act |
| | | Overfill Test Date | 08/04/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350 | | |

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 1
3501 Harrison Ave
Butte, MT 59701-3547 Silver Bow

System Facility ID:47-07932

Facility Code: 28433
Last Inspected On: 03/07/2025
Operating Permit Renewal Date: 05/06/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Operator Contact: Jack Hook;Linda Otonicar;Louis Sutey (406) 491-5808;(406) 494-2305 ldsutey66@thriftwayss.com;otonicarlinda@aol.com

Owner/Operator: Sutey Oil Co Inc (406) 494-2305 ldsutey66@thriftwayss.com

Cindy Beck, UST Class B Operator

thriftway1@thriftwayss.com

Jack Hook, UST Class A Operator

dsbrown@ttc-cmc.net

Jack Hook, UST Class B Global Operator

otonicarlinda@aol.com

Jack Hook, UST Class B Operator

ldsutey66@thriftwayss.com

James Brown, UST Class B Operator

ldsutey66@thriftwayss.com

Linda Otonicar, UST Class A Operator

ldsutey66@thriftwayss.com

Louis Sutey, UST Class A Operator

ldsutey66@thriftwayss.com

Louis Sutey, UST Class B Global Operator

srandall59701@gmail.com

Shelby Hart, UST Class B Operator

| Tank Code | 07 | Tank Age | 36 | Tank Installed Date | 04/10/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|-------------------------------|----------------|---------------|
| Tag Number | 2062 | Spill Test Date | 03/06/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Not Listed | CP Met Types | |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 12/04/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 14783 | ATG Test Date | 12/04/2024 | Line Tightness Test Date | 09/09/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 12/04/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 08 | Tank Age | 36 | Tank Installed Date | 04/10/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2063 | Spill Test Date | 12/04/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Not Listed | CP Met Types | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|-------------------------------|----------------|---------------|
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | 12/04/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 11627 | ATG Test Date | 04/03/2024 | Line Tightness Test Date | 08/30/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 03/06/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 09 | Tank Age | 36 | Tank Installed Date | 04/10/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2064 | Spill Test Date | 12/04/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Not Listed | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 12/04/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 11627 | ATG Test Date | 04/03/2024 | Line Tightness Test Date | 08/28/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 12/04/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 10 | Tank Age | 36 | Tank Installed Date | 04/10/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2065 | Spill Test Date | 12/04/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Not Listed | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 12/04/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 5929 | ATG Test Date | 04/03/2024 | Line Tightness Test Date | 09/05/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 12/04/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 11 | Tank Age | 36 | Tank Installed Date | 04/10/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2066 | Spill Test Date | 12/04/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Not Listed | CP Met Types | |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | 12/04/2024 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 5929 | ATG Test Date | 04/03/2024 | Line Tightness Test Date | 09/19/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 12/04/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 16
4701 Harrison Ave
Butte, MT 59701-7002 Silver Bow

System Facility ID:47-10657

Facility Code: 28486
Last Inspected On: 05/21/2025
Operating Permit Renewal Date: 07/10/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | |
|---|----------------|---------------------------|
| Owner Operator Contact: Sutey Oil Co Inc | (406) 494-2305 | ldsutey66@thriftwayss.com |
|---|----------------|---------------------------|

| | | |
|---|-------------------------------|---|
| Operator Contact: Linda Otonicar;Louis Sutey | (406) 491-5808;(406) 494-2305 | ldsutey66@thriftwayss.com;otonicarlinda@aol.com |
|---|-------------------------------|---|

| | | |
|---|----------------|---------------------------|
| Owner/Operator: Sutey Oil Co Inc | (406) 494-2305 | ldsutey66@thriftwayss.com |
| Linda Otonicar, UST Class A Operator | | otonicarlinda@aol.com |
| Louis Sutey, UST Class A Operator | | ldsutey66@thriftwayss.com |
| Raymond Doolittle, UST Class B Operator | | ldsutey66@thriftwayss.com |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|---------------|-----------------------|---------------|
| Tank Code | 01 | Tank Age | 39 | Tank Installed Date | 11/01/1987 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 1921 | Spill Test Date | 05/20/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | 10/13/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | 02/10/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/20/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 39 | Tank Installed Date | 11/01/1987 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 1922 | Spill Test Date | 09/02/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | 10/13/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | 02/11/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/20/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|---------------|----------------|---------------|
| Tank Code | 03 | Tank Age | 39 | Tank Installed Date | 11/01/1987 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 1923 | Spill Test Date | 05/20/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | 10/13/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | 02/11/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 05/20/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 04 | Tank Age | 39 | Tank Installed Date | 11/01/1987 | Tank Material | Cathodically Protected Steel | Piping Material | Steel | Overfill Types | Flapper Valve |
| Tag Number | 1924 | Spill Test Date | 03/18/2022 | Piping Installed Date | 09/14/2006 | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | 06/28/2022 | Tank/Piping CP Test Date | 10/13/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 01/04/2023 | Line Tightness Test Date | 02/12/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 06/28/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 2
1900 S Montana St
Butte, MT 59701-3023 Silver Bow

System Facility ID:47-07935

Facility Code: 28436
Last Inspected On: 05/01/2025
Operating Permit Renewal Date: 06/12/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | |
|---|----------------|---------------------------|
| Owner Operator Contact: Sutey Oil Co Inc | (406) 494-2305 | ldsutey66@thriftwayss.com |
|---|----------------|---------------------------|

| | | |
|---|-------------------------------|---|
| Operator Contact: Jack Hook;Linda Otonicar;Louis Sutey | (406) 491-5808;(406) 494-2305 | ldsutey66@thriftwayss.com;otonicarlinda@aol.com |
|---|-------------------------------|---|

| | | |
|---|----------------|---------------------------|
| Owner/Operator: Sutey Oil Co Inc | (406) 494-2305 | ldsutey66@thriftwayss.com |
|---|----------------|---------------------------|

Jack Hook, UST Class A Operator

Jessica Willis, UST Class B Global Operator

Linda Otonicar, UST Class A Operator

Louis Sutey, UST Class A Operator

Louis Sutey, UST Class B Global Operator

clownprincess269@gmail.com

otonicarlinda@aol.com

ldsutey66@thriftwayss.com

ldsutey66@thriftwayss.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|-------------------------------|-----------------------|---------------|
| Tank Code | 04 | Tank Age | 37 | Tank Installed Date | 05/15/1989 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2070 | Spill Test Date | 04/21/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/15/2019 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLLD Test Date | 04/21/2025 | Tank/Piping CP Test Date | 06/29/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 11627 | ATG Test Date | 04/21/2025 | Line Tightness Test Date | 04/15/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/21/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 05 | Tank Age | 37 | Tank Installed Date | 05/15/1989 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2071 | Spill Test Date | 04/21/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/15/2019 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Diesel | PLLD Test Date | 04/21/2025 | Tank/Piping CP Test Date | 06/29/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 11627 | ATG Test Date | 04/21/2025 | Line Tightness Test Date | 04/15/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |

| | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|-------------------------------|-----------------------|
| | | Overfill Test Date | 04/21/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | |
| Tank Code | 06 | Tank Age | 37 | Tank Installed Date | 05/15/1989 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 2072 | Spill Test Date | 04/21/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | 04/15/2019 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Gasoline | PLLD Test Date | 04/21/2025 | Tank/Piping CP Test Date | 06/29/2022 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery |
| Capacity | 11627 | ATG Test Date | 04/21/2025 | Line Tightness Test Date | 04/15/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act |
| | | Overfill Test Date | 04/21/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 4
2610 Harrison Ave
Butte, MT 59701 Silver Bow

System Facility ID:47-07934

Facility Code: 28435
Last Inspected On: 05/02/2025
Operating Permit Renewal Date: 06/20/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: David Sutey;Sutey Oil Co Inc **(406) 494-2305** **ldsutey66@thriftwayss.com**

Operator Contact: Geoff Gifford;Jack Hook;Linda Otonicar;Louis Sutey **(406) 491-5808;(406) 494-2305;(406) 494-3155** **ldsutey66@thriftwayss.com;otonicarlinda@aol.com;Thriftway16@Thriftwayss.com**

Owner/Operator: David L Sutey

Owner/Operator: Sutey Oil Co Inc

Geoff Gifford, UST Class A Operator

Thriftway16@Thriftwayss.com

Jack Hook, UST Class A Operator

maeskasey@gmail.com

Kasey Maes, UST Class B Operator

otonicarlinda@aol.com

Linda Otonicar, UST Class A Operator

otonicarlinda@aol.com

Linda Otonicar, UST Class B Global Operator

ldsutey66@thriftwayss.com

Louis Sutey, UST Class A Operator

ldsutey66@thriftwayss.com

Louis Sutey, UST Class B Global Operator

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|-------------------------------|---------------------------------|-------------------------------|-----------------------|----------------|
| Tank Code | 05 | Tank Age | 36 | Tank Installed Date | 03/13/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2067 | Spill Test Date | 04/28/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/15/2019 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 04/28/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 11627 | ATG Test Date | 04/28/2025 | Line Tightness Test Date | 01/25/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/28/2025 | | | ATG Type | Veeder Root/TLS-350 | | | | |
| Tank Code | 06 | Tank Age | 36 | Tank Installed Date | 03/13/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2068 | Spill Test Date | 09/03/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/15/2019 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 04/28/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|-------------------------------|--------------------------|-------------------------------|----------------|----------------|
| Capacity | 11627 | ATG Test Date | 04/28/2025 | Line Tightness Test Date | 01/25/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/28/2025 | | | ATG Type | Veeder Root/TLS-350 | | | | |
| Tank Code | 07 | Tank Age | 36 | Tank Installed Date | 03/13/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2069 | Spill Test Date | 09/13/2025 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/15/2019 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 04/28/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | ELLD 0.2 | Vapor Recovery | No |
| Capacity | 11627 | ATG Test Date | 04/28/2025 | Line Tightness Test Date | 01/25/2022 | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | No |
| | | Overfill Test Date | 04/28/2025 | | | ATG Type | Veeder Root/TLS-350 | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 5
901 E Front St
Butte, MT 59701-2929 Silver Bow

System Facility ID:47-00942

Facility Code: 28334
Last Inspected On: 01/22/2025
Operating Permit Renewal Date: 06/12/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: David Sutey;Sutey Oil Co Inc

(406) 494-2305

ldsutey66@thriftwayss.com

Operator Contact: Linda Otonicar;Louis Sutey

(406) 491-5808;(406) 494-2305

ldsutey66@thriftwayss.com;otonicarlinda@aol.com

Owner/Operator: David L Sutey

Owner/Operator: Sutey Oil Co Inc

Katie Black, UST Class B Operator

katie.black1369@gmail.com

Kenneth Beck, UST Class B Global Operator

suesman@hotmail.com

Linda Otonicar, UST Class A Operator

otonicarlinda@aol.com

Linda Otonicar, UST Class B Operator

otonicarlinda@aol.com

Louis Sutey, UST Class A Operator

ldsutey66@thriftwayss.com

Louis Sutey, UST Class B Global Operator

ldsutey66@thriftwayss.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|--------------------------------|
| Tank Code | 05 | Tank Age | 32 | Tank Installed Date | 08/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 2059 | Spill Test Date | 01/22/2025 | Piping Installed Date | 11/07/2016 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 02/11/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 04/09/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 04/09/2025 | Line Tightness Test Date | 08/16/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 01/21/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 06 | Tank Age | 32 | Tank Installed Date | 08/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 2060 | Spill Test Date | 01/22/2025 | Piping Installed Date | 11/07/2016 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 02/11/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|--------------------------------|
| Product | Diesel | PLL D Test Date | 04/09/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 04/09/2025 | Line Tightness Test Date | 11/18/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 01/21/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 07 | Tank Age | 32 | Tank Installed Date | 08/01/1994 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 2061 | Spill Test Date | 01/22/2025 | Piping Installed Date | 11/07/2016 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 02/11/2022 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | Gasoline | PLL D Test Date | 04/09/2024 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 04/09/2024 | Line Tightness Test Date | 08/20/2021 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 01/21/2025 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 6
2401 Continental Dr
Butte, MT 59701-6562 Silver Bow

System Facility ID:47-07936

Facility Code: 28437
Last Inspected On: 10/29/2024
Operating Permit Renewal Date: 02/27/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

| | | |
|---|----------------|---------------------------|
| Owner Operator Contact: Sutey Oil Co Inc | (406) 494-2305 | ldsutey66@thriftwayss.com |
|---|----------------|---------------------------|

| | | |
|---|-------------------------------|---|
| Operator Contact: Linda Otonicar;Louis Sutey | (406) 491-5808;(406) 494-2305 | ldsutey66@thriftwayss.com;otonicarlinda@aol.com |
|---|-------------------------------|---|

| | | |
|--|----------------|---------------------------|
| Owner/Operator: Sutey Oil Co Inc | (406) 494-2305 | ldsutey66@thriftwayss.com |
| Justin Shafford, UST Class B Operator | | ldsutey66@thriftwayss.com |
| Linda Otonicar, UST Class A Operator | | otonicarlinda@aol.com |
| Louis Sutey, UST Class A Operator | | ldsutey66@thriftwayss.com |
| Louis Sutey, UST Class B Global Operator | | ldsutey66@thriftwayss.com |
| Thomas Thompson, UST Class B Operator | | ldsutey66@thriftwayss.com |

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|----------------------------------|---------------------------------|------------------------------------|-----------------------|-------------------|
| Tank Code | 01 | Tank Age | 58 | Tank Installed Date | 05/07/1968 | Tank Material | Bare Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2073 | Spill Test Date | 10/29/2024 | Piping Installed Date | 06/23/2014 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 12/13/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 04/11/2024 | Tank/Piping CP Test Date | 04/05/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 04/11/2024 | Line Tightness Test Date | 01/17/2019 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 10/29/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 02 | Tank Age | 58 | Tank Installed Date | 05/07/1968 | Tank Material | Bare Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2074 | Spill Test Date | 10/29/2024 | Piping Installed Date | 06/23/2014 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 12/13/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 04/11/2024 | Tank/Piping CP Test Date | 04/05/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |

| | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|----------------------------------|------------------------|------------------------------------|----------------|
| Capacity | 10000 | ATG Test Date | 04/11/2024 | Line Tightness Test Date | 01/21/2019 | Secondary Tank Leak Detection | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 10/29/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | |
| Tank Code | 03 | Tank Age | 53 | Tank Installed Date | 05/07/1973 | Tank Material | Bare Steel | Piping Material | Flexible Plastic | Overfill Types |
| Tag Number | 2075 | Spill Test Date | 10/29/2024 | Piping Installed Date | 06/23/2014 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 12/13/2021 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | 04/11/2024 | Tank/Piping CP Test Date | 04/05/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |
| Capacity | 8000 | ATG Test Date | 04/11/2024 | Line Tightness Test Date | 01/19/2019 | Secondary Tank Leak Detection | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 10/29/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP BUTTE #5
2305 Continental Dr
Butte, MT 59701 Silver Bow

System Facility ID: 60-15187

Facility Code: 30912
Last Inspected On: 03/26/2025
Operating Permit Renewal Date: 08/31/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Butte 5 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Butte 5 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|----------------|
| Tank Code | 01 | Tank Age | 15 | Tank Installed Date | 11/01/2011 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5310 | Spill Test Date | 10/02/2024 | Piping Installed Date | 07/28/2011 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/07/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 03/26/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 20000 | ATG Test Date | 03/26/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 10/02/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 02 | Tank Age | 15 | Tank Installed Date | 11/01/2011 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 5311 | Spill Test Date | 06/07/2024 | Piping Installed Date | 07/28/2011 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/07/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/26/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 03/26/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |

| | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|
| | | Overfill Test Date | 06/07/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | |
| Tank Code | 03 | Tank Age | 15 | Tank Installed Date | 11/01/2011 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 5312 | Spill Test Date | 06/07/2024 | Piping Installed Date | 07/28/2011 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/07/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Gasoline | PLLD Test Date | 03/26/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery |
| Capacity | 12000 | ATG Test Date | 03/26/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act |
| | | Overfill Test Date | 06/07/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 1
1370 Harrison Ave
Butte, MT 59701-4848 Silver Bow

System Facility ID:47-08679

Facility Code: 28450
Last Inspected On: 05/19/2025
Operating Permit Renewal Date: 09/19/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Butte 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Butte 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|-------------------|
| Tank Code | 05 | Tank Age | 38 | Tank Installed Date | 04/11/1988 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2618 | Spill Test Date | 10/07/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 05/19/2025 | Tank/Piping CP Test Date | 04/11/2024 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 05/19/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 10/07/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 06 | Tank Age | 40 | Tank Installed Date | 04/11/1986 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2619 | Spill Test Date | 10/07/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 05/19/2025 | Tank/Piping CP Test Date | 04/11/2024 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 05/19/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|
| | | Overfill Test Date | 10/07/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | |
| Tank Code | 07 | Tank Age | 38 | Tank Installed Date | 04/11/1988 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types |
| Tag Number | 2620 | Spill Test Date | 10/07/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Gasoline | PLLD Test Date | 05/19/2025 | Tank/Piping CP Test Date | 04/11/2024 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery |
| Capacity | 8000 | ATG Test Date | 05/19/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act |
| | | Overfill Test Date | 10/07/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | |
| Tank Code | 08 | Tank Age | 35 | Tank Installed Date | 07/28/1991 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types |
| Tag Number | 2621 | Spill Test Date | 04/11/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | 05/19/2025 | Tank/Piping CP Test Date | 04/11/2024 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery |
| Capacity | 4000 | ATG Test Date | 05/19/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act |
| | | Overfill Test Date | 04/11/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 10
901 N Excelsior Ave
Butte, MT 59701 Silver Bow

System Facility ID:47-08687

Facility Code: 28458
Last Inspected On: 03/26/2025
Operating Permit Renewal Date: 08/03/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Butte 10 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Butte 10 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|-------------------|
| Tank Code | 01 | Tank Age | 55 | Tank Installed Date | 04/12/1971 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2633 | Spill Test Date | 10/31/2024 | Piping Installed Date | 11/01/2019 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/17/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 03/26/2025 | Tank/Piping CP Test Date | 04/27/2021 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 04/17/2024 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | 04/17/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 02 | Tank Age | 55 | Tank Installed Date | 04/12/1971 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2634 | Spill Test Date | 04/17/2024 | Piping Installed Date | 11/01/2019 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 04/17/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 03/26/2025 | Tank/Piping CP Test Date | 04/27/2021 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 03/26/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |

| | | | | | | | |
|--|---------------------------|------------|--|-----------------|---|--|--|
| | Overfill Test Date | 04/17/2024 | | ATG Type | Gilbarco-Veeder Root/TLS- 450PLUS | | |
|--|---------------------------|------------|--|-----------------|---|--|--|

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 2
531 S Montana St
Butte, MT 59701 Silver Bow

System Facility ID:47-08680

Facility Code: 28451
Last Inspected On: 05/20/2025
Operating Permit Renewal Date: 09/01/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Butte 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Butte 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|----------------|
| Tank Code | 04 | Tank Age | 5 | Tank Installed Date | 03/31/2021 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6038 | Spill Test Date | 06/07/2024 | Piping Installed Date | 03/31/2021 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/07/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/19/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 24000 | ATG Test Date | 05/19/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 06/07/2024 | | | ATG Type | | | | | |
| Tank Code | 05 | Tank Age | 5 | Tank Installed Date | 03/31/2021 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6039 | Spill Test Date | 06/07/2024 | Piping Installed Date | 03/31/2021 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/07/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/19/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 6000 | ATG Test Date | 05/19/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 06/07/2024 | | | ATG Type | | | | | |
| Tank Code | 06 | Tank Age | 5 | Tank Installed Date | 03/31/2021 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----------------|
| Tag Number | 6040 | Spill Test Date | 06/07/2024 | Piping Installed Date | 03/31/2021 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/07/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/19/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 15000 | ATG Test Date | 05/19/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 06/07/2024 | | | ATG Type | | | | | |
| Tank Code | 07 | Tank Age | 5 | Tank Installed Date | 03/31/2021 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6041 | Spill Test Date | 06/07/2024 | Piping Installed Date | 03/31/2021 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/07/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/19/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 05/19/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 06/07/2024 | | | ATG Type | | | | | |
| Tank Code | 08 | Tank Age | 5 | Tank Installed Date | 03/31/2021 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6042 | Spill Test Date | 06/07/2024 | Piping Installed Date | 03/31/2021 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/07/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/19/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 15000 | ATG Test Date | 05/19/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 06/07/2024 | | | ATG Type | | | | | |
| Tank Code | 09 | Tank Age | 5 | Tank Installed Date | 03/31/2021 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6043 | Spill Test Date | 06/07/2024 | Piping Installed Date | 03/31/2021 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/07/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | 05/19/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |

| | | | | | | | | | | | |
|-----------------|------|---------------------------|------------|---------------------------------|--|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-------------------|-----|
| Capacity | 6000 | ATG Test Date | 05/19/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 06/07/2024 | | | ATG Type | | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 3
2328 S Montana St
Butte, MT 59701 Silver Bow

System Facility ID:47-08682

Facility Code: 28453
Last Inspected On: 03/20/2025
Operating Permit Renewal Date: 07/27/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Butte 3 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Butte 3 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|------------------|
| Tank Code | 01 | Tank Age | 45 | Tank Installed Date | 04/11/1981 | Tank Material | Cathodically Protected Steel | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2625 | Spill Test Date | 07/25/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 03/20/2025 | Tank/Piping CP Test Date | 07/25/2024 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Approved Remote Monitoring | Secondary Pipe Detection | Approved Remote Monitoring | Energy Act | No |
| | | Overfill Test Date | 07/25/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 04 | Tank Age | 36 | Tank Installed Date | 10/01/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2626 | Spill Test Date | 07/25/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 03/20/2025 | Tank/Piping CP Test Date | 05/05/2012 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Approved Remote Monitoring | Secondary Pipe Detection | Approved Remote Monitoring | Energy Act | No |
| | | Overfill Test Date | 07/25/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----------------|
| Tank Code | 05 | Tank Age | 36 | Tank Installed Date | 10/01/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2627 | Spill Test Date | 07/25/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 03/20/2025 | Tank/Piping CP Test Date | 05/05/2012 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Approved Remote Monitoring | Secondary Pipe Detection | Approved Remote Monitoring | Energy Act | No |
| | | Overfill Test Date | 07/25/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 06 | Tank Age | 36 | Tank Installed Date | 10/01/1990 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Flapper Valve |
| Tag Number | 2628 | Spill Test Date | 07/25/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Single Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/20/2025 | Tank/Piping CP Test Date | 05/05/2012 | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Approved Remote Monitoring | Secondary Pipe Detection | Approved Remote Monitoring | Energy Act | No |
| | | Overfill Test Date | 07/25/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 4
3700 Harrison Ave
Butte, MT 59701 Silver Bow

System Facility ID: 56-13911

Facility Code: 30581
Last Inspected On: 05/20/2025
Operating Permit Renewal Date: 09/15/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Butte 4 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Butte 4 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|----------------|
| Tank Code | 01 | Tank Age | 27 | Tank Installed Date | 04/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4022 | Spill Test Date | 10/02/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/17/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 02 | Tank Age | 27 | Tank Installed Date | 04/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4023 | Spill Test Date | 04/17/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|
| | | Overfill Test Date | 04/17/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | |
| Tank Code | 03 | Tank Age | 27 | Tank Installed Date | 04/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types |
| Tag Number | 4024 | Spill Test Date | 04/17/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Gasoline | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery |
| Capacity | 15000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act |
| | | Overfill Test Date | 04/17/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | |
| Tank Code | 04 | Tank Age | 27 | Tank Installed Date | 04/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types |
| Tag Number | 4025 | Spill Test Date | 04/17/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery |
| Capacity | 8000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act |
| | | Overfill Test Date | 04/17/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | |
| Tank Code | 05 | Tank Age | 27 | Tank Installed Date | 04/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types |
| Tag Number | 4026 | Spill Test Date | 04/17/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery |
| Capacity | 6000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act |
| | | Overfill Test Date | 04/17/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----------------|
| Tank Code | 06 | Tank Age | 27 | Tank Installed Date | 04/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4294 | Spill Test Date | 04/17/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | 05/20/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 05/20/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/17/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 8
2001 Dewey Blvd
Butte, MT 59701 Silver Bow

System Facility ID:47-08686

Facility Code: 28457
Last Inspected On: 10/20/2022
Operating Permit Renewal Date: 10/20/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Butte 8 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Butte 8 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|----------------|
| Tank Code | 05 | Tank Age | 1 | Tank Installed Date | 06/04/2025 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6246 | Spill Test Date | 04/21/2025 | Piping Installed Date | 06/04/2025 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline, E10 | PLLD Test Date | 06/09/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 15000 | ATG Test Date | 06/09/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 04/21/2025 | | | ATG Type | | | | | |
| Tank Code | 06 | Tank Age | 1 | Tank Installed Date | 06/04/2025 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6247 | Spill Test Date | 04/21/2025 | Piping Installed Date | 06/04/2025 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 06/09/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 15000 | ATG Test Date | 06/09/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 04/21/2025 | | | ATG Type | | | | | |
| Tank Code | 07 | Tank Age | 1 | Tank Installed Date | 06/04/2025 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----------------|
| Tag Number | 6248 | Spill Test Date | 04/21/2025 | Piping Installed Date | 06/04/2025 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 06/09/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 6000 | ATG Test Date | 06/09/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 04/21/2025 | | | ATG Type | | | | | |
| Tank Code | 08 | Tank Age | 1 | Tank Installed Date | 06/04/2025 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6249 | Spill Test Date | 04/21/2025 | Piping Installed Date | 06/04/2025 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline, E10 | PLLD Test Date | 06/09/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 24000 | ATG Test Date | 06/09/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 04/21/2025 | | | ATG Type | | | | | |

Facility Summary in Silver Bow County in the City of Melrose

Location: MELROSE BAR
120 Main St
Melrose, MT 59743 Silver Bow

System Facility ID:47-07486

Facility Code: 28431
Last Inspected On: 11/15/2023
Operating Permit Renewal Date: 03/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Melrose License Holdings LLC;Rebecca Mergenthaler (406) 443-3360;(406) 799-3577 **melrosebar@yahoo.com**

Operator Contact: Lee Lively;Rebecca Mergenthaler (406) 799-3577 **brkcano@3rivers.net;melrosebar@yahoo.com**

Owner/Operator: Melrose License Holdings LLC (406) 443-3360 **melrosebar@yahoo.com**

Owner/Operator: Rebecca Mergenthaler (406) 443-3360 **melrosebar@yahoo.com**

Lee Lively, UST Class A Operator

Lee Lively, UST Class B Operator

Rebecca Mergenthaler, UST Class A Operator

Rebecca Mergenthaler, UST Class B Operator

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|------------------------------------|-----------------------|-------------------|
| Tank Code | 01 | Tank Age | 43 | Tank Installed Date | 05/08/1983 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4054 | Spill Test Date | 10/01/2024 | Piping Installed Date | 08/16/2011 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 07/20/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Gasoline | PLLD Test Date | 09/10/2025 | Tank/Piping CP Test Date | 02/03/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 09/10/2025 | Line Tightness Test Date | 10/06/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 10/01/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 02 | Tank Age | 43 | Tank Installed Date | 05/08/1983 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4055 | Spill Test Date | 10/01/2024 | Piping Installed Date | 08/16/2011 | Tank Construction | Lined Interior/Impressed Current | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 07/20/2023 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Impressed Current |
| Product | Diesel | PLLD Test Date | 09/10/2025 | Tank/Piping CP Test Date | 02/03/2021 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |

| | | | | | | | | | | | |
|-----------------|------|---------------------------|------------|---------------------------------|------------|--------------------------------------|---|---------------------------------|----------|-------------------|----|
| Capacity | 6000 | ATG Test Date | 09/10/2025 | Line Tightness Test Date | 10/06/2020 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 10/01/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Silver Bow County in the City of Rocker

Location: TOWN PUMP INC ROCKER
1000 Grizzly Trl
Rocker, MT 59701-9646 Silver Bow

System Facility ID:47-13173

Facility Code: 28501
Last Inspected On: 03/27/2025
Operating Permit Renewal Date: 09/15/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocker 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Rocker 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

Trentb@townpump.com

| | | | | | | | | | | | |
|--------------------|------------------|---------------------------|------------|---------------------------------|------------|--------------------------------------|--------------------------------------|---------------------------------|--------------------------------------|-----------------------|------------------|
| Tank Code | 01 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2635 | Spill Test Date | 04/16/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 03/27/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Approved Remote Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 02 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2636 | Spill Test Date | 07/31/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 03/27/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Approved Remote Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |

| | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--|----------------|
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | |
| Tank Code | 03 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 2637 | Spill Test Date | 07/31/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST |
| Tank Status | Currently in Use | MLLD Test Date | 02/25/2020 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Gasoline | PLLD Test Date | 03/27/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery |
| Capacity | 12000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Approved Remote Monitoring | Secondary Pipe Detection | Approved Remote Monitoring; Continuous Interstitial Monitoring | Energy Act |
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | |
| Tank Code | 04 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 2638 | Spill Test Date | 07/31/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST |
| Tank Status | Currently in Use | MLLD Test Date | 02/25/2020 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | 03/27/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery |
| Capacity | 12000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Approved Remote Monitoring | Secondary Pipe Detection | Approved Remote Monitoring | Energy Act |
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | |
| Tank Code | 05 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types |
| Tag Number | 2639 | Spill Test Date | 04/16/2024 | Piping Installed Date | 09/14/2006 | Tank Construction | | Piping Construction | None | AST |
| Tank Status | Currently in Use | MLLD Test Date | 03/27/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery |
| Capacity | 12000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Approved Remote Monitoring | Secondary Pipe Detection | Approved Remote Monitoring | Energy Act |
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Code | 06 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2640 | Spill Test Date | 04/16/2024 | Piping Installed Date | 09/14/2006 | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 03/27/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Approved Remote Monitoring | Secondary Pipe Detection | Approved Remote Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 07 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2641 | Spill Test Date | 04/16/2024 | Piping Installed Date | 09/14/2006 | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Approved Remote Monitoring | Secondary Pipe Detection | Approved Remote Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 08 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2642 | Spill Test Date | 07/31/2024 | Piping Installed Date | 09/14/2006 | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 03/27/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Approved Remote Monitoring | Secondary Pipe Detection | Approved Remote Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 09 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2643 | Spill Test Date | 04/16/2024 | Piping Installed Date | 09/14/2006 | Tank Construction | | Piping Construction | None | AST | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Status | Currently in Use | MLLD Test Date | 03/27/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Approved Remote Monitoring | Secondary Pipe Detection | Approved Remote Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 10 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2644 | Spill Test Date | 04/16/2024 | Piping Installed Date | 09/14/2006 | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 03/27/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Approved Remote Monitoring | Secondary Pipe Detection | Approved Remote Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 11 | Tank Age | 33 | Tank Installed Date | 06/01/1993 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2645 | Spill Test Date | 07/31/2024 | Piping Installed Date | | Tank Construction | | Piping Construction | None | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 03/27/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Approved Remote Monitoring | Secondary Pipe Detection | Approved Remote Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 12 | Tank Age | 27 | Tank Installed Date | 06/01/1999 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4103 | Spill Test Date | 04/16/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 03/27/2025 | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |

| | | | | | | | | | | | |
|-------------|---------------------|--------------------|------------|--------------------------|------------|-------------------------------|--|--------------------------|--|----------------|-----|
| Capacity | 8000 | ATG Test Date | 03/27/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 04/16/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 13 | Tank Age | 14 | Tank Installed Date | 11/01/2012 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Fiberglass Reinforced Plastic | Overfill Types | |
| Tag Number | 5375 | Spill Test Date | | Piping Installed Date | 05/07/2012 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Other | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Auto Dialer | Piping Type | Pressurized | CP Met Types | |
| Product | DEF (Not Regulated) | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Primary Pipe Detection | Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 07/25/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | | Secondary Pipe Detection | | Energy Act | Yes |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-450PLUS | | | | |