

Facility Summary in Sweet Grass County in the City of Big Timber

Location: THE FORT
228 Big Timber Loop
Big Timber, MT 59011 Sweet Grass

System Facility ID:49-02680

Facility Code: 28652
Last Inspected On: 06/22/2023
Operating Permit Renewal Date: 09/21/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: J Diamond L Inc;Jeffrey Cowell(406) 932-5992

Operator Contact: Justin Cowell(406) 932-5992justincowell@fortmt.com

Owner/Operator: J Diamond L Inc(406) 932-5992

Owner/Operator: Jeffrey L Cowell(406) 932-5992

Jeremy Frisk, UST Class B Operatorsports@fortmt.com

Justin Cowell, UST Class A Operatorjustincowell@fortmt.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|--------------------------------|
| Tank Code | 04 | Tank Age | 30 | Tank Installed Date | 08/01/1996 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 3229 | Spill Test Date | 02/17/2022 | Piping Installed Date | 06/25/2010 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel | PLLD Test Date | 06/22/2023 | Tank/Piping CP Test Date | 06/22/2023 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 06/22/2023 | Line Tightness Test Date | 02/19/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/13/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 05 | Tank Age | 30 | Tank Installed Date | 08/01/1996 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 3230 | Spill Test Date | 02/17/2022 | Piping Installed Date | 06/25/2010 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Diesel, Dyed | PLLD Test Date | 08/17/2022 | Tank/Piping CP Test Date | 09/19/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 4000 | ATG Test Date | 08/17/2022 | Line Tightness Test Date | 02/19/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|---|--------------------------|------------------------------------|----------------|--------------------------------|
| | | Overfill Test Date | 02/17/2022 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 06 | Tank Age | 30 | Tank Installed Date | 08/01/1996 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 3231 | Spill Test Date | 07/13/2023 | Piping Installed Date | 06/25/2010 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 08/17/2022 | Tank/Piping CP Test Date | 09/19/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 08/17/2022 | Line Tightness Test Date | 02/19/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | 07/13/2023 | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |
| Tank Code | 07 | Tank Age | 21 | Tank Installed Date | 10/31/2005 | Tank Material | Cathodically Protected Steel | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve;Flapper Valve |
| Tag Number | 5052 | Spill Test Date | | Piping Installed Date | 06/25/2010 | Tank Construction | | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Galvanic |
| Product | Gasoline | PLLD Test Date | 08/17/2022 | Tank/Piping CP Test Date | 09/19/2020 | Primary Tank Leak Detection | Automatic Tank Gauging 0.2 | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 20000 | ATG Test Date | 08/17/2022 | Line Tightness Test Date | 02/19/2024 | Secondary Tank Leak Detection | | Secondary Pipe Detection | ELLD 0.2 | Energy Act | No |
| | | Overfill Test Date | | | | ATG Type | Gilbarco-Veeder Root/TLS-350/Gilbarco EMC | | | | |

Facility Summary in Sweet Grass County in the City of Big Timber

Location: TOWN PUMP BIG TIMBER 2
20 A Big Timber Loop Rd
Big Timber, MT 59011 Sweet Grass

System Facility ID:49-09311

Facility Code: 28709
Last Inspected On: 03/18/2025
Operating Permit Renewal Date: 08/23/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Big Timber 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Big Timber 2 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----------------|
| Tank Code | 05 | Tank Age | 23 | Tank Installed Date | 04/30/2003 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4828 | Spill Test Date | 10/17/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/08/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 03/18/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/18/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 07/08/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 06 | Tank Age | 23 | Tank Installed Date | 04/30/2003 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4829 | Spill Test Date | 10/17/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/08/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 03/18/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 03/18/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 07/08/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----------------|
| Tank Code | 07 | Tank Age | 23 | Tank Installed Date | 04/30/2003 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4830 | Spill Test Date | 07/08/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/08/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/18/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 03/18/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 07/08/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 08 | Tank Age | 23 | Tank Installed Date | 04/30/2003 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 4831 | Spill Test Date | 07/08/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/08/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/18/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 03/18/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 07/08/2024 | | | ATG Type | Gilbarco-Veeder Root/TLS-450 | | | | |
| Tank Code | 09 | Tank Age | 4 | Tank Installed Date | 02/24/2022 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6050 | Spill Test Date | 10/17/2024 | Piping Installed Date | 02/24/2022 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/08/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 03/18/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 20000 | ATG Test Date | 03/18/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 07/08/2024 | | | ATG Type | | | | | |
| Tank Code | 10 | Tank Age | 4 | Tank Installed Date | 02/24/2022 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6051 | Spill Test Date | 02/15/2022 | Piping Installed Date | 02/24/2022 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/08/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----------------|
| Product | Gasoline | PLLD Test Date | 03/18/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 6000 | ATG Test Date | 03/18/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 07/08/2024 | | | ATG Type | | | | | |
| Tank Code | 11 | Tank Age | 4 | Tank Installed Date | 02/24/2022 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6052 | Spill Test Date | 10/17/2024 | Piping Installed Date | 02/24/2022 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/08/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/18/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 18000 | ATG Test Date | 03/18/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 07/08/2024 | | | ATG Type | | | | | |
| Tank Code | 12 | Tank Age | 4 | Tank Installed Date | 02/24/2022 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6053 | Spill Test Date | 07/08/2024 | Piping Installed Date | 02/24/2022 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/08/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | 03/18/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | Yes |
| Capacity | 12000 | ATG Test Date | 03/18/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 02/21/2022 | | | ATG Type | | | | | |
| Tank Code | 13 | Tank Age | 4 | Tank Installed Date | 04/05/2022 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6054 | Spill Test Date | 07/08/2024 | Piping Installed Date | 04/05/2022 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/08/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/18/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 30000 | ATG Test Date | 03/18/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 03/31/2025 | | | ATG Type | | | | | |

| | | | | | | | | | | | |
|-------------|---------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|----------------|
| Tank Code | 14 | Tank Age | 4 | Tank Installed Date | 04/05/2022 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6055 | Spill Test Date | 07/08/2024 | Piping Installed Date | 04/05/2022 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/08/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | 03/18/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 03/18/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 07/08/2024 | | | ATG Type | | | | | |
| Tank Code | 15 | Tank Age | 4 | Tank Installed Date | 04/05/2022 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6056 | Spill Test Date | 07/08/2024 | Piping Installed Date | 04/05/2022 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 07/08/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 03/18/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Continuous Interstitial Monitoring | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 6000 | ATG Test Date | 03/18/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Statistical Inventory Reconciliation | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | Yes |
| | | Overfill Test Date | 07/08/2024 | | | ATG Type | | | | | |
| Tank Code | 16 | Tank Age | 4 | Tank Installed Date | 04/05/2022 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Flapper Valve |
| Tag Number | 6057 | Spill Test Date | 02/21/2022 | Piping Installed Date | 04/05/2022 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | |
| Product | DEF (Not Regulated) | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 8000 | ATG Test Date | 04/06/2022 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | Yes |
| | | Overfill Test Date | | | | ATG Type | | | | | |

Facility Summary in Sweet Grass County in the City of Big Timber

Location: TOWN PUMP INC BIG TIMBER 1ST AVE
510 W 1st Ave
Big Timber, MT 59011 Sweet Grass

System Facility ID:49-13756

Facility Code: 28726
Last Inspected On: 04/29/2025
Operating Permit Renewal Date: 10/19/2028

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Big Timber 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Operator Contact: Trent Biggers

Trentb@townpump.com

Owner/Operator: Big Timber 1 Town Pump LLC

(406) 497-6700

environmental@townpump.com

Trent Biggers, UST Class A Operator

Trentb@townpump.com

Trent Biggers, UST Class B Global Operator

Trentb@townpump.com

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Code | 01 | Tank Age | 30 | Tank Installed Date | 08/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2652 | Spill Test Date | 11/06/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/29/2025 | Sump Tightness Test Date | 06/27/2024 | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 07/01/2025 | Line Tightness Test Date | 09/01/2015 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/27/2024 | | | ATG Type | Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 02 | Tank Age | 30 | Tank Installed Date | 10/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2653 | Spill Test Date | 11/06/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/29/2025 | Sump Tightness Test Date | 06/27/2024 | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 07/01/2025 | Line Tightness Test Date | 09/01/2015 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/27/2024 | | | ATG Type | Veeder Root/TLS-450PLUS | | | | |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Code | 03 | Tank Age | 30 | Tank Installed Date | 10/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2654 | Spill Test Date | 11/06/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/29/2025 | Sump Tightness Test Date | 06/27/2024 | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Gasoline | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 12000 | ATG Test Date | 07/01/2025 | Line Tightness Test Date | 09/01/2015 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/27/2024 | | | ATG Type | Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 04 | Tank Age | 30 | Tank Installed Date | 10/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2655 | Spill Test Date | 06/27/2024 | Piping Installed Date | 10/29/2020 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/27/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 07/01/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 07/01/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | 06/27/2024 | | | ATG Type | Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 05 | Tank Age | 30 | Tank Installed Date | 10/01/1996 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 2656 | Spill Test Date | 06/27/2024 | Piping Installed Date | 10/29/2020 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | | Sump Tightness Test Date | 06/27/2024 | Catastrophic L.D Type 3.0 | Electronic Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | 07/01/2025 | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 07/01/2025 | Line Tightness Test Date | | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | 06/27/2024 | | | ATG Type | Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 06 | Tank Age | 24 | Tank Installed Date | 05/01/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4649 | Spill Test Date | 06/27/2024 | Piping Installed Date | | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |

| | | | | | | | | | | | |
|-------------|------------------|--------------------|------------|--------------------------|------------|-------------------------------|--------------------------------------|--------------------------|--------------------------------------|----------------|------------------|
| Tank Status | Currently in Use | MLLD Test Date | 04/29/2025 | Sump Tightness Test Date | 06/27/2024 | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel, Dyed | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Statistical Inventory Reconciliation | Vapor Recovery | No |
| Capacity | 10000 | ATG Test Date | 07/01/2025 | Line Tightness Test Date | 09/01/2015 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Continuous Interstitial Monitoring | Energy Act | No |
| | | Overfill Test Date | 06/27/2024 | | | ATG Type | Veeder Root/TLS-450PLUS | | | | |
| Tank Code | 07 | Tank Age | 24 | Tank Installed Date | 05/01/2002 | Tank Material | Fiberglass Reinforced Plastic | Piping Material | Flexible Plastic | Overfill Types | Ball Float Valve |
| Tag Number | 4650 | Spill Test Date | 11/06/2024 | Piping Installed Date | 10/29/2020 | Tank Construction | Double-Walled | Piping Construction | Double Walled | AST | No |
| Tank Status | Currently in Use | MLLD Test Date | 04/29/2025 | Sump Tightness Test Date | 06/27/2024 | Catastrophic L.D Type 3.0 | Mechanical Line Leak Detector | Piping Type | Pressurized | CP Met Types | Non-corrodible |
| Product | Diesel | PLLD Test Date | | Tank/Piping CP Test Date | | Primary Tank Leak Detection | Statistical Inventory Reconciliation | Primary Pipe Detection | Continuous Interstitial Monitoring | Vapor Recovery | No |
| Capacity | 5000 | ATG Test Date | 07/01/2025 | Line Tightness Test Date | 09/01/2015 | Secondary Tank Leak Detection | Continuous Interstitial Monitoring | Secondary Pipe Detection | Statistical Inventory Reconciliation | Energy Act | No |
| | | Overfill Test Date | 11/06/2024 | | | ATG Type | Veeder Root/TLS-450PLUS | | | | |