

Facility Summary in Treasure County in the City of Hysham

Location: FRIENDLY CORNER
718 Elliot Ave
Hysham, MT 59038 Treasure

System Facility ID:52-06316

Facility Code: 29186
Last Inspected On: 06/26/2024
Operating Permit Renewal Date: 09/29/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Cross Petroleum Services Billings (406) 252-5519

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife

gcross@crosspetroleumservice.com;rlsrp@yahoo.com

Owner/Operator: Cross Petroleum Services Billings (406) 252-5519

Greg Cross, UST Class A Operator
Greg Cross, UST Class A Operator
R J Serpe, UST Class A Operator
R J Serpe, UST Class A Operator
R J Serpe, UST Class B Global Operator
R J Serpe, UST Class B Global Operator
Shelli Thrower, UST Class B Operator
Shelli Thrower, UST Class B Operator
Timothy Fife, UST Class A Operator
Timothy Fife, UST Class A Operator

gcross@crosspetroleumservice.com
gcross@crosspetroleumservice.com
rlsrp@yahoo.com
rlsrp@yahoo.com
rlsrp@yahoo.com
rlsrp@yahoo.com
seves74@hotmail.com
seves74@hotmail.com

Tank Code	01	Tank Age	46	Tank Installed Date	08/01/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1405	Spill Test Date	06/26/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/26/2024	Line Tightness Test Date	03/24/2012	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/19/2024			ATG Type	Incon/TS-550 EVO				
Tank Code	02	Tank Age	46	Tank Installed Date	08/01/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm

Tag Number	1406	Spill Test Date	06/26/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/26/2024	Line Tightness Test Date	04/01/2012	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/19/2024			ATG Type	Incon/TS-550 EVO				
Tank Code	03	Tank Age	46	Tank Installed Date	08/01/1979	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1407	Spill Test Date	06/26/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/26/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	3000	ATG Test Date	06/26/2024	Line Tightness Test Date	04/05/2012	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/19/2024			ATG Type	Incon/TS-550 EVO				

Facility Summary in Treasure County in the City of Hysham

Location: VALLEY FARMERS SUPPLY HYSHAM
121 Elliot Ave
Hysham, MT 59038 Treasure

System Facility ID:52-01905

Facility Code: 29169
Last Inspected On: 10/26/2023
Operating Permit Renewal Date: 02/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Valley Farmers Supply **(406) 967-3100** **sblack@vfarmers.com**

Operator Contact: Scott Black **(406) 967-3100** **sblack@vfarmers.com**

Owner/Operator: Valley Farmers Supply (406) 967-3100 sblack@vfarmers.com

- Earl Mitchell, UST Class B Operator
sblack@vfarmers.com
- Earl Mitchell, UST Class B Operator
emitchell@vfarmers.com
- Scott Black, UST Class A Operator
emitchell@vfarmers.com
- Scott Black, UST Class A Operator
sblack@vfarmers.com
- Scott Black, UST Class B Global Operator
sblack@vfarmers.com
- Scott Black, UST Class B Global Operator
sblack@vfarmers.com
- Shawn Hedges, UST Class B Operator
sblack@vfarmers.com
- Shawn Hedges, UST Class B Operator
sblack@vfarmers.com
- Sheryl Warren, UST Class B Operator
sblack@vfarmers.com
- Sheryl Warren, UST Class B Operator
sblack@vfarmers.com

Tank Code	03	Tank Age	35	Tank Installed Date	07/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3144	Spill Test Date	10/26/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/26/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	10/26/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/26/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	04	Tank Age	35	Tank Installed Date	07/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3145	Spill Test Date	10/26/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic

Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/26/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	10/26/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/26/2023			ATG Type	Veeder Root/TLS-300				