Facility Summary in YELLOWSTONE County in the City of BALLANTINE

Location: TIGER TOWN
2253 S 16TH RD
BALLANTINE, MT 59006 YELLOWSTONE

Contact: Carol & James Hayes, (406) 967-2895

Sys Fac ID: 56-06325
Last Inspected On: 4/4/2014
Operating Permit Renewal Date: 7/10/2017

Owners/Operators: Carol Hayes, Owner (406)-967-2753 DBA TIGER TOWN
PO BOX 26
BALLANTINE MT 59006-0026

Carol Hayes, UST Class A Operator
Patti Anderson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	24	11/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3310			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		4/1/2014	Automatic Tank Gauging 0.2	Deferred	
3,000			TS-1001 , Incon		
10	24	11/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3311			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/1/2014	Automatic Tank Gauging 0.2	Deferred	
4,000			TS-1001 , Incon		
11	24	11/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3312			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/1/2014	Automatic Tank Gauging 0.2	Deferred	
5,000			TS-1001 , Incon		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 51
1544 BROADWATER AVE
BILLINGS, MT 59102 YELLOWSTONE
Contact: (406) 651-0001

Sys Fac ID: 56-00050
Last Inspected On: 2/23/2015
Operating Permit Renewal Date: 7/14/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Ian Johnstone, UST Class A Operator
Nicholas Merritt, UST Class A Operator
Nicholas Merritt, UST Class B Operator
Darcy Ziegler, UST Class B Operator
Nicholas Merritt, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	19	10/30/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3074			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
5	19	10/30/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3075			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
6	19	10/30/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3076			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		2/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 5 CORNERS EXPRESS
5550 US HIGHWAY 312
BILLINGS, MT 59105 YELLOWSTONE

Contact: Mykel Stockton, (406) 245-6376

Sys Fac ID: 56-00062
Last Inspected On: 11/14/2016
Operating Permit Renewal Date: 11/28/2019

Owners/Operators: Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756
BILLINGS MT 59103-1756

Mykel Stockton, UST Class A Operator
Joey McConnell, UST Class B Global Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	00	6/30/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5653		6/30/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		6/29/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
5	00	6/30/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5654		6/30/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		6/29/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
6	00	6/30/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5655		6/30/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		6/29/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 5 CORNERS EXPRESS
5550 US HIGHWAY 312
BILLINGS, MT 59105 YELLOWSTONE

Contact: Mykel Stockton, (406) 245-6376

Sys Fac ID: 56-00062
Last Inspected On: 11/14/2016
Operating Permit Renewal Date: 11/28/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	00	6/30/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5656		6/30/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		6/29/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 3 GS CONVENIENCE CENTER 3
730 LAKE ELMO DR
BILLINGS, MT 59105 YELLOWSTONE
Contact: (406) 255-0688

Sys Fac ID: 56-00063
Last Inspected On: 10/3/2014
Operating Permit Renewal Date: 1/8/2018

Owners/Operators: SNG Inc 3, Owner (406)-245-0161 4410 STATE AVE
BILLINGS MT 59101-5060

KELLY GROSLACK, UST Class A Operator
Larry Groslack, UST Class A Operator
TAMI MAUCH, UST Class A Operator
KELLY GROSLACK, UST Class B Operator
Larry Groslack, UST Class B Operator
TAMI MAUCH, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	12/20/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1871			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		9/30/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
10,000		9/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	31	12/20/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1872			Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/30/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
10,000		9/29/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	31	12/20/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1873			Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/30/2014	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor, MLLD Line Tightness Testing	
10,000		9/29/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: RIMROCK SUBARU INC
324 S 24TH ST W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Scott Hazlet, (406) 655-8572

Sys Fac ID: 56-00066
Last Inspected On: 4/29/2016
Operating Permit Renewal Date: 6/7/2019

Owners/Operators:

Rimrock Subaru Inc, Owner	(406)-651-5200	PO BOX 80208 BILLINGS MT 59108
Jack McCoy, Operator	(406)-651-5000	RIMROCK AUTO 324 S 24TH ST W BILLINGS MT 59102-5644
Scott Haslet, UST Class A Operator		
Scott Haslet, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	25	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1863			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		5/4/2016	Automatic Tank Gauging 0.2	Deferred	
1,000		4/7/2010	OPW 1500 , OPW		
5	25	10/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1864			None	None	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Waste Oil		5/4/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
1,000		5/4/2016	OPW 1500 , OPW		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ARCHIE COCHRANE MOTORS
2133 KING AVE W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Garry Brayko, (406) 656-1100

Sys Fac ID: 56-00123
Last Inspected On: 10/24/2014
Operating Permit Renewal Date: 3/26/2018

Owners/Operators: Archie Cochrane Motors, Owner (406)-656-1100 PO BOX 80605
BILLINGS MT 59108-0605

LAUREN GOPP, UST Class A Operator
Don Hofer, UST Class A Operator
Don Hofer, UST Class B Operator
LAUREN GOPP, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	23	8/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
390			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/24/2014	Manual Interstitial Monitor	Deferred	
2,000					
5	23	8/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
391			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/3/2011	Manual Interstitial Monitor	Deferred	
1,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CONOMART SUPERSTORE 4
1240 S 27TH ST
BILLINGS, MT 59101 YELLOWSTONE

Sys Fac ID: 56-00503
Last Inspected On: 6/14/2016
Operating Permit Renewal Date: 9/28/2019

Contact: Dennis Whitmore, (406) 252-4661

Owners/Operators:

C Store Properties LLC, Owner	(406)-651-5101	PO BOX 80391 BILLINGS MT 59108
GM Cono Stores LLC, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107

Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Ken Jackson, UST Class A Operator
Charlie McHenry, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Laura Geffre, UST Class B Operator
Kim Hauck, UST Class B Operator
Roger Schmechel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1148			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/28/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		8/23/2010	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
5	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1149			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/28/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		8/22/2010	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CONOMART SUPERSTORE 4
1240 S 27TH ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Dennis Whitmore, (406) 252-4661

Sys Fac ID: 56-00503
Last Inspected On: 6/14/2016
Operating Permit Renewal Date: 9/28/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1150		4/1/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		5/28/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		5/3/2015	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN PUMP INC BILLINGS 1
1028 US HIGHWAY 87 E
BILLINGS, MT 59101 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-00767
Last Inspected On: 2/3/2015
Operating Permit Renewal Date: 2/6/2018

Owners/Operators: Billings Holdings LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
6	20	10/2/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4583			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	20	10/2/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2665			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
8	20	10/2/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2666			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN PUMP INC BILLINGS 1
1028 US HIGHWAY 87 E
BILLINGS, MT 59101 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-00767
Last Inspected On: 2/3/2015
Operating Permit Renewal Date: 2/6/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	20	10/2/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
2667			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
10	17	2/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
3921			Double-Walled	Double-Walled	Yes
Currently in Use		1/1/2009	Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MSU FACILITY SERVICES BLDG
1500 UNIVERSITY DR
BILLINGS, MT 59101 YELLOWSTONE

Contact: Ken Billman, (406) 657-2309

Sys Fac ID: 56-00904
Last Inspected On: 4/27/2015
Operating Permit Renewal Date: 8/21/2018

Owners/Operators: Montana State University Billings, Owner (406)-657-2309 1500 UNIVERSITY DR BILLINGS MT 59101-0252

Brian Mackey, UST Class A Operator
Jason McGimpsey, UST Class A Operator
John Grimstad, UST Class B Operator
Brian Mackey, UST Class B Operator
Brian Mackey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
846			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Deferred	
1,000			TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS LOGAN INTERNATIONAL AIRPORT UST
1901 TERMINAL CIR STE 216
BILLINGS, MT 59105 YELLOWSTONE

Contact: Donald (Kim) Annin, (406) 657-8482

Sys Fac ID: 56-00909
Last Inspected On: 6/9/2016
Operating Permit Renewal Date: 9/4/2019

Owners/Operators: Billings Logan International Airport, Owner (406)-657-8482 1901 TERMINAL CIR STE 216 BILLINGS MT 59105-1991

Donald Annin, UST Class A Operator
Shawn Gaalswyk, UST Class A Operator
Shawn Gaalswyk, UST Class B Operator
Colter Smith, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	29	1/1/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
623			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		6/6/2016	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
3	23	10/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
624			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/9/2016	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	23	10/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
625			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		6/9/2016	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS LOGAN INTERNATIONAL AIRPORT UST
1901 TERMINAL CIR STE 216
BILLINGS, MT 59105 YELLOWSTONE

Contact: Donald (Kim) Annin, (406) 657-8482

Sys Fac ID: 56-00909
Last Inspected On: 6/9/2016
Operating Permit Renewal Date: 9/4/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
17	23	10/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4826			Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Waste Oil		6/9/2016	Manual Interstitial Monitor	MLLD Line Tightness Testing	
500		6/9/2016			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: NORTHWESTERN ENERGY FACILITY
405 S 20TH ST W
BILLINGS, MT 59102 YELLOWSTONE
Contact: Darren Brockel, (406) 655-2521

Sys Fac ID: 56-01188
Last Inspected On: 8/29/2014
Operating Permit Renewal Date: 12/9/2017

Owners/Operators: Northwestern Energy, Owner (406)-655-2521 405 S 20TH ST W BILLINGS MT 59102
John Habeger, UST Class A Operator
Darren Brockel, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	36	4/30/1980	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff), High Level Alarm
1683			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		4/4/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		11/1/2016	EECO 1500 , EMCO Electronics		
4	36	4/30/1980	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff), High Level Alarm
1684			None	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		4/4/2014	Automatic Tank Gauging 0.2	Deferred	
2,000			EECO 1500 , EMCO Electronics		
5	36	4/30/1980	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff), High Level Alarm
1685			None	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		4/4/2014	Automatic Tank Gauging 0.2	Deferred	
4,000			EECO 1500 , EMCO Electronics		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CARDLOCK #3
1004 4TH AVE N
BILLINGS, MT 59101 YELLOWSTONE

Sys Fac ID: 56-01290
Last Inspected On: 6/23/2016
Operating Permit Renewal Date: 8/16/2019

Contact: Roger Schmechel, (406) 252-4661

Owners/Operators:

W G Properties LLC, Owner	(406)-651-5101	PO BOX 80391 BILLINGS MT 59108-0391
City Service Valcon LLC DBA GM Petroleum Distributors, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107

Jay Brookie, UST Class A Operator
Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Cody P Oconnor, UST Class A Operator
Roger Schmechel, UST Class A Operator
Laura Geffre, UST Class B Operator
Cody P Oconnor, UST Class B Operator
Roger Schmechel, UST Class B Operator
Jay Brookie, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	40	2/4/1976	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
752		6/23/2016	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/8/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
2	40	1/1/1976	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
753			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/8/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CARDLOCK #3
1004 4TH AVE N
BILLINGS, MT 59101 YELLOWSTONE
Contact: Roger Schmechel, (406) 252-4661

Sys Fac ID: 56-01290
Last Inspected On: 6/23/2016
Operating Permit Renewal Date: 8/16/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
3	40	2/4/1976	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
754		6/23/2016	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/8/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
4	40	2/4/1976	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
755		6/23/2016	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/8/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
5	40	2/4/1976	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
756			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		7/8/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: REDDAWAY
833 MULLOWNEY LN
BILLINGS, MT 59101 YELLOWSTONE

Contact: Fort Gary, (406) 252-3877

Sys Fac ID: 56-01340
Last Inspected On: 4/7/2016
Operating Permit Renewal Date: 5/30/2019

Owners/Operators: Reddaway, Owner (913)-344-3367 10990 ROE AVE MS A-650 OVERLAND PARK KS 66211

Gary Fort, UST Class A Operator
Gary Fort, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	23	8/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3154			None	None	Yes
Currently in Use		8/1/2003	Not Required	Safe Suction	Galvanic
Diesel		4/7/2016	Automatic Tank Gauging 0.2	Deferred	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 56
16 SHILOH RD
BILLINGS, MT 59106 YELLOWSTONE

Contact: Sean Hurley, (509) 535-7701

Sys Fac ID: 56-01664
Last Inspected On: 2/17/2015
Operating Permit Renewal Date: 7/9/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Ian Johnstone, UST Class A Operator
Darcy Ziegler, UST Class B Operator
Karina Serrano, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	12/31/1984	Bare Steel	Flexible Plastic	High Level Alarm
4344			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		2/17/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	31	12/31/1984	Bare Steel	Flexible Plastic	High Level Alarm
4345			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/17/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	27	11/10/1989	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4346			Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		2/17/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 57
1046 N 27TH ST
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 252-9654

Sys Fac ID: 56-01665
Last Inspected On: 2/9/2015
Operating Permit Renewal Date: 7/11/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Ian Johnstone, UST Class A Operator
Chuck Crane, UST Class B Operator
ROBERT HAYS, UST Class B Operator
Ian Johnstone, UST Class B Global Operator
Katherine Warmus, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	18	1/28/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
3080			Double-Walled	Double-Walled	Yes
Currently in Use		1/8/2009	Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/8/2009	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
15,000			Gilbarco EMC Basic , Gilbarco		
4	18	1/28/1998	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
3081			Double-Walled	Double-Walled	Yes
Currently in Use		1/8/2009	Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		1/8/2009	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MT STATE WOMENS PRISON
701 S 27TH ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Dennis Wolfe, (406) 247-5133

Sys Fac ID: 56-01757
Last Inspected On: 3/10/2015
Operating Permit Renewal Date: 4/4/2018

Owners/Operators: Montana State Womens Prison, Owner (406)-247-5100 701 S 27TH ST BILLINGS MT 59101-4511

Ron Himmelspach, UST Class A Operator
Dennis Wolff, UST Class A Operator
Ron Himmelspach, UST Class B Operator
Dennis Wolff, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	11	10/1/2005	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
5053		2/10/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Diesel		2/10/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,000			TLS-300 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DEACONESS BILLINGS CLINIC 9TH AVE
2800 10TH AVE N
BILLINGS, MT 59101 YELLOWSTONE

Contact: Mitch Goplen, (406) 657-4030

Sys Fac ID: 56-02067
Last Inspected On: 6/1/2015
Operating Permit Renewal Date: 9/29/2018

Owners/Operators: Deaconess Clinic Billings, Owner (406)-657-4036 2800 10TH AVE N BILLINGS MT 59101-0703

Cody Anderson, UST Class A Operator
Lloyd Newman, UST Class A Operator
Cody Anderson, UST Class B Operator
Lloyd Newman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	2/1/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
826		9/17/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Diesel		2/27/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SAINT VINCENT HOSPITAL & HEALTH CENTER
1233 N 30TH ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Kevin Maddox, (406) 657-7000

Sys Fac ID: 56-02666
Last Inspected On: 12/23/2015
Operating Permit Renewal Date: 1/22/2019

Owners/Operators: Saint Vincent Hospital & Health Center, Owner (406)-237-3065 PO BOX 35200 BILLINGS MT 59107-5200

Kevin Maddox, UST Class A Operator
Kevin Maddox, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	17	11/8/1999	Bare Steel	Copper	
1953	Yes	11/9/2012	None	Secondary Containment Chase	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
4,000		1/13/2016	Auto Stik II , EBW		
6	17	11/8/1999	Bare Steel	Copper	
1954	Yes	11/9/2012	None	Secondary Containment Chase	Yes
Currently in Use			Auto Dialer	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
4,000		1/13/2016	Auto Stik II , EBW		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SYSCO FOOD SERVICES OF MONTANA MONAD RD
1509 MONAD RD
BILLINGS, MT 59101 YELLOWSTONE

Sys Fac ID: 56-03530
Last Inspected On: 4/24/2014
Operating Permit Renewal Date: 6/11/2017

Contact: Greg Murray, (406) 247-1100

Owners/Operators: Sysco Food Services of Montana, Owner (406)-247-1131 PO BOX 31198
BILLINGS MT 59107-1198

Greg Murray, UST Class A Operator
Greg Murray, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	08	12/27/2007	Unknown	Flexible Plastic	
5144	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		11/23/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
5	08	12/27/2007	Unknown	Flexible Plastic	
5145	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		11/21/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: YELLOWSTONE COUNTY PUBLIC WORKS DEPT
3321 KING AVE E
BILLINGS, MT 59101 YELLOWSTONE

Contact: John Ostlund, (406) 256-6812

Sys Fac ID: 56-03658
Last Inspected On: 6/11/2015
Operating Permit Renewal Date: 9/29/2018

Owners/Operators: Yellowstone County Public Works Dept, Owner (406)-256-6812 3321 KING AVE E
BILLINGS MT 59101-5533

Kim Peterson, UST Class A Operator
Oscar Thompson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	17	6/1/1999	Cathodically Protected Steel	Flexible Plastic	
4092		6/11/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Waste Oil		6/11/2015	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: POLY CONOCO
1704 POLY DR
BILLINGS, MT 59102 YELLOWSTONE
Contact: Larry Sperry, (406) 245-6944

Sys Fac ID: 56-04414
Last Inspected On: 4/7/2016
Operating Permit Renewal Date: 7/14/2019

Owners/Operators: Poly Conoco Inc, Owner (406)-245-6944 1704 POLY DR BILLINGS MT 59102-1729
Lawrence Sperry, UST Class A Operator
Lawrence Sperry, UST Class B Operator

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
5	18	2/11/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4718			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		4/5/2016	Gilbarco EMC Basic , Gilbarco		
6	18	2/11/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4719			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
7,000		4/5/2016	Gilbarco EMC Basic , Gilbarco		
7	18	2/11/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4720			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		4/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
3,000		4/5/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MEADOW GOLD DAIRIES INC BILLINGS
109 S 28TH ST
BILLINGS, MT 59101 YELLOWSTONE
Contact: Tim Diet, (406) 252-2118

Sys Fac ID: 56-04464
Last Inspected On: 5/19/2015
Operating Permit Renewal Date: 10/1/2018

Owners/Operators: Meadow Gold Dairies Inc Billings, Owner (406)-252-2118 109 S 28TH ST BILLINGS MT 59101-4134
WADE BARMAN, UST Class A Operator
FRANK COOK, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	27	8/7/1989	Cathodically Protected Steel	Steel	High Level Alarm
4264			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		5/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
10,000			EECO 1500 , EMCO Electronics		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: FIRST STUDENT INC
425 SUGAR AVE PO BOX 31133
BILLINGS, MT 59101 YELLOWSTONE

Contact: Fernando Crosa, (406) 248-3667

Sys Fac ID: 56-04467
Last Inspected On: 6/18/2016
Operating Permit Renewal Date:

Owners/Operators: FIRST STUDENT INC, Owner (513)-241-2200 600 VINE ST STE 1400
CINCINNATI OH 45202-2426

Philip Steadman, UST Class A Operator
Philip Steadman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	19	7/25/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
1869			Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Not Applicable
Diesel		9/28/2011	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
12,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: UNITED PARCEL SERVICE BILLINGS
1830 LAMPMAN DR
BILLINGS, MT 59102 YELLOWSTONE

Sys Fac ID: 56-04542
Last Inspected On: 2/19/2016
Operating Permit Renewal Date: 3/22/2019

Contact: Scott Oleson, (406) 652-8772

Owners/Operators:

United Parcel Service, Inc, Owner	(503)-978-7678	6707 N BASIN AVE PORTLAND OR 97217
United Parcel Service Plant Engineering Dept, Operator	(206)-621-6261	4455 7TH AVE S SEATTLE WA 98108

Robert Counts, UST Class A Operator
Treair Smith, UST Class A Operator
Russell Stott, UST Class A Operator
Paul Vandehey, UST Class A Operator
Robert Counts, UST Class B Operator
Russell Stott, UST Class B Operator
Treair Smith, UST Class B Global Operator
Paul Vandehey, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	23	7/20/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2183			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
12,000		2/19/2016	TLS-350/Gilbarco EMC , Veeder Root		
6	23	7/20/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2184			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
12,000		2/19/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: STOCKTON OIL CO 4TH AVE N
1607 4TH AVE N
BILLINGS, MT 59101 YELLOWSTONE

Contact: Joey McConnell, (406) 245-6376

Sys Fac ID: 56-04839
Last Inspected On: 11/26/2013
Operating Permit Renewal Date: 12/3/2016

Owners/Operators: Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756
BILLINGS MT 59103-1756

Mykel Stockton, UST Class A Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Mykel Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	36	3/26/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1988			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/1/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000					
5	24	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1989			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/1/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000					
6	24	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1990			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/1/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					
7	24	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1991			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/1/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: STOCKTON OIL CO 4TH AVE N
1607 4TH AVE N
BILLINGS, MT 59101 YELLOWSTONE

Contact: Joey McConnell, (406) 245-6376

Sys Fac ID: 56-04839
Last Inspected On: 11/26/2013
Operating Permit Renewal Date: 12/3/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	24	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1992			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/1/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					
9	24	4/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1993			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/1/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					
10	22	7/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	
			None	None	Yes
Currently in Use				Not Listed	
Oil/Water Separator			Automatic Tank Gauging 0.2	MLLD Line Tightness Testing, Deferred	
1,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 3 GS CONVENIENCE CENTER STATE AVE
4410 STATE AVE
BILLINGS, MT 59101 YELLOWSTONE

Sys Fac ID: 56-04946
Last Inspected On: 8/25/2016
Operating Permit Renewal Date: 11/5/2019

Contact: Larry or Kelly Grosulak, (406) 256-6246

Owners/Operators: SNG Inc 3, Owner (406)-245-0161 4410 STATE AVE
BILLINGS MT 59101-5060

Larry Groslack, Operator (406)-256-6246 4410 STATE AVE
BILLINGS MT 59101-5060

KELLY GROSLACK, UST Class A Operator
Larry Groslack, UST Class A Operator
TAMI MAUCH, UST Class A Operator
KELLY GROSLACK, UST Class B Operator
Larry Groslack, UST Class B Operator
TAMI MAUCH, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	03	4/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5400		5/1/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes
4	03	4/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5401		5/1/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 3 GS CONVENIENCE CENTER STATE AVE
4410 STATE AVE
BILLINGS, MT 59101 YELLOWSTONE

Contact: Larry or Kelly Grosulak, (406) 256-6246

Sys Fac ID: 56-04946
Last Inspected On: 8/25/2016
Operating Permit Renewal Date: 11/5/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	03	4/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5402		5/1/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SOCO EXPRESS 10
5400 LAUREL RD
BILLINGS, MT 59101 YELLOWSTONE
Contact: Michael Stockton, (406) 245-6376

Sys Fac ID: 56-04951
Last Inspected On: 3/5/2015
Operating Permit Renewal Date:

Owners/Operators: Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756 BILLINGS MT 59103-1756
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	25	5/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1994			None	None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/9/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		1/15/2005	TLS-350/Gilbarco EMC , Veeder Root		
6	25	5/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1995			None	None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/9/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		11/5/2008	TLS-350/Gilbarco EMC , Veeder Root		
7	25	5/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1996			None	None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/9/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		11/5/2008	TLS-350/Gilbarco EMC , Veeder Root		
8	25	5/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1997			None	None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		2/9/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		11/5/2008	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SOCO EXPRESS 10
5400 LAUREL RD
BILLINGS, MT 59101 YELLOWSTONE
Contact: Michael Stockton, (406) 245-6376

Sys Fac ID: 56-04951
Last Inspected On: 3/5/2015
Operating Permit Renewal Date:

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	25	5/1/1991	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1998			None	None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		2/9/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		11/5/2008	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SOCO EXPRESS
1503 GRAND AVE
BILLINGS, MT 59102 YELLOWSTONE
Contact: (406) 256-0386

Sys Fac ID: 56-04954
Last Inspected On: 2/12/2014
Operating Permit Renewal Date:

Owners/Operators: Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756 BILLINGS MT 59103-1756

Mykel Stockton, UST Class A Operator
Joey McConnell, UST Class B Global Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Mykel Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	28	6/1/1988	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3780			None	none	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/12/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000					
4	30	3/26/1986	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3781			None	none	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/12/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000					
5	30	3/26/1986	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3782			None	none	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/12/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SOCO EXPRESS 15TH & BROADWATER
1503 BROADWATER AVE
BILLINGS, MT 59102 YELLOWSTONE
Contact: Mykel Stockton, (406) 245-6376

Sys Fac ID: 56-04956
Last Inspected On: 12/23/2014
Operating Permit Renewal Date: 2/19/2018

Owners/Operators: Stockton Oil Company, Owner/Operator (406)-245-6376 PO BOX 1756 BILLINGS MT 59103-1756

Mykel Stockton, UST Class A Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Mykel Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	39	3/26/1977	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3751			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/22/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
8,000					
2	47	3/26/1969	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3752			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/22/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
8,000					
3	47	3/26/1969	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3753			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/22/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
8,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 3 GS CONVENIENCE CENTER E WICKS LANE
1221 WICKS LN
BILLINGS, MT 59105 YELLOWSTONE

Contact: Larry Grosulak, (406) 670-0085

Sys Fac ID: 56-04957
Last Inspected On: 3/30/2015
Operating Permit Renewal Date: 3/31/2018

Owners/Operators: SNG Inc 3, Owner (406)-245-0161 4410 STATE AVE
BILLINGS MT 59101-5060

KELLY GROSLACK, UST Class A Operator
Larry Groslack, UST Class A Operator
TAMI MAUCH, UST Class A Operator
KELLY GROSLACK, UST Class B Operator
Larry Groslack, UST Class B Operator
TAMI MAUCH, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	02	9/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5532		12/17/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		12/17/2014	TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	
4	02	9/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5533		12/17/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		12/17/2014	TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	
5	02	9/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5534		12/17/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		12/17/2014	TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: PACIFIC SUPPLY
600 DANIEL ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Dennis Yonts, (406) 254-8876

Sys Fac ID: 56-04965
Last Inspected On: 3/14/2014
Operating Permit Renewal Date: 5/14/2017

Owners/Operators:

Pacific Coast Building Products, Owner	(916)-971-2301	PO BOX 419074 RANCHO CORDOVA CA 95741-9074
Dennis Yonts, Operator	(406)-245-8876	600 DANIEL ST BILLINGS MT 59101-0637

Ryan Eklund, UST Class A Operator
Kate Renner, UST Class A Operator
Dennis Yonts, UST Class A Operator
Ryan Eklund, UST Class B Operator
Kayla Wittman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	23	11/1/1993	Fiberglass Reinforced Plastic	Steel	Flapper Valve (Auto Shutoff)
4350			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Continuous Interstitial Monitor	Deferred	
10,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DONS EXPRESS CENTER
2344 CENTRAL AVE
BILLINGS, MT 59102 YELLOWSTONE

Contact: Michael Stockton, (406) 245-6376

Sys Fac ID: 56-05072
Last Inspected On: 7/17/2014
Operating Permit Renewal Date: 9/25/2017

Owners/Operators: Automatic Car Wash Inc, Owner (406)-248-2558 PO BOX 1278
BILLINGS MT 59103-1278

Mykel Stockton, UST Class A Operator
Christopher Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	22	11/8/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2002			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
20,000		7/17/2014	TLS-350/Gilbarco EMC , Veeder Root		
6	22	11/8/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2003			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		7/17/2014	TLS-350/Gilbarco EMC , Veeder Root		
7	22	11/8/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2004			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		7/17/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: LOCKWOOD INTERSTATE EXXON
1031 US HIGHWAY 87 E
BILLINGS, MT 59101 YELLOWSTONE

Sys Fac ID: 56-05074
Last Inspected On: 1/30/2015
Operating Permit Renewal Date: 2/7/2018

Contact: Michael Stockton, (406) 245-6376

Owners/Operators: Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756 BILLINGS MT 59103-1756

Mykel Stockton, UST Class A Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Mykel Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	11/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2006			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		12/12/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		6/25/2014	Gilbarco EMC Basic , Gilbarco		
2	23	11/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2005			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		12/12/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		6/25/2014	Gilbarco EMC Basic , Gilbarco		
7	28	11/30/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3677			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/12/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		6/25/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: LOCKWOOD INTERSTATE EXXON
1031 US HIGHWAY 87 E
BILLINGS, MT 59101 YELLOWSTONE

Contact: Michael Stockton, (406) 245-6376

Sys Fac ID: 56-05074
Last Inspected On: 1/30/2015
Operating Permit Renewal Date: 2/7/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	28	11/30/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3676			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/12/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		6/25/2014	Gilbarco EMC Basic , Gilbarco		
10	28	11/30/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3675			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/12/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		6/25/2014	Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MERIDIAN AUTOMOTIVE SERVICE INC
1240 AVENUE C
BILLINGS, MT 59102 YELLOWSTONE

Sys Fac ID: 56-05077
Last Inspected On: 7/10/2015
Operating Permit Renewal Date:

Contact: Richard Skewis, (406) 259-6922

Owners/Operators: Meridian Automotive Service LLC, Owner (406)-259-6922 1240 AVENUE C
BILLINGS MT 59102-3238

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	22	1/11/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3182			None	none	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		7/2/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
2,000			Gilbarco EMC Basic , Gilbarco		
6	22	1/11/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3183			None	none	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		7/2/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
4,000			Gilbarco EMC Basic , Gilbarco		
7	22	1/11/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3184			None	none	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		7/2/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CASEY'S CORNER #10
3443 CENTRAL AVE
BILLINGS, MT 59102 YELLOWSTONE

Sys Fac ID: 56-05085
Last Inspected On: 4/1/2016
Operating Permit Renewal Date: 6/14/2019

Contact: Jason Shanley, (406) 587-0702

Owners/Operators:

Story Distributing Co, Owner	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771-1201
Jason Shanley, Operator	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771-1201

Jeffrey Fletcher, UST Class A Operator
Gary Scales, UST Class A Operator
Ethan Granzow, UST Class B Operator
Gary Scales, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	21	5/1/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2009		6/30/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		2/16/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		1/7/2016	TLS-450 , Veeder Root		
6	21	5/1/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2007		6/30/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/16/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		1/7/2016	TLS-450 , Veeder Root		
7	21	5/1/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4473		6/30/2014	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/16/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		1/7/2016	TLS-450 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 3 G'S CONVENIENCE STORE
1425 US HIGHWAY 87 E
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 252-9763

Sys Fac ID: 56-05086
Last Inspected On: 11/16/2013
Operating Permit Renewal Date: 12/31/2016

Owners/Operators: VESTA VENTURES LLP, Owner (406)-656-8402 5629 BILLY CASPER DR BILLINGS MT 59106-1053

KELLY GROSLACK, UST Class A Operator
Larry Groslack, UST Class A Operator
JERRY KLEIN, UST Class A Operator
TAMI MAUCH, UST Class A Operator
KELLY GROSLACK, UST Class B Operator
Larry Groslack, UST Class B Operator
TAMI MAUCH, UST Class B Operator
JERRY KLEIN, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	41	4/25/1975	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1151			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		9/11/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		9/11/2013			
2	41	4/25/1975	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1152			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/11/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		9/11/2013			
3	41	4/25/1975	Bare Steel	Fiberglass Reinforced Plastic	Ball Float Valve
1153			Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/11/2013	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		9/11/2013			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CONO MART SUPER STORE 10
11 W WICKS LN
BILLINGS, MT 59105 YELLOWSTONE

Contact: Dennis Whitmore, (406) 252-4661

Sys Fac ID: 56-05088
Last Inspected On: 11/21/2014
Operating Permit Renewal Date: 3/3/2018

Owners/Operators:

B & A Holding LLC, Owner	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107
GM Cono Stores LLC, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107

Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Ken Jackson, UST Class A Operator
Charlie McHenry, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Laura Geffre, UST Class B Operator
Roger Schmechel, UST Class B Operator
Mark Zinnecker, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm, Ball Float Valve
1156			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/21/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000		9/18/2011			
2	26	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm, Ball Float Valve
1154			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/21/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000		9/18/2011			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CONO MART SUPER STORE 10
11 W WICKS LN
BILLINGS, MT 59105 YELLOWSTONE

Contact: Dennis Whitmore, (406) 252-4661

Sys Fac ID: 56-05088
Last Inspected On: 11/21/2014
Operating Permit Renewal Date: 3/3/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	26	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm, Ball Float Valve
1155			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/21/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000		9/18/2011			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MCFINYS #2
3306 RIMROCK RD
BILLINGS, MT 59102 YELLOWSTONE
Contact: Ken McCullough, (406) 861-3952

Sys Fac ID: 56-05090
Last Inspected On: 1/27/2016
Operating Permit Renewal Date: 6/14/2019

Owners/Operators: VESTA VENTURES LLP, Owner (406)-656-8402 5629 BILLY CASPER DR
BILLINGS MT 59106-1053

MCFINNY'S, Operator 2108 BROADWATER AVE STE 102
BILLINGS MT 59102

Joe McCullough, UST Class A Operator
Ken McCullough, UST Class A Operator
Joe McCullough, UST Class B Operator
Ken McCullough, UST Class B Operator
Ken McCullough, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	28	11/30/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3681			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/26/2016	Gilbarco EMC Basic , Gilbarco		
2	28	11/30/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3682			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		1/26/2016	Gilbarco EMC Basic , Gilbarco		
3	28	11/30/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3683			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		1/26/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		1/26/2016	Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DONS CAR WASH GRAND AVE
1125 GRAND AVE
BILLINGS, MT 59102 YELLOWSTONE

Contact: Gary Carlson, (406) 259-4955

Sys Fac ID: 56-05491
Last Inspected On: 11/4/2014
Operating Permit Renewal Date: 2/10/2018

Owners/Operators: Automatic Car Wash Inc, Owner (406)-248-2558 PO BOX 1278 BILLINGS MT 59103-1278

Gene Carlson, UST Class A Operator
Gene Carlson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	28	5/4/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
406			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000		12/3/2011			
3	28	5/4/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
407			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000		12/4/2011			
4	28	5/4/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
408			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/4/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
6,000		5/15/2011			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DONS CAR WASH CENTRAL AVE
2343 CENTRAL AVE
BILLINGS, MT 59102 YELLOWSTONE

Sys Fac ID: 56-05492
Last Inspected On: 10/23/2014
Operating Permit Renewal Date: 2/10/2018

Contact: Gene Carlson, (406) 656-7051

Owners/Operators: Automatic Car Wash Inc, Owner (406)-248-2558 PO BOX 1278
BILLINGS MT 59103-1278

Gene Carlson, UST Class A Operator
Gene Carlson, UST Class B Operator
Jamie Gehring, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	26	5/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
409			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/23/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		10/12/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	
5	26	5/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4467			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/23/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		7/3/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	
6	26	5/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
411			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		10/23/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		7/3/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 3 Gs CONVENIENCE STORE
4106 STATE AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 259-0995

Sys Fac ID: 56-05748
Last Inspected On: 12/3/2014
Operating Permit Renewal Date: 1/6/2018

Owners/Operators: VESTA VENTURES LLP, Owner (406)-656-8402 5629 BILLY CASPER DR BILLINGS MT 59106-1053

KELLY GROSLACK, UST Class A Operator
Larry Groslack, UST Class A Operator
TAMI MAUCH, UST Class A Operator
KELLY GROSLACK, UST Class B Operator
Larry Groslack, UST Class B Operator
TAMI MAUCH, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	14	8/23/2002	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4714		5/3/2016	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/3/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
9,000		5/13/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	14	8/23/2002	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4715		5/3/2016	None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/3/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
3,000		5/13/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MCFINY'S 3
446 GRAND AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 259-0466

Sys Fac ID: 56-05749
Last Inspected On: 10/16/2014
Operating Permit Renewal Date: 1/6/2018

Owners/Operators: Kwik Way Inc, Owner (406)-656-6310 THERESA J JENKINS
PO BOX 20799
BILLINGS MT 59104-0799

Ken McCullough, UST Class A Operator
Ken McCullough, UST Class B Operator
Ken McCullough, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	19	11/1/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3456			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/16/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		10/11/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	
6	19	11/1/1997	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3457			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		10/16/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		10/11/2014	TLS-350/Gilbarco EMC , Veeder Root	ELLD Line Tightness Testing	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 24TH STREET CENEX
1031 24TH ST W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Teresa Bidleman, (406) 652-1529

Sys Fac ID: 56-05750
Last Inspected On: 10/5/2015
Operating Permit Renewal Date: 2/5/2019

Owners/Operators: Quast Inc, Owner (406)-652-1529 1031 24TH ST W
BILLINGS MT 59102-3807

Teresa Bidleman, UST Class A Operator
Jeff Bidleman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	9/1/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3720			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/20/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		5/2/2015	Gilbarco EMC Basic , Gilbarco	ELLD Line Tightness Testing	
2	32	9/1/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3721			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/20/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		8/17/2015	Gilbarco EMC Basic , Gilbarco	ELLD Line Tightness Testing	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DONS CAR WASH
1433 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE
Contact: Bob Carlson, (406) 256-1941

Sys Fac ID: 56-05755
Last Inspected On: 3/30/2015
Operating Permit Renewal Date: 5/14/2018

Owners/Operators: Automatic Car Wash Inc, Owner (406)-248-2558 PO BOX 1278 BILLINGS MT 59103-1278
Gene Carlson, UST Class A Operator
Gene Carlson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	11	11/10/2005	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
5030			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/30/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		7/4/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	11	11/10/2005	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
5031			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/30/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		7/4/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	11	11/10/2005	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
5032			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/30/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000		7/8/2011	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: AT & T COMMUNICATIONS BILLINGS
3011 2ND AVE N
BILLINGS, MT 59101 YELLOWSTONE

Contact: Gary Donnovan, (406) 256-6607

Sys Fac ID: 56-05758
Last Inspected On: 11/23/2015
Operating Permit Renewal Date: 3/9/2019

Owners/Operators: AT & T Communications Inc, Owner (214)-464-1469 ENVIRONMENTAL MANAGER
308 S AKARD ST RM 1700
DALLAS TX 75202-5315

Philip Bunker, UST Class A Operator
Gerald Eshbaugh, UST Class A Operator
Richard Powell, UST Class A Operator
Gary Vantress, UST Class A Operator
Gary Vantress, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	22	9/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
399			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Diesel		11/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SUPER VALU INC BILLINGS
1629 KING AVE W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Scott Armstrong, (406) 247-1513

Sys Fac ID: 56-06097
Last Inspected On: 6/3/2016
Operating Permit Renewal Date: 8/28/2019

Owners/Operators: Super Valu Inc Billings Distribution Center, Owner (406)-761-8444 1629 KING AVE W BILLINGS MT 59102-6448

John Beadle, UST Class A Operator
Scott Combs, UST Class A Operator
Mike Frost, UST Class A Operator
Jeffrey Lindell, UST Class A Operator
John Beadle, UST Class B Operator
Steve Schilling, UST Class B Operator
Scott Combs, UST Class B Global Operator
Mike Frost, UST Class B Global Operator
Jeffrey Lindell, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	9/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1867			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		4/18/2016	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	18	9/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1868			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		4/18/2016	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: FOOD SERVICES OF AMERICA BILLINGS
802 PARKWAY LN
BILLINGS, MT 59101 YELLOWSTONE

Contact: Kevin Malley, (406) 238-7800

Sys Fac ID: 56-06132
Last Inspected On: 9/9/2016
Operating Permit Renewal Date: 12/14/2019

Owners/Operators: Food Services Of America Inc, Owner (406)-238-7800 PO BOX 25119
SCOTTSDALE AZ 85255-0178

Jeff Brent, UST Class A Operator
Rick Hansen, UST Class A Operator
Rod Ostman, UST Class A Operator
Jeff Brent, UST Class B Operator
Larry Hoye, UST Class B Operator
Rodney Hunt, UST Class B Operator
Duane Young, UST Class B Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	23	11/2/1993	Cathodically Protected Steel	Steel	High Level Alarm
1781			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		9/9/2016	Automatic Tank Gauging 0.2	Deferred	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BLUE BASKET #2
2347 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE
Contact: (406) 252-7679

Sys Fac ID: 56-06593
Last Inspected On: 2/21/2014
Operating Permit Renewal Date: 4/25/2017

Owners/Operators: Blue Basket Markets Billings, Owner (406)-252-0166 PO BOX 531
BILLINGS MT 59103-0531

Brit Miller, UST Class A Operator
Steve Berg, UST Class B Operator
Randy Lowe, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	35	10/1/1981	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
459			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		1/24/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		11/6/2010	TLS-350/Gilbarco EMC , Veeder Root		
2	35	10/1/1981	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
460			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/24/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		11/6/2010	TLS-350/Gilbarco EMC , Veeder Root		
3	35	10/1/1981	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
461			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/24/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		11/6/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: Caseys #8
2816 OLD HARDIN RD
BILLINGS, MT 59101 YELLOWSTONE
Contact: Gary Scales, (406) 587-7438

Sys Fac ID: 56-06594
Last Inspected On: 1/21/2015
Operating Permit Renewal Date: 2/28/2018

Owners/Operators:

Story Distributing Company, Owner	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771
Jason Shanley, Operator	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771-1201

Jason Shanley, UST Class A Operator
Chuck Crane, UST Class B Operator
Andrew Mclellan, UST Class B Operator
Jason Shanley, UST Class B Operator
STEVE WILLDEN, UST Class B Operator
Kelly Scott Shutes, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Positive Shutoff
462			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/25/2011	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Positive Shutoff
463			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/25/2011	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
464			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		8/25/2011	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: Caseys #8
2816 OLD HARDIN RD
BILLINGS, MT 59101 YELLOWSTONE
Contact: Gary Scales, (406) 587-7438

Sys Fac ID: 56-06594
Last Inspected On: 1/21/2015
Operating Permit Renewal Date: 2/28/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	18	5/1/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
465			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		8/25/2011	Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: Caseys #7
2007 BLUE CREEK RD
BILLINGS, MT 59101 YELLOWSTONE

Sys Fac ID: 56-06595
Last Inspected On: 9/26/2014
Operating Permit Renewal Date: 11/29/2017

Contact: Jason Shanley, (406) 587-7438

Owners/Operators:

Central Holdings LLC, Owner	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771
Jason Shanley, Operator	(406)-587-0702	PO BOX 1201 BOZEMAN MT 59771-1201

Jason Shanley, UST Class A Operator
Irene Matzen, UST Class B Operator
Jason Shanley, UST Class B Operator
Melanie Sims, UST Class B Operator
Kelly Scott Shutes, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	24	11/2/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
466			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		7/24/2014	TLS-300 , Veeder Root	ELLD Line Tightness Testing	
4	24	11/2/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
467			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		7/28/2014	TLS-300 , Veeder Root	ELLD Line Tightness Testing	
5	24	11/2/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
468			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000		8/7/2014	TLS-300 , Veeder Root	ELLD Line Tightness Testing	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SHORT STOP
804 CENTRAL AVE
BILLINGS, MT 59102 YELLOWSTONE

Contact: Joe Stockton, (406) 591-7332

Sys Fac ID: 56-06609
Last Inspected On: 10/10/2016
Operating Permit Renewal Date: 10/26/2016

Owners/Operators: Stockton Oil Company, Owner (406)-245-6376 PO BOX 1756
BILLINGS MT 59103-1756

Mykel Stockton, UST Class A Operator
Joey McConnell, UST Class B Global Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	35	3/26/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3754			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/10/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
8,000					
2	35	3/26/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3899			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/10/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
8,000					
3	35	3/26/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4920			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/10/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
8,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SHORT STOP
804 CENTRAL AVE
BILLINGS, MT 59102 YELLOWSTONE

Contact: Joe Stockton, (406) 591-7332

Sys Fac ID: 56-06609
Last Inspected On: 10/10/2016
Operating Permit Renewal Date: 10/26/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	35	3/26/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4921			Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/10/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
8,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CONO MART SUPER STORE 6
1219 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE

Sys Fac ID: 56-06948
Last Inspected On: 11/21/2014
Operating Permit Renewal Date: 1/28/2018

Contact: Dennis Whitmore, (406) 252-4661

Owners/Operators:

C Store Properties LLC, Owner	(406)-651-5101	PO BOX 80391 BILLINGS MT 59108
GM Cono Stores LLC, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107

Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Ken Jackson, UST Class A Operator
Charlie McHenry, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Troy Davis, UST Class B Operator
Laura Geffre, UST Class B Operator
Roger Schmechel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	40	4/21/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3618			Lined Interior/Impressed Current	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/21/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000		10/16/2011			
2	45	4/22/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3619			Lined Interior/Impressed Current	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/21/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000		6/28/2011			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CONO MART SUPER STORE 6
1219 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE

Contact: Dennis Whitmore, (406) 252-4661

Sys Fac ID: 56-06948
Last Inspected On: 11/21/2014
Operating Permit Renewal Date: 1/28/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	45	4/22/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3620			Lined Interior/Impressed Current	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		11/21/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
4,000		9/28/2011			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: REDDI ELECTRIC INC
1045 1/2 CENTRAL AVE
BILLINGS, MT 59102 YELLOWSTONE

Contact: Mike Schmidt, (406) 245-3141

Sys Fac ID: 56-06953
Last Inspected On: 4/22/2015
Operating Permit Renewal Date: 9/16/2018

Owners/Operators: Reddi Electric Inc, Owner (406)-245-3141 1045 1/2 CENTRAL AVE BILLINGS MT 59102-5821

Darin Linger, UST Class A Operator
Mike Schmidt, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	1/10/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1837			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/21/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
560			TLS-300 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DONS CAR WASH 1ST AVE
1924 1ST AVE N
BILLINGS, MT 59101 YELLOWSTONE

Contact: Bob Carlson, (406) 259-3539

Sys Fac ID: 56-06956
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 2/10/2018

Owners/Operators: Automatic Car Wash Inc, Owner (406)-248-2558 PO BOX 1278 BILLINGS MT 59103-1278

Gene Carlson, UST Class A Operator
Dick Berg, UST Class B Operator
Gene Carlson, UST Class B Operator
Gene Carlson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	28	11/11/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
412			None	Double-Walled	Yes
Currently in Use		11/11/1998	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/21/2005	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	28	11/11/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
413			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/1/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	28	11/11/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
414			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/2/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HEIGHTS CONOCO 13 UST
1320 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE

Sys Fac ID: 56-06960
Last Inspected On: 7/18/2013
Operating Permit Renewal Date: 12/12/2016

Contact: Joe Borgstrom, (651) 247-6200

Owners/Operators: TAG Inc, Owner (406)-259-3700 1320 MAIN ST
BILLINGS MT 59105-1742

Joseph Borgstrom, UST Class A Operator
Joseph Borgstrom, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	40	4/21/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1164			Lined Interior/Impressed Current	None	Yes
Currently in Use		5/1/2005	Mechanical Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		7/18/2013	Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
10,000		7/18/2013			
2	40	4/21/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1165			Lined Interior/Impressed Current	None	Yes
Currently in Use		5/1/2005	Mechanical Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		7/18/2013	Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
10,000		7/18/2013			
3	40	4/21/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1166			Lined Interior/Impressed Current	None	Yes
Currently in Use		5/1/2005	Mechanical Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		7/18/2013	Stat. Inventory Reconcilitation	MLLD Line Tightness Testing	
5,000		7/18/2013			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: GM PETROLEUM DISTRIBUTORS
2100 1ST AVE S
BILLINGS, MT 59101 YELLOWSTONE

Contact: Jay Brookie, (406) 294-0865

Sys Fac ID: 56-06962
Last Inspected On: 12/15/2014
Operating Permit Renewal Date: 3/14/2018

Owners/Operators: City Service Valcon LLC DBA GM Petroleum Distributors, Owner/Operator (406)-252-4661 PO BOX 30335 BILLINGS MT 59107
Jay Brookie, UST Class A Operator
Laura Geffre, UST Class A Operator
Roger Schmechel, UST Class A Operator
Laura Geffre, UST Class B Operator
Roger Schmechel, UST Class B Operator
Jay Brookie, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	31	6/1/1985	Bare Steel	Steel	High Level Alarm
1167			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		6/28/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
2	31	6/1/1985	Bare Steel	Steel	High Level Alarm
1168			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		6/28/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
3	31	6/1/1985	Bare Steel	Steel	High Level Alarm
1169			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		6/28/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
6,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: GM PETROLEUM DISTRIBUTORS
2100 1ST AVE S
BILLINGS, MT 59101 YELLOWSTONE

Contact: Jay Brookie, (406) 294-0865

Sys Fac ID: 56-06962
Last Inspected On: 12/15/2014
Operating Permit Renewal Date: 3/14/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	31	6/1/1985	Bare Steel	Steel	High Level Alarm
4626			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		6/28/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
5	33	5/7/1983	Bare Steel	Steel	High Level Alarm
4627			Impressed Current	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Waste Oil		6/28/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TRADING POST CONOCO
1225 MULLOWNEY LN
BILLINGS, MT 59101 YELLOWSTONE
Contact: Jeff Sowden, (406) 256-8465

Sys Fac ID: 56-06963
Last Inspected On: 9/7/2016
Operating Permit Renewal Date: 11/30/2019

Owners/Operators: S & G Partnership, Owner (406)-252-4661 1225 MULLOWNEY LN BILLINGS MT 59101-6301
Jeffrey Sowden, UST Class A Operator
Jeffrey Sowden, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	13	5/9/2003	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4836			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		6/18/2010	Gilbarco EMC Basic , Gilbarco		
6	13	5/9/2003	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4837			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		6/18/2010	Gilbarco EMC Basic , Gilbarco		
7	13	5/9/2003	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4838			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		9/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		6/18/2010	Gilbarco EMC Basic , Gilbarco		
8	13	5/9/2003	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4839			Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		9/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		6/18/2010	Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DOWNTOWN CONOCO
2701 6TH AVE N
BILLINGS, MT 59101 YELLOWSTONE

Contact: Dennis Whitmore, (406) 254-1401

Sys Fac ID: 56-06967
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 1/28/2018

Owners/Operators:

Grunstead Family Limited Partnership, Owner	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107
J & L Properties Management Inc, Operator	(406)-254-1401	2701 6TH AVE N BILLINGS MT 59101

Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Jim Murphy, UST Class A Operator
Paul Murphy, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Laura Geffre, UST Class B Operator
Jim Murphy, UST Class B Operator
Roger Schmechel, UST Class B Operator
Paul Murphy, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	48	4/22/1968	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
3621			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/26/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
8,000		12/1/2011			
2	46	4/22/1970	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
3622			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/26/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
6,000		11/7/2011			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DOWNTOWN CONOCO
2701 6TH AVE N
BILLINGS, MT 59101 YELLOWSTONE

Contact: Dennis Whitmore, (406) 254-1401

Sys Fac ID: 56-06967
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 1/28/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	42	4/22/1974	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
3623			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/26/2010	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		11/9/2011			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: WILSON DUNHAM SERVICE INC
2511 1ST AVE S
BILLINGS, MT 59101 YELLOWSTONE

Contact: Joan Erickson, (406) 724-7335

Sys Fac ID: 56-07756
Last Inspected On: 4/10/2014
Operating Permit Renewal Date: 6/3/2017

Owners/Operators:

Wilson Dunham Petroleum Supply, Owner	(406)-252-0880	2511 1ST AVE S BILLINGS MT 59101-2320
Erick Forum, Operator	(406)-724-7335	2511 1ST AVE S BILLINGS MT 59101
William Dunham, UST Class A Operator		
Joan Erickson, UST Class A Operator		
Joan Erickson, UST Class B Operator		
William Dunham, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	26	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2277			None	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		4/8/2014	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
6	26	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2278			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/8/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		11/4/2013	TLS-350/Gilbarco EMC , Veeder Root		
7	26	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2279			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/8/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		11/4/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: WILSON DUNHAM SERVICE INC
2511 1ST AVE S
BILLINGS, MT 59101 YELLOWSTONE

Contact: Joan Erickson, (406) 724-7335

Sys Fac ID: 56-07756
Last Inspected On: 4/10/2014
Operating Permit Renewal Date: 6/3/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	26	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2280			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/8/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
8,000		11/4/2013	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: LYNCH FLYING SERVICE
1691 AVIATION PL
BILLINGS, MT 59105 YELLOWSTONE

Contact: Warren Nemitz, (406) 252-0508

Sys Fac ID: 56-07797
Last Inspected On: 10/8/2015
Operating Permit Renewal Date: 12/17/2018

Owners/Operators: LYNCH FLYING SERVICE INC, Owner (406)-252-0508 DBA EDWARDS JET CENTER
1691 AVIATION PL
BILLINGS MT 59105-1981

Robert McCullough, UST Class A Operator
Warren Nemitz, UST Class A Operator
Joel Simmons, UST Class A Operator
Aaron VanLuchene, UST Class A Operator
Robert McCullough, UST Class B Operator
Joel Simmons, UST Class B Operator
Warren Nemitz, UST Class B Global Operator
Aaron VanLuchene, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	10/25/1990	Cathodically Protected Steel	No Piping	High Level Alarm
1565			Lined Interior	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Jet Fuel		10/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
2	26	10/25/1990	Cathodically Protected Steel	No Piping	High Level Alarm
1566			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Aviation Gas		10/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
3	26	10/25/1990	Cathodically Protected Steel	Steel	High Level Alarm
1567			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: LYNCH FLYING SERVICE
1691 AVIATION PL
BILLINGS, MT 59105 YELLOWSTONE

Contact: Warren Nemitz, (406) 252-0508

Sys Fac ID: 56-07797
Last Inspected On: 10/8/2015
Operating Permit Renewal Date: 12/17/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	26	10/25/1990	Cathodically Protected Steel	No Piping	High Level Alarm
1563			Lined Interior	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Jet Fuel		10/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
12	26	10/25/1990	Cathodically Protected Steel	No Piping	High Level Alarm
1564			Lined Interior	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Jet Fuel		10/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
13	18	6/26/1998	Cathodically Protected Steel	No Piping	High Level Alarm
1568			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Jet Fuel		10/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
14	18	6/26/1998	Cathodically Protected Steel	No Piping	High Level Alarm
1569			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Jet Fuel		10/8/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
20,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 266
745 GRAND AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 248-7038

Sys Fac ID: 56-08058
Last Inspected On: 8/1/2016
Operating Permit Renewal Date: 11/20/2019

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Jack Krueger Jr, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Courtney Sheriff, UST Class B Operator
Linda French, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	6/8/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3039			Double-Walled	Double-Walled	Yes
Currently in Use		6/8/2005	Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		7/29/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		3/23/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	21	6/8/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3036			Double-Walled	Double-Walled	Yes
Currently in Use		6/8/2005	Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		7/29/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
12,000		3/23/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	21	6/8/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3037			Double-Walled	Double-Walled	Yes
Currently in Use		6/8/2005	Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		7/29/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		3/23/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 266
745 GRAND AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 248-7038

Sys Fac ID: 56-08058
Last Inspected On: 8/1/2016
Operating Permit Renewal Date: 11/20/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	21	6/8/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3038			Double-Walled	Double-Walled	Yes
Currently in Use		6/8/2005	Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		7/29/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		3/23/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 274
2620 6TH AVE N
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 248-7037

Sys Fac ID: 56-08062
Last Inspected On: 7/28/2016
Operating Permit Renewal Date: 10/29/2019

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Stephen Reckinger, UST Class A Operator
Dean Townsend, UST Class A Operator
Ronald VanDenBroeke, UST Class A Operator
Michael Boileau, UST Class B Operator
Linda French, UST Class B Global Operator
Stephen Reckinger, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator
Dean Townsend, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	21	10/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3040			Double-Walled	Double-Walled	Yes
Currently in Use		10/1/2005	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/23/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		12/25/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	21	10/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
4399			Double-Walled	Double-Walled	Yes
Currently in Use		10/1/2005	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/23/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		12/25/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 274
2620 6TH AVE N
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 248-7037

Sys Fac ID: 56-08062
Last Inspected On: 7/28/2016
Operating Permit Renewal Date: 10/29/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	21	10/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3042			Double-Walled	Double-Walled	Yes
Currently in Use		10/1/1995	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		8/23/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
10,000		12/25/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 275
105 BROADWATER AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 259-7361

Sys Fac ID: 56-08063
Last Inspected On: 6/3/2014
Operating Permit Renewal Date: 11/6/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Lisa Pedersen, UST Class A Operator
Lisa Pedersen, UST Class B Operator
Jeff Reed, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	21	7/13/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3043			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/23/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Manual Interstitial Monitor	
6	21	7/13/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3044			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/23/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Manual Interstitial Monitor	
7	21	7/13/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3045			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/23/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Manual Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 275
105 BROADWATER AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 259-7361

Sys Fac ID: 56-08063
Last Inspected On: 6/3/2014
Operating Permit Renewal Date: 11/6/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	21	7/13/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3046			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		5/23/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Manual Interstitial Monitor	
9	21	7/13/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3047			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		5/23/2012	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Manual Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 54
151 ROSEBUD LN
BILLINGS, MT 59101 YELLOWSTONE
Contact: Ian Johnstone, (406) 259-5426

Sys Fac ID: 56-08208
Last Inspected On: 6/24/2015
Operating Permit Renewal Date: 6/25/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Nicholas Merritt, UST Class A Operator
Pete Nussbaum, UST Class A Operator
Tom Savas, UST Class A Operator
Chuck Crane, UST Class B Operator
Nicholas Merritt, UST Class B Operator
Nicholas Merritt, UST Class B Global Operator
Karina Serrano, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	02	9/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm, Auto Limiter
5525		11/1/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Manual Interstitial Monitor	Continuous Interstitial Monitor	
17,000		2/13/2015	TLS-450 , Veeder Root	Not Listed	
8	02	9/1/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Auto Limiter
5526		11/1/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Manual Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
8,000		2/13/2015	TLS-450 , Veeder Root	Not Listed	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 54
151 ROSEBUD LN
BILLINGS, MT 59101 YELLOWSTONE
Contact: Ian Johnstone, (406) 259-5426

Sys Fac ID: 56-08208
Last Inspected On: 6/24/2015
Operating Permit Renewal Date: 6/25/2018

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
9	02	9/1/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Auto Limiter
5527		11/1/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Manual Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
17,000		2/13/2015	TLS-450 , Veeder Root	Not Listed	
10	02	9/1/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Auto Limiter
5528		11/1/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Manual Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
8,000		2/13/2015	TLS-450 , Veeder Root	Not Listed	
11	02	9/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm, Auto Limiter
5529		11/1/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Manual Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
25,000		2/13/2015	TLS-450 , Veeder Root	Not Listed	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 58
610 WICKS LN
BILLINGS, MT 59105 YELLOWSTONE
Contact: (406) 259-7054

Sys Fac ID: 56-08209
Last Inspected On: 1/19/2015
Operating Permit Renewal Date: 3/17/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Sean Hurley, UST Class A Operator
Tom Savas, UST Class A Operator
Chuck Crane, UST Class B Operator
Karina Serrano, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	17	1/1/1999	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4256			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/19/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	17	1/1/1999	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4257			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		4/19/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 58
610 WICKS LN
BILLINGS, MT 59105 YELLOWSTONE
Contact: (406) 259-7054

Sys Fac ID: 56-08209
Last Inspected On: 1/19/2015
Operating Permit Renewal Date: 3/17/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	17	1/1/1999	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4258			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		4/19/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MARKET BASKET STORE
8014 S FRONTAGE RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Kebi Bowers, (406) 652-1529

Sys Fac ID: 56-08286
Last Inspected On: 4/19/2016
Operating Permit Renewal Date: 7/28/2019

Owners/Operators: Market Basket Store, Owner (406)-656-3546 8014 S FRONTAGE RD BILLINGS MT 59101-6202

Teresa Bidleman, UST Class A Operator
Jeff Bidleman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	10/6/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
3314			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/19/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/1/2016	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
2	21	10/6/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
3315			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		2/19/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		4/1/2016	TLS-300 , Veeder Root	Continuous Interstitial Monitor	
5	13	11/28/2003	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
4945			None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		2/19/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
8,000		4/1/2016	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: PEPSI COLA BOTTLING CO BILLINGS
344 HOWARD AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 252-9355

Sys Fac ID: 56-08323
Last Inspected On: 10/23/2015
Operating Permit Renewal Date: 12/4/2018

Owners/Operators: Pepsi Cola Bottling Co Billings, Owner (406)-252-9355 344 HOWARD AVE BILLINGS MT 59101-3039
ERNE BRESTER, UST Class A Operator
ERNE BRESTER, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	8/1/1990	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
1798			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
3,000			OPW 1500 , OPW		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CARDLOCK #2
36TH & 1ST AVE S
BILLINGS, MT 59101 YELLOWSTONE

Sys Fac ID: 56-08324
Last Inspected On: 10/5/2016
Operating Permit Renewal Date: 12/24/2019

Contact: Roger Schmechel, (406) 252-4661

Owners/Operators:

GM Petroleum Dist, Owner	(406)-661-1112	PO BOX 80391 BILLINGS MT 59108
City Service Valcon LLC DBA GM Petroleum Distributors, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107
Jay Brookie, UST Class A Operator		
Laura Geffre, UST Class A Operator		
Bill Grunstead, UST Class A Operator		
Roger Schmechel, UST Class A Operator		
Laura Geffre, UST Class B Operator		
Roger Schmechel, UST Class B Operator		
Jay Brookie, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	38	5/6/1978	Cathodically Protected Steel	Steel	High Level Alarm
1179			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/1/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		10/29/2010	Gilbarco EMC Basic , Gilbarco		
2	38	5/6/1978	Cathodically Protected Steel	Steel	High Level Alarm
1180			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/1/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		10/29/2010	Gilbarco EMC Basic , Gilbarco		
3	38	5/6/1978	Cathodically Protected Steel	Steel	High Level Alarm
1181			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/1/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		10/29/2010	Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SUBZERO INC DBA BROADWATER QUICK STOP
942 BROADWATER AVE
BILLINGS, MT 59101 YELLOWSTONE

Sys Fac ID: 56-08671
Last Inspected On: 9/19/2014
Operating Permit Renewal Date: 12/16/2017

Contact: Duane Young, (406) 208-8232

Owners/Operators:

Gordon Vandiviere, Operator	(406)-348-2222	235 3RD ST N HUNTLEY MT 59037-2714
Subzero Inc, Owner/Operator	(406)-702-3569	1129 PEONY DR BILLINGS MT 59105

Gordon Vandiviere, UST Class A Operator
Duane Young, UST Class A Operator
Diane Vandiviere, UST Class B Operator
Cerena Young, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	22	12/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3170			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/9/2014	Tank Tightness Testing, Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
8,000					
5	22	12/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3169			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/9/2014	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation, MLLD Line Tightness Testing	
8,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: QWEST BILLINGS WEST CENTRAL OFFICE
3190 CENTRAL AVE
BILLINGS, MT 59102 YELLOWSTONE

Contact: Kevin Robison, (801) 237-3006

Sys Fac ID: 56-08762
Last Inspected On: 6/25/2015
Operating Permit Renewal Date: 11/13/2018

Owners/Operators:

Qwest Corporation, Owner	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111
Qwest Corporation, Operator	(801)-237-3006	250 E 200 S #1601 SALT LAKE CITY UT 84111

Thomas J Pitts, UST Class A Operator
Kevin Robison, UST Class A Operator
Thomas J Pitts, UST Class B Operator
Thomas J Pitts, UST Class B Global Operator
Kevin Robison, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	22	11/1/1994	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1733			Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Not Applicable
Diesel		8/20/2012	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
1,000		6/25/2015	TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 52
1201 CENTRAL AVE
BILLINGS, MT 59102 YELLOWSTONE
Contact: (406) 245-9670

Sys Fac ID: 56-08903
Last Inspected On: 11/22/2016
Operating Permit Renewal Date: 5/21/2017

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Sean Hurley, UST Class A Operator
Pete Nussbaum, UST Class A Operator
Darcy Ziegler, UST Class B Operator
Pete Nussbaum, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	06	11/22/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5270			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
15,000			TLS-350/Gilbarco EMC , Veeder Root		Yes
7	06	11/22/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5271			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
7,000			TLS-350/Gilbarco EMC , Veeder Root		Yes
8	06	11/22/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5272			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 55
236 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE
Contact: (406) 259-3240

Sys Fac ID: 56-08904
Last Inspected On: 2/27/2015
Operating Permit Renewal Date: 7/11/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Ian Johnstone, UST Class A Operator
Chuck Crane, UST Class B Operator
Darcy Ziegler, UST Class B Operator
Karina Serrano, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	34	10/3/1982	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
589		10/8/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/1/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		10/13/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	34	10/3/1982	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
590		10/8/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/1/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		10/13/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	34	10/3/1982	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
591		10/8/2014	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		8/1/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		10/13/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CARDLOCK #4
275 DANIELS ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Roger Schmechel, (406) 252-4661

Sys Fac ID: 56-09271
Last Inspected On: 1/26/2016
Operating Permit Renewal Date: 4/20/2019

Owners/Operators:

Monad Daniels LLC, Owner	(406)-252-4661	PO BOX 80391 BILLINGS MT 59108
City Service Valcon LLC DBA GM Petroleum Distributors, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107

Jay Brookie, UST Class A Operator
Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Roger Schmechel, UST Class A Operator
Laura Geffre, UST Class B Operator
Roger Schmechel, UST Class B Operator
Jay Brookie, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	1/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), Ball Float Valve
4716			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		10/10/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	23	1/1/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff), Ball Float Valve
4717			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		10/10/2009	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MDOT BILLINGS SITE
424 MOREY ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Joe Radonich, (406) 444-9204

Sys Fac ID: 56-09501
Last Inspected On: 1/13/2014
Operating Permit Renewal Date: 4/25/2017

Owners/Operators:

MDOT Helena, Owner	(406)-444-6200	KIM JANZEN PO BOX 201001 HELENA MT 59620-1001
Joseph J Radonich, Operator	(406)-444-9204	MDT DEADHEAD HELENA MT 59620-0901

Jeff Gleason, UST Class A Operator
Walt Kerttula, UST Class A Operator
Mike Murolo, UST Class A Operator
Joe Radonich, UST Class A Operator
Charlie Eddlemon, UST Class B Operator
Ronald Joslyn, UST Class B Operator
John McCloskey, UST Class B Operator
Joe Radonich, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	9/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2948			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		1/13/2014	Automatic Tank Gauging 0.2	Deferred	
10,000					
2	23	9/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2949			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		1/13/2014	Automatic Tank Gauging 0.2	Deferred	
10,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 280
1020 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE
Contact: (406) 245-1254

Sys Fac ID: 56-09695
Last Inspected On: 6/25/2014
Operating Permit Renewal Date: 11/29/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Jack Krueger Jr, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Kimberly Robers, UST Class B Operator
Stephanie Wilz, UST Class B Operator
Linda French, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	4/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
3048		10/3/2013	None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/25/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
12,000		3/12/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	29	4/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
3049		10/3/2013	None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/25/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
12,000		11/27/2013	TLS-350/Gilbarco EMC , Veeder Root		
3	29	4/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
3050		10/3/2013	None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/25/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		6/25/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 280
1020 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE
Contact: (406) 245-1254

Sys Fac ID: 56-09695
Last Inspected On: 6/25/2014
Operating Permit Renewal Date: 11/29/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	29	4/1/1987	Cathodically Protected Steel	Steel	Ball Float Valve
3051		10/3/2013	None	none	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/25/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		3/14/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS FIRE STATION 1
2305 8TH AVE N
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 657-8423

Sys Fac ID: 56-09739
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 2/20/2018

Owners/Operators: City of Billings Fire Dept, Owner (406)-657-8428 2305 8TH AVE N BILLINGS MT 59101-1018
Boyd Vopel, UST Class A Operator
Boyd Vopel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	12/1/1993	Cathodically Protected Steel	Copper	High Level Alarm
2729			None	Secondary Containment Chase	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/18/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
517					
2	22	12/1/1993	Cathodically Protected Steel	Copper	High Level Alarm
2728			None	Secondary Containment Chase	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Diesel		6/18/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,035					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS FIRE STATION 2
501 S 28TH ST
BILLINGS, MT 59101 YELLOWSTONE

Sys Fac ID: 56-09740
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 2/20/2018

Contact: Marvin Jochems, (406) 657-8423

Owners/Operators: City of Billings Fire Dept, Owner (406)-657-8428 2305 8TH AVE N
BILLINGS MT 59101-1018

Boyd Vopel, UST Class A Operator
Boyd Vopel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	26	6/12/1990	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3699			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/22/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000					
4	26	6/12/1990	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
3700			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/22/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS FIRE STATION 3
1928 17TH ST W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Marvin Jochems, (406) 657-8423

Sys Fac ID: 56-09741
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 2/20/2018

Owners/Operators: City of Billings Fire Dept, Owner (406)-657-8428 2305 8TH AVE N
BILLINGS MT 59101-1018

Boyd Vopel, UST Class A Operator
Boyd Vopel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	24	3/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4297			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		6/18/2012	Automatic Tank Gauging 0.2	Not Listed	
500			TLS-300 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS FIRE STATION 5
605 S 24TH ST W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Marvin L Jochems, (406) 657-8423

Sys Fac ID: 56-09742
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 2/20/2018

Owners/Operators: City of Billings Fire Dept, Owner (406)-657-8428 2305 8TH AVE N
BILLINGS MT 59101-1018

Boyd Vopel, UST Class A Operator
Boyd Vopel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	23	1/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2731			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/18/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
517					
5	23	1/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2732			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		6/18/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
517					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS FIRE STATION 6
1601 ST ANDREWS DR
BILLINGS, MT 59105 YELLOWSTONE

Contact: Marvin Jochems, (406) 657-8423

Sys Fac ID: 56-09743
Last Inspected On: 11/3/2014
Operating Permit Renewal Date: 2/20/2018

Owners/Operators: City of Billings Fire Dept, Owner (406)-657-8428 2305 8TH AVE N
BILLINGS MT 59101-1018

Boyd Vopel, UST Class A Operator
Boyd Vopel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	10/19/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2733			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		6/18/2012	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
500					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS REGIONAL LANDFILL
5240 JELLISON RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Barbara Butler, (406) 657-8260

Sys Fac ID: 56-09744
Last Inspected On: 6/25/2015
Operating Permit Renewal Date: 9/4/2018

Owners/Operators: CITY OF BILLINGS SOLID WASTE DIVISION, Owner/Operator (406)-657-8240 PO BOX 1178 BILLINGS MT 59103
Clarence Kostenko, UST Class A Operator
Anthony Lehner, UST Class A Operator
Anthony Lehner, UST Class B Operator
Clarence Kostenko, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	30	10/1/1986	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
630		6/25/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		6/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
10,000			TLS-300 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: PUBLIC UTILITIES DEPT
2251 BELKNAP AVE
BILLINGS, MT 59101 YELLOWSTONE

Contact: Larry Diedrich, (406) 657-8335

Sys Fac ID: 56-09746
Last Inspected On: 6/19/2015
Operating Permit Renewal Date: 10/29/2018

Owners/Operators: City of Billings Public Works, Owner (406)-657-8335 2251 BELKNAP AVE BILLINGS MT 59101
Lawrence Diedrich, UST Class A Operator
Lawrence Diedrich, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	1/1/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
631			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
10,000			Gilbarco EMC Basic , Gilbarco		
2	26	1/1/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
632			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		6/19/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
10,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS METROPOLITAN TRANSIT
1705 MONAD RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: John Bishop, (406) 657-8218

Sys Fac ID: 56-09747
Last Inspected On: 8/13/2015
Operating Permit Renewal Date: 12/18/2018

Owners/Operators: City of Billings MET Transit, Owner (406)-657-8219 PO BOX 1178
BILLINGS MT 59103-1178

John Bishop, UST Class A Operator
Rusty Logan, UST Class A Operator
Rick Pirami, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	33	10/15/1983	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
635			None	None	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Waste Oil		8/13/2015	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		8/13/2015	Gilbarco EMC Basic , Gilbarco		
4	13	9/3/2003	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4862			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		8/13/2015	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
8,000		8/13/2015	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
5	13	9/3/2003	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4863			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel		8/13/2015	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
8,000		8/13/2015	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 284
3226 ROSEBUD DR
BILLINGS, MT 59102 YELLOWSTONE

Contact: Barbara Sparovic, (406) 652-4095

Sys Fac ID: 56-09752
Last Inspected On: 3/3/2014
Operating Permit Renewal Date: 5/30/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Jack Krueger Jr, UST Class A Operator
Ronald VanDenBroeke, UST Class A Operator
Garrett Lapp, UST Class B Operator
Irene Matzen, UST Class B Operator
Linda French, UST Class B Global Operator
Jack Krueger Jr, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	33	11/5/1983	Cathodically Protected Steel	Steel	Ball Float Valve
3052			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
10,000		11/24/2007	TLS-350/Gilbarco EMC , Veeder Root		
2	33	11/5/1983	Cathodically Protected Steel	Steel	Ball Float Valve
3053			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		3/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
10,000		11/24/2007	TLS-350/Gilbarco EMC , Veeder Root		
3	33	11/5/1983	Cathodically Protected Steel	Steel	Ball Float Valve
3054			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	IImpressed Current
Gasoline		3/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
6,000		11/24/2007	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 285
785 S 20TH ST W
BILLINGS, MT 59102 YELLOWSTONE
Contact: Jack Krueger, (406) 656-3430

Sys Fac ID: 56-09753
Last Inspected On: 11/19/2014
Operating Permit Renewal Date: 1/22/2018

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Jack Krueger Jr, UST Class A Operator
Russell Ericson, UST Class B Operator
Stan Sauer, UST Class B Operator
Jeff Reed, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	19	4/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
3055			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/19/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Yes
8,000					
6	19	4/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
3056			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/19/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Yes
8,000					
7	19	4/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
3057			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/19/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Yes
8,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 285
785 S 20TH ST W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Jack Krueger, (406) 656-3430

Sys Fac ID: 56-09753
Last Inspected On: 11/19/2014
Operating Permit Renewal Date: 1/22/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	19	4/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
3058			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/19/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Yes
8,000					
9	19	4/1/1997	Steel Clad	Flexible Plastic	Ball Float Valve
3059			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/19/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000		10/8/2008			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DEEDLES
3189 KING AVE W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Paul DiLorenzo, (406) 591-1921

Sys Fac ID: 56-10075
Last Inspected On: 12/31/2013
Operating Permit Renewal Date: 3/15/2017

Owners/Operators:

Stockton Oil Company, Owner	(406)-245-6376	PO BOX 1756 BILLINGS MT 59103-1756
Paul J DiLorenzo, Operator	(406)-839-2399	3189 KING AVE WEST BILLINGS MT 59102-7466

Paul J DiLorenzo, UST Class A Operator
Mykel Stockton, UST Class A Operator
Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Mykel Stockton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	1/13/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3834			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/31/2013	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
8,000					
2	29	1/13/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3835			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/31/2013	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
6,000					
3	29	1/13/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3836			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/31/2013	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
6,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SKYVIEW HIGH SCHOOL DIST 2
1775 HIGH SIERRA BLVD
BILLINGS, MT 59105 YELLOWSTONE

Contact: Jim Miller, (406) 281-5200

Sys Fac ID: 56-10585
Last Inspected On: 2/3/2016
Operating Permit Renewal Date: 6/22/2019

Owners/Operators: Billings School District, Owner (406)-247-3777 415 N 30TH ST BILLINGS MT 59101-1298

Dennis Stellingwerf, UST Class A Operator
Jim Miller, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	29	3/16/1987	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
448		2/3/2016	None	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil		2/3/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
5,000			TLS-300 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: 3 GS CONVENIENCE CENTER 27TH ST
702 S 27TH ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Larry Grosulak, (406) 256-6246

Sys Fac ID: 56-10797
Last Inspected On: 9/30/2014
Operating Permit Renewal Date: 1/7/2018

Owners/Operators: SNG Inc 3, Owner (406)-245-0161 4410 STATE AVE
BILLINGS MT 59101-5060

KELLY GROSLACK, UST Class A Operator
Larry Groslack, UST Class A Operator
TAMI MAUCH, UST Class A Operator
KELLY GROSLACK, UST Class B Operator
Larry Groslack, UST Class B Operator
TAMI MAUCH, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	18	7/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4751			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/19/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000		7/18/2008	TLS-300 , Veeder Root	Automatic Tank Gauging 0.2	
5	18	7/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4752			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/19/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000		7/18/2008	TLS-300 , Veeder Root	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: GAS N GO
800 JACKSON ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Connie Pelican, (406) 656-5882

Sys Fac ID: 56-10866
Last Inspected On: 10/13/2016
Operating Permit Renewal Date: 1/4/2020

Owners/Operators:

TLC Enterprises Inc, Owner	(406)-245-1133	122 1ST AVE S LAUREL MT 59044
Gas N Go, Operator	(406)-245-1133	800 JACKSON STREET BILLINGS MT 59101

Renee Andrews, UST Class A Operator
Connie Pelican, UST Class A Operator
Renee Andrews, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	32	4/10/1984	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
4551			Lined Interior/Impressed Current	None	Yes
Currently in Use		9/1/2008	Not Required	Safe Suction	Impressed Current
Gasoline		10/13/2016	Stat. Inventory Reconcilitation	Deferred	
6,000					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: EXXONMOBIL BILLINGS PRODUCTS TERMINAL
607 EXXONMOBIL RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Michael Bailey, (406) 657-5404

Sys Fac ID: 56-11335
Last Inspected On: 2/12/2016
Operating Permit Renewal Date: 5/12/2019

Owners/Operators: Exxon Mobil Corporation, Owner (832)-625-7781 607 EXXONMOBIL RD BILLINGS MT 59101-7363

Michael T Bailey, UST Class A Operator
Charles Herre, UST Class A Operator
Alan Mizner, UST Class A Operator
James Vokral Sup, UST Class A Operator
Christopher Scott Martin, UST Class B Operator
Alan Mizner, UST Class B Operator
Michael T Bailey, UST Class B Global Operator
Charles Herre, UST Class B Global Operator
Marc Larson, UST Class B Global Operator
James Vokral Sup, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1			Bare Steel	Steel	
			None	none	Yes
Currently in Use				Not Listed	
Oil/Water Separator		10/3/2008	Deferred	Deferred	
4,000		11/10/2009			
2	22	10/1/1994	Steel Clad	Steel	High Level Alarm
2736			Double-Walled	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Mixture		12/5/2015	Continuous Interstitial Monitor	Not Listed	
3,000		11/22/2015			
4	66	1/1/1950	Unknown	Steel - Terminal Piping	
2738	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Gasoline		12/5/2015	Deferred	MLLD Line Tightness Testing	
197,000		11/17/2015			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: EXXONMOBIL BILLINGS PRODUCTS TERMINAL
607 EXXONMOBIL RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Michael Bailey, (406) 657-5404

Sys Fac ID: 56-11335
Last Inspected On: 2/12/2016
Operating Permit Renewal Date: 5/12/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	66	1/1/1950	Unknown	Steel - Terminal Piping	
2740	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		12/5/2015	Deferred	MLLD Line Tightness Testing	
60,000		11/17/2015			
15	66	1/1/1950	Unknown	Steel - Terminal Piping	
2749	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		12/5/2015	Deferred	MLLD Line Tightness Testing	
60,000		11/22/2015			
16	66	1/1/1950	Unknown	Steel - Terminal Piping	
2750	Yes		Impressed Current	None	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Gasoline		12/5/2015	Deferred	MLLD Line Tightness Testing	
60,000		11/22/2015			
36	64	1/1/1952	Unknown	Steel - Terminal Piping	
2764	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable, Impressed Current
Gasoline		12/5/2015	Deferred	MLLD Line Tightness Testing	
2,959,110		11/17/2015			
37	64	1/1/1952	Unknown	Steel - Terminal Piping	
2765	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable, Impressed Current
Diesel		12/5/2015	Deferred	MLLD Line Tightness Testing	
1,784,454		11/17/2015			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: EXXONMOBIL BILLINGS PRODUCTS TERMINAL
607 EXXONMOBIL RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Michael Bailey, (406) 657-5404

Sys Fac ID: 56-11335
Last Inspected On: 2/12/2016
Operating Permit Renewal Date: 5/12/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
38	64	1/1/1952	Unknown	Steel - Terminal Piping	
2766	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable, Impressed Current
Diesel		12/5/2015	Deferred	MLLD Line Tightness Testing	
1,749,888		11/17/2015			
39	19	5/1/1997	Unknown	Steel	
2758	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
15,000		11/10/2009			
40	19	5/1/1997	Unknown	Steel	
2759	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
15,000		11/10/2009			
41	19	5/1/1997	Unknown	Steel	
2760	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
15,000		11/10/2009			
42	19	5/1/1997	Unknown	Steel	
2761	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
15,000		11/10/2009			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: EXXONMOBIL BILLINGS PRODUCTS TERMINAL
607 EXXONMOBIL RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Michael Bailey, (406) 657-5404

Sys Fac ID: 56-11335
Last Inspected On: 2/12/2016
Operating Permit Renewal Date: 5/12/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
43	19	5/1/1997	Unknown	Steel	
2762	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
15,000		11/10/2009			
44	19	5/1/1997	Unknown	Steel	
2751	Yes		None	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	MLLD Line Tightness Testing	
15,000		11/10/2009			
45	19	5/1/1997	Unknown	Steel	
2752	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
6,000		11/10/2009			
46	19	5/1/1997	Unknown	Steel	
2753	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
6,000		11/10/2009			
47	19	5/1/1997	Unknown	Steel	
2754	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
6,000		11/10/2009			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: EXXONMOBIL BILLINGS PRODUCTS TERMINAL
607 EXXONMOBIL RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Michael Bailey, (406) 657-5404

Sys Fac ID: 56-11335
Last Inspected On: 2/12/2016
Operating Permit Renewal Date: 5/12/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
48	19	5/1/1997	Unknown	Steel	
2755	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
6,000		11/10/2009			
49	19	5/1/1997	Unknown	Steel	
2756	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
6,000		11/10/2009			
50	19	5/1/1997	Unknown	Steel	
2763	Yes		Impressed Current	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Hazardous Substance		10/3/2008	Deferred	Not Listed	
6,000		11/10/2009			

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: FLYING J INC BILLINGS
2775 OLD HARDIN RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-12585
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 2/13/2018

Owners/Operators: Montana Innovations LLC, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Trent Biggers, UST Class A Operator
Don Edmisten, UST Class A Operator
Trent Biggers, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1109			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/29/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000		6/26/2007	TLS-350/Gilbarco EMC , Veeder Root		
2	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1108			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/29/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000		6/26/2007	TLS-350/Gilbarco EMC , Veeder Root		
3	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1105			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/29/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		6/26/2007	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: FLYING J INC BILLINGS
2775 OLD HARDIN RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-12585
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 2/13/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4447			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/29/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		6/26/2007	TLS-350/Gilbarco EMC , Veeder Root		
5	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1110			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/29/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000		6/26/2007	TLS-350/Gilbarco EMC , Veeder Root		
6	25	8/1/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4448			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/29/2012	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000		6/26/2007	TLS-350/Gilbarco EMC , Veeder Root		
7	03	8/1/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5425		10/4/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: FLYING J INC BILLINGS
2775 OLD HARDIN RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-12585
Last Inspected On: 2/2/2015
Operating Permit Renewal Date: 2/13/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
9	03	8/1/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5427		10/4/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: ZIP TRIP 53
2975 GRAND AVE
BILLINGS, MT 59102 YELLOWSTONE
Contact: (406) 655-0871

Sys Fac ID: 56-13245
Last Inspected On: 2/23/2015
Operating Permit Renewal Date: 7/14/2018

Owners/Operators:

CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE WA 99213
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216

Ian Johnstone, UST Class A Operator
Nicholas Merritt, UST Class A Operator
Nicholas Merritt, UST Class B Operator
Darcy Ziegler, UST Class B Operator
Nicholas Merritt, UST Class B Global Operator
Karina Serrano, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	23	9/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
594			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		2/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco		
2	23	9/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
592			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco		
3	23	9/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
593			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		2/23/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 87
4041 GRAND AVE
BILLINGS, MT 59106 YELLOWSTONE
Contact: Paul Courchaine, (406) 651-9353

Sys Fac ID: 56-13723
Last Inspected On: 8/19/2016
Operating Permit Renewal Date: 11/20/2019

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

David Kujath, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Paul Courchaine, UST Class B Operator
Greg Hoffman, UST Class B Operator
Garrett Lapp, UST Class B Operator
Linda French, UST Class B Global Operator
David Kujath, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	6/1/1996	Steel Clad	Flexible Plastic	Ball Float Valve
3062			Double-Walled	Double-Walled	Yes
Currently in Use		6/1/2006	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/11/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		6/21/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	20	6/1/1996	Steel Clad	Flexible Plastic	Ball Float Valve
3063			Double-Walled	Double-Walled	Yes
Currently in Use		6/1/2006	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/11/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		6/21/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	20	6/1/1996	Steel Clad	Flexible Plastic	Ball Float Valve
3064			Double-Walled	Double-Walled	Yes
Currently in Use		6/1/2006	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/11/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		6/21/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 87
4041 GRAND AVE
BILLINGS, MT 59106 YELLOWSTONE

Contact: Paul Courchaine, (406) 651-9353

Sys Fac ID: 56-13723
Last Inspected On: 8/19/2016
Operating Permit Renewal Date: 11/20/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
4	20	6/1/1996	Steel Clad	Flexible Plastic	Ball Float Valve
3065			Double-Walled	Double-Walled	Yes
Currently in Use		6/1/2006	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/11/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	Yes
8,000		6/21/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	20	6/1/1996	Steel Clad	Flexible Plastic	Ball Float Valve
3066			Double-Walled	Double-Walled	Yes
Currently in Use		6/1/2006	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		7/11/2013	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		6/21/2013	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN AND COUNTRY HILL TOP
523 HILLTOP RD
BILLINGS, MT 59105 YELLOWSTONE

Contact: Wes Burley, (406) 256-1020

Sys Fac ID: 56-13731
Last Inspected On: 9/7/2016
Operating Permit Renewal Date: 12/12/2019

Owners/Operators: Town & Country Supply Association, Owner (406)-628-6314 PO BOX 367
LAUREL MT 59044-0367

Lucy Green, UST Class A Operator
Mark Heimbichner, UST Class A Operator
Leilani McCarthy, UST Class A Operator
Steven Shelton, UST Class A Operator
Leilani McCarthy, UST Class B Operator
Mark Heimbichner, UST Class B Global Operator
Steven Shelton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	7/1/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3419			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		12/3/2010	Gilbarco EMC Basic , Gilbarco		
2	20	7/1/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3420			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/7/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		12/3/2010	Gilbarco EMC Basic , Gilbarco		
3	02	6/30/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5509		6/30/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		7/14/2014	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor, Not Listed	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN PUMP BILLINGS #8
3969 GRAND AVE
BILLINGS, MT 59102 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-13741
Last Inspected On: 9/29/2014
Operating Permit Renewal Date: 2/7/2018

Owners/Operators:

Townhouse Inns of Conrad, Owner	(406)-497-6700	PO BOX 6000 BUTTE MT 59702
Town Pump Inc, Operator	(406)-497-6700	PO BOX 6000 BUTTE MT 59702-2534

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2013			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/22/2011	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000			TLS-350/Gilbarco EMC , Veeder Root		
2	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2014			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		12/22/2011	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
20,000			TLS-350/Gilbarco EMC , Veeder Root		
3	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2015			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/22/2011	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN PUMP BILLINGS #8
3969 GRAND AVE
BILLINGS, MT 59102 YELLOWSTONE
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-13741
Last Inspected On: 9/29/2014
Operating Permit Renewal Date: 2/7/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2016			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/22/2011	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
5	20	9/1/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
2017			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		12/22/2011	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: FIRST INTERSTATE CENTER
401 N 31ST ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Jermone Ries, (406) 255-7100

Sys Fac ID: 56-13766
Last Inspected On: 1/15/2016
Operating Permit Renewal Date: 6/1/2019

Owners/Operators: Billings 401 LLC, Owner (406)-255-7100 PO BOX 7047
BILLINGS MT 59103-7047

Jerome Ries, UST Class A Operator
Ricky Coop, UST Class B Operator
Patrick Kelly, UST Class B Operator
Leonard Meyer, UST Class B Operator
Jerome Ries, UST Class B Operator
Dennis Tallant, UST Class B Operator
Brad Zimmer, UST Class B Operator
Jim Zimmer, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	18	10/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
3400		1/15/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Diesel		1/16/2013	Manual Interstitial Monitor	Manual Interstitial Monitor	
560					

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CONOMART SUPERSTORE 7
4903 SOUTHGATE DR
BILLINGS, MT 59101 YELLOWSTONE

Contact: Dennis Whitmore, (406) 252-4661

Sys Fac ID: 56-13808
Last Inspected On: 9/7/2016
Operating Permit Renewal Date: 12/31/2019

Owners/Operators:

C Store Properties LLC, Owner	(406)-651-5101	PO BOX 80391 BILLINGS MT 59108
GM Cono Stores LLC, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107

Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Ken Jackson, UST Class A Operator
Charlie McHenry, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Laura Geffre, UST Class B Operator
Kerry Schmelzer, UST Class B Operator
Ron Tenney, UST Class B Operator
Tammie Turner, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	18	12/5/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1182			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/29/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	18	12/5/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1183			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/29/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: CONOMART SUPERSTORE 7
4903 SOUTHGATE DR
BILLINGS, MT 59101 YELLOWSTONE

Contact: Dennis Whitmore, (406) 252-4661

Sys Fac ID: 56-13808
Last Inspected On: 9/7/2016
Operating Permit Renewal Date: 12/31/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	17	12/5/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1184			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		5/29/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: THE WAVE CAR WASH
858 S 29TH ST W
BILLINGS, MT 59102 YELLOWSTONE
Contact: Steve Ott, (406) 656-2781

Sys Fac ID: 56-13884
Last Inspected On: 7/6/2016
Operating Permit Renewal Date: 9/13/2019

Owners/Operators: Ste Ott, Owner (406)-656-2781 858 S 29TH ST W BILLINGS MT 59102-7449

Stacy Ott, UST Class A Operator
Steven Ott, UST Class A Operator
Jessica Mascarena, UST Class B Operator
Stacy Ott, UST Class B Operator
Mark Roth, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	18	6/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3527			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/10/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
2	18	6/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3528			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		6/10/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: COSTCO WHOLESALE GASOLINE 69
2290 KING AVE W
BILLINGS, MT 59102 YELLOWSTONE
Contact: Dennis Bock, (425) 313-8100

Sys Fac ID: 56-13953
Last Inspected On: 1/22/2016
Operating Permit Renewal Date: 4/1/2019

Owners/Operators: Costco Wholesale, Owner (425)-313-8100 ATTN: LICENSING
PO BOX 35005
SEATTLE WA 98124-8990

Dennis Bock, UST Class A Operator
Michael Clough, UST Class A Operator
Richard Colgrove, UST Class A Operator
Andrew Jurcich, UST Class A Operator
Shawn Kipp, UST Class A Operator
Kyle Knox, UST Class A Operator
Arthur Kraft, UST Class A Operator
Dan Martinez, UST Class A Operator
Joel Osborne, UST Class A Operator
Samuel Rodriguez, UST Class A Operator
Michael Schaeffer, UST Class A Operator
Andrew Jurcich, UST Class B Operator
Shawn Kipp, UST Class B Operator
Kyle Knox, UST Class B Operator
Arthur Kraft, UST Class B Operator
Joel Osborne, UST Class B Operator
Hal Ostlund, UST Class B Operator
Brett G Smith, UST Class B Operator
Dennis Bock, UST Class B Global Operator
Michael Clough, UST Class B Global Operator
Kyle Knox, UST Class B Global Operator
Samuel Rodriguez, UST Class B Global Operator
Michael Schaeffer, UST Class B Global Operator
Mark Shellabarger, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: COSTCO WHOLESALE GASOLINE 69
2290 KING AVE W
BILLINGS, MT 59102 YELLOWSTONE
Contact: Dennis Bock, (425) 313-8100

Sys Fac ID: 56-13953
Last Inspected On: 1/22/2016
Operating Permit Renewal Date: 4/1/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	17	10/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4109			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Approved Remote Monitoring	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing, Approved Remote Monitoring	
30,000		11/19/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	17	10/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4110			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Approved Remote Monitoring	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing, Approved Remote Monitoring	
15,000		11/19/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	17	10/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4111			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Approved Remote Monitoring	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing, Approved Remote Monitoring	
15,000		11/19/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	05	4/1/2011	Concrete	Fiberglass Reinforced Plastic	High Level Alarm
5354	Yes		Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Hazardous Substance			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Deferred	MLLD Line Tightness Testing, Approved Remote Monitoring	
1,200		11/19/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: WELLS FARGO CENTER
175 N 27TH ST
BILLINGS, MT 59101 YELLOWSTONE

Contact: Robert Slayton, (406) 245-2748

Sys Fac ID: 56-13972
Last Inspected On: 3/27/2014
Operating Permit Renewal Date: 8/20/2017

Owners/Operators: S F H II LLC, Owner (406)-651-0603 PO BOX 1942
BILLINGS MT 59103-1942

John Schafnitz, UST Class A Operator
John Schafnitz, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
2	16	11/1/2000	Cathodically Protected Steel	Copper	Flapper Valve (Auto Shutoff)
4231			Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		3/27/2014	Continuous Interstitial Monitor	Not Listed	
400			LDE Series , Pneumercator		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: WELLS FARGO BANK OPERATIONS CENTER
2324 OVERLAND AVE
BILLINGS, MT 59102 YELLOWSTONE

Contact: Barr Stan, (406) 690-6680

Sys Fac ID: 56-13992
Last Inspected On: 5/19/2014
Operating Permit Renewal Date: 8/19/2017

Owners/Operators: Wells Fargo Bank Billings Operations Center, Owner (406)-655-7390 2324 OVERLAND AVE BILLINGS MT 59102-6401

Greg Amos, UST Class A Operator
Stan Barr Jr, UST Class A Operator
Richard Brodston, UST Class A Operator
Greg Amos, UST Class B Operator
Stan Barr Jr, UST Class B Operator
Richard Brodston, UST Class B Operator
Stan Barr Jr, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	16	9/1/2000	Steel Clad	Flexible Plastic	High Level Alarm
4279		9/10/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel		5/30/2008	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
2	16	9/1/2000	Steel Clad	Flexible Plastic	High Level Alarm
4280		9/10/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel		5/30/2008	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 108
790 S BILLINGS BLVD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Jack Krueger, (406) 860-9083

Sys Fac ID: 56-13994
Last Inspected On: 12/3/2013
Operating Permit Renewal Date: 2/4/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Jack Krueger Jr, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Linda French, UST Class B Global Operator
Jack Krueger Jr, UST Class B Global Operator
Jack Reed, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	15	5/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4285			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000		6/19/2010	TLS-350/Gilbarco EMC , Veeder Root		
2	15	5/4/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4286			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
10,000		6/29/2010	TLS-350/Gilbarco EMC , Veeder Root		
3	15	5/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4287			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Yes
10,000		7/25/2010	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 108
790 S BILLINGS BLVD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Jack Krueger, (406) 860-9083

Sys Fac ID: 56-13994
Last Inspected On: 12/3/2013
Operating Permit Renewal Date: 2/4/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	15	5/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4288			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconcilitation	Automatic Tank Gauging 0.2	Yes
20,000		6/22/2009	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: JTL GROUP INC UST
1102 SHILOH RD
BILLINGS, MT 59106 YELLOWSTONE

Contact: Patrick Schneider, (406) 322-2012

Sys Fac ID: 56-14001
Last Inspected On: 6/6/2016
Operating Permit Renewal Date: 10/23/2019

Owners/Operators: JTL Group Inc, Owner (406)-655-2012 PO BOX 80066
BILLINGS MT 59108-0066

Brian Nickel, UST Class A Operator
Dan Ottman, UST Class A Operator
Brian Nickel, UST Class B Operator
Dan Ottman, UST Class B Operator
Brian Nickel, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	15	4/1/2001	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
4397			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Deferred	
1,958			TLS-300 , Veeder Root		
2	15	4/1/2001	Steel Clad	Flexible Plastic	High Level Alarm
4398			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
13,019			TLS-300 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS SENIOR HIGH SCHOOL
425 GRAND AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: (406) 247-2100

Sys Fac ID: 56-14045
Last Inspected On: 2/3/2016
Operating Permit Renewal Date:

Owners/Operators: Billings School District, Owner (406)-247-3777 415 N 30TH ST BILLINGS MT 59101-1298

Dennis Stellingwerf, UST Class A Operator
Rodney Grotbo, UST Class B Operator
Bruce Schliticing, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	14	12/17/2001	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4601		10/27/2012	Double-Walled	Double-Walled	Yes
Temporarily Out of Use			Auto Dialer	Pressurized	Galvanic
Diesel		2/3/2016	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
3,000			ILS-350 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: LEWIS AND CLARK MIDDLE SCHOOL
1315 LEWIS AVE
BILLINGS, MT 59102 YELLOWSTONE

Contact: Richard Whitney, (406) 255-3778

Sys Fac ID: 56-14070
Last Inspected On: 10/23/2016
Operating Permit Renewal Date: 3/30/2020

Owners/Operators: Lewis and Clark Middle School, Owner (406)-255-3778 1315 LEWIS AVE BILLINGS MT 59102-4237

Dennis Stellingwerf, UST Class A Operator
Fred Gleich, UST Class B Global Operator
Timothy Schafft, UST Class B Global Operator

Tank Id	**Age**	**Installed**	**Tank Material of Construction**	**Piping Material**	**Overfill Types**
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	12	11/15/2004	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4970		9/13/2016	Double-Walled	Double-Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil		9/13/2016	Continuous Interstitial Monitor	Continuous Interstitial Monitor	
2,000			ILS-350 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MIDWEST MOTOR EXPRESS INC
214 ORCHARD LN
BILLINGS, MT 59101 YELLOWSTONE

Contact: Chris Booth, (406) 245-5938

Sys Fac ID: 56-14075
Last Inspected On: 11/17/2014
Operating Permit Renewal Date: 2/3/2018

Owners/Operators:

Midwest Motor Express, Owner	(406)-245-5938	220 ORCHARD LN BILLINGS MT 59101-4952
Christopher Booth, Operator	(406)-660-2151	305 SW BANNACK ST DILLON MT 59725

Loyd Allison, UST Class A Operator
Christopher Booth, UST Class A Operator
Loyd Allison, UST Class B Operator
Christopher Booth, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	13	1/9/2003	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
4782		10/17/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
20,000			TLS-300 , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS DIGITAL AIRPORT SURVEILLANCE RADAR
1901 TERMINAL CIR
BILLINGS, MT 59105 YELLOWSTONE

Sys Fac ID: 56-14077
Last Inspected On: 1/23/2015
Operating Permit Renewal Date: 3/26/2018

Contact: Charles Osborne, (406) 657-6981

Owners/Operators: Federal Aviation Admin Yellowstone SSC, Owner (406)-657-6455 FAA YELLOWSTONE SSC
1540 LAKE ELMO DR STE 6
BILLINGS MT 59105-1798

Michael Atkins, UST Class A Operator
Kim Feldt, UST Class A Operator
Paul Henley, UST Class A Operator
George Lamb, UST Class A Operator
Evan Wolfe, UST Class A Operator
Michael Atkins, UST Class B Operator
Paul Henley, UST Class B Operator
Kim Feldt, UST Class B Global Operator
Paul Henley, UST Class B Global Operator
George Lamb, UST Class B Global Operator
Evan Wolfe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	13	12/30/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff, High Level Alarm
4780		7/3/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
1,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY #731
1280 GRAND AVE
BILLINGS, MT 59102 YELLOWSTONE
Contact: (952) 830-8899

Sys Fac ID: 56-14090
Last Inspected On: 5/13/2015
Operating Permit Renewal Date: 10/1/2018

Owners/Operators:

Rocky Mountain Oil Inc, Owner	(952)-830-8700	ATTN: ENVIRONMENTAL DIRECTOR 4567 AMERICAN BLVD W BLOOMINGTON MN 55437
Holiday #731, Operator	(952)-830-8747	1280 GRAND AVE BILLINGS MT 59102

Robert Deninno, UST Class A Operator
Michael Anderson, UST Class B Operator
Denny Munger, UST Class B Operator
Jason Vetsch, UST Class B Operator
Shelley Waters, UST Class B Operator
Darold Heck, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	13	6/24/2003	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm, Positive Shutoff
4844			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		6/22/2012	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	13	6/24/2003	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4845			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		5/9/2012	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY #731
1280 GRAND AVE
BILLINGS, MT 59102 YELLOWSTONE
Contact: (952) 830-8899

Sys Fac ID: 56-14090
Last Inspected On: 5/13/2015
Operating Permit Renewal Date: 10/1/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	13	6/24/2003	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4846			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000		5/7/2012	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: RADISSON HOTEL BILLINGS
5500 MIDLAND RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Tony Contreraz, (406) 248-7701

Sys Fac ID: 56-14103
Last Inspected On: 4/20/2016
Operating Permit Renewal Date: 6/22/2019

Owners/Operators: 5500 Midland Holdings LLC, Owner (386)-947-7741 1275 W GRANADA BLVD STE 3B ORMOND BEACH FL 32174

Jonathan Harpole, UST Class A Operator
Douglas Schmidt, UST Class A Operator
Douglas Schmidt, UST Class B Operator
Jonathan Harpole, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	12	3/12/2004	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4887		4/20/2016	None	Secondary Containment Chase	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Diesel		4/20/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
500		9/20/2004	EECO 1500 , EMCO Electronics		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: BILLINGS OPERATION CENTER
4848 MIDLAND RD
BILLINGS, MT 59101 YELLOWSTONE
Contact: Clifford Fillner, (406) 657-8216

Sys Fac ID: 56-14118
Last Inspected On: 10/13/2016
Operating Permit Renewal Date: 12/10/2019

Owners/Operators: City of Billings Operation Center, Owner (406)-657-8216 PO BOX 1178 BILLINGS MT 59103-1178

Larry Deschene, UST Class A Operator
Troy Namen, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	12	7/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4935			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	12	7/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4936			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	12	7/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4937			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	12	7/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4938			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: AIR TRAFFIC CONTROL TOWER
1907 TERMINAL CIR
BILLINGS, MT 59105 YELLOWSTONE
Contact: George Lamb, (406) 657-6455

Sys Fac ID: 56-14127
Last Inspected On: 2/12/2014
Operating Permit Renewal Date: 4/18/2017

Owners/Operators: Federal Aviation Administration, Owner (406)-657-6981 1613 AVIATION PL BILLINGS MT 59105

Michael Atkins, UST Class A Operator
Kim Feldt, UST Class A Operator
Craig Fitzgerald, UST Class A Operator
Paul Henley, UST Class A Operator
George Lamb, UST Class A Operator
Evan Wolfe, UST Class A Operator
Michael Atkins, UST Class B Operator
Paul Henley, UST Class B Operator
Kim Feldt, UST Class B Global Operator
Craig Fitzgerald, UST Class B Global Operator
Paul Henley, UST Class B Global Operator
George Lamb, UST Class B Global Operator
Evan Wolfe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	11	12/9/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
4976		9/1/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN PUMP INC BILLINGS 3
3150 KING AVE W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15023
Last Inspected On: 12/21/2015
Operating Permit Renewal Date: 4/2/2019

Owners/Operators: New Inns Inc, Owner
PO BOX 6000
BUTTE MT 59702

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	10	4/14/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5062			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
20,000		5/1/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	10	4/1/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5056			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		5/1/2006	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	10	4/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5057			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		5/1/2006	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN PUMP INC BILLINGS 3
3150 KING AVE W
BILLINGS, MT 59102 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15023
Last Inspected On: 12/21/2015
Operating Permit Renewal Date: 4/2/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	10	4/14/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5058			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	10	4/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5059			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		5/1/2006	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	10	4/6/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5060			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		5/1/2006	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: MCDONALD LIGHTHOUSE
3212 1ST AVE S
BILLINGS, MT 59101 YELLOWSTONE

Contact: Dale Orth, (406) 670-2012

Sys Fac ID: 60-15027
Last Inspected On: 6/4/2015
Operating Permit Renewal Date: 9/6/2018

Owners/Operators:

Yellowstone Boys & Girls Ranch, Owner	(406)-651-3100	ATTN DALE ORTH 3212 1ST AVE S BILLINGS MT 59101-3824
DALE ORTH, Operator	(406)-670-2012	671 REPUBLIC AVE BILLINGS MT 59105

Gregory Leeds, UST Class A Operator
DALE ORTH, UST Class A Operator
Rick Kelum, UST Class B Operator
DALE ORTH, UST Class B Operator
Patrick Friesen, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	10	2/6/2006	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5072			Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Not Applicable
Heating Oil			Continuous Interstitial Monitor	MLLD Line Tightness Testing	
6,000		6/4/2015	ILS-350 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 385
3630 GABEL ROAD
BILLINGS, MT 59102 YELLOWSTONE
Contact: Jack Krueger, (406) 651-9872

Sys Fac ID: 60-15065
Last Inspected On: 2/21/2014
Operating Permit Renewal Date: 5/20/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner (952)-830-8899 ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55440

Jack Krueger Jr, UST Class A Operator
Ronald VanDenBroeke, UST Class A Operator
Carrie Cook, UST Class B Operator
Terry Youngblood, UST Class B Operator
Linda French, UST Class B Global Operator
Jack Krueger Jr, UST Class B Global Operator
Jeff Reed, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	08	12/11/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5139			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Manual Interstitial Monitor	Yes
20,000		12/24/2010	TLS-350/Gilbarco EMC , Veeder Root		Yes
2	08	12/11/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5140			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Manual Interstitial Monitor	Yes
12,000		12/22/2010	TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: HOLIDAY STATIONSTORE 385
3630 GABEL ROAD
BILLINGS, MT 59102 YELLOWSTONE

Contact: Jack Krueger, (406) 651-9872

Sys Fac ID: 60-15065
Last Inspected On: 2/21/2014
Operating Permit Renewal Date: 5/20/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	08	12/11/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5141			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Manual Interstitial Monitor	Yes
8,000		12/16/2010	TLS-350/Gilbarco EMC , Veeder Root		Yes
4	08	12/11/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5142			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Manual Interstitial Monitor	
12,000		12/24/2010	TLS-350/Gilbarco EMC , Veeder Root		Yes
5	08	12/11/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5143			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Manual Interstitial Monitor	
8,000		12/24/2010	TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DONS EXPRESS CENTER
2324 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE

Contact: Gary Carlson, (406) 248-2558

Sys Fac ID: 60-15096
Last Inspected On: 10/17/2014
Operating Permit Renewal Date: 1/10/2018

Owners/Operators: Automatic Car Wash Inc, Owner (406)-248-2558 PO BOX 1278 BILLINGS MT 59103-1278
Gene Carlson, UST Class A Operator
Gene Carlson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	08	6/29/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5160			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
12,000		7/21/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	Yes
2	08	6/29/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5161			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
5,000		7/21/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	Yes
3	08	6/29/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5162			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
5,000		7/20/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: DONS EXPRESS CENTER
2324 MAIN ST
BILLINGS, MT 59105 YELLOWSTONE

Contact: Gary Carlson, (406) 248-2558

Sys Fac ID: 60-15096
Last Inspected On: 10/17/2014
Operating Permit Renewal Date: 1/10/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	08	6/29/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5163			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
5,000		7/23/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, ELLD Line Tightness Testing	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: Lynch Flying Service Inc
1482 AVIATION PLACE
BILLINGS, MT 59105 YELLOWSTONE
Contact: (406) 252-0508

Sys Fac ID: 60-15100
Last Inspected On: 8/8/2014
Operating Permit Renewal Date: 10/15/2017

Owners/Operators:

Edwards Jet Center, Owner	(406)-252-0508	1691 AVIATION PL BILLINGS MT 59105-1994
LYNCH FLYING SERVICE INC, Operator	(406)-252-0508	DBA EDWARDS JET CENTER 1691 AVIATION PL BILLINGS MT 59105-1981

Warren Nemitz, UST Class A Operator
Joel Simmons, UST Class A Operator
Aaron VanLuchene, UST Class A Operator
Joel Simmons, UST Class B Operator
Warren Nemitz, UST Class B Global Operator
Aaron VanLuchene, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	08	2/25/2008	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
5172		7/28/2014	Double-Walled	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Not Listed	Not Applicable
Jet Fuel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
20,000			TLS-350/Gilbarco EMC , Veeder Root		Yes
2	08	2/25/2008	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
5173		7/28/2014	Double-Walled	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Not Listed	Not Applicable
Jet Fuel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
20,000			TLS-350/Gilbarco EMC , Veeder Root		Yes
3	08	2/25/2008	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
5174		7/28/2014	Double-Walled	None	Yes
Currently in Use			Continuous Interstitial Monitoring	Not Listed	Not Applicable
Aviation Gas			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Continuous Interstitial Monitor, Not Listed	
12,000			TLS-350/Gilbarco EMC , Veeder Root		Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN PUMP INC BILLINGS 4
2711 N FRONTAGE RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15104
Last Inspected On: 2/1/2016
Operating Permit Renewal Date: 4/2/2019

Owners/Operators:

Town Pump Inc, Owner	(406)-497-6700	PO BOX 6000 BUTTE MT 59702-2534
Park Street Holdings LLC, Operator	(406)-467-6700	PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	07	12/15/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5180			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
2	07	12/15/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5181			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
3	07	12/15/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5182			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
30,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: TOWN PUMP INC BILLINGS 4
2711 N FRONTAGE RD
BILLINGS, MT 59101 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 60-15104
Last Inspected On: 2/1/2016
Operating Permit Renewal Date: 4/2/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	07	12/15/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5183			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
24,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
5	07	12/18/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5184			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
6	07	12/18/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5185			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Yes
24,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
7	07	12/15/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
5186			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SAM'S CLUB
4420 KING AVE E
BILLINGS, MT 59101 YELLOWSTONE
Contact: John May, (479) 277-9639

Sys Fac ID: 60-15138
Last Inspected On: 4/6/2016
Operating Permit Renewal Date: 6/17/2019

Owners/Operators: WALMART STORES INC, Owner (479)-273-4000 ATTN JOHN MAY
702 SW 8TH ST
BENTONVILLE AR 72716-6209

Kevin E Allen, UST Class A Operator
Taryn Bailey, UST Class A Operator
Dustin Branson, UST Class A Operator
Donald Elderbaum, UST Class A Operator
Sandy Goff, UST Class A Operator
Steven Hodge, UST Class A Operator
Scott Murray, UST Class A Operator
Dustin Branson, UST Class B Operator
Joseph Khan, UST Class B Operator
Kevin E Allen, UST Class B Global Operator
Taryn Bailey, UST Class B Global Operator
Donald Elderbaum, UST Class B Global Operator
Sandy Goff, UST Class B Global Operator
Steven Hodge, UST Class B Global Operator
Scott Murray, UST Class B Global Operator
James Ray, UST Class B Global Operator
Rick Weaver, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	07	9/8/2009	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5210			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
20,000		4/6/2016	OPW 1500 , OPW	Continuous Interstitial Monitor	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: SAM'S CLUB
4420 KING AVE E
BILLINGS, MT 59101 YELLOWSTONE
Contact: John May, (479) 277-9639

Sys Fac ID: 60-15138
Last Inspected On: 4/6/2016
Operating Permit Renewal Date: 6/17/2019

Tank Id / Tag Number / Status / Product / Capacity	Age / AST	Installed / Sump Tightness / Inventory Control / Tank/Pipe CP / Line Tightness	Tank Material of Construction / Secondary Option / Catastrophic L.D. Type 3.0 / Tank Detection / ATG Type	Piping Material / Secondary Option / Piping Type / Primary Pipe Detection / Secondary Pipe Detection	Overfill Types / Spill Protected / CP Met Types / Vapor Recovery / Energy Act
2	07	9/8/2009	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5211			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
20,000		4/6/2016	OPW 1500 , OPW	Continuous Interstitial Monitor	Yes
3	07	9/8/2009	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5212			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
12,000		4/6/2016	OPW 1500 , OPW	Continuous Interstitial Monitor	Yes
4	07	9/8/2009	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5213			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	MLLD Line Tightness Testing	
8,000		4/6/2016	OPW 1500 , OPW	Continuous Interstitial Monitor	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: Rental Car Wash
3301 OVERLOOK DR
BILLINGS, MT 59105 YELLOWSTONE

Contact: DONALD KIM ANNIN, (406) 657-8482

Sys Fac ID: 60-15179
Last Inspected On: 12/23/2014
Operating Permit Renewal Date: 3/24/2018

Owners/Operators:

Billings Logan International Airport, Owner	(406)-657-8482	1901 TERMINAL CIR STE 216 BILLINGS MT 59105-1991
Donald Kim Annin, Operator	(406)-657-8495	BILLINGS LOGAN INTERNATIONAL AIRPORT 1901 TERMINAL CIR STE 216 BILLINGS MT 59105-1991

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	05	4/11/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5288			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
20,000		12/23/2014			Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: Fed Ex Freight
7107 COMMERCIAL AVE
BILLINGS, MT 59101 YELLOWSTONE
Contact: Chong Lee, (408) 654-3112

Sys Fac ID: 60-15181
Last Inspected On: 1/16/2015
Operating Permit Renewal Date: 3/17/2018

Owners/Operators: K W Billings, LLC, Owner (619)-435-1614 941 ORANGE AVE STE 512 CORONADO CA 92118

Adren Hillenburg, UST Class A Operator
Chong Lee, UST Class A Operator
Nick Haynes, UST Class B Operator
Kevin Roberts, UST Class B Operator
Adren Hillenburg, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	05	5/23/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5293			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		7/16/2014	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: FEDEX GROUND BILLINGS
3815 HESPER ROAD
BILLINGS, MT 59106 YELLOWSTONE

Contact: Nancy Beaumont, (412) 262-7347

Sys Fac ID: 60-15209
Last Inspected On: 12/15/2014
Operating Permit Renewal Date: 12/30/2017

Owners/Operators: FedEx Ground, Owner (412)-262-7347 1000 FEDEX DRIVE
MOON TOWNSHIP PA 15108

Lorraine Nogrady, UST Class A Operator
Lorraine Nogrady, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	03	10/1/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, High Level Alarm
5447		11/6/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
30,000		8/13/2014	TLS-450 , Veeder Root	MLLD Line Tightness Testing, Not Listed	
2	03	10/1/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve, High Level Alarm
5448		11/9/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
30,000		8/13/2014	TLS-450 , Veeder Root	MLLD Line Tightness Testing, Not Listed	
3	03	10/1/2013	Fiberglass Reinforced Plastic	Other	Ball Float Valve, High Level Alarm
5449		11/9/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
>B20			Continuous Interstitial Monitor	Continuous Interstitial Monitor	
12,000			TLS-450 , Veeder Root	Not Listed	

Facility Summary in YELLOWSTONE County in the City of BILLINGS

Location: OLD DOMINION FREIGHT LINES
1030 INTERMOUNTAIN STREET
BILLINGS, MT 59101 YELLOWSTONE

Sys Fac ID: 60-15216
Last Inspected On: 7/25/2016
Operating Permit Renewal Date: 8/25/2019

Contact: Robert Alexander, (336) 822-5571

Owners/Operators:

Old Dominion Freight Line, Owner	(336)-889-5000	ATTN: CONTROL MAINTENANCE 500 OLD DOMINION WAY THOMASVILLE NC 27360
Robert Alexander, Operator	(406)-256-6506	1030 INTERMOUNTAIN BILLINGS MT 59101
Richard A McGuire, UST Class A Operator		
Lorrin Wallace, UST Class A Operator		
Ben Figg, UST Class B Global Operator		
Lorrin Wallace, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	04	10/1/2012	Unknown	Fiberglass Reinforced Plastic	
5393	Yes		Double-Walled	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000		7/25/2016	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in YELLOWSTONE County in the City of BROADVIEW

Location: BROADVIEW 500 KV SUBSTATION
MT HIGHWAY 3
BROADVIEW, MT 59015 YELLOWSTONE

Contact: Beth Stimatz, (406) 497-2687

Sys Fac ID: 56-01431
Last Inspected On: 9/1/2016
Operating Permit Renewal Date: 11/7/2019

Owners/Operators: Northwestern Energy, Owner (406)-655-2521 405 S 20TH ST W BILLINGS MT 59102

John Habeger, UST Class A Operator
Darren Brockel, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	34	4/30/1982	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
1686		7/18/2016	None	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
2,500			OPW 1500 , OPW		

Facility Summary in YELLOWSTONE County in the City of BROADVIEW

Location: BROADVIEW SERVICE STATION LLC
16437 IOWA AVE
BROADVIEW, MT 59015 YELLOWSTONE

Contact: Elisha Lewis, (406) 322-5214

Sys Fac ID: 56-02373
Last Inspected On: 12/23/2014
Operating Permit Renewal Date: 2/24/2018

Owners/Operators:

Broadview Service Station LLC, Owner	(406)-667-2253	16437 IOWA AVE BROADVIEW MT 59015-9751
Farmers Union Trading Co Columbus, Operator	(406)-322-5618	PO BOX 509 COLUMBUS MT 59019-0509

Jennifer Calovis, UST Class A Operator
Sonia Hollingsworth, UST Class A Operator
Jarred Mosdal, UST Class A Operator
Nathanial Williams, UST Class A Operator
Scott Hollingsworth, UST Class B Operator
Sonia Hollingsworth, UST Class B Operator
Susan Wood, UST Class B Operator
Jennifer Calovis, UST Class B Global Operator
Sonia Hollingsworth, UST Class B Global Operator
Elisha Lewis, UST Class B Global Operator
Nathanial Williams, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
6	20	5/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3410			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/23/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		7/28/2014	TLS-350/Gilbarco EMC , Veeder Root		
7	20	5/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3411			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/23/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
6,000		7/28/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of BROADVIEW

Location: BROADVIEW SERVICE STATION LLC
16437 IOWA AVE
BROADVIEW, MT 59015 YELLOWSTONE

Contact: Elisha Lewis, (406) 322-5214

Sys Fac ID: 56-02373
Last Inspected On: 12/23/2014
Operating Permit Renewal Date: 2/24/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	20	5/1/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
3412			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		12/23/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		7/28/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of CUSTER

Location: CUSTER STATION
523 2ND ST
CUSTER, MT 59024 YELLOWSTONE
Contact: Kirk Marzolf, (406) 967-3100

Sys Fac ID: 56-05291
Last Inspected On: 2/6/2016
Operating Permit Renewal Date: 4/30/2019

Owners/Operators: Farmers Union Oil Co, Owner (406)-967-3100 PO BOX 309
WORDEN MT 59088-0309

Scott Black, UST Class A Operator
Kirk Marzolf, UST Class A Operator
Tammy Onstine, UST Class B Operator
Marion Perrin, UST Class B Operator
Lenore Rogers, UST Class B Operator
Sherry Ward, UST Class B Operator
Trina Wilson, UST Class B Operator
Scott Black, UST Class B Global Operator
Lacey Cox, UST Class B Global Operator
Marion Perrin, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	17	7/1/1999	Unknown	Flexible Plastic	
4079	Yes	6/21/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
5,000			Gilbarco EMC Basic , Gilbarco		
6	17	7/1/1999	Unknown	Flexible Plastic	
4080	Yes	6/21/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		
7	17	7/1/1999	Unknown	Flexible Plastic	
4081	Yes	6/21/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
12,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of CUSTER

Location: CUSTER STATION
523 2ND ST
CUSTER, MT 59024 YELLOWSTONE

Contact: Kirk Marzolf, (406) 967-3100

Sys Fac ID: 56-05291
Last Inspected On: 2/6/2016
Operating Permit Renewal Date: 4/30/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	17	7/1/1999	Unknown	Flexible Plastic	
4082	Yes	6/21/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
10,000			Gilbarco EMC Basic , Gilbarco		

Facility Summary in YELLOWSTONE County in the City of HUNTLEY

Location: HUNTLEY EXPRESSWAY
135 NORTHERN AVE
HUNTLEY, MT 59037 YELLOWSTONE

Contact: Jim Woods, (406) 640-2860

Sys Fac ID: 56-00627
Last Inspected On: 9/30/2014
Operating Permit Renewal Date: 12/16/2017

Owners/Operators: Set Five LLC, Owner (406)-348-9209 PO BOX 161730
BIG SKY MT 59716

Bernie Greenfield, Operator 1126 YORKTOWN ST
BILLINGS MT 59105

Bernie Greenfield, UST Class A Operator
Cheryl Greenfield, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	18	11/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3660			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
4	18	11/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3661			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
5	18	11/1/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3662			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/30/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: LAUREL TRAVEL CENTER
11360 S FRONTAGE RD
LAUREL, MT 59044 YELLOWSTONE
Contact: Kelly Gelski, (440) 808-7406

Sys Fac ID: 56-00626
Last Inspected On: 11/11/2016
Operating Permit Renewal Date: 12/31/2019

Owners/Operators: TA Operating LLC, Owner/Operator (440)-808-7406 24601 CENTER RIDGE RD WESTLAKE OH 44145

Renee Andrews, UST Class A Operator
Mike Rathbone, UST Class A Operator
Renee Andrews, UST Class B Operator
Mike Rathbone, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	45	5/3/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1795		8/18/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		8/1/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000		8/17/2016	TLS-350/Gilbarco EMC , Veeder Root	MLLD Line Tightness Testing	
2	48	5/2/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1796		8/18/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		8/1/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000		8/17/2016	TLS-350/Gilbarco EMC , Veeder Root	MLLD Line Tightness Testing	
3	48	5/2/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1794		8/18/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		8/1/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000		8/17/2016	TLS-350/Gilbarco EMC , Veeder Root	MLLD Line Tightness Testing	
4	48	5/2/1968	Cathodically Protected Steel	Steel	High Level Alarm
1792		8/18/2016	Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/1/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000		10/27/2016	TLS-350/Gilbarco EMC , Veeder Root	MLLD Line Tightness Testing	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: LAUREL TRAVEL CENTER
11360 S FRONTAGE RD
LAUREL, MT 59044 YELLOWSTONE
Contact: Kelly Gelski, (440) 808-7406

Sys Fac ID: 56-00626
Last Inspected On: 11/11/2016
Operating Permit Renewal Date: 12/31/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	48	5/2/1968	Cathodically Protected Steel	Steel	High Level Alarm
1793		8/18/2016	Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		8/1/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000		10/27/2016	TLS-350/Gilbarco EMC , Veeder Root	MLLD Line Tightness Testing	
6	48	5/2/1968	Cathodically Protected Steel	Steel	High Level Alarm
1791		8/18/2016	Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		8/1/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
6,000		10/27/2016	TLS-350/Gilbarco EMC , Veeder Root	MLLD Line Tightness Testing	
7	48	5/2/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1797		8/18/2016	Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		8/1/2016	Stat. Inventory Reconcilitation	Stat. Inventory Reconcilitation	
10,000		8/17/2016	TLS-350/Gilbarco EMC , Veeder Root	MLLD Line Tightness Testing	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: LAUREL SERVICE CENTER INC UST
201 W MAIN ST
LAUREL, MT 59044 YELLOWSTONE

Contact: David Powers, (406) 628-4216

Sys Fac ID: 56-01069
Last Inspected On: 7/8/2014
Operating Permit Renewal Date: 8/20/2017

Owners/Operators:

John Munro, Owner	(406)-628-4216	201 W MAIN ST LAUREL MT 59044-3108
Laurel Service Center Inc, Operator	(406)-628-4216	201 W MAIN ST LAUREL MT 59044-3108
John Munro, UST Class A Operator		
John Munro, UST Class B Global Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	30	4/29/1986	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1808			Impressed Current	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		6/20/2014	Automatic Tank Gauging 0.2	Deferred	
10,000		8/8/2007	TLS-350/Gilbarco EMC , Veeder Root		
2	28	4/28/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1809			Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/20/2014	Not Listed	Not Listed	
10,000		8/8/2007	TLS-350/Gilbarco EMC , Veeder Root		
10	29	4/29/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1810			None	None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		6/20/2014	Automatic Tank Gauging 0.2	Deferred	
10,000		8/8/2006	TLS-350/Gilbarco EMC , Veeder Root		
11	28	4/28/1988	Cathodically Protected Steel	No Piping	Flapper Valve (Auto Shutoff)
1811			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Safe Suction	Impressed Current
Diesel		6/20/2014	Not Listed	Not Listed	
10,000		8/8/2007	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: LAUREL SERVICE CENTER INC UST
201 W MAIN ST
LAUREL, MT 59044 YELLOWSTONE

Contact: David Powers, (406) 628-4216

Sys Fac ID: 56-01069
Last Inspected On: 7/8/2014
Operating Permit Renewal Date: 8/20/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
12	28	4/28/1988	Cathodically Protected Steel	No Piping	Flapper Valve (Auto Shutoff)
1812			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Diesel		6/20/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Not Listed	
8,000		8/8/2007	TLS-350/Gilbarco EMC , Veeder Root		
13	28	4/28/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1813			None	None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Diesel		6/20/2014	Not Listed	Not Listed	
4,000		8/8/2007	TLS-350/Gilbarco EMC , Veeder Root		
14	28	4/28/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1814			None	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/20/2014	Not Listed	Not Listed	
4,000		8/8/2007	TLS-350/Gilbarco EMC , Veeder Root		
15	18	11/15/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1815			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/20/2014	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
10,000		8/8/2007	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: TOWN & COUNTRY SUPPLY LAUREL ASSN
800 E MAIN ST
LAUREL, MT 59044 YELLOWSTONE

Sys Fac ID: 56-04497
Last Inspected On: 9/6/2016
Operating Permit Renewal Date: 12/14/2019

Contact: Wes Burley, (406) 628-6314

Owners/Operators: Town & Country Supply Association, Owner (406)-628-6314 PO BOX 367
LAUREL MT 59044-0367

Wesley Burley, UST Class A Operator
Karissa DeRudder, UST Class A Operator
Vincent Farr, UST Class A Operator
Ronni Nace, UST Class A Operator
Steven Shelton, UST Class A Operator
Karissa DeRudder, UST Class B Operator
Vincent Farr, UST Class B Operator
Ronni Nace, UST Class B Operator
Jennifer Reinhardt, UST Class B Operator
Steven Shelton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	26	2/12/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
4470			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/6/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		8/3/2016	TLS-350/Gilbarco EMC , Veeder Root		
2	26	2/12/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1520			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		9/6/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		8/3/2016	TLS-350/Gilbarco EMC , Veeder Root		
3	26	2/12/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
4471			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		9/6/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
2,000		8/3/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: TOWN & COUNTRY SUPPLY LAUREL ASSN
800 E MAIN ST
LAUREL, MT 59044 YELLOWSTONE

Contact: Wes Burley, (406) 628-6314

Sys Fac ID: 56-04497
Last Inspected On: 9/6/2016
Operating Permit Renewal Date: 12/14/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	26	2/12/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1518			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasohol/Ethanol		9/6/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		8/3/2016	TLS-350/Gilbarco EMC , Veeder Root		
12	26	2/12/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
4472			None	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		9/6/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	
4,000		8/3/2016	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: FASTLANE C STORES
815 E MAIN ST
LAUREL, MT 59044 YELLOWSTONE
Contact: (406) 628-6204

Sys Fac ID: 56-05083
Last Inspected On: 7/28/2014
Operating Permit Renewal Date: 9/25/2017

Owners/Operators:

East Main Development LLC, Owner	(406)-628-6204	1415 RIDGE DR LAUREL MT 59044
Fastlane C Stores, Operator	(406)-628-6204	1415 RIDGE DR LAUREL MT 59044
Dan Foos, UST Class A Operator		
Dan Foos, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	41	10/1/1975	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3831			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/28/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		5/27/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	41	10/1/1975	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3832			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		7/28/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,200		5/25/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	41	10/1/1975	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3833			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		7/28/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000		6/14/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: CONOMART SUPERSTORE 3
519 W MAIN ST
LAUREL, MT 59044 YELLOWSTONE

Contact: Dennis Whitmore, (406) 628-2034

Sys Fac ID: 56-06965
Last Inspected On: 1/25/2016
Operating Permit Renewal Date: 6/2/2019

Owners/Operators:

C Store Properties LLC, Owner	(406)-651-5101	PO BOX 80391 BILLINGS MT 59108
GM Cono Stores LLC, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107

Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Ken Jackson, UST Class A Operator
Charlie McHenry, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Jewell Borchardt, UST Class B Operator
Laura Geffre, UST Class B Operator
Roger Schmechel, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	21	10/17/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1173			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/29/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		11/9/2009	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	21	10/17/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1174			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		1/29/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		11/9/2009	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: CONOMART SUPERSTORE 3
519 W MAIN ST
LAUREL, MT 59044 YELLOWSTONE

Contact: Dennis Whitmore, (406) 628-2034

Sys Fac ID: 56-06965
Last Inspected On: 1/25/2016
Operating Permit Renewal Date: 6/2/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	21	10/17/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1172			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/29/2016	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		11/9/2009	Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: CONOMART SUPERSTORE 2
411 E 1ST ST
LAUREL, MT 59044 YELLOWSTONE

Contact: Whitmore Dennis, (406) 252-4661

Sys Fac ID: 56-06966
Last Inspected On: 9/22/2015
Operating Permit Renewal Date: 3/17/2019

Owners/Operators:

C Store Properties LLC, Owner	(406)-651-5101	PO BOX 80391 BILLINGS MT 59108
GM Cono Stores LLC, Operator	(406)-252-4661	PO BOX 30335 BILLINGS MT 59107

Laura Geffre, UST Class A Operator
Bill Grunstead, UST Class A Operator
Ken Jackson, UST Class A Operator
Charlie McHenry, UST Class A Operator
Roger Schmechel, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Linda Degele, UST Class B Operator
Laura Geffre, UST Class B Operator
Roger Schmechel, UST Class B Operator
Janice Wade, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	39	4/22/1977	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1177			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/22/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		5/22/2015	TLS-350/Gilbarco EMC , Veeder Root		
2	39	4/22/1977	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1176			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/22/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		5/22/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: CONOMART SUPERSTORE 2
411 E 1ST ST
LAUREL, MT 59044 YELLOWSTONE

Contact: Whitmore Dennis, (406) 252-4661

Sys Fac ID: 56-06966
Last Inspected On: 9/22/2015
Operating Permit Renewal Date: 3/17/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
3	39	4/22/1977	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1175			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		9/22/2015	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		5/16/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: LAUREL CENEX C STORE
315 S 1ST AVE
LAUREL, MT 59044 YELLOWSTONE

Contact: Wayne M Reese, (406) 628-8660

Sys Fac ID: 56-08161
Last Inspected On: 9/8/2016
Operating Permit Renewal Date: 12/27/2019

Owners/Operators: Town & Country Supply Association, Owner (406)-628-6314 PO BOX 367
LAUREL MT 59044-0367

Wesley Burley, UST Class A Operator
Steven Shelton, UST Class A Operator
Cathy Culp, UST Class B Global Operator
Steven Shelton, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
5	21	5/22/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1523			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasohol/Ethanol		9/8/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
6	21	5/22/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1524			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/8/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
7	21	5/22/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1525			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/8/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: LAUREL CENEX C STORE
315 S 1ST AVE
LAUREL, MT 59044 YELLOWSTONE

Contact: Wayne M Reese, (406) 628-8660

Sys Fac ID: 56-08161
Last Inspected On: 9/8/2016
Operating Permit Renewal Date: 12/27/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
8	21	5/22/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1526			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/8/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	21	5/22/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1527			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/8/2016	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: TOWN PUMP INC LAUREL
312 FIRST AVE S
LAUREL, MT 59044 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-08710
Last Inspected On: 2/29/2016
Operating Permit Renewal Date: 4/29/2019

Owners/Operators: Major Brands Distributing Imports Inc, Owner (406)-497-6700 PO BOX 6000 BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Don Edmisten, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	42	4/14/1974	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2668			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Diesel		11/18/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
2	42	4/14/1974	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2669			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		11/18/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		
3	42	4/14/1974	Cathodically Protected Steel	Steel	Flapper Valve (Auto Shutoff)
2670			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		11/18/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
8,000			TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: TOWN PUMP INC LAUREL
312 FIRST AVE S
LAUREL, MT 59044 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-08710
Last Inspected On: 2/29/2016
Operating Permit Renewal Date: 4/29/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
4	36	4/14/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), Ball Float Valve
4589			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Diesel		11/18/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	
5	36	4/14/1980	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
2672			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Gasoline		11/18/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	
6	29	4/1/1987	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff), Ball Float Valve
4603			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current, Galvanic
Diesel		11/18/2014	Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
12,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: TOWN PUMP INC LAUREL
312 FIRST AVE S
LAUREL, MT 59044 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-08710
Last Inspected On: 2/29/2016
Operating Permit Renewal Date: 4/29/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
7	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4590			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/18/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	
8	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4591			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/18/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	
9	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4592			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/18/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	
10	15	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4593			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/18/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: TOWN PUMP INC LAUREL
312 FIRST AVE S
LAUREL, MT 59044 YELLOWSTONE

Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 56-08710
Last Inspected On: 2/29/2016
Operating Permit Renewal Date: 4/29/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
11	15	8/25/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4594			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/18/2014	Continuous Interstitial Monitor, Stat. Inventory Reconcilitation, Approved Remote Monitoring	Stat. Inventory Reconcilitation, Approved Remote Monitoring	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Approved Remote Monitoring	

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: NORTHERN SKIES AVIATION
3900 FOX ROAD
LAUREL, MT 59044 YELLOWSTONE

Contact: Brent Larson, (406) 628-2219

Sys Fac ID: 56-13474
Last Inspected On: 11/16/2015
Operating Permit Renewal Date: 1/27/2019

Owners/Operators: Kent Potter, Owner (406)-628-2219 NORTHERN SKIES AVIATION
PO BOX 936
LAUREL MT 59044-0936

Brent Larson, UST Class A Operator
Brent Larson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	22	6/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4295			Double-Walled	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		11/16/2015	Manual Interstitial Monitor	MLLD Line Tightness Testing	
7,000		11/16/2015			
2	22	6/1/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
4296			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		11/16/2015	Manual Interstitial Monitor	Deferred	
3,000					

Facility Summary in YELLOWSTONE County in the City of LAUREL

Location: RICCIS EXPRESS
704 1ST AVE
LAUREL, MT 59044 YELLOWSTONE

Contact: Vince Ricci, (406) 628-7221

Sys Fac ID: 60-15061
Last Inspected On: 7/6/2016
Operating Permit Renewal Date: 11/2/2019

Owners/Operators: Ricci of Laurel Inc, Owner/Operator (406)-628-7221 VINCE RICCI
704 1ST AVE
LAUREL MT 59044-2100

Vince Ricci, UST Class A Operator
Wes Salveson, UST Class A Operator
Sandi Frank, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	09	3/28/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5105			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
6,000		5/7/2014	TLS-350/Gilbarco EMC , Veeder Root		
2	09	3/28/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5106			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
6,000		5/11/2014	TLS-350/Gilbarco EMC , Veeder Root		
3	09	3/28/2007	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5107			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
12,000		5/13/2014	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in YELLOWSTONE County in the City of WORDEN

Location: VALLEY FARMERS SUPPLY
1545 HIGHWAY 312
WORDEN, MT 59088 YELLOWSTONE
Contact: Ronald Broker, (406) 967-3100

Sys Fac ID: 56-02326
Last Inspected On: 12/2/2014
Operating Permit Renewal Date: 2/27/2018

Owners/Operators: Farmers Union Oil Co, Owner (406)-967-3100 PO BOX 309
WORDEN MT 59088-0309

Scott Black, UST Class A Operator
Kirk Marzolf, UST Class A Operator
Deborah Dvorak, UST Class B Operator
Scott Black, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	**AST**	**Sump Tightness**	**Secondary Option**	**Secondary Option**	**Spill Protected**
Status		**Inventory Control**	**Catastrophic L.D. Type 3.0**	**Piping Type**	**CP Met Types**
Product		**Tank/Pipe CP**	**Tank Detection**	**Primary Pipe Detection**	**Vapor Recovery**
Capacity		**Line Tightness**	**ATG Type**	**Secondary Pipe Detection**	**Energy Act**
1	25	11/1/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1006			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/16/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		6/6/2011	TLS-350/Gilbarco EMC , Veeder Root		
2	25	11/1/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1007			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/16/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000		6/6/2011	TLS-350/Gilbarco EMC , Veeder Root		
3	25	11/1/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1008			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/16/2011	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
3,000		6/6/2011	TLS-350/Gilbarco EMC , Veeder Root		