

# Farm, Residential, Heating Oil & Emergency Generator Tanks

Facility Name:	Facility ID#:
----------------	---------------

**ANNUAL 36-HOUR TANK GAUGING** is used for farm, residential, heating oil, and emergency generator USTs of 1,100 gallons and less capacity installed before April 27, 1995.

	<u>UST Information:</u> If a question does not apply, leave it blank.	Tag #	Tag #	Tag #	Tag #	Tag #
1	Is the UST 1,100 gallons or less capacity?					
2	Was the UST system installed before April 27, 1995? If the tank was installed on or after April 27, 1995, then this method is <b>NOT</b> valid and you must utilize a department approved monthly tank leak detection method (choose from other forms).					
3	Is the UST located at a farm or residential property and used for storing motor fuel for non-commercial purposes, or used for storing heating oil for consumptive use on the premises, or used as an emergency generator tank?					
4	Are passing monitoring records available for the current year? The minimum requirement is a written record of the results of an annual 36-hour gauge stick test.					
5	Do records show that liquid level measurements are taken at the beginning and ending of a 36 hour rest period hours (or longer duration) during which no liquid is added to or removed from tank?					
6	Are liquid level measurements based on an average of two consecutive stick readings, at both the beginning and the end of the test period?					
7	Can the gauge stick measure the level of product over the full range of the tank to the nearest 1/8 <sup>th</sup> of an inch? (Stick must be legible and not worn-down or damaged at the end)					

**Comments:**

(Inspector Initial)	(Date)	(Owner/Operator Initial)	(Date)