

17.38.219 SPECIAL SAMPLES (1) Under special conditions, additional samples may be required by the department. Such samples may be to determine adequacy of disinfection following line installation, replacement, or repair. Samples may also be required for determination of adequacy of source, storage, treatment or distribution of water to the public. The department may use these samples to determine compliance with MCLs, action levels, and treatment technique requirements, as set forth in this subchapter. (History: 75-6-103, MCA; IMP, 75-6-103, MCA; NEW, 1977 MAR p. 1187, Eff. 12/24/77; AMD, 1982 MAR p. 594, Eff. 3/26/82; AMD, 1991 MAR p. 1492, Eff. 8/16/91; AMD, 1994 MAR p. 2131, Eff. 8/12/94; TRANS, from DHES, 1996 MAR p. 1499.)