

# MONTANA DEPARTMENT OF ENVIRONMENTAL QUALITY

## AUTHORIZATION TO DISCHARGE UNDER THE MONTANA GROUND WATER POLLUTION CONTROL SYSTEM

In compliance with the Montana Water Quality Act, Title 75, Chapter 5, Montana Code Annotated (MCA) and the Administrative Rules of Montana (ARM) 17.30.Subchapter 5, Subchapter 7, and Subchapter 10, *et seq.*

### **Turah Meadows County Sewer and Water District**


is authorized to discharge from the **Turah Meadows Subdivision** to its sub-surface disposal system, located in Section 35, Township 13 North, Range 18 West in Missoula County, to receiving waters, **Class I ground water**,

in accordance with discharge point(s), effluent limitations, monitoring requirements and other conditions set forth herein. Authorization for discharge is limited to the outfall(s) specifically listed in the permit. The numeric effluent limits, water quality standards, and nondegradation-nonsignificance criteria specified herein support and serve to define the standard ground water mixing zone for affected receiving water.

This permit shall become effective: **March 1, 2012.**

This permit and the authorization to discharge shall expire at midnight, **February 28, 2017.**

FOR THE MONTANA DEPARTMENT OF  
ENVIRONMENTAL QUALITY



Jenny Chambers, Bureau Chief  
Water Protection Bureau  
Permitting & Compliance Division

Issue Date: January 6, 2012

## TABLE OF CONTENTS

Cover Sheet—Issuance and Expiration Dates

<b>I.</b>	<b>EFFLUENT LIMITATION AND MONITORING REQUIREMENT</b> .....	<b>3</b>
A.	Description of the Discharge Point.....	3
B.	Effluent Limitations.....	3
C.	Monitoring and Reporting Requirements .....	4
D.	Special Conditions - Ground Water Monitoring and Reporting.....	7
E.	Special Conditions - Other.....	7
<b>II.</b>	<b>MONITORING, RECORDING AND REPORTING REQUIREMENTS</b> .....	<b>8</b>
A.	Representative Sampling.....	8
B.	Monitoring Procedures.....	8
C.	Penalties for Tampering .....	8
D.	Reporting of Monitoring Results.....	8
E.	Compliance Schedules.....	9
F.	Additional Monitoring by the Permittee.....	9
G.	Records Contents.....	9
H.	Retention of Records .....	9
I.	Twenty-four Hour Notice of Noncompliance Reporting.....	9
J.	Other Noncompliance Reporting.....	10
K.	Inspection and Entry.....	10
<b>III.</b>	<b>COMPLIANCE RESPONSIBILITIES</b> .....	<b>12</b>
A.	Duty to Comply .....	12
B.	Penalties for Violations of Permit Conditions .....	12
C.	Need to Halt or Reduce Activity not a Defense.....	12
D.	Duty to Mitigate .....	12
E.	Proper Operation and Maintenance .....	12
F.	Removed Substances .....	13
G.	Bypass of Treatment Facilities .....	13
H.	Upset Conditions .....	13
<b>IV.</b>	<b>GENERAL REQUIREMENTS</b> .....	<b>15</b>
A.	Planned Changes .....	15
B.	Anticipated Noncompliance .....	15
C.	Permit Actions.....	15
D.	Duty to Reapply.....	15
E.	Duty to Provide Information .....	15
F.	Other Information.....	15
G.	Signatory Requirements .....	16
H.	Penalties for Falsification of Reports .....	17
I.	Availability of Reports .....	17
J.	Oil and Hazardous Substance Liability .....	17
K.	Property or Water Rights.....	17
L.	Severability.....	17
M.	Transfers.....	17
N.	Fees .....	18
O.	Reopener Provisions.....	18
P.	Biosolids.....	19
<b>V.</b>	<b>DEFINITIONS</b> .....	<b>20</b>

## I. EFFLUENT LIMITATION AND MONITORING REQUIREMENT

### A. Description of the Discharge Point

The authorization to discharge provided under this permit is limited to the outfalls that are specifically designated below as the discharge locations. Discharges at any location not authorized under an MGWPCS permit is a violation of the Montana Water Quality Act and could subject the person(s) responsible for such discharge to penalties under the Act. Knowingly discharging from an unauthorized location or failing to report an unauthorized discharge within a reasonable time from first learning of an unauthorized discharge could subject such person to criminal penalties as provided under Section 75-5-632 of the Montana Water Quality Act.

<u>Outfall</u>	<u>Description of Discharge Point</u>
001	The discharge is from a Level 2 wastewater treatment system to a subsurface drainfield discharging residential domestic strength wastewater at a maximum daily design capacity flow rate of 21,000 gallons per day (gpd). The wastewater gravity feeds from community septic tanks (in series) to a recirculating sand filter (RSF) treatment system that pressure-doses the effluent to a subsurface drainfield. The location of the discharge is 46° 50' 04'' North latitude and -113° 49' 57'' West longitude. The Department has granted a standard 500-foot ground water mixing zone for nitrate (as N), extending from the source 500 feet in a N40°W direction.

### B. Effluent Limitations

#### 1. Interim Effluent Limits

Upon the effective date of the permit (March 1, 2012) and lasting for two years (February 28, 2014) after the effective date; the quality of effluent discharged shall, as a minimum, meet the interim effluent limitations set forth in Table 1.

**Table 1. Interim Effluent Limits for Outfall 001**

<b>Parameter</b>	<b>Daily Maximum<sup>(1)</sup> Concentration (mg/L)</b>	<b>Annual Maximum Load (lbs/year)</b>
Total Nitrogen (as N)	26	NA
Total Phosphorous	NA	693.5

- (1) Report highest measure daily value for quarterly reporting period on Discharge Monitoring Report (DMR) form.  
NA = Not Applicable

## 2. Final Effluent Limits

Upon two (2) years after the effective date of the permit (March 1, 2014) and lasting until the term of the permit; the quality of effluent discharged shall, as a minimum, meet the final effluent limitations set forth in Table 2.

**Table 2. Final Effluent Limits for Outfall 001**

<b>Parameter</b>	<b>Daily Maximum<sup>(1)</sup> Concentration(mg/L)</b>	<b>Annual Maximum Load (lbs/year)</b>
Total Nitrogen (as N)	24	NA
Total Phosphorous	NA	693.5

- (1) Report highest measure daily value for quarterly reporting period on Discharge Monitoring Report (DMR) form.  
NA = Not Applicable

## 3. Additional Discharge Limitations:

The facility shall not discharge any hazardous substances as defined by 40 CFR, Part 116.4, or carcinogens as defined by Circular DEQ-7, at any time during the operation of the system.

The introduction of industrial & other wastes is prohibited.

## C. Monitoring and Reporting Requirements

1. Wastewater shall be monitored at the frequency and with the type of measurement indicated in Table 3. Samples representative of effluent quality will be collected from the last point of control (dose tank) located just prior to the drainfield. The required sampling frequency is individually listed in Table 3 for each respective parameter. The required sample type is listed in Table 3 for each respective parameter. Samples or

measurements shall be representative of the volume and nature of the monitored discharge.

2. The permittee shall report the monitoring data to the Department at the frequency respectively listed in Table 3 for each parameter (quarterly or yearly). Discharge Monitoring Report Forms (DMRs) will be required, regardless of the operational status of the facility. If no discharge occurs during the entire monitoring period, it shall be stated on the DMR's that no discharge or overflow occurred.

**Table 3. Effluent Monitoring and Reporting Requirements – Outfall 001**

Parameter	Units	Sample Type	Minimum Sample Freq	Reporting Requirements	Reporting Freq
Effluent Flow Rate	gpd	Continuous	Continuous	Daily Maximum <sup>(1)</sup> and Quarterly Avg	Quarterly
Total Ammonia, as N	mg/L	Grab	1/month	Daily Maximum <sup>(1)</sup> and Quarterly Avg	Quarterly
Total Nitrogen, as N <sup>(2)</sup> (TN)	mg/L	Grab	1/month	Daily Maximum <sup>(1)</sup> and Quarterly Avg	Quarterly
	lbs/day	Calculate	1/month	Daily Maximum <sup>(1)</sup> and Quarterly Avg	Quarterly
Total Kjeldahl Nitrogen (TKN)	mg/L	Grab	1/month	Daily Maximum <sup>(1)</sup> and Quarterly Avg	Quarterly
Nitrate+Nitrite (as N)	mg/L	Grab	1/month	Daily Maximum <sup>(1)</sup> and Quarterly Avg	Quarterly
Total Phosphorus (as P)	mg/L	Grab	1/month	Quarterly Avg	Quarterly
	lbs/day	Calculate	1/month	Quarterly Avg	
	lbs/year	Calculate <sup>(3)</sup>	1/year	Annual Maximum <sup>(4)</sup>	Yearly
Chloride	mg/L	Grab	1/month	Quarterly Avg	Quarterly
Biochemical Oxygen Demand (BOD <sub>5</sub> )	mg/L	Grab	1/month	Quarterly Avg	Quarterly
Total Suspended Solids (TSS)	mg/L	Grab	1/month	Quarterly Avg	Quarterly

(1) Report highest measure daily value for quarterly reporting period on Discharge Monitoring Report (DMR) form.

(2) Calculate TN:  $TN (mg/L) = \text{nitrate} + \text{nitrite, as N} (mg/L), \text{ plus total Kjeldahl nitrogen} (mg/L)$ .

(3) Calculate Annual Total Load:  $\text{lbs/year} = \text{sum of all monthly loads (lbs/day) for the calendar year}$ .

(4) Annual maximum load shall be reported on an annual basis (due January 28 each year of the permit cycle).

3. The load calculations shall use the daily flow measured during the same 24 hour period that analytical samples are collected. The load (lb/d) shall be calculated using the following equation:  
$$\text{Load (lb/d)} = \text{concentration (mg/L)} \times \text{flow (gpd)} \times (8.34 \times 10^{-6}).$$
4. The annual load (lb/yr) to be reported is the sum of the loads calculated during all required sampling periods occurring within a calendar year. If more than one sample is collected during an individual sampling period, the average value of the samples shall be used to calculate the load for that sampling period.
5. Total Nitrogen (mg/L) sums the  $\text{NO}_3 + \text{NO}_2$  (mg/L), Ammonia (mg/L), and organic nitrogen concentrations.
6. Analytical methods must be 40 CFR 136 approved methods unless otherwise approved by the Department. Analysis must meet the Required Reporting Values listed in Circular DEQ-7. Practical Quantification Limits are not acceptable substitutions for Required Reporting Values.

D. Special Conditions – Ground Water Monitoring and Reporting

1. As a minimum, all monitoring wells shall be monitored at the frequency and with the type of measurement listed in Table 4. Each sample shall include, but not be limited to, the respective parameters listed in Table 4 for each associated monitoring well.
2. The permittee will report a 90-day average for all parameters listed in Table 4.
3. The permittee shall report ground water monitoring data to the Department at a quarterly frequency. Submittal of DMR forms will be required, regardless of the status of each individual monitoring well. If the monitoring well(s) is not installed (or not yet established based on Department approval) for an individual monitoring period, the following shall be stated upon each applicable DMR: *Monitoring well has not been installed*. At no time shall the permittee mark: *No Discharge* on the monitoring well DMRs.
4. Monitoring well sampling shall be conducted in accordance with the Department's "Historical Nonpoint Source Water Quality Standard Operating Procedures", Section 11.10 "Groundwater Data Collection" <http://deq.mt.gov/wqinfo/monitoring/SOP/sop.mcp.x>. The permittee shall document the methodology and equipment used to sample monitoring wells during all sampling events. Self monitoring records shall be

maintained in accordance with Part II.H. of this permit.

**Table 4. Ground Water Monitoring and Reporting Requirements**

Parameter, units	Location	Minimum Sample Frequency	Sample Type
Static Water Level (SWL), feet below top of casing	MW-1A	1/Quarter	Instantaneous
	MW-2A	1/Six Months	
Specific Conductivity, $\mu\text{S}/\text{cm}$ @ 25°C	MW-1A	1/Quarter	Grab
	MW-2A	1/Six Months	
Nitrate + Nitrite (as N), mg/L	MW-1A	1/Quarter	Grab
	MW-2A	1/Six Months	
Total Kjeldahl Nitrogen (TKN), mg/L	MW-1A	1/Quarter	Grab
	MW-2A	1/Six Months	
Chloride, mg/L	MW-1A	1/Quarter	Grab
	MW-2A	1/Six Months	
<i>Escherichia Coli</i> , <1 CFU/100mL	MW-1A	1/Quarter	Grab
	MW-2A	1/Six Months	

**E. Special Conditions – Other**

1. A plan which addresses installation (or establishment) of the ground water monitoring well (MW-2A) must be completed on or before August 28, 2012. The plan is to include the location, design and construction details for the proposed ground water monitoring well. A written report must be received by the Department, for approval, due on or before the 28<sup>th</sup> day of the month (September 28, 2012) following the completion date. Monitoring well installation (or establishment) cannot commence until confirmation is received from the Department that the plan was approved.
2. A minimum of one (1) monitoring well (MW-2A) shall be installed (or established) on or before February 28, 2015. The monitoring well shall be constructed (or appointed) in conformance with the Department approved installation plan of Part I.E.1. of this permit. The monitoring well will be located upgradient (via ground water flow direction) and shall serve as a background ground water quality monitoring point.

The monitoring well shall be installed upon property owned by the permittee, or property that the permittee has an easement which provides for long term accessibility.

A written report documenting monitoring well installation (or establishment) must be received by the Department, due on or before

March 28, 2015 which documents the results of the monitoring well installation (or establishment). For the newly installed (or established) monitoring well, the report must include the final location of the monitoring well, drilling methods used, borehole lithologic log, and well construction details.

Ground water quality monitoring will begin upon installation (or establishment) of the monitoring well and continue through the duration of the permit. The permittee will report all sampling analytical data within DMR reports.

3. On or before March 01, 2014, the wastewater discharge must be capable of meeting the final effluent limits listed within Table 2.

**Table 5: Compliance Schedule**

<b>Action</b>	<b>Scheduled Completion Date<sup>(1)</sup></b>	<b>Scheduled Report Due Date<sup>(2)</sup></b>
Comply with interim effluent limits	Effective Date	Quarterly DMR
Comply with the final effluent permit limits	March 01, 2014	Quarterly DMR
Complete a plan for installation/establishment of monitoring wells.	August 28, 2012	September 28, 2012
Install/establish monitoring wells.	February 28, 2015	March 28, 2015

(1) The actions must be completed on or before the scheduled completion dates.

(2) Reports must be received by the Department on or before the scheduled report due dates.

## II. MONITORING, RECORDING AND REPORTING REQUIREMENTS

### A. Representative Sampling

Effluent samples taken in compliance with the monitoring requirements established under Part I shall be collected from the dose tank prior to entering the subsurface drainfield. Samples shall be representative of the volume and nature of the monitored medium.

### B. Monitoring Procedures

Monitoring must be conducted according to test procedures approved under Part 136, Title 40 of the Code of Federal Regulations, unless other test procedures have been specified in this permit. All flow-measuring and flow-recording devices used in obtaining data submitted in self-monitoring reports must indicate values within 10 percent of the actual flow being measured. Flow meter calibration must be done on a yearly basis and documented for the record.

### C. Penalties for Tampering

The Montana Water Quality Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate, any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$25,000, or by imprisonment for not more than six months, or by both.

### D. Reporting of Monitoring Results

Self-monitoring reports shall be submitted to the Department quarterly. Monitoring results obtained during the previous reporting period shall be summarized and reported on a Discharge Monitoring Report Form (EPA No. 3320-1), postmarked no later than the 28th day of the month following the completed reporting period. Following the issuance of this permit, if no discharge occurs during the reporting period, "no discharge" shall be reported. Legible copies of these, and all other reports required herein, shall be signed and certified in accordance with the Signatory Requirements (Part IV, Section G) and submitted to the Department at the following address:

Montana Department of Environmental Quality  
Water Protection Bureau  
PO Box 200901  
Helena, Montana 59620  
Phone: (406) 444-3080

All reports, notifications and inquires regarding compliance with this permit shall be submitted to the Department at the above address.

E. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on interim and final requirements contained in any Compliance Schedule of this permit shall be submitted no later than 14 days following each schedule date.

F. Additional Monitoring by the Permittee

If the permittee monitors any pollutant more frequently than required by this permit, using approved analytical methods as specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the Discharge Monitoring Report. Such increased frequency shall also be indicated.

G. Records Contents

Records of monitoring information shall include:

1. The dates, exact place, and time of sampling or measurements;
2. The initials or name(s) of the individual(s) who performed the sampling or measurements;
3. The date(s) analyses were performed;
4. The time analyses were initiated;
5. The initials or name(s) of individual(s) who performed the analyses;
6. References and written procedures, when available, for the analytical techniques or methods used; and,
7. The results of such analyses, including the bench sheets, instrument readouts, computer disks or tapes, etc., used to determine these results.

H. Retention of Records

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least three years from the date of the sample, measurement, report or application. This period may be extended by request of the Department at any time. Data collected on site, copies of monitoring reports, and a copy of this MGWPCS permit must be maintained on site during the duration of activity at the permitted location.

I. Twenty-four Hour Notice of Noncompliance Reporting

The permittee shall report serious incidents of noncompliance as soon as possible, but no later than twenty-four (24) hours from the time the permittee first became aware of the circumstances. The report shall be made to the Water Protection Bureau at (406) 444-3080 or the Office of Disaster and Emergency Services at (406) 841-3911. The following examples are considered serious incidents:

1. Any noncompliance which may seriously endanger health or the environment;
2. Any unanticipated bypass which exceeds any effluent limitation in the permit (See Part III.G of this permit, "Bypass of Treatment Facilities");
3. Any upset which exceeds any effluent limitation in the permit (See Part III.H of this permit, "Upset Conditions").
4. A written submission shall also be provided within five days of the time that the permittee becomes aware of the circumstances. The written submission shall contain:
  - a. A description of the noncompliance and its cause;
  - b. The period of noncompliance, including exact dates and times;
  - c. The estimated time noncompliance is expected to continue if it has not been corrected; and,
  - d. Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
5. The Department may waive the written report on a case-by-case basis if the oral report has been received within 24 hours by the Water Protection Bureau, by phone, at (406) 444-3080.
6. Reports shall be submitted to the addresses in Part II.D of this permit, "Reporting of Monitoring Results".

J. Other Noncompliance Reporting

Instances of noncompliance not required to be reported within 24 hours shall be reported at the time that monitoring reports for Part II.D of this permit are submitted. The reports shall contain the information listed in Part II.I.4 of this permit.

K. Inspection and Entry

The permittee shall allow the head of the Department or the Director or an authorized representative thereof, upon the presentation of credentials and other documents as may be required by law, to:

1. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;

2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
3. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and,
4. Sample or monitor at reasonable times, for the purpose of assuring permits compliance, any substances or parameters at any location.

### III. COMPLIANCE RESPONSIBILITIES

#### A. Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. The permittee shall give the Department and the Director advance notice of any planned changes at the permitted facility or of an activity which may result in permit noncompliance.

#### B. Penalties for Violations of Permit Conditions

The Montana Water Quality Act provides that any person who violates a permit condition of the Act is subject to civil or criminal penalties not to exceed \$25,000 per day or one year in prison, or both, for the first conviction, and \$50,000 per day of violation or by imprisonment for not more than two years, or both, for subsequent convictions. MCA 75-5-611(a) also provides for administrative penalties not to exceed \$10,000 for each day of violation and up to a maximum not to exceed \$100,000 for any related series of violations. Except as provided in permit conditions on Part III.G of this permit, "Bypass of Treatment Facilities" and Part III.H of this permit, "Upset Conditions", nothing in this permit shall be construed to relieve the permittee of the civil or criminal penalties for noncompliance.

#### C. Need to Halt or Reduce Activity not a Defense

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

#### D. Duty to Mitigate

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit, which has a reasonable likelihood of adversely affecting human health or the environment.

#### E. Proper Operation and Maintenance

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems, which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit. However, the permittee shall operate, as a minimum, one complete set of each main line unit treatment process whether or not this process is needed to achieve permit effluent compliance.

F. Removed Substances

Collected screenings, grit, solids, sludges, or other pollutants removed in the course of treatment shall be disposed in such a manner so as to prevent any pollutant from entering any waters of the state or creating a health hazard. Sludge shall not be directly blended with or enter either the final plant discharge and/or waters of the United States. Any sludges removed from the facility shall be disposed of in accordance with 40 CFR 503, 258 or other applicable rule. EPA and MDEQ shall be notified at least 180 days prior to such disposal taking place.

G. Bypass of Treatment Facilities

1. Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Parts III.G.2 and III.G.3 of this permit.
2. Notice:
  - a. Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten (10) days before the date of the bypass.
  - b. Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required under Part II.I of this permit, "Twenty-four Hour Reporting".
3. Prohibition of Bypass.
  - a. Bypass is prohibited and the Department may take enforcement action against a permittee for a bypass, unless:
    - (1) The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
    - (2) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgement to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and,
    - (3) The permittee submitted notices as required under Part III.G.2 of this

permit.

- b. The Department may approve an anticipated bypass, after considering its adverse effects, if the Department determines that it will meet the three conditions listed above in Part III.G.3.a of this permit.

H. Upset Conditions

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with technology based permit effluent limitations if the requirements of Part III.H.2 of this permit are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review (i.e., Permittees will have the opportunity for a judicial determination on any claim of upset only in an enforcement action brought for noncompliance with technology-based permit effluent limitations).
2. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - a. An upset occurred and that the permittee can identify the cause(s) of the upset;
  - b. The permitted facility was at the time being properly operated;
  - c. The permittee submitted notice of the upset as required under Part II.I of this permit, "Twenty-four Hour Notice of Noncompliance Reporting"; and,
  - d. The permittee complied with any remedial measures required under Part III.D of this permit, "Duty to Mitigate".
3. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

#### IV. GENERAL REQUIREMENTS

A. Planned Changes

The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:

1. The alteration or addition could significantly change the nature or increase the quantity of pollutant discharged. This notification applies to pollutants which are not subject to effluent limitations in the permit; or,
2. There are any planned substantial changes to the existing sewage sludge management practices of storage and disposal. The permittee shall give the Department notice of any planned changes at least 180 days prior to their implementation.

B. Anticipated Noncompliance

The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity, which may result in noncompliance with permit requirements.

C. Permit Actions

This permit may be revoked, modified and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

D. Duty to Reapply

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. The application must be submitted at least 180 days before the expiration date of this permit.

E. Duty to Provide Information

The permittee shall furnish to the Department, within a reasonable time, any information which the Department may request to determine whether cause exists for revoking, modifying and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Department, upon request, copies of records required to be kept by this permit.

F. Other Information

When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or any report to the Department, it shall promptly submit such facts or information with a narrative explanation

of the circumstances of the omission or incorrect submittal and why they weren't supplied

earlier.

G. Signatory Requirements

All applications, reports or information submitted to the Department shall be signed and certified.

1. All permit applications shall be signed by either a principal executive officer or ranking elected official.
2. All reports required by the permit and other information requested by the Department shall be signed by a person described above or by a duly authorized representative of that person. A person is considered a duly authorized representative only if:
  - a. The authorization is made in writing by a person described above and submitted to the Department; and,
  - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.)
3. Changes to authorization. If an authorization under Part IV.G.2 of this permit is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Part IV.G.2 of this permit must be submitted to the Department prior to or together with any reports, information, or applications to be signed by an authorized representative.
4. Certification. Any person signing a document under this section shall make the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

H. Penalties for Falsification of Reports

The Montana Water Quality Act provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction be punished by a fine of not more than \$25,000 per violation, or by imprisonment for not more than six months per violation, or by both.

I. Availability of Reports

Except for data determined to be confidential under 40 CFR Part 2, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Department. As required by the Clean Water Act, permit applications, permits and effluent data shall not be considered confidential.

J. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject under Section 311 of the Clean Water Act.

K. Property or Water Rights

The issuance of this permit does not convey any property or water rights of any sort, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.

L. Severability

The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

M. Transfers

This permit may be transferred to a new permittee if:

1. The current permittee notifies the Department at least 30 days in advance of the proposed transfer date;
2. The notice includes a written agreement between the existing and new permittees containing a specific date for transfer of permit responsibility, coverage, and liability between them;
3. The Department does not notify the existing permittee and the proposed new

permittee of intent to revoke or modify and reissue the permit. If this notice is not received, the transfer is effective on the date specified in the agreement mentioned in Part IV.M.2 of this permit; and

4. Required annual, application, and transfer fees have been paid.

N. Fees

The permittee is required to submit payment of an annual fee as set forth in ARM 17.30.201. If the permittee fails to pay the annual fee within 90 days after the due date for the payment, the Department may:

1. Impose an additional assessment consisting of 15% of the fee plus interest on the required fee computed at the rate established under 15-1-216(3), MCA, or
2. Suspend the processing of the application for a permit or authorization or, if the nonpayment involves an annual permit fee, suspend the permit, certificate or authorization for which the fee is required. The Department may lift suspension at any time up to one year after the suspension occurs if the holder has paid all outstanding fees, including all penalties, assessments and interest imposed under this sub-section. Suspensions are limited to one year, after which the permit will be terminated.

O. Reopener Provisions

This permit may be reopened and modified (following proper administrative procedures) to include the appropriate effluent limitations (and compliance schedule, if necessary), or other appropriate requirements if one or more of the following events occurs:

1. Water Quality Standards: The water quality standards of the receiving water(s) to which the permittee discharges are modified in such a manner as to require different effluent limits than contained in this permit.
2. Water Quality Standards are Exceeded: If it is found that water quality standards in the receiving waters, excluding mixing zones as designated by ARM 17.30.501-17.30-518, are exceeded for parameters included in the permit, the department may modify the effluent limits or water management plan.
3. TMDL or Wasteload Allocation: TMDL requirements or a wasteload allocation is developed and approved by the Department and/or EPA for incorporation in this permit.
4. Water Quality Management Plan: A revision to the current water quality management plan is approved and adopted which calls for different effluent limitations than contained in this permit.

5. Toxic Pollutants: A toxic standard or prohibition is established under Section 307(a) of the Clean Water Act for a toxic pollutant which is present in the discharge and such standard or prohibition is more stringent than any limitation for such pollutant in this permit.

P. Biosolids

Sewage sludge (which is not landfilled in accordance with solid waste regulation at 40 CFR Part 258) must meet all applicable requirements for disposing of sludge through land application or surface disposal site at 40 CFR Part 503. The regulations are administered by the U.S. Environmental Protection Agency.

Implement other measures as determined by the Department, which may include invoking the permit condition set forth in Part IV. O., "Reopener Provisions".

## V. DEFINITIONS

1. **“30-day (and monthly) average,”** other than for fecal coliform bacteria, means the arithmetic average of all samples collected during a consecutive 30-day period or calendar month, whichever is applicable. Geometric means shall be calculated for fecal coliform bacteria. The calendar month shall be used for purposes of reporting self-monitoring data.
2. **“90-day (and quarterly) average,”** other than for fecal coliform bacteria means the arithmetic average of all samples collected during a consecutive 90-day period or 3 calendar months, whichever is applicable. Geometric means shall be calculated for fecal coliform bacteria. The calendar quarter shall be used for purposes of reporting self-monitoring data.
3. **“90-day Average Load”** means the arithmetic mean of all 90-day or quarterly average loads reported during a calendar quarter for a monitored parameter.
4. **“BOD<sub>5</sub>”** means a measurement of the amount of oxygen utilized by the decomposition of organic material, over a five-day period of time in a wastewater sample; it is used as a measurement of the readily decomposable organic content of wastewater.
5. **“Bypass”** means the intentional diversion of waste streams from any portion of a treatment or storage facility.
6. **“Composite sample”** means a sample composed of two or more discrete samples and shall be flow proportioned. The aggregate samples will reflect the average water quality covering the compositing or sample period. The composite sample shall, as a minimum, contain at least four (4) samples collected over the compositing period. Unless otherwise specified, the time between the collection of the first sample and the last sampled shall not be less than six (6) hours nor more that 24 hours. Acceptable methods for preparation of composite samples are as follows:
  - a. Constant time interval between samples, sample volume proportional to flow rate at time of sampling;
  - b. Constant time interval between samples, sample volume proportional to total flow (volume) since last sample. For the first sample, the flow rate at the time the sample was collected my be used;
  - c. Constant sample volume, time interval between samples proportional to flow (i.e., sample taken every “X” gallons of flow); and ,
  - d. Continuous collections of sample, with sample collection rate proportional to flow rate.

7. **"Continuous"** means the measurement of effluent flow which occurs without interruption throughout the operating hours of the facility, except for infrequent shutdowns for maintenance process changes, or other similar activities.
8. **"Daily Maximum Limit"** means the maximum allowable discharge of a pollutant during a calendar day. Expressed as units of mass, the daily discharge is cumulative mass discharged over the course of the day. Expressed as a concentration, it is the arithmetic average of all measurements taken that day.
9. **"Department"** means the Montana Department of Environmental Quality.
10. **"Grab"** sample, for monitoring requirements, means a single "dip and take" sample collected at a representative point in the discharge stream or monitoring well.
11. **"Instantaneous"** measurement, for monitoring requirements, means a single reading, observation, or measurement.
12. **"Load limits"** means mass-based discharge limits expressed in units such as lb/day
13. **"Mixing zone"** means a limited area of a surface water body or aquifer where initial dilution of a discharge takes place and where water quality changes may occur. Also recognized as an area where certain water quality standards may be exceeded.
14. **"Nondegradation"** means the prevention of a significant change in water quality that lowers the quality of high-quality water for one or more parameters. Also, the prohibition of any increase in discharge that exceeds the limits established under or determined from a permit or approval issued by the Department prior to April 29, 1993.
15. **"Semi-Annual Average"** means the arithmetic average of all samples collected during a consecutive 180-day period or 6 calendar months, whichever is applicable.
16. **"Severe property damage"** means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
17. **"TMDL"** means the total maximum daily load of a parameter, representing the estimated assimilative capacity for a water body before other designated uses are adversely affected. Mathematically, it is the sum of waste load allocations for

point sources, load allocations for non-point and natural background sources, and a margin of safety.

18. "TSS" means total suspended solids, which is a measure of the filterable solids present in a sample, as determined by the method specified in 40 CFR part 136.