

Major Mechanical  
POTW w/ Pretreatment  
Permit No. MT0021920

## MONTANA DEPARTMENT OF ENVIRONMENTAL QUALITY

### AUTHORIZATION TO DISCHARGE UNDER THE MONTANA POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with Montana Water Quality Act, Title 75, Chapter 5, Montana Code Annotated (MCA) and the Federal Water Pollution Control Act (the "Clean Water Act"), 33 U.S.C. § 1251 *et seq.*,

#### **City of Great Falls**

is authorized to discharge from its **domestic wastewater treatment plant**

located at **1600 6<sup>th</sup> Street NE, Great Falls, Montana**

to receiving waters named the **Missouri River**

in accordance with discharge point(s), effluent limitations, monitoring requirements and other conditions set forth herein. Authorization for discharge is limited to those outfalls specifically listed in the permit.

This permit shall become effective: **December 1, 2010.**

This permit and the authorization to discharge shall expire at midnight, **November 30, 2015.**

FOR THE MONTANA DEPARTMENT OF  
ENVIRONMENTAL QUALITY



Paul Skubinna, Chief  
Water Protection Bureau  
Permitting & Compliance Division

Modification Date: April 11, 2013

## TABLE OF CONTENTS

Cover Sheet--Issuance and Expiration Dates

<b>I.</b>	<b>EFFLUENT LIMITATIONS, MONITORING REQUIREMENTS &amp; OTHER CONDITIONS.....</b>	<b>3</b>
A.	DESCRIPTION OF DISCHARGE POINTS AND MIXING ZONE .....	3
B.	EFFLUENT LIMITATIONS .....	4
C.	MONITORING REQUIREMENTS .....	7
D.	SPECIAL CONDITIONS .....	13
E.	PRETREATMENT REQUIREMENTS: .....	14
<b>II.</b>	<b>MONITORING, RECORDING AND REPORTING REQUIREMENTS.....</b>	<b>22</b>
A.	REPRESENTATIVE SAMPLING.....	22
B.	MONITORING PROCEDURES .....	22
C.	PENALTIES FOR TAMPERING.....	22
D.	REPORTING OF MONITORING RESULTS.....	22
E.	COMPLIANCE SCHEDULES .....	23
F.	ADDITIONAL MONITORING BY THE PERMITTEE.....	23
G.	RECORDS CONTENTS .....	23
H.	RETENTION OF RECORDS.....	23
I.	TWENTY-FOUR HOUR NOTICE OF NONCOMPLIANCE REPORTING .....	24
J.	OTHER NONCOMPLIANCE REPORTING.....	24
K.	INSPECTION AND ENTRY.....	25
<b>III.</b>	<b>COMPLIANCE RESPONSIBILITIES.....</b>	<b>26</b>
A.	DUTY TO COMPLY .....	26
B.	PENALTIES FOR VIOLATIONS OF PERMIT CONDITIONS.....	26
C.	NEED TO HALT OR REDUCE ACTIVITY NOT A DEFENSE.....	26
D.	DUTY TO MITIGATE.....	26
E.	PROPER OPERATION AND MAINTENANCE.....	26
F.	REMOVED SUBSTANCES .....	27
G.	BYPASS OF TREATMENT FACILITIES .....	27
H.	UPSET CONDITIONS .....	28
<b>IV.</b>	<b>GENERAL REQUIREMENTS .....</b>	<b>29</b>
A.	PLANNED CHANGES .....	29
B.	ANTICIPATED NONCOMPLIANCE .....	29
C.	PERMIT ACTIONS.....	29
D.	DUTY TO REAPPLY .....	29
E.	DUTY TO PROVIDE INFORMATION .....	29
F.	OTHER INFORMATION .....	29
G.	SIGNATORY REQUIREMENTS .....	30
H.	PENALTIES FOR FALSIFICATION OF REPORTS.....	31
I.	AVAILABILITY OF REPORTS.....	31
J.	OIL AND HAZARDOUS SUBSTANCE LIABILITY.....	31
K.	PROPERTY OR WATER RIGHTS .....	31
L.	SEVERABILITY.....	31
M.	TRANSFERS .....	31
N.	FEES .....	32
O.	REOPENER PROVISIONS .....	32
<b>V.</b>	<b>DEFINITIONS .....</b>	<b>34</b>

I. EFFLUENT LIMITATIONS, MONITORING REQUIREMENTS & OTHER CONDITIONS

A. Description of Discharge Points and Mixing Zone

The authorization to discharge provided under this permit is limited to those outfalls specially designated below as discharge locations. Discharges at any location not authorized under an MPDES permit is a violation of the Montana Water Quality Act (Act) and could subject the person(s) responsible for such discharge to penalties under the Act. Knowingly discharging from an unauthorized location or failing to report an unauthorized discharge within a reasonable time from first learning of an unauthorized discharge could subject such person to criminal penalties as provided under Section 75-5-632 of the Montana Water Quality Act.

Outfall

Description

003

**Location:** At the end of the pipe, discharging into the Missouri River, located at 47° 31' 13" N latitude, 111° 17' 49" W longitude.

**Mixing Zone:** The maximum extent of the chronic mixing zone in the Missouri River is 4,800 feet downstream for the following parameters: total residual chlorine; total ammonia, as nitrogen; nitrate + nitrite; and total recoverable metals (arsenic, copper, selenium, and thallium).

The maximum extent of the acute mixing zone in Missouri River is 80 feet downstream and 200 feet wide for the following parameters: total residual chlorine (TRC); total ammonia, as nitrogen; nitrate + nitrite; and total recoverable copper.

**Treatment Works:** Major, activated sludge mechanical treatment plant with anaerobic sludge digestion, and an Industrial Pretreatment Program. Currently disinfection is through chlorination; however, the planned upgrade will replace this with ultraviolet (UV) disinfection.

B. Effluent Limitations

Outfall 003

Interim Limitations

Effective immediately and lasting through midnight, November 30, 2014, the quality of effluent discharged by the facility shall, as a minimum, meet the limitations as set forth below.

Parameter	Units	Average Monthly Limitation <sup>(1)</sup>	Average Weekly Limitation <sup>(1)</sup>	Maximum Daily Limitation <sup>(1)</sup>
5-Day Carbonaceous Biochemical Oxygen Demand (CBOD <sub>5</sub> )	mg/L	25	40	--
	lb/day	4,377	7,005	--
Total Suspended Solids (TSS)	mg/L	30	45	--
	lb/day	4,500	7,881	--
<i>Escherichia coli</i> ( <i>E. coli</i> ) Bacteria <sup>(2)</sup>	cfu/100 mL	11,590	23,180	--
Oil and Grease (O&G) <sup>(3)</sup>	mg/L	--	--	<10
Total Residual Chlorine (TRC) <sup>(3)</sup>	mg/L	--	--	0.50

Footnotes: NA means not applicable.

(1) See Definition section at end of permit for explanation of terms.

(2) Report geometric mean if more than one sample is collected during the reporting period.

(3) Instantaneous Maximum Value.

pH: Effluent pH from Outfall 003 shall remain between 6.0 and 9.0 standard units (instantaneous minimum and instantaneous maximum). For compliance purposes, any single analysis or measurement beyond this limitation shall be considered a violation of the conditions of this permit.

85 Percent (%) Removal Requirement for 5-Day Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>) The arithmetic mean of the cBOD<sub>5</sub> for effluent samples collected in a period of 30 consecutive days shall not exceed 15% of the arithmetic mean of the values for influent samples collected at approximately the same times during the same period (85% removal). This is in addition to the concentration limitations on CBOD<sub>5</sub>.

85 Percent (%) Removal Requirement for Total Suspended Solids (TSS): The arithmetic mean of the TSS for effluent samples collected in a period of 30 consecutive days shall not exceed 15% of the arithmetic mean of the values for influent samples collected at approximately the same times during the same period (85% removal). This is in addition to the concentration limitations on TSS.

There shall be no discharge of floating solids or visible foam in other than trace amounts.

There shall be no discharge which causes visible oil sheen in the receiving stream.

Interim Limitations #2

Effective December 1, 2014, and lasting through midnight, October 31, 2015, the quality of effluent discharged by the facility shall, as a minimum, meet the limitations as set forth below.

Parameter	Units	Average Monthly Limitation <sup>(1)</sup>	Average Weekly Limitation <sup>(1)</sup>	Maximum Daily Limitation <sup>(1)</sup>
CBOD <sub>5</sub>	mg/L	25	40	--
	lb/day	4,377	7,005	--
TSS	mg/L	30	45	--
	lb/day	4,500	7,881	--
<i>E. coli</i> Bacteria, summer <sup>(2,3)</sup>	cfu/100 mL	126	252	--
<i>E. coli</i> Bacteria, winter <sup>(3,4)</sup>	cfu/100 mL	630	1,260	--
O&G <sup>(5)</sup>	mg/L	--	--	<10
TRC	mg/L	0.026	--	0.035
Total Ammonia as N	mg/L	2.86	--	4.50

Footnotes: NA means not applicable.  
(1) See Definition section at end of permit for explanation of terms.  
(2) Summer period is April 1 through October 31.  
(3) Report geometric mean if more than one sample is collected during the reporting period.  
(4) Winter period is November 1 through March 31.  
(5) Instantaneous maximum value.

pH: Effluent pH from Outfall 003 shall remain between 6.0 and 9.0 standard units (instantaneous minimum and instantaneous maximum). For compliance purposes, any single analysis or measurement beyond this limitation shall be considered a violation of the conditions of this permit.

85 Percent (%) Removal Requirement for CBOD<sub>5</sub>: The arithmetic mean of the CBOD<sub>5</sub> for effluent samples collected in a period of 30 consecutive days shall not exceed 15% of the arithmetic mean of the values for influent samples collected at approximately the same times during the same period (85% removal). This is in addition to the concentration limitations on CBOD<sub>5</sub>.

85 Percent (%) Removal Requirement for TSS: The arithmetic mean of the TSS for effluent samples collected in a period of 30 consecutive days shall not exceed 15% of the arithmetic mean of the values for influent samples collected at approximately the same times during the same period (85% removal). This is in addition to the concentration limitations on TSS.

There shall be no discharge of floating solids or visible foam in other than trace amounts.

There shall be no discharge which causes visible oil sheen in the receiving stream.

Final Limitations

Effective November 1, 2015, and lasting through the term of the permit, the quality of effluent discharged by the facility shall, as a minimum, meet the limitations as set forth below.

Parameter	Units	Average Monthly Limitation <sup>(1)</sup>	Average Weekly Limitation <sup>(1)</sup>	Maximum Daily Limitation <sup>(1)</sup>
CBOD <sub>5</sub>	mg/L	25	40	--
	lb/day	4,377	7,005	--
TSS	mg/L	30	45	--
	lb/day	4,500	7,881	--
<i>E. coli</i> Bacteria, summer <sup>(2,3)</sup>	cfu/100 mL	126	252	--
<i>E. coli</i> Bacteria, winter <sup>(3,4)</sup>	cfu/100 mL	630	1,260	--
O&G <sup>(5)</sup>	mg/L	--	--	<10
TRC	mg/L	0.026	--	0.035
Total Ammonia as N	mg/L	2.86	--	4.50
Arsenic, Total Recoverable	µg/L	13.7	--	16.0
Copper, Total Recoverable	µg/L	22.5	--	49.4
Footnotes: NA means not applicable.				
(1) See Definition section at end of permit for explanation of terms.				
(2) Summer period is April 1 through October 31.				
(3) Report geometric mean if more than one sample is collected during the reporting period.				
(4) Winter period is November 1 through March 31.				
(5) Instantaneous maximum value.				

pH: Effluent pH from Outfall 003 shall remain between 6.0 and 9.0 standard units (instantaneous minimum and instantaneous maximum). For compliance purposes, any single analysis or measurement beyond this limitation shall be considered a violation of the conditions of this permit.

85 Percent (%) Removal Requirement for CBOD<sub>5</sub>: The arithmetic mean of the CBOD<sub>5</sub> for effluent samples collected in a period of 30 consecutive days shall not exceed 15% of the arithmetic mean of the values for influent samples collected at approximately the same times during the same period (85% removal). This is in addition to the concentration limitations on CBOD<sub>5</sub>.

85 Percent (%) Removal Requirement for TSS: The arithmetic mean of the TSS for effluent samples collected in a period of 30 consecutive days shall not exceed 15% of the arithmetic mean of the values for influent samples collected at approximately the same times during the same period (85% removal). This is in addition to the concentration limitations on TSS.

There shall be no discharge of floating solids or visible foam in other than trace amounts.

There shall be no discharge which causes visible oil sheen in the receiving stream.

C. Monitoring Requirements

As a minimum, upon the effective date of this permit, the following constituents shall be monitored at the frequency and with the type of measurement indicated; samples or measurements shall be representative of the volume and nature of the monitored discharge. If no discharge occurs during the entire monitoring period, it shall be stated on the Discharge Monitoring Report (DMR) form (EPA No. 3320-1) that no discharge or overflow occurred.

The EPA-approved analytical methods in 40 CFR Part 136 requires Total Residual Chlorine (TRC) samples to be analyzed immediately. On-site analysis of TRC using an approved method is required. The method must achieve a minimum detection level of 0.10 mg/L. After December 1, 2014, the Permittee will be in compliance with the applicable effluent limitation if each measured TRC concentration is less than 0.10 mg/L.

The Required Reporting Value (RRV) is the detection level that must be achieved in reporting surface water monitoring or compliance data to DEQ. The RRV is the Department's best determination of a level of analysis that can be achieved by the majority of the commercial, university, or governmental laboratories using EPA-approved methods or methods approved by DEQ.

Self-monitoring of effluent discharged at Outfall 003 shall be conducted at the discharge structure downstream of all draw off or recycle return flows. Influent samples shall be collected at a point representative of the total influent upstream of any draw off or recycle return flows.

**Influent and Effluent Self-Monitoring Requirements**

Parameter	Unit	Sample Location	Sample Frequency	Sample Type <sup>(1)</sup>
Flow	mgd	Influent	Continuous <sup>(2)</sup>	Calculated
	mgd	Effluent	Continuous <sup>(2)</sup>	Calculated
5-Day Carbonaceous Biochemical Oxygen Demand (CBOD <sub>5</sub> )	mg/L	Influent	5/Week	Composite
	mg/L	Effluent	5/Week	Composite
	% Removal <sup>(3)</sup>	Effluent	1/Month	Calculated
	lb/day	Effluent	1/Month	Calculated
Total Suspended Solids (TSS)	mg/L	Influent	5/Week	Composite
	mg/L	Effluent	5/Week	Composite
	% Removal <sup>(3)</sup>	Effluent	1/Month	Calculated
	lb/day	Effluent	1/Month	Calculated
pH	s.u.	Effluent	1/Day	Instantaneous
Temperature	°C	Effluent	1/Day	Instantaneous
<i>E. coli</i> Bacteria	cfu/100 mL	Effluent	5/Week	Grab
Total Residual Chlorine <sup>(4)</sup>	mg/L	Effluent	1/Day	Grab
Total Ammonia as N	mg/L	Effluent	1/Week	Composite
Nitrate + Nitrite as N	mg/L	Effluent	1/Month	Composite
Total Kjeldahl Nitrogen	mg/L	Effluent	1/Month	Composite
Total Nitrogen as N <sup>(5)</sup>	mg/L	Effluent	1/Month	Calculated
	lb/day	Effluent	1/Month	Calculated
Total Phosphorus as P	mg/L	Effluent	1/Month	Composite
	lb/day	Effluent	1/Month	Calculated
Dissolved Oxygen	mg/L	Effluent	1/Day	Grab
Oil & Grease <sup>(6)</sup>	mg/L	Effluent	1/Month	Grab
Total Dissolved Solids (TDS)	mg/L	Effluent	1/Quarter <sup>(7)</sup>	Grab
Whole Effluent Toxicity, Acute	% Effluent	Effluent	1/Quarter <sup>(7)</sup>	Composite

Footnotes:

- (1) See Definitions section at end of permit for explanation of terms.
- (2) Requires recording device or totalizer. The Permittee shall report daily maximum and daily average flow (in mgd) for the month as measured by the meter installed at the Secondary Diversion Structure and corrected for draw-off flows on the DMR until midnight November 30, 2015, or upon notification to DEQ that the new flow monitoring system is functioning (whichever comes first).
- (3) Percent (%) removal shall be calculated using the monthly average values.
- (4) The permittee is only required to sample for total residual chlorine if chlorine is used as a disinfectant in the treatment process. If chlorine is *not* used, write "NA" on the DMR for this parameter.
- (5) Calculated as the sum of Nitrate + Nitrite as N and Total Kjeldahl Nitrogen concentrations.
- (6) Use EPA Method 1664, Revision A: N-Hexane Extractable Material (HEM), or equivalent.
- (7) Quarterly samples shall be collected more than 60 days apart.

**Influent and Effluent Self-Monitoring Requirements**

Parameter	Unit	Sample Frequency	Sample Type <sup>(1)</sup>	RRV
Arsenic, Total Recoverable <sup>(2)</sup>	µg/L	1/Month	Composite	1
Copper, Total Recoverable <sup>(2)</sup>	µg/L	1/Month	Composite	2
Selenium, Total Recoverable <sup>(2)</sup>	µg/L	1/Quarter <sup>(4)</sup>	Composite	1
Thallium, Total Recoverable <sup>(2)</sup>	µg/L	1/Quarter <sup>(4)</sup>	Composite	0.2
Bis(2-ethylhexyl)phthalate <sup>(3)</sup>	µg/L	1/Quarter <sup>(4)</sup>	Composite	2
Bromodichloromethane <sup>(3)</sup>	µg/L	1/Quarter <sup>(4)</sup>	Composite	0.6
Chloroform <sup>(3)</sup>	µg/L	1/Quarter <sup>(4)</sup>	Composite	0.9
1,2-Dichloroethane <sup>(3)</sup>	µg/L	1/Quarter <sup>(4)</sup>	Composite	0.5
Toluene <sup>(3)</sup>	µg/L	1/Quarter <sup>(4)</sup>	Composite	1

Footnotes:  
(1) See Definition section at end of permit for explanation of terms.  
(2) Both influent and effluent samples must be analyzed as required. Metals shall be analyzed as total recoverable; use EPA Method (Section) 4.1.4 [EPA 600/4-79-020, March 1983] or equivalent.  
(3) Both influent and effluent samples must be analyzed as required. 40 CFR 122, Appendix J, Table 2; use EPA Method 624 or equivalent.  
(4) Quarterly samples shall be collected more than 60 days apart.

Effective January 1, 2013, and lasting through the term of the permit, the required annual sample and the first semi-annual sample for the Industrial Pretreatment program (see below table) shall be collected in the second calendar quarter of the year (during the months of April, May, or June); the second semi-annual sample shall be collected in the fourth calendar quarter of the year (October, November, or December).

**Influent and Effluent Self-Monitoring Requirements in Support of the Industrial Pretreatment Program**

Parameter	Units	Sample Frequency	Sample Type <sup>(1)</sup>	ML
Aluminum, Dissolved <sup>(2)</sup>	µg/L	1/Quarter <sup>(3)</sup>	Composite	9
Antimony, Total Recoverable <sup>(2)</sup>	µg/L	1/Quarter <sup>(3)</sup>	Composite	3
Beryllium, Total Recoverable <sup>(2)</sup>	µg/L	1/Quarter <sup>(3)</sup>	Composite	1
Cadmium, Total Recoverable <sup>(2)</sup>	µg/L	1/Quarter <sup>(3)</sup>	Composite	0.08
Chromium, Total Recoverable <sup>(2)</sup>	µg/L	1/Quarter <sup>(3)</sup>	Composite	1
Lead, Total Recoverable <sup>(2)</sup>	µg/L	1/Quarter <sup>(3)</sup>	Composite	0.5
Mercury, Total Recoverable <sup>(2)</sup>	µg/L	1/Quarter <sup>(3)</sup>	Composite	0.01
Nickel, Total Recoverable <sup>(2)</sup>	µg/L	1/Quarter <sup>(3)</sup>	Composite	10
Silver, Total Recoverable <sup>(2)</sup>	µg/L	1/Quarter <sup>(3)</sup>	Composite	0.5
Zinc, Total Recoverable <sup>(2)</sup>	µg/L	1/Quarter <sup>(3)</sup>	Composite	10
Cyanide, Total	µg/L	1/Quarter <sup>(3)</sup>	Grab	5
Phenols, Total	µg/L	1/Quarter <sup>(3)</sup>	Grab	10
Volatile Organic Compounds <sup>(4)</sup>	µg/L	2/Year	Composite	<sup>(5)</sup>
Semi-Volatile, Acid Compounds <sup>(6)</sup>	µg/L	2/Year	Composite	<sup>(5)</sup>
Semi-Volatile, Base/Neutral <sup>(6)</sup>	µg/L	2/Year	Composite	<sup>(5)</sup>
Allyl chloride <sup>(7)</sup>	µg/L	1/Year <sup>(8)</sup>	Composite	<sup>(5)</sup>
Methacrylonitrile <sup>(7)</sup>	µg/L	1/Year <sup>(8)</sup>	Composite	<sup>(5)</sup>
Tetrahydrofuran <sup>(7)</sup>	µg/L	1/Year <sup>(8)</sup>	Composite	<sup>(5)</sup>

Footnotes:

- (1) See Definition section at end of permit for explanation of terms.
- (2) Both influent and effluent samples must be analyzed as required. Metals shall be analyzed as total recoverable; use EPA Method (Section) 4.1.4 [EPA 600/4-79-020, March 1983] or equivalent, with the exception of aluminum which is measured in the dissolved form. This information will not be entered on the DMR form; copies of the analytical laboratory reports must be attached to the DMR for the applicable reporting period.
- (3) Quarterly samples shall be collected more than 60 days apart.
- (4) Both influent and effluent samples must be analyzed as required. 40 CFR 122, Appendix J, Table 2; use EPA Method 624 or equivalent. This information will not be entered on the DMR form; copies of the analytical laboratory reports must be attached to the DMR for the applicable reporting period.
- (5) See approved method for minimum level (ML).
- (6) Both influent and effluent samples must be analyzed as required. 40 CFR 122, Appendix J, Table 2, use EPA Method 625 or equivalent. This information will not be entered on the DMR form; copies of the analytical laboratory reports must be attached to the DMR for the applicable reporting period.
- (7) Both influent and effluent samples must be analyzed as required. 40 CFR 122 Appendix D, Table V. This information will not be entered on the DMR form; copies of the analytical laboratory reports must be attached to the DMR for the applicable reporting period.
- (8) Annual samples must be collected more than 180 days apart, as described in the text, above.

## Reporting Requirements

### **Load Calculations**

In addition to reporting the concentration values, the monthly loads expressed in pounds per day (lb/day) must be calculated and reported for BOD<sub>5</sub>, TSS, total phosphorus as P, and total nitrogen. The weekly and monthly loads must be calculated using the average daily flow rate and daily average parameter concentration as shown in the following equations:

$$\text{Load (lb/day)} = \text{Parameter concentration (mg/L)} \times \text{Effluent Flow Rate (gpm)} \times (0.012)$$

or

$$\text{Parameter concentration (mg/L)} \times \text{Effluent Flow Rate (mgd)} \times (8.34)$$

### **Percent (%) Removal**

The percent removal shall be calculated using the following formula:

$$\% \text{ Removal} = \frac{[\text{Influent Concentration}] - [\text{Effluent Concentration}]}{[\text{Influent Concentration}]} \times 100$$

Where:

*Influent Concentration* = Corresponding 30-Day average influent concentration based on the analytical results of the reporting period.

*Effluent Concentration* = Corresponding 30-Day average effluent concentration based on the analytical results of the reporting period.

### **Reporting Total Residual Chlorine (TRC) Results**

On-site analysis of TRC using an approved method is required. The method must achieve a minimum detection level of 0.10 mg/L. The Permittee will be in compliance with the applicable effluent limitation if each measured TRC concentration value is less than 0.10 mg/L. When all measured TRC values are less than the analytical reporting level (0.10 mg/L), the Permittee shall report the analytical reporting level preceded by a less than symbol (<0.10 mg/L) on the DMR.

### **Whole Effluent Toxicity Testing – Acute Toxicity**

Starting in the first calendar quarter following the effective date of the permit, the Permittee shall, at least once each quarter, conduct an acute static replacement toxicity test on a composite sample of the effluent. Testing will employ two

species per quarter and will consist of 5 effluent concentrations (100, 50, 25, 12.5, 6.25 percent effluent) and a control. Dilution water and the control shall consist of the receiving water. Samples shall be collected on a two day progression; i.e., if the first quarterly sample is on a Monday, the second quarterly sample shall be collected on a Wednesday, etc. Saturdays, Sundays and Holidays will be skipped in the progression.

The static toxicity tests shall be conducted in general accordance with the procedures set out in the latest revision of *Methods for Measuring the Acute Toxicity of Effluent to Freshwater and Marine Organisms*, EPA-600/4-90/027 and the “*Region VIII EPA NPDES Acute Test Conditions-Static Renewal Whole Effluent Toxicity*”. The Permittee shall conduct an acute 48-hour static renewal toxicity test using *Ceriodaphnia dubia* and an acute 96-hour static renewal toxicity test using fathead minnows (*Pimephales promelas*) as the alternating species. The control of pH in the toxicity test utilizing CO<sub>2</sub> enriched atmospheres is allowed to prevent rising pH drift. The target pH selected must represent the pH value of the receiving water at the time of sample collection.

Acute toxicity occurs when 50 percent or more mortality is observed for either species at any effluent concentration. If more than 10 percent control mortality occurs, the test is considered invalid and shall be repeated until satisfactory control survival is achieved, unless a specific individual exception is granted by the Department. This exception may be granted if less than 10 percent mortality was observed at the dilutions containing high effluent concentrations.

If acute toxicity occurs in a routine test, an additional test (resample) shall be conducted within 14 days of the date of notification of the test failure. Should acute toxicity occur in the resample test, testing shall occur once a month until further notified by the Department. In all cases, the results of all toxicity tests must be submitted to the Department in accordance with Part II of this permit.

The quarterly results from the laboratory shall be reported along with the DMR form submitted for the end of the reporting calendar quarter (e.g., whole effluent testing results for the reporting quarter ending March 31 shall be reported with the March DMR due April 28<sup>th</sup> with the remaining quarterly reports submitted with the June, September, and December DMR). The format for the laboratory report shall be consistent with the latest revision of Region VIII Guidance for Acute Whole Effluent Reporting, and shall include all chemical and physical data as specified.

If the results for four consecutive quarters of testing indicate no acute toxicity, the Permittee may request a reduction to quarterly acute toxicity testing on only one species on an alternating basis. The Department may approve or deny the request based on the results and other available information without an additional public notice. If the request is approved, the test procedures are to be the same as specified above for the test species.

D. Special Conditions

1. Sewage Sludge:

The use or disposal of sewage sludge must be in conformance with the Environmental Protection Agency (EPA) General Permit MTG650000 or an equivalent permit issued pursuant to 40 CFR 503. A notice of intent must be filed with the EPA and the Department in accordance with the timeframes and procedures identified in the applicable permit. All materials required by the General Permit to be submitted to the Department shall be signed in accordance with Part IV.G and sent to the address provided in Part II.D of this permit.

The Permittee shall not dispose of sewage sludge such that any portion thereof enters any state water, including ground water. The Permittee shall notify the Department in writing 45 days prior to any change in sludge management at the facility.

2. Toxicity Identification Evaluation / Toxicity Reduction Evaluation: (TIE/TRE):

Should acute toxicity be detected in the required WET resample, a TIE/TRE shall be undertaken by the Permittee to establish the cause of the toxicity, locate the source(s) of the toxicity, and develop control or treatment for the toxicity. Failure to initiate or conduct an adequate TIE/TRE, or delays in the conduct of such tests, shall not be considered a justification for noncompliance with any whole effluent toxicity limitations contained in Part I.B of this permit. A TRE plan shall be submitted to the Department within 45 days after confirmation of the continuance of effluent toxicity (resample).

3. Compliance Schedule

A. Water Quality-based Final Effluent Limits

Final effluent limits for *E. coli* bacteria, Total Residual Chlorine, and total ammonia as N will be effective starting December 1, 2014.

Final effluent limits for total recoverable arsenic and total recoverable copper will be effective starting November 1, 2015.

*Schedule:* An annual report shall be submitted by January 28<sup>th</sup> of each year, starting with the first calendar year of the permit modification (2014) and lasting for the duration of this Special Condition. The reports shall describe the milestones accomplished and the steps planned towards compliance with the final effluent limits.

B. Facility Flow Monitoring

Accurate continuous influent and effluent flow measurement capabilities are required for compliance monitoring purposes. The 2010 renewal required Great Falls to install continuous flow measuring systems that has the capability of routine flow verification by the Permittee or appropriate regulatory authority by December 1, 2015.

Great Falls proposed influent and effluent monitoring strategies in the flow monitoring plan submitted to DEQ on November 30, 2012. DEQ agreed with the recommended flow monitoring strategies in a letter to Great Falls dated January 2, 2013, and has adjusted the monitoring table to reflect that the acceptable strategy will be considered “calculated.” Any actions undertaken to meet the requirements of this Special Condition must be completed by midnight on November 30, 2015.

*Schedule:* An annual report shall be submitted by January 28<sup>th</sup> of each year, starting in January 2014 and lasting for the duration of this Special Condition. The reports shall describe the milestones accomplished and the steps planned for each year.

E. Pretreatment Requirements:

1. Industrial Pretreatment Program - Contributing Industries and Pretreatment Requirements

- a. The Permittee shall operate an Industrial Pretreatment Program in accordance with the following permit requirements developed pursuant to Section 402(b)(8) of the federal Clean Water Act, the General Pretreatment Regulations (40 CFR Part 403), and the approved pretreatment program submitted by the Permittee. The pretreatment program was approved on December 23, 1985 and has subsequently incorporated substantial modifications as approved by the Approval Authority. The approved pretreatment program, and any approved modifications thereto, is hereby incorporated by reference and shall be implemented in a manner consistent with the following requirements:
  - i. Industrial user information shall be updated at a minimum of once per year or at that frequency necessary to ensure that all Industrial Users are properly permitted and/or controlled. The records shall be maintained and updated as necessary;
  - ii. The Permittee shall sample and inspect each Significant Industrial User (SIU) at least once per calendar year [40 CFR Section 403.8(f)(2)(v)]. This is in addition to any industrial self-monitoring activities. If the Permittee performs sampling for any SIU, then the Permittee shall perform any repeat sampling and analysis within 30 days of becoming aware of any violation [40 CFR Section 403.12(g)(2)];

- iii. The Permittee shall evaluate whether each SIU needs a plan to control Slug Discharges. SIUs must be evaluated within one (1) year of being designated as an SIU. Where needed, the Permittee shall require the SIU to prepare or update, and then implement the plan. Where a slug prevention plan is required, the Permittee shall ensure that the plan contains at least the minimum elements required in 40 CFR Section 403.8(f)(2)(vi). If required, the Permittee shall incorporate slug control requirements into the control mechanism for the SIU. [40 CFR, Section 403.8(f)(1)(iii)(B)(6)];
- iv. The Permittee shall investigate instances of non-compliance with Pretreatment Standards and requirements indicated in reports and notices required under 40 CFR Section 403.12, or indicated by analysis, inspection, and/or surveillance activities.
- v. The Permittee shall enforce all applicable Pretreatment Standards and requirements and obtain remedies for noncompliance by any industrial user;
- vi. The Permittee shall control, through the legal authority in the approved pretreatment program, the contribution to the Publicly Owned Treatment Works (POTW) by each industrial user to ensure compliance with applicable Pretreatment Standards and requirements. In the case of industrial users identified as significant under 40 CFR Section 403.3(v), this control shall be achieved through permit, order, or similar means and shall contain, at a minimum, the following conditions:
  - (A) Statement of duration [in no case more than five (5) years];
  - (B) Statement of non-transferability without, at a minimum, prior notification to the Permittee and provision of a copy of the existing control mechanism to the new owner or operator;
  - (C) Effluent limits, including Best Management Practices, based on applicable Pretreatment Standards, Categorical Pretreatment Standards, local limits, and State and local law;
  - (D) Self-monitoring, sampling, reporting, notification and record keeping requirements, including an identification of the pollutants to be monitored, sampling location, sampling frequency, and sample type, including documentation on BMP compliance, based on the applicable Pretreatment Standards in 40 CFR Part 403, Categorical Pretreatment Standards, local limits, and State and local law; and,
  - (E) Statement of applicable civil and criminal penalties for violation of Pretreatment Standards and requirements, and any applicable compliance schedule. Such schedules may not extend the compliance date beyond deadlines mandated by federal statute or regulation.

- (F) Requirements to control Slug Discharges, if determined by the POTW to be necessary.
- vii. The Permittee shall provide adequate staff, equipment, and support capabilities to carry out all elements of the pretreatment program as required by 40 CFR Section 403.8(f)(3);
  - viii. The approved program shall not be substantially modified by the Permittee without the approval of the EPA. Substantial and non-substantial modifications shall follow the procedures outlined in 40 CFR Section 403.18;
  - ix. The Permittee shall develop, implement, and maintain an enforcement response plan as required by 40 CFR Section 403.8(f)(5); and
  - x. The Permittee shall notify all Industrial Users of the users' obligations to comply with applicable requirements under Subtitles C and D of the Resource Conservation and Recovery Act (RCRA) as required by 40 CFR Section 403.8(f)(2)(iii).
- b. The Permittee shall establish and enforce specific local limits to implement the provisions of 40 CFR Section 403.5(a) and (b), as required by 40 CFR Section 403.5(c). The Permittee shall continue to develop these limits as necessary and effectively enforce such limits.

In accordance with EPA policy and with the requirements of 40 CFR sections 403.8(f)(4) and 403.5(c), the Permittee shall determine if technically based local limits are necessary to implement the general and specific prohibitions of 40 CFR sections 403.5(a) and (b). This evaluation should be conducted in accordance with the latest revision of the "*EPA Region VIII Strategy for Developing Technically Based Local Limits*", and after review of EPA's "*Local Limits Development Guidance*" July 2004. Where the Permittee determines that revised or new local limits are necessary, the Permittee shall submit the proposed local limits to the Approval Authority in an approvable form in accordance with 40 CFR Section 403.18.

- c. The Permittee shall analyze the treatment facility influent and effluent for the presence of the toxic pollutants listed in 40 CFR Part 122 Appendix D (NPDES Application Testing Requirements) Table II at least two (2) times per year as delineated in Part I.C. of this Permit and the toxic pollutants in Table III in 40 CFR Part 122 Appendix D at least once per quarter as delineated in Part I.C. of this Permit.

Bromodichloromethane, chloroform, 1,2-dichloroethane, and toluene have been identified as pollutants present in the effluent by sampling and analysis of the Facility influent, effluent and/or sludge during adherence to sampling requirements in the Permittee's Industrial Pretreatment Program. These

parameters shall be sampled and analyzed in the influent and effluent at least once per quarter. These data will be reported on the Facility DMR.

- i. Where the pollutants monitored in accordance with this section are reported as being above the method detection limit, the results for these pollutants shall be reported in the Permittee's pretreatment annual report.

In addition, allyl chloride, methacrylonitrile, and tetrahydrofuran have been identified as pollutants present in the effluent by sampling and analysis of the Facility influent, effluent and/or sludge and/or sludge during adherence to sampling requirements in the Permittee's Industrial Pretreatment Program. These parameters shall be sampled and analyzed in the influent and effluent at least once per year. These data will be reported on the Facility DMR.

- d. The Permittee shall analyze the treatment facility sludge (biosolids) prior to disposal, for the presence of toxic pollutants listed in 40 CFR 122 Appendix D (NPDES Application Testing Requirements) Table III at least once per year. If the Permittee does not dispose of biosolids during the calendar year, the Permittee shall certify to that in the Pretreatment Annual Report and the monitoring requirements in this paragraph shall be suspended for that calendar year.
  - i. The Permittee shall review the pollutants in 40 CFR Part 122, Appendix D, Tables II and V. If any of the pollutants in these tables were above detection in the influent samples during the previous two (2) years or the last two (2) analyses, whichever is greater, the Permittee shall sample and analyze its sewage sludge for these pollutants. The Permittee shall perform this evaluation and analysis at least once per year.
  - ii. The Permittee shall use sample collection and analysis procedures as approved for use under 40 CFR Part 503 or specified in the EPA Region 8 General Permit for biosolids.
  - iii. The Permittee shall report the results for these pollutants in the Permittee's pretreatment annual report, if required by EPA.
- e. All analyses shall be in accordance with test procedures established in 40 CFR Part 136. Where sampling methods are not specified, the influent and effluent samples collected shall be composite samples consisting of at least twelve (12) aliquots collected at approximately equal intervals over a representative 24-hour period and composited according to flow. Where automated composite sampling is inappropriate, at least four (4) grab samples shall be manually taken at equal intervals over a representative 24-hour period, and composited prior to analysis using approved methods; alternatively, the individual grab samples may be analyzed separately and the results from the respective grab samples mathematically combined based on flow (i.e., flow weighted) for the final result.

- f. The Permittee shall prepare annually a list of industrial users, which during the preceding twelve (12) months have significantly violated Pretreatment Standards or requirements. This list is to be published annually in a newspaper of general circulation in the Permittee's service area as required by 40 CFR Section 403.8(f)(2)(viii).

In addition, on or before March 28<sup>th</sup> of each year, the Permittee shall submit a pretreatment program annual report to the Approval Authority and the state permitting authority that contains the information requested by EPA or, at a minimum, the following information:

- i. An updated list of all SIUs as defined at 40 CFR 403.3(v). For each SIU listed the following information shall be included:
- (A) All applicable Standard Industrial Classification (SIC) codes and categorical determinations, as appropriate. In addition, a brief description of the industry and general activities;
  - (B) Permit status. Whether each SIU has an unexpired control mechanism and an explanation as to why any SIUs are operating without a current, unexpired control mechanism (e.g. permit);
  - (C) A summary of all monitoring activities performed within the previous twelve (12) months. The following information shall be reported:
    - Total number of SIUs inspected; and
    - Total number of SIUs sampled.
- ii. For all industrial users that were in Significant Non-Compliance during the previous twelve (12) months, provide the name of the violating industrial user; indicate the nature of the violations, the type and number of actions taken (administrative order, criminal or civil suit, fines or penalties collected, etc.) and current compliance status. Indicate if the company returned to compliance and the date compliance was attained. Determination of Significant Non-Compliance shall be performed as defined at 40 CFR Section 403.8(f)(2)(viii)(A-H).
- iii. A summary of all enforcement actions not covered by the paragraph above conducted in accordance with the approved Enforcement Response Plan, as required in 40 CFR, Section 403.8(f)(5).
- iv. A list of all SIUs whose authorization to discharge was terminated or revoked during the preceding twelve (12) month period and the reason for termination;

- v. A report on any Interference, Pass Through, upset or NPDES permit violations known or suspected to be caused by non-domestic discharges of pollutant and actions taken by the Permittee in response;
  - vi. Verification of publication of industrial users in Significant Non-Compliance;
  - vii. Identification of the specific locations, if any, designated by the Permittee for receipt (discharge) of trucked or hauled waste, if modified;
  - viii. Information as required by the Approval Authority or state permitting authority on the discharge to the POTW from the following activities:
    - (A) Ground water clean-up from underground storage tanks;
    - (B) Trucked or hauled waste; and,
    - (C) Groundwater clean-up from RCRA or Superfund sites.
  - ix. A description of all changes made during the previous calendar year to the Permittee's pretreatment program that were not submitted as substantial or non-substantial modifications to EPA.
  - x. The Permittee shall evaluate actual pollutants loadings against the approved Maximum Allowable Headworks Loadings (MAHLs). Where the actual loading exceeds the MAHL, the Permittee shall immediately begin a program to either revise the existing local limit and/or undertake such other studies as necessary to evaluate the cause(s) of the exceedence. The Permittee shall provide a summary of its intended action.
  - xi. Other information that may be deemed necessary by the Approval Authority.
- g. The Permittee shall prohibit the introduction of the following pollutants into the POTW:
- i. Pollutants which create a fire or explosion hazard in the publicly owned treatment works (POTW), including, but not limited to, waste streams with a closed cup flashpoint of less than sixty (60) degrees Centigrade (140 degrees Fahrenheit) using the test methods specified in 40 CFR Section 261.21;
  - ii. Pollutants which will cause corrosive structural damage to the POTW, but in no case discharges with pH lower than 5.0, unless the works are specifically designed to accommodate such discharges;
  - iii. Solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW, or other interference with the operation of the POTW;

- iv. Any pollutant, including oxygen demanding pollutants (e.g., BOD), released in a discharge at a flow rate and/or pollutant concentration which will cause Interference with the POTW;
  - v. Heat in amounts which will inhibit biological activity in the POTW resulting in Interference but in no case heat in such quantities that the temperature at the POTW treatment plant exceeds forty (40) degrees Centigrade (104 degrees Fahrenheit) unless the Approval Authority, upon request of the POTW, approves alternate temperature limits;
  - vi. Petroleum oil, non-biodegradable cutting oil, or products of mineral oil origin in amounts that will cause Interference or Pass Through;
  - vii. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems;
  - viii. Any trucked or hauled pollutants, except at discharge points designated by the POTW; and,
  - ix. Any specific pollutant that exceeds a local limitation established by the POTW in accordance with the requirements of 40 CFR Section 403.5(c) and (d).
  - x. Any other pollutant which may cause Pass Through or Interference.
- h. The Permittee shall provide the pretreatment Approval Authority with adequate notice of any substantial change in the volume or character of pollutants being introduced into the treatment works by any SIU introducing pollutants into the treatment works at the time of application for the discharge permit. For the purposes of this section, "substantial change" shall mean a level of change which has a reasonable probability of affecting the Permittee's ability to comply with its permit conditions or to cause a violation of stream standards applied to the receiving water.

Adequate notice shall include information on: (1) the quality and quantity of effluent to be introduced into the treatment works, and (2) any anticipated impact of the change on the quality or quantity of effluent to be discharged from the publicly owned treatment works.

- i. Section 309(f) of the Federal Clean Water Act provides that EPA may issue a notice to the POTW stating that a determination has been made that appropriate enforcement action must be taken against an industrial user for noncompliance with any Pretreatment Standards and requirements. The notice provides the POTW with thirty (30) days to commence such action. The issuance of such permit notice shall not be construed to limit the authority of the permit issuing authority or Approval Authority.

- j. The state permitting authority and/or the EPA retains, at all times, the right to take legal action against the industrial contributor for violations of a permit issued by the Permittee, violations of any Pretreatment Standard or requirement, or for failure to discharge at an acceptable level under national standards issued by EPA under 40 CFR, chapter I, subchapter N. In those cases where a MPDES permit violation has occurred because of the failure of the Permittee to properly develop and enforce Pretreatment Standards and requirements as necessary to protect the POTW, the state permitting authority and/or Approval Authority shall hold the Permittee responsible and may take legal action against the Permittee as well as the Indirect Discharger(s) contributing to the permit violation.

## II. MONITORING, RECORDING AND REPORTING REQUIREMENTS

### A. Representative Sampling

Samples taken in compliance with the monitoring requirements established under Part I of the permit shall be collected from the effluent stream prior to discharge into the receiving waters. Samples and measurements shall be representative of the volume and nature of the monitored discharge. Sludge samples shall be collected at a location representative of the quality of sludge immediately prior to use-disposal practice.

### B. Monitoring Procedures

Monitoring must be conducted according to test procedures approved under Part 136, Title 40 of the Code of Federal Regulations, unless other test procedures have been specified in this permit. See Part I.C of this permit for any applicable sludge monitoring procedures. All flow-measuring and flow-recording devices used in obtaining data submitted in self-monitoring reports must indicate values within 10 percent of the actual flow being measured.

### C. Penalties for Tampering

The Montana Water Quality Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate, any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$25,000, or by imprisonment for not more than six months, or by both.

### D. Reporting of Monitoring Results

Effluent monitoring results obtained during the previous month(s) shall be summarized for each month and reported on a Discharge Monitoring Report Form (EPA No. 3320-1), postmarked no later than the 28th day of the month following the completed reporting period. Whole effluent toxicity testing (biomonitoring) results must be reported with copies of the laboratory analysis report on forms from the most recent version of EPA Region VIII's "Guidance for Whole Effluent Reporting." If no discharge occurs during the reporting period, "no discharge" shall be reported on the report form. Legible copies of these, and all other reports required herein, shall be signed and certified in accordance with the "Signatory Requirements" (see Part IV.G of this permit), and submitted to the Department at the following addresses:

a) Montana Department of  
Environmental Quality  
Water Protection Bureau  
PO Box 200901  
Helena, Montana 59620-0901  
Phone: (406) 444-3080

(b) EPA Region 8, Montana Office  
Baucus Federal Building  
10 West 15th St.  
Suite 3200  
Helena, MT 59626  
Phone: (406) 457-5025

E. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on interim and final requirements contained in any Compliance Schedule of this permit shall be submitted no later than 14 days following each schedule date.

F. Additional Monitoring by the Permittee

If the Permittee monitors any pollutant more frequently than required by this permit, using approved analytical methods as specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the Discharge Monitoring Report. Such increased frequency shall also be indicated.

G. Records Contents

Records of monitoring information shall include:

1. The date, exact place, and time of sampling or measurements;
2. The initials or name(s) of the individual(s) who performed the sampling or measurements;
3. The date(s) analyses were performed;
4. The time analyses were initiated;
5. The initials or name(s) of individual(s) who performed the analyses;
6. References and written procedures, when available, for the analytical techniques or methods used; and
7. The results of such analyses, including the bench sheets, instrument readouts, computer disks or tapes, etc., used to determine these results.

H. Retention of Records

The Permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least three years from the date of the sample, measurement, report or application. This period may be extended by request of the Department at any time. Data collected on site, copies of Discharge Monitoring Reports, and a copy of this MPDES permit must be maintained on site during the duration of activity at the permitted location.

I. Twenty-four Hour Notice of Noncompliance Reporting

1. The Permittee shall report any serious incidents of noncompliance affecting the environment as soon as possible, but no later than twenty-four (24) hours from the time the Permittee first became aware of the circumstances. The report shall be made to the Water Protection Bureau at (406) 444-3080 or the Office of Disaster and Emergency Services at (406) 324-4777. The following examples are considered serious incidents:
  - a. Any noncompliance which may seriously endanger health or the environment;
  - b. Any unanticipated bypass which exceeds any effluent limitation in the permit (See Part III.G of this permit, "Bypass of Treatment Facilities");
  - c. Any upset which exceeds any effluent limitation in the permit (See Part III.H of this permit, "Upset Conditions").
2. A written submission shall also be provided within five days of the time that the Permittee becomes aware of the circumstances. The written submission shall contain:
  - a. A description of the noncompliance and its cause;
  - b. The period of noncompliance, including exact dates and times;
  - c. The estimated time noncompliance is expected to continue if it has not been corrected; and
  - d. Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
3. The Department may waive the written report on a case-by-case basis if the oral report has been received within 24 hours by the Water Protection Bureau, by phone, at (406) 444-3080.
4. Reports shall be submitted to the addresses in Part II.D of this permit, "Reporting of Monitoring Results".

J. Other Noncompliance Reporting

Instances of noncompliance not required to be reported within 24 hours shall be reported at the time that monitoring reports for Part II.D of this permit are submitted. The reports shall contain the information listed in Part II.I.2 of this permit.

K. Inspection and Entry

The Permittee shall allow the head of the Department or the Director, or an authorized representative thereof, upon the presentation of credentials and other documents as may be required by law, to:

1. Enter upon the Permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
3. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
4. Sample or monitor at reasonable times, for the purpose of assuring permit compliance, any substances or parameters at any location.

### III. COMPLIANCE RESPONSIBILITIES

A. Duty to Comply

The Permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. The Permittee shall give the Department and the Regional Administrator advance notice of any planned changes at the permitted facility or of an activity which may result in permit noncompliance.

B. Penalties for Violations of Permit Conditions

The Montana Water Quality Act provides that any person who violates a permit condition of the Act is subject to civil or criminal penalties not to exceed \$25,000 per day or one year in prison, or both, for the first conviction, and \$50,000 per day of violation or by imprisonment for not more than two years, or both, for subsequent convictions. MCA 75-5-611(a) also provides for administrative penalties not to exceed \$10,000 for each day of violation and up to a maximum not to exceed \$100,000 for any related series of violations. Except as provided in permit conditions on Part III.G of this permit, "Bypass of Treatment Facilities" and Part III.H of this permit, "Upset Conditions", nothing in this permit shall be construed to relieve the Permittee of the civil or criminal penalties for noncompliance.

C. Need to Halt or Reduce Activity not a Defense

It shall not be a defense for a Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

D. Duty to Mitigate

The Permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

E. Proper Operation and Maintenance

The Permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a Permittee only when the operation is necessary to achieve compliance with the conditions of the permit. However, the Permittee shall operate, as a minimum, one complete set of each main line unit treatment process whether or not this process is needed to achieve permit effluent compliance.

F. Removed Substances

Collected screenings, grit, solids, sludges, or other pollutants removed in the course of treatment shall be disposed of in such a manner so as to prevent any pollutant from entering any waters of the state or creating a health hazard. Sludge shall not be directly blended with or enter the final plant discharge and/or waters of the United States.

G. Bypass of Treatment Facilities

1. Bypass not exceeding limitations. The Permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Parts III.G.2 and III.G.3 of this permit.
2. Notice:
  - a. Anticipated bypass. If the Permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least 60 days before the date of the bypass.
  - b. Unanticipated bypass. The Permittee shall submit notice of an unanticipated bypass as required under Part II.I of this permit, "Twenty-four Hour Reporting".
3. Prohibition of bypass:
  - a. Bypass is prohibited and the Department may take enforcement action against a Permittee for a bypass, unless:
    - 1) The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
    - 2) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
    - 3) The Permittee submitted notices as required under Part III.G.2 of this permit.

- b. The Department may approve an anticipated bypass, after considering its adverse effects, if the Department determines that it will meet the three conditions listed above in Part III.G.3.a of this permit.

H. Upset Conditions

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with technology based permit effluent limitations if the requirements of Part III.H.2 of this permit are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review (i.e., Permittees will have the opportunity for a judicial determination on any claim of upset only in an enforcement action brought for noncompliance with technology-based permit effluent limitations).
2. Conditions necessary for a demonstration of upset. A Permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - a. An upset occurred and that the Permittee can identify the cause(s) of the upset;
  - b. The permitted facility was at the time being properly operated;
  - c. The Permittee submitted notice of the upset as required under Part II.I of this permit, "Twenty-four Hour Notice of Noncompliance Reporting"; and
  - d. The Permittee complied with any remedial measures required under Part III.D of this permit, "Duty to Mitigate".
3. Burden of proof. In any enforcement proceeding, the Permittee seeking to establish the occurrence of an upset has the burden of proof.

#### IV. GENERAL REQUIREMENTS

A. Planned Changes

The Permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:

1. The alteration or addition could significantly change the nature or increase the quantity of pollutant discharged. This notification applies to pollutants which are not subject to effluent limitations in the permit; or
2. There are any planned substantial changes to the existing sewage sludge management practices of storage and disposal. The Permittee shall give the Department notice of any planned changes at least 180 days prior to their implementation.

B. Anticipated Noncompliance

The Permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

C. Permit Actions

This permit may be revoked, modified and reissued, or terminated for cause. The filing of a request by the Permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

D. Duty to Reapply

If the Permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the Permittee must apply for and obtain a new permit. The application must be submitted at least 180 days before the expiration date of this permit.

E. Duty to Provide Information

The Permittee shall furnish to the Department, within a reasonable time, any information which the Department may request to determine whether cause exists for revoking, modifying and reissuing, or terminating this permit, or to determine compliance with this permit. The Permittee shall also furnish to the Department, upon request, copies of records required to be kept by this permit.

F. Other Information

When the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or any report to the Department, it shall promptly submit such facts or information with a narrative explanation of the circumstances of the omission or incorrect submittal and why they weren't supplied earlier.

G. Signatory Requirements

All applications, reports or information submitted to the Department shall be signed and certified.

1. All permit applications shall be signed by either a principal executive officer or ranking elected official.
2. All reports required by the permit and other information requested by the Department shall be signed by a person described above or by a duly authorized representative of that person. A person is considered a duly authorized representative only if:
  - a. The authorization is made in writing by a person described above and submitted to the Department; and
  - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters. (A duly authorized representative may thus be either a named individual or an individual occupying a named position.)
3. Changes to authorization. If an authorization under Part IV.G.2 of this permit is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Part IV.G.2 of this permit must be submitted to the Department prior to or together with any reports, information, or applications to be signed by an authorized representative.
4. Certification. Any person signing a document under this section shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

- H. Penalties for Falsification of Reports  
The Montana Water Quality Act provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction be punished by a fine of not more than \$25,000 per violation, or by imprisonment for not more than six months per violation, or by both.
- I. Availability of Reports  
Except for data determined to be confidential under 40 CFR Part 2, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Department and the EPA. As required by the Clean Water Act, permit applications, permits and effluent data shall not be considered confidential.
- J. Oil and Hazardous Substance Liability  
Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the Permittee from any responsibilities, liabilities, or penalties to which the Permittee is or may be subject under Section 311 of the Clean Water Act.
- K. Property or Water Rights  
The issuance of this permit does not convey any property or water rights of any sort, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.
- L. Severability  
The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.
- M. Transfers  
This permit may be automatically transferred to a new Permittee if:
1. The current Permittee notifies the Department at least 30 days in advance of the proposed transfer date;
  2. The notice includes a written agreement between the existing and new Permittees containing a specific date for transfer of permit responsibility, coverage, and liability between them;
  3. The Department does not notify the existing Permittee and the proposed new Permittee of an intent to revoke or modify and reissue the permit. If this notice is not received, the transfer is effective on the date specified in the agreement mentioned in Part IV.M.2 of this permit; and
  4. Required annual and application fees have been paid.

N. Fees

The Permittee is required to submit payment of an annual fee as set forth in ARM 17.30.201. If the Permittee fails to pay the annual fee within 90 days after the due date for the payment, the Department may:

1. Impose an additional fee assessment plus interest computed at the rate established under ARM 17.30.201, or
2. Suspend the processing of the application for a permit or authorization or, if the nonpayment involves an annual permit fee, suspend the permit, certificate or authorization for which the fee is required. The Department may lift suspension at any time up to one year after the suspension occurs if the holder has paid all outstanding fees, including all penalties, assessments and interest imposed under this sub-section. Suspensions are limited to one year, after which the permit will be terminated.

O. Reopener Provisions

This permit may be reopened and modified (following proper administrative procedures) to include the appropriate effluent limitations (and compliance schedule, if necessary), or other appropriate requirements if one or more of the following events occurs:

1. Water Quality Standards: The water quality standards of the receiving water(s) to which the Permittee discharges are modified in such a manner as to require different effluent limits than contained in this permit.
2. Water Quality Standards are Exceeded: If it is found that water quality standards or trigger values in the receiving stream are exceeded either for parameters included in the permit or others, the department may modify the effluent limits or water management plan.
3. TMDL or Wasteload Allocation: TMDL requirements or a wasteload allocation is developed and approved by the Department and/or EPA for incorporation in this permit.
4. Water Quality Management Plan: A revision to the current water quality management plan is approved and adopted which calls for different effluent limitations than contained in this permit.
5. Sewage Sludge: There have been substantial changes (or such changes are planned) in sludge use or disposal practices; applicable management practices or numerical limitations for pollutants in sludge have been promulgated which are more stringent than the requirements in this permit; and/or it has been determined that the Permittee's sludge use or disposal practices do not comply with existing applicable state or federal regulations.

6. Toxic Pollutants: A toxic standard or prohibition is established under Section 307(a) of the Clean Water Act for a toxic pollutant which is present in the discharge and such standard or prohibition is more stringent than any limitation for such pollutant in this permit.
  
7. Toxicity Limitations: Change in the whole effluent protocol, or any other conditions related to the control of toxicants have taken place, or if one or more of the following events have occurred:
  - a. Toxicity was detected late in the life of the permit near or past the deadline for compliance.
  - b. The TRE/TIE results indicated that compliance with the toxic limitations will require an implementation schedule past the date of expiration.
  - c. The TRE/TIE results indicated that the toxicant(s) represent pollutant(s) that may be controlled with specific numerical limitations.
  - d. Following the implementation of numerical controls on toxicants, a modified whole effluent protocol is needed to compensate for those toxicants that are controlled numerically.
  - e. The TRE/TIE revealed other unique conditions or characteristics which, in the opinion of the Department, justify the incorporation of unanticipated special conditions in this permit.

V. DEFINITIONS

1. **“Act”** means the Montana Water Quality Act, Title 75, Chapter 5, MCA
2. **“Administrator”** means the administrator of the United States Environmental Protection Agency.
3. **“Acute Toxicity”** occurs when 50 percent or more mortality is observed for either species (See Part I.C of this permit) at any effluent concentration. Mortality in the control must simultaneously be 10 percent or less for the effluent results to be considered valid.
4. **“Annual Average Load”** means the arithmetic mean of all 30-day or monthly average loads reported during the calendar year for a monitored parameter.
5. **“Approval Authority”** means the EPA Regional Administrator.
6. **“Arithmetic Mean” or “Arithmetic Average”** for any set of related values means the summation of the individual values divided by the number of individual values.
7. **“Average Monthly Limitation”** means the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.
8. **“Average Weekly Limitation”** means the highest allowable average of daily discharges over a calendar week, calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.
9. **“BOD<sub>5</sub>”** means the five-day measure of pollutant parameter biochemical oxygen demand.
10. **“Bypass”** means the intentional diversion of waste streams from any portion of a treatment facility.
11. **“CBOD<sub>5</sub>”** means the five-day measure of pollutant parameter carbonaceous biochemical oxygen demand.
12. **“Composite Samples”** shall be flow proportioned. The composite sample shall, as a minimum, contain at least four (4) samples collected over the compositing period. Unless otherwise specified, the time between the collection of the first sample and the last sample shall not be less than six (6) hours nor more than 24 hours. Acceptable methods for preparation of composite samples are as follows:

- a. Constant time interval between samples, sample volume proportional to flow rate at time of sampling;
  - b. Constant time interval between samples, sample volume proportional to total flow (volume) since last sample. For the first sample, the flow rate at the time the sample was collected may be used;
  - c. Constant sample volume, time interval between samples proportional to flow (i.e. sample taken every "X" gallons of flow); and,
  - d. Continuous collection of sample, with sample collection rate proportional to flow rate.
13. **"Daily Discharge"** means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the average measurement of the pollutant over the day.
  14. **"Daily Maximum Limitation"** means the maximum allowable discharge of a pollutant during a calendar day. Expressed as units of mass, the daily discharge is cumulative mass discharged over the course of the day. Expressed as a concentration, it is the arithmetic average of all measurements taken that day.
  15. **"Department"** means the Montana Department of Environmental Quality (MDEQ). Established by 2-15-3501, MCA.
  16. **"Director"** means the Director of the Montana Department of Environmental Quality.
  17. **"Discharge"** means the injection, deposit, dumping, spilling, leaking, placing, or failing to remove any pollutant so that it or any constituent thereof may enter into state waters, including ground water.
  18. **"EPA"** means the United States Environmental Protection Agency.
  19. **"Federal Clean Water Act"** means the federal legislation at 33 USC 1251, *et seq.*
  20. **"Geometric Mean"** means the value obtained by taking the Nth root of the product of the measured values.
  21. **"Grab Sample"** means a sample which is taken from a waste stream on a one-time basis without consideration of flow rate of the effluent or without consideration for time.
  22. **"Indirect discharger"** means a non-domestic discharger introducing pollutants to a publicly owned treatment works.

23. **"Instantaneous Maximum Limitation"** means the maximum allowable concentration of a pollutant determined from the analysis of any discrete or composite sample collected, independent of the flow rate and the duration of the sampling event.
24. **"Instantaneous Measurement"**, for monitoring requirements, means a single reading, observation, or measurement.
25. **"Interference"** means a discharge which, alone or in conjunction with other contributing discharges
  - a. Inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and
  - b. Therefore causes a violation of any requirement of the POTW's MPDES permit (including an increase in the magnitude or duration of a violation) or causes the prevention of sewage sludge use or disposal in compliance with the following statutes and regulations: Section 405 of the Clean Water Act; 40 CFR Part 503 - Standards for the Use and Disposal of Sewage Sludge; Resource Conservation and Recovery Act (RCRA); 40 CFR Part 258 - Criteria for Municipal Solid Waste Landfills; and/or any State regulations regarding the disposal of sewage sludge.
26. **"Maximum Daily Discharge Limitation"** means the highest allowable daily discharge.
27. **"Minimum Level"** (ML) of quantitation means the lowest level at which the entire analytical system gives a recognizable signal and acceptable calibration point for the analyte, as determined by the procedure set forth at 40 CFR 136. In most cases the ML is equivalent to the Required Reporting Value (RRV) unless otherwise specified in the permit (ARM 17.30.702(22)).
28. **"Mixing Zone"** means a limited area of a surface water body or aquifer where initial dilution of a discharge takes place and where certain water quality standards may be exceeded.
29. **"Nondegradation"** means the prevention of a significant change in water quality that lowers the quality of high-quality water for one or more parameters. Also, the prohibition of any increase in discharge that exceeds the limits established under or determined from a permit or approval issued by the Department prior to April 29, 1993.
30. **"Pass Through"** means a discharge which exits the POTW into waters of the State of Montana in quantities or concentrations which, alone or in conjunction with other discharges, is a cause of a violation of any requirement of the POTW's MPDES permit (including an increase in the magnitude or duration of a violation).

31. **"POTW"** means a publicly owned treatment works.
32. **"Regional Administrator"** means the administrator of Region VIII of EPA, which has jurisdiction over federal water pollution control activities in the state of Montana.
33. **"Severe Property Damage"** means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
34. **"Sewage Sludge"** means any solid, semi-solid or liquid residue generated during the treatment of domestic sewage and/or a combination of domestic sewage and industrial waste of a liquid nature in a treatment works. Sewage sludge includes, but is not limited to, domestic septage; scum or solids removed in primary, secondary, or advanced wastewater treatment processes; and a material derived from sewage sludge. Sewage sludge does not include ash generated during the incineration of sewage sludge or grit and screenings generated during preliminary treatment of domestic sewage in a treatment works.
35. **"Slug Discharge"** means any discharge of a non-routine, episodic nature, including but not limited to an accidental spill or a non-customary batch discharge, which has a reasonable potential to cause Interference or Pass Through, or in any other way violate the POTW's regulations, local limits or Permit conditions.
36. **"TIE"** means a toxicity identification evaluation.
37. **"TMDL"** means the total maximum daily load limitation of a parameter, representing the estimated assimilative capacity for a water body before other designated uses are adversely affected. Mathematically, it is the sum of wasteload allocations for point sources, load allocations for non-point and natural background sources, and a margin of safety.
38. **"TRE"** means a toxicity reduction evaluation.
39. **"TSS"** means the pollutant parameter total suspended solids.
40. **"Upset"** means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.