



**PUBLIC NOTICE NO. MT-16-05**  
**March 28, 2016**

PURPOSE OF PUBLIC NOTICE

The purpose of this notice is to state the Department's intention to issue a wastewater discharge permit to the facility listed in this notice. This permit is issued by the Department under the authority of 75-5-402, Montana Code Annotated (MCA); the Administrative Rules of Montana (ARM) 17.30.1301 *et seq.*, Montana Pollutant Discharge Elimination System (MPDES); and Sections 402 and 303 of the Federal Clean Water Act. The Water Protection Bureau has prepared a draft permit for the facility listed below. Copies of the draft permit, fact sheet, and environmental assessment are available upon request from the Water Protection Bureau or on the Department's website [www.deq.mt.gov](http://www.deq.mt.gov)

APPLICANT: TA Operating, LLC

FACILITY NAME: Laurel Travel Center Wastewater Treatment Facility

FACILITY LOCATION: 11360 Interstate 90 Frontage Road

COUNTY: Yellowstone

RECEIVING WATER: Nutting Drain

PERMIT NUMBER: MT0031879

This is a new Montana Pollutant Discharge Elimination System (MPDES) permit for discharge of treated wastewater from the Laurel Travel Center Wastewater Treatment Facility (WWTF) to the Nutting Drain. A fact sheet is available for review and describes the rationale for the permit conditions. The applicant proposes to discharge from a membrane bio-reactor package plant, which will provide advanced wastewater treatment of domestic wastes generated by the travel center, restaurant and hotel. The average facility design flow is 0.018 million gallons per day (mgd) and effluent is discharged from Outfall 001 to the Nutting Drain. The proposed permit will include limits for 5-day biochemical oxygen demand (BOD<sub>5</sub>), total suspended solids (TSS), *E. coli*, oil and grease and pH, total nitrogen, total phosphorus, and nitrate plus nitrite. The proposed permit requires periodic self-monitoring of discharge quality and quantity with monthly reporting of results. Instream monitoring in the Nutting Drain to characterize the receiving water is also required. This permit and fact sheet will be submitted to the EPA for approval.

PUBLIC COMMENT

Public Notice No.: MT-16-05

March 28, 2016

Page 2 of 2

Public comments are invited ANYTIME PRIOR TO CLOSE OF BUSINESS April 26, 2016. Comments may be directed to the DEQ Permitting & Compliance Division, Water Protection Bureau, PO Box 200901, Helena, MT 59620. All comments received or postmarked PRIOR TO CLOSE OF BUSINESS April 26, 2016 will be considered in the formulation of final determinations to be imposed on the permits. If you wish to comment electronically, you may e-mail the Department at [DEQWPBPublicComments@mt.gov](mailto:DEQWPBPublicComments@mt.gov).

During the public comment period provided by the notice, the Department will accept requests for a public hearing. A request for a public hearing must be in writing and must state the nature of the issue proposed to be raised in the hearing (ARM 17.30.1373).

The Department will respond to all substantive comments and issue a final decision within sixty days of this notice or as soon as possible thereafter. Additional information may be obtained upon request by calling (406) 444-3080 or by writing to the aforementioned address. The complete administrative record, including permit application and other pertinent information, is maintained at the Water Protection Bureau office in Helena and is available for review during business hours.

**PUBLIC NOTICE NO. MT-16-05**

**March 28, 2016**